DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	248626
Document Title:	QUARTERLY OPERATING REPORT- Q4 2022
Description:	QUARTERLY OPERATING REPORT- Q4 2022
Filer:	Anwar Ali
Organization:	PG&E
Submitter Role:	Commission Staff
Submission Date:	1/31/2023 11:28:45 PM
Docketed Date:	2/1/2023

Pacific Gas and Electric Company®

Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS23-L-02

January 30, 2023

Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Electronically submitted to anwar.ali@energy.ca.gov

Dear Mr. Ali:

Attached is the Fourth Quarter 2022 Operating Report for the Colusa Generating Station.

The QOR includes the following attachments:

Attachment 1: Complaints

Attachment 2: Fuel Quality Data

Attachment 3: 40 CFR 60 Section KKKK Information

Attachment 4: Excess Emissions / Downtime Report / EDS / CMS Reports

Attachment 5: Hourly Emissions – VOC

Attachment 6: Hourly Emissions – NOx

Attachment 7: Hourly Emissions – CO

Attachment 8: Hourly Emissions – NH3

Attachment 9: Quarterly / Annual Emissions (Fuel Use, Hours of Operation, and NH3 Injection)

ATTACHMENT 1
Complaints

During the fourth quarter of 2022, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

2022 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22	Avg
Gr/100SCF	0.202	0.149	OUTAGE	0.285	0.486	0.118	0.180	0.110	0.145	0.183	0.229	0.164	0.205

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V #17)

Atmospheric Analysis & Consulting, Inc

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 222151
REPORT DATE : 10/26/2022

On October 13, 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Oct-A	222151-37208	680.9

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Environmental Services | **SAMPLING DATE : 10/12/2022**
PROJECT NO. : 222151 | **ANALYSIS DATE : 10/19-24/2022**

	Client ID:	CPP-GS-Oct-A			
	AAC ID:	222151-37208			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 2.25	2.25	< 0.002	0.002
	O_2	2.98	0.225	5.12	0.004
	N_2	12.4	0.225	18.7	0.003
	CO	< 0.225	0.225	< 0.003	0.003
	CO_2	0.603	0.225	1.42	0.005
	CH_4	80.8	0.00011	69.5	0.009
	He	NM	NM	NM	NM
	Ar	< 0.225	0.225	< 0.004	0.004
HYDROCARBONS	C_2 (as Ethane)	3.14	0.00056	5.07	0.0008
	C_3 (as Propane)	0.0510	0.00011	0.121	0.0002
	C_4 (as Butane)	0.00942	0.00011	0.0294	0.0003
	C_5 (as Pentane)	0.00274	0.00011	0.0106	0.0004
	C_6 (as Hexane)	0.00082	0.00011	0.0038	0.0005
	C_{6+} (as Hexane)	0.00303	0.00011	0.0140	0.0005
TRS	Total Reduced Sulfur	0.000288	0.0000022	0.000526	0.000004
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	17780
Carbon (C)	56.6	*LHV Btu/lb*	16025
Hydrogen (H)	18.5	*HHV Btu/dscf*	873
Oxygen (O)	6.2	*LHV Btu/dscf*	787
Nitrogen (N)	18.7	*F-Factor*	8653
Helium (He)	0.00	*Relative Density*	0.6436
Argon (Ar)	0.00	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	18.639
Motor Octane Number	131.79	*Methane Number*	94.93
		Wobbe Number	1088.531

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 222151
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 10/12/2022
ANALYSIS DATE : 10/14/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Oct-A
AAC ID	222151-37208
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.822**
COS / SO2	**1.01**
Methyl Mercaptan	< 0.112
Ethyl Mercaptan	< 0.112
Dimethyl Sulfide	< 0.112
Carbon Disulfide	< 0.112
Isopropyl Mercaptan	< 0.112
tert-Butyl Mercaptan	< 0.112
n-Propyl Mercaptan	< 0.112
Methylethylsulfide	< 0.112
sec-Butyl Mercaptan / Thiophene	< 0.112
iso-Butyl Mercaptan	< 0.112
Diethyl Sulfide	< 0.112
n-Butyl Mercaptan	< 0.112
Dimethyl Disulfide	< 0.112
2-Methylthiophene	< 0.112
3-Methylthiophene	< 0.112
Tetrahydrothiophene	**0.813**
Bromothiophene	< 0.112
Thiophenol	< 0.112
Diethyl Disulfide	< 0.112
Total Unidentified Sulfur	**1.37**
Total Reduced Sulfurs	**3.01**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 222151
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 10/12/2022
RECEIVING DATE : 10/13/2022
ANALYSIS DATE : 10/14/2022
REPORT DATE : 10/26/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Oct-A
AAC ID	222151-37208
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.0501**
COS / SO2	**0.0616**
Methyl Mercaptan	< 0.00685
Ethyl Mercaptan	< 0.00685
Dimethyl Sulfide	< 0.00685
Carbon Disulfide	< 0.00685
Isopropyl Mercaptan	< 0.00685
tert-Butyl Mercaptan	< 0.00685
n-Propyl Mercaptan	< 0.00685
Methylethylsulfide	< 0.00685
sec-Butyl Mercaptan / Thiophene	< 0.00685
iso-Butyl Mercaptan	< 0.00685
Diethyl Sulfide	< 0.00685
n-Butyl Mercaptan	< 0.00685
Dimethyl Disulfide	< 0.00685
2-Methylthiophene	< 0.00685
3-Methylthiophene	< 0.00685
Tetrahydrothiophene	**0.0495**
Bromothiophene	< 0.00685
Thiophenol	< 0.00685
Diethyl Disulfide	< 0.00685
Total Unidentified Sulfur	**0.0837**
Total Reduced Sulfurs	**0.183**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 10/19/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	9.9	10.1	23.0	10.7	9.6	10.2
	% Rec *	99.7	98.2	111.9	106.8	95.6	102.7

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	9.8	10.1	22.7	10.8	9.8	10.3
	LCSD Result	9.9	10.3	22.8	10.6	9.6	10.3
	LCS % Rec *	99.1	97.6	110.7	107.7	97.6	103.3
	LCSD % Rec *	99.6	99.7	111.0	106.6	95.9	103.4
	% RPD ***	0.5	2.2	0.3	1.0	1.7	0.1

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
222142-37178	Sample	0.0	0.4	4.6	31.4	0.0	21.4
	Sample Dup	0.0	0.4	4.5	31.1	0.0	21.3
	Mean	0.0	0.4	4.5	31.3	0.0	21.3
	% RPD ***	0.0	0.0	1.6	0.9	0.0	0.5

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
222142-37178	Sample Conc	0.0	2.3	15.6	0.0	10.7
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.2	13.1	26.4	9.7	21.2
	MSD Result	10.3	13.6	26.0	9.9	21.0
	MS % Rec **	102.5	107.4	107.3	97.4	105.2
	MSD % Rec **	104.4	111.9	104.1	99.3	103.9
	% RPD ***	1.8	4.2	3.0	1.9	1.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.1	9.9	22.0	10.9	9.7	10.5
	% Rec *	102.3	95.8	107.1	108.7	96.7	105.7

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 10/24/2022
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	94.8	94.9	93.4	95.4	97.2	99.6
	% Rec *	95.9	95.7	94.7	97.3	99.0	99.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	97.3	97.5	95.3	97.3	101.3	102.5
	LCSD Result	97.1	96.7	95.6	97.7	99.6	101.8
	LCS % Rec *	98.4	98.4	96.6	99.2	103.3	102.7
	LCSD % Rec *	98.2	97.5	96.8	99.6	101.5	102.1
	% RPD ***	0.2	0.8	0.2	0.4	1.8	0.6

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	49.6	49.2	47.9	49.1	50.8	51.5
	MSD Result	56.1	55.0	54.4	55.3	56.8	58.2
	MS % Rec **	100.4	99.2	97.1	100.1	103.4	103.2
	MSD % Rec **	113.5	111.0	110.3	112.7	115.8	116.8
	% RPD ***	12.2	11.2	12.8	11.8	11.3	12.3

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	96.3	96.3	94.7	97.4	101.6	105.2
	% Rec *	97.4	97.2	95.9	99.3	103.5	105.5

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 10/14/2022
Analyst: ZD
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

499.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1844	500	100.1	0.8
Duplicate	1860	505	101.0	0.1
Triplicate	1872	508	101.6	0.7

547.5 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2332	541	98.8	2.3
Duplicate	2410	559	102.1	0.9
Triplicate	2421	561	102.5	1.4

479.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2480	469	97.9	1.1
Duplicate	2559	484	101.0	2.0
Triplicate	2484	470	98.0	0.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 220521-28941

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 220521-28941

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	249.9	252.8	258.7	101.2	103.5	2.3
MeSH	<PQL	273.8	287.2	281.6	104.9	102.9	2.0
DMS	<PQL	239.5	240.0	242.9	100.2	101.4	1.2

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	499.8	537.0	107.5
MeSH	547.5	570.1	104.1
DMS	479.0	506.0	105.6

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

222151

Fuel Gas Sampling

Client: PG&E Colusa Generating Station				Project Manager: TJ Gomez			Date	Preparation and Analysis													
Address: 4780 Dirks Rd				Telephone Number: 53-393-2926	Email: AJGU@pge.com		Laboratory: AAC Labs														
City: Maxwell	State: CA	Zip: 95955		Site Contacat			Laboratory Phone: 805-650-1642														
Project Number/Name: Natural Gas Sampling				Sampler: TJ Gomez 530-393-2926			Laboratory Fax														
Contract Number, PO Number				Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003																	
PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504	BTU										
CPP-GS-Oct-A	37208	12-Oct-2022	0930	Gas	1 liter	cyl	1	None		X	X										

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: TJ Gomez	Date: 12-Oct-2022	Time: 1500 hrs	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 10/13/22	Time: 0857

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS

Internal

1x 1.4L can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E Colusa Generating Sampling
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 222338
REPORT DATE	: 11/21/2022

On November 8th 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canisters for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned unique Laboratory ID numbers as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Nov-A	222338-38028	752.3

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of these samples. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/18/2022

	Client ID:	CPP-GS-Nov-A			
	AAC ID:	222338-38028			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 1.47	1.47	< 0.002	0.002
	O_2	0.394	0.147	0.723	0.002
	N_2	2.23	0.147	3.58	0.002
	CO	< 0.147	0.147	< 0.002	0.002
	CO_2	0.779	0.147	1.97	0.003
	CH_4	91.0	0.00007	83.8	0.006
	He	NM	NM	NM	NM
	Ar	< 0.147	0.147	< 0.003	0.003
HYDROCARBONS	C_2 (as Ethane)	5.20	0.00037	8.96	0.0006
	C_3 (as Propane)	0.273	0.00007	0.690	0.0002
	C_4 (as Butane)	0.0655	0.00007	0.218	0.0002
	C_5 (as Pentane)	0.0133	0.00007	0.0551	0.0003
	C_6 (as Hexane)	0.00197	0.00007	0.0098	0.0003
	C_{6+} (as Hexane)	0.00350	0.00007	0.0173	0.0003
TRS	Total Reduced Sulfur	0.000375	0.0000015	0.000732	0.000003

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	22231
Carbon (C)	71.2	*LHV Btu/lb*	20043
Hydrogen (H)	23.0	*HHV Btu/dscf*	1021
Oxygen (O)	2.2	*LHV Btu/dscf*	921
Nitrogen (N)	3.6	*F-Factor*	8652
Helium (He)	0.00	*Relative Density*	0.6020
Argon (Ar)	0.00	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	17.435
Motor Octane Number	128.64	*Methane Number*	89.81
		Wobbe Number	1316.318

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/10/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-Nov-A**
AAC ID	**222338-38028**
Canister Dil. Fac.	**1.5**
Analyte	**Result**
Hydrogen Sulfide	**1.36**
COS / SO2	**0.463**
Methyl Mercaptan	**0.358**
Ethyl Mercaptan	**0.256**
Dimethyl Sulfide	< 0.074
Carbon Disulfide	< 0.074
Isopropyl Mercaptan	< 0.074
tert-Butyl Mercaptan	**1.08**
n-Propyl Mercaptan	< 0.074
Methylethylsulfide	< 0.074
sec-Butyl Mercaptan / Thiophene	< 0.074
iso-Butyl Mercaptan	< 0.074
Diethyl Sulfide	< 0.074
n-Butyl Mercaptan	< 0.074
Dimethyl Disulfide	< 0.074
2-Methylthiophene	< 0.074
3-Methylthiophene	< 0.074
Tetrahydrothiophene	**0.713**
Bromothiophene	< 0.074
Thiophenol	< 0.074
Diethyl Disulfide	< 0.074
Total Unidentified Sulfur	< 0.074
Total Reduced Sulfurs	**3.77**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/10/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Nov-A
AAC ID	222338-38028
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	**0.08267**
COS / SO2	**0.02819**
Methyl Mercaptan	**0.02181**
Ethyl Mercaptan	**0.01562**
Dimethyl Sulfide	< 0.00449
Carbon Disulfide	< 0.00449
Isopropyl Mercaptan	< 0.00449
tert-Butyl Mercaptan	**0.06607**
n-Propyl Mercaptan	< 0.00449
Methylethylsulfide	< 0.00449
sec-Butyl Mercaptan / Thiophene	< 0.00449
iso-Butyl Mercaptan	< 0.00449
Diethyl Sulfide	< 0.00449
n-Butyl Mercaptan	< 0.00449
Dimethyl Disulfide	< 0.00449
2-Methylthiophene	< 0.00449
3-Methylthiophene	< 0.00449
Tetrahydrothiophene	**0.04345**
Bromothiophene	< 0.00449
Thiophenol	< 0.00449
Diethyl Disulfide	< 0.00449
Total Unidentified Sulfur	< 0.00449
Total Reduced Sulfurs	**0.2296**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 11/18/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.1	10.7	23.0	10.7	9.5	10.0
	% Rec *	102.1	103.6	112.3	106.7	95.2	99.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	10.1	10.3	22.7	10.9	9.7	10.5
	LCSD Result	10.3	10.2	22.3	11.1	9.9	10.6
	LCS % Rec *	102.2	99.9	110.8	109.2	97.4	105.0
	LCSD % Rec *	104.4	98.7	108.8	111.3	99.1	106.4
	% RPD ***	2.2	1.2	1.8	1.9	1.8	1.3

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
222334-38014	Sample	0.0	13.5	53.8	0.0	0.0	0.0
	Sample Dup	0.0	13.3	53.3	0.0	0.0	0.0
	Mean	0.0	13.4	53.5	0.0	0.0	0.0
	% RPD ***	0.0	0.9	0.8	0.0	0.0	0.0

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
222334-38014	Sample Conc	0.0	26.8	0.0	0.0	0.0
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.5	38.6	11.0	9.8	10.6
	MSD Result	10.6	37.7	11.3	10.1	10.8
	MS % Rec **	105.7	116.8	110.2	98.0	106.0
	MSD % Rec **	107.2	107.6	112.7	100.5	108.3
	% RPD ***	1.4	8.2	2.3	2.5	2.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	9.9	10.6	23.6	10.3	9.2	9.9
	% Rec *	99.5	102.6	115.0	103.1	92.1	99.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 11/18/2022
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	106.2	105.4	104.3	107.2	109.2	110.6
	% Rec *	107.4	106.3	105.6	109.3	111.3	110.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	88.2	87.9	87.0	88.6	92.2	93.5
	LCSD Result	93.1	93.5	92.0	94.6	97.1	98.1
	LCS % Rec *	89.2	88.7	88.2	90.3	93.9	93.7
	LCSD % Rec *	94.1	94.3	93.3	96.5	98.9	98.3
	% RPD ***	5.4	6.1	5.6	6.6	5.2	4.8

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	48.7	48.0	47.2	47.8	49.1	49.5
	MSD Result	47.5	46.8	46.2	46.9	48.0	48.7
	MS % Rec **	98.6	96.9	95.6	97.5	100.2	99.2
	MSD % Rec **	96.2	94.5	93.5	95.6	97.8	97.7
	% RPD ***	2.5	2.5	2.2	1.9	2.4	1.5

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	95.2	93.8	92.1	94.9	97.8	101.1
	% Rec *	96.3	94.7	93.3	96.7	99.7	101.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 11/10/2022
Analyst: ZD
Units: ppmV

Instrument ID: SCD-BTU
Calb. Date: 10/21/2021

Opening Calibration Verification Standard

0.500 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1115	0.508	101.6	1.6
Duplicate	1075	0.489	97.9	2.1
Triplicate	1103	0.502	100.5	0.5

0.548 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1235	0.560	102.3	0.9
Duplicate	1218	0.553	100.9	0.5
Triplicate	1220	0.553	101.1	0.4

0.479 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1186	0.489	102.1	0.7
Duplicate	1135	0.468	97.7	3.6
Triplicate	1213	0.500	104.4	2.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 220521-28939

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.000	0.0
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate Sample ID x2

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	0.250	0.231	0.251	92.4	100.5	8.3
MeSH	<PQL	0.274	0.262	0.267	95.7	97.5	1.9
DMS	<PQL	0.240	0.238	0.251	99.4	104.8	5.3

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.500	0.502	102.9
MeSH	0.548	0.561	96.4
DMS	0.479	0.491	102.9

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

PQL = 50.0 ppbV
MDL = 1.1 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

222338

Fuel Gas Sampling

Client: PG&E Colusa Generating Station			Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd			Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA	Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:			Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504	Preparation and Analysis: BTU
CPP-GS-Nov-A	38028	7-Nov-2022	1000	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other _____	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	7-Nov-2022	1500 hrs	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	11/8/22	1015

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1 x 1.4L can

Atmospheric Analysis & Consulting, Inc

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 230002
REPORT DATE	: 01/12/2023

On January 2nd, 2023, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Dec-A	230002-39621	737.7

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. Sample was received past the recommended hold time of seven days for sulfur analysis. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 230002

SAMPLING DATE : 12/21/2023
ANALYSIS DATE : 01/09/2023

	Client ID:	CPP-GS-Dec-A			
	AAC ID:	230002-39621			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 1.52	1.52	< 0.001	0.001
	O_2	2.99	0.152	4.99	0.002
	N_2	13.3	0.152	19.4	0.002
	CO	< 0.152	0.152	< 0.002	0.002
	CO_2	0.698	0.152	1.60	0.003
	CH_4	77.4	0.00008	64.7	0.006
	He	NM	NM	NM	NM
	Ar	0.160	0.152	0.332	0.003
HYDROCARBONS	C_2 (as Ethane)	4.93	0.00038	7.72	0.0006
	C_3 (as Propane)	0.352	0.00008	0.809	0.0002
	C_4 (as Butane)	0.0870	0.00008	0.263	0.0002
	C_5 (as Pentane)	0.0206	0.00008	0.0775	0.0003
	C_6 (as Hexane)	0.00530	0.00008	0.0238	0.0003
	C_{6+} (as Hexane)	0.00711	0.00008	0.0319	0.0003
TRS	Total Reduced Sulfur	0.000177	0.0000015	0.000314	0.000002
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	17442
Carbon (C)	56.0	*LHV Btu/lb*	15726
Hydrogen (H)	18.0	*HHV Btu/dscf*	882
Oxygen (O)	6.2	*LHV Btu/dscf*	796
Nitrogen (N)	19.4	*F-Factor*	8672
Helium (He)	0.00	*Relative Density*	0.6629
Argon (Ar)	0.33	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	19.197
Motor Octane Number	127.31	*Methane Number*	87.66
		Wobbe Number	1083.682

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E
PROJECT NO. : 230002
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 12/21/2023
ANALYSIS DATE : 01/03/2023

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-Dec-A**
AAC ID	**230002-39621**
Canister Dil. Fac.	**1.5**
Analyte	**Result**
Hydrogen Sulfide	< 0.076
COS / SO2	**0.719**
Methyl Mercaptan	< 0.076
Ethyl Mercaptan	< 0.076
Dimethyl Sulfide	< 0.076
Carbon Disulfide	< 0.076
Isopropyl Mercaptan	< 0.076
tert-Butyl Mercaptan	**0.471**
n-Propyl Mercaptan	< 0.076
Methylethylsulfide	< 0.076
sec-Butyl Mercaptan / Thiophene	< 0.076
iso-Butyl Mercaptan	< 0.076
Diethyl Sulfide	< 0.076
n-Butyl Mercaptan	< 0.076
Dimethyl Disulfide	< 0.076
2-Methylthiophene	< 0.076
3-Methylthiophene	< 0.076
Tetrahydrothiophene	**1.15**
Bromothiophene	< 0.076
Thiophenol	< 0.076
Diethyl Disulfide	< 0.076
Total Unidentified Sulfur	**0.231**
Total Reduced Sulfurs	**1.86**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : **PG&E**
PROJECT NO. : **230002**
MATRIX : **AIR**
UNITS : **grains/100 dscf**

SAMPLING DATE : **12/21/2023**
ANALYSIS DATE : **01/03/2023**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Dec-A
AAC ID	230002-39621
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	< 0.00463
COS / SO2	**0.04381**
Methyl Mercaptan	< 0.00463
Ethyl Mercaptan	< 0.00463
Dimethyl Sulfide	< 0.00463
Carbon Disulfide	< 0.00463
Isopropyl Mercaptan	< 0.00463
tert-Butyl Mercaptan	**0.02869**
n-Propyl Mercaptan	< 0.00463
Methylethylsulfide	< 0.00463
sec-Butyl Mercaptan / Thiophene	< 0.00463
iso-Butyl Mercaptan	< 0.00463
Diethyl Sulfide	< 0.00463
n-Butyl Mercaptan	< 0.00463
Dimethyl Disulfide	< 0.00463
2-Methylthiophene	< 0.00463
3-Methylthiophene	< 0.00463
Tetrahydrothiophene	**0.07032**
Bromothiophene	< 0.00463
Thiophenol	< 0.00463
Diethyl Disulfide	< 0.00463
Total Unidentified Sulfur	**0.01405**
Total Reduced Sulfurs	**0.11305**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 01/09/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.0	10.3	23.0	10.8	9.7	10.4
	% Rec *	101.3	100.2	112.4	107.8	96.5	104.2

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	9.9	10.2	23.3	11.0	9.7	10.7
	LCSD Result	10.2	10.4	23.2	10.9	9.7	10.5
	LCS % Rec *	100.1	98.7	113.8	110.0	97.0	107.4
	LCSD % Rec *	103.1	100.5	113.3	108.9	97.2	105.6
	% RPD ***	2.9	1.8	0.5	1.0	0.2	1.7

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
230001-39603	Sample	0.0	7.3	45.8	0.0	0.0	2.6
	Sample Dup	0.0	7.3	45.4	0.0	0.0	2.5
	Mean	0.0	7.3	45.6	0.0	0.0	2.5
	% RPD ***	0.0	0.7	0.9	0.0	0.0	1.8

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
230001-39603	Sample Conc	0.0	22.8	0.0	0.0	1.3
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.0	34.9	10.6	9.6	11.5
	MSD Result	10.3	34.0	10.8	9.8	11.8
	MS % Rec **	101.3	119.6	105.7	95.9	102.9
	MSD % Rec **	103.8	110.6	108.6	97.5	105.9
	% RPD ***	2.4	7.8	2.7	1.7	2.9

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.4	10.0	22.1	11.0	9.9	10.6
	% Rec *	104.8	97.1	107.6	110.3	98.6	106.3

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 01/09/2023
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	91.3	91.0	89.8	90.9	91.3	91.3
	% Rec *	92.4	91.9	91.0	92.7	93.1	91.5

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	92.1	90.9	89.8	92.1	94.0	93.8
	LCSD Result	97.9	96.5	95.3	98.0	99.0	98.6
	LCS % Rec *	93.1	91.7	90.9	93.9	95.8	94.0
	LCSD % Rec *	99.0	97.3	96.6	99.9	100.9	98.9
	% RPD ***	6.1	5.9	6.0	6.1	5.2	5.1

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29436	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29436	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	50.2	48.6	48.2	49.3	50.6	51.9
	MSD Result	49.2	47.3	47.3	48.2	50.5	51.7
	MS % Rec **	101.5	98.1	97.6	100.6	103.1	104.0
	MSD % Rec **	99.5	95.3	95.9	98.2	102.9	103.7
	% RPD ***	2.0	2.8	1.7	2.4	0.2	0.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	102.5	100.3	99.2	102.1	105.5	109.1
	% Rec *	103.7	101.2	100.5	104.1	107.5	109.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 1/3/2023
Analyst: ZD
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

499.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1779	483	96.6	2.9
Duplicate	1849	502	100.4	1.0
Triplicate	1866	506	101.3	1.9

547.5 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2347	544	99.4	1.2
Duplicate	2330	540	98.7	0.4
Triplicate	2283	529	96.7	1.6

479.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2640	499	104.2	2.3
Duplicate	2553	483	100.8	1.1
Triplicate	2549	482	100.6	1.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 220521-28941

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 220521-28941

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	249.9	242.1	242.4	96.9	97.0	0.1
MeSH	<PQL	273.8	270.6	265.3	98.8	96.9	2.0
DMS	<PQL	239.5	245.7	246.7	102.6	103.0	0.4

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	499.8	501.8	100.4
MeSH	547.5	558.7	102.0
DMS	479.0	478.9	100.0

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

230002

Fuel Gas Sampling

Client: PG&E Colusa Generating Station		Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd		Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA / Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling		Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504	Preparation and Analysis: BTU
CPP-GS-Dec-A	39621	21-Dec-2022	1000	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other _____	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	21-Dec-2022	1500 hrs	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	1/2/23	0954

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

1x 1.4L can

Internal

ATTACHMENT 3
40 CFR 60 Section KKKK

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/01/2022 00:00	1	1
10/01/2022 01:00	1	1
10/01/2022 02:00	1	1
10/01/2022 03:00	1	1
10/01/2022 04:00	1	1
10/01/2022 05:00	1	1
10/01/2022 06:00	1	1
10/01/2022 07:00	1	1
10/01/2022 08:00	1	1
10/01/2022 09:00	1	1
10/01/2022 10:00	1	1
10/01/2022 11:00	1	1
10/01/2022 12:00	1	13
10/01/2022 13:00	1	17
10/01/2022 14:00	1	21
10/01/2022 15:00	1	20
10/01/2022 16:00	1	8
10/01/2022 17:00	1	5
10/01/2022 18:00	1	1
10/01/2022 19:00	1	1
10/01/2022 20:00	1	1
10/01/2022 21:00	1	1
10/01/2022 22:00	1	1
10/01/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	21
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/02/2022 00:00	1	1
10/02/2022 01:00	1	1
10/02/2022 02:00	1	1
10/02/2022 03:00	1	1
10/02/2022 04:00	1	1
10/02/2022 05:00	1	1
10/02/2022 06:00	1	1
10/02/2022 07:00	1	1
10/02/2022 08:00	1	1
10/02/2022 09:00	1	1
10/02/2022 10:00	1	1
10/02/2022 11:00	1	12
10/02/2022 12:00	1	15
10/02/2022 13:00	1	18
10/02/2022 14:00	1	18
10/02/2022 15:00	1	6
10/02/2022 16:00	1	3
10/02/2022 17:00	1	1
10/02/2022 18:00	1	1
10/02/2022 19:00	1	1
10/02/2022 20:00	1	1
10/02/2022 21:00	1	1
10/02/2022 22:00	1	1
10/02/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/03/2022 00:00	1	1
10/03/2022 01:00	1	1
10/03/2022 02:00	14	1
10/03/2022 03:00	16	1
10/03/2022 04:00	16	1
10/03/2022 05:00	16	1
10/03/2022 06:00	3	0
10/03/2022 07:00	1	0
10/03/2022 08:00	1	0
10/03/2022 09:00	1	0
10/03/2022 10:00	1	0
10/03/2022 11:00	1	0
10/03/2022 12:00	1	1
10/03/2022 13:00	1	1
10/03/2022 14:00	1	1
10/03/2022 15:00	1	1
10/03/2022 16:00	1	1
10/03/2022 17:00	1	1
10/03/2022 18:00	1	1
10/03/2022 19:00	1	1
10/03/2022 20:00	1	1
10/03/2022 21:00	1	1
10/03/2022 22:00	1	1
10/03/2022 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	16	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/04/2022 00:00	1	1
10/04/2022 01:00	1	1
10/04/2022 02:00	1	1
10/04/2022 03:00	1	1
10/04/2022 04:00	1	1
10/04/2022 05:00	1	1
10/04/2022 06:00	1	1
10/04/2022 07:00	1	1
10/04/2022 08:00	1	1
10/04/2022 09:00	1	1
10/04/2022 10:00	1	1
10/04/2022 11:00	1	0
10/04/2022 12:00	1	1
10/04/2022 13:00	1	1
10/04/2022 14:00	1	1
10/04/2022 15:00	1	1
10/04/2022 16:00	1	1
10/04/2022 17:00	1	1
10/04/2022 18:00	1	1
10/04/2022 19:00	1	1
10/04/2022 20:00	1	1
10/04/2022 21:00	1	1
10/04/2022 22:00	1	1
10/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/05/2022 00:00	1	1
10/05/2022 01:00	1	1
10/05/2022 02:00	1	1
10/05/2022 03:00	1	1
10/05/2022 04:00	1	1
10/05/2022 05:00	1	1
10/05/2022 06:00	1	1
10/05/2022 07:00	1	1
10/05/2022 08:00	1	1
10/05/2022 09:00	1	1
10/05/2022 10:00	1	1
10/05/2022 11:00	1	1
10/05/2022 12:00	1	1
10/05/2022 13:00	1	1
10/05/2022 14:00	1	1
10/05/2022 15:00	1	1
10/05/2022 16:00	1	1
10/05/2022 17:00	1	1
10/05/2022 18:00	1	1
10/05/2022 19:00	1	1
10/05/2022 20:00	1	1
10/05/2022 21:00	1	1
10/05/2022 22:00	1	1
10/05/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/06/2022 00:00	1	1
10/06/2022 01:00	1	1
10/06/2022 02:00	1	1
10/06/2022 03:00	1	1
10/06/2022 04:00	1	1
10/06/2022 05:00	1	1
10/06/2022 06:00	1	1
10/06/2022 07:00	1	1
10/06/2022 08:00	1	1
10/06/2022 09:00	1	1
10/06/2022 10:00	1	1
10/06/2022 11:00	1	1
10/06/2022 12:00	1	1
10/06/2022 13:00	1	1
10/06/2022 14:00	1	1
10/06/2022 15:00	1	1
10/06/2022 16:00	1	1
10/06/2022 17:00	1	1
10/06/2022 18:00	1	1
10/06/2022 19:00	1	1
10/06/2022 20:00	1	1
10/06/2022 21:00	1	1
10/06/2022 22:00	1	1
10/06/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/07/2022 00:00	1	1
10/07/2022 01:00	1	1
10/07/2022 02:00	1	1
10/07/2022 03:00	1	1
10/07/2022 04:00	1	1
10/07/2022 05:00	1	1
10/07/2022 06:00	1	1
10/07/2022 07:00	1	1
10/07/2022 08:00	1	1
10/07/2022 09:00	1	1
10/07/2022 10:00	1	1
10/07/2022 11:00	1	1
10/07/2022 12:00	1	1
10/07/2022 13:00	1	1
10/07/2022 14:00	1	1
10/07/2022 15:00	1	1
10/07/2022 16:00	1	1
10/07/2022 17:00	1	1
10/07/2022 18:00	1	1
10/07/2022 19:00	1	1
10/07/2022 20:00	1	1
10/07/2022 21:00	1	1
10/07/2022 22:00	1	1
10/07/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/08/2022 00:00	1	1
10/08/2022 01:00	1	1
10/08/2022 02:00	1	1
10/08/2022 03:00	1	1
10/08/2022 04:00	1	1
10/08/2022 05:00	1	1
10/08/2022 06:00	1	1
10/08/2022 07:00	1	1
10/08/2022 08:00	1	1
10/08/2022 09:00	1	1
10/08/2022 10:00	1	0
10/08/2022 11:00	1	0
10/08/2022 12:00	1	0
10/08/2022 13:00	1	0
10/08/2022 14:00	1	1
10/08/2022 15:00	1	1
10/08/2022 16:00	1	1
10/08/2022 17:00	1	1
10/08/2022 18:00	1	1
10/08/2022 19:00	1	1
10/08/2022 20:00	1	1
10/08/2022 21:00	1	1
10/08/2022 22:00	1	1
10/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/09/2022 00:00	1	1
10/09/2022 01:00	1	1
10/09/2022 02:00	1	1
10/09/2022 03:00	1	1
10/09/2022 04:00	1	1
10/09/2022 05:00	1	1
10/09/2022 06:00	1	1
10/09/2022 07:00	1	1
10/09/2022 08:00	1	1
10/09/2022 09:00	1	1
10/09/2022 10:00	1	1
10/09/2022 11:00	4	1
10/09/2022 12:00	4	1
10/09/2022 13:00	4	1
10/09/2022 14:00	4	9
10/09/2022 15:00	1	11
10/09/2022 16:00	1	11
10/09/2022 17:00	1	11
10/09/2022 18:00	1	3
10/09/2022 19:00	1	1
10/09/2022 20:00	1	1
10/09/2022 21:00	1	1
10/09/2022 22:00	1	1
10/09/2022 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/10/2022 00:00	1	1
10/10/2022 01:00	1	1
10/10/2022 02:00	1	1
10/10/2022 03:00	1	1
10/10/2022 04:00	1	1
10/10/2022 05:00	1	1
10/10/2022 06:00	1	1
10/10/2022 07:00	1	1
10/10/2022 08:00	1	1
10/10/2022 09:00	1	1
10/10/2022 10:00	1	0
10/10/2022 11:00	1	0
10/10/2022 12:00	1	0
10/10/2022 13:00	1	0
10/10/2022 14:00	1	1
10/10/2022 15:00	1	1
10/10/2022 16:00	1	1
10/10/2022 17:00	1	1
10/10/2022 18:00	1	1
10/10/2022 19:00	1	1
10/10/2022 20:00	1	1
10/10/2022 21:00	1	1
10/10/2022 22:00	1	1
10/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/11/2022 00:00	1	1
10/11/2022 01:00	1	1
10/11/2022 02:00	1	0
10/11/2022 03:00	1	0
10/11/2022 04:00	1	0
10/11/2022 05:00	1	0
10/11/2022 06:00	1	0
10/11/2022 07:00	1	0
10/11/2022 08:00	1	0
10/11/2022 09:00	1	0
10/11/2022 10:00	1	0
10/11/2022 11:00	1	1
10/11/2022 12:00	1	1
10/11/2022 13:00	1	1
10/11/2022 14:00	1	1
10/11/2022 15:00	1	1
10/11/2022 16:00	1	1
10/11/2022 17:00	1	1
10/11/2022 18:00	1	1
10/11/2022 19:00	1	1
10/11/2022 20:00	1	1
10/11/2022 21:00	1	1
10/11/2022 22:00	1	1
10/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/12/2022 00:00	1	1
10/12/2022 01:00	1	1
10/12/2022 02:00	1	1
10/12/2022 03:00	1	1
10/12/2022 04:00	1	1
10/12/2022 05:00	1	1
10/12/2022 06:00	1	1
10/12/2022 07:00	1	1
10/12/2022 08:00	1	1
10/12/2022 09:00	1	1
10/12/2022 10:00	1	1
10/12/2022 11:00	1	1
10/12/2022 12:00	1	1
10/12/2022 13:00	1	1
10/12/2022 14:00	1	1
10/12/2022 15:00	1	1
10/12/2022 16:00	1	1
10/12/2022 17:00	1	1
10/12/2022 18:00	1	1
10/12/2022 19:00	1	1
10/12/2022 20:00	1	1
10/12/2022 21:00	1	1
10/12/2022 22:00	1	1
10/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/13/2022 00:00	1	1
10/13/2022 01:00	1	1
10/13/2022 02:00	1	1
10/13/2022 03:00	1	1
10/13/2022 04:00	1	1
10/13/2022 05:00	1	1
10/13/2022 06:00	1	1
10/13/2022 07:00	1	0
10/13/2022 08:00	1	0
10/13/2022 09:00	1	0
10/13/2022 10:00	1	0
10/13/2022 11:00	1	1
10/13/2022 12:00	1	1
10/13/2022 13:00	1	1
10/13/2022 14:00	1	1
10/13/2022 15:00	1	1
10/13/2022 16:00	1	1
10/13/2022 17:00	1	1
10/13/2022 18:00	1	1
10/13/2022 19:00	1	1
10/13/2022 20:00	1	1
10/13/2022 21:00	1	1
10/13/2022 22:00	1	1
10/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/14/2022 00:00	1	1
10/14/2022 01:00	1	1
10/14/2022 02:00	1	1
10/14/2022 03:00	1	1
10/14/2022 04:00	1	1
10/14/2022 05:00	1	1
10/14/2022 06:00	1	1
10/14/2022 07:00	1	1
10/14/2022 08:00	1	1
10/14/2022 09:00	1	1
10/14/2022 10:00	1	1
10/14/2022 11:00	1	1
10/14/2022 12:00	1	1
10/14/2022 13:00	1	1
10/14/2022 14:00	1	1
10/14/2022 15:00	1	1
10/14/2022 16:00	1	1
10/14/2022 17:00	1	1
10/14/2022 18:00	1	1
10/14/2022 19:00	1	1
10/14/2022 20:00	1	1
10/14/2022 21:00	1	1
10/14/2022 22:00	1	1
10/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/15/2022 00:00	1	1
10/15/2022 01:00	1	1
10/15/2022 02:00	1	1
10/15/2022 03:00	1	1
10/15/2022 04:00	1	1
10/15/2022 05:00	1	1
10/15/2022 06:00	1	1
10/15/2022 07:00	1	1
10/15/2022 08:00	1	1
10/15/2022 09:00	1	1
10/15/2022 10:00	1	1
10/15/2022 11:00	1	1
10/15/2022 12:00	1	1
10/15/2022 13:00	1	1
10/15/2022 14:00	1	1
10/15/2022 15:00	1	1
10/15/2022 16:00	1	1
10/15/2022 17:00	1	1
10/15/2022 18:00	1	1
10/15/2022 19:00	1	1
10/15/2022 20:00	1	1
10/15/2022 21:00	1	1
10/15/2022 22:00	1	1
10/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/16/2022 00:00	1	1
10/16/2022 01:00	1	1
10/16/2022 02:00	1	1
10/16/2022 03:00	1	1
10/16/2022 04:00	1	1
10/16/2022 05:00	1	1
10/16/2022 06:00	1	1
10/16/2022 07:00	1	1
10/16/2022 08:00	1	1
10/16/2022 09:00	1	1
10/16/2022 10:00	1	1
10/16/2022 11:00	1	1
10/16/2022 12:00	1	1
10/16/2022 13:00	1	1
10/16/2022 14:00	1	1
10/16/2022 15:00	1	1
10/16/2022 16:00	1	1
10/16/2022 17:00	1	14
10/16/2022 18:00	1	19
10/16/2022 19:00	1	22
10/16/2022 20:00	1	21
10/16/2022 21:00	1	9
10/16/2022 22:00	1	4
10/16/2022 23:00	13	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	13	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/17/2022 00:00	18	1
10/17/2022 01:00	18	1
10/17/2022 02:00	18	1
10/17/2022 03:00	6	1
10/17/2022 04:00	1	1
10/17/2022 05:00	1	1
10/17/2022 06:00	1	1
10/17/2022 07:00	1	1
10/17/2022 08:00	1	1
10/17/2022 09:00	1	1
10/17/2022 10:00	1	1
10/17/2022 11:00	1	1
10/17/2022 12:00	1	1
10/17/2022 13:00	1	1
10/17/2022 14:00	1	1
10/17/2022 15:00	1	1
10/17/2022 16:00	1	1
10/17/2022 17:00	1	1
10/17/2022 18:00	1	1
10/17/2022 19:00	1	1
10/17/2022 20:00	1	1
10/17/2022 21:00	1	1
10/17/2022 22:00	1	1
10/17/2022 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	18	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/18/2022 00:00	1	1
10/18/2022 01:00	1	1
10/18/2022 02:00	1	1
10/18/2022 03:00	1	1
10/18/2022 04:00	1	1
10/18/2022 05:00	1	1
10/18/2022 06:00	1	1
10/18/2022 07:00	1	1
10/18/2022 08:00	1	1
10/18/2022 09:00	1	1
10/18/2022 10:00	1	1
10/18/2022 11:00	1	1
10/18/2022 12:00	1	1
10/18/2022 13:00	1	1
10/18/2022 14:00	1	1
10/18/2022 15:00	1	1
10/18/2022 16:00	1	1
10/18/2022 17:00	1	1
10/18/2022 18:00	1	1
10/18/2022 19:00	1	1
10/18/2022 20:00	1	1
10/18/2022 21:00	1	1
10/18/2022 22:00	1	1
10/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/19/2022 00:00	1	1
10/19/2022 01:00	1	1
10/19/2022 02:00	1	1
10/19/2022 03:00	1	1
10/19/2022 04:00	1	1
10/19/2022 05:00	1	1
10/19/2022 06:00	1	1
10/19/2022 07:00	1	1
10/19/2022 08:00	1	1
10/19/2022 09:00	1	1
10/19/2022 10:00	1	1
10/19/2022 11:00	1	1
10/19/2022 12:00	1	1
10/19/2022 13:00	1	1
10/19/2022 14:00	1	1
10/19/2022 15:00	1	1
10/19/2022 16:00	1	1
10/19/2022 17:00	1	1
10/19/2022 18:00	1	1
10/19/2022 19:00	1	1
10/19/2022 20:00	1	1
10/19/2022 21:00	1	1
10/19/2022 22:00	1	1
10/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/20/2022 00:00	1	1
10/20/2022 01:00	1	1
10/20/2022 02:00	1	1
10/20/2022 03:00	1	1
10/20/2022 04:00	1	1
10/20/2022 05:00	1	1
10/20/2022 06:00	1	1
10/20/2022 07:00	1	1
10/20/2022 08:00	1	1
10/20/2022 09:00	1	1
10/20/2022 10:00	1	1
10/20/2022 11:00	1	1
10/20/2022 12:00	1	1
10/20/2022 13:00	1	1
10/20/2022 14:00	1	1
10/20/2022 15:00	1	1
10/20/2022 16:00	1	1
10/20/2022 17:00	1	1
10/20/2022 18:00	1	1
10/20/2022 19:00	1	1
10/20/2022 20:00	1	1
10/20/2022 21:00	1	1
10/20/2022 22:00	1	1
10/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/21/2022 00:00	1	1
10/21/2022 01:00	1	1
10/21/2022 02:00	1	1
10/21/2022 03:00	1	1
10/21/2022 04:00	1	1
10/21/2022 05:00	1	1
10/21/2022 06:00	1	1
10/21/2022 07:00	1	1
10/21/2022 08:00	1	1
10/21/2022 09:00	1	1
10/21/2022 10:00	1	1
10/21/2022 11:00	1	1
10/21/2022 12:00	1	1
10/21/2022 13:00	1	1
10/21/2022 14:00	1	1
10/21/2022 15:00	1	1
10/21/2022 16:00	1	1
10/21/2022 17:00	1	1
10/21/2022 18:00	1	1
10/21/2022 19:00	1	1
10/21/2022 20:00	1	1
10/21/2022 21:00	1	1
10/21/2022 22:00	1	1
10/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/22/2022 00:00	1	1
10/22/2022 01:00	1	1
10/22/2022 02:00	1	1
10/22/2022 03:00	1	1
10/22/2022 04:00	1	1
10/22/2022 05:00	1	1
10/22/2022 06:00	1	1
10/22/2022 07:00	1	1
10/22/2022 08:00	1	1
10/22/2022 09:00	1	1
10/22/2022 10:00	1	1
10/22/2022 11:00	1	1
10/22/2022 12:00	1	1
10/22/2022 13:00	1	1
10/22/2022 14:00	1	1
10/22/2022 15:00	1	1
10/22/2022 16:00	1	1
10/22/2022 17:00	1	1
10/22/2022 18:00	1	1
10/22/2022 19:00	1	1
10/22/2022 20:00	1	1
10/22/2022 21:00	1	1
10/22/2022 22:00	1	1
10/22/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/23/2022 00:00	1	1
10/23/2022 01:00	1	1
10/23/2022 02:00	1	1
10/23/2022 03:00	1	1
10/23/2022 04:00	1	1
10/23/2022 05:00	1	1
10/23/2022 06:00	1	1
10/23/2022 07:00	1	1
10/23/2022 08:00	1	1
10/23/2022 09:00	1	1
10/23/2022 10:00	1	1
10/23/2022 11:00	1	1
10/23/2022 12:00	1	1
10/23/2022 13:00	1	1
10/23/2022 14:00	1	1
10/23/2022 15:00	1	1
10/23/2022 16:00	1	1
10/23/2022 17:00	1	1
10/23/2022 18:00	1	1
10/23/2022 19:00	1	1
10/23/2022 20:00	1	15
10/23/2022 21:00	1	21
10/23/2022 22:00	1	25
10/23/2022 23:00	1	24
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/24/2022 00:00	1	10
10/24/2022 01:00	1	4
10/24/2022 02:00	1	1
10/24/2022 03:00	1	1
10/24/2022 04:00	1	1
10/24/2022 05:00	1	1
10/24/2022 06:00	1	1
10/24/2022 07:00	1	1
10/24/2022 08:00	1	1
10/24/2022 09:00	1	1
10/24/2022 10:00	1	1
10/24/2022 11:00	1	1
10/24/2022 12:00	1	1
10/24/2022 13:00	14	1
10/24/2022 14:00	16	1
10/24/2022 15:00	16	1
10/24/2022 16:00	16	1
10/24/2022 17:00	3	1
10/24/2022 18:00	1	1
10/24/2022 19:00	1	1
10/24/2022 20:00	1	1
10/24/2022 21:00	1	1
10/24/2022 22:00	1	1
10/24/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	16	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/25/2022 00:00	1	1
10/25/2022 01:00	1	1
10/25/2022 02:00	1	1
10/25/2022 03:00	1	1
10/25/2022 04:00	1	1
10/25/2022 05:00	1	1
10/25/2022 06:00	1	1
10/25/2022 07:00	1	1
10/25/2022 08:00	1	1
10/25/2022 09:00	1	1
10/25/2022 10:00	1	1
10/25/2022 11:00	1	1
10/25/2022 12:00	1	1
10/25/2022 13:00	1	1
10/25/2022 14:00	1	1
10/25/2022 15:00	1	1
10/25/2022 16:00	1	1
10/25/2022 17:00	1	1
10/25/2022 18:00	1	1
10/25/2022 19:00	1	1
10/25/2022 20:00	1	1
10/25/2022 21:00	1	1
10/25/2022 22:00	1	1
10/25/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/26/2022 00:00	1	1
10/26/2022 01:00	1	1
10/26/2022 02:00	1	1
10/26/2022 03:00	1	1
10/26/2022 04:00	1	1
10/26/2022 05:00	1	1
10/26/2022 06:00	1	1
10/26/2022 07:00	1	1
10/26/2022 08:00	2	1
10/26/2022 09:00	2	1
10/26/2022 10:00	2	1
10/26/2022 11:00	2	1
10/26/2022 12:00	2	1
10/26/2022 13:00	2	1
10/26/2022 14:00	2	1
10/26/2022 15:00	2	1
10/26/2022 16:00	13	1
10/26/2022 17:00	27	1
10/26/2022 18:00	34	1
10/26/2022 19:00	33	1
10/26/2022 20:00	21	1
10/26/2022 21:00	7	1
10/26/2022 22:00	1	1
10/26/2022 23:00	1	1
Average/Sum#:	7	1
Minimum:	1	1
Maximum:	34	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/27/2022 00:00	1	1
10/27/2022 01:00	1	1
10/27/2022 02:00	1	1
10/27/2022 03:00	1	1
10/27/2022 04:00	1	1
10/27/2022 05:00	1	1
10/27/2022 06:00	1	1
10/27/2022 07:00	1	1
10/27/2022 08:00	1	1
10/27/2022 09:00	1	1
10/27/2022 10:00	1	1
10/27/2022 11:00	1	1
10/27/2022 12:00	1	1
10/27/2022 13:00	1	1
10/27/2022 14:00	1	1
10/27/2022 15:00	1	1
10/27/2022 16:00	1	1
10/27/2022 17:00	1	1
10/27/2022 18:00	1	1
10/27/2022 19:00	1	1
10/27/2022 20:00	1	1
10/27/2022 21:00	1	1
10/27/2022 22:00	1	1
10/27/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/28/2022 00:00	1	1
10/28/2022 01:00	1	1
10/28/2022 02:00	1	1
10/28/2022 03:00	1	1
10/28/2022 04:00	1	1
10/28/2022 05:00	1	1
10/28/2022 06:00	1	1
10/28/2022 07:00	1	1
10/28/2022 08:00	1	1
10/28/2022 09:00	1	1
10/28/2022 10:00	1	1
10/28/2022 11:00	1	1
10/28/2022 12:00	1	1
10/28/2022 13:00	1	1
10/28/2022 14:00	1	1
10/28/2022 15:00	1	1
10/28/2022 16:00	1	1
10/28/2022 17:00	1	1
10/28/2022 18:00	1	1
10/28/2022 19:00	1	1
10/28/2022 20:00	1	1
10/28/2022 21:00	1	1
10/28/2022 22:00	1	1
10/28/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/29/2022 00:00	1	1
10/29/2022 01:00	1	1
10/29/2022 02:00	1	1
10/29/2022 03:00	1	1
10/29/2022 04:00	1	1
10/29/2022 05:00	1	1
10/29/2022 06:00	1	1
10/29/2022 07:00	1	1
10/29/2022 08:00	1	1
10/29/2022 09:00	1	1
10/29/2022 10:00	1	1
10/29/2022 11:00	1	1
10/29/2022 12:00	1	1
10/29/2022 13:00	1	1
10/29/2022 14:00	1	1
10/29/2022 15:00	1	1
10/29/2022 16:00	1	1
10/29/2022 17:00	1	1
10/29/2022 18:00	1	1
10/29/2022 19:00	1	1
10/29/2022 20:00	1	1
10/29/2022 21:00	1	1
10/29/2022 22:00	1	1
10/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/30/2022 00:00	1	1
10/30/2022 01:00	1	1
10/30/2022 02:00	1	1
10/30/2022 03:00	1	1
10/30/2022 04:00	1	1
10/30/2022 05:00	1	1
10/30/2022 06:00	1	1
10/30/2022 07:00	1	1
10/30/2022 08:00	1	1
10/30/2022 09:00	1	1
10/30/2022 10:00	1	1
10/30/2022 11:00	1	1
10/30/2022 12:00	1	1
10/30/2022 13:00	1	1
10/30/2022 14:00	1	1
10/30/2022 15:00	1	1
10/30/2022 16:00	1	1
10/30/2022 17:00	1	1
10/30/2022 18:00	1	1
10/30/2022 19:00	1	9
10/30/2022 20:00	1	21
10/30/2022 21:00	1	25
10/30/2022 22:00	1	29
10/30/2022 23:00	1	22
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	29
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/31/2022 00:00	1	10
10/31/2022 01:00	14	5
10/31/2022 02:00	18	1
10/31/2022 03:00	18	1
10/31/2022 04:00	18	1
10/31/2022 05:00	5	1
10/31/2022 06:00	1	1
10/31/2022 07:00	1	1
10/31/2022 08:00	1	1
10/31/2022 09:00	1	1
10/31/2022 10:00	1	1
10/31/2022 11:00	1	1
10/31/2022 12:00	1	1
10/31/2022 13:00	1	1
10/31/2022 14:00	1	1
10/31/2022 15:00	1	1
10/31/2022 16:00	1	1
10/31/2022 17:00	1	1
10/31/2022 18:00	1	1
10/31/2022 19:00	1	1
10/31/2022 20:00	1	1
10/31/2022 21:00	1	1
10/31/2022 22:00	1	1
10/31/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	18	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/01/2022 00:00	1	1
11/01/2022 01:00	1	1
11/01/2022 02:00	1	1
11/01/2022 03:00	1	1
11/01/2022 04:00	1	1
11/01/2022 05:00	1	1
11/01/2022 06:00	1	1
11/01/2022 07:00	1	1
11/01/2022 08:00	1	1
11/01/2022 09:00	1	1
11/01/2022 10:00	1	1
11/01/2022 11:00	1	1
11/01/2022 12:00	1	1
11/01/2022 13:00	1	1
11/01/2022 14:00	1	1
11/01/2022 15:00	1	1
11/01/2022 16:00	1	1
11/01/2022 17:00	1	1
11/01/2022 18:00	1	1
11/01/2022 19:00	1	1
11/01/2022 20:00	1	1
11/01/2022 21:00	1	1
11/01/2022 22:00	1	1
11/01/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/02/2022 00:00	1	1
11/02/2022 01:00	1	1
11/02/2022 02:00	1	1
11/02/2022 03:00	1	1
11/02/2022 04:00	1	1
11/02/2022 05:00	1	1
11/02/2022 06:00	1	1
11/02/2022 07:00	1	1
11/02/2022 08:00	1	1
11/02/2022 09:00	1	1
11/02/2022 10:00	1	1
11/02/2022 11:00	1	1
11/02/2022 12:00	1	1
11/02/2022 13:00	1	1
11/02/2022 14:00	1	1
11/02/2022 15:00	1	1
11/02/2022 16:00	1	1
11/02/2022 17:00	1	1
11/02/2022 18:00	1	1
11/02/2022 19:00	1	1
11/02/2022 20:00	1	1
11/02/2022 21:00	1	1
11/02/2022 22:00	1	1
11/02/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/03/2022 00:00	1	1
11/03/2022 01:00	1	1
11/03/2022 02:00	1	1
11/03/2022 03:00	1	1
11/03/2022 04:00	1	1
11/03/2022 05:00	1	1
11/03/2022 06:00	1	1
11/03/2022 07:00	1	1
11/03/2022 08:00	1	1
11/03/2022 09:00	1	1
11/03/2022 10:00	1	1
11/03/2022 11:00	1	1
11/03/2022 12:00	1	1
11/03/2022 13:00	1	1
11/03/2022 14:00	1	1
11/03/2022 15:00	1	1
11/03/2022 16:00	1	1
11/03/2022 17:00	1	1
11/03/2022 18:00	1	1
11/03/2022 19:00	1	1
11/03/2022 20:00	1	1
11/03/2022 21:00	1	1
11/03/2022 22:00	1	1
11/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/04/2022 00:00	1	1
11/04/2022 01:00	1	1
11/04/2022 02:00	1	1
11/04/2022 03:00	1	1
11/04/2022 04:00	1	1
11/04/2022 05:00	1	1
11/04/2022 06:00	1	1
11/04/2022 07:00	1	1
11/04/2022 08:00	1	1
11/04/2022 09:00	1	1
11/04/2022 10:00	1	1
11/04/2022 11:00	1	1
11/04/2022 12:00	1	1
11/04/2022 13:00	1	1
11/04/2022 14:00	1	1
11/04/2022 15:00	1	1
11/04/2022 16:00	1	1
11/04/2022 17:00	1	1
11/04/2022 18:00	1	1
11/04/2022 19:00	1	1
11/04/2022 20:00	1	1
11/04/2022 21:00	1	1
11/04/2022 22:00	1	1
11/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/05/2022 00:00	1	1
11/05/2022 01:00	1	1
11/05/2022 02:00	1	1
11/05/2022 03:00	1	1
11/05/2022 04:00	1	1
11/05/2022 05:00	1	1
11/05/2022 06:00	1	1
11/05/2022 07:00	2	3
11/05/2022 08:00	2	3
11/05/2022 09:00	2	3
11/05/2022 10:00	2	3
11/05/2022 11:00	2	3
11/05/2022 12:00	2	3
11/05/2022 13:00	6	3
11/05/2022 14:00	15	3
11/05/2022 15:00	15	3
11/05/2022 16:00	14	3
11/05/2022 17:00	9	3
11/05/2022 18:00	1	3
11/05/2022 19:00	1	3
11/05/2022 20:00	1	3
11/05/2022 21:00	1	3
11/05/2022 22:00	1	3
11/05/2022 23:00	1	3
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	15	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/06/2022 00:00	1	3
11/06/2022 01:00	1	3
11/06/2022 02:00	2	3
11/06/2022 03:00	2	3
11/06/2022 04:00	2	3
11/06/2022 05:00	2	3
11/06/2022 06:00	2	3
11/06/2022 07:00	2	3
11/06/2022 08:00	2	3
11/06/2022 09:00	2	14
11/06/2022 10:00	2	22
11/06/2022 11:00	2	25
11/06/2022 12:00	2	23
11/06/2022 13:00	2	12
11/06/2022 14:00	2	4
11/06/2022 15:00	2	1
11/06/2022 16:00	2	1
11/06/2022 17:00	2	1
11/06/2022 18:00	2	1
11/06/2022 19:00	2	1
11/06/2022 20:00	2	1
11/06/2022 21:00	2	1
11/06/2022 22:00	2	1
11/06/2022 23:00	2	1
Average/Sum#:	2	6
Minimum:	1	1
Maximum:	2	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/07/2022 00:00	2	2
11/07/2022 01:00	2	5
11/07/2022 02:00	2	5
11/07/2022 03:00	13	5
11/07/2022 04:00	21	3
11/07/2022 05:00	21	1
11/07/2022 06:00	21	1
11/07/2022 07:00	9	1
11/07/2022 08:00	1	1
11/07/2022 09:00	1	1
11/07/2022 10:00	1	1
11/07/2022 11:00	1	1
11/07/2022 12:00	1	1
11/07/2022 13:00	1	1
11/07/2022 14:00	1	1
11/07/2022 15:00	1	1
11/07/2022 16:00	1	1
11/07/2022 17:00	1	1
11/07/2022 18:00	1	1
11/07/2022 19:00	1	1
11/07/2022 20:00	1	1
11/07/2022 21:00	1	1
11/07/2022 22:00	1	1
11/07/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	21	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/08/2022 00:00	1	1
11/08/2022 01:00	1	1
11/08/2022 02:00	1	1
11/08/2022 03:00	1	1
11/08/2022 04:00	1	1
11/08/2022 05:00	1	1
11/08/2022 06:00	1	1
11/08/2022 07:00	1	1
11/08/2022 08:00	1	1
11/08/2022 09:00	1	1
11/08/2022 10:00	1	1
11/08/2022 11:00	1	1
11/08/2022 12:00	1	1
11/08/2022 13:00	1	1
11/08/2022 14:00	1	1
11/08/2022 15:00	1	1
11/08/2022 16:00	1	1
11/08/2022 17:00	1	1
11/08/2022 18:00	1	1
11/08/2022 19:00	1	1
11/08/2022 20:00	1	1
11/08/2022 21:00	1	1
11/08/2022 22:00	1	1
11/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/09/2022 00:00	1	1
11/09/2022 01:00	1	1
11/09/2022 02:00	1	1
11/09/2022 03:00	1	1
11/09/2022 04:00	1	1
11/09/2022 05:00	1	1
11/09/2022 06:00	1	1
11/09/2022 07:00	1	1
11/09/2022 08:00	1	1
11/09/2022 09:00	1	1
11/09/2022 10:00	1	1
11/09/2022 11:00	1	1
11/09/2022 12:00	1	1
11/09/2022 13:00	1	1
11/09/2022 14:00	1	1
11/09/2022 15:00	1	1
11/09/2022 16:00	1	1
11/09/2022 17:00	1	1
11/09/2022 18:00	1	1
11/09/2022 19:00	1	1
11/09/2022 20:00	1	1
11/09/2022 21:00	1	1
11/09/2022 22:00	1	1
11/09/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/10/2022 00:00	1	1
11/10/2022 01:00	1	1
11/10/2022 02:00	1	1
11/10/2022 03:00	1	1
11/10/2022 04:00	1	1
11/10/2022 05:00	1	1
11/10/2022 06:00	1	1
11/10/2022 07:00	1	1
11/10/2022 08:00	1	1
11/10/2022 09:00	1	1
11/10/2022 10:00	1	1
11/10/2022 11:00	1	1
11/10/2022 12:00	1	1
11/10/2022 13:00	1	1
11/10/2022 14:00	1	1
11/10/2022 15:00	1	1
11/10/2022 16:00	1	1
11/10/2022 17:00	1	1
11/10/2022 18:00	1	1
11/10/2022 19:00	1	1
11/10/2022 20:00	1	1
11/10/2022 21:00	1	1
11/10/2022 22:00	1	1
11/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/11/2022 00:00	1	1
11/11/2022 01:00	1	1
11/11/2022 02:00	1	1
11/11/2022 03:00	1	1
11/11/2022 04:00	1	1
11/11/2022 05:00	1	1
11/11/2022 06:00	1	1
11/11/2022 07:00	1	1
11/11/2022 08:00	1	1
11/11/2022 09:00	1	1
11/11/2022 10:00	1	1
11/11/2022 11:00	1	1
11/11/2022 12:00	1	1
11/11/2022 13:00	1	1
11/11/2022 14:00	1	1
11/11/2022 15:00	1	1
11/11/2022 16:00	1	1
11/11/2022 17:00	1	1
11/11/2022 18:00	1	1
11/11/2022 19:00	1	1
11/11/2022 20:00	1	1
11/11/2022 21:00	1	1
11/11/2022 22:00	1	1
11/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/12/2022 00:00	1	1
11/12/2022 01:00	1	1
11/12/2022 02:00	1	1
11/12/2022 03:00	1	1
11/12/2022 04:00	1	1
11/12/2022 05:00	1	1
11/12/2022 06:00	1	1
11/12/2022 07:00	1	1
11/12/2022 08:00	1	1
11/12/2022 09:00	1	1
11/12/2022 10:00	1	1
11/12/2022 11:00	1	1
11/12/2022 12:00	1	1
11/12/2022 13:00	1	1
11/12/2022 14:00	1	1
11/12/2022 15:00	1	1
11/12/2022 16:00	1	1
11/12/2022 17:00	1	1
11/12/2022 18:00	1	1
11/12/2022 19:00	1	1
11/12/2022 20:00	1	1
11/12/2022 21:00	1	1
11/12/2022 22:00	1	1
11/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/13/2022 00:00	1	1
11/13/2022 01:00	1	1
11/13/2022 02:00	1	1
11/13/2022 03:00	1	1
11/13/2022 04:00	1	1
11/13/2022 05:00	1	1
11/13/2022 06:00	1	1
11/13/2022 07:00	1	1
11/13/2022 08:00	1	1
11/13/2022 09:00	1	1
11/13/2022 10:00	1	1
11/13/2022 11:00	1	1
11/13/2022 12:00	1	1
11/13/2022 13:00	1	1
11/13/2022 14:00	1	1
11/13/2022 15:00	1	1
11/13/2022 16:00	1	1
11/13/2022 17:00	1	1
11/13/2022 18:00	1	1
11/13/2022 19:00	1	1
11/13/2022 20:00	1	1
11/13/2022 21:00	1	1
11/13/2022 22:00	1	1
11/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/14/2022 00:00	1	1
11/14/2022 01:00	1	1
11/14/2022 02:00	1	1
11/14/2022 03:00	1	1
11/14/2022 04:00	1	1
11/14/2022 05:00	1	1
11/14/2022 06:00	1	1
11/14/2022 07:00	1	1
11/14/2022 08:00	1	1
11/14/2022 09:00	1	1
11/14/2022 10:00	1	1
11/14/2022 11:00	1	1
11/14/2022 12:00	1	1
11/14/2022 13:00	1	1
11/14/2022 14:00	1	1
11/14/2022 15:00	1	1
11/14/2022 16:00	1	1
11/14/2022 17:00	1	1
11/14/2022 18:00	1	1
11/14/2022 19:00	1	1
11/14/2022 20:00	1	1
11/14/2022 21:00	1	1
11/14/2022 22:00	1	1
11/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/15/2022 00:00	1	1
11/15/2022 01:00	1	1
11/15/2022 02:00	1	1
11/15/2022 03:00	1	1
11/15/2022 04:00	1	1
11/15/2022 05:00	1	1
11/15/2022 06:00	1	1
11/15/2022 07:00	1	1
11/15/2022 08:00	1	1
11/15/2022 09:00	1	1
11/15/2022 10:00	1	1
11/15/2022 11:00	1	1
11/15/2022 12:00	1	1
11/15/2022 13:00	1	1
11/15/2022 14:00	1	1
11/15/2022 15:00	0	1
11/15/2022 16:00	0	1
11/15/2022 17:00	0	1
11/15/2022 18:00	1	1
11/15/2022 19:00	1	1
11/15/2022 20:00	1	1
11/15/2022 21:00	1	1
11/15/2022 22:00	1	1
11/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	12.50	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/16/2022 00:00	1	1
11/16/2022 01:00	1	1
11/16/2022 02:00	1	1
11/16/2022 03:00	1	1
11/16/2022 04:00	1	1
11/16/2022 05:00	1	1
11/16/2022 06:00	1	1
11/16/2022 07:00	1	1
11/16/2022 08:00	1	1
11/16/2022 09:00	1	1
11/16/2022 10:00	1	1
11/16/2022 11:00	1	1
11/16/2022 12:00	1	1
11/16/2022 13:00	1	1
11/16/2022 14:00	1	1
11/16/2022 15:00	1	1
11/16/2022 16:00	1	1
11/16/2022 17:00	1	1
11/16/2022 18:00	1	1
11/16/2022 19:00	1	1
11/16/2022 20:00	1	1
11/16/2022 21:00	1	1
11/16/2022 22:00	1	1
11/16/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/17/2022 00:00	1	1
11/17/2022 01:00	1	1
11/17/2022 02:00	1	1
11/17/2022 03:00	1	1
11/17/2022 04:00	1	1
11/17/2022 05:00	1	1
11/17/2022 06:00	1	1
11/17/2022 07:00	1	1
11/17/2022 08:00	1	1
11/17/2022 09:00	1	1
11/17/2022 10:00	1	1
11/17/2022 11:00	1	1
11/17/2022 12:00	1	1
11/17/2022 13:00	1	1
11/17/2022 14:00	1	1
11/17/2022 15:00	1	1
11/17/2022 16:00	1	1
11/17/2022 17:00	1	1
11/17/2022 18:00	1	1
11/17/2022 19:00	1	1
11/17/2022 20:00	1	1
11/17/2022 21:00	1	1
11/17/2022 22:00	1	1
11/17/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/18/2022 00:00	1	1
11/18/2022 01:00	1	1
11/18/2022 02:00	1	1
11/18/2022 03:00	1	1
11/18/2022 04:00	1	1
11/18/2022 05:00	1	1
11/18/2022 06:00	1	1
11/18/2022 07:00	1	1
11/18/2022 08:00	1	1
11/18/2022 09:00	1	1
11/18/2022 10:00	1	1
11/18/2022 11:00	1	1
11/18/2022 12:00	1	1
11/18/2022 13:00	1	1
11/18/2022 14:00	1	1
11/18/2022 15:00	1	1
11/18/2022 16:00	1	1
11/18/2022 17:00	1	1
11/18/2022 18:00	1	1
11/18/2022 19:00	1	1
11/18/2022 20:00	1	1
11/18/2022 21:00	1	1
11/18/2022 22:00	1	1
11/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/19/2022 00:00	1	1
11/19/2022 01:00	1	1
11/19/2022 02:00	1	1
11/19/2022 03:00	1	1
11/19/2022 04:00	1	1
11/19/2022 05:00	1	1
11/19/2022 06:00	1	1
11/19/2022 07:00	1	1
11/19/2022 08:00	1	1
11/19/2022 09:00	1	1
11/19/2022 10:00	1	1
11/19/2022 11:00	1	1
11/19/2022 12:00	1	1
11/19/2022 13:00	1	1
11/19/2022 14:00	1	1
11/19/2022 15:00	1	1
11/19/2022 16:00	1	1
11/19/2022 17:00	1	1
11/19/2022 18:00	1	1
11/19/2022 19:00	1	1
11/19/2022 20:00	1	1
11/19/2022 21:00	1	1
11/19/2022 22:00	1	1
11/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/20/2022 00:00	1	1
11/20/2022 01:00	1	1
11/20/2022 02:00	1	1
11/20/2022 03:00	1	1
11/20/2022 04:00	1	1
11/20/2022 05:00	1	1
11/20/2022 06:00	1	1
11/20/2022 07:00	1	1
11/20/2022 08:00	1	1
11/20/2022 09:00	1	1
11/20/2022 10:00	1	1
11/20/2022 11:00	1	0
11/20/2022 12:00	1	0
11/20/2022 13:00	1	0
11/20/2022 14:00	1	0
11/20/2022 15:00	1	0
11/20/2022 16:00	1	1
11/20/2022 17:00	1	1
11/20/2022 18:00	1	1
11/20/2022 19:00	1	1
11/20/2022 20:00	1	1
11/20/2022 21:00	1	1
11/20/2022 22:00	1	1
11/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/21/2022 00:00	1	1
11/21/2022 01:00	1	1
11/21/2022 02:00	1	1
11/21/2022 03:00	1	1
11/21/2022 04:00	1	1
11/21/2022 05:00	1	1
11/21/2022 06:00	1	1
11/21/2022 07:00	1	1
11/21/2022 08:00	1	1
11/21/2022 09:00	1	1
11/21/2022 10:00	1	1
11/21/2022 11:00	1	1
11/21/2022 12:00	1	1
11/21/2022 13:00	1	1
11/21/2022 14:00	1	1
11/21/2022 15:00	1	1
11/21/2022 16:00	1	1
11/21/2022 17:00	1	1
11/21/2022 18:00	1	1
11/21/2022 19:00	1	1
11/21/2022 20:00	1	1
11/21/2022 21:00	1	1
11/21/2022 22:00	1	1
11/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/22/2022 00:00	1	1
11/22/2022 01:00	1	1
11/22/2022 02:00	1	1
11/22/2022 03:00	1	1
11/22/2022 04:00	1	1
11/22/2022 05:00	1	1
11/22/2022 06:00	1	1
11/22/2022 07:00	1	1
11/22/2022 08:00	1	1
11/22/2022 09:00	1	1
11/22/2022 10:00	1	1
11/22/2022 11:00	1	1
11/22/2022 12:00	4	1
11/22/2022 13:00	4	1
11/22/2022 14:00	4	1
11/22/2022 15:00	4	1
11/22/2022 16:00	1	1
11/22/2022 17:00	1	1
11/22/2022 18:00	1	1
11/22/2022 19:00	1	1
11/22/2022 20:00	1	1
11/22/2022 21:00	1	1
11/22/2022 22:00	1	1
11/22/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	4	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/23/2022 00:00	1	1
11/23/2022 01:00	1	1
11/23/2022 02:00	1	1
11/23/2022 03:00	1	1
11/23/2022 04:00	1	1
11/23/2022 05:00	1	1
11/23/2022 06:00	1	1
11/23/2022 07:00	1	1
11/23/2022 08:00	1	1
11/23/2022 09:00	1	1
11/23/2022 10:00	1	1
11/23/2022 11:00	1	1
11/23/2022 12:00	1	0
11/23/2022 13:00	1	0
11/23/2022 14:00	1	0
11/23/2022 15:00	1	0
11/23/2022 16:00	1	1
11/23/2022 17:00	1	1
11/23/2022 18:00	1	1
11/23/2022 19:00	1	1
11/23/2022 20:00	1	1
11/23/2022 21:00	1	1
11/23/2022 22:00	1	1
11/23/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/24/2022 00:00	1	1
11/24/2022 01:00	1	1
11/24/2022 02:00	1	1
11/24/2022 03:00	1	1
11/24/2022 04:00	1	1
11/24/2022 05:00	1	1
11/24/2022 06:00	1	1
11/24/2022 07:00	1	1
11/24/2022 08:00	1	1
11/24/2022 09:00	1	1
11/24/2022 10:00	1	1
11/24/2022 11:00	1	0
11/24/2022 12:00	1	0
11/24/2022 13:00	1	0
11/24/2022 14:00	1	0
11/24/2022 15:00	1	0
11/24/2022 16:00	1	0
11/24/2022 17:00	1	0
11/24/2022 18:00	1	1
11/24/2022 19:00	1	1
11/24/2022 20:00	1	1
11/24/2022 21:00	1	1
11/24/2022 22:00	1	1
11/24/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/25/2022 00:00	1	1
11/25/2022 01:00	1	1
11/25/2022 02:00	1	1
11/25/2022 03:00	1	1
11/25/2022 04:00	1	1
11/25/2022 05:00	1	1
11/25/2022 06:00	1	1
11/25/2022 07:00	1	1
11/25/2022 08:00	1	1
11/25/2022 09:00	1	1
11/25/2022 10:00	1	1
11/25/2022 11:00	1	1
11/25/2022 12:00	1	1
11/25/2022 13:00	1	0
11/25/2022 14:00	1	0
11/25/2022 15:00	1	0
11/25/2022 16:00	1	1
11/25/2022 17:00	1	1
11/25/2022 18:00	1	1
11/25/2022 19:00	1	1
11/25/2022 20:00	1	1
11/25/2022 21:00	1	1
11/25/2022 22:00	1	1
11/25/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/26/2022 00:00	1	1
11/26/2022 01:00	1	1
11/26/2022 02:00	1	1
11/26/2022 03:00	1	1
11/26/2022 04:00	1	1
11/26/2022 05:00	1	1
11/26/2022 06:00	1	1
11/26/2022 07:00	1	1
11/26/2022 08:00	1	1
11/26/2022 09:00	1	1
11/26/2022 10:00	1	1
11/26/2022 11:00	1	1
11/26/2022 12:00	1	1
11/26/2022 13:00	1	1
11/26/2022 14:00	1	1
11/26/2022 15:00	1	1
11/26/2022 16:00	1	1
11/26/2022 17:00	1	1
11/26/2022 18:00	1	1
11/26/2022 19:00	1	1
11/26/2022 20:00	1	1
11/26/2022 21:00	1	1
11/26/2022 22:00	1	1
11/26/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/27/2022 00:00	1	1
11/27/2022 01:00	1	1
11/27/2022 02:00	1	1
11/27/2022 03:00	1	1
11/27/2022 04:00	1	1
11/27/2022 05:00	1	1
11/27/2022 06:00	1	1
11/27/2022 07:00	1	1
11/27/2022 08:00	1	1
11/27/2022 09:00	1	1
11/27/2022 10:00	1	1
11/27/2022 11:00	1	1
11/27/2022 12:00	1	1
11/27/2022 13:00	1	1
11/27/2022 14:00	1	1
11/27/2022 15:00	1	1
11/27/2022 16:00	1	1
11/27/2022 17:00	1	1
11/27/2022 18:00	1	1
11/27/2022 19:00	1	1
11/27/2022 20:00	1	1
11/27/2022 21:00	1	15
11/27/2022 22:00	1	21
11/27/2022 23:00	1	24
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	24
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/28/2022 00:00	1	23
11/28/2022 01:00	1	10
11/28/2022 02:00	14	4
11/28/2022 03:00	17	0
11/28/2022 04:00	17	0
11/28/2022 05:00	17	1
11/28/2022 06:00	4	1
11/28/2022 07:00	1	1
11/28/2022 08:00	1	1
11/28/2022 09:00	1	1
11/28/2022 10:00	1	1
11/28/2022 11:00	1	1
11/28/2022 12:00	1	0
11/28/2022 13:00	1	0
11/28/2022 14:00	1	0
11/28/2022 15:00	1	1
11/28/2022 16:00	1	1
11/28/2022 17:00	1	1
11/28/2022 18:00	1	1
11/28/2022 19:00	1	1
11/28/2022 20:00	1	1
11/28/2022 21:00	1	1
11/28/2022 22:00	1	1
11/28/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	0
Maximum:	17	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/29/2022 00:00	1	1
11/29/2022 01:00	1	1
11/29/2022 02:00	1	1
11/29/2022 03:00	1	1
11/29/2022 04:00	1	1
11/29/2022 05:00	1	1
11/29/2022 06:00	1	1
11/29/2022 07:00	1	1
11/29/2022 08:00	1	1
11/29/2022 09:00	1	1
11/29/2022 10:00	1	1
11/29/2022 11:00	1	1
11/29/2022 12:00	1	1
11/29/2022 13:00	1	1
11/29/2022 14:00	1	1
11/29/2022 15:00	1	1
11/29/2022 16:00	1	1
11/29/2022 17:00	1	1
11/29/2022 18:00	1	1
11/29/2022 19:00	1	1
11/29/2022 20:00	1	1
11/29/2022 21:00	1	1
11/29/2022 22:00	1	1
11/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/30/2022 00:00	1	1
11/30/2022 01:00	1	1
11/30/2022 02:00	1	1
11/30/2022 03:00	1	1
11/30/2022 04:00	1	1
11/30/2022 05:00	1	1
11/30/2022 06:00	1	1
11/30/2022 07:00	1	1
11/30/2022 08:00	1	1
11/30/2022 09:00	1	1
11/30/2022 10:00	1	1
11/30/2022 11:00	1	1
11/30/2022 12:00	1	1
11/30/2022 13:00	1	1
11/30/2022 14:00	1	1
11/30/2022 15:00	1	1
11/30/2022 16:00	1	1
11/30/2022 17:00	1	1
11/30/2022 18:00	1	1
11/30/2022 19:00	1	1
11/30/2022 20:00	1	1
11/30/2022 21:00	1	1
11/30/2022 22:00	1	1
11/30/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/01/2022 00:00	1	1
12/01/2022 01:00	1	1
12/01/2022 02:00	1	2
12/01/2022 03:00	1	4
12/01/2022 04:00	1	3
12/01/2022 05:00	1	3
12/01/2022 06:00	1	2
12/01/2022 07:00	1	1
12/01/2022 08:00	1	1
12/01/2022 09:00	1	1
12/01/2022 10:00	1	1
12/01/2022 11:00	1	1
12/01/2022 12:00	1	1
12/01/2022 13:00	1	1
12/01/2022 14:00	1	1
12/01/2022 15:00	1	1
12/01/2022 16:00	1	1
12/01/2022 17:00	1	1
12/01/2022 18:00	1	1
12/01/2022 19:00	1	1
12/01/2022 20:00	1	1
12/01/2022 21:00	1	1
12/01/2022 22:00	1	1
12/01/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/02/2022 00:00	1	1
12/02/2022 01:00	1	1
12/02/2022 02:00	1	1
12/02/2022 03:00	1	1
12/02/2022 04:00	1	1
12/02/2022 05:00	1	1
12/02/2022 06:00	1	1
12/02/2022 07:00	1	1
12/02/2022 08:00	1	1
12/02/2022 09:00	1	1
12/02/2022 10:00	1	1
12/02/2022 11:00	1	1
12/02/2022 12:00	1	1
12/02/2022 13:00	1	1
12/02/2022 14:00	1	1
12/02/2022 15:00	1	1
12/02/2022 16:00	1	1
12/02/2022 17:00	1	1
12/02/2022 18:00	1	1
12/02/2022 19:00	1	1
12/02/2022 20:00	1	1
12/02/2022 21:00	1	1
12/02/2022 22:00	1	1
12/02/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/03/2022 00:00	1	1
12/03/2022 01:00	1	1
12/03/2022 02:00	1	1
12/03/2022 03:00	1	1
12/03/2022 04:00	1	1
12/03/2022 05:00	1	1
12/03/2022 06:00	1	1
12/03/2022 07:00	1	1
12/03/2022 08:00	1	1
12/03/2022 09:00	1	1
12/03/2022 10:00	1	1
12/03/2022 11:00	1	1
12/03/2022 12:00	1	1
12/03/2022 13:00	1	1
12/03/2022 14:00	1	1
12/03/2022 15:00	1	1
12/03/2022 16:00	1	1
12/03/2022 17:00	1	1
12/03/2022 18:00	1	1
12/03/2022 19:00	1	1
12/03/2022 20:00	1	1
12/03/2022 21:00	1	1
12/03/2022 22:00	1	1
12/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/04/2022 00:00	1	1
12/04/2022 01:00	1	1
12/04/2022 02:00	1	1
12/04/2022 03:00	1	1
12/04/2022 04:00	1	1
12/04/2022 05:00	1	1
12/04/2022 06:00	1	1
12/04/2022 07:00	1	1
12/04/2022 08:00	1	1
12/04/2022 09:00	1	1
12/04/2022 10:00	1	1
12/04/2022 11:00	1	1
12/04/2022 12:00	1	1
12/04/2022 13:00	1	1
12/04/2022 14:00	1	1
12/04/2022 15:00	1	1
12/04/2022 16:00	1	1
12/04/2022 17:00	1	1
12/04/2022 18:00	1	1
12/04/2022 19:00	1	1
12/04/2022 20:00	1	1
12/04/2022 21:00	1	1
12/04/2022 22:00	1	1
12/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/05/2022 00:00	1	1
12/05/2022 01:00	1	1
12/05/2022 02:00	1	1
12/05/2022 03:00	1	1
12/05/2022 04:00	1	1
12/05/2022 05:00	1	1
12/05/2022 06:00	1	1
12/05/2022 07:00	1	1
12/05/2022 08:00	1	1
12/05/2022 09:00	4	1
12/05/2022 10:00	15	1
12/05/2022 11:00	15	1
12/05/2022 12:00	15	1
12/05/2022 13:00	12	1
12/05/2022 14:00	1	1
12/05/2022 15:00	1	1
12/05/2022 16:00	1	1
12/05/2022 17:00	1	1
12/05/2022 18:00	1	1
12/05/2022 19:00	1	1
12/05/2022 20:00	1	1
12/05/2022 21:00	1	1
12/05/2022 22:00	1	1
12/05/2022 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	15	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/06/2022 00:00	1	1
12/06/2022 01:00	1	1
12/06/2022 02:00	1	1
12/06/2022 03:00	1	1
12/06/2022 04:00	1	1
12/06/2022 05:00	1	1
12/06/2022 06:00	1	1
12/06/2022 07:00	1	1
12/06/2022 08:00	1	1
12/06/2022 09:00	1	1
12/06/2022 10:00	1	1
12/06/2022 11:00	1	1
12/06/2022 12:00	1	1
12/06/2022 13:00	1	1
12/06/2022 14:00	1	1
12/06/2022 15:00	1	1
12/06/2022 16:00	1	0
12/06/2022 17:00	1	0
12/06/2022 18:00	1	0
12/06/2022 19:00	1	1
12/06/2022 20:00	1	1
12/06/2022 21:00	1	1
12/06/2022 22:00	1	1
12/06/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/07/2022 00:00	1	1
12/07/2022 01:00	1	1
12/07/2022 02:00	1	1
12/07/2022 03:00	1	1
12/07/2022 04:00	1	1
12/07/2022 05:00	1	1
12/07/2022 06:00	1	1
12/07/2022 07:00	1	1
12/07/2022 08:00	1	1
12/07/2022 09:00	1	1
12/07/2022 10:00	1	1
12/07/2022 11:00	1	1
12/07/2022 12:00	1	1
12/07/2022 13:00	1	1
12/07/2022 14:00	1	1
12/07/2022 15:00	1	1
12/07/2022 16:00	1	1
12/07/2022 17:00	1	1
12/07/2022 18:00	1	1
12/07/2022 19:00	1	1
12/07/2022 20:00	1	1
12/07/2022 21:00	1	1
12/07/2022 22:00	1	1
12/07/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/08/2022 00:00	1	1
12/08/2022 01:00	1	1
12/08/2022 02:00	1	1
12/08/2022 03:00	1	1
12/08/2022 04:00	1	1
12/08/2022 05:00	1	1
12/08/2022 06:00	1	1
12/08/2022 07:00	1	1
12/08/2022 08:00	1	1
12/08/2022 09:00	1	1
12/08/2022 10:00	1	1
12/08/2022 11:00	1	1
12/08/2022 12:00	1	1
12/08/2022 13:00	1	1
12/08/2022 14:00	1	1
12/08/2022 15:00	1	1
12/08/2022 16:00	1	1
12/08/2022 17:00	1	1
12/08/2022 18:00	1	1
12/08/2022 19:00	1	1
12/08/2022 20:00	1	1
12/08/2022 21:00	1	1
12/08/2022 22:00	1	1
12/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/09/2022 00:00	1	1
12/09/2022 01:00	1	1
12/09/2022 02:00	1	1
12/09/2022 03:00	1	1
12/09/2022 04:00	1	1
12/09/2022 05:00	1	1
12/09/2022 06:00	1	1
12/09/2022 07:00	1	1
12/09/2022 08:00	1	1
12/09/2022 09:00	1	1
12/09/2022 10:00	1	1
12/09/2022 11:00	1	1
12/09/2022 12:00	1	1
12/09/2022 13:00	1	1
12/09/2022 14:00	1	1
12/09/2022 15:00	1	1
12/09/2022 16:00	1	1
12/09/2022 17:00	1	1
12/09/2022 18:00	1	1
12/09/2022 19:00	1	1
12/09/2022 20:00	1	1
12/09/2022 21:00	1	1
12/09/2022 22:00	1	1
12/09/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/10/2022 00:00	1	1
12/10/2022 01:00	1	1
12/10/2022 02:00	1	1
12/10/2022 03:00	1	1
12/10/2022 04:00	1	1
12/10/2022 05:00	1	1
12/10/2022 06:00	1	1
12/10/2022 07:00	1	1
12/10/2022 08:00	1	1
12/10/2022 09:00	1	1
12/10/2022 10:00	1	1
12/10/2022 11:00	1	1
12/10/2022 12:00	1	1
12/10/2022 13:00	1	1
12/10/2022 14:00	1	1
12/10/2022 15:00	1	1
12/10/2022 16:00	1	1
12/10/2022 17:00	1	1
12/10/2022 18:00	1	1
12/10/2022 19:00	1	1
12/10/2022 20:00	1	1
12/10/2022 21:00	1	1
12/10/2022 22:00	1	1
12/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/11/2022 00:00	1	1
12/11/2022 01:00	1	1
12/11/2022 02:00	1	1
12/11/2022 03:00	1	1
12/11/2022 04:00	1	1
12/11/2022 05:00	1	1
12/11/2022 06:00	1	1
12/11/2022 07:00	1	1
12/11/2022 08:00	1	1
12/11/2022 09:00	1	1
12/11/2022 10:00	1	1
12/11/2022 11:00	1	1
12/11/2022 12:00	1	1
12/11/2022 13:00	1	1
12/11/2022 14:00	1	1
12/11/2022 15:00	1	1
12/11/2022 16:00	1	1
12/11/2022 17:00	1	1
12/11/2022 18:00	1	1
12/11/2022 19:00	1	1
12/11/2022 20:00	1	1
12/11/2022 21:00	1	1
12/11/2022 22:00	1	1
12/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/12/2022 00:00	1	1
12/12/2022 01:00	1	1
12/12/2022 02:00	1	1
12/12/2022 03:00	1	1
12/12/2022 04:00	1	1
12/12/2022 05:00	1	1
12/12/2022 06:00	1	1
12/12/2022 07:00	1	1
12/12/2022 08:00	1	1
12/12/2022 09:00	1	1
12/12/2022 10:00	1	1
12/12/2022 11:00	1	1
12/12/2022 12:00	1	1
12/12/2022 13:00	1	1
12/12/2022 14:00	1	1
12/12/2022 15:00	1	1
12/12/2022 16:00	1	1
12/12/2022 17:00	1	1
12/12/2022 18:00	1	1
12/12/2022 19:00	1	1
12/12/2022 20:00	1	1
12/12/2022 21:00	1	1
12/12/2022 22:00	1	1
12/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/13/2022 00:00	1	1
12/13/2022 01:00	1	1
12/13/2022 02:00	1	1
12/13/2022 03:00	1	1
12/13/2022 04:00	1	1
12/13/2022 05:00	1	1
12/13/2022 06:00	1	1
12/13/2022 07:00	1	1
12/13/2022 08:00	1	1
12/13/2022 09:00	1	1
12/13/2022 10:00	1	1
12/13/2022 11:00	1	1
12/13/2022 12:00	1	1
12/13/2022 13:00	1	1
12/13/2022 14:00	1	1
12/13/2022 15:00	1	1
12/13/2022 16:00	1	1
12/13/2022 17:00	1	1
12/13/2022 18:00	1	1
12/13/2022 19:00	1	1
12/13/2022 20:00	1	1
12/13/2022 21:00	1	1
12/13/2022 22:00	1	1
12/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/14/2022 00:00	1	1
12/14/2022 01:00	1	1
12/14/2022 02:00	1	1
12/14/2022 03:00	1	1
12/14/2022 04:00	1	1
12/14/2022 05:00	1	1
12/14/2022 06:00	1	1
12/14/2022 07:00	1	1
12/14/2022 08:00	1	1
12/14/2022 09:00	1	1
12/14/2022 10:00	1	1
12/14/2022 11:00	1	1
12/14/2022 12:00	1	1
12/14/2022 13:00	1	1
12/14/2022 14:00	1	1
12/14/2022 15:00	1	1
12/14/2022 16:00	1	1
12/14/2022 17:00	1	1
12/14/2022 18:00	1	1
12/14/2022 19:00	1	1
12/14/2022 20:00	1	1
12/14/2022 21:00	1	1
12/14/2022 22:00	1	1
12/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/15/2022 00:00	1	1
12/15/2022 01:00	1	1
12/15/2022 02:00	1	1
12/15/2022 03:00	1	1
12/15/2022 04:00	1	1
12/15/2022 05:00	1	1
12/15/2022 06:00	1	1
12/15/2022 07:00	1	1
12/15/2022 08:00	1	1
12/15/2022 09:00	1	1
12/15/2022 10:00	1	1
12/15/2022 11:00	1	1
12/15/2022 12:00	1	1
12/15/2022 13:00	1	1
12/15/2022 14:00	1	1
12/15/2022 15:00	1	1
12/15/2022 16:00	1	1
12/15/2022 17:00	1	1
12/15/2022 18:00	1	1
12/15/2022 19:00	1	1
12/15/2022 20:00	1	1
12/15/2022 21:00	1	1
12/15/2022 22:00	1	1
12/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/16/2022 00:00	1	1
12/16/2022 01:00	1	1
12/16/2022 02:00	1	1
12/16/2022 03:00	1	1
12/16/2022 04:00	1	1
12/16/2022 05:00	1	1
12/16/2022 06:00	1	1
12/16/2022 07:00	1	1
12/16/2022 08:00	1	1
12/16/2022 09:00	1	1
12/16/2022 10:00	1	1
12/16/2022 11:00	1	1
12/16/2022 12:00	1	1
12/16/2022 13:00	1	0
12/16/2022 14:00	1	0
12/16/2022 15:00	1	0
12/16/2022 16:00	1	1
12/16/2022 17:00	1	1
12/16/2022 18:00	1	1
12/16/2022 19:00	1	1
12/16/2022 20:00	1	1
12/16/2022 21:00	1	1
12/16/2022 22:00	1	1
12/16/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/17/2022 00:00	1	1
12/17/2022 01:00	1	1
12/17/2022 02:00	1	1
12/17/2022 03:00	1	1
12/17/2022 04:00	1	1
12/17/2022 05:00	1	1
12/17/2022 06:00	1	1
12/17/2022 07:00	1	1
12/17/2022 08:00	1	1
12/17/2022 09:00	1	1
12/17/2022 10:00	1	1
12/17/2022 11:00	1	1
12/17/2022 12:00	1	1
12/17/2022 13:00	1	1
12/17/2022 14:00	1	1
12/17/2022 15:00	1	1
12/17/2022 16:00	1	1
12/17/2022 17:00	1	1
12/17/2022 18:00	1	1
12/17/2022 19:00	1	1
12/17/2022 20:00	1	1
12/17/2022 21:00	1	1
12/17/2022 22:00	1	1
12/17/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/18/2022 00:00	1	1
12/18/2022 01:00	1	1
12/18/2022 02:00	1	1
12/18/2022 03:00	1	1
12/18/2022 04:00	1	1
12/18/2022 05:00	1	1
12/18/2022 06:00	1	1
12/18/2022 07:00	1	1
12/18/2022 08:00	1	1
12/18/2022 09:00	1	1
12/18/2022 10:00	1	1
12/18/2022 11:00	1	1
12/18/2022 12:00	1	0
12/18/2022 13:00	1	0
12/18/2022 14:00	1	0
12/18/2022 15:00	1	0
12/18/2022 16:00	1	1
12/18/2022 17:00	1	1
12/18/2022 18:00	1	1
12/18/2022 19:00	1	1
12/18/2022 20:00	1	1
12/18/2022 21:00	1	1
12/18/2022 22:00	1	1
12/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/19/2022 00:00	1	1
12/19/2022 01:00	1	1
12/19/2022 02:00	1	1
12/19/2022 03:00	1	1
12/19/2022 04:00	1	1
12/19/2022 05:00	1	1
12/19/2022 06:00	1	1
12/19/2022 07:00	1	1
12/19/2022 08:00	1	1
12/19/2022 09:00	1	1
12/19/2022 10:00	1	1
12/19/2022 11:00	1	1
12/19/2022 12:00	1	1
12/19/2022 13:00	1	1
12/19/2022 14:00	1	1
12/19/2022 15:00	1	1
12/19/2022 16:00	1	1
12/19/2022 17:00	1	1
12/19/2022 18:00	1	1
12/19/2022 19:00	1	1
12/19/2022 20:00	1	1
12/19/2022 21:00	1	1
12/19/2022 22:00	1	1
12/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/20/2022 00:00	1	1
12/20/2022 01:00	1	1
12/20/2022 02:00	1	1
12/20/2022 03:00	1	1
12/20/2022 04:00	1	1
12/20/2022 05:00	1	1
12/20/2022 06:00	1	1
12/20/2022 07:00	1	1
12/20/2022 08:00	1	1
12/20/2022 09:00	1	1
12/20/2022 10:00	1	1
12/20/2022 11:00	1	1
12/20/2022 12:00	1	1
12/20/2022 13:00	1	1
12/20/2022 14:00	1	1
12/20/2022 15:00	1	1
12/20/2022 16:00	1	1
12/20/2022 17:00	1	1
12/20/2022 18:00	1	1
12/20/2022 19:00	1	1
12/20/2022 20:00	1	1
12/20/2022 21:00	1	1
12/20/2022 22:00	1	1
12/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/21/2022 00:00	1	1
12/21/2022 01:00	1	1
12/21/2022 02:00	1	1
12/21/2022 03:00	1	1
12/21/2022 04:00	1	1
12/21/2022 05:00	1	1
12/21/2022 06:00	1	1
12/21/2022 07:00	1	1
12/21/2022 08:00	1	1
12/21/2022 09:00	1	1
12/21/2022 10:00	1	1
12/21/2022 11:00	1	1
12/21/2022 12:00	1	1
12/21/2022 13:00	1	1
12/21/2022 14:00	1	1
12/21/2022 15:00	1	1
12/21/2022 16:00	1	1
12/21/2022 17:00	1	1
12/21/2022 18:00	1	1
12/21/2022 19:00	1	1
12/21/2022 20:00	1	1
12/21/2022 21:00	1	1
12/21/2022 22:00	1	1
12/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/22/2022 00:00	1	1
12/22/2022 01:00	1	1
12/22/2022 02:00	1	1
12/22/2022 03:00	1	1
12/22/2022 04:00	1	1
12/22/2022 05:00	1	1
12/22/2022 06:00	1	1
12/22/2022 07:00	1	1
12/22/2022 08:00	1	1
12/22/2022 09:00	1	1
12/22/2022 10:00	1	1
12/22/2022 11:00	1	1
12/22/2022 12:00	1	1
12/22/2022 13:00	1	1
12/22/2022 14:00	1	1
12/22/2022 15:00	1	1
12/22/2022 16:00	1	1
12/22/2022 17:00	1	1
12/22/2022 18:00	1	1
12/22/2022 19:00	1	1
12/22/2022 20:00	1	1
12/22/2022 21:00	1	1
12/22/2022 22:00	1	1
12/22/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/23/2022 00:00	1	1
12/23/2022 01:00	1	1
12/23/2022 02:00	1	1
12/23/2022 03:00	1	1
12/23/2022 04:00	1	1
12/23/2022 05:00	1	1
12/23/2022 06:00	1	1
12/23/2022 07:00	1	1
12/23/2022 08:00	1	1
12/23/2022 09:00	1	1
12/23/2022 10:00	1	1
12/23/2022 11:00	1	1
12/23/2022 12:00	1	1
12/23/2022 13:00	1	1
12/23/2022 14:00	1	1
12/23/2022 15:00	1	1
12/23/2022 16:00	1	1
12/23/2022 17:00	1	1
12/23/2022 18:00	1	1
12/23/2022 19:00	1	1
12/23/2022 20:00	1	1
12/23/2022 21:00	1	1
12/23/2022 22:00	1	1
12/23/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/24/2022 00:00	1	1
12/24/2022 01:00	1	1
12/24/2022 02:00	1	1
12/24/2022 03:00	1	1
12/24/2022 04:00	1	1
12/24/2022 05:00	1	1
12/24/2022 06:00	1	1
12/24/2022 07:00	1	1
12/24/2022 08:00	1	1
12/24/2022 09:00	1	1
12/24/2022 10:00	1	1
12/24/2022 11:00	1	1
12/24/2022 12:00	1	0
12/24/2022 13:00	1	1
12/24/2022 14:00	1	1
12/24/2022 15:00	1	1
12/24/2022 16:00	1	1
12/24/2022 17:00	1	1
12/24/2022 18:00	1	1
12/24/2022 19:00	1	1
12/24/2022 20:00	1	1
12/24/2022 21:00	1	1
12/24/2022 22:00	1	1
12/24/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/25/2022 00:00	1	1
12/25/2022 01:00	2	2
12/25/2022 02:00	2	2
12/25/2022 03:00	2	2
12/25/2022 04:00	2	2
12/25/2022 05:00	2	2
12/25/2022 06:00	2	2
12/25/2022 07:00	2	2
12/25/2022 08:00	2	2
12/25/2022 09:00	2	2
12/25/2022 10:00	2	2
12/25/2022 11:00	2	2
12/25/2022 12:00	2	2
12/25/2022 13:00	2	2
12/25/2022 14:00	2	2
12/25/2022 15:00	2	2
12/25/2022 16:00	2	2
12/25/2022 17:00	2	2
12/25/2022 18:00	2	15
12/25/2022 19:00	2	19
12/25/2022 20:00	2	22
12/25/2022 21:00	2	20
12/25/2022 22:00	2	7
12/25/2022 23:00	2	3
Average/Sum#:	2	5
Minimum:	1	1
Maximum:	2	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/26/2022 00:00	15	1
12/26/2022 01:00	19	1
12/26/2022 02:00	19	1
12/26/2022 03:00	18	1
12/26/2022 04:00	5	0
12/26/2022 05:00	1	1
12/26/2022 06:00	1	1
12/26/2022 07:00	1	1
12/26/2022 08:00	1	1
12/26/2022 09:00	1	0
12/26/2022 10:00	1	0
12/26/2022 11:00	1	0
12/26/2022 12:00	1	0
12/26/2022 13:00	1	0
12/26/2022 14:00	1	0
12/26/2022 15:00	1	0
12/26/2022 16:00	1	1
12/26/2022 17:00	1	1
12/26/2022 18:00	1	1
12/26/2022 19:00	1	1
12/26/2022 20:00	1	1
12/26/2022 21:00	1	1
12/26/2022 22:00	1	1
12/26/2022 23:00	2	2
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	19	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/27/2022 00:00	2	2
12/27/2022 01:00	2	2
12/27/2022 02:00	2	4
12/27/2022 03:00	2	4
12/27/2022 04:00	2	2
12/27/2022 05:00	5	3
12/27/2022 06:00	6	0
12/27/2022 07:00	6	1
12/27/2022 08:00	5	1
12/27/2022 09:00	2	1
12/27/2022 10:00	1	1
12/27/2022 11:00	1	1
12/27/2022 12:00	1	1
12/27/2022 13:00	1	1
12/27/2022 14:00	1	1
12/27/2022 15:00	1	1
12/27/2022 16:00	1	1
12/27/2022 17:00	1	1
12/27/2022 18:00	1	1
12/27/2022 19:00	1	1
12/27/2022 20:00	1	1
12/27/2022 21:00	1	1
12/27/2022 22:00	1	1
12/27/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	0
Maximum:	6	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/28/2022 00:00	1	1
12/28/2022 01:00	1	1
12/28/2022 02:00	1	0
12/28/2022 03:00	1	0
12/28/2022 04:00	1	0
12/28/2022 05:00	1	0
12/28/2022 06:00	1	0
12/28/2022 07:00	1	0
12/28/2022 08:00	1	1
12/28/2022 09:00	1	1
12/28/2022 10:00	1	0
12/28/2022 11:00	1	0
12/28/2022 12:00	1	0
12/28/2022 13:00	1	0
12/28/2022 14:00	1	0
12/28/2022 15:00	1	0
12/28/2022 16:00	1	1
12/28/2022 17:00	1	1
12/28/2022 18:00	1	1
12/28/2022 19:00	1	1
12/28/2022 20:00	1	1
12/28/2022 21:00	1	1
12/28/2022 22:00	1	1
12/28/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/29/2022 00:00	1	1
12/29/2022 01:00	1	1
12/29/2022 02:00	1	1
12/29/2022 03:00	1	1
12/29/2022 04:00	1	1
12/29/2022 05:00	1	1
12/29/2022 06:00	1	1
12/29/2022 07:00	1	1
12/29/2022 08:00	1	1
12/29/2022 09:00	1	1
12/29/2022 10:00	1	1
12/29/2022 11:00	1	1
12/29/2022 12:00	1	1
12/29/2022 13:00	1	1
12/29/2022 14:00	1	1
12/29/2022 15:00	1	1
12/29/2022 16:00	1	1
12/29/2022 17:00	1	1
12/29/2022 18:00	1	1
12/29/2022 19:00	1	1
12/29/2022 20:00	1	1
12/29/2022 21:00	1	1
12/29/2022 22:00	1	1
12/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/30/2022 00:00	2	2
12/30/2022 01:00	2	2
12/30/2022 02:00	2	2
12/30/2022 03:00	2	2
12/30/2022 04:00	2	2
12/30/2022 05:00	2	2
12/30/2022 06:00	2	2
12/30/2022 07:00	2	2
12/30/2022 08:00	2	2
12/30/2022 09:00	2	2
12/30/2022 10:00	2	2
12/30/2022 11:00	2	2
12/30/2022 12:00	2	2
12/30/2022 13:00	2	2
12/30/2022 14:00	2	2
12/30/2022 15:00	2	2
12/30/2022 16:00	2	2
12/30/2022 17:00	2	2
12/30/2022 18:00	2	2
12/30/2022 19:00	2	2
12/30/2022 20:00	2	2
12/30/2022 21:00	2	2
12/30/2022 22:00	2	2
12/30/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/31/2022 00:00	2	2
12/31/2022 01:00	2	2
12/31/2022 02:00	2	2
12/31/2022 03:00	2	2
12/31/2022 04:00	2	2
12/31/2022 05:00	2	2
12/31/2022 06:00	2	2
12/31/2022 07:00	2	2
12/31/2022 08:00	2	2
12/31/2022 09:00	2	2
12/31/2022 10:00	2	2
12/31/2022 11:00	2	2
12/31/2022 12:00	2	2
12/31/2022 13:00	2	2
12/31/2022 14:00	2	2
12/31/2022 15:00	2	2
12/31/2022 16:00	2	2
12/31/2022 17:00	2	2
12/31/2022 18:00	2	2
12/31/2022 19:00	2	2
12/31/2022 20:00	2	2
12/31/2022 21:00	2	2
12/31/2022 22:00	2	2
12/31/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:30 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 78.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**78.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:30 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 8.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**84.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:31 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:31 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:32 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:32 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:36 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:37 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:39 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:39 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:44 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:45 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:46 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:47 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:47 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:48 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:49 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:50 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:51 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s)
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/15/2022 14:00	11/15/2022 15:59	2	13 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	**1,689.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.88 %**
Percent Monitor Downtime:	**0.12 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Other known causes	2	100.00
8	Action	Quarterly Maintenance	2	100.00

Invalid Data Report

CT1 - Stack NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:51 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s)
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/15/2022 14:00	11/15/2022 15:59	2	13 - Maintenance	8 - Quarterly Maintenance

Total Operating Time:	**1,689.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.88 %**
Percent Monitor Downtime:	**0.12 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	2	100.00
8	Action	Quarterly Maintenance	2	100.00

Invalid Data Report

CT2 - Stack CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:52 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/04/2022 10:00	10/04/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	11/16/2022 11:00	11/16/2022 11:59	1	4 - Other known causes	3 - Performed manual calibration
3	12/21/2022 08:00	12/21/2022 08:59	1	5 - Unknown causes	3 - Performed manual calibration

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**3.00 Hour(s)**
Percent Monitor Availability:	**99.83 %**
Percent Monitor Downtime:	**0.17 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
3	Reason	Quality assurance calibration	1	33.33
5	Reason	Unknown causes	1	33.33
3	Action	Performed manual calibration	2	66.67
4	Action	Quarterly linearity/cga	1	33.33

Invalid Data Report

CT2 - Stack NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:52 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/04/2022 10:00	10/04/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	11/16/2022 11:00	11/16/2022 11:59	1	4 - Other known causes	3 - Performed manual calibration
3	12/21/2022 08:00	12/21/2022 08:59	1	5 - Unknown causes	3 - Performed manual calibration

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**3.00 Hour(s)**
Percent Monitor Availability:	**99.83 %**
Percent Monitor Downtime:	**0.17 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
3	Reason	Quality assurance calibration	1	33.33
5	Reason	Unknown causes	1	33.33
3	Action	Performed manual calibration	2	66.67
4	Action	Quarterly linearity/cga	1	33.33

ATTACHMENT 5
Hourly Emissions – VOC

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2022 00:00	-0.5	11.9	2,165.1	-0.1	1.5	1	1	1
10/01/2022 01:00	0.0	14.1	1,211.1	0.0	0.8	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.3	13.0	1,688.1	-0.1	1.2	2 #	1 #	2 #
Minimum:	-0.5	11.9	1,211.1	-0.1	0.8	0	0	0
Maximum:	0.0	14.1	2,165.1	0.0	1.5	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2022 02:00	0.0	17.5	336.0	0.0	0.2	1	0	0
10/03/2022 03:00	0.0	15.5	867.5	0.0	0.6	1	0	0
10/03/2022 04:00	0.3	13.8	1,711.7	0.4	1.2	1	1	0
10/03/2022 05:00	0.3	13.8	1,704.2	0.4	1.2	1	1	0
10/03/2022 06:00	0.3	13.8	1,701.6	0.4	1.2	1	1	0
10/03/2022 07:00	0.3	13.8	1,708.6	0.4	1.2	1	1	0
10/03/2022 08:00	0.4	13.8	1,718.8	0.4	1.2	1	1	0
10/03/2022 09:00	0.4	13.8	1,725.0	0.4	1.2	1	1	0
10/03/2022 10:00	0.2	13.9	1,728.2	0.3	1.2	1	1	0
10/03/2022 11:00	0.2	13.9	1,728.3	0.3	1.2	1	1	0
10/03/2022 12:00	0.2	13.9	1,728.4	0.3	1.2	1	1	0
10/03/2022 13:00	0.2	13.9	1,730.3	0.3	1.2	1	1	0
10/03/2022 14:00	0.2	13.9	1,724.6	0.3	1.2	1	1	0
10/03/2022 15:00	-0.1	13.6	1,766.0	0.1	1.2	1	1	1
10/03/2022 16:00	-1.1	12.3	2,061.1	-0.5	1.4	1	1	1
10/03/2022 17:00	-0.9	11.8	2,172.2	-0.4	1.5	1	1	1
10/03/2022 18:00	-0.8	11.6	2,206.8	-0.2	1.5	1	1	1
10/03/2022 19:00	-0.8	11.8	2,173.9	-0.2	1.5	1	1	1
10/03/2022 20:00	-0.8	11.7	2,187.2	-0.2	1.5	1	1	1
10/03/2022 21:00	-0.8	11.8	2,174.5	-0.2	1.5	1	1	1
10/03/2022 22:00	-0.8	12.0	2,152.4	-0.4	1.5	1	1	1
10/03/2022 23:00	-0.8	11.9	2,171.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.2	13.4	1,780.9	0.1	1.2	22 #	20 #	9 #
Minimum:	-1.1	11.6	336.0	-0.5	0.2	0	0	0
Maximum:	0.4	17.5	2,206.8	0.4	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2022 00:00	-0.8	12.0	2,154.5	-0.4	1.5	1	1	1
10/04/2022 01:00	-0.8	12.0	2,158.5	-0.4	1.5	1	1	1
10/04/2022 02:00	-0.8	12.0	2,156.3	-0.4	1.5	1	1	1
10/04/2022 03:00	-0.8	12.0	2,166.2	-0.4	1.5	1	1	1
10/04/2022 04:00	-0.8	12.0	2,173.6	-0.4	1.5	1	1	1
10/04/2022 05:00	-0.7	11.8	2,201.6	-0.2	1.5	1	1	1
10/04/2022 06:00	-0.7	12.0	2,166.7	-0.2	1.5	1	1	1
10/04/2022 07:00	-0.7	12.6	2,035.8	-0.2	1.4	1	1	1
10/04/2022 08:00	0.3	13.7	1,595.1	0.4	1.1	1	1	0
10/04/2022 09:00	0.2	13.8	1,547.9	0.3	1.1	1	1	0
10/04/2022 10:00	0.1	13.7	1,555.2	0.2	1.1	1	1	0
10/04/2022 11:00	0.1	13.7	1,564.0	0.2	1.1	1	1	0
10/04/2022 12:00	0.2	13.7	1,722.8	0.3	1.2	1	1	0
10/04/2022 13:00	-0.1	13.8	1,747.1	0.1	1.2	1	1	1
10/04/2022 14:00	-1.2	12.8	2,032.9	-0.7	1.4	1	1	1
10/04/2022 15:00	-0.9	12.0	2,150.2	-0.4	1.5	1	1	1
10/04/2022 16:00	-0.8	12.1	2,131.5	-0.4	1.5	1	1	1
10/04/2022 17:00	-0.8	12.0	2,143.7	-0.4	1.5	1	1	1
10/04/2022 18:00	-0.8	11.9	2,169.2	-0.4	1.5	1	1	1
10/04/2022 19:00	-0.8	11.9	2,185.2	-0.4	1.5	1	1	1
10/04/2022 20:00	-0.7	11.6	2,243.7	-0.2	1.6	1	1	1
10/04/2022 21:00	-0.7	11.9	2,190.4	-0.2	1.5	1	1	1
10/04/2022 22:00	-0.7	11.9	2,177.9	-0.2	1.5	1	1	1
10/04/2022 23:00	-0.8	12.2	2,144.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,021.5	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.6	1,547.9	-0.7	1.1	1	1	0
Maximum:	0.3	13.8	2,243.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	-0.8	12.2	2,136.7	-0.4	1.5	1	1	1
10/05/2022 01:00	-0.8	12.8	1,998.7	-0.4	1.4	1	1	1
10/05/2022 02:00	-0.9	13.0	1,971.1	-0.5	1.4	1	1	1
10/05/2022 03:00	-0.9	12.5	2,085.4	-0.5	1.5	1	1	1
10/05/2022 04:00	-0.9	12.3	2,111.1	-0.5	1.5	1	1	1
10/05/2022 05:00	-0.8	11.9	2,200.3	-0.4	1.5	1	1	1
10/05/2022 06:00	-0.7	11.9	2,201.4	-0.2	1.5	1	1	1
10/05/2022 07:00	-0.9	12.9	1,985.2	-0.5	1.4	1	1	1
10/05/2022 08:00	0.3	13.9	1,718.1	0.4	1.2	1	1	0
10/05/2022 09:00	0.3	13.9	1,682.9	0.4	1.2	1	1	0
10/05/2022 10:00	0.2	13.9	1,710.7	0.3	1.2	1	1	0
10/05/2022 11:00	0.2	13.9	1,722.4	0.3	1.2	1	1	0
10/05/2022 12:00	-0.4	13.8	1,738.9	-0.2	1.2	1	1	1
10/05/2022 13:00	-1.2	12.4	2,080.5	-0.7	1.5	1	1	1
10/05/2022 14:00	-0.9	11.8	2,190.4	-0.4	1.5	1	1	1
10/05/2022 15:00	-0.9	12.1	2,137.1	-0.4	1.5	1	1	1
10/05/2022 16:00	-0.8	11.9	2,159.1	-0.4	1.5	1	1	1
10/05/2022 17:00	-0.7	11.7	2,198.2	-0.2	1.5	1	1	1
10/05/2022 18:00	-0.7	11.6	2,230.9	-0.2	1.6	1	1	1
10/05/2022 19:00	-0.7	11.6	2,240.8	-0.2	1.6	1	1	1
10/05/2022 20:00	-0.7	11.9	2,190.7	-0.2	1.5	1	1	1
10/05/2022 21:00	-0.7	11.6	2,237.8	-0.2	1.6	1	1	1
10/05/2022 22:00	-0.8	12.0	2,166.4	-0.4	1.5	1	1	1
10/05/2022 23:00	-0.8	12.0	2,176.0	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,053.0	-0.2	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.6	1,682.9	-0.7	1.2	1	1	0
Maximum:	0.3	13.9	2,240.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	-0.8	12.1	2,165.7	-0.4	1.5	1	1	1
10/06/2022 01:00	-0.8	12.1	2,167.7	-0.4	1.5	1	1	1
10/06/2022 02:00	-0.8	12.1	2,165.0	-0.4	1.5	1	1	1
10/06/2022 03:00	-0.8	12.2	2,141.6	-0.4	1.5	1	1	1
10/06/2022 04:00	-0.5	12.0	2,181.3	-0.1	1.5	1	1	1
10/06/2022 05:00	-0.7	11.6	2,250.8	-0.2	1.6	1	1	1
10/06/2022 06:00	-0.5	11.8	2,238.5	-0.1	1.6	1	1	1
10/06/2022 07:00	-0.8	12.2	2,135.9	-0.4	1.5	1	1	1
10/06/2022 08:00	-0.8	12.4	2,082.9	-0.4	1.5	1	1	1
10/06/2022 09:00	-0.8	12.5	2,071.3	-0.4	1.4	1	1	1
10/06/2022 10:00	-0.8	12.5	2,082.0	-0.4	1.5	1	1	1
10/06/2022 11:00	-0.8	12.3	2,114.5	-0.4	1.5	1	1	1
10/06/2022 12:00	-0.8	12.1	2,136.7	-0.4	1.5	1	1	1
10/06/2022 13:00	-0.7	11.8	2,192.4	-0.2	1.5	1	1	1
10/06/2022 14:00	-0.7	11.8	2,197.6	-0.2	1.5	1	1	1
10/06/2022 15:00	-0.7	12.0	2,150.8	-0.2	1.5	1	1	1
10/06/2022 16:00	-0.7	11.8	2,191.5	-0.2	1.5	1	1	1
10/06/2022 17:00	-0.5	11.6	2,240.1	-0.1	1.6	1	1	1
10/06/2022 18:00	-0.5	11.7	2,239.0	-0.1	1.6	1	1	1
10/06/2022 19:00	-0.5	11.6	2,255.1	-0.1	1.6	1	1	1
10/06/2022 20:00	-0.5	11.6	2,259.5	-0.1	1.6	1	1	1
10/06/2022 21:00	-0.5	11.7	2,245.4	-0.1	1.6	1	1	1
10/06/2022 22:00	-0.7	12.0	2,190.1	-0.2	1.5	1	1	1
10/06/2022 23:00	-0.8	12.1	2,168.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,177.7	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	2,071.3	-0.4	1.4	1	1	1
Maximum:	-0.5	12.5	2,259.5	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	-0.8	12.2	2,143.9	-0.4	1.5	1	1	1
10/07/2022 01:00	-0.8	12.2	2,159.9	-0.4	1.5	1	1	1
10/07/2022 02:00	-0.8	12.2	2,141.6	-0.4	1.5	1	1	1
10/07/2022 03:00	-0.8	12.3	2,114.7	-0.4	1.5	1	1	1
10/07/2022 04:00	-0.8	12.2	2,155.6	-0.4	1.5	1	1	1
10/07/2022 05:00	-0.8	12.0	2,191.6	-0.4	1.5	1	1	1
10/07/2022 06:00	-0.7	12.0	2,204.6	-0.2	1.5	1	1	1
10/07/2022 07:00	-0.8	12.4	2,110.8	-0.4	1.5	1	1	1
10/07/2022 08:00	-0.8	12.7	2,030.0	-0.4	1.4	1	1	1
10/07/2022 09:00	-0.8	12.3	2,127.6	-0.4	1.5	1	1	1
10/07/2022 10:00	-0.8	12.3	2,127.5	-0.4	1.5	1	1	1
10/07/2022 11:00	-0.8	12.3	2,111.0	-0.4	1.5	1	1	1
10/07/2022 12:00	-0.8	12.0	2,168.6	-0.4	1.5	1	1	1
10/07/2022 13:00	-0.8	12.1	2,136.9	-0.4	1.5	1	1	1
10/07/2022 14:00	-0.7	11.9	2,182.3	-0.2	1.5	1	1	1
10/07/2022 15:00	-0.7	11.8	2,193.0	-0.2	1.5	1	1	1
10/07/2022 16:00	-0.7	11.9	2,179.2	-0.2	1.5	1	1	1
10/07/2022 17:00	-0.7	11.6	2,229.9	-0.2	1.6	1	1	1
10/07/2022 18:00	-0.5	11.6	2,243.3	-0.1	1.6	1	1	1
10/07/2022 19:00	-0.5	11.6	2,258.3	-0.1	1.6	1	1	1
10/07/2022 20:00	-0.5	11.6	2,262.5	-0.1	1.6	1	1	1
10/07/2022 21:00	-0.5	11.6	2,265.6	-0.1	1.6	1	1	1
10/07/2022 22:00	-0.5	11.7	2,257.3	-0.1	1.6	1	1	1
10/07/2022 23:00	-0.7	12.0	2,184.9	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,174.2	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	2,030.0	-0.4	1.4	1	1	1
Maximum:	-0.5	12.7	2,265.6	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	-0.8	12.1	2,173.3	-0.4	1.5	1	1	1
10/08/2022 01:00	-0.8	12.1	2,176.2	-0.4	1.5	1	1	1
10/08/2022 02:00	-0.8	12.1	2,167.4	-0.4	1.5	1	1	1
10/08/2022 03:00	-0.8	12.1	2,178.3	-0.4	1.5	1	1	1
10/08/2022 04:00	-0.8	12.0	2,176.1	-0.4	1.5	1	1	1
10/08/2022 05:00	-0.8	12.1	2,170.4	-0.4	1.5	1	1	1
10/08/2022 06:00	-0.8	12.3	2,110.4	-0.4	1.5	1	1	1
10/08/2022 07:00	-0.1	13.8	1,711.8	0.1	1.2	1	1	1
10/08/2022 08:00	0.1	13.9	1,365.6	0.2	1.0	1	1	0
10/08/2022 09:00	0.3	13.9	1,315.8	0.4	0.9	1	1	0
10/08/2022 10:00	0.3	14.0	1,312.6	0.4	0.9	1	1	0
10/08/2022 11:00	0.3	14.0	1,318.8	0.4	0.9	1	1	0
10/08/2022 12:00	0.2	13.8	1,569.8	0.3	1.1	1	1	0
10/08/2022 13:00	0.2	13.8	1,728.0	0.3	1.2	1	1	0
10/08/2022 14:00	-0.1	13.7	1,745.1	0.1	1.2	1	1	1
10/08/2022 15:00	-0.9	12.2	2,069.6	-0.4	1.4	1	1	1
10/08/2022 16:00	-0.8	11.7	2,201.9	-0.2	1.5	1	1	1
10/08/2022 17:00	-0.7	11.7	2,201.4	-0.2	1.5	1	1	1
10/08/2022 18:00	-0.8	11.9	2,167.0	-0.4	1.5	1	1	1
10/08/2022 19:00	-0.8	11.9	2,177.6	-0.4	1.5	1	1	1
10/08/2022 20:00	-0.8	11.9	2,180.4	-0.4	1.5	1	1	1
10/08/2022 21:00	-0.8	11.9	2,177.9	-0.4	1.5	1	1	1
10/08/2022 22:00	-0.8	12.0	2,173.3	-0.4	1.5	1	1	1
10/08/2022 23:00	-0.8	12.1	2,170.3	-0.4	1.5	1	1	1
Average/Sum#:	-0.5	12.6	1,947.5	-0.2	1.3	24 #	24 #	18 #
Minimum:	-0.9	11.7	1,312.6	-0.4	0.9	1	1	0
Maximum:	0.3	14.0	2,201.9	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	-0.8	12.0	2,166.8	-0.4	1.5	1	1	1
10/09/2022 01:00	-0.8	12.1	2,167.0	-0.4	1.5	1	1	1
10/09/2022 02:00	-0.8	12.2	2,138.4	-0.4	1.5	1	1	1
10/09/2022 03:00	-0.9	12.2	2,147.8	-0.4	1.5	1	1	1
10/09/2022 04:00	-0.8	12.1	2,158.6	-0.4	1.5	1	1	1
10/09/2022 05:00	-0.8	12.1	2,149.2	-0.4	1.5	1	1	1
10/09/2022 06:00	0.0	13.0	1,685.1	0.0	1.2	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	18.7	209.6	0.0	0.1	1	0	0
10/09/2022 11:00	0.0	15.6	799.9	0.0	0.6	1	0	0
10/09/2022 12:00	0.3	13.9	1,387.0	0.4	1.0	1	1	0
10/09/2022 13:00	0.3	14.0	1,390.9	0.4	1.0	1	1	0
10/09/2022 14:00	0.2	13.7	1,726.4	0.3	1.2	1	1	0
10/09/2022 15:00	0.2	13.8	1,562.3	0.3	1.1	1	1	0
10/09/2022 16:00	0.2	13.8	1,729.7	0.3	1.2	1	1	0
10/09/2022 17:00	-0.1	13.6	1,781.5	0.1	1.2	1	1	1
10/09/2022 18:00	-1.2	12.3	2,081.7	-0.7	1.5	1	1	1
10/09/2022 19:00	-0.8	11.7	2,209.0	-0.2	1.5	1	1	1
10/09/2022 20:00	-0.8	11.8	2,188.3	-0.2	1.5	1	1	1
10/09/2022 21:00	-0.8	11.9	2,174.8	-0.4	1.5	1	1	1
10/09/2022 22:00	-0.8	12.0	2,156.1	-0.4	1.5	1	1	1
10/09/2022 23:00	-0.8	12.1	2,147.1	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	13.1	1,817.0	-0.1	1.3	21 #	18 #	14 #
Minimum:	-1.2	11.7	209.6	-0.7	0.1	0	0	0
Maximum:	0.3	18.7	2,209.0	0.4	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	-0.8	12.2	2,121.9	-0.4	1.5	1	1	1
10/10/2022 01:00	-0.8	12.4	2,092.6	-0.4	1.5	1	1	1
10/10/2022 02:00	-1.1	12.9	1,980.8	-0.7	1.4	1	1	1
10/10/2022 03:00	-0.9	12.4	2,083.6	-0.5	1.5	1	1	1
10/10/2022 04:00	-0.8	12.3	2,127.1	-0.4	1.5	1	1	1
10/10/2022 05:00	-0.7	11.8	2,214.2	-0.2	1.5	1	1	1
10/10/2022 06:00	-0.7	11.9	2,205.4	-0.2	1.5	1	1	1
10/10/2022 07:00	-0.4	13.3	1,816.6	-0.1	1.3	1	1	1
10/10/2022 08:00	0.1	13.8	1,551.8	0.2	1.1	1	1	0
10/10/2022 09:00	0.3	13.9	1,545.1	0.4	1.1	1	1	0
10/10/2022 10:00	0.3	14.0	1,390.8	0.4	1.0	1	1	0
10/10/2022 11:00	0.3	13.9	1,560.6	0.4	1.1	1	1	0
10/10/2022 12:00	0.3	13.9	1,574.2	0.4	1.1	1	1	0
10/10/2022 13:00	0.3	13.8	1,729.9	0.4	1.2	1	1	0
10/10/2022 14:00	0.2	13.8	1,718.4	0.3	1.2	1	1	0
10/10/2022 15:00	0.2	13.8	1,602.6	0.3	1.1	1	1	0
10/10/2022 16:00	-1.1	12.6	1,973.3	-0.7	1.4	1	1	1
10/10/2022 17:00	-0.9	11.9	2,163.0	-0.4	1.5	1	1	1
10/10/2022 18:00	-0.8	11.7	2,198.7	-0.2	1.5	1	1	1
10/10/2022 19:00	-0.9	11.8	2,169.1	-0.4	1.5	1	1	1
10/10/2022 20:00	-0.9	11.9	2,160.6	-0.4	1.5	1	1	1
10/10/2022 21:00	-1.1	12.2	2,102.8	-0.5	1.5	1	1	1
10/10/2022 22:00	-1.1	12.4	2,085.4	-0.5	1.5	1	1	1
10/10/2022 23:00	-1.1	12.9	1,953.3	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	12.8	1,921.7	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.1	11.7	1,390.8	-0.7	1.0	1	1	0
Maximum:	0.3	14.0	2,214.2	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.1	13.9	1,376.2	0.1	1.0	1	1	0
10/11/2022 01:00	0.2	13.9	1,300.5	0.3	0.9	1	1	0
10/11/2022 02:00	0.2	13.9	1,300.2	0.3	0.9	1	1	0
10/11/2022 03:00	0.1	13.9	1,352.3	0.2	0.9	1	1	0
10/11/2022 04:00	0.2	13.9	1,495.7	0.3	1.0	1	1	0
10/11/2022 05:00	0.1	13.9	1,319.9	0.1	0.9	1	1	0
10/11/2022 06:00	0.0	13.9	1,313.8	0.1	0.9	1	1	0
10/11/2022 07:00	0.1	13.9	1,315.9	0.1	0.9	1	1	0
10/11/2022 08:00	0.1	13.9	1,317.2	0.2	0.9	1	1	0
10/11/2022 09:00	0.2	13.9	1,480.0	0.3	1.0	1	1	0
10/11/2022 10:00	0.2	13.9	1,548.1	0.3	1.1	1	1	0
10/11/2022 11:00	0.3	13.8	1,635.9	0.4	1.1	1	1	0
10/11/2022 12:00	0.2	13.6	1,802.5	0.3	1.3	1	1	0
10/11/2022 13:00	0.2	13.6	1,793.7	0.3	1.3	1	1	0
10/11/2022 14:00	0.2	13.6	1,789.9	0.3	1.3	1	1	0
10/11/2022 15:00	0.2	13.6	1,787.5	0.3	1.3	1	1	0
10/11/2022 16:00	0.2	13.6	1,788.3	0.3	1.3	1	1	0
10/11/2022 17:00	0.2	13.6	1,789.6	0.3	1.3	1	1	0
10/11/2022 18:00	-0.1	13.6	1,794.2	0.1	1.3	1	1	1
10/11/2022 19:00	-1.1	12.6	2,005.4	-0.7	1.4	1	1	1
10/11/2022 20:00	-0.9	12.1	2,131.3	-0.4	1.5	1	1	1
10/11/2022 21:00	-0.8	12.4	2,034.7	-0.4	1.4	1	1	1
10/11/2022 22:00	-0.8	12.2	2,102.6	-0.4	1.5	1	1	1
10/11/2022 23:00	-0.7	12.8	1,971.1	-0.4	1.4	1	1	1
Average/Sum#:	-0.1	13.5	1,647.8	0.1	1.2	24 #	24 #	6 #
Minimum:	-1.1	12.1	1,300.2	-0.7	0.9	1	1	0
Maximum:	0.3	13.9	2,131.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2022 00:00	-0.9	13.0	1,958.1	-0.5	1.4	1	1	1
10/12/2022 01:00	-0.9	13.0	1,935.0	-0.5	1.4	1	1	1
10/12/2022 02:00	0.1	13.8	1,519.8	0.2	1.1	1	1	0
10/12/2022 03:00	0.2	13.9	1,637.4	0.3	1.1	1	1	0
10/12/2022 04:00	0.2	13.7	1,768.9	0.3	1.2	1	1	0
10/12/2022 05:00	-1.1	12.0	2,131.1	-0.5	1.5	1	1	1
10/12/2022 06:00	-0.8	11.7	2,260.0	-0.2	1.6	1	1	1
10/12/2022 07:00	-0.7	11.7	2,255.1	-0.2	1.6	1	1	1
10/12/2022 08:00	-0.7	11.7	2,247.7	-0.2	1.6	1	1	1
10/12/2022 09:00	-0.7	11.7	2,246.9	-0.2	1.6	1	1	1
10/12/2022 10:00	-0.7	11.7	2,242.0	-0.2	1.6	1	1	1
10/12/2022 11:00	-0.7	11.7	2,245.9	-0.2	1.6	1	1	1
10/12/2022 12:00	-0.5	11.6	2,250.7	-0.1	1.6	1	1	1
10/12/2022 13:00	-0.5	11.6	2,248.0	-0.1	1.6	1	1	1
10/12/2022 14:00	-0.7	11.6	2,249.4	-0.2	1.6	1	1	1
10/12/2022 15:00	-0.7	11.6	2,250.4	-0.2	1.6	1	1	1
10/12/2022 16:00	-0.7	11.4	2,266.7	-0.2	1.6	1	1	1
10/12/2022 17:00	-0.7	11.4	2,274.9	-0.2	1.6	1	1	1
10/12/2022 18:00	-0.7	11.6	2,233.1	-0.2	1.6	1	1	1
10/12/2022 19:00	-0.9	12.1	2,138.2	-0.4	1.5	1	1	1
10/12/2022 20:00	-0.9	12.0	2,147.6	-0.4	1.5	1	1	1
10/12/2022 21:00	-0.9	12.2	2,119.1	-0.4	1.5	1	1	1
10/12/2022 22:00	-1.1	12.4	2,086.8	-0.5	1.5	1	1	1
10/12/2022 23:00	-1.2	12.9	1,967.8	-0.8	1.4	1	1	1
Average/Sum#:	-0.7	12.2	2,111.7	-0.2	1.5	24 #	24 #	21 #
Minimum:	-1.2	11.4	1,519.8	-0.8	1.1	1	1	0
Maximum:	0.2	13.9	2,274.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	-1.4	12.9	1,961.3	-0.8	1.4	1	1	1
10/13/2022 01:00	-1.2	12.7	2,005.0	-0.7	1.4	1	1	1
10/13/2022 02:00	-1.5	13.0	1,953.3	-0.9	1.4	1	1	1
10/13/2022 03:00	-1.4	13.0	1,959.2	-0.8	1.4	1	1	1
10/13/2022 04:00	-1.2	13.0	1,926.0	-0.8	1.3	1	1	1
10/13/2022 05:00	0.0	13.9	1,311.2	0.1	0.9	1	1	0
10/13/2022 06:00	0.0	13.9	1,311.4	0.1	0.9	1	1	0
10/13/2022 07:00	0.1	13.9	1,339.8	0.1	0.9	1	1	0
10/13/2022 08:00	0.2	13.8	1,587.0	0.3	1.1	1	1	0
10/13/2022 09:00	0.2	13.8	1,535.6	0.3	1.1	1	1	0
10/13/2022 10:00	0.2	13.6	1,804.0	0.3	1.3	1	1	0
10/13/2022 11:00	0.2	13.5	1,810.3	0.3	1.3	1	1	0
10/13/2022 12:00	0.2	13.6	1,808.3	0.3	1.3	1	1	0
10/13/2022 13:00	0.2	13.6	1,802.3	0.3	1.3	1	1	0
10/13/2022 14:00	0.2	13.6	1,793.3	0.3	1.3	1	1	0
10/13/2022 15:00	0.2	13.6	1,792.5	0.3	1.3	1	1	0
10/13/2022 16:00	0.2	13.6	1,790.7	0.3	1.3	1	1	0
10/13/2022 17:00	0.2	13.6	1,796.8	0.3	1.3	1	1	0
10/13/2022 18:00	0.2	13.5	1,804.3	0.3	1.3	1	1	0
10/13/2022 19:00	-0.2	13.5	1,807.0	-0.1	1.3	1	1	1
10/13/2022 20:00	-1.2	12.4	2,059.6	-0.7	1.4	1	1	1
10/13/2022 21:00	-1.1	12.0	2,159.9	-0.5	1.5	1	1	1
10/13/2022 22:00	-0.9	12.4	2,083.7	-0.5	1.5	1	1	1
10/13/2022 23:00	-0.9	12.5	2,071.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.4	13.3	1,803.1	-0.1	1.3	24 #	24 #	10 #
Minimum:	-1.5	12.0	1,311.2	-0.9	0.9	1	1	0
Maximum:	0.2	13.9	2,159.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	-0.8	12.6	2,061.0	-0.4	1.4	1	1	1
10/14/2022 01:00	-0.8	12.5	2,055.5	-0.4	1.4	1	1	1
10/14/2022 02:00	-0.8	12.5	2,056.0	-0.4	1.4	1	1	1
10/14/2022 03:00	-0.7	12.5	2,053.2	-0.2	1.4	1	1	1
10/14/2022 04:00	-0.7	12.3	2,098.1	-0.2	1.5	1	1	1
10/14/2022 05:00	-0.5	11.5	2,254.4	-0.1	1.6	1	1	1
10/14/2022 06:00	-0.4	11.5	2,261.5	0.1	1.6	1	1	1
10/14/2022 07:00	-0.4	11.5	2,266.0	0.1	1.6	1	1	1
10/14/2022 08:00	-0.7	12.5	2,033.0	-0.2	1.4	1	1	1
10/14/2022 09:00	-0.8	12.9	1,968.5	-0.4	1.4	1	1	1
10/14/2022 10:00	-0.8	12.7	1,978.5	-0.4	1.4	1	1	1
10/14/2022 11:00	-0.8	12.7	1,988.2	-0.4	1.4	1	1	1
10/14/2022 12:00	-0.8	12.7	1,992.9	-0.4	1.4	1	1	1
10/14/2022 13:00	-0.8	12.6	1,998.9	-0.4	1.4	1	1	1
10/14/2022 14:00	-0.8	12.2	2,104.1	-0.4	1.5	1	1	1
10/14/2022 15:00	-0.8	12.0	2,146.5	-0.4	1.5	1	1	1
10/14/2022 16:00	-0.7	12.0	2,145.1	-0.2	1.5	1	1	1
10/14/2022 17:00	-0.7	11.5	2,227.8	-0.2	1.6	1	1	1
10/14/2022 18:00	-0.8	11.9	2,153.4	-0.4	1.5	1	1	1
10/14/2022 19:00	-0.8	12.1	2,127.2	-0.4	1.5	1	1	1
10/14/2022 20:00	-0.8	12.0	2,134.2	-0.4	1.5	1	1	1
10/14/2022 21:00	-0.8	12.1	2,122.5	-0.4	1.5	1	1	1
10/14/2022 22:00	-0.8	12.3	2,095.3	-0.4	1.5	1	1	1
10/14/2022 23:00	0.0	13.9	1,333.3	0.0	0.9	1	0	1
Average/Sum#:	-0.7	12.3	2,069.0	-0.3	1.5	24 #	23 #	24 #
Minimum:	-0.8	11.5	1,333.3	-0.4	0.9	1	0	1
Maximum:	0.0	13.9	2,266.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 23:00	0.0	17.8	305.8	0.0	0.2	1	0	0
Average/Sum#:	0.0	17.8	305.8	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	17.8	305.8	0.0	0.2	0	0	0
Maximum:	0.0	17.8	305.8	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.0	15.6	846.3	0.0	0.6	1	0	0
10/17/2022 01:00	0.2	13.8	1,704.0	0.3	1.2	1	1	0
10/17/2022 02:00	0.2	13.8	1,714.0	0.3	1.2	1	1	0
10/17/2022 03:00	-0.1	13.7	1,810.2	0.1	1.3	1	1	1
10/17/2022 04:00	-0.9	12.3	2,087.2	-0.5	1.5	1	1	1
10/17/2022 05:00	-0.8	11.9	2,182.2	-0.4	1.5	1	1	1
10/17/2022 06:00	-0.8	12.2	2,151.6	-0.4	1.5	1	1	1
10/17/2022 07:00	-0.8	12.4	2,100.6	-0.4	1.5	1	1	1
10/17/2022 08:00	-0.2	13.6	1,691.4	-0.1	1.2	1	1	1
10/17/2022 09:00	0.3	13.8	1,644.4	0.4	1.2	1	1	0
10/17/2022 10:00	0.2	13.9	1,523.9	0.3	1.1	1	1	0
10/17/2022 11:00	0.3	13.8	1,608.2	0.4	1.1	1	1	0
10/17/2022 12:00	0.2	13.9	1,506.8	0.3	1.1	1	1	0
10/17/2022 13:00	0.2	13.9	1,513.1	0.3	1.1	1	1	0
10/17/2022 14:00	0.3	13.9	1,670.2	0.4	1.2	1	1	0
10/17/2022 15:00	-0.1	13.7	1,713.7	0.1	1.2	1	1	1
10/17/2022 16:00	-0.9	12.4	2,086.6	-0.5	1.5	1	1	1
10/17/2022 17:00	-0.7	11.6	2,242.9	-0.2	1.6	1	1	1
10/17/2022 18:00	-0.7	11.6	2,260.4	-0.2	1.6	1	1	1
10/17/2022 19:00	-0.7	11.7	2,236.0	-0.2	1.6	1	1	1
10/17/2022 20:00	-0.7	11.7	2,243.1	-0.2	1.6	1	1	1
10/17/2022 21:00	-0.7	11.6	2,256.3	-0.2	1.6	1	1	1
10/17/2022 22:00	-0.8	12.0	2,182.4	-0.4	1.5	1	1	1
10/17/2022 23:00	-0.8	12.0	2,180.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.0	1,881.5	-0.1	1.3	24 #	23 #	15 #
Minimum:	-0.9	11.6	846.3	-0.5	0.6	1	0	0
Maximum:	0.3	15.6	2,260.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	-0.8	12.0	2,175.4	-0.4	1.5	1	1	1
10/18/2022 01:00	-0.7	12.1	2,166.0	-0.2	1.5	1	1	1
10/18/2022 02:00	-0.5	12.0	2,168.9	-0.1	1.5	1	1	1
10/18/2022 03:00	-0.5	11.9	2,193.4	-0.1	1.5	1	1	1
10/18/2022 04:00	-0.5	11.9	2,192.8	-0.1	1.5	1	1	1
10/18/2022 05:00	-0.5	12.0	2,173.8	-0.1	1.5	1	1	1
10/18/2022 06:00	-0.7	12.2	2,149.9	-0.2	1.5	1	1	1
10/18/2022 07:00	-0.7	12.1	2,148.0	-0.2	1.5	1	1	1
10/18/2022 08:00	-0.8	12.1	2,167.9	-0.4	1.5	1	1	1
10/18/2022 09:00	-0.8	12.1	2,165.6	-0.4	1.5	1	1	1
10/18/2022 10:00	-0.9	12.2	2,133.5	-0.4	1.5	1	1	1
10/18/2022 11:00	-0.9	12.3	2,107.8	-0.5	1.5	1	1	1
10/18/2022 12:00	-0.8	12.3	2,105.5	-0.4	1.5	1	1	1
10/18/2022 13:00	-0.9	12.3	2,109.2	-0.5	1.5	1	1	1
10/18/2022 14:00	-0.9	12.2	2,117.2	-0.4	1.5	1	1	1
10/18/2022 15:00	-0.9	12.1	2,149.3	-0.4	1.5	1	1	1
10/18/2022 16:00	-0.7	11.7	2,239.2	-0.2	1.6	1	1	1
10/18/2022 17:00	-0.8	11.9	2,202.8	-0.4	1.5	1	1	1
10/18/2022 18:00	-0.7	11.7	2,249.3	-0.2	1.6	1	1	1
10/18/2022 19:00	-0.7	11.6	2,271.7	-0.2	1.6	1	1	1
10/18/2022 20:00	-0.7	11.6	2,277.4	-0.2	1.6	1	1	1
10/18/2022 21:00	-0.7	11.6	2,277.9	-0.2	1.6	1	1	1
10/18/2022 22:00	-0.8	11.9	2,202.9	-0.4	1.5	1	1	1
10/18/2022 23:00	-0.8	11.9	2,201.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,181.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	2,105.5	-0.5	1.5	1	1	1
Maximum:	-0.5	12.3	2,277.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2022 00:00	-0.9	12.0	2,189.4	-0.4	1.5	1	1	1
10/19/2022 01:00	-0.8	12.4	2,117.8	-0.4	1.5	1	1	1
10/19/2022 02:00	-0.7	12.5	2,070.1	-0.2	1.4	1	1	1
10/19/2022 03:00	-0.5	12.3	2,105.5	-0.1	1.5	1	1	1
10/19/2022 04:00	-0.5	12.1	2,139.4	-0.1	1.5	1	1	1
10/19/2022 05:00	-0.4	11.7	2,201.4	0.1	1.5	1	1	1
10/19/2022 06:00	-0.8	11.9	2,222.6	-0.4	1.6	1	1	1
10/19/2022 07:00	-0.9	12.2	2,151.9	-0.4	1.5	1	1	1
10/19/2022 08:00	-0.9	12.3	2,140.6	-0.5	1.5	1	1	1
10/19/2022 09:00	-0.9	12.4	2,101.5	-0.5	1.5	1	1	1
10/19/2022 10:00	-0.9	12.4	2,092.4	-0.5	1.5	1	1	1
10/19/2022 11:00	-0.9	12.2	2,121.8	-0.4	1.5	1	1	1
10/19/2022 12:00	-0.9	12.1	2,136.5	-0.4	1.5	1	1	1
10/19/2022 13:00	-0.8	12.0	2,154.1	-0.4	1.5	1	1	1
10/19/2022 14:00	-0.8	12.1	2,145.1	-0.4	1.5	1	1	1
10/19/2022 15:00	-0.8	11.8	2,185.0	-0.2	1.5	1	1	1
10/19/2022 16:00	-0.8	11.7	2,199.7	-0.2	1.5	1	1	1
10/19/2022 17:00	-0.9	12.1	2,124.9	-0.4	1.5	1	1	1
10/19/2022 18:00	-0.9	12.2	2,109.1	-0.4	1.5	1	1	1
10/19/2022 19:00	-0.9	12.2	2,115.7	-0.4	1.5	1	1	1
10/19/2022 20:00	-0.9	12.1	2,154.7	-0.4	1.5	1	1	1
10/19/2022 21:00	-0.9	12.3	2,120.2	-0.5	1.5	1	1	1
10/19/2022 22:00	-0.9	12.4	2,092.4	-0.5	1.5	1	1	1
10/19/2022 23:00	-0.9	12.3	2,111.2	-0.5	1.5	1	1	1
Average/Sum#:	-0.8	12.2	2,137.6	-0.4	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.7	2,070.1	-0.5	1.4	1	1	1
Maximum:	-0.4	12.5	2,222.6	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	-0.9	12.3	2,129.2	-0.5	1.5	1	1	1
10/20/2022 01:00	-0.9	12.4	2,089.4	-0.5	1.5	1	1	1
10/20/2022 02:00	-0.9	12.5	2,083.4	-0.5	1.5	1	1	1
10/20/2022 03:00	-1.1	12.4	2,093.7	-0.5	1.5	1	1	1
10/20/2022 04:00	-0.9	12.3	2,133.0	-0.5	1.5	1	1	1
10/20/2022 05:00	-0.7	11.8	2,202.7	-0.2	1.5	1	1	1
10/20/2022 06:00	-0.8	12.0	2,196.1	-0.4	1.5	1	1	1
10/20/2022 07:00	-0.9	12.6	2,066.6	-0.5	1.4	1	1	1
10/20/2022 08:00	-0.9	12.6	2,058.0	-0.5	1.4	1	1	1
10/20/2022 09:00	-0.9	12.5	2,072.7	-0.5	1.5	1	1	1
10/20/2022 10:00	-0.9	12.5	2,068.4	-0.5	1.4	1	1	1
10/20/2022 11:00	-0.9	12.4	2,087.7	-0.5	1.5	1	1	1
10/20/2022 12:00	-0.9	12.3	2,089.8	-0.5	1.5	1	1	1
10/20/2022 13:00	-0.9	12.3	2,104.8	-0.5	1.5	1	1	1
10/20/2022 14:00	-0.9	12.2	2,117.9	-0.4	1.5	1	1	1
10/20/2022 15:00	-0.8	12.1	2,149.5	-0.4	1.5	1	1	1
10/20/2022 16:00	-0.7	11.5	2,255.7	-0.2	1.6	1	1	1
10/20/2022 17:00	-0.8	11.8	2,184.0	-0.2	1.5	1	1	1
10/20/2022 18:00	-0.8	11.7	2,231.4	-0.2	1.6	1	1	1
10/20/2022 19:00	-0.9	12.2	2,115.3	-0.4	1.5	1	1	1
10/20/2022 20:00	-0.9	12.2	2,110.7	-0.4	1.5	1	1	1
10/20/2022 21:00	-0.9	12.4	2,086.7	-0.5	1.5	1	1	1
10/20/2022 22:00	-0.9	12.4	2,088.4	-0.5	1.5	1	1	1
10/20/2022 23:00	-0.8	12.2	2,125.0	-0.4	1.5	1	1	1
Average/Sum#:	-0.9	12.2	2,122.5	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.5	2,058.0	-0.5	1.4	1	1	1
Maximum:	-0.7	12.6	2,255.7	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	-0.5	12.8	1,944.1	-0.2	1.4	1	1	1
10/21/2022 01:00	0.3	13.9	1,583.3	0.4	1.1	1	1	0
10/21/2022 02:00	0.3	13.9	1,597.9	0.4	1.1	1	1	0
10/21/2022 03:00	0.2	13.9	1,547.4	0.3	1.1	1	1	0
10/21/2022 04:00	0.3	13.9	1,708.6	0.4	1.2	1	1	0
10/21/2022 05:00	0.2	13.9	1,710.6	0.3	1.2	1	1	0
10/21/2022 06:00	0.2	13.9	1,608.8	0.3	1.1	1	1	0
10/21/2022 07:00	0.2	13.9	1,676.8	0.3	1.2	1	1	0
10/21/2022 08:00	0.3	13.9	1,716.7	0.4	1.2	1	1	0
10/21/2022 09:00	0.3	13.9	1,720.8	0.4	1.2	1	1	0
10/21/2022 10:00	0.3	13.9	1,719.5	0.4	1.2	1	1	0
10/21/2022 11:00	0.3	13.9	1,683.4	0.4	1.2	1	1	0
10/21/2022 12:00	0.2	13.8	1,661.0	0.3	1.2	1	1	0
10/21/2022 13:00	0.2	13.8	1,633.6	0.3	1.1	1	1	0
10/21/2022 14:00	0.1	13.8	1,692.1	0.2	1.2	1	1	0
10/21/2022 15:00	-0.4	13.8	1,568.6	-0.2	1.1	1	1	1
10/21/2022 16:00	-1.1	12.2	2,099.1	-0.5	1.5	1	1	1
10/21/2022 17:00	-0.9	11.8	2,183.0	-0.4	1.5	1	1	1
10/21/2022 18:00	-0.9	12.0	2,142.7	-0.4	1.5	1	1	1
10/21/2022 19:00	-1.1	12.3	2,098.0	-0.5	1.5	1	1	1
10/21/2022 20:00	-0.9	12.2	2,114.4	-0.4	1.5	1	1	1
10/21/2022 21:00	-0.9	11.9	2,175.3	-0.4	1.5	1	1	1
10/21/2022 22:00	0.0	14.0	1,230.6	0.0	0.9	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	13.4	1,774.6	0.1	1.2	23 #	22 #	9 #
Minimum:	-1.1	11.8	1,230.6	-0.5	0.9	0	0	0
Maximum:	0.3	14.0	2,183.0	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 12:00	0.0	21.0	2.2	0.0	0.0	1	0	0
10/24/2022 13:00	0.0	17.0	429.7	0.0	0.3	1	0	0
10/24/2022 14:00	0.0	14.1	1,572.3	0.0	1.1	1	0	0
10/24/2022 15:00	0.3	13.7	1,771.7	0.4	1.2	1	1	0
10/24/2022 16:00	0.3	13.7	1,770.8	0.4	1.2	1	1	0
10/24/2022 17:00	0.3	13.7	1,779.7	0.4	1.2	1	1	0
10/24/2022 18:00	0.3	13.7	1,791.6	0.4	1.3	1	1	0
10/24/2022 19:00	0.3	13.7	1,799.7	0.4	1.3	1	1	0
10/24/2022 20:00	0.3	13.7	1,806.0	0.4	1.3	1	1	0
10/24/2022 21:00	0.3	13.7	1,813.9	0.4	1.3	1	1	0
10/24/2022 22:00	0.3	13.7	1,810.6	0.4	1.3	1	1	0
10/24/2022 23:00	0.3	13.7	1,822.7	0.4	1.3	1	1	0
Average/Sum#:	0.2	14.6	1,514.2	0.3	1.1	12 #	9 #	0 #
Minimum:	0.0	13.7	2.2	0.0	0.0	0	0	0
Maximum:	0.3	21.0	1,822.7	0.4	1.3	1	1	0
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.3	13.7	1,809.3	0.4	1.3	1	1	0
10/25/2022 01:00	0.3	13.7	1,804.8	0.4	1.3	1	1	0
10/25/2022 02:00	0.3	13.8	1,804.4	0.4	1.3	1	1	0
10/25/2022 03:00	0.3	13.8	1,802.4	0.4	1.3	1	1	0
10/25/2022 04:00	0.3	13.8	1,805.0	0.4	1.3	1	1	0
10/25/2022 05:00	0.3	13.8	1,808.1	0.4	1.3	1	1	0
10/25/2022 06:00	0.3	13.8	1,808.2	0.4	1.3	1	1	0
10/25/2022 07:00	0.3	13.8	1,807.7	0.4	1.3	1	1	0
10/25/2022 08:00	0.3	13.7	1,812.1	0.4	1.3	1	1	0
10/25/2022 09:00	0.3	13.7	1,815.9	0.4	1.3	1	1	0
10/25/2022 10:00	0.3	13.7	1,814.8	0.4	1.3	1	1	0
10/25/2022 11:00	0.2	13.7	1,829.7	0.3	1.3	1	1	0
10/25/2022 12:00	0.2	13.7	1,832.3	0.3	1.3	1	1	0
10/25/2022 13:00	0.2	13.6	1,836.6	0.3	1.3	1	1	0
10/25/2022 14:00	0.2	13.6	1,831.6	0.3	1.3	1	1	0
10/25/2022 15:00	0.2	13.6	1,832.4	0.3	1.3	1	1	0
10/25/2022 16:00	0.2	13.6	1,831.0	0.3	1.3	1	1	0
10/25/2022 17:00	0.2	13.6	1,834.2	0.3	1.3	1	1	0
10/25/2022 18:00	0.2	13.7	1,826.1	0.3	1.3	1	1	0
10/25/2022 19:00	0.2	13.7	1,814.8	0.3	1.3	1	1	0
10/25/2022 20:00	0.2	13.7	1,807.6	0.3	1.3	1	1	0
10/25/2022 21:00	0.2	13.7	1,809.8	0.3	1.3	1	1	0
10/25/2022 22:00	0.3	13.7	1,804.5	0.4	1.3	1	1	0
10/25/2022 23:00	0.3	13.9	1,635.5	0.4	1.1	1	1	0
Average/Sum#:	0.3	13.7	1,809.1	0.4	1.3	24 #	24 #	0 #
Minimum:	0.2	13.6	1,635.5	0.3	1.1	1	1	0
Maximum:	0.3	13.9	1,836.6	0.4	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.3	13.8	1,630.9	0.4	1.1	1	1	0
10/26/2022 01:00	0.3	13.9	1,631.9	0.4	1.1	1	1	0
10/26/2022 02:00	0.3	13.9	1,628.9	0.4	1.1	1	1	0
10/26/2022 03:00	0.3	13.9	1,616.4	0.4	1.1	1	1	0
10/26/2022 04:00	0.3	13.8	1,794.6	0.4	1.3	1	1	0
10/26/2022 05:00	0.3	13.9	1,733.8	0.4	1.2	1	1	0
10/26/2022 06:00	0.3	13.9	1,691.8	0.4	1.2	1	1	0
10/26/2022 07:00	0.3	13.8	1,742.7	0.4	1.2	1	1	0
10/26/2022 08:00	0.0	15.4	735.2	0.0	0.5	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	18.3	240.1	0.0	0.2	1	0	0
10/26/2022 17:00	0.0	17.6	391.6	0.0	0.3	1	0	0
10/26/2022 18:00	0.0	15.4	828.0	0.0	0.6	1	0	0
10/26/2022 19:00	0.2	13.7	1,825.1	0.3	1.3	1	1	0
10/26/2022 20:00	0.2	13.7	1,820.3	0.3	1.3	1	1	0
10/26/2022 21:00	0.2	13.7	1,810.2	0.3	1.3	1	1	0
10/26/2022 22:00	0.2	13.7	1,764.5	0.3	1.2	1	1	0
10/26/2022 23:00	0.0	14.5	1,164.0	0.0	0.8	1	0	0
Average/Sum#:	0.2	14.5	1,414.7	0.3	1.0	17 #	12 #	0 #
Minimum:	0.0	13.7	240.1	0.0	0.2	0	0	0
Maximum:	0.3	18.3	1,825.1	0.4	1.3	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/31/2022 01:00	0.0	17.7	299.3	0.0	0.2	1	0	0
10/31/2022 02:00	0.0	16.0	725.0	0.0	0.5	1	0	0
10/31/2022 03:00	0.2	13.8	1,712.6	0.3	1.2	1	1	0
10/31/2022 04:00	0.2	13.8	1,726.3	0.3	1.2	1	1	0
10/31/2022 05:00	0.2	13.8	1,711.3	0.3	1.2	1	1	0
10/31/2022 06:00	0.2	13.8	1,692.8	0.3	1.2	1	1	0
10/31/2022 07:00	0.2	13.8	1,693.6	0.3	1.2	1	1	0
10/31/2022 08:00	0.2	13.8	1,704.5	0.3	1.2	1	1	0
10/31/2022 09:00	0.2	13.9	1,706.8	0.3	1.2	1	1	0
10/31/2022 10:00	0.2	13.9	1,708.4	0.3	1.2	1	1	0
10/31/2022 11:00	0.2	13.9	1,689.0	0.3	1.2	1	1	0
10/31/2022 12:00	0.3	13.9	1,687.9	0.4	1.2	1	1	0
10/31/2022 13:00	0.3	13.9	1,702.8	0.4	1.2	1	1	0
10/31/2022 14:00	-0.2	13.7	1,767.7	-0.1	1.2	1	1	1
10/31/2022 15:00	-1.2	12.5	2,082.4	-0.7	1.5	1	1	1
10/31/2022 16:00	-1.1	12.3	2,105.6	-0.5	1.5	1	1	1
10/31/2022 17:00	-1.1	12.4	2,076.3	-0.5	1.5	1	1	1
10/31/2022 18:00	-1.1	12.4	2,082.4	-0.5	1.5	1	1	1
10/31/2022 19:00	-1.1	12.4	2,103.6	-0.5	1.5	1	1	1
10/31/2022 20:00	-0.9	12.4	2,089.0	-0.5	1.5	1	1	1
10/31/2022 21:00	-0.8	12.2	2,130.3	-0.4	1.5	1	1	1
10/31/2022 22:00	-0.8	12.3	2,096.7	-0.4	1.5	1	1	1
10/31/2022 23:00	-0.8	12.2	2,136.9	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.5	1,757.9	0.0	1.2	23 #	21 #	10 #
Minimum:	-1.2	12.2	299.3	-0.7	0.2	0	0	0
Maximum:	0.3	17.7	2,136.9	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	-0.8	12.2	2,154.2	-0.4	1.5	1	1	1
11/01/2022 01:00	-0.8	12.2	2,150.3	-0.4	1.5	1	1	1
11/01/2022 02:00	-0.8	12.2	2,158.5	-0.4	1.5	1	1	1
11/01/2022 03:00	-0.8	12.2	2,167.8	-0.4	1.5	1	1	1
11/01/2022 04:00	-0.8	12.2	2,175.8	-0.4	1.5	1	1	1
11/01/2022 05:00	-0.8	12.1	2,176.4	-0.4	1.5	1	1	1
11/01/2022 06:00	-0.7	11.8	2,250.2	-0.2	1.6	1	1	1
11/01/2022 07:00	-0.7	12.0	2,187.2	-0.2	1.5	1	1	1
11/01/2022 08:00	-0.5	11.7	2,240.2	-0.1	1.6	1	1	1
11/01/2022 09:00	-0.7	12.2	2,118.9	-0.2	1.5	1	1	1
11/01/2022 10:00	-0.8	12.3	2,123.0	-0.4	1.5	1	1	1
11/01/2022 11:00	-0.7	12.0	2,183.5	-0.2	1.5	1	1	1
11/01/2022 12:00	-0.7	11.9	2,189.4	-0.2	1.5	1	1	1
11/01/2022 13:00	-0.5	12.0	2,180.9	-0.1	1.5	1	1	1
11/01/2022 14:00	-0.7	12.4	2,089.8	-0.2	1.5	1	1	1
11/01/2022 15:00	-0.9	12.6	2,087.1	-0.5	1.5	1	1	1
11/01/2022 16:00	-0.7	12.1	2,204.2	-0.2	1.5	1	1	1
11/01/2022 17:00	-0.5	11.6	2,294.1	-0.1	1.6	1	1	1
11/01/2022 18:00	-0.7	12.1	2,186.6	-0.2	1.5	1	1	1
11/01/2022 19:00	-0.7	12.3	2,168.2	-0.2	1.5	1	1	1
11/01/2022 20:00	-0.7	12.1	2,209.2	-0.2	1.5	1	1	1
11/01/2022 21:00	-0.7	12.6	2,087.6	-0.2	1.5	1	1	1
11/01/2022 22:00	-0.7	12.7	2,075.1	-0.2	1.5	1	1	1
11/01/2022 23:00	-0.5	13.3	1,849.2	-0.2	1.3	1	1	1
Average/Sum#:	-0.7	12.2	2,154.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	1,849.2	-0.5	1.3	1	1	1
Maximum:	-0.5	13.3	2,294.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.1	13.9	1,353.8	0.1	0.9	1	1	0
11/02/2022 01:00	0.2	13.9	1,639.5	0.3	1.1	1	1	0
11/02/2022 02:00	0.2	13.8	1,709.9	0.3	1.2	1	1	0
11/02/2022 03:00	-0.2	13.9	1,353.8	0.0	0.9	1	1	0
11/02/2022 04:00	0.2	13.8	1,683.4	0.3	1.2	1	1	0
11/02/2022 05:00	-0.8	13.1	1,917.9	-0.5	1.3	1	1	1
11/02/2022 06:00	-0.9	12.5	2,169.6	-0.5	1.5	1	1	1
11/02/2022 07:00	-0.8	12.7	2,129.3	-0.4	1.5	1	1	1
11/02/2022 08:00	-0.8	12.9	2,028.9	-0.4	1.4	1	1	1
11/02/2022 09:00	0.2	13.8	1,719.4	0.3	1.2	1	1	0
11/02/2022 10:00	0.2	13.9	1,549.8	0.3	1.1	1	1	0
11/02/2022 11:00	0.2	13.9	1,678.6	0.3	1.2	1	1	0
11/02/2022 12:00	0.2	13.9	1,558.6	0.3	1.1	1	1	0
11/02/2022 13:00	0.2	13.9	1,562.4	0.3	1.1	1	1	0
11/02/2022 14:00	0.2	13.9	1,544.2	0.3	1.1	1	1	0
11/02/2022 15:00	-0.1	13.9	1,612.7	0.1	1.1	1	1	1
11/02/2022 16:00	-0.9	12.6	2,080.8	-0.5	1.5	1	1	1
11/02/2022 17:00	-0.8	12.3	2,172.4	-0.4	1.5	1	1	1
11/02/2022 18:00	-0.8	12.4	2,164.8	-0.4	1.5	1	1	1
11/02/2022 19:00	-0.8	12.4	2,165.2	-0.4	1.5	1	1	1
11/02/2022 20:00	-0.8	12.4	2,166.8	-0.4	1.5	1	1	1
11/02/2022 21:00	-0.8	12.5	2,152.9	-0.4	1.5	1	1	1
11/02/2022 22:00	-0.8	12.4	2,163.4	-0.4	1.5	1	1	1
11/02/2022 23:00	-0.8	12.4	2,176.3	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.2	1,852.3	-0.1	1.3	24 #	24 #	13 #
Minimum:	-0.9	12.3	1,353.8	-0.5	0.9	1	1	0
Maximum:	0.2	13.9	2,176.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	-0.8	12.4	2,167.7	-0.4	1.5	1	1	1
11/03/2022 01:00	-0.8	12.5	2,153.5	-0.4	1.5	1	1	1
11/03/2022 02:00	-0.8	12.3	2,199.7	-0.4	1.5	1	1	1
11/03/2022 03:00	-0.7	12.1	2,243.0	-0.2	1.6	1	1	1
11/03/2022 04:00	-0.8	12.4	2,170.3	-0.4	1.5	1	1	1
11/03/2022 05:00	-0.8	12.4	2,175.5	-0.4	1.5	1	1	1
11/03/2022 06:00	-0.7	12.1	2,246.8	-0.2	1.6	1	1	1
11/03/2022 07:00	-0.7	12.6	2,117.7	-0.2	1.5	1	1	1
11/03/2022 08:00	0.2	13.9	1,461.2	0.3	1.0	1	1	0
11/03/2022 09:00	0.2	13.9	1,567.5	0.3	1.1	1	1	0
11/03/2022 10:00	0.2	13.9	1,581.7	0.3	1.1	1	1	0
11/03/2022 11:00	0.3	13.9	1,575.7	0.4	1.1	1	1	0
11/03/2022 12:00	0.3	13.9	1,587.6	0.4	1.1	1	1	0
11/03/2022 13:00	0.2	13.9	1,496.8	0.3	1.0	1	1	0
11/03/2022 14:00	0.3	13.9	1,564.2	0.4	1.1	1	1	0
11/03/2022 15:00	0.1	13.8	1,787.2	0.2	1.3	1	1	1
11/03/2022 16:00	-0.9	12.7	2,081.8	-0.5	1.5	1	1	1
11/03/2022 17:00	-0.8	12.4	2,162.4	-0.4	1.5	1	1	1
11/03/2022 18:00	-0.8	12.3	2,178.2	-0.4	1.5	1	1	1
11/03/2022 19:00	-0.7	12.3	2,176.0	-0.2	1.5	1	1	1
11/03/2022 20:00	-0.7	12.3	2,164.2	-0.2	1.5	1	1	1
11/03/2022 21:00	-0.7	12.3	2,163.9	-0.2	1.5	1	1	1
11/03/2022 22:00	-0.7	12.3	2,163.3	-0.2	1.5	1	1	1
11/03/2022 23:00	-0.7	12.1	2,220.6	-0.2	1.6	1	1	1
Average/Sum#:	-0.4	12.9	1,975.3	-0.1	1.4	24 #	24 #	17 #
Minimum:	-0.9	12.1	1,461.2	-0.5	1.0	1	1	0
Maximum:	0.3	13.9	2,246.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	-0.8	12.5	2,148.4	-0.4	1.5	1	1	1
11/04/2022 01:00	-0.8	12.6	2,120.9	-0.4	1.5	1	1	1
11/04/2022 02:00	-0.7	12.8	2,070.3	-0.4	1.4	1	1	1
11/04/2022 03:00	-0.8	12.8	2,074.1	-0.4	1.5	1	1	1
11/04/2022 04:00	-0.8	12.5	2,153.1	-0.4	1.5	1	1	1
11/04/2022 05:00	-0.7	12.0	2,266.7	-0.2	1.6	1	1	1
11/04/2022 06:00	-0.8	12.4	2,187.8	-0.4	1.5	1	1	1
11/04/2022 07:00	-0.8	12.8	2,062.9	-0.4	1.4	1	1	1
11/04/2022 08:00	0.3	13.8	1,733.8	0.4	1.2	1	1	0
11/04/2022 09:00	0.2	13.9	1,557.3	0.3	1.1	1	1	0
11/04/2022 10:00	0.2	13.9	1,396.0	0.3	1.0	1	1	0
11/04/2022 11:00	0.1	14.0	1,324.8	0.2	0.9	1	1	0
11/04/2022 12:00	0.1	14.0	1,322.8	0.2	0.9	1	1	0
11/04/2022 13:00	0.2	14.0	1,324.0	0.3	0.9	1	1	0
11/04/2022 14:00	0.1	13.9	1,404.7	0.2	1.0	1	1	0
11/04/2022 15:00	-0.2	13.8	1,636.8	-0.1	1.1	1	1	1
11/04/2022 16:00	-0.9	12.6	2,081.0	-0.5	1.5	1	1	1
11/04/2022 17:00	-0.8	12.4	2,119.5	-0.4	1.5	1	1	1
11/04/2022 18:00	-0.7	12.7	2,057.5	-0.2	1.4	1	1	1
11/04/2022 19:00	-0.7	12.7	2,056.8	-0.2	1.4	1	1	1
11/04/2022 20:00	-0.7	12.8	2,052.8	-0.4	1.4	1	1	1
11/04/2022 21:00	-0.7	12.8	2,054.4	-0.4	1.4	1	1	1
11/04/2022 22:00	-0.7	12.8	2,054.9	-0.4	1.4	1	1	1
11/04/2022 23:00	-0.9	13.3	1,952.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.1	1,883.9	-0.2	1.3	24 #	24 #	17 #
Minimum:	-0.9	12.0	1,322.8	-0.7	0.9	1	1	0
Maximum:	0.3	14.0	2,266.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2022 00:00	-1.1	13.3	1,950.5	-0.7	1.4	1	1	1
11/05/2022 01:00	-1.1	13.3	1,950.4	-0.7	1.4	1	1	1
11/05/2022 02:00	-1.1	13.3	1,950.1	-0.7	1.4	1	1	1
11/05/2022 03:00	-1.2	13.3	1,950.9	-0.8	1.4	1	1	1
11/05/2022 04:00	-1.2	13.3	1,954.3	-0.8	1.4	1	1	1
11/05/2022 05:00	-1.2	13.3	1,956.6	-0.8	1.4	1	1	1
11/05/2022 06:00	-1.2	13.3	1,927.6	-0.8	1.3	1	1	1
11/05/2022 07:00	0.0	15.8	567.3	0.0	0.4	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	18.8	195.5	0.0	0.1	1	0	0
11/05/2022 14:00	0.0	16.1	711.5	0.0	0.5	1	0	0
11/05/2022 15:00	0.2	13.9	1,436.7	0.3	1.0	1	1	0
11/05/2022 16:00	-0.9	13.4	1,707.2	-0.7	1.2	1	1	1
11/05/2022 17:00	-1.1	13.0	1,981.9	-0.7	1.4	1	1	1
11/05/2022 18:00	-1.2	13.0	1,971.9	-0.8	1.4	1	1	1
11/05/2022 19:00	-1.4	13.0	1,972.1	-0.8	1.4	1	1	1
11/05/2022 20:00	-1.5	13.0	1,975.2	-0.9	1.4	1	1	1
11/05/2022 21:00	-0.9	13.5	1,647.5	-0.7	1.2	1	1	1
11/05/2022 22:00	0.1	13.9	1,409.8	0.1	1.0	1	1	0
11/05/2022 23:00	0.2	13.8	1,653.4	0.3	1.2	1	1	0
Average/Sum#:	-0.8	13.9	1,624.8	-0.5	1.2	19 #	16 #	13 #
Minimum:	-1.5	13.0	195.5	-0.9	0.1	0	0	0
Maximum:	0.2	18.8	1,981.9	0.3	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.2	13.8	1,564.1	0.3	1.1	1	1	0
11/06/2022 01:00	0.1	13.8	1,463.6	0.2	1.0	1	1	0
11/06/2022 02:00	0.0	16.3	377.6	0.0	0.3	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.6	1,135.1	0.2	0.8	3 #	2 #	0 #
Minimum:	0.0	13.8	377.6	0.0	0.3	0	0	0
Maximum:	0.2	16.3	1,564.1	0.3	1.1	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 03:00	0.0	18.1	281.0	0.0	0.2	1	0	0
11/07/2022 04:00	0.0	16.6	549.1	0.0	0.4	1	0	0
11/07/2022 05:00	0.0	13.7	1,723.5	0.0	1.2	1	0	0
11/07/2022 06:00	-0.8	12.9	2,000.6	-0.4	1.4	1	1	1
11/07/2022 07:00	-0.8	12.1	2,210.3	-0.4	1.5	1	1	1
11/07/2022 08:00	-0.8	13.0	1,980.7	-0.4	1.4	1	1	1
11/07/2022 09:00	-0.9	13.0	1,964.2	-0.5	1.4	1	1	1
11/07/2022 10:00	-0.8	13.0	1,956.5	-0.4	1.4	1	1	1
11/07/2022 11:00	-0.5	13.1	1,957.6	-0.2	1.4	1	1	1
11/07/2022 12:00	-0.4	13.1	1,957.2	-0.1	1.4	1	1	1
11/07/2022 13:00	-0.5	13.1	1,960.7	-0.2	1.4	1	1	1
11/07/2022 14:00	-0.7	12.8	2,055.3	-0.4	1.4	1	1	1
11/07/2022 15:00	-0.7	12.2	2,186.1	-0.2	1.5	1	1	1
11/07/2022 16:00	-0.5	11.9	2,241.6	-0.1	1.6	1	1	1
11/07/2022 17:00	-0.4	11.8	2,276.8	-0.1	1.6	1	1	1
11/07/2022 18:00	-0.4	11.8	2,279.9	-0.1	1.6	1	1	1
11/07/2022 19:00	-0.4	11.8	2,279.4	-0.1	1.6	1	1	1
11/07/2022 20:00	-0.4	11.8	2,276.6	-0.1	1.6	1	1	1
11/07/2022 21:00	-0.4	11.8	2,272.9	-0.1	1.6	1	1	1
11/07/2022 22:00	-0.5	12.0	2,232.3	-0.1	1.6	1	1	1
11/07/2022 23:00	-0.5	12.4	2,159.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.5	13.0	1,942.9	-0.2	1.4	21 #	18 #	18 #
Minimum:	-0.9	11.8	281.0	-0.5	0.2	0	0	0
Maximum:	0.0	18.1	2,279.9	0.0	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	-0.7	12.4	2,151.8	-0.2	1.5	1	1	1
11/08/2022 01:00	-0.7	12.4	2,149.8	-0.2	1.5	1	1	1
11/08/2022 02:00	-0.5	12.6	2,096.5	-0.2	1.5	1	1	1
11/08/2022 03:00	-0.7	12.4	2,143.2	-0.2	1.5	1	1	1
11/08/2022 04:00	-0.7	12.2	2,180.4	-0.2	1.5	1	1	1
11/08/2022 05:00	-0.5	12.1	2,197.5	-0.1	1.5	1	1	1
11/08/2022 06:00	-0.4	11.7	2,281.0	0.1	1.6	1	1	1
11/08/2022 07:00	-0.5	12.1	2,193.7	-0.1	1.5	1	1	1
11/08/2022 08:00	-0.5	12.1	2,185.1	-0.1	1.5	1	1	1
11/08/2022 09:00	-0.5	12.2	2,181.7	-0.1	1.5	1	1	1
11/08/2022 10:00	-0.7	12.3	2,165.2	-0.2	1.5	1	1	1
11/08/2022 11:00	-0.5	12.9	2,016.4	-0.2	1.4	1	1	1
11/08/2022 12:00	-0.5	13.1	1,972.3	-0.2	1.4	1	1	1
11/08/2022 13:00	-0.5	13.2	1,972.1	-0.2	1.4	1	1	1
11/08/2022 14:00	-0.7	12.9	2,046.8	-0.4	1.4	1	1	1
11/08/2022 15:00	-0.5	12.9	2,043.8	-0.2	1.4	1	1	1
11/08/2022 16:00	-0.5	12.2	2,202.3	-0.1	1.5	1	1	1
11/08/2022 17:00	-0.5	12.2	2,181.5	-0.1	1.5	1	1	1
11/08/2022 18:00	-0.7	12.4	2,151.7	-0.2	1.5	1	1	1
11/08/2022 19:00	-0.5	12.2	2,186.1	-0.1	1.5	1	1	1
11/08/2022 20:00	-0.5	12.2	2,194.5	-0.1	1.5	1	1	1
11/08/2022 21:00	-0.5	12.2	2,195.9	-0.1	1.5	1	1	1
11/08/2022 22:00	-0.5	12.2	2,180.1	-0.1	1.5	1	1	1
11/08/2022 23:00	-0.7	12.4	2,137.2	-0.2	1.5	1	1	1
Average/Sum#:	-0.6	12.4	2,141.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.7	11.7	1,972.1	-0.4	1.4	1	1	1
Maximum:	-0.4	13.2	2,281.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	-0.7	12.4	2,147.1	-0.2	1.5	1	1	1
11/09/2022 01:00	-0.7	12.4	2,147.0	-0.2	1.5	1	1	1
11/09/2022 02:00	-0.7	12.3	2,184.9	-0.2	1.5	1	1	1
11/09/2022 03:00	-0.7	12.3	2,187.0	-0.2	1.5	1	1	1
11/09/2022 04:00	-0.7	12.5	2,154.3	-0.2	1.5	1	1	1
11/09/2022 05:00	-0.5	11.9	2,246.2	-0.1	1.6	1	1	1
11/09/2022 06:00	-0.4	11.9	2,284.3	-0.1	1.6	1	1	1
11/09/2022 07:00	-0.5	12.4	2,184.8	-0.2	1.5	1	1	1
11/09/2022 08:00	-0.5	12.5	2,147.6	-0.2	1.5	1	1	1
11/09/2022 09:00	0.1	13.7	1,760.8	0.2	1.2	1	1	1
11/09/2022 10:00	0.4	13.9	1,725.2	0.4	1.2	1	1	0
11/09/2022 11:00	0.4	13.9	1,641.0	0.4	1.1	1	1	0
11/09/2022 12:00	0.4	13.9	1,716.3	0.4	1.2	1	1	0
11/09/2022 13:00	0.4	13.9	1,625.0	0.4	1.1	1	1	0
11/09/2022 14:00	0.4	13.9	1,698.0	0.4	1.2	1	1	0
11/09/2022 15:00	0.1	13.9	1,645.4	0.2	1.2	1	1	1
11/09/2022 16:00	-0.8	12.8	2,074.2	-0.4	1.5	1	1	1
11/09/2022 17:00	-0.7	12.5	2,153.5	-0.2	1.5	1	1	1
11/09/2022 18:00	-0.7	13.1	2,009.9	-0.4	1.4	1	1	1
11/09/2022 19:00	-0.9	13.3	1,973.0	-0.7	1.4	1	1	1
11/09/2022 20:00	-0.9	13.3	1,976.7	-0.7	1.4	1	1	1
11/09/2022 21:00	-0.9	13.3	1,988.3	-0.7	1.4	1	1	1
11/09/2022 22:00	-0.9	13.3	1,979.1	-0.7	1.4	1	1	1
11/09/2022 23:00	-0.9	13.3	1,977.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.0	1,984.5	-0.2	1.4	24 #	24 #	19 #
Minimum:	-0.9	11.9	1,625.0	-0.7	1.1	1	1	0
Maximum:	0.4	13.9	2,284.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	-0.9	13.3	1,977.3	-0.7	1.4	1	1	1
11/10/2022 01:00	-0.9	13.3	1,975.5	-0.7	1.4	1	1	1
11/10/2022 02:00	-0.9	13.3	1,974.4	-0.7	1.4	1	1	1
11/10/2022 03:00	-0.9	13.3	1,977.4	-0.7	1.4	1	1	1
11/10/2022 04:00	-0.8	12.9	2,073.4	-0.4	1.5	1	1	1
11/10/2022 05:00	-0.5	12.3	2,174.8	-0.1	1.5	1	1	1
11/10/2022 06:00	-0.5	12.0	2,299.8	-0.1	1.6	1	1	1
11/10/2022 07:00	-0.7	12.7	2,110.5	-0.2	1.5	1	1	1
11/10/2022 08:00	-0.9	13.3	1,967.3	-0.7	1.4	1	1	1
11/10/2022 09:00	-0.9	13.3	1,948.5	-0.7	1.4	1	1	1
11/10/2022 10:00	0.4	13.9	1,736.2	0.4	1.2	1	1	0
11/10/2022 11:00	0.4	13.9	1,728.1	0.4	1.2	1	1	0
11/10/2022 12:00	0.4	13.9	1,714.9	0.4	1.2	1	1	0
11/10/2022 13:00	0.4	14.0	1,570.6	0.4	1.1	1	1	0
11/10/2022 14:00	0.4	13.9	1,724.2	0.4	1.2	1	1	0
11/10/2022 15:00	0.2	13.9	1,723.1	0.2	1.2	1	1	1
11/10/2022 16:00	-1.1	12.6	2,126.5	-0.7	1.5	1	1	1
11/10/2022 17:00	-0.4	11.9	2,271.9	-0.1	1.6	1	1	1
11/10/2022 18:00	-0.4	11.9	2,274.6	-0.1	1.6	1	1	1
11/10/2022 19:00	-0.4	11.9	2,278.5	-0.1	1.6	1	1	1
11/10/2022 20:00	-0.4	11.9	2,278.8	-0.1	1.6	1	1	1
11/10/2022 21:00	-0.4	11.9	2,281.7	-0.1	1.6	1	1	1
11/10/2022 22:00	-0.4	11.9	2,281.2	-0.1	1.6	1	1	1
11/10/2022 23:00	-0.4	12.0	2,256.4	-0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.9	2,030.2	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.9	1,570.6	-0.7	1.1	1	1	0
Maximum:	0.4	14.0	2,299.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	-0.4	12.0	2,281.8	-0.1	1.6	1	1	1
11/11/2022 01:00	-0.4	12.0	2,275.8	-0.1	1.6	1	1	1
11/11/2022 02:00	-0.5	12.6	2,145.1	-0.2	1.5	1	1	1
11/11/2022 03:00	-0.5	12.6	2,142.7	-0.2	1.5	1	1	1
11/11/2022 04:00	-0.5	12.1	2,271.6	-0.1	1.6	1	1	1
11/11/2022 05:00	-0.5	12.0	2,285.2	-0.1	1.6	1	1	1
11/11/2022 06:00	-0.4	12.0	2,284.1	-0.1	1.6	1	1	1
11/11/2022 07:00	-0.7	12.7	2,108.2	-0.2	1.5	1	1	1
11/11/2022 08:00	-0.9	13.3	1,940.2	-0.7	1.4	1	1	1
11/11/2022 09:00	0.4	13.9	1,718.1	0.4	1.2	1	1	0
11/11/2022 10:00	0.4	13.9	1,724.0	0.4	1.2	1	1	0
11/11/2022 11:00	0.4	13.9	1,688.9	0.4	1.2	1	1	0
11/11/2022 12:00	0.4	13.9	1,687.5	0.4	1.2	1	1	0
11/11/2022 13:00	0.4	13.9	1,700.7	0.4	1.2	1	1	0
11/11/2022 14:00	0.4	13.9	1,582.3	0.4	1.1	1	1	0
11/11/2022 15:00	0.4	13.9	1,688.6	0.4	1.2	1	1	0
11/11/2022 16:00	-0.8	13.0	1,979.8	-0.4	1.4	1	1	1
11/11/2022 17:00	-0.4	11.8	2,273.3	-0.1	1.6	1	1	1
11/11/2022 18:00	-0.4	11.9	2,266.1	-0.1	1.6	1	1	1
11/11/2022 19:00	-0.4	11.9	2,254.1	-0.1	1.6	1	1	1
11/11/2022 20:00	-0.4	11.9	2,250.8	-0.1	1.6	1	1	1
11/11/2022 21:00	-0.4	11.9	2,249.2	-0.1	1.6	1	1	1
11/11/2022 22:00	-0.5	12.1	2,243.3	-0.1	1.6	1	1	1
11/11/2022 23:00	-0.5	12.0	2,260.9	-0.1	1.6	1	1	1
Average/Sum#:	-0.2	12.7	2,054.3	0.0	1.5	24 #	24 #	17 #
Minimum:	-0.9	11.8	1,582.3	-0.7	1.1	1	1	0
Maximum:	0.4	13.9	2,285.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	-0.5	12.0	2,265.2	-0.1	1.6	1	1	1
11/12/2022 01:00	-0.5	12.0	2,268.8	-0.1	1.6	1	1	1
11/12/2022 02:00	-0.5	12.0	2,275.3	-0.1	1.6	1	1	1
11/12/2022 03:00	-0.5	12.0	2,278.8	-0.1	1.6	1	1	1
11/12/2022 04:00	-0.5	12.0	2,285.3	-0.1	1.6	1	1	1
11/12/2022 05:00	-0.5	12.0	2,286.6	-0.1	1.6	1	1	1
11/12/2022 06:00	-0.5	12.0	2,277.1	-0.1	1.6	1	1	1
11/12/2022 07:00	-0.5	12.7	2,119.5	-0.2	1.5	1	1	1
11/12/2022 08:00	-0.5	12.2	2,196.2	-0.1	1.5	1	1	1
11/12/2022 09:00	0.1	13.7	1,755.8	0.2	1.2	1	1	1
11/12/2022 10:00	0.4	13.9	1,596.8	0.4	1.1	1	1	0
11/12/2022 11:00	0.4	13.9	1,557.9	0.4	1.1	1	1	0
11/12/2022 12:00	0.4	13.9	1,557.2	0.4	1.1	1	1	0
11/12/2022 13:00	0.4	13.9	1,580.9	0.4	1.1	1	1	0
11/12/2022 14:00	0.4	13.9	1,557.8	0.4	1.1	1	1	0
11/12/2022 15:00	0.2	13.8	1,793.1	0.4	1.3	1	1	1
11/12/2022 16:00	-1.1	12.5	2,136.2	-0.5	1.5	1	1	1
11/12/2022 17:00	-0.4	11.8	2,289.6	-0.1	1.6	1	1	1
11/12/2022 18:00	-0.4	11.8	2,288.4	-0.1	1.6	1	1	1
11/12/2022 19:00	-0.4	11.8	2,294.2	-0.1	1.6	1	1	1
11/12/2022 20:00	-0.4	11.8	2,304.8	-0.1	1.6	1	1	1
11/12/2022 21:00	-0.4	11.8	2,300.6	-0.1	1.6	1	1	1
11/12/2022 22:00	-0.5	12.3	2,197.1	-0.1	1.5	1	1	1
11/12/2022 23:00	-0.5	12.3	2,192.7	-0.1	1.5	1	1	1
Average/Sum#:	-0.3	12.6	2,069.0	0.0	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.8	1,557.2	-0.5	1.1	1	1	0
Maximum:	0.4	13.9	2,304.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	-0.5	12.4	2,183.0	-0.2	1.5	1	1	1
11/13/2022 01:00	-0.5	12.4	2,169.4	-0.2	1.5	1	1	1
11/13/2022 02:00	-0.5	12.5	2,162.2	-0.2	1.5	1	1	1
11/13/2022 03:00	-0.5	12.3	2,198.3	-0.1	1.5	1	1	1
11/13/2022 04:00	-0.5	12.4	2,192.5	-0.2	1.5	1	1	1
11/13/2022 05:00	-0.5	12.4	2,185.1	-0.2	1.5	1	1	1
11/13/2022 06:00	-0.5	12.3	2,201.5	-0.1	1.5	1	1	1
11/13/2022 07:00	-0.4	12.0	2,269.1	-0.1	1.6	1	1	1
11/13/2022 08:00	-0.2	12.9	1,972.8	0.1	1.4	1	1	1
11/13/2022 09:00	0.4	13.9	1,713.6	0.4	1.2	1	1	0
11/13/2022 10:00	0.4	13.9	1,714.5	0.4	1.2	1	1	0
11/13/2022 11:00	0.4	13.9	1,714.3	0.4	1.2	1	1	0
11/13/2022 12:00	0.4	13.9	1,712.3	0.4	1.2	1	1	0
11/13/2022 13:00	0.4	14.0	1,713.9	0.4	1.2	1	1	0
11/13/2022 14:00	0.4	14.0	1,686.9	0.4	1.2	1	1	0
11/13/2022 15:00	0.2	13.8	1,797.5	0.4	1.3	1	1	1
11/13/2022 16:00	-0.5	12.6	2,132.3	-0.2	1.5	1	1	1
11/13/2022 17:00	-0.2	12.0	2,273.8	0.1	1.6	1	1	1
11/13/2022 18:00	-0.2	12.0	2,273.5	0.1	1.6	1	1	1
11/13/2022 19:00	-0.2	12.0	2,277.3	0.1	1.6	1	1	1
11/13/2022 20:00	-0.2	12.0	2,280.0	0.1	1.6	1	1	1
11/13/2022 21:00	-0.2	12.0	2,284.9	0.1	1.6	1	1	1
11/13/2022 22:00	-0.2	12.0	2,287.2	0.1	1.6	1	1	1
11/13/2022 23:00	-0.2	12.0	2,294.0	0.1	1.6	1	1	1
Average/Sum#:	-0.1	12.7	2,070.4	0.1	1.4	24 #	24 #	18 #
Minimum:	-0.5	12.0	1,686.9	-0.2	1.2	1	1	0
Maximum:	0.4	14.0	2,294.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	-0.2	12.1	2,288.4	0.1	1.6	1	1	1
11/14/2022 01:00	-0.4	12.1	2,277.6	-0.1	1.6	1	1	1
11/14/2022 02:00	-0.4	12.2	2,265.6	-0.1	1.6	1	1	1
11/14/2022 03:00	-0.5	12.7	2,149.5	-0.2	1.5	1	1	1
11/14/2022 04:00	-0.5	12.4	2,230.6	-0.2	1.6	1	1	1
11/14/2022 05:00	-0.4	12.2	2,291.8	-0.1	1.6	1	1	1
11/14/2022 06:00	-0.4	12.2	2,286.5	-0.1	1.6	1	1	1
11/14/2022 07:00	-0.5	12.6	2,184.1	-0.2	1.5	1	1	1
11/14/2022 08:00	-0.5	12.7	2,143.2	-0.2	1.5	1	1	1
11/14/2022 09:00	-0.5	12.6	2,149.5	-0.2	1.5	1	1	1
11/14/2022 10:00	-0.5	12.6	2,141.4	-0.2	1.5	1	1	1
11/14/2022 11:00	-0.4	12.7	2,116.8	-0.1	1.5	1	1	1
11/14/2022 12:00	-0.4	12.7	2,106.1	-0.1	1.5	1	1	1
11/14/2022 13:00	-0.4	12.5	2,137.1	-0.1	1.5	1	1	1
11/14/2022 14:00	-0.4	12.5	2,137.4	-0.1	1.5	1	1	1
11/14/2022 15:00	-0.4	12.8	2,062.7	-0.1	1.4	1	1	1
11/14/2022 16:00	-0.2	12.1	2,229.8	0.1	1.6	1	1	1
11/14/2022 17:00	-0.4	12.3	2,177.1	-0.1	1.5	1	1	1
11/14/2022 18:00	-0.4	12.5	2,159.1	-0.1	1.5	1	1	1
11/14/2022 19:00	-0.2	12.1	2,265.3	0.1	1.6	1	1	1
11/14/2022 20:00	-0.2	12.0	2,281.3	0.1	1.6	1	1	1
11/14/2022 21:00	-0.2	12.1	2,256.1	0.1	1.6	1	1	1
11/14/2022 22:00	-0.2	12.1	2,259.7	0.1	1.6	1	1	1
11/14/2022 23:00	-0.2	12.2	2,239.5	0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.4	2,201.5	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.5	12.0	2,062.7	-0.2	1.4	1	1	1
Maximum:	-0.2	12.8	2,291.8	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2022 00:00	-0.2	12.1	2,265.0	0.1	1.6	1	1	1
11/15/2022 01:00	-0.2	12.1	2,268.0	0.1	1.6	1	1	1
11/15/2022 02:00	-0.2	12.0	2,286.6	0.1	1.6	1	1	1
11/15/2022 03:00	-0.2	12.0	2,296.0	0.1	1.6	1	1	1
11/15/2022 04:00	-0.2	12.0	2,299.8	0.1	1.6	1	1	1
11/15/2022 05:00	-0.2	11.7	2,332.5	0.1	1.6	1	1	1
11/15/2022 06:00	-0.4	12.2	2,202.6	-0.1	1.5	1	1	1
11/15/2022 07:00	-0.2	11.8	2,323.2	0.1	1.6	1	1	1
11/15/2022 08:00	-0.2	12.0	2,234.7	0.1	1.6	1	1	1
11/15/2022 09:00	-0.4	12.6	2,114.0	-0.1	1.5	1	1	1
11/15/2022 10:00	-0.5	12.5	2,135.7	-0.2	1.5	1	1	1
11/15/2022 11:00	-0.7	12.9	2,037.3	-0.4	1.4	1	1	1
11/15/2022 12:00	-1.2	13.3	1,961.1	-0.8	1.4	1	1	1
11/15/2022 13:00	-1.2	13.3	1,967.3	-0.8	1.4	1	1	1
11/15/2022 14:00	0.7	0.0	1,973.8	0.7	1.4	1	1	1
11/15/2022 15:00	0.7	0.0	2,007.0	0.7	1.4	1	1	1
11/15/2022 16:00	-0.7	12.5	2,120.1	-0.2	1.5	1	1	1
11/15/2022 17:00	-0.7	12.4	2,133.8	-0.2	1.5	1	1	1
11/15/2022 18:00	-0.5	12.4	2,123.0	-0.2	1.5	1	1	1
11/15/2022 19:00	-0.5	12.3	2,137.1	-0.1	1.5	1	1	1
11/15/2022 20:00	-0.5	12.2	2,175.2	-0.1	1.5	1	1	1
11/15/2022 21:00	-0.4	11.9	2,237.4	-0.1	1.6	1	1	1
11/15/2022 22:00	-0.5	12.3	2,149.1	-0.1	1.5	1	1	1
11/15/2022 23:00	-0.5	12.3	2,148.1	-0.1	1.5	1	1	1
Average/Sum#:	-0.5	12.3	2,163.7	-0.1	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.7	1,961.1	-0.8	1.4	1	1	1
Maximum:	-0.2	13.3	2,332.5	0.1	1.6	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	-0.5	12.3	2,142.4	-0.1	1.5	1	1	1
11/16/2022 01:00	-0.5	12.5	2,116.0	-0.2	1.5	1	1	1
11/16/2022 02:00	-0.5	12.4	2,139.8	-0.2	1.5	1	1	1
11/16/2022 03:00	-0.5	12.4	2,144.4	-0.2	1.5	1	1	1
11/16/2022 04:00	-0.5	11.9	2,274.6	-0.1	1.6	1	1	1
11/16/2022 05:00	-0.4	11.5	2,340.0	0.1	1.6	1	1	1
11/16/2022 06:00	-0.2	11.5	2,346.5	0.1	1.6	1	1	1
11/16/2022 07:00	-0.4	11.9	2,254.3	-0.1	1.6	1	1	1
11/16/2022 08:00	-0.8	13.3	1,966.8	-0.5	1.4	1	1	1
11/16/2022 09:00	-1.1	13.6	1,997.0	-0.8	1.4	1	1	1
11/16/2022 10:00	-1.1	13.2	1,964.8	-0.7	1.4	1	1	1
11/16/2022 11:00	-1.1	13.2	1,969.2	-0.7	1.4	1	1	1
11/16/2022 12:00	-1.1	13.1	1,978.0	-0.7	1.4	1	1	1
11/16/2022 13:00	-1.1	13.1	1,980.5	-0.7	1.4	1	1	1
11/16/2022 14:00	-1.1	13.1	1,981.2	-0.7	1.4	1	1	1
11/16/2022 15:00	-0.8	12.6	2,101.9	-0.4	1.5	1	1	1
11/16/2022 16:00	-0.5	12.3	2,161.6	-0.1	1.5	1	1	1
11/16/2022 17:00	-0.5	12.3	2,165.8	-0.1	1.5	1	1	1
11/16/2022 18:00	-0.4	12.0	2,221.6	-0.1	1.6	1	1	1
11/16/2022 19:00	-0.4	11.9	2,228.4	-0.1	1.6	1	1	1
11/16/2022 20:00	-0.4	11.9	2,229.7	-0.1	1.6	1	1	1
11/16/2022 21:00	-0.5	12.0	2,244.6	-0.1	1.6	1	1	1
11/16/2022 22:00	-0.5	12.2	2,216.3	-0.1	1.6	1	1	1
11/16/2022 23:00	-0.5	12.0	2,243.9	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.4	2,142.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.5	1,964.8	-0.8	1.4	1	1	1
Maximum:	-0.2	13.6	2,346.5	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	-0.5	12.4	2,159.1	-0.2	1.5	1	1	1
11/17/2022 01:00	-0.5	12.4	2,159.4	-0.2	1.5	1	1	1
11/17/2022 02:00	-0.5	12.5	2,146.1	-0.2	1.5	1	1	1
11/17/2022 03:00	-0.5	12.5	2,149.6	-0.2	1.5	1	1	1
11/17/2022 04:00	-0.5	12.2	2,231.0	-0.1	1.6	1	1	1
11/17/2022 05:00	-0.4	11.6	2,357.0	0.1	1.6	1	1	1
11/17/2022 06:00	-0.4	11.9	2,276.3	-0.1	1.6	1	1	1
11/17/2022 07:00	-0.5	12.4	2,162.7	-0.2	1.5	1	1	1
11/17/2022 08:00	-0.8	13.1	1,985.4	-0.5	1.4	1	1	1
11/17/2022 09:00	-0.5	12.5	2,129.0	-0.2	1.5	1	1	1
11/17/2022 10:00	-0.5	12.5	2,110.8	-0.2	1.5	1	1	1
11/17/2022 11:00	-0.5	12.3	2,133.9	-0.1	1.5	1	1	1
11/17/2022 12:00	-0.4	12.1	2,171.5	-0.1	1.5	1	1	1
11/17/2022 13:00	-0.4	12.2	2,169.8	-0.1	1.5	1	1	1
11/17/2022 14:00	-0.4	12.9	2,005.0	-0.1	1.4	1	1	1
11/17/2022 15:00	-0.4	12.4	2,118.7	-0.1	1.5	1	1	1
11/17/2022 16:00	-0.4	11.9	2,234.9	-0.1	1.6	1	1	1
11/17/2022 17:00	-0.2	11.8	2,268.2	0.1	1.6	1	1	1
11/17/2022 18:00	-0.2	11.8	2,255.7	0.1	1.6	1	1	1
11/17/2022 19:00	-0.2	11.8	2,258.8	0.1	1.6	1	1	1
11/17/2022 20:00	-0.4	11.8	2,260.2	-0.1	1.6	1	1	1
11/17/2022 21:00	-0.2	11.8	2,262.4	0.1	1.6	1	1	1
11/17/2022 22:00	-0.4	11.9	2,246.4	-0.1	1.6	1	1	1
11/17/2022 23:00	-0.5	12.2	2,206.6	-0.1	1.5	1	1	1
Average/Sum#:	-0.4	12.2	2,185.8	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	1,985.4	-0.5	1.4	1	1	1
Maximum:	-0.2	13.1	2,357.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	-0.5	12.4	2,157.1	-0.2	1.5	1	1	1
11/18/2022 01:00	-0.5	12.3	2,164.4	-0.1	1.5	1	1	1
11/18/2022 02:00	-0.5	12.2	2,166.7	-0.1	1.5	1	1	1
11/18/2022 03:00	-0.5	12.3	2,166.0	-0.1	1.5	1	1	1
11/18/2022 04:00	-0.2	11.6	2,308.1	0.1	1.6	1	1	1
11/18/2022 05:00	-0.2	11.5	2,326.0	0.1	1.6	1	1	1
11/18/2022 06:00	-0.2	11.5	2,333.1	0.1	1.6	1	1	1
11/18/2022 07:00	-0.4	11.8	2,267.0	-0.1	1.6	1	1	1
11/18/2022 08:00	-0.5	12.3	2,145.7	-0.1	1.5	1	1	1
11/18/2022 09:00	-0.5	12.3	2,153.7	-0.1	1.5	1	1	1
11/18/2022 10:00	-0.4	12.2	2,162.8	-0.1	1.5	1	1	1
11/18/2022 11:00	-0.4	12.4	2,100.8	-0.1	1.5	1	1	1
11/18/2022 12:00	-0.5	13.1	1,958.4	-0.2	1.4	1	1	1
11/18/2022 13:00	-0.5	13.1	1,960.1	-0.2	1.4	1	1	1
11/18/2022 14:00	-0.5	13.0	1,964.5	-0.2	1.4	1	1	1
11/18/2022 15:00	-0.5	12.7	2,040.1	-0.2	1.4	1	1	1
11/18/2022 16:00	-0.4	12.0	2,220.5	-0.1	1.6	1	1	1
11/18/2022 17:00	-0.4	11.9	2,244.9	-0.1	1.6	1	1	1
11/18/2022 18:00	-0.4	11.9	2,243.3	-0.1	1.6	1	1	1
11/18/2022 19:00	-0.4	11.9	2,245.4	-0.1	1.6	1	1	1
11/18/2022 20:00	-0.4	11.8	2,276.3	-0.1	1.6	1	1	1
11/18/2022 21:00	-0.2	11.6	2,328.6	0.1	1.6	1	1	1
11/18/2022 22:00	-0.2	11.6	2,341.0	0.1	1.6	1	1	1
11/18/2022 23:00	-0.2	11.8	2,301.5	0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.1	2,190.7	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.5	11.5	1,958.4	-0.2	1.4	1	1	1
Maximum:	-0.2	13.1	2,341.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	-0.5	12.3	2,163.6	-0.1	1.5	1	1	1
11/19/2022 01:00	-0.5	12.5	2,142.3	-0.2	1.5	1	1	1
11/19/2022 02:00	-0.5	12.5	2,139.1	-0.2	1.5	1	1	1
11/19/2022 03:00	-0.5	12.6	2,118.3	-0.2	1.5	1	1	1
11/19/2022 04:00	-0.5	12.1	2,231.5	-0.1	1.6	1	1	1
11/19/2022 05:00	-0.4	11.9	2,257.3	-0.1	1.6	1	1	1
11/19/2022 06:00	-0.5	12.3	2,191.6	-0.1	1.5	1	1	1
11/19/2022 07:00	-0.5	12.5	2,123.0	-0.2	1.5	1	1	1
11/19/2022 08:00	-0.9	13.2	1,963.6	-0.5	1.4	1	1	1
11/19/2022 09:00	-0.9	13.2	1,961.7	-0.5	1.4	1	1	1
11/19/2022 10:00	-0.9	13.2	1,956.6	-0.5	1.4	1	1	1
11/19/2022 11:00	-0.9	13.1	1,953.3	-0.5	1.4	1	1	1
11/19/2022 12:00	-0.8	13.1	1,953.3	-0.5	1.4	1	1	1
11/19/2022 13:00	-0.7	13.1	1,954.1	-0.4	1.4	1	1	1
11/19/2022 14:00	-0.7	13.1	1,960.9	-0.4	1.4	1	1	1
11/19/2022 15:00	-0.5	12.8	2,021.3	-0.2	1.4	1	1	1
11/19/2022 16:00	-0.4	12.2	2,156.6	-0.1	1.5	1	1	1
11/19/2022 17:00	-0.4	12.1	2,176.7	-0.1	1.5	1	1	1
11/19/2022 18:00	-0.4	12.2	2,169.1	-0.1	1.5	1	1	1
11/19/2022 19:00	-0.2	11.8	2,273.1	0.1	1.6	1	1	1
11/19/2022 20:00	-0.2	11.6	2,305.7	0.1	1.6	1	1	1
11/19/2022 21:00	-0.2	11.6	2,312.8	0.1	1.6	1	1	1
11/19/2022 22:00	-0.4	11.7	2,340.7	0.1	1.6	1	1	1
11/19/2022 23:00	-0.4	11.6	2,358.5	0.1	1.7	1	1	1
Average/Sum#:	-0.5	12.4	2,132.7	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	1,953.3	-0.5	1.4	1	1	1
Maximum:	-0.2	13.2	2,358.5	0.1	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	-0.5	12.0	2,254.8	-0.1	1.6	1	1	1
11/20/2022 01:00	-0.4	11.9	2,273.0	-0.1	1.6	1	1	1
11/20/2022 02:00	-0.4	11.8	2,301.3	-0.1	1.6	1	1	1
11/20/2022 03:00	-0.4	11.9	2,301.2	-0.1	1.6	1	1	1
11/20/2022 04:00	-0.4	11.9	2,306.4	-0.1	1.6	1	1	1
11/20/2022 05:00	-0.4	11.7	2,350.0	0.1	1.6	1	1	1
11/20/2022 06:00	-0.5	12.1	2,254.5	-0.1	1.6	1	1	1
11/20/2022 07:00	-0.5	12.6	2,096.3	-0.2	1.5	1	1	1
11/20/2022 08:00	0.4	13.8	1,722.3	0.4	1.2	1	1	0
11/20/2022 09:00	0.4	13.8	1,725.4	0.4	1.2	1	1	0
11/20/2022 10:00	0.4	13.8	1,571.5	0.4	1.1	1	1	0
11/20/2022 11:00	0.4	13.9	1,573.6	0.4	1.1	1	1	0
11/20/2022 12:00	0.4	13.9	1,545.9	0.4	1.1	1	1	0
11/20/2022 13:00	0.4	13.9	1,536.5	0.4	1.1	1	1	0
11/20/2022 14:00	0.4	13.8	1,695.0	0.4	1.2	1	1	0
11/20/2022 15:00	0.2	13.8	1,732.2	0.4	1.2	1	1	1
11/20/2022 16:00	-0.5	12.3	2,147.2	-0.1	1.5	1	1	1
11/20/2022 17:00	-0.4	11.8	2,265.5	-0.1	1.6	1	1	1
11/20/2022 18:00	-0.4	11.8	2,252.2	-0.1	1.6	1	1	1
11/20/2022 19:00	-0.4	11.8	2,253.5	-0.1	1.6	1	1	1
11/20/2022 20:00	-0.4	11.8	2,257.4	-0.1	1.6	1	1	1
11/20/2022 21:00	-0.4	12.1	2,192.6	-0.1	1.5	1	1	1
11/20/2022 22:00	-0.5	12.4	2,157.4	-0.2	1.5	1	1	1
11/20/2022 23:00	-0.7	12.5	2,147.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.2	12.6	2,038.1	0.1	1.4	24 #	24 #	17 #
Minimum:	-0.7	11.7	1,536.5	-0.2	1.1	1	1	0
Maximum:	0.4	13.9	2,350.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2022 00:00	-0.5	12.4	2,156.8	-0.2	1.5	1	1	1
11/21/2022 01:00	-0.5	12.6	2,130.5	-0.2	1.5	1	1	1
11/21/2022 02:00	-0.8	12.9	2,058.0	-0.4	1.4	1	1	1
11/21/2022 03:00	-0.7	12.4	2,172.2	-0.2	1.5	1	1	1
11/21/2022 04:00	-0.5	12.0	2,259.2	-0.1	1.6	1	1	1
11/21/2022 05:00	-0.5	12.0	2,267.5	-0.1	1.6	1	1	1
11/21/2022 06:00	-0.5	12.0	2,284.4	-0.1	1.6	1	1	1
11/21/2022 07:00	-0.7	12.5	2,147.1	-0.2	1.5	1	1	1
11/21/2022 08:00	-1.1	13.2	1,965.1	-0.7	1.4	1	1	1
11/21/2022 09:00	-1.2	13.2	1,965.2	-0.8	1.4	1	1	1
11/21/2022 10:00	-1.1	13.2	1,961.7	-0.7	1.4	1	1	1
11/21/2022 11:00	-0.8	13.1	1,958.9	-0.5	1.4	1	1	1
11/21/2022 12:00	-0.7	13.0	1,966.2	-0.4	1.4	1	1	1
11/21/2022 13:00	-0.5	13.0	1,977.7	-0.2	1.4	1	1	1
11/21/2022 14:00	-0.5	12.2	2,161.3	-0.1	1.5	1	1	1
11/21/2022 15:00	-0.2	11.8	2,272.0	0.1	1.6	1	1	1
11/21/2022 16:00	-0.5	12.0	2,229.0	-0.1	1.6	1	1	1
11/21/2022 17:00	-0.4	11.9	2,230.9	-0.1	1.6	1	1	1
11/21/2022 18:00	-0.4	11.9	2,230.5	-0.1	1.6	1	1	1
11/21/2022 19:00	-0.4	11.8	2,258.6	-0.1	1.6	1	1	1
11/21/2022 20:00	-0.4	11.8	2,263.5	-0.1	1.6	1	1	1
11/21/2022 21:00	-0.4	11.8	2,264.2	-0.1	1.6	1	1	1
11/21/2022 22:00	-0.4	11.8	2,264.8	-0.1	1.6	1	1	1
11/21/2022 23:00	-0.4	12.0	2,226.0	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.4	2,153.0	-0.2	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,958.9	-0.8	1.4	1	1	1
Maximum:	-0.2	13.2	2,284.4	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2022 00:00	-0.5	12.4	2,143.9	-0.2	1.5	1	1	1
11/22/2022 01:00	-0.7	12.6	2,125.4	-0.2	1.5	1	1	1
11/22/2022 02:00	-0.7	12.6	2,094.4	-0.2	1.5	1	1	1
11/22/2022 03:00	-0.8	13.1	1,973.7	-0.5	1.4	1	1	1
11/22/2022 04:00	-0.9	13.1	1,977.2	-0.5	1.4	1	1	1
11/22/2022 05:00	-0.8	12.6	2,065.9	-0.4	1.4	1	1	1
11/22/2022 06:00	-0.7	12.5	2,149.0	-0.2	1.5	1	1	1
11/22/2022 07:00	-0.8	12.7	2,088.9	-0.4	1.5	1	1	1
11/22/2022 08:00	-0.9	12.9	2,051.0	-0.5	1.4	1	1	1
11/22/2022 09:00	0.0	14.2	1,444.6	0.0	1.0	1	0	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2022 11:00	0.0	19.5	58.0	0.0	0.0	1	0	0
11/22/2022 12:00	0.0	15.8	756.7	0.0	0.5	1	0	0
11/22/2022 13:00	0.3	13.8	1,622.5	0.4	1.1	1	1	0
11/22/2022 14:00	0.4	13.8	1,790.4	0.4	1.3	1	1	0
11/22/2022 15:00	0.4	13.8	1,790.4	0.4	1.3	1	1	0
11/22/2022 16:00	-0.4	13.2	1,897.6	-0.1	1.3	1	1	1
11/22/2022 17:00	-0.7	12.3	2,141.8	-0.2	1.5	1	1	1
11/22/2022 18:00	-0.7	12.7	2,035.3	-0.2	1.4	1	1	1
11/22/2022 19:00	-0.8	13.0	1,982.5	-0.4	1.4	1	1	1
11/22/2022 20:00	-0.7	12.4	2,138.7	-0.2	1.5	1	1	1
11/22/2022 21:00	-0.8	12.9	2,017.6	-0.4	1.4	1	1	1
11/22/2022 22:00	-0.8	12.8	2,028.8	-0.4	1.4	1	1	1
11/22/2022 23:00	-1.1	13.2	1,957.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.4	1,840.5	-0.2	1.3	23 #	20 #	18 #
Minimum:	-1.1	12.3	58.0	-0.7	0.0	0	0	0
Maximum:	0.4	19.5	2,149.0	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	-1.1	13.2	1,958.7	-0.7	1.4	1	1	1
11/23/2022 01:00	-1.1	13.2	1,960.6	-0.7	1.4	1	1	1
11/23/2022 02:00	-1.1	13.2	1,958.4	-0.7	1.4	1	1	1
11/23/2022 03:00	-1.1	13.2	1,962.5	-0.7	1.4	1	1	1
11/23/2022 04:00	-1.1	13.1	1,969.2	-0.7	1.4	1	1	1
11/23/2022 05:00	-0.7	12.5	2,057.1	-0.2	1.4	1	1	1
11/23/2022 06:00	-0.8	12.8	2,048.5	-0.4	1.4	1	1	1
11/23/2022 07:00	-0.7	12.6	2,103.9	-0.2	1.5	1	1	1
11/23/2022 08:00	-0.8	13.0	1,993.7	-0.4	1.4	1	1	1
11/23/2022 09:00	0.4	13.8	1,707.7	0.4	1.2	1	1	0
11/23/2022 10:00	0.4	13.8	1,562.1	0.4	1.1	1	1	0
11/23/2022 11:00	0.4	13.9	1,556.2	0.4	1.1	1	1	0
11/23/2022 12:00	0.4	13.9	1,424.7	0.4	1.0	1	1	0
11/23/2022 13:00	0.4	13.9	1,558.7	0.4	1.1	1	1	0
11/23/2022 14:00	0.4	13.9	1,628.7	0.4	1.1	1	1	0
11/23/2022 15:00	0.2	13.8	1,649.5	0.4	1.2	1	1	1
11/23/2022 16:00	-0.8	12.5	2,097.1	-0.4	1.5	1	1	1
11/23/2022 17:00	-0.7	12.3	2,159.6	-0.2	1.5	1	1	1
11/23/2022 18:00	-0.8	12.6	2,078.6	-0.4	1.5	1	1	1
11/23/2022 19:00	-0.9	12.8	2,045.2	-0.5	1.4	1	1	1
11/23/2022 20:00	-0.7	12.3	2,155.0	-0.2	1.5	1	1	1
11/23/2022 21:00	-0.7	12.2	2,168.6	-0.2	1.5	1	1	1
11/23/2022 22:00	-0.7	12.4	2,143.6	-0.2	1.5	1	1	1
11/23/2022 23:00	-0.7	12.4	2,140.6	-0.2	1.5	1	1	1
Average/Sum#:	-0.5	13.1	1,920.4	-0.2	1.4	24 #	24 #	18 #
Minimum:	-1.1	12.2	1,424.7	-0.7	1.0	1	1	0
Maximum:	0.4	13.9	2,168.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	-1.1	13.1	1,975.4	-0.7	1.4	1	1	1
11/24/2022 01:00	-1.4	13.2	1,962.5	-0.9	1.4	1	1	1
11/24/2022 02:00	-1.4	13.2	1,963.6	-0.9	1.4	1	1	1
11/24/2022 03:00	-0.8	13.0	1,975.0	-0.4	1.4	1	1	1
11/24/2022 04:00	-0.7	12.9	1,985.5	-0.4	1.4	1	1	1
11/24/2022 05:00	-0.7	12.5	2,052.9	-0.2	1.4	1	1	1
11/24/2022 06:00	-0.5	12.2	2,165.6	-0.1	1.5	1	1	1
11/24/2022 07:00	-0.5	12.5	2,079.4	-0.2	1.5	1	1	1
11/24/2022 08:00	0.4	13.8	1,712.0	0.4	1.2	1	1	0
11/24/2022 09:00	0.4	13.8	1,709.0	0.4	1.2	1	1	0
11/24/2022 10:00	0.4	13.8	1,716.4	0.4	1.2	1	1	0
11/24/2022 11:00	0.4	13.9	1,560.1	0.4	1.1	1	1	0
11/24/2022 12:00	0.4	13.9	1,351.9	0.4	0.9	1	1	0
11/24/2022 13:00	0.4	13.9	1,350.9	0.4	0.9	1	1	0
11/24/2022 14:00	0.4	13.9	1,562.2	0.4	1.1	1	1	0
11/24/2022 15:00	0.4	13.9	1,450.2	0.4	1.0	1	1	0
11/24/2022 16:00	0.4	13.8	1,769.5	0.4	1.2	1	1	0
11/24/2022 17:00	0.4	13.8	1,768.6	0.4	1.2	1	1	0
11/24/2022 18:00	0.4	13.8	1,745.4	0.4	1.2	1	1	0
11/24/2022 19:00	0.4	13.8	1,737.1	0.4	1.2	1	1	0
11/24/2022 20:00	0.3	13.8	1,746.5	0.4	1.2	1	1	0
11/24/2022 21:00	0.3	13.8	1,747.1	0.4	1.2	1	1	0
11/24/2022 22:00	0.3	13.8	1,751.3	0.4	1.2	1	1	0
11/24/2022 23:00	0.3	13.8	1,753.2	0.4	1.2	1	1	0
Average/Sum#:	0.0	13.5	1,774.6	0.1	1.2	24 #	24 #	8 #
Minimum:	-1.4	12.2	1,350.9	-0.9	0.9	1	1	0
Maximum:	0.4	13.9	2,165.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.3	13.8	1,757.2	0.4	1.2	1	1	0
11/25/2022 01:00	0.3	13.8	1,758.4	0.4	1.2	1	1	0
11/25/2022 02:00	0.3	13.8	1,761.0	0.4	1.2	1	1	0
11/25/2022 03:00	0.3	13.8	1,764.3	0.4	1.2	1	1	0
11/25/2022 04:00	0.4	13.8	1,775.1	0.4	1.2	1	1	0
11/25/2022 05:00	0.3	13.8	1,771.2	0.4	1.2	1	1	0
11/25/2022 06:00	0.3	13.8	1,766.8	0.4	1.2	1	1	0
11/25/2022 07:00	0.3	13.8	1,766.8	0.4	1.2	1	1	0
11/25/2022 08:00	-0.5	13.4	1,882.1	-0.2	1.3	1	1	1
11/25/2022 09:00	-0.7	13.1	1,919.7	-0.4	1.3	1	1	1
11/25/2022 10:00	0.4	13.8	1,668.0	0.4	1.2	1	1	0
11/25/2022 11:00	0.3	13.8	1,549.0	0.4	1.1	1	1	0
11/25/2022 12:00	0.4	13.8	1,574.7	0.4	1.1	1	1	0
11/25/2022 13:00	0.4	13.8	1,543.3	0.4	1.1	1	1	0
11/25/2022 14:00	0.3	13.8	1,531.6	0.4	1.1	1	1	0
11/25/2022 15:00	0.1	13.7	1,644.3	0.2	1.2	1	1	1
11/25/2022 16:00	-0.8	12.6	2,082.1	-0.4	1.5	1	1	1
11/25/2022 17:00	-0.7	12.5	2,096.7	-0.2	1.5	1	1	1
11/25/2022 18:00	-0.8	13.0	1,970.2	-0.4	1.4	1	1	1
11/25/2022 19:00	-0.9	13.1	1,955.6	-0.5	1.4	1	1	1
11/25/2022 20:00	-0.9	13.1	1,955.0	-0.5	1.4	1	1	1
11/25/2022 21:00	-1.1	13.1	1,966.3	-0.7	1.4	1	1	1
11/25/2022 22:00	-0.7	12.5	2,118.6	-0.2	1.5	1	1	1
11/25/2022 23:00	-0.7	12.6	2,080.0	-0.2	1.5	1	1	1
Average/Sum#:	-0.1	13.4	1,819.1	0.1	1.3	24 #	24 #	11 #
Minimum:	-1.1	12.5	1,531.6	-0.7	1.1	1	1	0
Maximum:	0.4	13.8	2,118.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	-0.8	12.9	2,016.8	-0.4	1.4	1	1	1
11/26/2022 01:00	-0.8	12.7	2,062.0	-0.4	1.4	1	1	1
11/26/2022 02:00	0.0	13.8	1,575.4	0.0	1.1	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.5	13.1	1,884.7	-0.3	1.3	3 #	2 #	3 #
Minimum:	-0.8	12.7	1,575.4	-0.4	1.1	0	0	0
Maximum:	0.0	13.8	2,062.0	0.0	1.4	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2022 02:00	0.0	17.4	344.2	0.0	0.2	1	0	0
11/28/2022 03:00	0.0	15.2	949.6	0.0	0.7	1	0	0
11/28/2022 04:00	0.3	13.7	1,724.6	0.4	1.2	1	1	0
11/28/2022 05:00	-0.1	13.7	1,654.5	0.1	1.2	1	1	1
11/28/2022 06:00	-0.9	12.5	2,164.7	-0.5	1.5	1	1	1
11/28/2022 07:00	-0.7	12.0	2,260.4	-0.2	1.6	1	1	1
11/28/2022 08:00	-0.8	13.0	1,970.9	-0.4	1.4	1	1	1
11/28/2022 09:00	0.3	13.8	1,613.8	0.4	1.1	1	1	0
11/28/2022 10:00	0.3	13.8	1,719.0	0.4	1.2	1	1	0
11/28/2022 11:00	0.3	13.8	1,526.4	0.4	1.1	1	1	0
11/28/2022 12:00	0.4	13.8	1,571.0	0.4	1.1	1	1	0
11/28/2022 13:00	0.4	13.8	1,644.0	0.4	1.2	1	1	0
11/28/2022 14:00	0.4	13.8	1,627.3	0.4	1.1	1	1	0
11/28/2022 15:00	0.1	13.7	1,623.7	0.2	1.1	1	1	1
11/28/2022 16:00	-0.8	12.8	2,023.4	-0.4	1.4	1	1	1
11/28/2022 17:00	-0.7	12.5	2,090.0	-0.2	1.5	1	1	1
11/28/2022 18:00	-0.7	13.0	1,980.4	-0.4	1.4	1	1	1
11/28/2022 19:00	-0.9	13.1	1,958.5	-0.5	1.4	1	1	1
11/28/2022 20:00	-0.8	12.7	2,080.3	-0.4	1.5	1	1	1
11/28/2022 21:00	-0.5	12.1	2,212.4	-0.1	1.5	1	1	1
11/28/2022 22:00	-0.7	12.7	2,084.2	-0.2	1.5	1	1	1
11/28/2022 23:00	-0.8	13.1	1,981.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.5	1,763.9	0.0	1.2	22 #	20 #	13 #
Minimum:	-0.9	12.0	344.2	-0.5	0.2	0	0	0
Maximum:	0.4	17.4	2,260.4	0.4	1.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	-0.7	12.4	2,141.8	-0.2	1.5	1	1	1
11/29/2022 01:00	-0.7	12.3	2,186.9	-0.2	1.5	1	1	1
11/29/2022 02:00	-0.7	12.3	2,175.4	-0.2	1.5	1	1	1
11/29/2022 03:00	-0.8	12.7	2,087.1	-0.4	1.5	1	1	1
11/29/2022 04:00	-0.7	12.5	2,149.0	-0.2	1.5	1	1	1
11/29/2022 05:00	-0.7	12.3	2,196.7	-0.2	1.5	1	1	1
11/29/2022 06:00	-0.5	11.9	2,281.7	-0.1	1.6	1	1	1
11/29/2022 07:00	-0.5	11.9	2,281.4	-0.1	1.6	1	1	1
11/29/2022 08:00	-0.5	11.9	2,244.1	-0.1	1.6	1	1	1
11/29/2022 09:00	-0.5	12.3	2,150.7	-0.1	1.5	1	1	1
11/29/2022 10:00	-0.5	12.3	2,145.0	-0.1	1.5	1	1	1
11/29/2022 11:00	-0.5	12.3	2,136.9	-0.1	1.5	1	1	1
11/29/2022 12:00	-0.5	12.3	2,126.6	-0.1	1.5	1	1	1
11/29/2022 13:00	-0.5	12.3	2,125.1	-0.1	1.5	1	1	1
11/29/2022 14:00	-0.5	12.3	2,128.4	-0.1	1.5	1	1	1
11/29/2022 15:00	-0.5	12.3	2,146.5	-0.1	1.5	1	1	1
11/29/2022 16:00	-0.4	11.8	2,253.8	-0.1	1.6	1	1	1
11/29/2022 17:00	-0.4	11.8	2,262.7	-0.1	1.6	1	1	1
11/29/2022 18:00	-0.4	11.8	2,269.7	-0.1	1.6	1	1	1
11/29/2022 19:00	-0.4	11.8	2,270.4	-0.1	1.6	1	1	1
11/29/2022 20:00	-0.5	11.9	2,275.0	-0.1	1.6	1	1	1
11/29/2022 21:00	-0.5	11.9	2,279.4	-0.1	1.6	1	1	1
11/29/2022 22:00	-0.5	11.9	2,281.0	-0.1	1.6	1	1	1
11/29/2022 23:00	-0.5	11.9	2,279.2	-0.1	1.6	1	1	1
Average/Sum#:	-0.5	12.1	2,203.1	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.8	2,087.1	-0.4	1.5	1	1	1
Maximum:	-0.4	12.7	2,281.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2022 00:00	-0.7	12.5	2,172.7	-0.2	1.5	1	1	1
11/30/2022 01:00	-0.7	12.5	2,154.2	-0.2	1.5	1	1	1
11/30/2022 02:00	-0.7	12.5	2,150.7	-0.2	1.5	1	1	1
11/30/2022 03:00	-0.7	12.5	2,151.7	-0.2	1.5	1	1	1
11/30/2022 04:00	-0.7	12.5	2,168.0	-0.2	1.5	1	1	1
11/30/2022 05:00	-0.8	12.5	2,165.1	-0.4	1.5	1	1	1
11/30/2022 06:00	-0.7	12.1	2,258.1	-0.2	1.6	1	1	1
11/30/2022 07:00	-0.7	12.5	2,146.1	-0.2	1.5	1	1	1
11/30/2022 08:00	-1.2	13.2	1,980.7	-0.8	1.4	1	1	1
11/30/2022 09:00	-1.2	13.1	1,994.5	-0.8	1.4	1	1	1
11/30/2022 10:00	-1.1	13.2	1,971.3	-0.7	1.4	1	1	1
11/30/2022 11:00	-1.1	13.1	1,965.9	-0.7	1.4	1	1	1
11/30/2022 12:00	-1.1	13.1	1,966.2	-0.7	1.4	1	1	1
11/30/2022 13:00	-0.9	13.0	1,964.4	-0.5	1.4	1	1	1
11/30/2022 14:00	-0.7	12.4	2,104.4	-0.2	1.5	1	1	1
11/30/2022 15:00	-0.7	12.3	2,113.2	-0.2	1.5	1	1	1
11/30/2022 16:00	-0.5	11.9	2,217.4	-0.1	1.6	1	1	1
11/30/2022 17:00	-0.4	11.7	2,265.7	0.1	1.6	1	1	1
11/30/2022 18:00	-0.4	11.7	2,264.2	0.1	1.6	1	1	1
11/30/2022 19:00	-0.4	11.7	2,263.8	0.1	1.6	1	1	1
11/30/2022 20:00	-0.4	11.8	2,258.6	-0.1	1.6	1	1	1
11/30/2022 21:00	-0.5	11.9	2,224.8	-0.1	1.6	1	1	1
11/30/2022 22:00	-0.7	12.5	2,086.6	-0.2	1.5	1	1	1
11/30/2022 23:00	0.0	13.7	1,584.9	0.0	1.1	1	0	1
Average/Sum#:	-0.7	12.5	2,108.1	-0.3	1.5	24 #	23 #	24 #
Minimum:	-1.2	11.7	1,584.9	-0.8	1.1	1	0	1
Maximum:	0.0	13.7	2,265.7	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 09:00	0.0	20.2	1.9	0.0	0.0	1	0	0
12/05/2022 10:00	0.0	16.6	470.2	0.0	0.3	1	0	0
12/05/2022 11:00	0.0	13.2	1,793.9	0.0	1.3	1	0	1
12/05/2022 12:00	-0.7	12.2	2,140.7	-0.2	1.5	1	1	1
12/05/2022 13:00	-0.7	12.7	2,012.1	-0.2	1.4	1	1	1
12/05/2022 14:00	-0.7	12.7	2,032.3	-0.2	1.4	1	1	1
12/05/2022 15:00	-0.5	12.6	2,051.5	-0.2	1.4	1	1	1
12/05/2022 16:00	-0.5	12.0	2,193.6	-0.1	1.5	1	1	1
12/05/2022 17:00	-0.4	11.7	2,269.5	0.1	1.6	1	1	1
12/05/2022 18:00	-0.4	11.7	2,271.5	0.1	1.6	1	1	1
12/05/2022 19:00	-0.4	11.7	2,271.1	0.1	1.6	1	1	1
12/05/2022 20:00	-0.5	11.8	2,272.1	-0.1	1.6	1	1	1
12/05/2022 21:00	-0.5	12.1	2,201.5	-0.1	1.5	1	1	1
12/05/2022 22:00	-0.8	12.7	2,067.0	-0.4	1.4	1	1	1
12/05/2022 23:00	-0.8	12.8	2,045.9	-0.4	1.4	1	1	1
Average/Sum#:	-0.5	13.1	1,873.0	-0.1	1.3	15 #	12 #	13 #
Minimum:	-0.8	11.7	1.9	-0.4	0.0	0	0	0
Maximum:	0.0	20.2	2,272.1	0.1	1.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2022 00:00	-1.1	13.2	1,967.2	-0.7	1.4	1	1	1
12/06/2022 01:00	-1.2	13.2	1,966.1	-0.8	1.4	1	1	1
12/06/2022 02:00	-1.2	13.2	1,965.7	-0.8	1.4	1	1	1
12/06/2022 03:00	-1.2	13.2	1,967.0	-0.8	1.4	1	1	1
12/06/2022 04:00	-1.1	13.1	1,982.2	-0.7	1.4	1	1	1
12/06/2022 05:00	-0.8	12.9	2,009.3	-0.4	1.4	1	1	1
12/06/2022 06:00	-1.1	13.1	1,982.0	-0.7	1.4	1	1	1
12/06/2022 07:00	-0.8	12.7	2,084.6	-0.4	1.5	1	1	1
12/06/2022 08:00	-0.7	11.9	2,259.2	-0.2	1.6	1	1	1
12/06/2022 09:00	-0.5	12.0	2,240.1	-0.1	1.6	1	1	1
12/06/2022 10:00	-0.5	12.0	2,234.8	-0.1	1.6	1	1	1
12/06/2022 11:00	-0.5	12.0	2,230.6	-0.1	1.6	1	1	1
12/06/2022 12:00	-0.5	12.0	2,217.9	-0.1	1.6	1	1	1
12/06/2022 13:00	0.1	13.6	1,788.8	0.2	1.3	1	1	1
12/06/2022 14:00	0.3	13.9	1,318.8	0.4	0.9	1	1	0
12/06/2022 15:00	0.3	13.9	1,318.6	0.4	0.9	1	1	0
12/06/2022 16:00	0.3	13.8	1,520.8	0.4	1.1	1	1	0
12/06/2022 17:00	0.4	13.7	1,823.5	0.4	1.3	1	1	0
12/06/2022 18:00	0.4	13.7	1,825.1	0.4	1.3	1	1	0
12/06/2022 19:00	0.1	13.7	1,829.3	0.2	1.3	1	1	1
12/06/2022 20:00	-0.8	12.5	2,123.4	-0.4	1.5	1	1	1
12/06/2022 21:00	-0.5	12.0	2,220.9	-0.1	1.6	1	1	1
12/06/2022 22:00	-0.7	12.5	2,096.6	-0.2	1.5	1	1	1
12/06/2022 23:00	-0.8	13.2	1,968.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.0	1,955.9	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.9	1,318.6	-0.8	0.9	1	1	0
Maximum:	0.4	13.9	2,259.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	-0.7	12.7	2,080.4	-0.2	1.5	1	1	1
12/07/2022 01:00	-0.8	13.1	1,983.5	-0.5	1.4	1	1	1
12/07/2022 02:00	-0.7	12.5	2,133.1	-0.2	1.5	1	1	1
12/07/2022 03:00	-0.7	12.5	2,140.6	-0.2	1.5	1	1	1
12/07/2022 04:00	-0.7	12.4	2,147.2	-0.2	1.5	1	1	1
12/07/2022 05:00	-0.7	12.3	2,161.2	-0.2	1.5	1	1	1
12/07/2022 06:00	-0.7	12.1	2,240.0	-0.2	1.6	1	1	1
12/07/2022 07:00	-0.5	12.0	2,240.5	-0.1	1.6	1	1	1
12/07/2022 08:00	-0.7	12.6	2,123.6	-0.2	1.5	1	1	1
12/07/2022 09:00	-0.7	12.5	2,160.5	-0.2	1.5	1	1	1
12/07/2022 10:00	-0.7	12.4	2,154.7	-0.2	1.5	1	1	1
12/07/2022 11:00	-0.7	12.4	2,152.0	-0.2	1.5	1	1	1
12/07/2022 12:00	-0.7	12.5	2,125.4	-0.2	1.5	1	1	1
12/07/2022 13:00	-0.5	12.5	2,105.1	-0.2	1.5	1	1	1
12/07/2022 14:00	-0.7	12.7	2,045.2	-0.2	1.4	1	1	1
12/07/2022 15:00	-0.7	12.6	2,072.9	-0.2	1.5	1	1	1
12/07/2022 16:00	-0.5	11.9	2,242.3	-0.1	1.6	1	1	1
12/07/2022 17:00	-0.5	11.8	2,263.1	-0.1	1.6	1	1	1
12/07/2022 18:00	-0.5	11.9	2,262.6	-0.1	1.6	1	1	1
12/07/2022 19:00	-0.5	11.9	2,259.5	-0.1	1.6	1	1	1
12/07/2022 20:00	-0.5	11.9	2,260.4	-0.1	1.6	1	1	1
12/07/2022 21:00	-0.5	12.0	2,254.9	-0.1	1.6	1	1	1
12/07/2022 22:00	-0.7	12.4	2,171.8	-0.2	1.5	1	1	1
12/07/2022 23:00	-0.7	12.4	2,171.2	-0.2	1.5	1	1	1
Average/Sum#:	-0.6	12.3	2,164.7	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.8	1,983.5	-0.5	1.4	1	1	1
Maximum:	-0.5	13.1	2,263.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	-0.7	12.6	2,128.3	-0.2	1.5	1	1	1
12/08/2022 01:00	-0.7	12.6	2,124.0	-0.2	1.5	1	1	1
12/08/2022 02:00	-0.7	12.6	2,125.4	-0.2	1.5	1	1	1
12/08/2022 03:00	-0.7	12.6	2,126.6	-0.2	1.5	1	1	1
12/08/2022 04:00	-0.7	12.5	2,151.8	-0.2	1.5	1	1	1
12/08/2022 05:00	-0.8	12.1	2,206.3	-0.4	1.5	1	1	1
12/08/2022 06:00	-0.7	12.0	2,276.7	-0.2	1.6	1	1	1
12/08/2022 07:00	-0.7	12.2	2,235.9	-0.2	1.6	1	1	1
12/08/2022 08:00	-0.9	13.0	2,033.3	-0.5	1.4	1	1	1
12/08/2022 09:00	-0.8	12.7	2,119.8	-0.4	1.5	1	1	1
12/08/2022 10:00	-0.7	12.6	2,125.2	-0.2	1.5	1	1	1
12/08/2022 11:00	-0.7	12.5	2,152.4	-0.2	1.5	1	1	1
12/08/2022 12:00	-0.7	12.4	2,146.3	-0.2	1.5	1	1	1
12/08/2022 13:00	-0.7	12.3	2,151.6	-0.2	1.5	1	1	1
12/08/2022 14:00	-0.7	12.3	2,154.1	-0.2	1.5	1	1	1
12/08/2022 15:00	-0.7	12.3	2,161.0	-0.2	1.5	1	1	1
12/08/2022 16:00	-0.5	11.8	2,252.5	-0.1	1.6	1	1	1
12/08/2022 17:00	-0.5	11.9	2,253.7	-0.1	1.6	1	1	1
12/08/2022 18:00	-0.5	11.8	2,260.9	-0.1	1.6	1	1	1
12/08/2022 19:00	-0.5	11.8	2,258.9	-0.1	1.6	1	1	1
12/08/2022 20:00	-0.5	11.8	2,260.5	-0.1	1.6	1	1	1
12/08/2022 21:00	-0.5	11.8	2,262.3	-0.1	1.6	1	1	1
12/08/2022 22:00	-0.7	12.2	2,175.3	-0.2	1.5	1	1	1
12/08/2022 23:00	-0.7	12.3	2,175.7	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.3	2,179.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.8	2,033.3	-0.5	1.4	1	1	1
Maximum:	-0.5	13.0	2,276.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2022 00:00	-0.7	12.4	2,133.4	-0.2	1.5	1	1	1
12/09/2022 01:00	-0.8	12.9	2,049.3	-0.4	1.4	1	1	1
12/09/2022 02:00	-0.7	12.5	2,145.6	-0.2	1.5	1	1	1
12/09/2022 03:00	-0.7	12.5	2,141.8	-0.2	1.5	1	1	1
12/09/2022 04:00	-0.7	12.3	2,188.2	-0.2	1.5	1	1	1
12/09/2022 05:00	-0.7	11.9	2,279.0	-0.2	1.6	1	1	1
12/09/2022 06:00	-0.7	11.9	2,284.6	-0.2	1.6	1	1	1
12/09/2022 07:00	-0.7	12.0	2,273.6	-0.2	1.6	1	1	1
12/09/2022 08:00	-0.9	12.8	2,069.7	-0.5	1.4	1	1	1
12/09/2022 09:00	-0.9	13.0	2,024.0	-0.5	1.4	1	1	1
12/09/2022 10:00	-1.2	13.2	1,975.9	-0.8	1.4	1	1	1
12/09/2022 11:00	-0.8	12.8	2,071.4	-0.4	1.4	1	1	1
12/09/2022 12:00	-0.9	13.0	2,003.4	-0.5	1.4	1	1	1
12/09/2022 13:00	-0.7	12.4	2,147.1	-0.2	1.5	1	1	1
12/09/2022 14:00	-0.7	12.4	2,137.6	-0.2	1.5	1	1	1
12/09/2022 15:00	-0.9	12.8	2,036.0	-0.5	1.4	1	1	1
12/09/2022 16:00	-0.5	11.9	2,251.5	-0.1	1.6	1	1	1
12/09/2022 17:00	-0.5	11.9	2,251.1	-0.1	1.6	1	1	1
12/09/2022 18:00	-0.5	11.9	2,251.7	-0.1	1.6	1	1	1
12/09/2022 19:00	-0.5	11.9	2,253.6	-0.1	1.6	1	1	1
12/09/2022 20:00	-0.5	11.9	2,258.2	-0.1	1.6	1	1	1
12/09/2022 21:00	-0.5	11.9	2,257.3	-0.1	1.6	1	1	1
12/09/2022 22:00	-0.5	11.9	2,255.6	-0.1	1.6	1	1	1
12/09/2022 23:00	-0.5	11.9	2,249.1	-0.1	1.6	1	1	1
Average/Sum#:	-0.7	12.3	2,166.2	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.9	1,975.9	-0.8	1.4	1	1	1
Maximum:	-0.5	13.2	2,284.6	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	-0.9	12.9	2,006.4	-0.5	1.4	1	1	1
12/10/2022 01:00	-0.9	12.9	1,999.6	-0.5	1.4	1	1	1
12/10/2022 02:00	-1.1	13.1	1,963.4	-0.7	1.4	1	1	1
12/10/2022 03:00	-1.1	13.0	1,964.2	-0.7	1.4	1	1	1
12/10/2022 04:00	-1.1	13.0	1,959.0	-0.7	1.4	1	1	1
12/10/2022 05:00	-1.1	12.9	1,970.7	-0.7	1.4	1	1	1
12/10/2022 06:00	-1.2	13.0	1,958.3	-0.8	1.4	1	1	1
12/10/2022 07:00	-1.2	13.0	1,965.3	-0.8	1.4	1	1	1
12/10/2022 08:00	-0.9	12.8	2,005.5	-0.5	1.4	1	1	1
12/10/2022 09:00	-1.1	12.9	1,981.7	-0.7	1.4	1	1	1
12/10/2022 10:00	-1.2	13.0	1,958.2	-0.8	1.4	1	1	1
12/10/2022 11:00	-0.9	12.7	2,001.0	-0.5	1.4	1	1	1
12/10/2022 12:00	-0.7	12.3	2,097.7	-0.2	1.5	1	1	1
12/10/2022 13:00	-0.5	12.0	2,155.9	-0.1	1.5	1	1	1
12/10/2022 14:00	-0.7	12.6	2,002.4	-0.2	1.4	1	1	1
12/10/2022 15:00	-0.7	12.6	2,024.6	-0.2	1.4	1	1	1
12/10/2022 16:00	-0.7	12.3	2,094.2	-0.2	1.5	1	1	1
12/10/2022 17:00	-0.7	12.5	2,057.1	-0.2	1.4	1	1	1
12/10/2022 18:00	-0.8	12.5	2,058.1	-0.4	1.4	1	1	1
12/10/2022 19:00	-0.5	11.8	2,229.9	-0.1	1.6	1	1	1
12/10/2022 20:00	-0.5	12.1	2,153.8	-0.1	1.5	1	1	1
12/10/2022 21:00	-0.7	12.5	2,068.8	-0.2	1.4	1	1	1
12/10/2022 22:00	-0.8	12.8	2,009.3	-0.4	1.4	1	1	1
12/10/2022 23:00	-0.7	12.5	2,063.5	-0.2	1.4	1	1	1
Average/Sum#:	-0.9	12.7	2,031.2	-0.4	1.4	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,958.2	-0.8	1.4	1	1	1
Maximum:	-0.5	13.1	2,229.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	-0.9	13.0	1,956.5	-0.5	1.4	1	1	1
12/11/2022 01:00	-1.1	13.1	1,954.5	-0.7	1.4	1	1	1
12/11/2022 02:00	-1.1	13.1	1,954.5	-0.7	1.4	1	1	1
12/11/2022 03:00	-1.1	13.1	1,953.0	-0.7	1.4	1	1	1
12/11/2022 04:00	-1.2	13.1	1,955.4	-0.8	1.4	1	1	1
12/11/2022 05:00	-1.2	13.1	1,956.0	-0.8	1.4	1	1	1
12/11/2022 06:00	-1.2	13.1	1,958.5	-0.8	1.4	1	1	1
12/11/2022 07:00	-1.2	13.1	1,960.5	-0.8	1.4	1	1	1
12/11/2022 08:00	-1.2	13.1	1,961.5	-0.8	1.4	1	1	1
12/11/2022 09:00	-1.2	13.1	1,964.5	-0.8	1.4	1	1	1
12/11/2022 10:00	-1.2	13.1	1,963.7	-0.8	1.4	1	1	1
12/11/2022 11:00	-1.1	13.1	1,959.8	-0.7	1.4	1	1	1
12/11/2022 12:00	-1.1	13.1	1,958.4	-0.7	1.4	1	1	1
12/11/2022 13:00	-1.1	13.0	1,960.6	-0.7	1.4	1	1	1
12/11/2022 14:00	-1.1	13.0	1,958.2	-0.7	1.4	1	1	1
12/11/2022 15:00	-0.8	12.7	2,050.1	-0.4	1.4	1	1	1
12/11/2022 16:00	-0.8	12.7	2,053.8	-0.4	1.4	1	1	1
12/11/2022 17:00	-0.7	12.4	2,123.8	-0.2	1.5	1	1	1
12/11/2022 18:00	-0.9	12.9	2,040.4	-0.5	1.4	1	1	1
12/11/2022 19:00	-0.8	12.8	2,068.4	-0.4	1.4	1	1	1
12/11/2022 20:00	-0.8	12.6	2,119.1	-0.4	1.5	1	1	1
12/11/2022 21:00	-1.1	13.1	2,002.7	-0.7	1.4	1	1	1
12/11/2022 22:00	-1.2	13.2	1,968.1	-0.8	1.4	1	1	1
12/11/2022 23:00	-1.2	13.2	1,965.9	-0.8	1.4	1	1	1
Average/Sum#:	-1.1	13.0	1,990.3	-0.7	1.4	24 #	24 #	24 #
Minimum:	-1.2	12.4	1,953.0	-0.8	1.4	1	1	1
Maximum:	-0.7	13.2	2,123.8	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	-1.2	13.2	1,974.6	-0.8	1.4	1	1	1
12/12/2022 01:00	-1.2	13.2	1,974.7	-0.8	1.4	1	1	1
12/12/2022 02:00	-1.2	13.2	1,974.6	-0.8	1.4	1	1	1
12/12/2022 03:00	-1.2	13.2	1,972.4	-0.8	1.4	1	1	1
12/12/2022 04:00	-1.2	13.2	1,975.3	-0.8	1.4	1	1	1
12/12/2022 05:00	-0.8	12.4	2,111.2	-0.4	1.5	1	1	1
12/12/2022 06:00	-0.7	12.3	2,205.4	-0.2	1.5	1	1	1
12/12/2022 07:00	-0.7	12.3	2,187.8	-0.2	1.5	1	1	1
12/12/2022 08:00	-0.9	12.8	2,074.1	-0.5	1.5	1	1	1
12/12/2022 09:00	-0.8	12.8	2,066.2	-0.4	1.4	1	1	1
12/12/2022 10:00	-1.2	13.2	1,973.4	-0.8	1.4	1	1	1
12/12/2022 11:00	-1.2	13.2	1,968.1	-0.8	1.4	1	1	1
12/12/2022 12:00	-1.2	13.2	1,964.0	-0.8	1.4	1	1	1
12/12/2022 13:00	-1.1	13.1	1,961.0	-0.7	1.4	1	1	1
12/12/2022 14:00	-1.1	13.1	1,953.7	-0.7	1.4	1	1	1
12/12/2022 15:00	-1.1	13.1	1,956.5	-0.7	1.4	1	1	1
12/12/2022 16:00	-0.7	12.4	2,131.9	-0.2	1.5	1	1	1
12/12/2022 17:00	-0.5	12.0	2,216.3	-0.1	1.6	1	1	1
12/12/2022 18:00	-0.4	11.8	2,275.3	-0.1	1.6	1	1	1
12/12/2022 19:00	-0.4	11.8	2,277.0	-0.1	1.6	1	1	1
12/12/2022 20:00	-0.4	11.8	2,281.0	-0.1	1.6	1	1	1
12/12/2022 21:00	-0.5	12.0	2,246.6	-0.1	1.6	1	1	1
12/12/2022 22:00	-0.5	12.3	2,188.8	-0.1	1.5	1	1	1
12/12/2022 23:00	-0.8	13.0	2,025.1	-0.4	1.4	1	1	1
Average/Sum#:	-0.9	12.7	2,080.6	-0.5	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,953.7	-0.8	1.4	1	1	1
Maximum:	-0.4	13.2	2,281.0	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	-0.7	12.6	2,151.0	-0.2	1.5	1	1	1
12/13/2022 01:00	-0.7	12.5	2,157.4	-0.2	1.5	1	1	1
12/13/2022 02:00	-0.7	12.4	2,161.4	-0.2	1.5	1	1	1
12/13/2022 03:00	-0.7	12.5	2,146.4	-0.2	1.5	1	1	1
12/13/2022 04:00	-0.7	12.4	2,189.1	-0.2	1.5	1	1	1
12/13/2022 05:00	-0.7	12.0	2,273.8	-0.2	1.6	1	1	1
12/13/2022 06:00	-0.5	11.9	2,310.2	-0.1	1.6	1	1	1
12/13/2022 07:00	-0.5	11.9	2,287.8	-0.1	1.6	1	1	1
12/13/2022 08:00	-0.7	12.5	2,134.0	-0.2	1.5	1	1	1
12/13/2022 09:00	-0.9	13.0	2,010.3	-0.5	1.4	1	1	1
12/13/2022 10:00	-1.1	13.2	1,963.5	-0.7	1.4	1	1	1
12/13/2022 11:00	-1.1	13.2	1,966.2	-0.7	1.4	1	1	1
12/13/2022 12:00	-1.1	13.1	1,963.9	-0.7	1.4	1	1	1
12/13/2022 13:00	-1.1	13.1	1,958.8	-0.7	1.4	1	1	1
12/13/2022 14:00	-1.1	13.1	1,948.4	-0.7	1.4	1	1	1
12/13/2022 15:00	-0.8	12.7	2,055.9	-0.4	1.4	1	1	1
12/13/2022 16:00	-0.4	11.9	2,251.4	-0.1	1.6	1	1	1
12/13/2022 17:00	-0.4	11.8	2,271.2	-0.1	1.6	1	1	1
12/13/2022 18:00	-0.4	11.8	2,273.1	-0.1	1.6	1	1	1
12/13/2022 19:00	-0.4	11.9	2,270.7	-0.1	1.6	1	1	1
12/13/2022 20:00	-0.5	11.9	2,269.3	-0.1	1.6	1	1	1
12/13/2022 21:00	-0.5	12.0	2,274.0	-0.1	1.6	1	1	1
12/13/2022 22:00	-0.5	12.0	2,272.2	-0.1	1.6	1	1	1
12/13/2022 23:00	-0.5	11.9	2,268.0	-0.1	1.6	1	1	1
Average/Sum#:	-0.7	12.4	2,159.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.8	1,948.4	-0.7	1.4	1	1	1
Maximum:	-0.4	13.2	2,310.2	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	-0.5	12.3	2,186.8	-0.1	1.5	1	1	1
12/14/2022 01:00	-0.7	12.4	2,187.5	-0.2	1.5	1	1	1
12/14/2022 02:00	-0.7	12.4	2,188.4	-0.2	1.5	1	1	1
12/14/2022 03:00	-0.7	12.4	2,189.7	-0.2	1.5	1	1	1
12/14/2022 04:00	-0.7	12.4	2,186.4	-0.2	1.5	1	1	1
12/14/2022 05:00	-0.7	12.0	2,291.8	-0.2	1.6	1	1	1
12/14/2022 06:00	-0.5	12.0	2,297.1	-0.1	1.6	1	1	1
12/14/2022 07:00	-0.5	12.1	2,255.1	-0.1	1.6	1	1	1
12/14/2022 08:00	-0.8	12.9	2,069.6	-0.4	1.4	1	1	1
12/14/2022 09:00	-0.9	13.1	2,007.9	-0.5	1.4	1	1	1
12/14/2022 10:00	-0.8	13.0	2,023.9	-0.4	1.4	1	1	1
12/14/2022 11:00	-0.9	13.2	1,967.4	-0.5	1.4	1	1	1
12/14/2022 12:00	-1.1	13.2	1,967.7	-0.7	1.4	1	1	1
12/14/2022 13:00	-0.9	13.2	1,966.4	-0.5	1.4	1	1	1
12/14/2022 14:00	-0.9	13.2	1,961.9	-0.5	1.4	1	1	1
12/14/2022 15:00	-0.9	13.0	2,003.9	-0.5	1.4	1	1	1
12/14/2022 16:00	-0.5	12.2	2,196.7	-0.1	1.5	1	1	1
12/14/2022 17:00	-0.5	11.9	2,270.2	-0.1	1.6	1	1	1
12/14/2022 18:00	-0.5	11.9	2,263.7	-0.1	1.6	1	1	1
12/14/2022 19:00	-0.5	11.9	2,270.0	-0.1	1.6	1	1	1
12/14/2022 20:00	-0.5	11.9	2,269.8	-0.1	1.6	1	1	1
12/14/2022 21:00	-0.5	12.0	2,270.9	-0.1	1.6	1	1	1
12/14/2022 22:00	-0.5	12.1	2,250.1	-0.1	1.6	1	1	1
12/14/2022 23:00	-0.5	12.4	2,172.6	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.5	2,154.8	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.9	1,961.9	-0.7	1.4	1	1	1
Maximum:	-0.5	13.2	2,297.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2022 00:00	-0.5	11.9	2,285.2	-0.1	1.6	1	1	1
12/15/2022 01:00	-0.5	11.9	2,294.2	-0.1	1.6	1	1	1
12/15/2022 02:00	-0.4	11.9	2,295.1	-0.1	1.6	1	1	1
12/15/2022 03:00	-0.5	11.9	2,296.8	-0.1	1.6	1	1	1
12/15/2022 04:00	-0.4	11.9	2,302.4	-0.1	1.6	1	1	1
12/15/2022 05:00	-0.4	11.8	2,305.6	-0.1	1.6	1	1	1
12/15/2022 06:00	-0.4	11.8	2,303.9	-0.1	1.6	1	1	1
12/15/2022 07:00	-0.4	11.9	2,297.7	-0.1	1.6	1	1	1
12/15/2022 08:00	-0.4	12.2	2,216.9	-0.1	1.6	1	1	1
12/15/2022 09:00	-0.5	12.1	2,210.5	-0.1	1.5	1	1	1
12/15/2022 10:00	-0.8	13.1	1,975.6	-0.5	1.4	1	1	1
12/15/2022 11:00	-0.8	13.0	1,984.0	-0.4	1.4	1	1	1
12/15/2022 12:00	-0.7	12.8	2,010.5	-0.4	1.4	1	1	1
12/15/2022 13:00	-0.7	12.8	2,027.3	-0.4	1.4	1	1	1
12/15/2022 14:00	-0.4	12.5	2,076.8	-0.1	1.5	1	1	1
12/15/2022 15:00	-0.4	11.9	2,224.3	-0.1	1.6	1	1	1
12/15/2022 16:00	-0.2	11.9	2,242.6	0.1	1.6	1	1	1
12/15/2022 17:00	-0.4	11.9	2,240.4	-0.1	1.6	1	1	1
12/15/2022 18:00	-0.4	12.0	2,233.1	-0.1	1.6	1	1	1
12/15/2022 19:00	-0.5	12.0	2,230.3	-0.1	1.6	1	1	1
12/15/2022 20:00	-0.4	12.0	2,232.7	-0.1	1.6	1	1	1
12/15/2022 21:00	-0.5	12.1	2,238.4	-0.1	1.6	1	1	1
12/15/2022 22:00	-0.5	12.1	2,242.7	-0.1	1.6	1	1	1
12/15/2022 23:00	-0.5	12.2	2,230.3	-0.1	1.6	1	1	1
Average/Sum#:	-0.5	12.2	2,208.2	-0.1	1.6	24 #	24 #	24 #
Minimum:	-0.8	11.8	1,975.6	-0.5	1.4	1	1	1
Maximum:	-0.2	13.1	2,305.6	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2022 00:00	-0.9	13.1	1,993.7	-0.5	1.4	1	1	1
12/16/2022 01:00	-1.1	13.2	1,967.6	-0.7	1.4	1	1	1
12/16/2022 02:00	-1.1	13.2	1,966.9	-0.7	1.4	1	1	1
12/16/2022 03:00	-1.1	13.2	1,969.7	-0.7	1.4	1	1	1
12/16/2022 04:00	-1.1	13.2	1,968.6	-0.7	1.4	1	1	1
12/16/2022 05:00	-1.1	13.2	1,982.9	-0.7	1.4	1	1	1
12/16/2022 06:00	-0.8	12.7	2,114.1	-0.4	1.5	1	1	1
12/16/2022 07:00	-0.5	12.3	2,208.1	-0.1	1.5	1	1	1
12/16/2022 08:00	-0.5	12.6	2,142.7	-0.2	1.5	1	1	1
12/16/2022 09:00	-0.7	12.7	2,066.1	-0.2	1.4	1	1	1
12/16/2022 10:00	0.4	13.8	1,542.9	0.4	1.1	1	1	0
12/16/2022 11:00	0.3	13.9	1,461.4	0.4	1.0	1	1	0
12/16/2022 12:00	0.2	13.9	1,324.4	0.3	0.9	1	1	0
12/16/2022 13:00	0.3	13.9	1,326.3	0.4	0.9	1	1	0
12/16/2022 14:00	0.4	13.8	1,587.9	0.4	1.1	1	1	0
12/16/2022 15:00	0.1	13.8	1,555.8	0.2	1.1	1	1	1
12/16/2022 16:00	-0.7	12.4	2,147.0	-0.2	1.5	1	1	1
12/16/2022 17:00	-0.5	12.0	2,222.2	-0.1	1.6	1	1	1
12/16/2022 18:00	-0.5	12.4	2,150.0	-0.2	1.5	1	1	1
12/16/2022 19:00	-0.5	12.4	2,159.8	-0.2	1.5	1	1	1
12/16/2022 20:00	-0.4	11.9	2,243.7	-0.1	1.6	1	1	1
12/16/2022 21:00	-0.5	12.2	2,187.6	-0.1	1.5	1	1	1
12/16/2022 22:00	-0.7	12.7	2,087.4	-0.2	1.5	1	1	1
12/16/2022 23:00	-0.9	13.2	1,976.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.0	1,931.4	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.9	1,324.4	-0.7	0.9	1	1	0
Maximum:	0.4	13.9	2,243.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	-0.7	12.5	2,146.2	-0.2	1.5	1	1	1
12/17/2022 01:00	-0.7	12.5	2,148.8	-0.2	1.5	1	1	1
12/17/2022 02:00	-0.7	12.5	2,140.6	-0.2	1.5	1	1	1
12/17/2022 03:00	-0.7	12.5	2,153.2	-0.2	1.5	1	1	1
12/17/2022 04:00	-0.7	12.5	2,153.6	-0.2	1.5	1	1	1
12/17/2022 05:00	-0.7	12.5	2,151.4	-0.2	1.5	1	1	1
12/17/2022 06:00	-0.5	12.2	2,233.8	-0.1	1.6	1	1	1
12/17/2022 07:00	-0.7	12.7	2,099.2	-0.2	1.5	1	1	1
12/17/2022 08:00	-0.7	12.5	2,159.2	-0.2	1.5	1	1	1
12/17/2022 09:00	-0.7	12.6	2,117.2	-0.2	1.5	1	1	1
12/17/2022 10:00	-0.8	13.1	1,997.6	-0.5	1.4	1	1	1
12/17/2022 11:00	-0.9	13.2	1,964.4	-0.5	1.4	1	1	1
12/17/2022 12:00	-0.9	13.2	1,960.9	-0.5	1.4	1	1	1
12/17/2022 13:00	-0.8	13.1	1,956.6	-0.5	1.4	1	1	1
12/17/2022 14:00	-0.8	13.0	1,970.0	-0.4	1.4	1	1	1
12/17/2022 15:00	-0.5	12.5	2,100.3	-0.2	1.5	1	1	1
12/17/2022 16:00	-0.4	11.9	2,248.1	-0.1	1.6	1	1	1
12/17/2022 17:00	-0.5	12.0	2,217.8	-0.1	1.6	1	1	1
12/17/2022 18:00	-0.5	12.4	2,137.6	-0.2	1.5	1	1	1
12/17/2022 19:00	-0.5	11.8	2,260.0	-0.1	1.6	1	1	1
12/17/2022 20:00	-0.4	11.8	2,263.2	-0.1	1.6	1	1	1
12/17/2022 21:00	-0.4	11.8	2,264.7	-0.1	1.6	1	1	1
12/17/2022 22:00	-0.4	11.9	2,261.6	-0.1	1.6	1	1	1
12/17/2022 23:00	-0.5	12.3	2,180.2	-0.1	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,136.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.8	1,956.6	-0.5	1.4	1	1	1
Maximum:	-0.4	13.2	2,264.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	-0.5	12.5	2,132.5	-0.2	1.5	1	1	1
12/18/2022 01:00	-0.7	12.6	2,135.5	-0.2	1.5	1	1	1
12/18/2022 02:00	-0.9	13.0	2,021.6	-0.5	1.4	1	1	1
12/18/2022 03:00	-1.1	13.2	1,975.9	-0.7	1.4	1	1	1
12/18/2022 04:00	-0.7	12.6	2,135.5	-0.2	1.5	1	1	1
12/18/2022 05:00	-0.7	12.5	2,156.2	-0.2	1.5	1	1	1
12/18/2022 06:00	-0.7	12.4	2,171.1	-0.2	1.5	1	1	1
12/18/2022 07:00	-0.7	12.3	2,208.2	-0.2	1.5	1	1	1
12/18/2022 08:00	-0.7	12.6	2,085.2	-0.2	1.5	1	1	1
12/18/2022 09:00	0.3	13.8	1,618.7	0.4	1.1	1	1	0
12/18/2022 10:00	0.3	13.8	1,561.3	0.4	1.1	1	1	0
12/18/2022 11:00	0.3	13.8	1,559.0	0.4	1.1	1	1	0
12/18/2022 12:00	0.2	13.8	1,408.9	0.3	1.0	1	1	0
12/18/2022 13:00	0.2	13.8	1,399.2	0.3	1.0	1	1	0
12/18/2022 14:00	0.3	13.8	1,643.4	0.4	1.2	1	1	0
12/18/2022 15:00	0.1	13.8	1,651.7	0.2	1.2	1	1	1
12/18/2022 16:00	-0.8	12.4	2,130.5	-0.4	1.5	1	1	1
12/18/2022 17:00	-0.5	12.0	2,242.0	-0.1	1.6	1	1	1
12/18/2022 18:00	-0.5	11.9	2,269.4	-0.1	1.6	1	1	1
12/18/2022 19:00	-0.5	11.9	2,270.4	-0.1	1.6	1	1	1
12/18/2022 20:00	-0.7	12.1	2,236.3	-0.2	1.6	1	1	1
12/18/2022 21:00	-0.7	12.3	2,210.2	-0.2	1.5	1	1	1
12/18/2022 22:00	-0.7	12.4	2,198.1	-0.2	1.5	1	1	1
12/18/2022 23:00	-0.9	12.9	2,049.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.4	12.8	1,977.9	-0.1	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.9	1,399.2	-0.7	1.0	1	1	0
Maximum:	0.3	13.8	2,270.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2022 00:00	-0.8	12.6	2,143.3	-0.4	1.5	1	1	1
12/19/2022 01:00	-0.7	12.5	2,153.6	-0.2	1.5	1	1	1
12/19/2022 02:00	-0.7	12.6	2,150.3	-0.2	1.5	1	1	1
12/19/2022 03:00	-0.7	12.6	2,151.5	-0.2	1.5	1	1	1
12/19/2022 04:00	-0.8	12.5	2,181.6	-0.4	1.5	1	1	1
12/19/2022 05:00	-0.7	12.0	2,296.4	-0.2	1.6	1	1	1
12/19/2022 06:00	-0.7	12.0	2,296.2	-0.2	1.6	1	1	1
12/19/2022 07:00	-0.7	12.0	2,295.5	-0.2	1.6	1	1	1
12/19/2022 08:00	-0.7	12.1	2,248.0	-0.2	1.6	1	1	1
12/19/2022 09:00	-0.7	12.1	2,257.3	-0.2	1.6	1	1	1
12/19/2022 10:00	-0.7	12.5	2,169.7	-0.2	1.5	1	1	1
12/19/2022 11:00	-0.7	12.5	2,172.8	-0.2	1.5	1	1	1
12/19/2022 12:00	-0.7	12.5	2,163.1	-0.2	1.5	1	1	1
12/19/2022 13:00	-0.7	12.5	2,154.7	-0.2	1.5	1	1	1
12/19/2022 14:00	-0.7	12.5	2,157.0	-0.2	1.5	1	1	1
12/19/2022 15:00	-0.7	12.3	2,218.7	-0.2	1.6	1	1	1
12/19/2022 16:00	-0.7	12.1	2,259.5	-0.2	1.6	1	1	1
12/19/2022 17:00	-0.7	12.1	2,264.7	-0.2	1.6	1	1	1
12/19/2022 18:00	-0.7	12.1	2,265.6	-0.2	1.6	1	1	1
12/19/2022 19:00	-0.7	12.1	2,264.2	-0.2	1.6	1	1	1
12/19/2022 20:00	-0.7	12.1	2,259.5	-0.2	1.6	1	1	1
12/19/2022 21:00	-0.7	12.1	2,259.7	-0.2	1.6	1	1	1
12/19/2022 22:00	-0.7	12.1	2,264.3	-0.2	1.6	1	1	1
12/19/2022 23:00	-0.7	12.1	2,263.6	-0.2	1.6	1	1	1
Average/Sum#:	-0.7	12.3	2,221.3	-0.2	1.6	24 #	24 #	24 #
Minimum:	-0.8	12.0	2,143.3	-0.4	1.5	1	1	1
Maximum:	-0.7	12.6	2,296.4	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	-0.7	12.5	2,172.5	-0.2	1.5	1	1	1
12/20/2022 01:00	-0.7	12.5	2,169.3	-0.2	1.5	1	1	1
12/20/2022 02:00	-0.7	12.5	2,173.2	-0.2	1.5	1	1	1
12/20/2022 03:00	-0.7	12.5	2,179.2	-0.2	1.5	1	1	1
12/20/2022 04:00	-0.7	12.5	2,184.8	-0.2	1.5	1	1	1
12/20/2022 05:00	-0.7	12.5	2,186.9	-0.2	1.5	1	1	1
12/20/2022 06:00	-0.7	12.1	2,279.9	-0.2	1.6	1	1	1
12/20/2022 07:00	-0.7	12.1	2,273.5	-0.2	1.6	1	1	1
12/20/2022 08:00	-0.7	12.5	2,163.7	-0.2	1.5	1	1	1
12/20/2022 09:00	-0.7	12.5	2,161.4	-0.2	1.5	1	1	1
12/20/2022 10:00	-0.7	12.6	2,120.5	-0.2	1.5	1	1	1
12/20/2022 11:00	-0.7	12.7	2,088.3	-0.2	1.5	1	1	1
12/20/2022 12:00	-1.1	13.2	1,961.1	-0.7	1.4	1	1	1
12/20/2022 13:00	-1.1	13.2	1,963.4	-0.7	1.4	1	1	1
12/20/2022 14:00	-1.1	13.2	1,958.0	-0.7	1.4	1	1	1
12/20/2022 15:00	-0.9	12.9	2,030.5	-0.5	1.4	1	1	1
12/20/2022 16:00	-0.5	12.3	2,184.0	-0.1	1.5	1	1	1
12/20/2022 17:00	-0.5	12.0	2,248.1	-0.1	1.6	1	1	1
12/20/2022 18:00	-0.5	12.0	2,246.6	-0.1	1.6	1	1	1
12/20/2022 19:00	-0.5	12.0	2,239.7	-0.1	1.6	1	1	1
12/20/2022 20:00	-0.5	12.0	2,241.8	-0.1	1.6	1	1	1
12/20/2022 21:00	-0.5	12.4	2,154.7	-0.2	1.5	1	1	1
12/20/2022 22:00	-0.5	12.4	2,156.3	-0.2	1.5	1	1	1
12/20/2022 23:00	-0.5	12.2	2,209.3	-0.1	1.5	1	1	1
Average/Sum#:	-0.7	12.5	2,156.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	12.0	1,958.0	-0.7	1.4	1	1	1
Maximum:	-0.5	13.2	2,279.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	-0.5	11.9	2,265.8	-0.1	1.6	1	1	1
12/21/2022 01:00	-0.5	11.9	2,263.2	-0.1	1.6	1	1	1
12/21/2022 02:00	-0.5	12.0	2,261.3	-0.1	1.6	1	1	1
12/21/2022 03:00	-0.5	12.0	2,267.1	-0.1	1.6	1	1	1
12/21/2022 04:00	-0.5	12.0	2,267.5	-0.1	1.6	1	1	1
12/21/2022 05:00	-0.5	12.0	2,262.9	-0.1	1.6	1	1	1
12/21/2022 06:00	-0.5	12.0	2,262.6	-0.1	1.6	1	1	1
12/21/2022 07:00	-0.5	12.0	2,260.4	-0.1	1.6	1	1	1
12/21/2022 08:00	-0.5	12.1	2,249.7	-0.1	1.6	1	1	1
12/21/2022 09:00	-0.7	12.1	2,235.5	-0.2	1.6	1	1	1
12/21/2022 10:00	-0.5	12.1	2,227.8	-0.1	1.6	1	1	1
12/21/2022 11:00	-0.5	12.2	2,195.0	-0.1	1.5	1	1	1
12/21/2022 12:00	-0.5	12.1	2,213.1	-0.1	1.5	1	1	1
12/21/2022 13:00	-0.5	12.1	2,208.4	-0.1	1.5	1	1	1
12/21/2022 14:00	-0.5	12.4	2,133.5	-0.2	1.5	1	1	1
12/21/2022 15:00	-0.5	12.1	2,205.0	-0.1	1.5	1	1	1
12/21/2022 16:00	-0.5	12.0	2,227.3	-0.1	1.6	1	1	1
12/21/2022 17:00	-0.5	12.0	2,234.1	-0.1	1.6	1	1	1
12/21/2022 18:00	-0.5	12.0	2,239.9	-0.1	1.6	1	1	1
12/21/2022 19:00	-0.5	12.0	2,241.3	-0.1	1.6	1	1	1
12/21/2022 20:00	-0.5	12.0	2,238.6	-0.1	1.6	1	1	1
12/21/2022 21:00	-0.5	12.0	2,238.6	-0.1	1.6	1	1	1
12/21/2022 22:00	-0.5	12.1	2,239.1	-0.1	1.6	1	1	1
12/21/2022 23:00	-0.7	12.1	2,239.7	-0.2	1.6	1	1	1
Average/Sum#:	-0.5	12.1	2,236.6	-0.1	1.6	24 #	24 #	24 #
Minimum:	-0.7	11.9	2,133.5	-0.2	1.5	1	1	1
Maximum:	-0.5	12.4	2,267.5	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2022 00:00	-0.7	12.3	2,179.5	-0.2	1.5	1	1	1
12/22/2022 01:00	-1.1	13.1	1,980.0	-0.7	1.4	1	1	1
12/22/2022 02:00	-1.4	13.2	1,961.4	-0.9	1.4	1	1	1
12/22/2022 03:00	-1.4	13.2	1,964.7	-0.9	1.4	1	1	1
12/22/2022 04:00	-1.1	12.8	2,094.8	-0.7	1.5	1	1	1
12/22/2022 05:00	-0.8	12.1	2,222.3	-0.4	1.6	1	1	1
12/22/2022 06:00	-0.7	12.1	2,261.4	-0.2	1.6	1	1	1
12/22/2022 07:00	-0.7	12.1	2,259.7	-0.2	1.6	1	1	1
12/22/2022 08:00	-0.7	12.1	2,238.6	-0.2	1.6	1	1	1
12/22/2022 09:00	-0.7	12.5	2,150.2	-0.2	1.5	1	1	1
12/22/2022 10:00	-0.7	12.6	2,145.1	-0.2	1.5	1	1	1
12/22/2022 11:00	-0.7	12.5	2,140.3	-0.2	1.5	1	1	1
12/22/2022 12:00	-0.7	12.5	2,137.6	-0.2	1.5	1	1	1
12/22/2022 13:00	-0.7	12.5	2,137.2	-0.2	1.5	1	1	1
12/22/2022 14:00	-0.7	12.5	2,144.7	-0.2	1.5	1	1	1
12/22/2022 15:00	-0.7	12.2	2,203.3	-0.2	1.5	1	1	1
12/22/2022 16:00	-0.7	12.2	2,198.4	-0.2	1.5	1	1	1
12/22/2022 17:00	-0.7	12.0	2,238.8	-0.2	1.6	1	1	1
12/22/2022 18:00	-0.7	12.0	2,242.2	-0.2	1.6	1	1	1
12/22/2022 19:00	-0.7	12.0	2,246.6	-0.2	1.6	1	1	1
12/22/2022 20:00	-0.7	12.0	2,243.5	-0.2	1.6	1	1	1
12/22/2022 21:00	-0.7	12.0	2,241.4	-0.2	1.6	1	1	1
12/22/2022 22:00	-0.7	12.2	2,200.2	-0.2	1.5	1	1	1
12/22/2022 23:00	-0.8	12.8	2,068.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.8	12.4	2,162.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.4	12.0	1,961.4	-0.9	1.4	1	1	1
Maximum:	-0.7	13.2	2,261.4	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	-0.7	12.2	2,215.5	-0.2	1.6	1	1	1
12/23/2022 01:00	-0.7	12.0	2,252.2	-0.2	1.6	1	1	1
12/23/2022 02:00	-0.7	12.0	2,250.3	-0.2	1.6	1	1	1
12/23/2022 03:00	-0.7	12.0	2,245.6	-0.2	1.6	1	1	1
12/23/2022 04:00	-0.7	12.0	2,248.2	-0.2	1.6	1	1	1
12/23/2022 05:00	-0.7	12.0	2,241.2	-0.2	1.6	1	1	1
12/23/2022 06:00	-0.7	12.0	2,250.7	-0.2	1.6	1	1	1
12/23/2022 07:00	-0.7	12.1	2,232.9	-0.2	1.6	1	1	1
12/23/2022 08:00	-0.7	12.3	2,172.6	-0.2	1.5	1	1	1
12/23/2022 09:00	-0.7	12.3	2,163.4	-0.2	1.5	1	1	1
12/23/2022 10:00	-0.7	12.5	2,122.9	-0.2	1.5	1	1	1
12/23/2022 11:00	-0.5	12.4	2,124.2	-0.2	1.5	1	1	1
12/23/2022 12:00	-0.8	12.8	2,017.4	-0.4	1.4	1	1	1
12/23/2022 13:00	-0.9	13.1	1,950.0	-0.5	1.4	1	1	1
12/23/2022 14:00	-1.1	13.1	1,941.4	-0.7	1.4	1	1	1
12/23/2022 15:00	-0.8	12.7	2,049.7	-0.4	1.4	1	1	1
12/23/2022 16:00	-0.5	11.9	2,228.2	-0.1	1.6	1	1	1
12/23/2022 17:00	-0.5	11.9	2,230.8	-0.1	1.6	1	1	1
12/23/2022 18:00	-0.5	11.9	2,231.0	-0.1	1.6	1	1	1
12/23/2022 19:00	-0.4	12.0	2,229.3	-0.1	1.6	1	1	1
12/23/2022 20:00	-0.4	12.0	2,230.7	-0.1	1.6	1	1	1
12/23/2022 21:00	-0.4	11.9	2,234.3	-0.1	1.6	1	1	1
12/23/2022 22:00	-0.5	11.9	2,233.5	-0.1	1.6	1	1	1
12/23/2022 23:00	-0.5	12.0	2,225.6	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.2	2,180.1	-0.2	1.6	24 #	24 #	24 #
Minimum:	-1.1	11.9	1,941.4	-0.7	1.4	1	1	1
Maximum:	-0.4	13.1	2,252.2	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	-0.5	12.4	2,119.0	-0.2	1.5	1	1	1
12/24/2022 01:00	-0.5	12.5	2,113.9	-0.2	1.5	1	1	1
12/24/2022 02:00	-0.9	13.1	1,961.4	-0.5	1.4	1	1	1
12/24/2022 03:00	-1.1	13.2	1,955.3	-0.7	1.4	1	1	1
12/24/2022 04:00	-1.1	13.2	1,953.0	-0.7	1.4	1	1	1
12/24/2022 05:00	-1.1	13.2	1,951.1	-0.7	1.4	1	1	1
12/24/2022 06:00	-1.1	13.1	1,974.8	-0.7	1.4	1	1	1
12/24/2022 07:00	-0.9	13.0	1,998.9	-0.5	1.4	1	1	1
12/24/2022 08:00	-0.8	13.3	1,833.9	-0.5	1.3	1	1	1
12/24/2022 09:00	0.1	13.8	1,320.7	0.2	0.9	1	1	0
12/24/2022 10:00	0.3	13.8	1,559.7	0.4	1.1	1	1	0
12/24/2022 11:00	0.3	13.8	1,555.6	0.4	1.1	1	1	0
12/24/2022 12:00	0.3	13.8	1,554.9	0.4	1.1	1	1	0
12/24/2022 13:00	0.4	13.8	1,558.8	0.4	1.1	1	1	0
12/24/2022 14:00	0.4	13.8	1,730.9	0.4	1.2	1	1	0
12/24/2022 15:00	0.4	13.8	1,739.5	0.4	1.2	1	1	0
12/24/2022 16:00	0.1	13.8	1,594.1	0.2	1.1	1	1	1
12/24/2022 17:00	-1.1	13.1	1,944.9	-0.7	1.4	1	1	1
12/24/2022 18:00	-0.9	13.1	1,943.7	-0.5	1.4	1	1	1
12/24/2022 19:00	-0.9	13.1	1,944.1	-0.5	1.4	1	1	1
12/24/2022 20:00	-0.9	13.1	1,947.7	-0.5	1.4	1	1	1
12/24/2022 21:00	-0.9	13.1	1,944.2	-0.5	1.4	1	1	1
12/24/2022 22:00	-1.1	13.2	1,946.9	-0.7	1.4	1	1	1
12/24/2022 23:00	-1.1	13.2	1,949.6	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.3	1,837.4	-0.3	1.3	24 #	24 #	17 #
Minimum:	-1.1	12.4	1,320.7	-0.7	0.9	1	1	0
Maximum:	0.4	13.8	2,119.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	-1.1	13.2	1,930.0	-0.7	1.4	1	1	1
12/25/2022 01:00	0.0	15.6	591.4	0.0	0.4	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.6	14.4	1,260.7	-0.4	0.9	2 #	1 #	1 #
Minimum:	-1.1	13.2	591.4	-0.7	0.4	0	0	0
Maximum:	0.0	15.6	1,930.0	0.0	1.4	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.0	17.6	332.1	0.0	0.2	1	0	0
12/26/2022 01:00	0.0	15.1	969.8	0.0	0.7	1	0	0
12/26/2022 02:00	0.2	13.7	1,715.8	0.3	1.2	1	1	0
12/26/2022 03:00	0.2	13.7	1,736.0	0.3	1.2	1	1	0
12/26/2022 04:00	0.2	13.7	1,735.7	0.3	1.2	1	1	0
12/26/2022 05:00	0.2	13.7	1,750.8	0.3	1.2	1	1	0
12/26/2022 06:00	0.2	13.7	1,750.6	0.3	1.2	1	1	0
12/26/2022 07:00	0.2	13.7	1,742.3	0.3	1.2	1	1	0
12/26/2022 08:00	0.2	13.7	1,748.4	0.3	1.2	1	1	0
12/26/2022 09:00	0.2	13.8	1,563.8	0.3	1.1	1	1	0
12/26/2022 10:00	0.2	13.8	1,559.4	0.3	1.1	1	1	0
12/26/2022 11:00	0.2	13.8	1,550.2	0.3	1.1	1	1	0
12/26/2022 12:00	0.1	13.8	1,541.0	0.2	1.1	1	1	0
12/26/2022 13:00	0.2	13.8	1,561.8	0.3	1.1	1	1	0
12/26/2022 14:00	0.2	13.7	1,623.4	0.3	1.1	1	1	0
12/26/2022 15:00	0.2	13.7	1,751.1	0.3	1.2	1	1	0
12/26/2022 16:00	-0.1	13.7	1,782.9	0.1	1.2	1	1	1
12/26/2022 17:00	-1.2	12.5	2,103.9	-0.7	1.5	1	1	1
12/26/2022 18:00	-0.8	12.3	2,145.3	-0.4	1.5	1	1	1
12/26/2022 19:00	-1.1	12.9	2,004.1	-0.7	1.4	1	1	1
12/26/2022 20:00	-1.1	13.0	1,990.7	-0.7	1.4	1	1	1
12/26/2022 21:00	-1.4	13.1	1,960.1	-0.9	1.4	1	1	1
12/26/2022 22:00	-1.4	13.1	1,936.0	-0.9	1.4	1	1	1
12/26/2022 23:00	0.0	15.6	602.1	0.0	0.4	1	0	0
Average/Sum#:	-0.2	13.8	1,631.6	0.0	1.1	24 #	21 #	7 #
Minimum:	-1.4	12.3	332.1	-0.9	0.2	1	0	0
Maximum:	0.2	17.6	2,145.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 05:00	0.0	17.0	482.2	0.0	0.3	1	0	0
12/27/2022 06:00	0.0	14.3	1,185.6	0.0	0.8	1	0	0
12/27/2022 07:00	0.3	13.7	1,737.9	0.4	1.2	1	1	0
12/27/2022 08:00	-0.1	13.6	1,714.6	0.1	1.2	1	1	1
12/27/2022 09:00	-1.4	12.9	1,950.3	-0.8	1.4	1	1	1
12/27/2022 10:00	-1.1	12.9	1,947.7	-0.7	1.4	1	1	1
12/27/2022 11:00	-0.8	12.9	1,950.7	-0.4	1.4	1	1	1
12/27/2022 12:00	-0.7	12.9	1,949.0	-0.4	1.4	1	1	1
12/27/2022 13:00	-0.7	12.9	1,947.5	-0.4	1.4	1	1	1
12/27/2022 14:00	-0.7	12.9	1,948.0	-0.4	1.4	1	1	1
12/27/2022 15:00	-0.7	12.9	1,949.1	-0.4	1.4	1	1	1
12/27/2022 16:00	-0.8	12.9	1,950.9	-0.4	1.4	1	1	1
12/27/2022 17:00	-1.1	13.0	1,941.7	-0.7	1.4	1	1	1
12/27/2022 18:00	-1.1	13.1	1,938.3	-0.7	1.4	1	1	1
12/27/2022 19:00	-1.1	13.1	1,941.5	-0.7	1.4	1	1	1
12/27/2022 20:00	-1.2	13.1	1,950.2	-0.8	1.4	1	1	1
12/27/2022 21:00	-1.1	13.1	1,946.3	-0.7	1.4	1	1	1
12/27/2022 22:00	-1.1	13.1	1,927.1	-0.7	1.3	1	1	1
12/27/2022 23:00	0.2	13.9	1,398.6	0.3	1.0	1	1	0
Average/Sum#:	-0.7	13.4	1,776.7	-0.4	1.3	19 #	17 #	15 #
Minimum:	-1.4	12.9	482.2	-0.8	0.3	0	0	0
Maximum:	0.3	17.0	1,950.9	0.4	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.3	13.8	1,551.1	0.4	1.1	1	1	0
12/28/2022 01:00	0.2	13.8	1,473.8	0.3	1.0	1	1	0
12/28/2022 02:00	0.2	13.8	1,538.3	0.3	1.1	1	1	0
12/28/2022 03:00	0.2	13.8	1,537.5	0.3	1.1	1	1	0
12/28/2022 04:00	0.2	13.8	1,543.0	0.3	1.1	1	1	0
12/28/2022 05:00	0.3	13.7	1,735.6	0.4	1.2	1	1	0
12/28/2022 06:00	0.3	13.7	1,753.7	0.4	1.2	1	1	0
12/28/2022 07:00	0.3	13.7	1,756.5	0.4	1.2	1	1	0
12/28/2022 08:00	0.3	13.7	1,732.6	0.4	1.2	1	1	0
12/28/2022 09:00	0.3	13.7	1,723.8	0.4	1.2	1	1	0
12/28/2022 10:00	0.3	13.8	1,562.0	0.4	1.1	1	1	0
12/28/2022 11:00	0.3	13.8	1,577.9	0.4	1.1	1	1	0
12/28/2022 12:00	0.3	13.8	1,560.7	0.4	1.1	1	1	0
12/28/2022 13:00	0.3	13.8	1,535.3	0.4	1.1	1	1	0
12/28/2022 14:00	0.3	13.8	1,554.0	0.4	1.1	1	1	0
12/28/2022 15:00	-0.1	13.7	1,601.3	0.1	1.1	1	1	1
12/28/2022 16:00	-1.1	12.5	2,087.1	-0.5	1.5	1	1	1
12/28/2022 17:00	-0.9	13.0	1,974.8	-0.5	1.4	1	1	1
12/28/2022 18:00	-1.1	13.1	1,954.9	-0.7	1.4	1	1	1
12/28/2022 19:00	-1.1	13.1	1,956.3	-0.7	1.4	1	1	1
12/28/2022 20:00	-1.2	13.1	1,955.8	-0.8	1.4	1	1	1
12/28/2022 21:00	-1.1	13.0	1,967.9	-0.7	1.4	1	1	1
12/28/2022 22:00	-1.2	13.1	1,952.9	-0.8	1.4	1	1	1
12/28/2022 23:00	-1.2	13.1	1,957.6	-0.8	1.4	1	1	1
Average/Sum#:	-0.2	13.5	1,731.0	0.0	1.2	24 #	24 #	9 #
Minimum:	-1.2	12.5	1,473.8	-0.8	1.0	1	1	0
Maximum:	0.3	13.8	2,087.1	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2022 00:00	-1.2	13.1	1,953.1	-0.8	1.4	1	1	1
12/29/2022 01:00	-1.2	13.1	1,953.2	-0.8	1.4	1	1	1
12/29/2022 02:00	-1.2	13.1	1,953.7	-0.8	1.4	1	1	1
12/29/2022 03:00	-1.2	13.1	1,955.0	-0.8	1.4	1	1	1
12/29/2022 04:00	-1.2	13.1	1,957.5	-0.8	1.4	1	1	1
12/29/2022 05:00	-0.9	12.7	2,029.7	-0.5	1.4	1	1	1
12/29/2022 06:00	-0.9	12.8	2,039.0	-0.5	1.4	1	1	1
12/29/2022 07:00	-0.9	12.8	2,042.7	-0.5	1.4	1	1	1
12/29/2022 08:00	-0.8	12.2	2,185.5	-0.4	1.5	1	1	1
12/29/2022 09:00	-0.7	11.9	2,234.1	-0.2	1.6	1	1	1
12/29/2022 10:00	-0.7	12.3	2,142.2	-0.2	1.5	1	1	1
12/29/2022 11:00	-0.9	12.9	2,012.8	-0.5	1.4	1	1	1
12/29/2022 12:00	-1.1	13.0	1,975.6	-0.7	1.4	1	1	1
12/29/2022 13:00	-1.4	13.1	1,962.0	-0.9	1.4	1	1	1
12/29/2022 14:00	-1.2	13.0	1,971.1	-0.8	1.4	1	1	1
12/29/2022 15:00	-1.2	13.0	1,977.5	-0.8	1.4	1	1	1
12/29/2022 16:00	-1.1	12.6	2,082.3	-0.7	1.5	1	1	1
12/29/2022 17:00	-0.7	12.3	2,149.3	-0.2	1.5	1	1	1
12/29/2022 18:00	-0.8	12.6	2,062.6	-0.4	1.4	1	1	1
12/29/2022 19:00	-1.4	13.1	1,956.5	-0.9	1.4	1	1	1
12/29/2022 20:00	-1.4	13.1	1,963.5	-0.9	1.4	1	1	1
12/29/2022 21:00	-1.2	13.0	1,973.9	-0.8	1.4	1	1	1
12/29/2022 22:00	-1.4	13.0	1,958.1	-0.8	1.4	1	1	1
12/29/2022 23:00	-1.4	13.1	1,930.3	-0.9	1.4	1	1	1
Average/Sum#:	-1.1	12.8	2,017.6	-0.7	1.4	24 #	24 #	24 #
Minimum:	-1.4	11.9	1,930.3	-0.9	1.4	1	1	1
Maximum:	-0.7	13.1	2,234.1	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	0.0	15.6	627.2	0.0	0.4	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.6	627.2	0.0	0.4	1 #	0 #	0 #
Minimum:	0.0	15.6	627.2	0.0	0.4	0	0	0
Maximum:	0.0	15.6	627.2	0.0	0.4	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.2	12.1	2,166.3	0.4	0.6	1	1	1
10/01/2022 01:00	0.0	14.2	1,202.0	0.0	0.4	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	17.7	308.0	0.0	0.1	1	0	0
10/01/2022 13:00	0.0	17.2	376.4	0.0	0.1	1	0	0
10/01/2022 14:00	0.0	15.5	875.8	0.0	0.3	1	0	0
10/01/2022 15:00	0.4	14.1	1,414.5	0.4	0.4	1	1	0
10/01/2022 16:00	0.1	13.6	1,717.8	0.2	0.5	1	1	1
10/01/2022 17:00	0.1	11.6	2,258.0	0.2	0.7	1	1	1
10/01/2022 18:00	0.1	11.9	2,188.3	0.2	0.7	1	1	1
10/01/2022 19:00	-0.2	12.6	2,026.7	0.1	0.6	1	1	1
10/01/2022 20:00	0.1	11.9	2,210.8	0.2	0.7	1	1	1
10/01/2022 21:00	0.1	12.5	1,932.3	0.2	0.6	1	1	1
10/01/2022 22:00	0.4	13.8	1,569.8	0.4	0.5	1	1	0
10/01/2022 23:00	0.0	15.6	630.9	0.0	0.2	1	0	0
Average/Sum#:	0.1	13.9	1,491.3	0.2	0.5	14 #	9 #	8 #
Minimum:	-0.2	11.6	308.0	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,258.0	0.4	0.7	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	17.7	311.4	0.0	0.1	1	0	0
10/02/2022 12:00	0.0	17.2	404.4	0.0	0.1	1	0	0
10/02/2022 13:00	0.0	15.6	880.7	0.0	0.3	1	0	0
10/02/2022 14:00	0.4	13.8	1,730.7	0.4	0.5	1	1	0
10/02/2022 15:00	-0.2	13.2	1,719.8	-0.1	0.5	1	1	1
10/02/2022 16:00	-0.2	12.0	2,184.2	0.1	0.7	1	1	1
10/02/2022 17:00	0.1	11.6	2,265.0	0.2	0.7	1	1	1
10/02/2022 18:00	0.1	11.6	2,270.6	0.2	0.7	1	1	1
10/02/2022 19:00	0.2	11.6	2,272.9	0.4	0.7	1	1	1
10/02/2022 20:00	0.2	11.6	2,274.3	0.4	0.7	1	1	1
10/02/2022 21:00	-0.1	12.4	2,098.7	0.2	0.6	1	1	1
10/02/2022 22:00	0.1	12.7	1,912.0	0.2	0.6	1	1	1
10/02/2022 23:00	0.4	13.9	1,550.6	0.4	0.5	1	1	0
Average/Sum#:	0.1	13.5	1,682.7	0.2	0.5	13 #	10 #	8 #
Minimum:	-0.2	11.6	311.4	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	2,274.3	0.4	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.4	13.9	1,546.4	0.4	0.5	1	1	0
10/03/2022 01:00	0.4	13.9	1,550.3	0.4	0.5	1	1	0
10/03/2022 02:00	0.4	13.8	1,784.2	0.4	0.5	1	1	0
10/03/2022 03:00	0.4	13.9	1,582.9	0.4	0.5	1	1	0
10/03/2022 04:00	0.4	13.9	1,715.7	0.4	0.5	1	1	0
10/03/2022 05:00	0.4	13.9	1,713.6	0.4	0.5	1	1	0
10/03/2022 06:00	0.4	13.9	1,710.7	0.4	0.5	1	1	0
10/03/2022 07:00	0.4	13.9	1,711.1	0.4	0.5	1	1	0
10/03/2022 08:00	0.4	13.9	1,717.3	0.4	0.5	1	1	0
10/03/2022 09:00	0.4	13.9	1,722.1	0.4	0.5	1	1	0
10/03/2022 10:00	0.4	13.9	1,724.5	0.4	0.5	1	1	0
10/03/2022 11:00	0.4	13.9	1,724.7	0.4	0.5	1	1	0
10/03/2022 12:00	0.4	13.9	1,724.6	0.4	0.5	1	1	0
10/03/2022 13:00	0.4	13.9	1,725.3	0.4	0.5	1	1	0
10/03/2022 14:00	0.4	13.9	1,716.6	0.4	0.5	1	1	0
10/03/2022 15:00	0.2	13.8	1,754.9	0.4	0.5	1	1	1
10/03/2022 16:00	-0.2	12.5	2,060.1	0.1	0.6	1	1	1
10/03/2022 17:00	0.1	12.0	2,170.1	0.2	0.7	1	1	1
10/03/2022 18:00	0.2	11.8	2,202.2	0.4	0.7	1	1	1
10/03/2022 19:00	0.2	12.0	2,175.9	0.4	0.7	1	1	1
10/03/2022 20:00	0.2	11.9	2,186.8	0.4	0.7	1	1	1
10/03/2022 21:00	0.2	12.0	2,178.8	0.4	0.7	1	1	1
10/03/2022 22:00	0.2	12.2	2,156.6	0.4	0.6	1	1	1
10/03/2022 23:00	0.2	12.1	2,174.0	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.3	1,851.2	0.4	0.6	24 #	24 #	9 #
Minimum:	-0.2	11.8	1,546.4	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,202.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	0.2	12.2	2,156.2	0.4	0.6	1	1	1
10/04/2022 01:00	0.2	12.2	2,159.9	0.4	0.6	1	1	1
10/04/2022 02:00	0.2	12.2	2,158.6	0.4	0.6	1	1	1
10/04/2022 03:00	0.2	12.1	2,168.6	0.4	0.7	1	1	1
10/04/2022 04:00	0.2	12.1	2,182.7	0.4	0.7	1	1	1
10/04/2022 05:00	0.4	12.0	2,216.4	0.5	0.7	1	1	1
10/04/2022 06:00	0.2	12.3	2,179.8	0.4	0.7	1	1	1
10/04/2022 07:00	0.2	12.7	2,043.5	0.4	0.6	1	1	1
10/04/2022 08:00	0.4	13.8	1,586.2	0.4	0.5	1	1	0
10/04/2022 09:00	0.4	13.9	1,548.5	0.4	0.5	1	1	0
10/04/2022 10:00	0.6	0.0	1,554.2	0.6	0.5	1	1	0
10/04/2022 11:00	0.4	13.9	1,562.4	0.4	0.5	1	1	0
10/04/2022 12:00	0.4	13.9	1,707.0	0.4	0.5	1	1	0
10/04/2022 13:00	-0.1	13.8	1,733.0	0.1	0.5	1	1	1
10/04/2022 14:00	-0.2	12.7	2,019.5	0.1	0.6	1	1	1
10/04/2022 15:00	0.1	12.1	2,136.1	0.2	0.6	1	1	1
10/04/2022 16:00	0.1	12.1	2,128.5	0.2	0.6	1	1	1
10/04/2022 17:00	0.2	12.1	2,140.4	0.4	0.6	1	1	1
10/04/2022 18:00	0.2	12.0	2,169.9	0.4	0.7	1	1	1
10/04/2022 19:00	0.2	11.9	2,188.2	0.4	0.7	1	1	1
10/04/2022 20:00	0.4	11.7	2,242.8	0.5	0.7	1	1	1
10/04/2022 21:00	0.4	11.9	2,190.4	0.5	0.7	1	1	1
10/04/2022 22:00	0.2	12.0	2,179.1	0.4	0.7	1	1	1
10/04/2022 23:00	0.2	12.2	2,143.7	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.5	2,020.7	0.4	0.6	24 #	24 #	19 #
Minimum:	-0.2	11.7	1,548.5	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,242.8	0.5	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	0.2	12.2	2,136.6	0.4	0.6	1	1	1
10/05/2022 01:00	0.1	12.8	1,995.6	0.2	0.6	1	1	1
10/05/2022 02:00	-0.1	13.0	1,971.2	0.1	0.6	1	1	1
10/05/2022 03:00	0.1	12.5	2,088.5	0.2	0.6	1	1	1
10/05/2022 04:00	0.2	12.3	2,117.7	0.4	0.6	1	1	1
10/05/2022 05:00	0.4	12.0	2,204.8	0.5	0.7	1	1	1
10/05/2022 06:00	0.4	12.1	2,206.4	0.5	0.7	1	1	1
10/05/2022 07:00	0.1	12.9	1,980.3	0.2	0.6	1	1	1
10/05/2022 08:00	0.5	13.9	1,702.3	0.5	0.5	1	1	0
10/05/2022 09:00	0.4	13.9	1,667.6	0.4	0.5	1	1	0
10/05/2022 10:00	0.4	13.9	1,693.9	0.4	0.5	1	1	0
10/05/2022 11:00	0.4	13.9	1,706.3	0.4	0.5	1	1	0
10/05/2022 12:00	0.2	13.8	1,723.0	0.4	0.5	1	1	1
10/05/2022 13:00	-0.1	12.5	2,064.2	0.1	0.6	1	1	1
10/05/2022 14:00	0.2	11.9	2,181.4	0.4	0.7	1	1	1
10/05/2022 15:00	0.2	12.1	2,135.0	0.4	0.6	1	1	1
10/05/2022 16:00	0.2	12.0	2,157.2	0.4	0.6	1	1	1
10/05/2022 17:00	0.2	11.8	2,196.1	0.4	0.7	1	1	1
10/05/2022 18:00	0.4	11.7	2,231.0	0.5	0.7	1	1	1
10/05/2022 19:00	0.4	11.7	2,237.6	0.5	0.7	1	1	1
10/05/2022 20:00	0.2	11.9	2,188.3	0.4	0.7	1	1	1
10/05/2022 21:00	0.4	11.7	2,234.5	0.5	0.7	1	1	1
10/05/2022 22:00	0.2	12.1	2,163.4	0.4	0.6	1	1	1
10/05/2022 23:00	0.2	12.1	2,172.8	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,048.2	0.4	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.7	1,667.6	0.1	0.5	1	1	0
Maximum:	0.5	13.9	2,237.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	0.2	12.2	2,162.3	0.4	0.6	1	1	1
10/06/2022 01:00	0.2	12.1	2,166.4	0.4	0.6	1	1	1
10/06/2022 02:00	0.2	12.1	2,164.4	0.4	0.6	1	1	1
10/06/2022 03:00	0.2	12.2	2,142.9	0.4	0.6	1	1	1
10/06/2022 04:00	0.4	12.0	2,184.4	0.5	0.7	1	1	1
10/06/2022 05:00	0.4	11.8	2,246.2	0.5	0.7	1	1	1
10/06/2022 06:00	0.4	11.9	2,233.3	0.5	0.7	1	1	1
10/06/2022 07:00	0.2	12.3	2,131.1	0.4	0.6	1	1	1
10/06/2022 08:00	0.1	12.5	2,082.8	0.2	0.6	1	1	1
10/06/2022 09:00	0.1	12.6	2,065.4	0.2	0.6	1	1	1
10/06/2022 10:00	0.1	12.5	2,076.7	0.2	0.6	1	1	1
10/06/2022 11:00	0.1	12.3	2,113.6	0.2	0.6	1	1	1
10/06/2022 12:00	0.2	12.1	2,142.5	0.4	0.6	1	1	1
10/06/2022 13:00	0.4	11.9	2,198.7	0.5	0.7	1	1	1
10/06/2022 14:00	0.4	11.8	2,207.0	0.5	0.7	1	1	1
10/06/2022 15:00	0.2	12.0	2,158.9	0.4	0.6	1	1	1
10/06/2022 16:00	0.2	11.9	2,197.5	0.4	0.7	1	1	1
10/06/2022 17:00	0.4	11.7	2,245.6	0.5	0.7	1	1	1
10/06/2022 18:00	0.4	11.7	2,241.8	0.5	0.7	1	1	1
10/06/2022 19:00	0.4	11.7	2,251.9	0.5	0.7	1	1	1
10/06/2022 20:00	0.4	11.7	2,253.7	0.5	0.7	1	1	1
10/06/2022 21:00	0.4	11.8	2,243.5	0.5	0.7	1	1	1
10/06/2022 22:00	0.4	12.0	2,189.6	0.5	0.7	1	1	1
10/06/2022 23:00	0.2	12.1	2,168.9	0.4	0.7	1	1	1
Average/Sum#:	0.3	12.0	2,177.9	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.7	2,065.4	0.2	0.6	1	1	1
Maximum:	0.4	12.6	2,253.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	0.2	12.3	2,144.9	0.4	0.6	1	1	1
10/07/2022 01:00	0.2	12.2	2,158.5	0.4	0.6	1	1	1
10/07/2022 02:00	0.2	12.3	2,141.1	0.4	0.6	1	1	1
10/07/2022 03:00	0.2	12.4	2,115.0	0.4	0.6	1	1	1
10/07/2022 04:00	0.2	12.2	2,155.3	0.4	0.6	1	1	1
10/07/2022 05:00	0.2	12.1	2,191.5	0.4	0.7	1	1	1
10/07/2022 06:00	0.4	12.1	2,204.8	0.5	0.7	1	1	1
10/07/2022 07:00	0.2	12.4	2,111.6	0.4	0.6	1	1	1
10/07/2022 08:00	0.1	12.7	2,031.6	0.2	0.6	1	1	1
10/07/2022 09:00	0.2	12.3	2,132.5	0.4	0.6	1	1	1
10/07/2022 10:00	0.2	12.3	2,127.2	0.4	0.6	1	1	1
10/07/2022 11:00	0.2	12.3	2,117.0	0.4	0.6	1	1	1
10/07/2022 12:00	0.2	12.0	2,174.6	0.4	0.7	1	1	1
10/07/2022 13:00	0.2	12.1	2,147.2	0.4	0.6	1	1	1
10/07/2022 14:00	0.2	11.9	2,194.6	0.4	0.7	1	1	1
10/07/2022 15:00	0.4	11.8	2,203.8	0.5	0.7	1	1	1
10/07/2022 16:00	0.2	11.9	2,188.4	0.4	0.7	1	1	1
10/07/2022 17:00	0.4	11.7	2,238.4	0.5	0.7	1	1	1
10/07/2022 18:00	0.4	11.7	2,248.1	0.5	0.7	1	1	1
10/07/2022 19:00	0.4	11.7	2,254.3	0.5	0.7	1	1	1
10/07/2022 20:00	0.4	11.7	2,259.1	0.5	0.7	1	1	1
10/07/2022 21:00	0.4	11.7	2,262.1	0.5	0.7	1	1	1
10/07/2022 22:00	0.4	11.7	2,256.4	0.5	0.7	1	1	1
10/07/2022 23:00	0.4	12.0	2,191.4	0.5	0.7	1	1	1
Average/Sum#:	0.3	12.1	2,177.1	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.7	2,031.6	0.2	0.6	1	1	1
Maximum:	0.4	12.7	2,262.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	0.2	12.1	2,179.0	0.4	0.7	1	1	1
10/08/2022 01:00	0.2	12.1	2,173.7	0.4	0.7	1	1	1
10/08/2022 02:00	0.2	12.2	2,165.8	0.4	0.6	1	1	1
10/08/2022 03:00	0.2	12.1	2,178.8	0.4	0.7	1	1	1
10/08/2022 04:00	0.2	12.1	2,186.4	0.4	0.7	1	1	1
10/08/2022 05:00	0.2	12.2	2,175.0	0.4	0.7	1	1	1
10/08/2022 06:00	0.1	12.6	2,114.0	0.2	0.6	1	1	1
10/08/2022 07:00	0.2	13.7	1,700.8	0.4	0.5	1	1	1
10/08/2022 08:00	0.4	14.0	1,358.1	0.4	0.4	1	1	0
10/08/2022 09:00	0.5	14.1	1,309.6	0.5	0.4	1	1	0
10/08/2022 10:00	0.5	14.1	1,309.0	0.5	0.4	1	1	0
10/08/2022 11:00	0.5	14.1	1,314.2	0.5	0.4	1	1	0
10/08/2022 12:00	0.4	13.9	1,559.1	0.4	0.5	1	1	0
10/08/2022 13:00	0.4	13.9	1,711.4	0.4	0.5	1	1	0
10/08/2022 14:00	0.2	13.8	1,728.5	0.4	0.5	1	1	1
10/08/2022 15:00	-0.1	12.3	2,093.4	0.2	0.6	1	1	1
10/08/2022 16:00	0.2	11.8	2,196.4	0.4	0.7	1	1	1
10/08/2022 17:00	0.2	11.8	2,200.9	0.4	0.7	1	1	1
10/08/2022 18:00	0.2	12.0	2,169.3	0.4	0.7	1	1	1
10/08/2022 19:00	0.2	12.0	2,176.3	0.4	0.7	1	1	1
10/08/2022 20:00	0.2	12.0	2,183.4	0.4	0.7	1	1	1
10/08/2022 21:00	0.2	12.0	2,182.8	0.4	0.7	1	1	1
10/08/2022 22:00	0.2	12.1	2,179.0	0.4	0.7	1	1	1
10/08/2022 23:00	0.2	12.2	2,177.1	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.7	1,946.8	0.4	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.8	1,309.0	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,200.9	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	0.2	12.1	2,173.7	0.4	0.7	1	1	1
10/09/2022 01:00	0.2	12.2	2,176.5	0.4	0.7	1	1	1
10/09/2022 02:00	0.2	12.3	2,147.0	0.4	0.6	1	1	1
10/09/2022 03:00	0.2	12.3	2,158.6	0.4	0.6	1	1	1
10/09/2022 04:00	0.2	12.2	2,165.0	0.4	0.6	1	1	1
10/09/2022 05:00	0.2	12.2	2,156.0	0.4	0.6	1	1	1
10/09/2022 06:00	0.0	13.7	1,682.6	0.0	0.5	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 14:00	0.0	17.6	384.2	0.0	0.1	1	0	0
10/09/2022 15:00	0.0	14.5	1,309.2	0.0	0.4	1	0	0
10/09/2022 16:00	0.4	13.9	1,714.4	0.4	0.5	1	1	0
10/09/2022 17:00	0.2	13.7	1,764.8	0.4	0.5	1	1	1
10/09/2022 18:00	-0.1	12.4	2,079.4	0.2	0.6	1	1	1
10/09/2022 19:00	0.4	11.8	2,207.7	0.5	0.7	1	1	1
10/09/2022 20:00	0.4	12.0	2,185.0	0.5	0.7	1	1	1
10/09/2022 21:00	0.2	12.1	2,173.4	0.4	0.7	1	1	1
10/09/2022 22:00	0.2	12.2	2,156.8	0.4	0.6	1	1	1
10/09/2022 23:00	0.2	12.2	2,148.5	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,928.4	0.3	0.6	17 #	14 #	14 #
Minimum:	-0.1	11.8	384.2	0.0	0.1	0	0	0
Maximum:	0.4	17.6	2,207.7	0.5	0.7	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	0.2	12.3	2,123.4	0.4	0.6	1	1	1
10/10/2022 01:00	0.2	12.5	2,095.3	0.4	0.6	1	1	1
10/10/2022 02:00	-0.1	13.0	1,981.4	0.1	0.6	1	1	1
10/10/2022 03:00	0.1	12.5	2,093.7	0.2	0.6	1	1	1
10/10/2022 04:00	0.2	12.4	2,139.2	0.4	0.6	1	1	1
10/10/2022 05:00	0.4	12.0	2,225.5	0.5	0.7	1	1	1
10/10/2022 06:00	0.4	12.1	2,215.7	0.5	0.7	1	1	1
10/10/2022 07:00	0.2	13.4	1,803.1	0.4	0.5	1	1	1
10/10/2022 08:00	0.4	13.9	1,542.0	0.4	0.5	1	1	0
10/10/2022 09:00	0.4	14.0	1,535.7	0.4	0.5	1	1	0
10/10/2022 10:00	0.5	14.1	1,390.1	0.5	0.4	1	1	0
10/10/2022 11:00	0.4	14.0	1,562.7	0.4	0.5	1	1	0
10/10/2022 12:00	0.4	14.1	1,576.8	0.4	0.5	1	1	0
10/10/2022 13:00	0.4	13.9	1,704.6	0.4	0.5	1	1	0
10/10/2022 14:00	0.4	13.9	1,711.9	0.4	0.5	1	1	0
10/10/2022 15:00	0.4	13.9	1,584.5	0.4	0.5	1	1	0
10/10/2022 16:00	-0.1	12.8	1,953.3	0.1	0.6	1	1	1
10/10/2022 17:00	0.2	12.0	2,159.8	0.4	0.6	1	1	1
10/10/2022 18:00	0.2	11.9	2,194.5	0.4	0.7	1	1	1
10/10/2022 19:00	0.2	12.0	2,171.3	0.4	0.7	1	1	1
10/10/2022 20:00	0.2	12.1	2,163.2	0.4	0.6	1	1	1
10/10/2022 21:00	0.1	12.3	2,109.3	0.2	0.6	1	1	1
10/10/2022 22:00	0.1	12.5	2,091.9	0.2	0.6	1	1	1
10/10/2022 23:00	-0.1	13.0	1,947.6	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,919.9	0.4	0.6	24 #	24 #	16 #
Minimum:	-0.1	11.9	1,390.1	0.1	0.4	1	1	0
Maximum:	0.5	14.1	2,225.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.4	14.0	1,368.8	0.4	0.4	1	1	0
10/11/2022 01:00	0.4	14.0	1,294.0	0.4	0.4	1	1	0
10/11/2022 02:00	0.5	14.0	1,293.9	0.5	0.4	1	1	0
10/11/2022 03:00	0.4	14.0	1,345.8	0.4	0.4	1	1	0
10/11/2022 04:00	0.4	14.0	1,489.9	0.4	0.4	1	1	0
10/11/2022 05:00	0.4	14.0	1,314.3	0.4	0.4	1	1	0
10/11/2022 06:00	0.4	14.0	1,303.1	0.4	0.4	1	1	0
10/11/2022 07:00	0.4	14.0	1,318.9	0.4	0.4	1	1	0
10/11/2022 08:00	0.4	13.9	1,748.2	0.4	0.5	1	1	0
10/11/2022 09:00	0.4	14.0	1,592.2	0.4	0.5	1	1	0
10/11/2022 10:00	0.4	13.8	1,729.7	0.4	0.5	1	1	0
10/11/2022 11:00	0.4	13.8	1,747.4	0.4	0.5	1	1	0
10/11/2022 12:00	0.4	13.9	1,748.6	0.4	0.5	1	1	0
10/11/2022 13:00	0.4	13.9	1,740.2	0.4	0.5	1	1	0
10/11/2022 14:00	0.4	13.9	1,733.2	0.4	0.5	1	1	0
10/11/2022 15:00	0.4	13.9	1,737.7	0.4	0.5	1	1	0
10/11/2022 16:00	0.4	13.8	1,760.7	0.4	0.5	1	1	0
10/11/2022 17:00	0.4	13.7	1,770.9	0.4	0.5	1	1	0
10/11/2022 18:00	0.2	13.7	1,775.7	0.4	0.5	1	1	1
10/11/2022 19:00	-0.2	12.5	2,057.5	0.1	0.6	1	1	1
10/11/2022 20:00	0.1	12.3	2,104.9	0.2	0.6	1	1	1
10/11/2022 21:00	0.1	12.1	2,159.4	0.2	0.6	1	1	1
10/11/2022 22:00	0.1	12.4	2,094.6	0.2	0.6	1	1	1
10/11/2022 23:00	-0.1	13.0	1,961.3	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.6	1,674.6	0.4	0.5	24 #	24 #	6 #
Minimum:	-0.2	12.1	1,293.9	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,159.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	-0.4	13.1	1,948.6	-0.1	0.6	1	1	1
10/12/2022 01:00	-0.4	13.1	1,928.9	-0.1	0.6	1	1	1
10/12/2022 02:00	0.4	13.9	1,512.2	0.4	0.5	1	1	0
10/12/2022 03:00	0.4	13.9	1,624.7	0.4	0.5	1	1	0
10/12/2022 04:00	0.4	13.8	1,746.5	0.4	0.5	1	1	0
10/12/2022 05:00	-0.1	12.4	2,122.6	0.2	0.6	1	1	1
10/12/2022 06:00	0.2	11.9	2,254.3	0.4	0.7	1	1	1
10/12/2022 07:00	0.4	11.9	2,245.2	0.5	0.7	1	1	1
10/12/2022 08:00	0.4	11.9	2,243.2	0.5	0.7	1	1	1
10/12/2022 09:00	0.4	11.9	2,238.0	0.5	0.7	1	1	1
10/12/2022 10:00	0.4	11.9	2,234.1	0.5	0.7	1	1	1
10/12/2022 11:00	0.4	11.9	2,233.9	0.5	0.7	1	1	1
10/12/2022 12:00	0.4	11.9	2,231.6	0.5	0.7	1	1	1
10/12/2022 13:00	0.4	11.9	2,228.9	0.5	0.7	1	1	1
10/12/2022 14:00	0.4	11.9	2,229.7	0.5	0.7	1	1	1
10/12/2022 15:00	0.4	11.8	2,235.6	0.5	0.7	1	1	1
10/12/2022 16:00	0.4	11.6	2,251.1	0.5	0.7	1	1	1
10/12/2022 17:00	0.4	11.6	2,260.5	0.5	0.7	1	1	1
10/12/2022 18:00	0.4	11.8	2,224.2	0.5	0.7	1	1	1
10/12/2022 19:00	0.2	12.2	2,135.6	0.4	0.6	1	1	1
10/12/2022 20:00	0.2	12.2	2,150.7	0.4	0.6	1	1	1
10/12/2022 21:00	0.1	12.3	2,115.2	0.2	0.6	1	1	1
10/12/2022 22:00	0.1	12.5	2,084.9	0.2	0.6	1	1	1
10/12/2022 23:00	-0.2	13.0	1,959.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.3	2,101.6	0.4	0.6	24 #	24 #	21 #
Minimum:	-0.4	11.6	1,512.2	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,260.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	-0.2	13.0	1,956.6	0.1	0.6	1	1	1
10/13/2022 01:00	-0.2	12.8	2,000.9	0.1	0.6	1	1	1
10/13/2022 02:00	-0.5	13.1	1,947.1	-0.2	0.6	1	1	1
10/13/2022 03:00	-0.4	13.1	1,959.2	-0.1	0.6	1	1	1
10/13/2022 04:00	-0.5	13.1	1,939.6	-0.2	0.6	1	1	1
10/13/2022 05:00	0.4	13.9	1,307.9	0.4	0.4	1	1	0
10/13/2022 06:00	0.4	13.9	1,308.4	0.4	0.4	1	1	0
10/13/2022 07:00	0.4	14.0	1,308.7	0.4	0.4	1	1	0
10/13/2022 08:00	0.4	13.9	1,486.8	0.4	0.4	1	1	0
10/13/2022 09:00	0.4	13.9	1,537.2	0.4	0.5	1	1	0
10/13/2022 10:00	0.4	13.8	1,712.7	0.4	0.5	1	1	0
10/13/2022 11:00	0.4	13.7	1,794.6	0.4	0.5	1	1	0
10/13/2022 12:00	0.4	13.7	1,790.4	0.4	0.5	1	1	0
10/13/2022 13:00	0.4	13.7	1,784.6	0.4	0.5	1	1	0
10/13/2022 14:00	0.4	13.7	1,779.9	0.4	0.5	1	1	0
10/13/2022 15:00	0.4	13.7	1,777.3	0.4	0.5	1	1	0
10/13/2022 16:00	0.4	13.7	1,779.0	0.4	0.5	1	1	0
10/13/2022 17:00	0.4	13.7	1,779.7	0.4	0.5	1	1	0
10/13/2022 18:00	0.4	13.7	1,784.4	0.4	0.5	1	1	0
10/13/2022 19:00	0.2	13.7	1,788.0	0.4	0.5	1	1	1
10/13/2022 20:00	-0.2	12.6	2,057.0	0.1	0.6	1	1	1
10/13/2022 21:00	0.1	12.2	2,156.4	0.2	0.6	1	1	1
10/13/2022 22:00	0.1	12.5	2,080.5	0.2	0.6	1	1	1
10/13/2022 23:00	0.1	12.6	2,070.0	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,787.0	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.5	12.2	1,307.9	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	2,156.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2022 00:00	0.1	12.7	2,061.1	0.2	0.6	1	1	1
10/14/2022 01:00	0.1	12.6	2,074.7	0.2	0.6	1	1	1
10/14/2022 02:00	0.1	12.6	2,074.6	0.2	0.6	1	1	1
10/14/2022 03:00	0.1	12.6	2,071.6	0.2	0.6	1	1	1
10/14/2022 04:00	0.2	12.4	2,112.7	0.4	0.6	1	1	1
10/14/2022 05:00	0.4	11.8	2,260.2	0.5	0.7	1	1	1
10/14/2022 06:00	0.4	11.8	2,253.5	0.5	0.7	1	1	1
10/14/2022 07:00	0.4	11.9	2,225.2	0.5	0.7	1	1	1
10/14/2022 08:00	0.2	12.7	2,025.4	0.4	0.6	1	1	1
10/14/2022 09:00	0.1	13.0	1,963.8	0.2	0.6	1	1	1
10/14/2022 10:00	0.1	12.9	1,974.2	0.2	0.6	1	1	1
10/14/2022 11:00	0.1	12.8	1,981.1	0.2	0.6	1	1	1
10/14/2022 12:00	-0.1	12.8	1,989.4	0.1	0.6	1	1	1
10/14/2022 13:00	0.1	12.7	1,999.2	0.2	0.6	1	1	1
10/14/2022 14:00	0.1	12.3	2,098.0	0.2	0.6	1	1	1
10/14/2022 15:00	0.2	12.2	2,127.4	0.4	0.6	1	1	1
10/14/2022 16:00	0.2	12.2	2,119.3	0.4	0.6	1	1	1
10/14/2022 17:00	0.4	11.8	2,207.4	0.5	0.7	1	1	1
10/14/2022 18:00	0.2	12.1	2,149.5	0.4	0.6	1	1	1
10/14/2022 19:00	0.2	12.2	2,120.7	0.4	0.6	1	1	1
10/14/2022 20:00	0.2	12.2	2,129.6	0.4	0.6	1	1	1
10/14/2022 21:00	0.2	12.3	2,120.9	0.4	0.6	1	1	1
10/14/2022 22:00	0.2	12.4	2,093.7	0.4	0.6	1	1	1
10/14/2022 23:00	0.0	14.0	1,326.6	0.0	0.4	1	0	1
Average/Sum#:	0.2	12.5	2,065.0	0.3	0.6	24 #	23 #	24 #
Minimum:	-0.1	11.8	1,326.6	0.0	0.4	1	0	1
Maximum:	0.4	14.0	2,260.2	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	17.7	328.5	0.0	0.1	1	0	0
10/16/2022 18:00	0.0	16.5	574.4	0.0	0.2	1	0	0
10/16/2022 19:00	0.0	15.1	965.7	0.0	0.3	1	0	0
10/16/2022 20:00	0.4	13.8	1,770.5	0.4	0.5	1	1	0
10/16/2022 21:00	0.4	13.8	1,686.0	0.4	0.5	1	1	0
10/16/2022 22:00	0.4	13.9	1,594.4	0.4	0.5	1	1	0
10/16/2022 23:00	0.4	13.8	1,803.8	0.4	0.5	1	1	0
Average/Sum#:	0.2	14.9	1,246.2	0.2	0.4	7 #	4 #	0 #
Minimum:	0.0	13.8	328.5	0.0	0.1	0	0	0
Maximum:	0.4	17.7	1,803.8	0.4	0.5	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.4	13.9	1,642.9	0.4	0.5	1	1	0
10/17/2022 01:00	0.4	13.9	1,698.6	0.4	0.5	1	1	0
10/17/2022 02:00	0.4	13.9	1,702.5	0.4	0.5	1	1	0
10/17/2022 03:00	0.4	13.8	1,794.9	0.4	0.5	1	1	1
10/17/2022 04:00	0.1	12.7	2,058.2	0.2	0.6	1	1	1
10/17/2022 05:00	0.4	12.2	2,160.0	0.5	0.6	1	1	1
10/17/2022 06:00	0.4	12.3	2,145.3	0.5	0.6	1	1	1
10/17/2022 07:00	0.2	12.5	2,099.6	0.4	0.6	1	1	1
10/17/2022 08:00	0.4	13.8	1,683.3	0.4	0.5	1	1	1
10/17/2022 09:00	0.5	13.9	1,632.3	0.5	0.5	1	1	0
10/17/2022 10:00	0.4	14.0	1,522.6	0.4	0.5	1	1	0
10/17/2022 11:00	0.4	14.0	1,609.1	0.4	0.5	1	1	0
10/17/2022 12:00	0.4	14.0	1,506.6	0.4	0.5	1	1	0
10/17/2022 13:00	0.4	14.0	1,501.4	0.4	0.5	1	1	0
10/17/2022 14:00	0.4	14.0	1,657.9	0.4	0.5	1	1	0
10/17/2022 15:00	0.2	13.8	1,696.8	0.4	0.5	1	1	1
10/17/2022 16:00	-0.1	12.5	2,079.8	0.1	0.6	1	1	1
10/17/2022 17:00	0.2	11.8	2,230.9	0.4	0.7	1	1	1
10/17/2022 18:00	0.4	11.8	2,246.4	0.5	0.7	1	1	1
10/17/2022 19:00	0.4	11.9	2,223.6	0.5	0.7	1	1	1
10/17/2022 20:00	0.4	11.9	2,229.9	0.5	0.7	1	1	1
10/17/2022 21:00	0.4	11.8	2,239.7	0.5	0.7	1	1	1
10/17/2022 22:00	0.2	12.2	2,177.2	0.4	0.7	1	1	1
10/17/2022 23:00	0.2	12.2	2,183.6	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.0	1,905.1	0.4	0.6	24 #	24 #	15 #
Minimum:	-0.1	11.8	1,501.4	0.1	0.5	1	1	0
Maximum:	0.5	14.0	2,246.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	0.2	12.2	2,179.1	0.4	0.7	1	1	1
10/18/2022 01:00	0.4	12.3	2,170.9	0.5	0.7	1	1	1
10/18/2022 02:00	0.4	12.2	2,170.7	0.5	0.7	1	1	1
10/18/2022 03:00	0.4	12.1	2,176.9	0.5	0.7	1	1	1
10/18/2022 04:00	0.4	12.1	2,177.4	0.5	0.7	1	1	1
10/18/2022 05:00	0.2	12.2	2,182.6	0.4	0.7	1	1	1
10/18/2022 06:00	0.2	12.3	2,168.2	0.4	0.7	1	1	1
10/18/2022 07:00	0.2	12.3	2,166.7	0.4	0.7	1	1	1
10/18/2022 08:00	0.2	12.3	2,171.0	0.4	0.7	1	1	1
10/18/2022 09:00	0.2	12.4	2,155.8	0.4	0.6	1	1	1
10/18/2022 10:00	0.1	12.4	2,119.5	0.2	0.6	1	1	1
10/18/2022 11:00	0.1	12.5	2,098.2	0.2	0.6	1	1	1
10/18/2022 12:00	0.1	12.5	2,098.2	0.2	0.6	1	1	1
10/18/2022 13:00	0.1	12.5	2,102.8	0.2	0.6	1	1	1
10/18/2022 14:00	0.1	12.4	2,107.4	0.2	0.6	1	1	1
10/18/2022 15:00	0.1	12.3	2,134.7	0.2	0.6	1	1	1
10/18/2022 16:00	0.2	11.9	2,216.3	0.4	0.7	1	1	1
10/18/2022 17:00	0.2	12.1	2,188.4	0.4	0.7	1	1	1
10/18/2022 18:00	0.2	11.9	2,231.8	0.4	0.7	1	1	1
10/18/2022 19:00	0.4	11.8	2,253.5	0.5	0.7	1	1	1
10/18/2022 20:00	0.4	11.8	2,259.4	0.5	0.7	1	1	1
10/18/2022 21:00	0.4	11.8	2,259.3	0.5	0.7	1	1	1
10/18/2022 22:00	0.2	12.1	2,195.6	0.4	0.7	1	1	1
10/18/2022 23:00	0.2	12.1	2,192.8	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.2	2,174.1	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.8	2,098.2	0.2	0.6	1	1	1
Maximum:	0.4	12.5	2,259.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	0.2	12.2	2,182.0	0.4	0.7	1	1	1
10/19/2022 01:00	0.1	12.5	2,136.3	0.2	0.6	1	1	1
10/19/2022 02:00	0.1	12.6	2,103.7	0.2	0.6	1	1	1
10/19/2022 03:00	0.1	12.5	2,144.5	0.2	0.6	1	1	1
10/19/2022 04:00	0.2	12.3	2,188.0	0.4	0.7	1	1	1
10/19/2022 05:00	0.2	12.0	2,237.9	0.4	0.7	1	1	1
10/19/2022 06:00	0.2	12.2	2,213.4	0.4	0.7	1	1	1
10/19/2022 07:00	0.1	12.4	2,148.6	0.2	0.6	1	1	1
10/19/2022 08:00	0.1	12.5	2,138.1	0.2	0.6	1	1	1
10/19/2022 09:00	0.1	12.6	2,094.9	0.2	0.6	1	1	1
10/19/2022 10:00	0.1	12.6	2,079.5	0.2	0.6	1	1	1
10/19/2022 11:00	0.1	12.4	2,110.0	0.2	0.6	1	1	1
10/19/2022 12:00	0.1	12.3	2,130.2	0.2	0.6	1	1	1
10/19/2022 13:00	0.1	12.2	2,149.0	0.2	0.6	1	1	1
10/19/2022 14:00	0.1	12.2	2,141.4	0.2	0.6	1	1	1
10/19/2022 15:00	0.2	12.0	2,178.1	0.4	0.7	1	1	1
10/19/2022 16:00	0.2	12.0	2,194.2	0.4	0.7	1	1	1
10/19/2022 17:00	0.1	12.3	2,123.6	0.2	0.6	1	1	1
10/19/2022 18:00	0.1	12.4	2,099.3	0.2	0.6	1	1	1
10/19/2022 19:00	0.1	12.4	2,108.5	0.2	0.6	1	1	1
10/19/2022 20:00	0.1	12.3	2,147.1	0.2	0.6	1	1	1
10/19/2022 21:00	0.1	12.5	2,114.2	0.2	0.6	1	1	1
10/19/2022 22:00	0.1	12.6	2,087.5	0.2	0.6	1	1	1
10/19/2022 23:00	0.1	12.5	2,105.2	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.4	2,139.8	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	12.0	2,079.5	0.2	0.6	1	1	1
Maximum:	0.2	12.6	2,237.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	0.1	12.5	2,124.0	0.2	0.6	1	1	1
10/20/2022 01:00	0.1	12.6	2,087.9	0.2	0.6	1	1	1
10/20/2022 02:00	0.1	12.6	2,078.6	0.2	0.6	1	1	1
10/20/2022 03:00	-0.1	12.6	2,089.3	0.1	0.6	1	1	1
10/20/2022 04:00	0.1	12.5	2,135.5	0.2	0.6	1	1	1
10/20/2022 05:00	0.2	12.1	2,217.9	0.4	0.7	1	1	1
10/20/2022 06:00	0.2	12.3	2,191.7	0.4	0.7	1	1	1
10/20/2022 07:00	0.1	12.8	2,069.5	0.2	0.6	1	1	1
10/20/2022 08:00	0.1	12.8	2,056.4	0.2	0.6	1	1	1
10/20/2022 09:00	-0.1	12.7	2,066.1	0.1	0.6	1	1	1
10/20/2022 10:00	0.1	12.7	2,060.8	0.2	0.6	1	1	1
10/20/2022 11:00	0.1	12.5	2,079.4	0.2	0.6	1	1	1
10/20/2022 12:00	0.1	12.5	2,079.4	0.2	0.6	1	1	1
10/20/2022 13:00	0.1	12.4	2,099.7	0.2	0.6	1	1	1
10/20/2022 14:00	0.1	12.3	2,121.0	0.2	0.6	1	1	1
10/20/2022 15:00	0.1	12.2	2,147.2	0.2	0.6	1	1	1
10/20/2022 16:00	0.2	11.7	2,241.0	0.4	0.7	1	1	1
10/20/2022 17:00	0.2	12.0	2,178.6	0.4	0.7	1	1	1
10/20/2022 18:00	0.2	11.9	2,212.5	0.4	0.7	1	1	1
10/20/2022 19:00	0.1	12.3	2,107.9	0.2	0.6	1	1	1
10/20/2022 20:00	0.1	12.4	2,104.9	0.2	0.6	1	1	1
10/20/2022 21:00	0.1	12.6	2,083.3	0.2	0.6	1	1	1
10/20/2022 22:00	0.1	12.6	2,083.3	0.2	0.6	1	1	1
10/20/2022 23:00	0.1	12.4	2,136.7	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.4	2,118.9	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	2,056.4	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,241.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	-0.1	12.9	1,988.0	0.1	0.6	1	1	1
10/21/2022 01:00	0.4	14.0	1,577.0	0.4	0.5	1	1	0
10/21/2022 02:00	0.4	13.9	1,586.8	0.4	0.5	1	1	0
10/21/2022 03:00	0.4	13.9	1,543.4	0.4	0.5	1	1	0
10/21/2022 04:00	0.4	14.0	1,696.1	0.4	0.5	1	1	0
10/21/2022 05:00	0.4	14.0	1,698.2	0.4	0.5	1	1	0
10/21/2022 06:00	0.4	14.0	1,598.5	0.4	0.5	1	1	0
10/21/2022 07:00	0.4	14.0	1,668.5	0.4	0.5	1	1	0
10/21/2022 08:00	0.4	14.0	1,704.9	0.4	0.5	1	1	0
10/21/2022 09:00	0.4	14.0	1,708.4	0.4	0.5	1	1	0
10/21/2022 10:00	0.4	14.0	1,706.9	0.4	0.5	1	1	0
10/21/2022 11:00	0.4	14.0	1,671.9	0.4	0.5	1	1	0
10/21/2022 12:00	0.4	14.0	1,648.8	0.4	0.5	1	1	0
10/21/2022 13:00	0.4	14.0	1,624.1	0.4	0.5	1	1	0
10/21/2022 14:00	0.4	13.9	1,681.0	0.4	0.5	1	1	0
10/21/2022 15:00	0.2	13.9	1,556.4	0.2	0.5	1	1	1
10/21/2022 16:00	-0.1	12.4	2,095.8	0.2	0.6	1	1	1
10/21/2022 17:00	0.2	12.0	2,180.2	0.4	0.7	1	1	1
10/21/2022 18:00	0.1	12.2	2,136.5	0.2	0.6	1	1	1
10/21/2022 19:00	0.1	12.4	2,098.4	0.2	0.6	1	1	1
10/21/2022 20:00	0.1	12.3	2,116.7	0.2	0.6	1	1	1
10/21/2022 21:00	0.2	12.0	2,176.0	0.4	0.7	1	1	1
10/21/2022 22:00	0.0	14.3	1,201.6	0.0	0.4	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.5	1,768.0	0.3	0.5	23 #	22 #	9 #
Minimum:	-0.1	12.0	1,201.6	0.0	0.4	0	0	0
Maximum:	0.4	14.3	2,180.2	0.4	0.7	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	17.8	297.2	0.0	0.1	1	0	0
10/23/2022 21:00	0.0	17.3	370.7	0.0	0.1	1	0	0
10/23/2022 22:00	0.0	15.9	787.1	0.0	0.2	1	0	0
10/23/2022 23:00	0.5	14.1	1,353.7	0.5	0.4	1	1	0
Average/Sum#:	0.1	16.3	702.2	0.1	0.2	4 #	1 #	0 #
Minimum:	0.0	14.1	297.2	0.0	0.1	0	0	0
Maximum:	0.5	17.8	1,353.7	0.5	0.4	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.5	14.1	1,368.5	0.5	0.4	1	1	0
10/24/2022 01:00	0.5	14.1	1,359.7	0.5	0.4	1	1	0
10/24/2022 02:00	0.5	14.1	1,359.6	0.5	0.4	1	1	0
10/24/2022 03:00	0.5	14.1	1,359.6	0.5	0.4	1	1	0
10/24/2022 04:00	0.5	13.9	1,649.1	0.5	0.5	1	1	0
10/24/2022 05:00	0.5	13.8	1,820.4	0.5	0.5	1	1	0
10/24/2022 06:00	0.5	13.8	1,821.7	0.5	0.5	1	1	0
10/24/2022 07:00	0.5	13.8	1,819.3	0.5	0.5	1	1	0
10/24/2022 08:00	0.5	13.9	1,816.0	0.5	0.5	1	1	0
10/24/2022 09:00	0.4	13.9	1,793.7	0.4	0.5	1	1	0
10/24/2022 10:00	0.4	13.8	1,841.1	0.4	0.6	1	1	0
10/24/2022 11:00	0.4	13.8	1,831.5	0.4	0.5	1	1	0
10/24/2022 12:00	0.4	13.9	1,769.6	0.4	0.5	1	1	0
10/24/2022 13:00	0.4	13.9	1,746.6	0.4	0.5	1	1	0
10/24/2022 14:00	0.0	15.1	1,013.9	0.0	0.3	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.0	1,624.7	0.4	0.5	15 #	14 #	0 #
Minimum:	0.0	13.8	1,013.9	0.0	0.3	0	0	0
Maximum:	0.5	15.1	1,841.1	0.5	0.6	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	18.9	164.5	0.0	0.0	1	0	0
10/30/2022 20:00	0.0	17.3	372.9	0.0	0.1	1	0	0
10/30/2022 21:00	0.0	16.8	562.7	0.0	0.2	1	0	0
10/30/2022 22:00	0.0	16.0	878.4	0.0	0.3	1	0	0
10/30/2022 23:00	0.4	13.8	1,773.4	0.4	0.5	1	1	0
Average/Sum#:	0.1	16.6	750.4	0.1	0.2	5 #	1 #	0 #
Minimum:	0.0	13.8	164.5	0.0	0.0	0	0	0
Maximum:	0.4	18.9	1,773.4	0.4	0.5	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.4	14.0	1,565.8	0.4	0.5	1	1	0
10/31/2022 01:00	0.4	13.9	1,787.0	0.4	0.5	1	1	0
10/31/2022 02:00	0.4	14.0	1,671.4	0.4	0.5	1	1	0
10/31/2022 03:00	0.4	14.0	1,708.8	0.4	0.5	1	1	0
10/31/2022 04:00	0.4	14.0	1,723.8	0.4	0.5	1	1	0
10/31/2022 05:00	0.4	14.0	1,708.1	0.4	0.5	1	1	0
10/31/2022 06:00	0.4	14.0	1,699.3	0.4	0.5	1	1	0
10/31/2022 07:00	0.4	14.0	1,700.7	0.4	0.5	1	1	0
10/31/2022 08:00	0.4	14.0	1,704.0	0.4	0.5	1	1	0
10/31/2022 09:00	0.4	14.0	1,705.2	0.4	0.5	1	1	0
10/31/2022 10:00	0.4	14.0	1,708.1	0.4	0.5	1	1	0
10/31/2022 11:00	0.4	14.0	1,687.1	0.4	0.5	1	1	0
10/31/2022 12:00	0.4	14.0	1,677.9	0.4	0.5	1	1	0
10/31/2022 13:00	0.4	14.0	1,691.9	0.4	0.5	1	1	0
10/31/2022 14:00	0.2	13.9	1,760.4	0.2	0.5	1	1	1
10/31/2022 15:00	-0.2	12.6	2,079.3	0.1	0.6	1	1	1
10/31/2022 16:00	-0.1	12.5	2,105.8	0.1	0.6	1	1	1
10/31/2022 17:00	-0.1	12.6	2,078.5	0.1	0.6	1	1	1
10/31/2022 18:00	-0.1	12.6	2,081.3	0.1	0.6	1	1	1
10/31/2022 19:00	0.1	12.5	2,104.0	0.2	0.6	1	1	1
10/31/2022 20:00	0.1	12.5	2,108.1	0.2	0.6	1	1	1
10/31/2022 21:00	0.1	12.3	2,163.0	0.2	0.6	1	1	1
10/31/2022 22:00	0.2	12.5	2,119.3	0.4	0.6	1	1	1
10/31/2022 23:00	0.2	12.3	2,146.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,853.5	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	12.3	1,565.8	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,163.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	0.2	12.4	2,163.8	0.4	0.6	1	1	1
11/01/2022 01:00	0.2	12.4	2,153.2	0.4	0.6	1	1	1
11/01/2022 02:00	0.2	12.4	2,162.1	0.4	0.6	1	1	1
11/01/2022 03:00	0.2	12.4	2,163.5	0.4	0.6	1	1	1
11/01/2022 04:00	0.2	12.4	2,167.9	0.4	0.7	1	1	1
11/01/2022 05:00	0.2	12.4	2,167.4	0.4	0.7	1	1	1
11/01/2022 06:00	0.4	12.1	2,232.9	0.5	0.7	1	1	1
11/01/2022 07:00	0.4	12.3	2,179.4	0.5	0.7	1	1	1
11/01/2022 08:00	0.4	12.0	2,231.6	0.5	0.7	1	1	1
11/01/2022 09:00	0.4	12.4	2,116.2	0.5	0.6	1	1	1
11/01/2022 10:00	0.2	12.5	2,121.2	0.4	0.6	1	1	1
11/01/2022 11:00	0.4	12.2	2,178.7	0.5	0.7	1	1	1
11/01/2022 12:00	0.4	12.2	2,182.8	0.5	0.7	1	1	1
11/01/2022 13:00	0.4	12.3	2,169.2	0.5	0.7	1	1	1
11/01/2022 14:00	0.4	12.6	2,083.1	0.5	0.6	1	1	1
11/01/2022 15:00	0.1	12.7	2,094.6	0.2	0.6	1	1	1
11/01/2022 16:00	0.2	12.2	2,225.8	0.4	0.7	1	1	1
11/01/2022 17:00	0.5	11.9	2,292.1	0.5	0.7	1	1	1
11/01/2022 18:00	0.4	12.3	2,192.0	0.5	0.7	1	1	1
11/01/2022 19:00	0.4	12.5	2,163.6	0.5	0.6	1	1	1
11/01/2022 20:00	0.4	12.3	2,201.7	0.5	0.7	1	1	1
11/01/2022 21:00	0.2	12.8	2,080.8	0.4	0.6	1	1	1
11/01/2022 22:00	0.2	12.9	2,070.4	0.4	0.6	1	1	1
11/01/2022 23:00	0.4	13.4	1,845.9	0.4	0.6	1	1	1
Average/Sum#:	0.3	12.4	2,151.7	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,845.9	0.2	0.6	1	1	1
Maximum:	0.5	13.4	2,292.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.5	14.1	1,347.9	0.5	0.4	1	1	0
11/02/2022 01:00	0.5	14.0	1,630.5	0.5	0.5	1	1	0
11/02/2022 02:00	0.4	14.0	1,698.9	0.4	0.5	1	1	0
11/02/2022 03:00	0.4	14.0	1,348.8	0.4	0.4	1	1	0
11/02/2022 04:00	0.4	14.0	1,665.7	0.4	0.5	1	1	0
11/02/2022 05:00	0.2	13.5	1,907.9	0.4	0.6	1	1	1
11/02/2022 06:00	0.1	12.7	2,175.1	0.2	0.7	1	1	1
11/02/2022 07:00	0.2	12.8	2,135.9	0.4	0.6	1	1	1
11/02/2022 08:00	0.1	13.1	2,040.3	0.2	0.6	1	1	1
11/02/2022 09:00	0.5	14.0	1,710.1	0.5	0.5	1	1	0
11/02/2022 10:00	0.5	14.0	1,543.3	0.5	0.5	1	1	0
11/02/2022 11:00	0.5	14.0	1,672.4	0.5	0.5	1	1	0
11/02/2022 12:00	0.5	14.0	1,549.7	0.5	0.5	1	1	0
11/02/2022 13:00	0.5	14.0	1,552.9	0.5	0.5	1	1	0
11/02/2022 14:00	0.4	14.0	1,535.2	0.4	0.5	1	1	0
11/02/2022 15:00	0.4	14.0	1,604.0	0.4	0.5	1	1	1
11/02/2022 16:00	0.1	12.8	2,092.6	0.2	0.6	1	1	1
11/02/2022 17:00	0.2	12.5	2,182.8	0.4	0.7	1	1	1
11/02/2022 18:00	0.2	12.5	2,177.3	0.4	0.7	1	1	1
11/02/2022 19:00	0.2	12.5	2,175.0	0.4	0.7	1	1	1
11/02/2022 20:00	0.2	12.6	2,175.1	0.4	0.7	1	1	1
11/02/2022 21:00	0.2	12.6	2,157.6	0.4	0.6	1	1	1
11/02/2022 22:00	0.2	12.6	2,164.2	0.4	0.6	1	1	1
11/02/2022 23:00	0.2	12.6	2,177.5	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.4	1,850.9	0.4	0.6	24 #	24 #	13 #
Minimum:	0.1	12.5	1,347.9	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,182.8	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2022 00:00	0.2	12.6	2,169.0	0.4	0.7	1	1	1
11/03/2022 01:00	0.2	12.7	2,153.0	0.4	0.6	1	1	1
11/03/2022 02:00	0.2	12.5	2,194.3	0.4	0.7	1	1	1
11/03/2022 03:00	0.4	12.3	2,234.1	0.5	0.7	1	1	1
11/03/2022 04:00	0.2	12.6	2,163.9	0.4	0.6	1	1	1
11/03/2022 05:00	0.2	12.6	2,166.0	0.4	0.6	1	1	1
11/03/2022 06:00	0.4	12.4	2,231.2	0.5	0.7	1	1	1
11/03/2022 07:00	0.2	12.8	2,110.9	0.4	0.6	1	1	1
11/03/2022 08:00	0.5	14.1	1,456.2	0.5	0.4	1	1	0
11/03/2022 09:00	0.5	14.0	1,559.4	0.5	0.5	1	1	0
11/03/2022 10:00	0.5	14.0	1,574.2	0.5	0.5	1	1	0
11/03/2022 11:00	0.5	14.0	1,570.2	0.5	0.5	1	1	0
11/03/2022 12:00	0.5	14.0	1,579.0	0.5	0.5	1	1	0
11/03/2022 13:00	0.5	14.1	1,487.4	0.5	0.4	1	1	0
11/03/2022 14:00	0.4	14.1	1,553.3	0.4	0.5	1	1	0
11/03/2022 15:00	0.4	14.0	1,771.8	0.4	0.5	1	1	1
11/03/2022 16:00	0.1	12.8	2,084.1	0.2	0.6	1	1	1
11/03/2022 17:00	0.2	12.5	2,162.5	0.4	0.6	1	1	1
11/03/2022 18:00	0.4	12.5	2,175.5	0.5	0.7	1	1	1
11/03/2022 19:00	0.4	12.5	2,174.2	0.5	0.7	1	1	1
11/03/2022 20:00	0.4	12.5	2,163.4	0.5	0.6	1	1	1
11/03/2022 21:00	0.4	12.5	2,161.9	0.5	0.6	1	1	1
11/03/2022 22:00	0.4	12.5	2,161.6	0.5	0.6	1	1	1
11/03/2022 23:00	0.4	12.4	2,201.2	0.5	0.7	1	1	1
Average/Sum#:	0.4	13.0	1,969.1	0.5	0.6	24 #	24 #	17 #
Minimum:	0.1	12.3	1,456.2	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,234.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	0.2	12.7	2,139.4	0.4	0.6	1	1	1
11/04/2022 01:00	0.2	12.7	2,120.0	0.4	0.6	1	1	1
11/04/2022 02:00	0.2	12.9	2,069.1	0.4	0.6	1	1	1
11/04/2022 03:00	0.2	12.9	2,071.1	0.4	0.6	1	1	1
11/04/2022 04:00	0.2	12.7	2,149.6	0.4	0.6	1	1	1
11/04/2022 05:00	0.4	12.3	2,242.1	0.5	0.7	1	1	1
11/04/2022 06:00	0.2	12.6	2,177.1	0.4	0.7	1	1	1
11/04/2022 07:00	0.2	13.0	2,059.9	0.4	0.6	1	1	1
11/04/2022 08:00	0.5	14.0	1,718.3	0.5	0.5	1	1	1
11/04/2022 09:00	0.5	14.0	1,552.2	0.5	0.5	1	1	0
11/04/2022 10:00	0.5	14.1	1,390.6	0.5	0.4	1	1	0
11/04/2022 11:00	0.5	14.1	1,319.4	0.5	0.4	1	1	0
11/04/2022 12:00	0.5	14.1	1,316.8	0.5	0.4	1	1	0
11/04/2022 13:00	0.5	14.1	1,317.6	0.5	0.4	1	1	0
11/04/2022 14:00	0.4	14.1	1,398.3	0.4	0.4	1	1	0
11/04/2022 15:00	0.2	13.9	1,629.0	0.2	0.5	1	1	1
11/04/2022 16:00	0.1	12.7	2,105.1	0.2	0.6	1	1	1
11/04/2022 17:00	0.2	12.5	2,145.5	0.4	0.6	1	1	1
11/04/2022 18:00	0.2	12.8	2,089.4	0.4	0.6	1	1	1
11/04/2022 19:00	0.2	12.8	2,086.7	0.4	0.6	1	1	1
11/04/2022 20:00	0.2	12.8	2,076.1	0.4	0.6	1	1	1
11/04/2022 21:00	0.2	12.8	2,074.7	0.4	0.6	1	1	1
11/04/2022 22:00	0.2	12.8	2,082.6	0.4	0.6	1	1	1
11/04/2022 23:00	0.2	13.3	1,970.2	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,887.5	0.4	0.6	24 #	24 #	18 #
Minimum:	0.1	12.3	1,316.8	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,242.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	0.1	13.3	1,965.0	0.2	0.6	1	1	1
11/05/2022 01:00	0.2	13.3	1,965.4	0.4	0.6	1	1	1
11/05/2022 02:00	0.1	13.3	1,965.9	0.2	0.6	1	1	1
11/05/2022 03:00	0.1	13.3	1,965.1	0.2	0.6	1	1	1
11/05/2022 04:00	0.1	13.3	1,973.7	0.2	0.6	1	1	1
11/05/2022 05:00	0.1	13.3	1,978.5	0.2	0.6	1	1	1
11/05/2022 06:00	0.1	13.3	1,948.0	0.2	0.6	1	1	1
11/05/2022 07:00	0.0	15.9	568.2	0.0	0.2	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.6	1,791.2	0.2	0.6	8 #	7 #	7 #
Minimum:	0.0	13.3	568.2	0.0	0.2	0	0	0
Maximum:	0.2	15.9	1,978.5	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	18.2	259.0	0.0	0.1	1	0	0
11/06/2022 10:00	0.0	17.4	380.5	0.0	0.1	1	0	0
11/06/2022 11:00	0.0	15.7	828.7	0.0	0.2	1	0	0
11/06/2022 12:00	0.4	14.0	1,401.7	0.4	0.4	1	1	0
11/06/2022 13:00	0.4	14.0	1,533.1	0.4	0.5	1	1	0
11/06/2022 14:00	0.4	13.9	1,606.7	0.4	0.5	1	1	0
11/06/2022 15:00	0.1	12.9	1,957.5	0.2	0.6	1	1	1
11/06/2022 16:00	0.2	11.8	2,286.9	0.4	0.7	1	1	1
11/06/2022 17:00	0.4	11.7	2,303.5	0.5	0.7	1	1	1
11/06/2022 18:00	0.1	12.9	2,010.4	0.2	0.6	1	1	1
11/06/2022 19:00	-0.1	13.2	1,964.3	0.1	0.6	1	1	1
11/06/2022 20:00	-0.1	13.1	1,989.1	0.1	0.6	1	1	1
11/06/2022 21:00	0.0	13.3	1,677.6	0.0	0.5	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.0	1,553.8	0.2	0.5	13 #	9 #	7 #
Minimum:	-0.1	11.7	259.0	0.0	0.1	0	0	0
Maximum:	0.4	18.2	2,303.5	0.5	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	18.1	314.8	0.0	0.1	1	0	0
11/07/2022 01:00	0.0	15.3	1,013.6	0.0	0.3	1	0	0
11/07/2022 02:00	0.4	14.0	1,566.8	0.4	0.5	1	1	0
11/07/2022 03:00	0.4	14.0	1,619.9	0.4	0.5	1	1	0
11/07/2022 04:00	0.4	14.0	1,676.5	0.4	0.5	1	1	0
11/07/2022 05:00	0.4	13.9	1,708.4	0.4	0.5	1	1	0
11/07/2022 06:00	0.1	12.9	2,008.4	0.2	0.6	1	1	1
11/07/2022 07:00	0.2	12.2	2,239.0	0.4	0.7	1	1	1
11/07/2022 08:00	0.1	13.2	1,992.4	0.2	0.6	1	1	1
11/07/2022 09:00	0.1	13.2	1,975.3	0.2	0.6	1	1	1
11/07/2022 10:00	0.1	13.2	1,964.7	0.2	0.6	1	1	1
11/07/2022 11:00	0.1	13.2	1,962.6	0.2	0.6	1	1	1
11/07/2022 12:00	0.1	13.2	1,963.8	0.2	0.6	1	1	1
11/07/2022 13:00	0.1	13.2	1,962.7	0.2	0.6	1	1	1
11/07/2022 14:00	0.1	12.8	2,060.4	0.2	0.6	1	1	1
11/07/2022 15:00	0.2	12.3	2,192.5	0.4	0.7	1	1	1
11/07/2022 16:00	0.4	12.0	2,250.1	0.5	0.7	1	1	1
11/07/2022 17:00	0.5	11.9	2,290.9	0.5	0.7	1	1	1
11/07/2022 18:00	0.5	11.9	2,297.0	0.5	0.7	1	1	1
11/07/2022 19:00	0.5	11.9	2,293.7	0.5	0.7	1	1	1
11/07/2022 20:00	0.5	11.9	2,289.5	0.5	0.7	1	1	1
11/07/2022 21:00	0.5	11.9	2,293.4	0.5	0.7	1	1	1
11/07/2022 22:00	0.4	12.1	2,257.7	0.5	0.7	1	1	1
11/07/2022 23:00	0.2	12.4	2,181.0	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.1	1,932.3	0.3	0.6	24 #	22 #	18 #
Minimum:	0.0	11.9	314.8	0.0	0.1	1	0	0
Maximum:	0.5	18.1	2,297.0	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.2	12.4	2,172.6	0.4	0.7	1	1	1
11/08/2022 01:00	0.2	12.5	2,167.5	0.4	0.7	1	1	1
11/08/2022 02:00	0.2	12.6	2,112.2	0.4	0.6	1	1	1
11/08/2022 03:00	0.2	12.5	2,160.9	0.4	0.6	1	1	1
11/08/2022 04:00	0.4	12.3	2,200.1	0.5	0.7	1	1	1
11/08/2022 05:00	0.4	12.2	2,219.7	0.5	0.7	1	1	1
11/08/2022 06:00	0.5	11.8	2,300.5	0.5	0.7	1	1	1
11/08/2022 07:00	0.4	12.2	2,213.6	0.5	0.7	1	1	1
11/08/2022 08:00	0.4	12.2	2,202.3	0.5	0.7	1	1	1
11/08/2022 09:00	0.4	12.2	2,200.4	0.5	0.7	1	1	1
11/08/2022 10:00	0.4	12.3	2,185.6	0.5	0.7	1	1	1
11/08/2022 11:00	0.2	13.0	2,032.7	0.4	0.6	1	1	1
11/08/2022 12:00	0.1	13.2	1,987.2	0.2	0.6	1	1	1
11/08/2022 13:00	0.1	13.2	1,985.1	0.2	0.6	1	1	1
11/08/2022 14:00	0.1	12.9	2,056.2	0.2	0.6	1	1	1
11/08/2022 15:00	0.1	12.9	2,056.3	0.2	0.6	1	1	1
11/08/2022 16:00	0.2	12.3	2,217.1	0.4	0.7	1	1	1
11/08/2022 17:00	0.4	12.3	2,201.6	0.5	0.7	1	1	1
11/08/2022 18:00	0.2	12.4	2,173.9	0.4	0.7	1	1	1
11/08/2022 19:00	0.4	12.3	2,206.4	0.5	0.7	1	1	1
11/08/2022 20:00	0.4	12.3	2,206.2	0.5	0.7	1	1	1
11/08/2022 21:00	0.4	12.3	2,204.5	0.5	0.7	1	1	1
11/08/2022 22:00	0.4	12.3	2,190.4	0.5	0.7	1	1	1
11/08/2022 23:00	0.2	12.5	2,146.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	12.5	2,158.3	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.8	1,985.1	0.2	0.6	1	1	1
Maximum:	0.5	13.2	2,300.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2022 00:00	0.2	12.5	2,155.3	0.4	0.6	1	1	1
11/09/2022 01:00	0.2	12.5	2,154.5	0.4	0.6	1	1	1
11/09/2022 02:00	0.4	12.4	2,194.0	0.5	0.7	1	1	1
11/09/2022 03:00	0.4	12.4	2,195.1	0.5	0.7	1	1	1
11/09/2022 04:00	0.2	12.5	2,162.1	0.4	0.6	1	1	1
11/09/2022 05:00	0.4	12.2	2,258.0	0.5	0.7	1	1	1
11/09/2022 06:00	0.4	12.0	2,298.8	0.5	0.7	1	1	1
11/09/2022 07:00	0.4	12.4	2,203.8	0.5	0.7	1	1	1
11/09/2022 08:00	0.4	12.5	2,162.6	0.5	0.6	1	1	1
11/09/2022 09:00	0.4	13.8	1,742.9	0.4	0.5	1	1	1
11/09/2022 10:00	0.5	13.9	1,701.0	0.5	0.5	1	1	0
11/09/2022 11:00	0.5	13.9	1,628.8	0.5	0.5	1	1	0
11/09/2022 12:00	0.5	13.9	1,704.5	0.5	0.5	1	1	0
11/09/2022 13:00	0.5	14.0	1,617.1	0.5	0.5	1	1	0
11/09/2022 14:00	0.5	13.9	1,688.5	0.5	0.5	1	1	0
11/09/2022 15:00	0.5	13.9	1,636.8	0.5	0.5	1	1	1
11/09/2022 16:00	0.1	12.8	2,083.4	0.2	0.6	1	1	1
11/09/2022 17:00	0.2	12.5	2,158.5	0.4	0.6	1	1	1
11/09/2022 18:00	0.2	13.1	2,013.7	0.4	0.6	1	1	1
11/09/2022 19:00	0.2	13.3	1,976.3	0.4	0.6	1	1	1
11/09/2022 20:00	0.2	13.3	1,979.9	0.4	0.6	1	1	1
11/09/2022 21:00	0.2	13.3	2,004.2	0.4	0.6	1	1	1
11/09/2022 22:00	0.2	13.3	1,996.1	0.4	0.6	1	1	1
11/09/2022 23:00	0.2	13.3	1,995.5	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,988.0	0.4	0.6	24 #	24 #	19 #
Minimum:	0.1	12.0	1,617.1	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,298.8	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	0.2	13.3	1,995.0	0.4	0.6	1	1	1
11/10/2022 01:00	0.2	13.3	1,993.3	0.4	0.6	1	1	1
11/10/2022 02:00	0.2	13.3	1,991.3	0.4	0.6	1	1	1
11/10/2022 03:00	0.2	13.3	1,994.2	0.4	0.6	1	1	1
11/10/2022 04:00	0.2	13.0	2,084.2	0.4	0.6	1	1	1
11/10/2022 05:00	0.2	12.6	2,176.6	0.4	0.7	1	1	1
11/10/2022 06:00	0.4	12.0	2,294.6	0.5	0.7	1	1	1
11/10/2022 07:00	0.2	12.8	2,120.5	0.4	0.6	1	1	1
11/10/2022 08:00	0.2	13.3	1,983.8	0.4	0.6	1	1	1
11/10/2022 09:00	0.2	13.3	1,965.9	0.4	0.6	1	1	1
11/10/2022 10:00	0.5	14.0	1,725.4	0.5	0.5	1	1	0
11/10/2022 11:00	0.5	14.0	1,712.5	0.5	0.5	1	1	0
11/10/2022 12:00	0.5	14.0	1,711.2	0.5	0.5	1	1	0
11/10/2022 13:00	0.5	14.0	1,562.8	0.5	0.5	1	1	0
11/10/2022 14:00	0.5	14.0	1,712.6	0.5	0.5	1	1	0
11/10/2022 15:00	0.4	13.9	1,716.1	0.4	0.5	1	1	1
11/10/2022 16:00	0.2	12.7	2,137.8	0.4	0.6	1	1	1
11/10/2022 17:00	0.5	12.2	2,271.9	0.5	0.7	1	1	1
11/10/2022 18:00	0.5	12.2	2,274.5	0.5	0.7	1	1	1
11/10/2022 19:00	0.5	12.2	2,277.9	0.5	0.7	1	1	1
11/10/2022 20:00	0.5	12.2	2,279.9	0.5	0.7	1	1	1
11/10/2022 21:00	0.5	12.2	2,281.1	0.5	0.7	1	1	1
11/10/2022 22:00	0.5	12.2	2,281.8	0.5	0.7	1	1	1
11/10/2022 23:00	0.5	12.3	2,260.5	0.5	0.7	1	1	1
Average/Sum#:	0.4	13.0	2,033.6	0.5	0.6	24 #	24 #	19 #
Minimum:	0.2	12.0	1,562.8	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,294.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.5	12.2	2,281.0	0.5	0.7	1	1	1
11/11/2022 01:00	0.5	12.2	2,270.4	0.5	0.7	1	1	1
11/11/2022 02:00	0.4	12.7	2,154.0	0.5	0.6	1	1	1
11/11/2022 03:00	0.4	12.7	2,151.7	0.5	0.6	1	1	1
11/11/2022 04:00	0.5	12.3	2,272.4	0.5	0.7	1	1	1
11/11/2022 05:00	0.5	12.2	2,285.8	0.5	0.7	1	1	1
11/11/2022 06:00	0.5	12.3	2,289.0	0.5	0.7	1	1	1
11/11/2022 07:00	0.4	12.9	2,119.2	0.5	0.6	1	1	1
11/11/2022 08:00	0.2	13.4	1,954.8	0.4	0.6	1	1	1
11/11/2022 09:00	0.5	14.0	1,708.7	0.5	0.5	1	1	0
11/11/2022 10:00	0.5	14.0	1,712.4	0.5	0.5	1	1	0
11/11/2022 11:00	0.5	14.0	1,684.1	0.5	0.5	1	1	0
11/11/2022 12:00	0.5	14.0	1,684.6	0.5	0.5	1	1	0
11/11/2022 13:00	0.4	14.0	1,694.9	0.4	0.5	1	1	0
11/11/2022 14:00	0.4	14.0	1,573.1	0.4	0.5	1	1	0
11/11/2022 15:00	0.4	14.0	1,687.2	0.4	0.5	1	1	0
11/11/2022 16:00	0.2	13.1	1,984.8	0.4	0.6	1	1	1
11/11/2022 17:00	0.5	12.1	2,268.3	0.5	0.7	1	1	1
11/11/2022 18:00	0.5	12.1	2,263.3	0.5	0.7	1	1	1
11/11/2022 19:00	0.5	12.2	2,260.6	0.5	0.7	1	1	1
11/11/2022 20:00	0.5	12.2	2,253.7	0.5	0.7	1	1	1
11/11/2022 21:00	0.5	12.2	2,252.9	0.5	0.7	1	1	1
11/11/2022 22:00	0.5	12.3	2,246.0	0.5	0.7	1	1	1
11/11/2022 23:00	0.5	12.2	2,259.7	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.9	2,054.7	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.1	1,573.1	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,289.0	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.5	12.3	2,267.0	0.5	0.7	1	1	1
11/12/2022 01:00	0.5	12.3	2,275.6	0.5	0.7	1	1	1
11/12/2022 02:00	0.5	12.2	2,278.8	0.5	0.7	1	1	1
11/12/2022 03:00	0.5	12.2	2,280.4	0.5	0.7	1	1	1
11/12/2022 04:00	0.5	12.2	2,285.0	0.5	0.7	1	1	1
11/12/2022 05:00	0.5	12.2	2,285.3	0.5	0.7	1	1	1
11/12/2022 06:00	0.5	12.2	2,276.7	0.5	0.7	1	1	1
11/12/2022 07:00	0.2	12.8	2,103.5	0.4	0.6	1	1	1
11/12/2022 08:00	0.4	12.3	2,210.7	0.5	0.7	1	1	1
11/12/2022 09:00	0.5	13.8	1,747.7	0.5	0.5	1	1	1
11/12/2022 10:00	0.5	14.0	1,589.6	0.5	0.5	1	1	0
11/12/2022 11:00	0.5	14.0	1,554.3	0.5	0.5	1	1	0
11/12/2022 12:00	0.5	14.0	1,551.1	0.5	0.5	1	1	0
11/12/2022 13:00	0.5	14.0	1,570.2	0.5	0.5	1	1	0
11/12/2022 14:00	0.5	14.0	1,549.0	0.5	0.5	1	1	0
11/12/2022 15:00	0.4	13.9	1,791.5	0.4	0.5	1	1	1
11/12/2022 16:00	0.2	12.7	2,126.7	0.4	0.6	1	1	1
11/12/2022 17:00	0.5	12.2	2,245.9	0.5	0.7	1	1	1
11/12/2022 18:00	0.5	12.2	2,246.8	0.5	0.7	1	1	1
11/12/2022 19:00	0.5	12.2	2,251.2	0.5	0.7	1	1	1
11/12/2022 20:00	0.5	12.2	2,260.4	0.5	0.7	1	1	1
11/12/2022 21:00	0.5	12.2	2,259.8	0.5	0.7	1	1	1
11/12/2022 22:00	0.5	12.5	2,193.5	0.5	0.7	1	1	1
11/12/2022 23:00	0.5	12.5	2,190.6	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.8	2,058.0	0.5	0.6	24 #	24 #	19 #
Minimum:	0.2	12.2	1,549.0	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,285.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.4	12.6	2,180.8	0.5	0.7	1	1	1
11/13/2022 01:00	0.4	12.6	2,170.0	0.5	0.7	1	1	1
11/13/2022 02:00	0.4	12.7	2,165.0	0.5	0.6	1	1	1
11/13/2022 03:00	0.5	12.5	2,194.5	0.5	0.7	1	1	1
11/13/2022 04:00	0.5	12.6	2,189.7	0.5	0.7	1	1	1
11/13/2022 05:00	0.4	12.6	2,184.1	0.5	0.7	1	1	1
11/13/2022 06:00	0.5	12.5	2,195.0	0.5	0.7	1	1	1
11/13/2022 07:00	0.5	12.4	2,240.2	0.5	0.7	1	1	1
11/13/2022 08:00	0.5	13.1	1,966.4	0.5	0.6	1	1	1
11/13/2022 09:00	0.5	14.0	1,706.5	0.5	0.5	1	1	0
11/13/2022 10:00	0.5	14.0	1,707.9	0.5	0.5	1	1	0
11/13/2022 11:00	0.5	14.0	1,707.9	0.5	0.5	1	1	0
11/13/2022 12:00	0.5	14.0	1,706.8	0.5	0.5	1	1	0
11/13/2022 13:00	0.4	14.0	1,709.5	0.4	0.5	1	1	0
11/13/2022 14:00	0.4	14.0	1,677.7	0.4	0.5	1	1	0
11/13/2022 15:00	0.4	13.9	1,782.8	0.4	0.5	1	1	1
11/13/2022 16:00	0.2	12.5	2,138.8	0.4	0.6	1	1	1
11/13/2022 17:00	0.5	11.9	2,280.1	0.5	0.7	1	1	1
11/13/2022 18:00	0.5	11.9	2,280.5	0.5	0.7	1	1	1
11/13/2022 19:00	0.5	11.9	2,284.4	0.5	0.7	1	1	1
11/13/2022 20:00	0.5	11.9	2,288.2	0.5	0.7	1	1	1
11/13/2022 21:00	0.5	11.9	2,292.8	0.5	0.7	1	1	1
11/13/2022 22:00	0.5	11.9	2,295.1	0.5	0.7	1	1	1
11/13/2022 23:00	0.5	11.9	2,299.3	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.8	2,068.5	0.5	0.6	24 #	24 #	18 #
Minimum:	0.2	11.9	1,677.7	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,299.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.5	11.9	2,298.5	0.5	0.7	1	1	1
11/14/2022 01:00	0.5	12.0	2,289.5	0.5	0.7	1	1	1
11/14/2022 02:00	0.4	12.1	2,286.2	0.5	0.7	1	1	1
11/14/2022 03:00	0.2	12.6	2,166.7	0.4	0.7	1	1	1
11/14/2022 04:00	0.4	12.3	2,241.5	0.5	0.7	1	1	1
11/14/2022 05:00	0.4	12.0	2,303.2	0.5	0.7	1	1	1
11/14/2022 06:00	0.4	12.1	2,299.4	0.5	0.7	1	1	1
11/14/2022 07:00	0.2	12.5	2,194.7	0.4	0.7	1	1	1
11/14/2022 08:00	0.2	12.7	2,159.1	0.4	0.6	1	1	1
11/14/2022 09:00	0.2	12.6	2,167.7	0.4	0.7	1	1	1
11/14/2022 10:00	0.2	12.6	2,158.5	0.4	0.6	1	1	1
11/14/2022 11:00	0.2	12.6	2,130.2	0.4	0.6	1	1	1
11/14/2022 12:00	0.2	12.6	2,126.0	0.4	0.6	1	1	1
11/14/2022 13:00	0.4	12.5	2,154.3	0.5	0.6	1	1	1
11/14/2022 14:00	0.4	12.4	2,150.3	0.5	0.6	1	1	1
11/14/2022 15:00	0.2	12.8	2,079.7	0.4	0.6	1	1	1
11/14/2022 16:00	0.4	12.0	2,254.0	0.5	0.7	1	1	1
11/14/2022 17:00	0.4	12.3	2,198.1	0.5	0.7	1	1	1
11/14/2022 18:00	0.4	12.4	2,182.1	0.5	0.7	1	1	1
11/14/2022 19:00	0.4	12.1	2,240.9	0.5	0.7	1	1	1
11/14/2022 20:00	0.4	12.1	2,243.9	0.5	0.7	1	1	1
11/14/2022 21:00	0.5	12.0	2,288.0	0.5	0.7	1	1	1
11/14/2022 22:00	0.5	12.0	2,288.7	0.5	0.7	1	1	1
11/14/2022 23:00	0.5	12.1	2,271.0	0.5	0.7	1	1	1
Average/Sum#:	0.4	12.3	2,215.5	0.5	0.7	24 #	24 #	24 #
Minimum:	0.2	11.9	2,079.7	0.4	0.6	1	1	1
Maximum:	0.5	12.8	2,303.2	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	0.5	12.0	2,301.3	0.5	0.7	1	1	1
11/15/2022 01:00	0.5	11.9	2,300.4	0.5	0.7	1	1	1
11/15/2022 02:00	0.5	12.0	2,290.8	0.5	0.7	1	1	1
11/15/2022 03:00	0.5	12.0	2,281.4	0.5	0.7	1	1	1
11/15/2022 04:00	0.5	12.1	2,264.5	0.5	0.7	1	1	1
11/15/2022 05:00	0.4	12.2	2,243.0	0.5	0.7	1	1	1
11/15/2022 06:00	0.4	12.3	2,213.0	0.5	0.7	1	1	1
11/15/2022 07:00	0.4	12.4	2,183.3	0.5	0.7	1	1	1
11/15/2022 08:00	0.4	12.6	2,133.4	0.5	0.6	1	1	1
11/15/2022 09:00	0.4	12.7	2,108.5	0.5	0.6	1	1	1
11/15/2022 10:00	0.2	12.6	2,141.8	0.4	0.6	1	1	1
11/15/2022 11:00	0.2	12.9	2,056.8	0.4	0.6	1	1	1
11/15/2022 12:00	0.1	13.3	1,977.9	0.2	0.6	1	1	1
11/15/2022 13:00	0.1	13.3	1,979.2	0.2	0.6	1	1	1
11/15/2022 14:00	0.1	13.3	1,979.2	0.2	0.6	1	1	1
11/15/2022 15:00	0.1	13.1	2,018.4	0.2	0.6	1	1	1
11/15/2022 16:00	0.2	12.6	2,149.3	0.4	0.6	1	1	1
11/15/2022 17:00	0.2	12.5	2,177.7	0.4	0.7	1	1	1
11/15/2022 18:00	0.2	12.4	2,193.7	0.4	0.7	1	1	1
11/15/2022 19:00	0.4	12.4	2,188.4	0.5	0.7	1	1	1
11/15/2022 20:00	0.4	12.3	2,196.2	0.5	0.7	1	1	1
11/15/2022 21:00	0.5	12.1	2,244.0	0.5	0.7	1	1	1
11/15/2022 22:00	0.4	12.4	2,174.7	0.5	0.7	1	1	1
11/15/2022 23:00	0.4	12.5	2,174.2	0.5	0.7	1	1	1
Average/Sum#:	0.3	12.5	2,165.5	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,977.9	0.2	0.6	1	1	1
Maximum:	0.5	13.3	2,301.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2022 00:00	0.4	12.5	2,168.0	0.5	0.7	1	1	1
11/16/2022 01:00	0.4	12.6	2,140.8	0.5	0.6	1	1	1
11/16/2022 02:00	0.4	12.5	2,165.7	0.5	0.6	1	1	1
11/16/2022 03:00	0.4	12.5	2,167.5	0.5	0.7	1	1	1
11/16/2022 04:00	0.4	12.4	2,178.7	0.5	0.7	1	1	1
11/16/2022 05:00	0.4	12.5	2,174.9	0.5	0.7	1	1	1
11/16/2022 06:00	0.4	12.5	2,168.0	0.5	0.7	1	1	1
11/16/2022 07:00	0.5	12.2	2,241.0	0.5	0.7	1	1	1
11/16/2022 08:00	0.2	13.2	1,987.0	0.4	0.6	1	1	1
11/16/2022 09:00	0.2	13.2	2,018.8	0.4	0.6	1	1	1
11/16/2022 10:00	0.1	13.3	1,985.3	0.2	0.6	1	1	1
11/16/2022 11:00	0.7	0.0	1,986.8	0.7	0.6	1	1	1
11/16/2022 12:00	0.7	13.2	1,985.9	0.7	0.6	1	1	1
11/16/2022 13:00	0.7	13.2	1,986.9	0.7	0.6	1	1	1
11/16/2022 14:00	0.7	13.2	1,985.4	0.7	0.6	1	1	1
11/16/2022 15:00	0.7	12.6	2,113.3	0.7	0.6	1	1	1
11/16/2022 16:00	0.7	12.3	2,177.2	0.7	0.7	1	1	1
11/16/2022 17:00	0.7	12.3	2,192.8	0.7	0.7	1	1	1
11/16/2022 18:00	0.7	11.9	2,278.4	0.7	0.7	1	1	1
11/16/2022 19:00	0.7	11.9	2,286.5	0.7	0.7	1	1	1
11/16/2022 20:00	0.7	11.9	2,286.7	0.7	0.7	1	1	1
11/16/2022 21:00	0.7	12.0	2,266.9	0.7	0.7	1	1	1
11/16/2022 22:00	0.7	12.2	2,230.9	0.7	0.7	1	1	1
11/16/2022 23:00	0.7	12.0	2,257.4	0.7	0.7	1	1	1
Average/Sum#:	0.5	12.5	2,143.0	0.6	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,985.3	0.2	0.6	1	1	1
Maximum:	0.7	13.3	2,286.7	0.7	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.7	12.4	2,177.8	0.7	0.7	1	1	1
11/17/2022 01:00	0.7	12.3	2,181.0	0.7	0.7	1	1	1
11/17/2022 02:00	0.7	12.4	2,165.8	0.7	0.6	1	1	1
11/17/2022 03:00	0.7	12.5	2,166.0	0.7	0.6	1	1	1
11/17/2022 04:00	0.7	12.5	2,169.1	0.7	0.7	1	1	1
11/17/2022 05:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
11/17/2022 06:00	0.7	11.9	2,291.5	0.7	0.7	1	1	1
11/17/2022 07:00	0.7	12.4	2,182.1	0.7	0.7	1	1	1
11/17/2022 08:00	0.7	13.1	1,994.1	0.7	0.6	1	1	1
11/17/2022 09:00	0.7	12.5	2,150.8	0.7	0.6	1	1	1
11/17/2022 10:00	0.7	12.5	2,143.2	0.7	0.6	1	1	1
11/17/2022 11:00	0.7	12.3	2,174.6	0.7	0.7	1	1	1
11/17/2022 12:00	0.7	12.1	2,198.3	0.7	0.7	1	1	1
11/17/2022 13:00	0.7	12.2	2,183.9	0.7	0.7	1	1	1
11/17/2022 14:00	0.7	12.9	2,015.7	0.7	0.6	1	1	1
11/17/2022 15:00	0.7	12.4	2,130.6	0.7	0.6	1	1	1
11/17/2022 16:00	0.7	11.9	2,243.2	0.7	0.7	1	1	1
11/17/2022 17:00	0.7	11.8	2,276.9	0.7	0.7	1	1	1
11/17/2022 18:00	0.7	11.8	2,275.4	0.7	0.7	1	1	1
11/17/2022 19:00	0.7	11.8	2,278.6	0.7	0.7	1	1	1
11/17/2022 20:00	0.7	11.8	2,280.8	0.7	0.7	1	1	1
11/17/2022 21:00	0.7	11.8	2,282.5	0.7	0.7	1	1	1
11/17/2022 22:00	0.7	11.9	2,269.7	0.7	0.7	1	1	1
11/17/2022 23:00	0.7	12.2	2,226.9	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,193.3	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.8	1,994.1	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,291.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.7	12.4	2,177.7	0.7	0.7	1	1	1
11/18/2022 01:00	0.7	12.3	2,188.2	0.7	0.7	1	1	1
11/18/2022 02:00	0.7	12.2	2,194.3	0.7	0.7	1	1	1
11/18/2022 03:00	0.7	12.3	2,188.5	0.7	0.7	1	1	1
11/18/2022 04:00	0.7	12.2	2,185.6	0.7	0.7	1	1	1
11/18/2022 05:00	0.7	12.3	2,173.7	0.7	0.7	1	1	1
11/18/2022 06:00	0.7	12.4	2,160.2	0.7	0.6	1	1	1
11/18/2022 07:00	0.7	12.0	2,255.3	0.7	0.7	1	1	1
11/18/2022 08:00	0.7	12.3	2,177.7	0.7	0.7	1	1	1
11/18/2022 09:00	0.7	12.3	2,185.0	0.7	0.7	1	1	1
11/18/2022 10:00	0.7	12.2	2,190.4	0.7	0.7	1	1	1
11/18/2022 11:00	0.7	12.5	2,120.3	0.7	0.6	1	1	1
11/18/2022 12:00	0.7	13.1	1,970.2	0.7	0.6	1	1	1
11/18/2022 13:00	0.7	13.1	1,973.1	0.7	0.6	1	1	1
11/18/2022 14:00	0.7	13.1	1,974.5	0.7	0.6	1	1	1
11/18/2022 15:00	0.7	12.8	2,058.5	0.7	0.6	1	1	1
11/18/2022 16:00	0.7	12.0	2,235.0	0.7	0.7	1	1	1
11/18/2022 17:00	0.7	11.9	2,257.9	0.7	0.7	1	1	1
11/18/2022 18:00	0.7	12.0	2,260.4	0.7	0.7	1	1	1
11/18/2022 19:00	0.7	12.0	2,263.4	0.7	0.7	1	1	1
11/18/2022 20:00	0.7	12.1	2,228.1	0.7	0.7	1	1	1
11/18/2022 21:00	0.7	12.3	2,181.4	0.7	0.7	1	1	1
11/18/2022 22:00	0.7	12.5	2,145.0	0.7	0.6	1	1	1
11/18/2022 23:00	0.7	12.1	2,239.0	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,166.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.2	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,263.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.7	12.3	2,194.0	0.7	0.7	1	1	1
11/19/2022 01:00	0.7	12.4	2,172.4	0.7	0.7	1	1	1
11/19/2022 02:00	0.7	12.5	2,168.7	0.7	0.7	1	1	1
11/19/2022 03:00	0.7	12.6	2,144.8	0.7	0.6	1	1	1
11/19/2022 04:00	0.7	12.2	2,238.2	0.7	0.7	1	1	1
11/19/2022 05:00	0.7	12.1	2,271.6	0.7	0.7	1	1	1
11/19/2022 06:00	0.7	12.3	2,218.2	0.7	0.7	1	1	1
11/19/2022 07:00	0.7	12.6	2,132.0	0.7	0.6	1	1	1
11/19/2022 08:00	0.7	13.2	1,978.8	0.7	0.6	1	1	1
11/19/2022 09:00	0.7	13.2	1,978.8	0.7	0.6	1	1	1
11/19/2022 10:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
11/19/2022 11:00	0.7	13.2	1,970.6	0.7	0.6	1	1	1
11/19/2022 12:00	0.7	13.1	1,971.0	0.7	0.6	1	1	1
11/19/2022 13:00	0.7	13.1	1,971.9	0.7	0.6	1	1	1
11/19/2022 14:00	0.7	13.1	1,970.2	0.7	0.6	1	1	1
11/19/2022 15:00	0.7	12.8	2,050.9	0.7	0.6	1	1	1
11/19/2022 16:00	0.7	12.2	2,184.1	0.7	0.7	1	1	1
11/19/2022 17:00	0.7	12.1	2,201.8	0.7	0.7	1	1	1
11/19/2022 18:00	0.7	12.2	2,197.4	0.7	0.7	1	1	1
11/19/2022 19:00	0.7	11.9	2,260.7	0.7	0.7	1	1	1
11/19/2022 20:00	0.7	12.1	2,219.4	0.7	0.7	1	1	1
11/19/2022 21:00	0.7	12.3	2,177.5	0.7	0.7	1	1	1
11/19/2022 22:00	0.7	12.5	2,175.6	0.7	0.7	1	1	1
11/19/2022 23:00	0.7	12.6	2,143.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,123.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.2	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,271.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.7	12.7	2,106.9	0.7	0.6	1	1	1
11/20/2022 01:00	0.7	12.8	2,078.9	0.7	0.6	1	1	1
11/20/2022 02:00	0.7	12.9	2,062.3	0.7	0.6	1	1	1
11/20/2022 03:00	0.7	12.9	2,063.5	0.7	0.6	1	1	1
11/20/2022 04:00	0.7	12.9	2,070.5	0.7	0.6	1	1	1
11/20/2022 05:00	0.7	12.5	2,183.5	0.7	0.7	1	1	1
11/20/2022 06:00	0.7	12.1	2,276.9	0.7	0.7	1	1	1
11/20/2022 07:00	0.7	12.6	2,113.0	0.7	0.6	1	1	1
11/20/2022 08:00	0.6	13.9	1,703.8	0.6	0.5	1	1	0
11/20/2022 09:00	0.6	13.9	1,708.6	0.6	0.5	1	1	0
11/20/2022 10:00	0.6	13.9	1,565.5	0.6	0.5	1	1	0
11/20/2022 11:00	0.6	13.9	1,563.6	0.6	0.5	1	1	0
11/20/2022 12:00	0.6	14.0	1,533.4	0.6	0.5	1	1	0
11/20/2022 13:00	0.6	14.0	1,523.9	0.6	0.5	1	1	0
11/20/2022 14:00	0.7	13.8	1,701.2	0.7	0.5	1	1	1
11/20/2022 15:00	0.7	13.8	1,723.3	0.7	0.5	1	1	1
11/20/2022 16:00	0.7	12.4	2,162.3	0.7	0.6	1	1	1
11/20/2022 17:00	0.7	11.9	2,276.4	0.7	0.7	1	1	1
11/20/2022 18:00	0.7	11.9	2,265.8	0.7	0.7	1	1	1
11/20/2022 19:00	0.7	11.9	2,256.8	0.7	0.7	1	1	1
11/20/2022 20:00	0.7	11.9	2,261.0	0.7	0.7	1	1	1
11/20/2022 21:00	0.7	12.2	2,204.5	0.7	0.7	1	1	1
11/20/2022 22:00	0.7	12.4	2,168.3	0.7	0.7	1	1	1
11/20/2022 23:00	0.7	12.5	2,153.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,988.6	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,523.9	0.6	0.5	1	1	0
Maximum:	0.7	14.0	2,276.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	0.7	12.5	2,160.3	0.7	0.6	1	1	1
11/21/2022 01:00	0.7	12.6	2,137.5	0.7	0.6	1	1	1
11/21/2022 02:00	0.7	12.9	2,062.0	0.7	0.6	1	1	1
11/21/2022 03:00	0.7	12.4	2,174.4	0.7	0.7	1	1	1
11/21/2022 04:00	0.7	12.1	2,256.2	0.7	0.7	1	1	1
11/21/2022 05:00	0.7	12.1	2,267.1	0.7	0.7	1	1	1
11/21/2022 06:00	0.7	12.0	2,284.1	0.7	0.7	1	1	1
11/21/2022 07:00	0.7	12.5	2,150.4	0.7	0.6	1	1	1
11/21/2022 08:00	0.7	13.3	1,968.4	0.7	0.6	1	1	1
11/21/2022 09:00	0.7	13.3	1,968.7	0.7	0.6	1	1	1
11/21/2022 10:00	0.7	13.2	1,969.1	0.7	0.6	1	1	1
11/21/2022 11:00	0.7	13.2	1,979.0	0.7	0.6	1	1	1
11/21/2022 12:00	0.7	13.1	1,980.5	0.7	0.6	1	1	1
11/21/2022 13:00	0.7	13.1	1,980.3	0.7	0.6	1	1	1
11/21/2022 14:00	0.7	12.3	2,160.9	0.7	0.6	1	1	1
11/21/2022 15:00	0.7	11.9	2,251.4	0.7	0.7	1	1	1
11/21/2022 16:00	0.7	12.1	2,226.7	0.7	0.7	1	1	1
11/21/2022 17:00	0.7	11.9	2,273.3	0.7	0.7	1	1	1
11/21/2022 18:00	0.7	12.0	2,283.4	0.7	0.7	1	1	1
11/21/2022 19:00	0.7	11.9	2,265.1	0.7	0.7	1	1	1
11/21/2022 20:00	0.7	11.9	2,265.4	0.7	0.7	1	1	1
11/21/2022 21:00	0.7	11.9	2,267.8	0.7	0.7	1	1	1
11/21/2022 22:00	0.7	11.9	2,264.5	0.7	0.7	1	1	1
11/21/2022 23:00	0.7	12.1	2,228.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,159.4	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,968.4	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,284.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	0.7	12.4	2,154.9	0.7	0.6	1	1	1
11/22/2022 01:00	0.7	12.6	2,130.2	0.7	0.6	1	1	1
11/22/2022 02:00	0.7	12.7	2,101.3	0.7	0.6	1	1	1
11/22/2022 03:00	0.7	13.1	1,980.1	0.7	0.6	1	1	1
11/22/2022 04:00	0.7	13.2	1,985.4	0.7	0.6	1	1	1
11/22/2022 05:00	0.7	12.8	2,071.1	0.7	0.6	1	1	1
11/22/2022 06:00	0.7	12.5	2,156.2	0.7	0.6	1	1	1
11/22/2022 07:00	0.7	12.8	2,097.2	0.7	0.6	1	1	1
11/22/2022 08:00	0.7	12.9	2,055.9	0.7	0.6	1	1	1
11/22/2022 09:00	0.7	13.8	1,648.0	0.7	0.5	1	1	1
11/22/2022 10:00	0.6	13.8	1,674.5	0.6	0.5	1	1	0
11/22/2022 11:00	0.6	13.9	1,795.0	0.6	0.5	1	1	0
11/22/2022 12:00	0.6	13.9	1,556.4	0.6	0.5	1	1	0
11/22/2022 13:00	0.6	13.9	1,617.1	0.6	0.5	1	1	0
11/22/2022 14:00	0.6	13.8	1,779.5	0.6	0.5	1	1	0
11/22/2022 15:00	0.6	13.8	1,781.6	0.6	0.5	1	1	0
11/22/2022 16:00	0.7	13.2	1,919.5	0.7	0.6	1	1	1
11/22/2022 17:00	0.7	12.3	2,191.5	0.7	0.7	1	1	1
11/22/2022 18:00	0.7	12.8	2,055.9	0.7	0.6	1	1	1
11/22/2022 19:00	0.7	13.1	1,999.0	0.7	0.6	1	1	1
11/22/2022 20:00	0.7	12.5	2,155.9	0.7	0.6	1	1	1
11/22/2022 21:00	0.7	12.9	2,034.0	0.7	0.6	1	1	1
11/22/2022 22:00	0.7	12.9	2,045.3	0.7	0.6	1	1	1
11/22/2022 23:00	0.7	13.2	1,973.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,956.6	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.3	1,556.4	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,191.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	0.7	13.2	1,974.3	0.7	0.6	1	1	1
11/23/2022 01:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
11/23/2022 02:00	0.7	13.2	1,973.8	0.7	0.6	1	1	1
11/23/2022 03:00	0.7	13.2	1,976.4	0.7	0.6	1	1	1
11/23/2022 04:00	0.7	13.2	1,982.4	0.7	0.6	1	1	1
11/23/2022 05:00	0.7	12.7	2,074.5	0.7	0.6	1	1	1
11/23/2022 06:00	0.7	12.7	2,056.8	0.7	0.6	1	1	1
11/23/2022 07:00	0.7	12.7	2,111.0	0.7	0.6	1	1	1
11/23/2022 08:00	0.7	13.0	2,004.8	0.7	0.6	1	1	1
11/23/2022 09:00	0.6	13.9	1,703.0	0.6	0.5	1	1	0
11/23/2022 10:00	0.6	13.9	1,554.3	0.6	0.5	1	1	0
11/23/2022 11:00	0.6	13.9	1,550.6	0.6	0.5	1	1	0
11/23/2022 12:00	0.6	14.0	1,422.8	0.6	0.4	1	1	0
11/23/2022 13:00	0.6	14.0	1,559.1	0.6	0.5	1	1	0
11/23/2022 14:00	0.6	14.0	1,630.2	0.6	0.5	1	1	0
11/23/2022 15:00	0.7	13.9	1,636.5	0.7	0.5	1	1	1
11/23/2022 16:00	0.5	12.6	2,110.6	0.5	0.6	1	1	1
11/23/2022 17:00	0.7	12.3	2,185.3	0.7	0.7	1	1	1
11/23/2022 18:00	0.7	12.7	2,100.4	0.7	0.6	1	1	1
11/23/2022 19:00	0.5	12.9	2,063.5	0.5	0.6	1	1	1
11/23/2022 20:00	0.7	12.3	2,182.9	0.7	0.7	1	1	1
11/23/2022 21:00	0.7	12.3	2,201.9	0.7	0.7	1	1	1
11/23/2022 22:00	0.7	12.4	2,176.3	0.7	0.7	1	1	1
11/23/2022 23:00	0.7	12.4	2,171.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	13.1	1,932.4	0.7	0.6	24 #	24 #	18 #
Minimum:	0.5	12.3	1,422.8	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,201.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	0.5	13.1	1,990.6	0.5	0.6	1	1	1
11/24/2022 01:00	0.4	13.2	1,976.9	0.4	0.6	1	1	1
11/24/2022 02:00	0.4	13.2	1,976.7	0.4	0.6	1	1	1
11/24/2022 03:00	0.7	13.1	2,019.5	0.7	0.6	1	1	1
11/24/2022 04:00	0.5	13.0	2,026.8	0.5	0.6	1	1	1
11/24/2022 05:00	0.7	12.8	2,102.0	0.7	0.6	1	1	1
11/24/2022 06:00	0.7	12.2	2,191.0	0.7	0.7	1	1	1
11/24/2022 07:00	0.7	12.5	2,097.3	0.7	0.6	1	1	1
11/24/2022 08:00	0.6	13.9	1,712.8	0.6	0.5	1	1	0
11/24/2022 09:00	0.6	13.9	1,696.5	0.6	0.5	1	1	0
11/24/2022 10:00	0.6	13.9	1,703.7	0.6	0.5	1	1	0
11/24/2022 11:00	0.6	14.0	1,549.0	0.6	0.5	1	1	0
11/24/2022 12:00	0.6	14.0	1,349.8	0.6	0.4	1	1	0
11/24/2022 13:00	0.6	14.0	1,345.2	0.6	0.4	1	1	0
11/24/2022 14:00	0.6	14.0	1,551.3	0.6	0.5	1	1	0
11/24/2022 15:00	0.6	14.0	1,440.8	0.6	0.4	1	1	0
11/24/2022 16:00	0.6	13.9	1,756.8	0.6	0.5	1	1	0
11/24/2022 17:00	0.6	13.9	1,755.3	0.6	0.5	1	1	0
11/24/2022 18:00	0.6	13.9	1,738.1	0.6	0.5	1	1	0
11/24/2022 19:00	0.6	13.9	1,735.7	0.6	0.5	1	1	0
11/24/2022 20:00	0.6	13.9	1,736.2	0.6	0.5	1	1	0
11/24/2022 21:00	0.6	13.9	1,739.4	0.6	0.5	1	1	0
11/24/2022 22:00	0.6	13.9	1,742.8	0.6	0.5	1	1	0
11/24/2022 23:00	0.6	13.9	1,744.5	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.6	1,778.3	0.6	0.5	24 #	24 #	8 #
Minimum:	0.4	12.2	1,345.2	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,191.0	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.6	13.9	1,746.5	0.6	0.5	1	1	0
11/25/2022 01:00	0.6	13.9	1,746.8	0.6	0.5	1	1	0
11/25/2022 02:00	0.6	13.9	1,749.6	0.6	0.5	1	1	0
11/25/2022 03:00	0.6	13.9	1,753.4	0.6	0.5	1	1	0
11/25/2022 04:00	0.6	13.9	1,763.9	0.6	0.5	1	1	0
11/25/2022 05:00	0.6	13.9	1,761.2	0.6	0.5	1	1	0
11/25/2022 06:00	0.6	13.9	1,755.3	0.6	0.5	1	1	0
11/25/2022 07:00	0.6	13.9	1,755.9	0.6	0.5	1	1	0
11/25/2022 08:00	0.7	13.5	1,878.1	0.7	0.6	1	1	1
11/25/2022 09:00	0.7	13.2	1,927.0	0.7	0.6	1	1	1
11/25/2022 10:00	0.6	13.9	1,661.2	0.6	0.5	1	1	0
11/25/2022 11:00	0.6	13.9	1,538.8	0.6	0.5	1	1	0
11/25/2022 12:00	0.6	13.9	1,565.4	0.6	0.5	1	1	0
11/25/2022 13:00	0.6	13.9	1,534.3	0.6	0.5	1	1	0
11/25/2022 14:00	0.6	13.9	1,521.7	0.6	0.5	1	1	0
11/25/2022 15:00	0.7	13.8	1,630.3	0.7	0.5	1	1	1
11/25/2022 16:00	0.5	12.6	2,098.5	0.5	0.6	1	1	1
11/25/2022 17:00	0.7	12.5	2,115.1	0.7	0.6	1	1	1
11/25/2022 18:00	0.7	13.1	1,976.4	0.7	0.6	1	1	1
11/25/2022 19:00	0.7	13.2	1,966.1	0.7	0.6	1	1	1
11/25/2022 20:00	0.7	13.2	1,974.0	0.7	0.6	1	1	1
11/25/2022 21:00	0.7	13.2	1,977.2	0.7	0.6	1	1	1
11/25/2022 22:00	0.7	12.6	2,131.7	0.7	0.6	1	1	1
11/25/2022 23:00	0.7	12.7	2,091.1	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,817.5	0.6	0.5	24 #	24 #	11 #
Minimum:	0.5	12.5	1,521.7	0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,131.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	0.7	13.0	2,033.3	0.7	0.6	1	1	1
11/26/2022 01:00	0.7	12.8	2,080.1	0.7	0.6	1	1	1
11/26/2022 02:00	0.0	13.9	1,574.8	0.0	0.5	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.2	1,896.1	0.5	0.6	3 #	2 #	3 #
Minimum:	0.0	12.8	1,574.8	0.0	0.5	0	0	0
Maximum:	0.7	13.9	2,080.1	0.7	0.6	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	17.7	330.2	0.0	0.1	1	0	0
11/27/2022 22:00	0.0	17.3	396.9	0.0	0.1	1	0	0
11/27/2022 23:00	0.0	15.5	901.6	0.0	0.3	1	0	0
Average/Sum#:	0.0	16.8	542.9	0.0	0.2	3 #	0 #	0 #
Minimum:	0.0	15.5	330.2	0.0	0.1	0	0	0
Maximum:	0.0	17.7	901.6	0.0	0.3	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.6	13.9	1,574.9	0.6	0.5	1	1	0
11/28/2022 01:00	0.6	13.9	1,487.8	0.6	0.4	1	1	0
11/28/2022 02:00	0.6	13.8	1,745.5	0.6	0.5	1	1	0
11/28/2022 03:00	0.6	13.9	1,530.8	0.6	0.5	1	1	0
11/28/2022 04:00	0.6	13.9	1,710.5	0.6	0.5	1	1	0
11/28/2022 05:00	0.7	13.8	1,642.2	0.7	0.5	1	1	1
11/28/2022 06:00	0.7	12.3	2,173.2	0.7	0.7	1	1	1
11/28/2022 07:00	0.7	12.0	2,270.2	0.7	0.7	1	1	1
11/28/2022 08:00	0.7	13.1	1,972.1	0.7	0.6	1	1	1
11/28/2022 09:00	0.6	13.9	1,601.7	0.6	0.5	1	1	0
11/28/2022 10:00	0.6	13.9	1,699.0	0.6	0.5	1	1	0
11/28/2022 11:00	0.6	13.9	1,519.7	0.6	0.5	1	1	0
11/28/2022 12:00	0.6	13.9	1,566.4	0.6	0.5	1	1	0
11/28/2022 13:00	0.6	13.9	1,634.0	0.6	0.5	1	1	0
11/28/2022 14:00	0.6	13.9	1,616.9	0.6	0.5	1	1	0
11/28/2022 15:00	0.7	13.8	1,620.0	0.7	0.5	1	1	1
11/28/2022 16:00	0.7	12.8	2,041.1	0.7	0.6	1	1	1
11/28/2022 17:00	0.7	12.6	2,100.3	0.7	0.6	1	1	1
11/28/2022 18:00	0.7	13.1	1,988.5	0.7	0.6	1	1	1
11/28/2022 19:00	0.7	13.2	1,967.8	0.7	0.6	1	1	1
11/28/2022 20:00	0.7	12.7	2,094.0	0.7	0.6	1	1	1
11/28/2022 21:00	0.7	12.1	2,238.4	0.7	0.7	1	1	1
11/28/2022 22:00	0.7	12.7	2,095.4	0.7	0.6	1	1	1
11/28/2022 23:00	0.7	13.1	1,996.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.3	1,828.6	0.7	0.6	24 #	24 #	13 #
Minimum:	0.6	12.0	1,487.8	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,270.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.7	12.5	2,165.2	0.7	0.6	1	1	1
11/29/2022 01:00	0.7	12.3	2,212.8	0.7	0.7	1	1	1
11/29/2022 02:00	0.7	12.4	2,192.2	0.7	0.7	1	1	1
11/29/2022 03:00	0.7	12.8	2,088.0	0.7	0.6	1	1	1
11/29/2022 04:00	0.7	12.5	2,152.8	0.7	0.6	1	1	1
11/29/2022 05:00	0.7	12.4	2,205.6	0.7	0.7	1	1	1
11/29/2022 06:00	0.7	11.9	2,296.9	0.7	0.7	1	1	1
11/29/2022 07:00	0.7	11.9	2,304.2	0.7	0.7	1	1	1
11/29/2022 08:00	0.7	12.0	2,274.9	0.7	0.7	1	1	1
11/29/2022 09:00	0.7	12.4	2,174.5	0.7	0.7	1	1	1
11/29/2022 10:00	0.7	12.4	2,167.1	0.7	0.7	1	1	1
11/29/2022 11:00	0.7	12.4	2,157.9	0.7	0.6	1	1	1
11/29/2022 12:00	0.7	12.4	2,151.2	0.7	0.6	1	1	1
11/29/2022 13:00	0.7	12.4	2,151.4	0.7	0.6	1	1	1
11/29/2022 14:00	0.7	12.4	2,156.0	0.7	0.6	1	1	1
11/29/2022 15:00	0.7	12.3	2,170.6	0.7	0.7	1	1	1
11/29/2022 16:00	0.7	11.9	2,281.5	0.7	0.7	1	1	1
11/29/2022 17:00	0.7	11.9	2,289.6	0.7	0.7	1	1	1
11/29/2022 18:00	0.7	11.9	2,292.8	0.7	0.7	1	1	1
11/29/2022 19:00	0.7	11.9	2,290.5	0.7	0.7	1	1	1
11/29/2022 20:00	0.7	12.0	2,289.3	0.7	0.7	1	1	1
11/29/2022 21:00	0.7	11.9	2,292.2	0.7	0.7	1	1	1
11/29/2022 22:00	0.7	12.0	2,297.8	0.7	0.7	1	1	1
11/29/2022 23:00	0.7	12.0	2,296.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,223.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	2,088.0	0.7	0.6	1	1	1
Maximum:	0.7	12.8	2,304.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	0.7	12.6	2,170.7	0.7	0.7	1	1	1
11/30/2022 01:00	0.7	12.6	2,153.2	0.7	0.6	1	1	1
11/30/2022 02:00	0.7	12.6	2,153.8	0.7	0.6	1	1	1
11/30/2022 03:00	0.7	12.6	2,151.0	0.7	0.6	1	1	1
11/30/2022 04:00	0.7	12.6	2,169.6	0.7	0.7	1	1	1
11/30/2022 05:00	0.7	12.6	2,169.3	0.7	0.7	1	1	1
11/30/2022 06:00	0.7	12.1	2,268.0	0.7	0.7	1	1	1
11/30/2022 07:00	0.7	12.6	2,158.0	0.7	0.6	1	1	1
11/30/2022 08:00	0.5	13.3	1,984.3	0.5	0.6	1	1	1
11/30/2022 09:00	0.5	13.2	1,998.7	0.5	0.6	1	1	1
11/30/2022 10:00	0.5	13.2	1,980.3	0.5	0.6	1	1	1
11/30/2022 11:00	0.5	13.2	1,984.1	0.5	0.6	1	1	1
11/30/2022 12:00	0.5	13.2	1,983.8	0.5	0.6	1	1	1
11/30/2022 13:00	0.7	13.1	1,978.8	0.7	0.6	1	1	1
11/30/2022 14:00	0.7	12.5	2,132.5	0.7	0.6	1	1	1
11/30/2022 15:00	0.7	12.4	2,140.8	0.7	0.6	1	1	1
11/30/2022 16:00	0.7	11.9	2,251.8	0.7	0.7	1	1	1
11/30/2022 17:00	0.7	11.7	2,297.3	0.7	0.7	1	1	1
11/30/2022 18:00	0.7	11.8	2,289.4	0.7	0.7	1	1	1
11/30/2022 19:00	0.7	11.8	2,289.6	0.7	0.7	1	1	1
11/30/2022 20:00	0.7	11.8	2,288.9	0.7	0.7	1	1	1
11/30/2022 21:00	0.7	12.0	2,256.6	0.7	0.7	1	1	1
11/30/2022 22:00	0.7	12.6	2,106.9	0.7	0.6	1	1	1
11/30/2022 23:00	0.0	13.8	1,590.5	0.0	0.5	1	0	1
Average/Sum#:	0.6	12.6	2,122.8	0.6	0.6	24 #	23 #	24 #
Minimum:	0.0	11.7	1,590.5	0.0	0.5	1	0	1
Maximum:	0.7	13.8	2,297.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	17.9	301.9	0.0	0.1	1	0	0
12/01/2022 03:00	0.0	14.8	1,144.0	0.0	0.3	1	0	0
12/01/2022 04:00	0.6	13.8	1,703.6	0.6	0.5	1	1	0
12/01/2022 05:00	0.7	13.5	1,790.5	0.7	0.5	1	1	1
12/01/2022 06:00	0.7	11.7	2,291.0	0.7	0.7	1	1	1
12/01/2022 07:00	0.7	11.6	2,326.9	0.7	0.7	1	1	1
12/01/2022 08:00	0.7	12.1	2,203.6	0.7	0.7	1	1	1
12/01/2022 09:00	0.7	12.2	2,190.4	0.7	0.7	1	1	1
12/01/2022 10:00	0.7	12.2	2,195.3	0.7	0.7	1	1	1
12/01/2022 11:00	0.7	12.3	2,173.6	0.7	0.7	1	1	1
12/01/2022 12:00	0.7	12.2	2,176.8	0.7	0.7	1	1	1
12/01/2022 13:00	0.7	12.2	2,177.9	0.7	0.7	1	1	1
12/01/2022 14:00	0.7	12.1	2,192.3	0.7	0.7	1	1	1
12/01/2022 15:00	0.7	11.6	2,311.4	0.7	0.7	1	1	1
12/01/2022 16:00	0.7	11.6	2,338.6	0.7	0.7	1	1	1
12/01/2022 17:00	0.7	11.6	2,347.2	0.7	0.7	1	1	1
12/01/2022 18:00	0.7	11.6	2,335.6	0.7	0.7	1	1	1
12/01/2022 19:00	0.7	11.7	2,345.2	0.7	0.7	1	1	1
12/01/2022 20:00	0.7	11.7	2,349.1	0.7	0.7	1	1	1
12/01/2022 21:00	0.7	11.8	2,324.3	0.7	0.7	1	1	1
12/01/2022 22:00	0.7	12.4	2,184.7	0.7	0.7	1	1	1
12/01/2022 23:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
Average/Sum#:	0.6	12.5	2,072.1	0.6	0.6	22 #	20 #	19 #
Minimum:	0.0	11.6	301.9	0.0	0.1	0	0	0
Maximum:	0.7	17.9	2,349.1	0.7	0.7	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.7	12.4	2,181.7	0.7	0.7	1	1	1
12/02/2022 01:00	0.7	12.4	2,185.0	0.7	0.7	1	1	1
12/02/2022 02:00	0.5	12.4	2,189.6	0.5	0.7	1	1	1
12/02/2022 03:00	0.5	12.5	2,168.0	0.5	0.7	1	1	1
12/02/2022 04:00	0.5	12.5	2,177.5	0.5	0.7	1	1	1
12/02/2022 05:00	0.5	12.5	2,174.2	0.5	0.7	1	1	1
12/02/2022 06:00	0.7	12.0	2,312.0	0.7	0.7	1	1	1
12/02/2022 07:00	0.7	11.9	2,323.5	0.7	0.7	1	1	1
12/02/2022 08:00	0.7	12.0	2,321.3	0.7	0.7	1	1	1
12/02/2022 09:00	0.5	12.4	2,196.4	0.5	0.7	1	1	1
12/02/2022 10:00	0.5	12.4	2,196.5	0.5	0.7	1	1	1
12/02/2022 11:00	0.7	12.3	2,214.2	0.7	0.7	1	1	1
12/02/2022 12:00	0.7	12.3	2,217.5	0.7	0.7	1	1	1
12/02/2022 13:00	0.7	12.3	2,208.5	0.7	0.7	1	1	1
12/02/2022 14:00	0.7	12.3	2,186.0	0.7	0.7	1	1	1
12/02/2022 15:00	0.7	11.9	2,306.4	0.7	0.7	1	1	1
12/02/2022 16:00	0.7	11.7	2,337.6	0.7	0.7	1	1	1
12/02/2022 17:00	0.7	11.8	2,328.6	0.7	0.7	1	1	1
12/02/2022 18:00	0.7	11.9	2,318.8	0.7	0.7	1	1	1
12/02/2022 19:00	0.7	11.9	2,324.2	0.7	0.7	1	1	1
12/02/2022 20:00	0.7	11.9	2,321.7	0.7	0.7	1	1	1
12/02/2022 21:00	0.7	11.9	2,315.9	0.7	0.7	1	1	1
12/02/2022 22:00	0.7	11.9	2,313.3	0.7	0.7	1	1	1
12/02/2022 23:00	0.7	11.9	2,317.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.1	2,255.7	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.7	2,168.0	0.5	0.7	1	1	1
Maximum:	0.7	12.5	2,337.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.7	12.0	2,310.3	0.7	0.7	1	1	1
12/03/2022 01:00	0.7	12.0	2,318.6	0.7	0.7	1	1	1
12/03/2022 02:00	0.7	11.9	2,322.5	0.7	0.7	1	1	1
12/03/2022 03:00	0.7	11.9	2,322.3	0.7	0.7	1	1	1
12/03/2022 04:00	0.7	11.9	2,317.9	0.7	0.7	1	1	1
12/03/2022 05:00	0.7	11.9	2,321.6	0.7	0.7	1	1	1
12/03/2022 06:00	0.7	11.9	2,325.5	0.7	0.7	1	1	1
12/03/2022 07:00	0.7	11.8	2,334.4	0.7	0.7	1	1	1
12/03/2022 08:00	0.7	11.9	2,328.6	0.7	0.7	1	1	1
12/03/2022 09:00	0.7	11.8	2,330.7	0.7	0.7	1	1	1
12/03/2022 10:00	0.7	11.9	2,311.2	0.7	0.7	1	1	1
12/03/2022 11:00	0.7	12.0	2,279.7	0.7	0.7	1	1	1
12/03/2022 12:00	0.7	11.9	2,308.6	0.7	0.7	1	1	1
12/03/2022 13:00	0.7	12.3	2,197.2	0.7	0.7	1	1	1
12/03/2022 14:00	0.5	12.4	2,185.4	0.5	0.7	1	1	1
12/03/2022 15:00	0.7	11.9	2,313.0	0.7	0.7	1	1	1
12/03/2022 16:00	0.7	11.7	2,334.9	0.7	0.7	1	1	1
12/03/2022 17:00	0.7	11.8	2,325.1	0.7	0.7	1	1	1
12/03/2022 18:00	0.7	11.8	2,312.8	0.7	0.7	1	1	1
12/03/2022 19:00	0.7	11.8	2,316.1	0.7	0.7	1	1	1
12/03/2022 20:00	0.7	11.7	2,329.1	0.7	0.7	1	1	1
12/03/2022 21:00	0.7	11.7	2,344.0	0.7	0.7	1	1	1
12/03/2022 22:00	0.7	11.7	2,350.9	0.7	0.7	1	1	1
12/03/2022 23:00	0.7	11.7	2,342.1	0.7	0.7	1	1	1
Average/Sum#:	0.7	11.9	2,311.8	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.7	2,185.4	0.5	0.7	1	1	1
Maximum:	0.7	12.4	2,350.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.7	12.3	2,200.3	0.7	0.7	1	1	1
12/04/2022 01:00	0.7	12.3	2,203.9	0.7	0.7	1	1	1
12/04/2022 02:00	0.7	12.3	2,208.7	0.7	0.7	1	1	1
12/04/2022 03:00	0.5	12.3	2,200.4	0.5	0.7	1	1	1
12/04/2022 04:00	0.7	12.3	2,211.5	0.7	0.7	1	1	1
12/04/2022 05:00	0.7	12.3	2,202.2	0.7	0.7	1	1	1
12/04/2022 06:00	0.7	11.8	2,326.8	0.7	0.7	1	1	1
12/04/2022 07:00	0.7	11.7	2,339.1	0.7	0.7	1	1	1
12/04/2022 08:00	0.7	12.3	2,214.8	0.7	0.7	1	1	1
12/04/2022 09:00	0.5	12.3	2,191.3	0.5	0.7	1	1	1
12/04/2022 10:00	0.7	12.2	2,206.1	0.7	0.7	1	1	1
12/04/2022 11:00	0.7	12.2	2,206.4	0.7	0.7	1	1	1
12/04/2022 12:00	0.7	12.1	2,197.7	0.7	0.7	1	1	1
12/04/2022 13:00	0.7	12.1	2,193.2	0.7	0.7	1	1	1
12/04/2022 14:00	0.7	12.1	2,207.4	0.7	0.7	1	1	1
12/04/2022 15:00	0.7	12.1	2,194.8	0.7	0.7	1	1	1
12/04/2022 16:00	0.7	11.6	2,322.7	0.7	0.7	1	1	1
12/04/2022 17:00	0.7	11.6	2,338.7	0.7	0.7	1	1	1
12/04/2022 18:00	0.7	11.6	2,323.4	0.7	0.7	1	1	1
12/04/2022 19:00	0.7	11.7	2,320.9	0.7	0.7	1	1	1
12/04/2022 20:00	0.7	11.7	2,321.9	0.7	0.7	1	1	1
12/04/2022 21:00	0.7	11.7	2,322.9	0.7	0.7	1	1	1
12/04/2022 22:00	0.7	11.8	2,311.7	0.7	0.7	1	1	1
12/04/2022 23:00	0.7	12.3	2,192.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.0	2,248.3	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.6	2,191.3	0.5	0.7	1	1	1
Maximum:	0.7	12.3	2,339.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.7	12.3	2,194.3	0.7	0.7	1	1	1
12/05/2022 01:00	0.7	12.3	2,191.4	0.7	0.7	1	1	1
12/05/2022 02:00	0.7	12.3	2,196.4	0.7	0.7	1	1	1
12/05/2022 03:00	0.7	12.3	2,190.0	0.7	0.7	1	1	1
12/05/2022 04:00	0.7	12.2	2,215.9	0.7	0.7	1	1	1
12/05/2022 05:00	0.7	11.8	2,320.8	0.7	0.7	1	1	1
12/05/2022 06:00	0.7	11.6	2,344.1	0.7	0.7	1	1	1
12/05/2022 07:00	0.7	11.7	2,340.6	0.7	0.7	1	1	1
12/05/2022 08:00	0.7	11.6	2,351.7	0.7	0.7	1	1	1
12/05/2022 09:00	0.7	11.5	2,366.0	0.7	0.7	1	1	1
12/05/2022 10:00	0.7	11.9	2,141.8	0.7	0.6	1	1	1
12/05/2022 11:00	0.7	13.2	1,826.8	0.7	0.5	1	1	1
12/05/2022 12:00	0.7	12.2	2,161.8	0.7	0.6	1	1	1
12/05/2022 13:00	0.7	12.8	2,027.0	0.7	0.6	1	1	1
12/05/2022 14:00	0.7	12.7	2,056.5	0.7	0.6	1	1	1
12/05/2022 15:00	0.7	12.6	2,074.4	0.7	0.6	1	1	1
12/05/2022 16:00	0.7	12.0	2,222.7	0.7	0.7	1	1	1
12/05/2022 17:00	0.7	11.7	2,298.0	0.7	0.7	1	1	1
12/05/2022 18:00	0.7	11.7	2,298.7	0.7	0.7	1	1	1
12/05/2022 19:00	0.7	11.8	2,302.3	0.7	0.7	1	1	1
12/05/2022 20:00	0.7	11.8	2,299.3	0.7	0.7	1	1	1
12/05/2022 21:00	0.7	12.1	2,221.1	0.7	0.7	1	1	1
12/05/2022 22:00	0.7	12.7	2,074.3	0.7	0.6	1	1	1
12/05/2022 23:00	0.7	12.8	2,049.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.2	2,198.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.5	1,826.8	0.7	0.5	1	1	1
Maximum:	0.7	13.2	2,366.0	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	0.7	13.2	1,968.4	0.7	0.6	1	1	1
12/06/2022 01:00	0.7	13.2	1,968.0	0.7	0.6	1	1	1
12/06/2022 02:00	0.5	13.2	1,968.0	0.5	0.6	1	1	1
12/06/2022 03:00	0.5	13.2	1,969.4	0.5	0.6	1	1	1
12/06/2022 04:00	0.7	13.1	1,984.1	0.7	0.6	1	1	1
12/06/2022 05:00	0.7	13.0	2,012.5	0.7	0.6	1	1	1
12/06/2022 06:00	0.7	13.1	1,985.5	0.7	0.6	1	1	1
12/06/2022 07:00	0.7	12.7	2,090.5	0.7	0.6	1	1	1
12/06/2022 08:00	0.7	11.9	2,283.2	0.7	0.7	1	1	1
12/06/2022 09:00	0.7	12.0	2,270.7	0.7	0.7	1	1	1
12/06/2022 10:00	0.7	12.0	2,264.3	0.7	0.7	1	1	1
12/06/2022 11:00	0.7	12.0	2,260.4	0.7	0.7	1	1	1
12/06/2022 12:00	0.7	12.0	2,241.0	0.7	0.7	1	1	1
12/06/2022 13:00	0.7	13.7	1,779.8	0.7	0.5	1	1	1
12/06/2022 14:00	0.6	14.0	1,314.5	0.6	0.4	1	1	0
12/06/2022 15:00	0.6	14.0	1,314.1	0.6	0.4	1	1	0
12/06/2022 16:00	0.6	13.9	1,512.4	0.6	0.5	1	1	0
12/06/2022 17:00	0.6	13.8	1,808.0	0.6	0.5	1	1	0
12/06/2022 18:00	0.6	13.8	1,807.8	0.6	0.5	1	1	0
12/06/2022 19:00	0.7	13.8	1,817.6	0.7	0.5	1	1	1
12/06/2022 20:00	0.7	12.5	2,137.3	0.7	0.6	1	1	1
12/06/2022 21:00	0.7	12.1	2,235.9	0.7	0.7	1	1	1
12/06/2022 22:00	0.7	12.6	2,105.7	0.7	0.6	1	1	1
12/06/2022 23:00	0.7	13.2	1,973.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,961.3	0.7	0.6	24 #	24 #	19 #
Minimum:	0.5	11.9	1,314.1	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,283.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.7	12.7	2,084.1	0.7	0.6	1	1	1
12/07/2022 01:00	0.7	13.1	1,990.9	0.7	0.6	1	1	1
12/07/2022 02:00	0.7	12.6	2,139.0	0.7	0.6	1	1	1
12/07/2022 03:00	0.7	12.5	2,147.2	0.7	0.6	1	1	1
12/07/2022 04:00	0.7	12.5	2,164.6	0.7	0.6	1	1	1
12/07/2022 05:00	0.7	12.4	2,173.1	0.7	0.7	1	1	1
12/07/2022 06:00	0.7	12.1	2,253.6	0.7	0.7	1	1	1
12/07/2022 07:00	0.7	12.1	2,265.4	0.7	0.7	1	1	1
12/07/2022 08:00	0.7	12.6	2,137.8	0.7	0.6	1	1	1
12/07/2022 09:00	0.7	12.5	2,172.2	0.7	0.7	1	1	1
12/07/2022 10:00	0.7	12.5	2,171.5	0.7	0.7	1	1	1
12/07/2022 11:00	0.7	12.5	2,169.0	0.7	0.7	1	1	1
12/07/2022 12:00	0.7	12.5	2,144.8	0.7	0.6	1	1	1
12/07/2022 13:00	0.7	12.5	2,120.6	0.7	0.6	1	1	1
12/07/2022 14:00	0.7	12.8	2,065.4	0.7	0.6	1	1	1
12/07/2022 15:00	0.7	12.7	2,088.9	0.7	0.6	1	1	1
12/07/2022 16:00	0.7	12.0	2,262.1	0.7	0.7	1	1	1
12/07/2022 17:00	0.7	11.9	2,276.0	0.7	0.7	1	1	1
12/07/2022 18:00	0.7	11.9	2,279.2	0.7	0.7	1	1	1
12/07/2022 19:00	0.7	11.9	2,277.8	0.7	0.7	1	1	1
12/07/2022 20:00	0.7	11.9	2,278.1	0.7	0.7	1	1	1
12/07/2022 21:00	0.7	12.0	2,272.8	0.7	0.7	1	1	1
12/07/2022 22:00	0.7	12.4	2,185.4	0.7	0.7	1	1	1
12/07/2022 23:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,179.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,990.9	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,279.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.7	12.6	2,140.3	0.7	0.6	1	1	1
12/08/2022 01:00	0.7	12.6	2,134.5	0.7	0.6	1	1	1
12/08/2022 02:00	0.7	12.6	2,131.2	0.7	0.6	1	1	1
12/08/2022 03:00	0.7	12.7	2,128.7	0.7	0.6	1	1	1
12/08/2022 04:00	0.7	12.6	2,153.6	0.7	0.6	1	1	1
12/08/2022 05:00	0.7	12.4	2,211.4	0.7	0.7	1	1	1
12/08/2022 06:00	0.7	12.0	2,286.3	0.7	0.7	1	1	1
12/08/2022 07:00	0.7	12.2	2,241.1	0.7	0.7	1	1	1
12/08/2022 08:00	0.7	13.0	2,033.7	0.7	0.6	1	1	1
12/08/2022 09:00	0.7	12.8	2,111.2	0.7	0.6	1	1	1
12/08/2022 10:00	0.7	12.7	2,119.0	0.7	0.6	1	1	1
12/08/2022 11:00	0.7	12.5	2,150.5	0.7	0.6	1	1	1
12/08/2022 12:00	0.7	12.5	2,152.8	0.7	0.6	1	1	1
12/08/2022 13:00	0.7	12.4	2,166.9	0.7	0.7	1	1	1
12/08/2022 14:00	0.7	12.3	2,177.4	0.7	0.7	1	1	1
12/08/2022 15:00	0.7	12.3	2,183.9	0.7	0.7	1	1	1
12/08/2022 16:00	0.7	11.9	2,283.7	0.7	0.7	1	1	1
12/08/2022 17:00	0.7	11.9	2,284.7	0.7	0.7	1	1	1
12/08/2022 18:00	0.7	11.9	2,287.5	0.7	0.7	1	1	1
12/08/2022 19:00	0.7	11.9	2,285.8	0.7	0.7	1	1	1
12/08/2022 20:00	0.7	11.9	2,287.4	0.7	0.7	1	1	1
12/08/2022 21:00	0.7	11.9	2,285.0	0.7	0.7	1	1	1
12/08/2022 22:00	0.7	12.3	2,194.3	0.7	0.7	1	1	1
12/08/2022 23:00	0.7	12.3	2,195.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.3	2,192.8	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	2,033.7	0.7	0.6	1	1	1
Maximum:	0.7	13.0	2,287.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	0.7	12.5	2,144.3	0.7	0.6	1	1	1
12/09/2022 01:00	0.7	12.9	2,046.2	0.7	0.6	1	1	1
12/09/2022 02:00	0.7	12.6	2,142.3	0.7	0.6	1	1	1
12/09/2022 03:00	0.7	12.6	2,144.2	0.7	0.6	1	1	1
12/09/2022 04:00	0.7	12.4	2,194.9	0.7	0.7	1	1	1
12/09/2022 05:00	0.7	12.0	2,296.2	0.7	0.7	1	1	1
12/09/2022 06:00	0.7	12.0	2,298.6	0.7	0.7	1	1	1
12/09/2022 07:00	0.7	12.0	2,286.8	0.7	0.7	1	1	1
12/09/2022 08:00	0.7	12.9	2,072.5	0.7	0.6	1	1	1
12/09/2022 09:00	0.7	13.0	2,032.9	0.7	0.6	1	1	1
12/09/2022 10:00	0.5	13.2	1,984.3	0.5	0.6	1	1	1
12/09/2022 11:00	0.7	12.8	2,074.2	0.7	0.6	1	1	1
12/09/2022 12:00	0.7	13.0	2,007.8	0.7	0.6	1	1	1
12/09/2022 13:00	0.7	12.4	2,160.2	0.7	0.6	1	1	1
12/09/2022 14:00	0.7	12.4	2,163.1	0.7	0.6	1	1	1
12/09/2022 15:00	0.7	12.9	2,055.6	0.7	0.6	1	1	1
12/09/2022 16:00	0.7	11.9	2,286.0	0.7	0.7	1	1	1
12/09/2022 17:00	0.7	11.9	2,285.5	0.7	0.7	1	1	1
12/09/2022 18:00	0.7	11.9	2,285.9	0.7	0.7	1	1	1
12/09/2022 19:00	0.7	11.9	2,287.2	0.7	0.7	1	1	1
12/09/2022 20:00	0.7	11.9	2,289.2	0.7	0.7	1	1	1
12/09/2022 21:00	0.7	11.9	2,287.9	0.7	0.7	1	1	1
12/09/2022 22:00	0.7	11.9	2,286.6	0.7	0.7	1	1	1
12/09/2022 23:00	0.7	11.9	2,280.4	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,183.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.9	1,984.3	0.5	0.6	1	1	1
Maximum:	0.7	13.2	2,298.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	0.7	13.0	2,020.4	0.7	0.6	1	1	1
12/10/2022 01:00	0.7	13.0	2,016.4	0.7	0.6	1	1	1
12/10/2022 02:00	0.7	13.1	1,980.5	0.7	0.6	1	1	1
12/10/2022 03:00	0.7	13.1	1,981.2	0.7	0.6	1	1	1
12/10/2022 04:00	0.7	13.1	1,976.3	0.7	0.6	1	1	1
12/10/2022 05:00	0.7	13.0	1,986.7	0.7	0.6	1	1	1
12/10/2022 06:00	0.7	13.1	1,973.6	0.7	0.6	1	1	1
12/10/2022 07:00	0.7	13.1	1,981.0	0.7	0.6	1	1	1
12/10/2022 08:00	0.7	12.9	2,021.2	0.7	0.6	1	1	1
12/10/2022 09:00	0.7	12.9	1,998.2	0.7	0.6	1	1	1
12/10/2022 10:00	0.7	13.0	1,974.5	0.7	0.6	1	1	1
12/10/2022 11:00	0.7	12.8	2,015.4	0.7	0.6	1	1	1
12/10/2022 12:00	0.7	12.4	2,121.1	0.7	0.6	1	1	1
12/10/2022 13:00	0.7	12.0	2,182.6	0.7	0.7	1	1	1
12/10/2022 14:00	0.7	12.7	2,018.0	0.7	0.6	1	1	1
12/10/2022 15:00	0.7	12.6	2,043.8	0.7	0.6	1	1	1
12/10/2022 16:00	0.7	12.4	2,112.6	0.7	0.6	1	1	1
12/10/2022 17:00	0.7	12.5	2,071.9	0.7	0.6	1	1	1
12/10/2022 18:00	0.7	12.6	2,072.8	0.7	0.6	1	1	1
12/10/2022 19:00	0.7	11.8	2,252.8	0.7	0.7	1	1	1
12/10/2022 20:00	0.7	12.2	2,175.1	0.7	0.7	1	1	1
12/10/2022 21:00	0.7	12.5	2,080.6	0.7	0.6	1	1	1
12/10/2022 22:00	0.7	12.9	2,016.0	0.7	0.6	1	1	1
12/10/2022 23:00	0.7	12.6	2,077.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	2,047.9	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,973.6	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,252.8	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	0.7	13.1	1,967.5	0.7	0.6	1	1	1
12/11/2022 01:00	0.7	13.1	1,965.0	0.7	0.6	1	1	1
12/11/2022 02:00	0.7	13.1	1,964.9	0.7	0.6	1	1	1
12/11/2022 03:00	0.7	13.1	1,965.4	0.7	0.6	1	1	1
12/11/2022 04:00	0.7	13.1	1,969.0	0.7	0.6	1	1	1
12/11/2022 05:00	0.7	13.1	1,967.8	0.7	0.6	1	1	1
12/11/2022 06:00	0.7	13.1	1,969.4	0.7	0.6	1	1	1
12/11/2022 07:00	0.7	13.2	1,972.0	0.7	0.6	1	1	1
12/11/2022 08:00	0.7	13.2	1,973.7	0.7	0.6	1	1	1
12/11/2022 09:00	0.7	13.1	1,971.0	0.7	0.6	1	1	1
12/11/2022 10:00	0.7	13.1	1,969.2	0.7	0.6	1	1	1
12/11/2022 11:00	0.7	13.1	1,966.9	0.7	0.6	1	1	1
12/11/2022 12:00	0.7	13.1	1,966.8	0.7	0.6	1	1	1
12/11/2022 13:00	0.7	13.1	1,968.3	0.7	0.6	1	1	1
12/11/2022 14:00	0.7	13.1	1,963.5	0.7	0.6	1	1	1
12/11/2022 15:00	0.7	12.7	2,060.7	0.7	0.6	1	1	1
12/11/2022 16:00	0.7	12.8	2,068.6	0.7	0.6	1	1	1
12/11/2022 17:00	0.7	12.5	2,141.4	0.7	0.6	1	1	1
12/11/2022 18:00	0.7	12.9	2,048.1	0.7	0.6	1	1	1
12/11/2022 19:00	0.7	12.8	2,066.7	0.7	0.6	1	1	1
12/11/2022 20:00	0.7	12.6	2,120.2	0.7	0.6	1	1	1
12/11/2022 21:00	0.7	13.1	2,003.0	0.7	0.6	1	1	1
12/11/2022 22:00	0.7	13.2	1,972.7	0.7	0.6	1	1	1
12/11/2022 23:00	0.7	13.2	1,974.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,999.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.5	1,963.5	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,141.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	0.7	13.2	1,981.6	0.7	0.6	1	1	1
12/12/2022 01:00	0.7	13.2	1,982.3	0.7	0.6	1	1	1
12/12/2022 02:00	0.7	13.2	1,981.4	0.7	0.6	1	1	1
12/12/2022 03:00	0.7	13.2	1,978.4	0.7	0.6	1	1	1
12/12/2022 04:00	0.7	13.2	1,977.9	0.7	0.6	1	1	1
12/12/2022 05:00	0.7	12.7	2,119.2	0.7	0.6	1	1	1
12/12/2022 06:00	0.7	12.2	2,218.1	0.7	0.7	1	1	1
12/12/2022 07:00	0.7	12.3	2,198.9	0.7	0.7	1	1	1
12/12/2022 08:00	0.7	12.8	2,076.7	0.7	0.6	1	1	1
12/12/2022 09:00	0.7	12.9	2,068.8	0.7	0.6	1	1	1
12/12/2022 10:00	0.5	13.3	1,973.0	0.5	0.6	1	1	1
12/12/2022 11:00	0.5	13.2	1,970.2	0.5	0.6	1	1	1
12/12/2022 12:00	0.5	13.2	1,970.6	0.5	0.6	1	1	1
12/12/2022 13:00	0.5	13.2	1,969.6	0.5	0.6	1	1	1
12/12/2022 14:00	0.5	13.2	1,968.0	0.5	0.6	1	1	1
12/12/2022 15:00	0.7	13.2	1,967.7	0.7	0.6	1	1	1
12/12/2022 16:00	0.7	12.5	2,153.9	0.7	0.6	1	1	1
12/12/2022 17:00	0.7	12.1	2,250.2	0.7	0.7	1	1	1
12/12/2022 18:00	0.7	11.8	2,314.5	0.7	0.7	1	1	1
12/12/2022 19:00	0.7	11.8	2,316.4	0.7	0.7	1	1	1
12/12/2022 20:00	0.7	11.8	2,320.3	0.7	0.7	1	1	1
12/12/2022 21:00	0.7	12.0	2,269.9	0.7	0.7	1	1	1
12/12/2022 22:00	0.7	12.3	2,201.9	0.7	0.7	1	1	1
12/12/2022 23:00	0.7	13.0	2,035.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	2,094.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.5	11.8	1,967.7	0.5	0.6	1	1	1
Maximum:	0.7	13.3	2,320.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.7	12.6	2,155.3	0.7	0.6	1	1	1
12/13/2022 01:00	0.7	12.5	2,162.4	0.7	0.6	1	1	1
12/13/2022 02:00	0.7	12.5	2,171.0	0.7	0.7	1	1	1
12/13/2022 03:00	0.7	12.5	2,161.4	0.7	0.6	1	1	1
12/13/2022 04:00	0.7	12.4	2,201.7	0.7	0.7	1	1	1
12/13/2022 05:00	0.7	12.1	2,286.6	0.7	0.7	1	1	1
12/13/2022 06:00	0.7	11.9	2,323.5	0.7	0.7	1	1	1
12/13/2022 07:00	0.7	11.9	2,314.5	0.7	0.7	1	1	1
12/13/2022 08:00	0.7	12.5	2,149.7	0.7	0.6	1	1	1
12/13/2022 09:00	0.7	13.1	2,013.4	0.7	0.6	1	1	1
12/13/2022 10:00	0.7	13.3	1,978.2	0.7	0.6	1	1	1
12/13/2022 11:00	0.7	13.2	1,972.8	0.7	0.6	1	1	1
12/13/2022 12:00	0.7	13.2	1,971.6	0.7	0.6	1	1	1
12/13/2022 13:00	0.7	13.2	1,969.9	0.7	0.6	1	1	1
12/13/2022 14:00	0.7	13.2	1,968.6	0.7	0.6	1	1	1
12/13/2022 15:00	0.7	12.8	2,076.2	0.7	0.6	1	1	1
12/13/2022 16:00	0.7	11.9	2,282.3	0.7	0.7	1	1	1
12/13/2022 17:00	0.7	11.8	2,299.2	0.7	0.7	1	1	1
12/13/2022 18:00	0.7	11.9	2,297.3	0.7	0.7	1	1	1
12/13/2022 19:00	0.7	11.9	2,296.7	0.7	0.7	1	1	1
12/13/2022 20:00	0.7	11.9	2,293.3	0.7	0.7	1	1	1
12/13/2022 21:00	0.7	12.0	2,293.3	0.7	0.7	1	1	1
12/13/2022 22:00	0.7	12.0	2,297.4	0.7	0.7	1	1	1
12/13/2022 23:00	0.7	11.9	2,293.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,176.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.8	1,968.6	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,323.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.7	12.4	2,201.0	0.7	0.7	1	1	1
12/14/2022 01:00	0.7	12.4	2,205.8	0.7	0.7	1	1	1
12/14/2022 02:00	0.7	12.4	2,207.5	0.7	0.7	1	1	1
12/14/2022 03:00	0.7	12.5	2,202.0	0.7	0.7	1	1	1
12/14/2022 04:00	0.7	12.5	2,195.8	0.7	0.7	1	1	1
12/14/2022 05:00	0.7	12.0	2,307.3	0.7	0.7	1	1	1
12/14/2022 06:00	0.7	12.0	2,311.1	0.7	0.7	1	1	1
12/14/2022 07:00	0.7	12.1	2,277.8	0.7	0.7	1	1	1
12/14/2022 08:00	0.7	12.9	2,081.0	0.7	0.6	1	1	1
12/14/2022 09:00	0.7	13.1	2,011.1	0.7	0.6	1	1	1
12/14/2022 10:00	0.7	13.0	2,028.4	0.7	0.6	1	1	1
12/14/2022 11:00	0.7	13.2	1,974.9	0.7	0.6	1	1	1
12/14/2022 12:00	0.7	13.2	1,976.5	0.7	0.6	1	1	1
12/14/2022 13:00	0.7	13.2	1,978.3	0.7	0.6	1	1	1
12/14/2022 14:00	0.7	13.2	1,975.2	0.7	0.6	1	1	1
12/14/2022 15:00	0.7	13.1	2,018.4	0.7	0.6	1	1	1
12/14/2022 16:00	0.7	12.2	2,219.4	0.7	0.7	1	1	1
12/14/2022 17:00	0.7	11.9	2,291.2	0.7	0.7	1	1	1
12/14/2022 18:00	0.7	11.9	2,288.1	0.7	0.7	1	1	1
12/14/2022 19:00	0.7	11.9	2,292.6	0.7	0.7	1	1	1
12/14/2022 20:00	0.7	12.0	2,292.9	0.7	0.7	1	1	1
12/14/2022 21:00	0.7	12.0	2,291.3	0.7	0.7	1	1	1
12/14/2022 22:00	0.7	12.1	2,265.2	0.7	0.7	1	1	1
12/14/2022 23:00	0.7	12.5	2,178.6	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,169.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,974.9	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,311.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2022 00:00	0.7	12.0	2,300.0	0.7	0.7	1	1	1
12/15/2022 01:00	0.7	11.9	2,310.7	0.7	0.7	1	1	1
12/15/2022 02:00	0.7	11.9	2,310.7	0.7	0.7	1	1	1
12/15/2022 03:00	0.7	11.9	2,312.5	0.7	0.7	1	1	1
12/15/2022 04:00	0.7	11.9	2,317.5	0.7	0.7	1	1	1
12/15/2022 05:00	0.7	11.9	2,320.2	0.7	0.7	1	1	1
12/15/2022 06:00	0.7	11.9	2,319.6	0.7	0.7	1	1	1
12/15/2022 07:00	0.7	11.9	2,314.8	0.7	0.7	1	1	1
12/15/2022 08:00	0.7	12.2	2,232.9	0.7	0.7	1	1	1
12/15/2022 09:00	0.7	12.1	2,231.2	0.7	0.7	1	1	1
12/15/2022 10:00	0.7	13.1	1,978.7	0.7	0.6	1	1	1
12/15/2022 11:00	0.7	13.1	1,990.3	0.7	0.6	1	1	1
12/15/2022 12:00	0.7	12.9	2,023.1	0.7	0.6	1	1	1
12/15/2022 13:00	0.7	12.8	2,045.1	0.7	0.6	1	1	1
12/15/2022 14:00	0.7	12.6	2,102.6	0.7	0.6	1	1	1
12/15/2022 15:00	0.7	11.9	2,258.0	0.7	0.7	1	1	1
12/15/2022 16:00	0.7	11.9	2,270.0	0.7	0.7	1	1	1
12/15/2022 17:00	0.7	11.9	2,268.1	0.7	0.7	1	1	1
12/15/2022 18:00	0.7	12.0	2,258.2	0.7	0.7	1	1	1
12/15/2022 19:00	0.7	12.0	2,251.3	0.7	0.7	1	1	1
12/15/2022 20:00	0.7	12.0	2,253.0	0.7	0.7	1	1	1
12/15/2022 21:00	0.7	12.1	2,254.6	0.7	0.7	1	1	1
12/15/2022 22:00	0.7	12.1	2,260.1	0.7	0.7	1	1	1
12/15/2022 23:00	0.7	12.2	2,242.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,226.1	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,978.7	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,320.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	0.7	13.1	1,997.7	0.7	0.6	1	1	1
12/16/2022 01:00	0.7	13.2	1,975.0	0.7	0.6	1	1	1
12/16/2022 02:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
12/16/2022 03:00	0.7	13.2	1,977.9	0.7	0.6	1	1	1
12/16/2022 04:00	0.7	13.2	1,976.0	0.7	0.6	1	1	1
12/16/2022 05:00	0.7	13.2	1,986.3	0.7	0.6	1	1	1
12/16/2022 06:00	0.7	12.7	2,114.7	0.7	0.6	1	1	1
12/16/2022 07:00	0.7	12.4	2,213.4	0.7	0.7	1	1	1
12/16/2022 08:00	0.7	12.6	2,148.7	0.7	0.6	1	1	1
12/16/2022 09:00	0.7	12.8	2,073.1	0.7	0.6	1	1	1
12/16/2022 10:00	0.6	13.9	1,533.9	0.6	0.5	1	1	0
12/16/2022 11:00	0.6	14.0	1,455.0	0.6	0.4	1	1	0
12/16/2022 12:00	0.6	14.0	1,319.9	0.6	0.4	1	1	0
12/16/2022 13:00	0.6	14.0	1,322.2	0.6	0.4	1	1	0
12/16/2022 14:00	0.6	13.9	1,577.2	0.6	0.5	1	1	0
12/16/2022 15:00	0.7	13.9	1,550.0	0.7	0.5	1	1	1
12/16/2022 16:00	0.7	12.4	2,166.8	0.7	0.7	1	1	1
12/16/2022 17:00	0.7	12.1	2,236.7	0.7	0.7	1	1	1
12/16/2022 18:00	0.7	12.4	2,162.4	0.7	0.6	1	1	1
12/16/2022 19:00	0.7	12.4	2,168.7	0.7	0.7	1	1	1
12/16/2022 20:00	0.7	12.0	2,256.4	0.7	0.7	1	1	1
12/16/2022 21:00	0.7	12.2	2,198.9	0.7	0.7	1	1	1
12/16/2022 22:00	0.7	12.7	2,089.5	0.7	0.6	1	1	1
12/16/2022 23:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,935.4	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.0	1,319.9	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,256.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.7	12.5	2,148.3	0.7	0.6	1	1	1
12/17/2022 01:00	0.7	12.5	2,151.2	0.7	0.6	1	1	1
12/17/2022 02:00	0.7	12.6	2,142.6	0.7	0.6	1	1	1
12/17/2022 03:00	0.7	12.6	2,153.4	0.7	0.6	1	1	1
12/17/2022 04:00	0.7	12.5	2,154.4	0.7	0.6	1	1	1
12/17/2022 05:00	0.7	12.6	2,151.3	0.7	0.6	1	1	1
12/17/2022 06:00	0.7	12.1	2,242.2	0.7	0.7	1	1	1
12/17/2022 07:00	0.7	12.7	2,099.3	0.7	0.6	1	1	1
12/17/2022 08:00	0.7	12.5	2,165.9	0.7	0.6	1	1	1
12/17/2022 09:00	0.7	12.7	2,124.8	0.7	0.6	1	1	1
12/17/2022 10:00	0.7	13.1	2,009.5	0.7	0.6	1	1	1
12/17/2022 11:00	0.7	13.2	1,977.3	0.7	0.6	1	1	1
12/17/2022 12:00	0.7	13.2	1,970.0	0.7	0.6	1	1	1
12/17/2022 13:00	0.7	13.2	1,970.2	0.7	0.6	1	1	1
12/17/2022 14:00	0.7	13.1	1,991.1	0.7	0.6	1	1	1
12/17/2022 15:00	0.7	12.6	2,124.4	0.7	0.6	1	1	1
12/17/2022 16:00	0.7	11.9	2,279.1	0.7	0.7	1	1	1
12/17/2022 17:00	0.7	12.0	2,247.4	0.7	0.7	1	1	1
12/17/2022 18:00	0.7	12.4	2,159.7	0.7	0.6	1	1	1
12/17/2022 19:00	0.7	11.9	2,288.0	0.7	0.7	1	1	1
12/17/2022 20:00	0.7	11.9	2,291.4	0.7	0.7	1	1	1
12/17/2022 21:00	0.7	11.9	2,292.3	0.7	0.7	1	1	1
12/17/2022 22:00	0.7	11.9	2,284.2	0.7	0.7	1	1	1
12/17/2022 23:00	0.7	12.3	2,192.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,150.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.0	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,292.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.7	12.5	2,141.4	0.7	0.6	1	1	1
12/18/2022 01:00	0.7	12.6	2,140.8	0.7	0.6	1	1	1
12/18/2022 02:00	0.7	13.1	2,023.7	0.7	0.6	1	1	1
12/18/2022 03:00	0.7	13.3	1,985.2	0.7	0.6	1	1	1
12/18/2022 04:00	0.7	12.7	2,140.3	0.7	0.6	1	1	1
12/18/2022 05:00	0.7	12.6	2,162.0	0.7	0.6	1	1	1
12/18/2022 06:00	0.7	12.4	2,182.1	0.7	0.7	1	1	1
12/18/2022 07:00	0.7	12.3	2,219.3	0.7	0.7	1	1	1
12/18/2022 08:00	0.7	12.7	2,091.7	0.7	0.6	1	1	1
12/18/2022 09:00	0.6	13.9	1,607.9	0.6	0.5	1	1	0
12/18/2022 10:00	0.6	13.9	1,552.2	0.6	0.5	1	1	0
12/18/2022 11:00	0.6	13.9	1,544.4	0.6	0.5	1	1	0
12/18/2022 12:00	0.6	14.0	1,404.3	0.6	0.4	1	1	0
12/18/2022 13:00	0.6	14.0	1,395.8	0.6	0.4	1	1	0
12/18/2022 14:00	0.6	13.9	1,634.8	0.6	0.5	1	1	0
12/18/2022 15:00	0.7	13.9	1,645.9	0.7	0.5	1	1	1
12/18/2022 16:00	0.7	12.5	2,143.3	0.7	0.6	1	1	1
12/18/2022 17:00	0.7	12.0	2,254.0	0.7	0.7	1	1	1
12/18/2022 18:00	0.7	11.9	2,283.9	0.7	0.7	1	1	1
12/18/2022 19:00	0.7	11.9	2,288.7	0.7	0.7	1	1	1
12/18/2022 20:00	0.7	12.2	2,245.0	0.7	0.7	1	1	1
12/18/2022 21:00	0.7	12.4	2,208.9	0.7	0.7	1	1	1
12/18/2022 22:00	0.7	12.4	2,205.7	0.7	0.7	1	1	1
12/18/2022 23:00	0.7	13.0	2,049.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,981.3	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,395.8	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,288.7	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	0.7	12.7	2,141.9	0.7	0.6	1	1	1
12/19/2022 01:00	0.7	12.6	2,153.5	0.7	0.6	1	1	1
12/19/2022 02:00	0.7	12.6	2,149.7	0.7	0.6	1	1	1
12/19/2022 03:00	0.7	12.6	2,152.1	0.7	0.6	1	1	1
12/19/2022 04:00	0.7	12.5	2,185.5	0.7	0.7	1	1	1
12/19/2022 05:00	0.7	12.0	2,309.6	0.7	0.7	1	1	1
12/19/2022 06:00	0.7	12.0	2,310.1	0.7	0.7	1	1	1
12/19/2022 07:00	0.7	12.0	2,310.1	0.7	0.7	1	1	1
12/19/2022 08:00	0.7	12.2	2,262.0	0.7	0.7	1	1	1
12/19/2022 09:00	0.7	12.1	2,274.3	0.7	0.7	1	1	1
12/19/2022 10:00	0.7	12.5	2,181.5	0.7	0.7	1	1	1
12/19/2022 11:00	0.7	12.5	2,181.8	0.7	0.7	1	1	1
12/19/2022 12:00	0.7	12.6	2,174.1	0.7	0.7	1	1	1
12/19/2022 13:00	0.7	12.6	2,164.7	0.7	0.6	1	1	1
12/19/2022 14:00	0.7	12.6	2,166.8	0.7	0.7	1	1	1
12/19/2022 15:00	0.7	12.3	2,231.0	0.7	0.7	1	1	1
12/19/2022 16:00	0.7	12.1	2,274.5	0.7	0.7	1	1	1
12/19/2022 17:00	0.7	12.1	2,275.0	0.7	0.7	1	1	1
12/19/2022 18:00	0.7	12.1	2,277.1	0.7	0.7	1	1	1
12/19/2022 19:00	0.7	12.1	2,280.3	0.7	0.7	1	1	1
12/19/2022 20:00	0.7	12.2	2,277.2	0.7	0.7	1	1	1
12/19/2022 21:00	0.7	12.2	2,277.4	0.7	0.7	1	1	1
12/19/2022 22:00	0.7	12.1	2,283.3	0.7	0.7	1	1	1
12/19/2022 23:00	0.7	12.1	2,278.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.3	2,232.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	12.0	2,141.9	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,310.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.7	12.6	2,180.6	0.7	0.7	1	1	1
12/20/2022 01:00	0.7	12.6	2,178.9	0.7	0.7	1	1	1
12/20/2022 02:00	0.7	12.5	2,184.2	0.7	0.7	1	1	1
12/20/2022 03:00	0.7	12.5	2,189.6	0.7	0.7	1	1	1
12/20/2022 04:00	0.7	12.5	2,190.7	0.7	0.7	1	1	1
12/20/2022 05:00	0.7	12.5	2,190.8	0.7	0.7	1	1	1
12/20/2022 06:00	0.7	12.1	2,291.6	0.7	0.7	1	1	1
12/20/2022 07:00	0.7	12.1	2,284.8	0.7	0.7	1	1	1
12/20/2022 08:00	0.7	12.6	2,170.4	0.7	0.7	1	1	1
12/20/2022 09:00	0.7	12.5	2,170.0	0.7	0.7	1	1	1
12/20/2022 10:00	0.7	12.7	2,128.2	0.7	0.6	1	1	1
12/20/2022 11:00	0.7	12.8	2,095.1	0.7	0.6	1	1	1
12/20/2022 12:00	0.7	13.3	1,961.4	0.7	0.6	1	1	1
12/20/2022 13:00	0.7	13.3	1,965.5	0.7	0.6	1	1	1
12/20/2022 14:00	0.7	13.3	1,964.0	0.7	0.6	1	1	1
12/20/2022 15:00	0.7	13.0	2,038.6	0.7	0.6	1	1	1
12/20/2022 16:00	0.7	12.3	2,199.8	0.7	0.7	1	1	1
12/20/2022 17:00	0.7	12.0	2,266.0	0.7	0.7	1	1	1
12/20/2022 18:00	0.7	12.0	2,265.9	0.7	0.7	1	1	1
12/20/2022 19:00	0.7	12.0	2,259.4	0.7	0.7	1	1	1
12/20/2022 20:00	0.7	12.0	2,259.9	0.7	0.7	1	1	1
12/20/2022 21:00	0.7	12.4	2,168.4	0.7	0.7	1	1	1
12/20/2022 22:00	0.7	12.4	2,167.9	0.7	0.7	1	1	1
12/20/2022 23:00	0.7	12.2	2,226.6	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,166.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	12.0	1,961.4	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,291.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2022 00:00	0.7	12.0	2,286.1	0.7	0.7	1	1	1
12/21/2022 01:00	0.7	12.0	2,284.9	0.7	0.7	1	1	1
12/21/2022 02:00	0.7	12.0	2,281.3	0.7	0.7	1	1	1
12/21/2022 03:00	0.7	12.0	2,289.0	0.7	0.7	1	1	1
12/21/2022 04:00	0.7	12.0	2,282.4	0.7	0.7	1	1	1
12/21/2022 05:00	0.7	12.0	2,284.7	0.7	0.7	1	1	1
12/21/2022 06:00	0.7	12.0	2,284.5	0.7	0.7	1	1	1
12/21/2022 07:00	0.7	12.0	2,283.3	0.7	0.7	1	1	1
12/21/2022 08:00	0.7	0.0	2,268.8	0.7	0.7	1	1	1
12/21/2022 09:00	0.5	12.2	2,259.9	0.5	0.7	1	1	1
12/21/2022 10:00	0.5	12.2	2,253.9	0.5	0.7	1	1	1
12/21/2022 11:00	0.5	12.3	2,219.0	0.5	0.7	1	1	1
12/21/2022 12:00	0.5	12.2	2,236.9	0.5	0.7	1	1	1
12/21/2022 13:00	0.5	12.1	2,229.8	0.5	0.7	1	1	1
12/21/2022 14:00	0.5	12.5	2,160.3	0.5	0.6	1	1	1
12/21/2022 15:00	0.5	12.1	2,234.3	0.5	0.7	1	1	1
12/21/2022 16:00	0.7	12.0	2,257.4	0.7	0.7	1	1	1
12/21/2022 17:00	0.5	12.0	2,255.2	0.5	0.7	1	1	1
12/21/2022 18:00	0.5	12.0	2,258.5	0.5	0.7	1	1	1
12/21/2022 19:00	0.7	12.0	2,256.4	0.7	0.7	1	1	1
12/21/2022 20:00	0.5	12.1	2,252.8	0.5	0.7	1	1	1
12/21/2022 21:00	0.5	12.1	2,253.7	0.5	0.7	1	1	1
12/21/2022 22:00	0.5	12.1	2,250.9	0.5	0.7	1	1	1
12/21/2022 23:00	0.5	12.1	2,248.9	0.5	0.7	1	1	1
Average/Sum#:	0.6	12.1	2,257.2	0.6	0.7	24 #	24 #	24 #
Minimum:	0.5	12.0	2,160.3	0.5	0.6	1	1	1
Maximum:	0.7	12.5	2,289.0	0.7	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	0.4	12.4	2,185.3	0.5	0.7	1	1	1
12/22/2022 01:00	0.2	13.2	1,981.3	0.4	0.6	1	1	1
12/22/2022 02:00	0.2	13.2	1,968.8	0.4	0.6	1	1	1
12/22/2022 03:00	0.2	13.2	1,968.0	0.4	0.6	1	1	1
12/22/2022 04:00	0.2	12.8	2,091.8	0.4	0.6	1	1	1
12/22/2022 05:00	0.5	12.4	2,221.8	0.5	0.7	1	1	1
12/22/2022 06:00	0.5	12.1	2,268.5	0.5	0.7	1	1	1
12/22/2022 07:00	0.5	12.1	2,266.2	0.5	0.7	1	1	1
12/22/2022 08:00	0.5	12.2	2,248.9	0.5	0.7	1	1	1
12/22/2022 09:00	0.4	12.6	2,149.4	0.5	0.6	1	1	1
12/22/2022 10:00	0.4	12.6	2,146.2	0.5	0.6	1	1	1
12/22/2022 11:00	0.4	12.6	2,143.8	0.5	0.6	1	1	1
12/22/2022 12:00	0.4	12.6	2,141.5	0.5	0.6	1	1	1
12/22/2022 13:00	0.5	12.6	2,143.3	0.5	0.6	1	1	1
12/22/2022 14:00	0.4	12.6	2,149.6	0.5	0.6	1	1	1
12/22/2022 15:00	0.5	12.3	2,214.6	0.5	0.7	1	1	1
12/22/2022 16:00	0.5	12.3	2,209.7	0.5	0.7	1	1	1
12/22/2022 17:00	0.5	12.1	2,256.5	0.5	0.7	1	1	1
12/22/2022 18:00	0.5	12.1	2,261.1	0.5	0.7	1	1	1
12/22/2022 19:00	0.5	12.1	2,267.4	0.5	0.7	1	1	1
12/22/2022 20:00	0.5	12.1	2,262.7	0.5	0.7	1	1	1
12/22/2022 21:00	0.7	12.1	2,260.5	0.7	0.7	1	1	1
12/22/2022 22:00	0.5	12.3	2,215.3	0.5	0.7	1	1	1
12/22/2022 23:00	0.4	12.8	2,077.3	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.5	2,170.8	0.5	0.7	24 #	24 #	24 #
Minimum:	0.2	12.1	1,968.0	0.4	0.6	1	1	1
Maximum:	0.7	13.2	2,268.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.5	12.3	2,228.2	0.5	0.7	1	1	1
12/23/2022 01:00	0.5	12.1	2,265.3	0.5	0.7	1	1	1
12/23/2022 02:00	0.5	12.1	2,261.5	0.5	0.7	1	1	1
12/23/2022 03:00	0.5	12.1	2,261.6	0.5	0.7	1	1	1
12/23/2022 04:00	0.5	12.1	2,262.1	0.5	0.7	1	1	1
12/23/2022 05:00	0.5	12.1	2,259.9	0.5	0.7	1	1	1
12/23/2022 06:00	0.5	12.1	2,259.7	0.5	0.7	1	1	1
12/23/2022 07:00	0.5	12.2	2,240.1	0.5	0.7	1	1	1
12/23/2022 08:00	0.5	12.4	2,187.9	0.5	0.7	1	1	1
12/23/2022 09:00	0.5	12.4	2,182.4	0.5	0.7	1	1	1
12/23/2022 10:00	0.5	12.5	2,137.6	0.5	0.6	1	1	1
12/23/2022 11:00	0.5	12.5	2,141.7	0.5	0.6	1	1	1
12/23/2022 12:00	0.4	12.9	2,027.4	0.5	0.6	1	1	1
12/23/2022 13:00	0.4	13.2	1,960.0	0.4	0.6	1	1	1
12/23/2022 14:00	0.4	13.2	1,953.8	0.4	0.6	1	1	1
12/23/2022 15:00	0.4	12.8	2,064.7	0.5	0.6	1	1	1
12/23/2022 16:00	0.7	12.0	2,253.1	0.7	0.7	1	1	1
12/23/2022 17:00	0.7	12.0	2,254.2	0.7	0.7	1	1	1
12/23/2022 18:00	0.7	12.0	2,260.1	0.7	0.7	1	1	1
12/23/2022 19:00	0.7	12.0	2,252.4	0.7	0.7	1	1	1
12/23/2022 20:00	0.7	12.0	2,248.8	0.7	0.7	1	1	1
12/23/2022 21:00	0.7	12.0	2,253.2	0.7	0.7	1	1	1
12/23/2022 22:00	0.7	12.0	2,252.2	0.7	0.7	1	1	1
12/23/2022 23:00	0.7	12.0	2,242.9	0.7	0.7	1	1	1
Average/Sum#:	0.6	12.3	2,196.3	0.6	0.7	24 #	24 #	24 #
Minimum:	0.4	12.0	1,953.8	0.4	0.6	1	1	1
Maximum:	0.7	13.2	2,265.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.5	12.5	2,130.9	0.5	0.6	1	1	1
12/24/2022 01:00	0.5	12.6	2,124.1	0.5	0.6	1	1	1
12/24/2022 02:00	0.4	13.2	1,963.2	0.4	0.6	1	1	1
12/24/2022 03:00	0.4	13.2	1,955.6	0.4	0.6	1	1	1
12/24/2022 04:00	0.4	13.2	1,955.0	0.4	0.6	1	1	1
12/24/2022 05:00	0.4	13.2	1,953.0	0.4	0.6	1	1	1
12/24/2022 06:00	0.4	13.1	1,979.9	0.4	0.6	1	1	1
12/24/2022 07:00	0.4	13.0	2,010.1	0.5	0.6	1	1	1
12/24/2022 08:00	0.4	13.4	1,837.3	0.4	0.6	1	1	1
12/24/2022 09:00	0.6	13.9	1,316.3	0.6	0.4	1	1	0
12/24/2022 10:00	0.5	13.9	1,548.3	0.5	0.5	1	1	0
12/24/2022 11:00	0.5	13.9	1,547.9	0.5	0.5	1	1	0
12/24/2022 12:00	0.5	13.9	1,552.0	0.5	0.5	1	1	0
12/24/2022 13:00	0.6	13.9	1,554.4	0.6	0.5	1	1	0
12/24/2022 14:00	0.6	13.9	1,730.3	0.6	0.5	1	1	0
12/24/2022 15:00	0.6	13.9	1,734.3	0.6	0.5	1	1	0
12/24/2022 16:00	0.7	13.9	1,590.2	0.7	0.5	1	1	1
12/24/2022 17:00	0.2	13.1	1,969.4	0.4	0.6	1	1	1
12/24/2022 18:00	0.4	13.1	1,965.8	0.4	0.6	1	1	1
12/24/2022 19:00	0.5	13.1	1,965.9	0.5	0.6	1	1	1
12/24/2022 20:00	0.5	13.1	1,967.3	0.5	0.6	1	1	1
12/24/2022 21:00	0.5	13.1	1,962.5	0.5	0.6	1	1	1
12/24/2022 22:00	0.5	13.2	1,965.3	0.5	0.6	1	1	1
12/24/2022 23:00	0.5	13.1	1,967.2	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.4	1,843.6	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.5	1,316.3	0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,130.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	0.5	13.1	1,946.8	0.5	0.6	1	1	1
12/25/2022 01:00	0.0	15.6	592.2	0.0	0.2	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	17.7	345.3	0.0	0.1	1	0	0
12/25/2022 19:00	0.0	17.3	411.1	0.0	0.1	1	0	0
12/25/2022 20:00	0.0	15.9	780.4	0.0	0.2	1	0	0
12/25/2022 21:00	0.5	13.9	1,417.5	0.5	0.4	1	1	0
12/25/2022 22:00	0.6	13.9	1,455.7	0.6	0.4	1	1	0
12/25/2022 23:00	0.5	13.9	1,477.4	0.5	0.4	1	1	0
Average/Sum#:	0.3	15.2	1,053.3	0.3	0.3	8 #	4 #	1 #
Minimum:	0.0	13.1	345.3	0.0	0.1	0	0	0
Maximum:	0.6	17.7	1,946.8	0.6	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.5	13.8	1,763.9	0.5	0.5	1	1	0
12/26/2022 01:00	0.5	13.8	1,543.0	0.5	0.5	1	1	0
12/26/2022 02:00	0.5	13.8	1,700.6	0.5	0.5	1	1	0
12/26/2022 03:00	0.5	13.8	1,721.9	0.5	0.5	1	1	0
12/26/2022 04:00	0.5	13.8	1,721.7	0.5	0.5	1	1	0
12/26/2022 05:00	0.5	13.8	1,737.5	0.5	0.5	1	1	0
12/26/2022 06:00	0.5	13.8	1,736.8	0.5	0.5	1	1	0
12/26/2022 07:00	0.5	13.8	1,728.0	0.5	0.5	1	1	0
12/26/2022 08:00	0.5	13.8	1,734.8	0.5	0.5	1	1	0
12/26/2022 09:00	0.5	13.9	1,548.8	0.5	0.5	1	1	0
12/26/2022 10:00	0.5	13.9	1,544.0	0.5	0.5	1	1	0
12/26/2022 11:00	0.5	13.9	1,535.6	0.5	0.5	1	1	0
12/26/2022 12:00	0.5	13.9	1,526.6	0.5	0.5	1	1	0
12/26/2022 13:00	0.5	13.9	1,547.1	0.5	0.5	1	1	0
12/26/2022 14:00	0.5	13.8	1,610.5	0.5	0.5	1	1	0
12/26/2022 15:00	0.5	13.8	1,740.0	0.5	0.5	1	1	0
12/26/2022 16:00	0.5	13.8	1,774.3	0.5	0.5	1	1	1
12/26/2022 17:00	0.2	12.6	2,122.6	0.4	0.6	1	1	1
12/26/2022 18:00	0.4	12.4	2,163.9	0.5	0.6	1	1	1
12/26/2022 19:00	0.2	13.0	2,015.8	0.4	0.6	1	1	1
12/26/2022 20:00	0.2	13.1	2,000.4	0.4	0.6	1	1	1
12/26/2022 21:00	0.2	13.2	1,969.8	0.4	0.6	1	1	1
12/26/2022 22:00	0.2	13.2	1,947.6	0.4	0.6	1	1	1
12/26/2022 23:00	0.0	15.6	609.2	0.0	0.2	1	0	0
Average/Sum#:	0.4	13.7	1,710.2	0.5	0.5	24 #	23 #	7 #
Minimum:	0.0	12.4	609.2	0.0	0.2	1	0	0
Maximum:	0.5	15.6	2,163.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	18.8	198.2	0.0	0.1	1	0	0
12/27/2022 02:00	0.0	16.0	756.8	0.0	0.2	1	0	0
12/27/2022 03:00	0.6	13.8	1,538.4	0.6	0.5	1	1	0
12/27/2022 04:00	0.6	13.9	1,539.3	0.6	0.5	1	1	0
12/27/2022 05:00	0.6	13.8	1,685.4	0.6	0.5	1	1	0
12/27/2022 06:00	0.6	13.9	1,397.3	0.6	0.4	1	1	0
12/27/2022 07:00	0.6	13.8	1,731.2	0.6	0.5	1	1	0
12/27/2022 08:00	0.5	13.8	1,701.6	0.5	0.5	1	1	1
12/27/2022 09:00	0.2	12.9	1,972.8	0.4	0.6	1	1	1
12/27/2022 10:00	0.2	12.9	1,967.9	0.4	0.6	1	1	1
12/27/2022 11:00	0.4	12.9	1,970.4	0.5	0.6	1	1	1
12/27/2022 12:00	0.4	12.9	1,969.6	0.5	0.6	1	1	1
12/27/2022 13:00	0.4	12.9	1,969.2	0.5	0.6	1	1	1
12/27/2022 14:00	0.4	12.9	1,970.6	0.5	0.6	1	1	1
12/27/2022 15:00	0.4	12.9	1,970.8	0.5	0.6	1	1	1
12/27/2022 16:00	0.4	13.0	1,970.5	0.5	0.6	1	1	1
12/27/2022 17:00	0.4	13.0	1,962.5	0.5	0.6	1	1	1
12/27/2022 18:00	0.4	13.1	1,960.1	0.4	0.6	1	1	1
12/27/2022 19:00	0.4	13.1	1,959.5	0.4	0.6	1	1	1
12/27/2022 20:00	0.4	13.1	1,971.6	0.4	0.6	1	1	1
12/27/2022 21:00	0.4	13.1	1,972.6	0.4	0.6	1	1	1
12/27/2022 22:00	0.4	13.2	1,945.8	0.4	0.6	1	1	1
12/27/2022 23:00	0.6	14.0	1,392.3	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.6	1,716.3	0.5	0.5	23 #	21 #	15 #
Minimum:	0.0	12.9	198.2	0.0	0.1	0	0	0
Maximum:	0.6	18.8	1,972.8	0.6	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.6	13.9	1,539.7	0.6	0.5	1	1	0
12/28/2022 01:00	0.6	13.9	1,465.2	0.6	0.4	1	1	0
12/28/2022 02:00	0.6	13.9	1,520.9	0.6	0.5	1	1	0
12/28/2022 03:00	0.6	13.9	1,518.1	0.6	0.5	1	1	0
12/28/2022 04:00	0.6	13.9	1,528.2	0.6	0.5	1	1	0
12/28/2022 05:00	0.5	13.8	1,718.9	0.5	0.5	1	1	0
12/28/2022 06:00	0.6	13.8	1,735.9	0.6	0.5	1	1	0
12/28/2022 07:00	0.5	13.8	1,738.4	0.5	0.5	1	1	0
12/28/2022 08:00	0.6	13.8	1,716.3	0.6	0.5	1	1	0
12/28/2022 09:00	0.5	13.8	1,707.8	0.5	0.5	1	1	0
12/28/2022 10:00	0.5	13.9	1,547.7	0.5	0.5	1	1	0
12/28/2022 11:00	0.6	13.9	1,563.0	0.6	0.5	1	1	0
12/28/2022 12:00	0.6	13.9	1,545.4	0.6	0.5	1	1	0
12/28/2022 13:00	0.6	13.9	1,525.3	0.6	0.5	1	1	0
12/28/2022 14:00	0.6	13.9	1,549.1	0.6	0.5	1	1	0
12/28/2022 15:00	0.5	13.9	1,592.4	0.5	0.5	1	1	1
12/28/2022 16:00	0.2	12.6	2,095.4	0.4	0.6	1	1	1
12/28/2022 17:00	0.2	13.1	1,976.0	0.4	0.6	1	1	1
12/28/2022 18:00	0.2	13.2	1,956.1	0.4	0.6	1	1	1
12/28/2022 19:00	0.2	13.2	1,957.5	0.4	0.6	1	1	1
12/28/2022 20:00	0.2	13.2	1,959.0	0.4	0.6	1	1	1
12/28/2022 21:00	0.2	13.1	1,970.4	0.4	0.6	1	1	1
12/28/2022 22:00	0.2	13.2	1,956.0	0.4	0.6	1	1	1
12/28/2022 23:00	0.2	13.2	1,960.9	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.6	1,722.7	0.5	0.5	24 #	24 #	9 #
Minimum:	0.2	12.6	1,465.2	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,095.4	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	0.2	13.2	1,956.9	0.4	0.6	1	1	1
12/29/2022 01:00	0.2	13.2	1,961.0	0.4	0.6	1	1	1
12/29/2022 02:00	0.2	13.2	1,965.0	0.4	0.6	1	1	1
12/29/2022 03:00	0.2	13.2	1,964.8	0.4	0.6	1	1	1
12/29/2022 04:00	0.2	13.2	1,969.1	0.4	0.6	1	1	1
12/29/2022 05:00	0.2	12.9	2,038.0	0.4	0.6	1	1	1
12/29/2022 06:00	0.2	12.6	2,047.5	0.4	0.6	1	1	1
12/29/2022 07:00	0.2	12.8	2,051.3	0.4	0.6	1	1	1
12/29/2022 08:00	0.4	12.2	2,206.4	0.5	0.7	1	1	1
12/29/2022 09:00	0.5	11.9	2,259.5	0.5	0.7	1	1	1
12/29/2022 10:00	0.5	12.4	2,161.9	0.5	0.6	1	1	1
12/29/2022 11:00	0.2	12.9	2,024.3	0.4	0.6	1	1	1
12/29/2022 12:00	0.2	13.1	1,986.2	0.4	0.6	1	1	1
12/29/2022 13:00	0.2	13.2	1,975.5	0.4	0.6	1	1	1
12/29/2022 14:00	0.2	13.1	1,985.1	0.4	0.6	1	1	1
12/29/2022 15:00	0.2	13.1	1,989.5	0.4	0.6	1	1	1
12/29/2022 16:00	0.2	12.7	2,100.3	0.4	0.6	1	1	1
12/29/2022 17:00	0.5	12.3	2,176.8	0.5	0.7	1	1	1
12/29/2022 18:00	0.4	12.6	2,085.5	0.5	0.6	1	1	1
12/29/2022 19:00	0.1	13.2	1,968.4	0.2	0.6	1	1	1
12/29/2022 20:00	0.1	13.2	1,977.8	0.2	0.6	1	1	1
12/29/2022 21:00	0.2	13.1	1,989.3	0.4	0.6	1	1	1
12/29/2022 22:00	0.1	13.1	1,972.1	0.2	0.6	1	1	1
12/29/2022 23:00	0.1	13.1	1,943.3	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	2,031.5	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	11.9	1,943.3	0.2	0.6	1	1	1
Maximum:	0.5	13.2	2,259.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	0.0	15.9	561.7	0.0	0.2	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.9	561.7	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	15.9	561.7	0.0	0.2	0	0	0
Maximum:	0.0	15.9	561.7	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:13 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 78.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**78.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:14 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,645.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 563.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,645.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:15 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:16 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 8.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**84.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:16 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:17 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	1.3	11.9	2,165.1	0.9	6.50	1	1	1
10/01/2022 01:00	2.4	14.1	1,211.1	2.1	4.66	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	13.0	1,688.1	1.5	11.16 #	2 #	1 #	2 #
Minimum:	1.3	11.9	1,211.1	0.9	4.66	0	0	0
Maximum:	2.4	14.1	2,165.1	2.1	6.50	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2022 02:00	29.3	17.5	336.0	50.8	51.50	1	0	0
10/03/2022 03:00	9.1	15.5	867.5	9.9	32.10	1	0	0
10/03/2022 04:00	1.1	13.8	1,711.7	0.9	5.10	1	1	0
10/03/2022 05:00	1.1	13.8	1,704.2	0.9	5.10	1	1	0
10/03/2022 06:00	1.1	13.8	1,701.6	0.9	5.10	1	1	0
10/03/2022 07:00	1.2	13.8	1,708.6	1.0	6.80	1	1	0
10/03/2022 08:00	1.1	13.8	1,718.8	0.9	5.20	1	1	0
10/03/2022 09:00	1.1	13.8	1,725.0	0.9	5.20	1	1	0
10/03/2022 10:00	0.1	13.9	1,728.2	0.1	0.00	1	1	0
10/03/2022 11:00	1.0	13.9	1,728.3	0.8	5.20	1	1	0
10/03/2022 12:00	1.1	13.9	1,728.4	0.9	5.20	1	1	0
10/03/2022 13:00	1.1	13.9	1,730.3	0.9	5.20	1	1	0
10/03/2022 14:00	1.1	13.9	1,724.6	0.9	5.20	1	1	0
10/03/2022 15:00	1.2	13.6	1,766.0	1.0	7.10	1	1	1
10/03/2022 16:00	1.3	12.3	2,061.1	0.9	6.20	1	1	1
10/03/2022 17:00	1.5	11.8	2,172.2	1.0	8.70	1	1	1
10/03/2022 18:00	1.5	11.6	2,206.8	1.0	8.80	1	1	1
10/03/2022 19:00	1.4	11.8	2,173.9	0.9	6.50	1	1	1
10/03/2022 20:00	1.4	11.7	2,187.2	0.9	6.60	1	1	1
10/03/2022 21:00	1.4	11.8	2,174.5	0.9	6.50	1	1	1
10/03/2022 22:00	1.4	12.0	2,152.4	0.9	6.50	1	1	1
10/03/2022 23:00	1.4	11.9	2,171.8	0.9	6.50	1	1	1
Average/Sum#:	2.8	13.4	1,780.9	3.6	200.30 #	22 #	20 #	9 #
Minimum:	0.1	11.6	336.0	0.1	0.00	0	0	0
Maximum:	29.3	17.5	2,206.8	50.8	51.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2022 00:00	1.4	12.0	2,154.5	0.9	6.50	1	1	1
10/04/2022 01:00	1.4	12.0	2,158.5	0.9	6.50	1	1	1
10/04/2022 02:00	1.4	12.0	2,156.3	0.9	6.50	1	1	1
10/04/2022 03:00	1.4	12.0	2,166.2	0.9	6.50	1	1	1
10/04/2022 04:00	1.4	12.0	2,173.6	0.9	6.50	1	1	1
10/04/2022 05:00	1.4	11.8	2,201.6	0.9	6.60	1	1	1
10/04/2022 06:00	1.4	12.0	2,166.7	0.9	6.50	1	1	1
10/04/2022 07:00	1.3	12.6	2,035.8	0.9	6.10	1	1	1
10/04/2022 08:00	1.1	13.7	1,595.1	0.9	4.80	1	1	0
10/04/2022 09:00	1.3	13.8	1,547.9	1.1	6.20	1	1	0
10/04/2022 10:00	1.4	13.7	1,555.2	1.1	6.20	1	1	0
10/04/2022 11:00	1.4	13.7	1,564.0	1.1	6.30	1	1	0
10/04/2022 12:00	1.5	13.7	1,722.8	1.2	8.60	1	1	0
10/04/2022 13:00	0.2	13.8	1,747.1	0.2	1.70	1	1	1
10/04/2022 14:00	0.3	12.8	2,032.9	0.2	2.00	1	1	1
10/04/2022 15:00	1.3	12.0	2,150.2	0.9	6.50	1	1	1
10/04/2022 16:00	1.2	12.1	2,131.5	0.8	6.40	1	1	1
10/04/2022 17:00	1.2	12.0	2,143.7	0.8	6.40	1	1	1
10/04/2022 18:00	1.2	11.9	2,169.2	0.8	6.50	1	1	1
10/04/2022 19:00	1.3	11.9	2,185.2	0.9	6.60	1	1	1
10/04/2022 20:00	1.2	11.6	2,243.7	0.8	6.70	1	1	1
10/04/2022 21:00	1.2	11.9	2,190.4	0.8	6.60	1	1	1
10/04/2022 22:00	1.3	11.9	2,177.9	0.9	6.50	1	1	1
10/04/2022 23:00	1.2	12.2	2,144.8	0.8	6.40	1	1	1
Average/Sum#:	1.2	12.5	2,021.5	0.9	146.10 #	24 #	24 #	19 #
Minimum:	0.2	11.6	1,547.9	0.2	1.70	1	1	0
Maximum:	1.5	13.8	2,243.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.2	12.2	2,136.7	0.8	6.40	1	1	1
10/05/2022 01:00	1.2	12.8	1,998.7	0.9	6.00	1	1	1
10/05/2022 02:00	1.1	13.0	1,971.1	0.8	5.90	1	1	1
10/05/2022 03:00	1.2	12.5	2,085.4	0.8	6.30	1	1	1
10/05/2022 04:00	1.2	12.3	2,111.1	0.8	6.30	1	1	1
10/05/2022 05:00	1.3	11.9	2,200.3	0.9	6.60	1	1	1
10/05/2022 06:00	1.2	11.9	2,201.4	0.8	6.60	1	1	1
10/05/2022 07:00	1.1	12.9	1,985.2	0.8	6.00	1	1	1
10/05/2022 08:00	1.0	13.9	1,718.1	0.8	5.20	1	1	0
10/05/2022 09:00	1.0	13.9	1,682.9	0.8	5.00	1	1	0
10/05/2022 10:00	0.9	13.9	1,710.7	0.8	5.10	1	1	0
10/05/2022 11:00	1.1	13.9	1,722.4	0.9	5.20	1	1	0
10/05/2022 12:00	0.6	13.8	1,738.9	0.5	3.50	1	1	1
10/05/2022 13:00	1.2	12.4	2,080.5	0.8	6.20	1	1	1
10/05/2022 14:00	1.2	11.8	2,190.4	0.8	6.60	1	1	1
10/05/2022 15:00	1.2	12.1	2,137.1	0.8	6.40	1	1	1
10/05/2022 16:00	1.3	11.9	2,159.1	0.9	6.50	1	1	1
10/05/2022 17:00	1.2	11.7	2,198.2	0.8	6.60	1	1	1
10/05/2022 18:00	1.2	11.6	2,230.9	0.8	6.70	1	1	1
10/05/2022 19:00	1.3	11.6	2,240.8	0.8	6.70	1	1	1
10/05/2022 20:00	1.2	11.9	2,190.7	0.8	6.60	1	1	1
10/05/2022 21:00	1.2	11.6	2,237.8	0.8	6.70	1	1	1
10/05/2022 22:00	1.2	12.0	2,166.4	0.8	6.50	1	1	1
10/05/2022 23:00	1.3	12.0	2,176.0	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.5	2,053.0	0.8	146.10 #	24 #	24 #	20 #
Minimum:	0.6	11.6	1,682.9	0.5	3.50	1	1	0
Maximum:	1.3	13.9	2,240.8	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.3	12.1	2,165.7	0.9	6.50	1	1	1
10/06/2022 01:00	1.2	12.1	2,167.7	0.8	6.50	1	1	1
10/06/2022 02:00	1.2	12.1	2,165.0	0.8	6.50	1	1	1
10/06/2022 03:00	1.2	12.2	2,141.6	0.8	6.40	1	1	1
10/06/2022 04:00	1.3	12.0	2,181.3	0.9	6.50	1	1	1
10/06/2022 05:00	1.0	11.6	2,250.8	0.6	4.50	1	1	1
10/06/2022 06:00	1.3	11.8	2,238.5	0.8	6.70	1	1	1
10/06/2022 07:00	1.2	12.2	2,135.9	0.8	6.40	1	1	1
10/06/2022 08:00	1.2	12.4	2,082.9	0.8	6.20	1	1	1
10/06/2022 09:00	1.2	12.5	2,071.3	0.8	6.20	1	1	1
10/06/2022 10:00	1.2	12.5	2,082.0	0.8	6.20	1	1	1
10/06/2022 11:00	1.2	12.3	2,114.5	0.8	6.30	1	1	1
10/06/2022 12:00	1.2	12.1	2,136.7	0.8	6.40	1	1	1
10/06/2022 13:00	1.2	11.8	2,192.4	0.8	6.60	1	1	1
10/06/2022 14:00	1.2	11.8	2,197.6	0.8	6.60	1	1	1
10/06/2022 15:00	1.2	12.0	2,150.8	0.8	6.50	1	1	1
10/06/2022 16:00	1.2	11.8	2,191.5	0.8	6.60	1	1	1
10/06/2022 17:00	1.2	11.6	2,240.1	0.8	6.70	1	1	1
10/06/2022 18:00	1.2	11.7	2,239.0	0.8	6.70	1	1	1
10/06/2022 19:00	1.2	11.6	2,255.1	0.8	6.80	1	1	1
10/06/2022 20:00	1.2	11.6	2,259.5	0.8	6.80	1	1	1
10/06/2022 21:00	1.2	11.7	2,245.4	0.8	6.70	1	1	1
10/06/2022 22:00	1.2	12.0	2,190.1	0.8	6.60	1	1	1
10/06/2022 23:00	1.2	12.1	2,168.8	0.8	6.50	1	1	1
Average/Sum#:	1.2	12.0	2,177.7	0.8	154.40 #	24 #	24 #	24 #
Minimum:	1.0	11.6	2,071.3	0.6	4.50	1	1	1
Maximum:	1.3	12.5	2,259.5	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.2	12.2	2,143.9	0.8	6.40	1	1	1
10/07/2022 01:00	1.2	12.2	2,159.9	0.8	6.50	1	1	1
10/07/2022 02:00	1.2	12.2	2,141.6	0.8	6.40	1	1	1
10/07/2022 03:00	1.2	12.3	2,114.7	0.8	6.30	1	1	1
10/07/2022 04:00	1.2	12.2	2,155.6	0.8	6.50	1	1	1
10/07/2022 05:00	1.4	12.0	2,191.6	0.9	6.60	1	1	1
10/07/2022 06:00	1.2	12.0	2,204.6	0.8	6.60	1	1	1
10/07/2022 07:00	1.2	12.4	2,110.8	0.8	6.30	1	1	1
10/07/2022 08:00	1.2	12.7	2,030.0	0.9	6.10	1	1	1
10/07/2022 09:00	1.2	12.3	2,127.6	0.8	6.40	1	1	1
10/07/2022 10:00	1.2	12.3	2,127.5	0.8	6.40	1	1	1
10/07/2022 11:00	1.3	12.3	2,111.0	0.9	6.30	1	1	1
10/07/2022 12:00	1.2	12.0	2,168.6	0.8	6.50	1	1	1
10/07/2022 13:00	1.2	12.1	2,136.9	0.8	6.40	1	1	1
10/07/2022 14:00	1.2	11.9	2,182.3	0.8	6.50	1	1	1
10/07/2022 15:00	1.3	11.8	2,193.0	0.8	6.60	1	1	1
10/07/2022 16:00	1.2	11.9	2,179.2	0.8	6.50	1	1	1
10/07/2022 17:00	1.2	11.6	2,229.9	0.8	6.70	1	1	1
10/07/2022 18:00	1.2	11.6	2,243.3	0.8	6.70	1	1	1
10/07/2022 19:00	1.2	11.6	2,258.3	0.8	6.80	1	1	1
10/07/2022 20:00	1.2	11.6	2,262.5	0.8	6.80	1	1	1
10/07/2022 21:00	1.2	11.6	2,265.6	0.8	6.80	1	1	1
10/07/2022 22:00	1.2	11.7	2,257.3	0.8	6.80	1	1	1
10/07/2022 23:00	1.2	12.0	2,184.9	0.8	6.60	1	1	1
Average/Sum#:	1.2	12.0	2,174.2	0.8	156.50 #	24 #	24 #	24 #
Minimum:	1.2	11.6	2,030.0	0.8	6.10	1	1	1
Maximum:	1.4	12.7	2,265.6	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.2	12.1	2,173.3	0.8	6.50	1	1	1
10/08/2022 01:00	1.2	12.1	2,176.2	0.8	6.50	1	1	1
10/08/2022 02:00	1.2	12.1	2,167.4	0.8	6.50	1	1	1
10/08/2022 03:00	1.3	12.1	2,178.3	0.9	6.50	1	1	1
10/08/2022 04:00	1.2	12.0	2,176.1	0.8	6.50	1	1	1
10/08/2022 05:00	1.0	12.1	2,170.4	0.7	4.30	1	1	1
10/08/2022 06:00	1.2	12.3	2,110.4	0.8	6.30	1	1	1
10/08/2022 07:00	1.3	13.8	1,711.8	1.1	6.80	1	1	1
10/08/2022 08:00	1.1	13.9	1,365.6	0.9	4.10	1	1	0
10/08/2022 09:00	1.1	13.9	1,315.8	0.9	3.90	1	1	0
10/08/2022 10:00	1.1	14.0	1,312.6	0.9	3.90	1	1	0
10/08/2022 11:00	1.1	14.0	1,318.8	0.9	4.00	1	1	0
10/08/2022 12:00	1.1	13.8	1,569.8	0.9	4.70	1	1	0
10/08/2022 13:00	1.2	13.8	1,728.0	1.0	6.90	1	1	0
10/08/2022 14:00	1.2	13.7	1,745.1	1.0	7.00	1	1	1
10/08/2022 15:00	1.4	12.2	2,069.6	0.9	6.20	1	1	1
10/08/2022 16:00	1.4	11.7	2,201.9	0.9	6.60	1	1	1
10/08/2022 17:00	1.4	11.7	2,201.4	0.9	6.60	1	1	1
10/08/2022 18:00	1.4	11.9	2,167.0	0.9	6.50	1	1	1
10/08/2022 19:00	1.4	11.9	2,177.6	0.9	6.50	1	1	1
10/08/2022 20:00	1.4	11.9	2,180.4	0.9	6.50	1	1	1
10/08/2022 21:00	1.4	11.9	2,177.9	0.9	6.50	1	1	1
10/08/2022 22:00	1.4	12.0	2,173.3	0.9	6.50	1	1	1
10/08/2022 23:00	1.4	12.1	2,170.3	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.6	1,947.5	0.9	142.80 #	24 #	24 #	18 #
Minimum:	1.0	11.7	1,312.6	0.7	3.90	1	1	0
Maximum:	1.4	14.0	2,201.9	1.1	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.4	12.0	2,166.8	0.9	6.50	1	1	1
10/09/2022 01:00	1.4	12.1	2,167.0	0.9	6.50	1	1	1
10/09/2022 02:00	1.3	12.2	2,138.4	0.9	6.40	1	1	1
10/09/2022 03:00	1.4	12.2	2,147.8	0.9	6.40	1	1	1
10/09/2022 04:00	1.4	12.1	2,158.6	0.9	6.50	1	1	1
10/09/2022 05:00	1.4	12.1	2,149.2	0.9	6.40	1	1	1
10/09/2022 06:00	1.7	13.0	1,685.1	1.3	8.40	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 10:00	0.6	18.7	209.6	1.6	0.29	1	0	0
10/09/2022 11:00	10.6	15.6	799.9	11.8	34.40	1	0	0
10/09/2022 12:00	1.1	13.9	1,387.0	0.9	4.20	1	1	0
10/09/2022 13:00	1.1	14.0	1,390.9	0.9	4.20	1	1	0
10/09/2022 14:00	1.2	13.7	1,726.4	1.0	6.90	1	1	0
10/09/2022 15:00	1.1	13.8	1,562.3	0.9	4.70	1	1	0
10/09/2022 16:00	1.2	13.8	1,729.7	1.0	6.90	1	1	0
10/09/2022 17:00	1.2	13.6	1,781.5	1.0	7.10	1	1	1
10/09/2022 18:00	1.4	12.3	2,081.7	1.0	8.30	1	1	1
10/09/2022 19:00	1.5	11.7	2,209.0	1.0	8.80	1	1	1
10/09/2022 20:00	1.4	11.8	2,188.3	0.9	6.60	1	1	1
10/09/2022 21:00	1.4	11.9	2,174.8	0.9	6.50	1	1	1
10/09/2022 22:00	1.4	12.0	2,156.1	0.9	6.50	1	1	1
10/09/2022 23:00	1.4	12.1	2,147.1	0.9	6.40	1	1	1
Average/Sum#:	1.7	13.1	1,817.0	1.5	158.89 #	21 #	18 #	14 #
Minimum:	0.6	11.7	209.6	0.9	0.29	0	0	0
Maximum:	10.6	18.7	2,209.0	11.8	34.40	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.4	12.2	2,121.9	0.9	6.40	1	1	1
10/10/2022 01:00	1.3	12.4	2,092.6	0.9	6.30	1	1	1
10/10/2022 02:00	1.3	12.9	1,980.8	1.0	7.90	1	1	1
10/10/2022 03:00	1.3	12.4	2,083.6	0.9	6.30	1	1	1
10/10/2022 04:00	1.4	12.3	2,127.1	1.0	8.50	1	1	1
10/10/2022 05:00	1.4	11.8	2,214.2	0.9	6.60	1	1	1
10/10/2022 06:00	1.4	11.9	2,205.4	0.9	6.60	1	1	1
10/10/2022 07:00	1.2	13.3	1,816.6	0.9	5.40	1	1	1
10/10/2022 08:00	1.1	13.8	1,551.8	0.9	4.70	1	1	0
10/10/2022 09:00	1.1	13.9	1,545.1	0.9	4.60	1	1	0
10/10/2022 10:00	1.1	14.0	1,390.8	0.9	4.20	1	1	0
10/10/2022 11:00	1.1	13.9	1,560.6	0.9	4.70	1	1	0
10/10/2022 12:00	1.1	13.9	1,574.2	0.9	4.70	1	1	0
10/10/2022 13:00	1.2	13.8	1,729.9	1.0	6.90	1	1	0
10/10/2022 14:00	1.2	13.8	1,718.4	1.0	6.90	1	1	0
10/10/2022 15:00	1.2	13.8	1,602.6	1.0	6.40	1	1	0
10/10/2022 16:00	1.3	12.6	1,973.3	0.9	5.90	1	1	1
10/10/2022 17:00	1.4	11.9	2,163.0	0.9	6.50	1	1	1
10/10/2022 18:00	1.4	11.7	2,198.7	0.9	6.60	1	1	1
10/10/2022 19:00	1.4	11.8	2,169.1	0.9	6.50	1	1	1
10/10/2022 20:00	1.4	11.9	2,160.6	0.9	6.50	1	1	1
10/10/2022 21:00	1.4	12.2	2,102.8	0.9	6.30	1	1	1
10/10/2022 22:00	1.3	12.4	2,085.4	0.9	6.30	1	1	1
10/10/2022 23:00	1.3	12.9	1,953.3	1.0	7.80	1	1	1
Average/Sum#:	1.3	12.8	1,921.7	0.9	149.50 #	24 #	24 #	16 #
Minimum:	1.1	11.7	1,390.8	0.9	4.20	1	1	0
Maximum:	1.4	14.0	2,214.2	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	1.1	13.9	1,376.2	0.9	4.10	1	1	0
10/11/2022 01:00	1.1	13.9	1,300.5	0.9	3.90	1	1	0
10/11/2022 02:00	1.1	13.9	1,300.2	0.9	3.90	1	1	0
10/11/2022 03:00	1.1	13.9	1,352.3	0.9	4.10	1	1	0
10/11/2022 04:00	1.0	13.9	1,495.7	0.8	4.50	1	1	0
10/11/2022 05:00	1.1	13.9	1,319.9	0.9	4.00	1	1	0
10/11/2022 06:00	1.1	13.9	1,313.8	0.9	3.90	1	1	0
10/11/2022 07:00	1.1	13.9	1,315.9	0.9	3.90	1	1	0
10/11/2022 08:00	1.1	13.9	1,317.2	0.9	4.00	1	1	0
10/11/2022 09:00	1.1	13.9	1,480.0	0.9	4.40	1	1	0
10/11/2022 10:00	1.1	13.9	1,548.1	0.9	4.60	1	1	0
10/11/2022 11:00	1.1	13.8	1,635.9	0.9	4.90	1	1	0
10/11/2022 12:00	1.2	13.6	1,802.5	1.0	7.20	1	1	0
10/11/2022 13:00	1.2	13.6	1,793.7	1.0	7.20	1	1	0
10/11/2022 14:00	1.2	13.6	1,789.9	1.0	7.20	1	1	0
10/11/2022 15:00	1.2	13.6	1,787.5	1.0	7.20	1	1	0
10/11/2022 16:00	1.2	13.6	1,788.3	1.0	7.20	1	1	0
10/11/2022 17:00	1.2	13.6	1,789.6	1.0	7.20	1	1	0
10/11/2022 18:00	1.2	13.6	1,794.2	1.0	7.20	1	1	1
10/11/2022 19:00	1.3	12.6	2,005.4	0.9	6.00	1	1	1
10/11/2022 20:00	1.4	12.1	2,131.3	0.9	6.40	1	1	1
10/11/2022 21:00	1.4	12.4	2,034.7	1.0	8.10	1	1	1
10/11/2022 22:00	1.4	12.2	2,102.6	0.9	6.30	1	1	1
10/11/2022 23:00	1.3	12.8	1,971.1	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.5	1,647.8	0.9	133.30 #	24 #	24 #	6 #
Minimum:	1.0	12.1	1,300.2	0.8	3.90	1	1	0
Maximum:	1.4	13.9	2,131.3	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2022 00:00	1.3	13.0	1,958.1	1.0	7.80	1	1	1
10/12/2022 01:00	1.2	13.0	1,935.0	0.9	5.80	1	1	1
10/12/2022 02:00	1.1	13.8	1,519.8	0.9	4.60	1	1	0
10/12/2022 03:00	1.1	13.9	1,637.4	0.9	4.90	1	1	0
10/12/2022 04:00	1.2	13.7	1,768.9	1.0	7.10	1	1	0
10/12/2022 05:00	1.3	12.0	2,131.1	0.9	6.40	1	1	1
10/12/2022 06:00	1.4	11.7	2,260.0	0.9	6.80	1	1	1
10/12/2022 07:00	1.4	11.7	2,255.1	0.9	6.80	1	1	1
10/12/2022 08:00	1.4	11.7	2,247.7	0.9	6.70	1	1	1
10/12/2022 09:00	1.4	11.7	2,246.9	0.9	6.70	1	1	1
10/12/2022 10:00	1.4	11.7	2,242.0	0.9	6.70	1	1	1
10/12/2022 11:00	1.4	11.7	2,245.9	0.9	6.70	1	1	1
10/12/2022 12:00	1.5	11.6	2,250.7	1.0	9.00	1	1	1
10/12/2022 13:00	1.4	11.6	2,248.0	0.9	6.70	1	1	1
10/12/2022 14:00	1.4	11.6	2,249.4	0.9	6.70	1	1	1
10/12/2022 15:00	1.5	11.6	2,250.4	1.0	9.00	1	1	1
10/12/2022 16:00	1.4	11.4	2,266.7	0.9	6.80	1	1	1
10/12/2022 17:00	1.4	11.4	2,274.9	0.9	6.80	1	1	1
10/12/2022 18:00	1.5	11.6	2,233.1	1.0	8.90	1	1	1
10/12/2022 19:00	1.4	12.1	2,138.2	0.9	6.40	1	1	1
10/12/2022 20:00	1.4	12.0	2,147.6	0.9	6.40	1	1	1
10/12/2022 21:00	1.4	12.2	2,119.1	0.9	6.40	1	1	1
10/12/2022 22:00	1.3	12.4	2,086.8	0.9	6.30	1	1	1
10/12/2022 23:00	1.3	12.9	1,967.8	1.0	7.90	1	1	1
Average/Sum#:	1.4	12.2	2,111.7	0.9	164.30 #	24 #	24 #	21 #
Minimum:	1.1	11.4	1,519.8	0.9	4.60	1	1	0
Maximum:	1.5	13.9	2,274.9	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.3	12.9	1,961.3	1.0	7.80	1	1	1
10/13/2022 01:00	1.3	12.7	2,005.0	0.9	6.00	1	1	1
10/13/2022 02:00	1.2	13.0	1,953.3	0.9	5.90	1	1	1
10/13/2022 03:00	1.3	13.0	1,959.2	1.0	7.80	1	1	1
10/13/2022 04:00	1.2	13.0	1,926.0	0.9	5.80	1	1	1
10/13/2022 05:00	1.2	13.9	1,311.2	1.0	5.20	1	1	0
10/13/2022 06:00	1.1	13.9	1,311.4	0.9	3.90	1	1	0
10/13/2022 07:00	1.1	13.9	1,339.8	0.9	4.00	1	1	0
10/13/2022 08:00	1.2	13.8	1,587.0	1.0	6.30	1	1	0
10/13/2022 09:00	1.1	13.8	1,535.6	0.9	4.60	1	1	0
10/13/2022 10:00	1.2	13.6	1,804.0	1.0	7.20	1	1	0
10/13/2022 11:00	1.2	13.5	1,810.3	1.0	7.20	1	1	0
10/13/2022 12:00	1.2	13.6	1,808.3	1.0	7.20	1	1	0
10/13/2022 13:00	1.2	13.6	1,802.3	1.0	7.20	1	1	0
10/13/2022 14:00	1.2	13.6	1,793.3	1.0	7.20	1	1	0
10/13/2022 15:00	1.2	13.6	1,792.5	1.0	7.20	1	1	0
10/13/2022 16:00	1.2	13.6	1,790.7	1.0	7.20	1	1	0
10/13/2022 17:00	1.2	13.6	1,796.8	1.0	7.20	1	1	0
10/13/2022 18:00	1.2	13.5	1,804.3	1.0	7.20	1	1	0
10/13/2022 19:00	1.2	13.5	1,807.0	1.0	7.20	1	1	1
10/13/2022 20:00	1.3	12.4	2,059.6	0.9	6.20	1	1	1
10/13/2022 21:00	1.4	12.0	2,159.9	0.9	6.50	1	1	1
10/13/2022 22:00	1.4	12.4	2,083.7	1.0	8.30	1	1	1
10/13/2022 23:00	1.3	12.5	2,071.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.3	1,803.1	1.0	156.50 #	24 #	24 #	10 #
Minimum:	1.1	12.0	1,311.2	0.9	3.90	1	1	0
Maximum:	1.4	13.9	2,159.9	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.3	12.6	2,061.0	0.9	6.20	1	1	1
10/14/2022 01:00	1.3	12.5	2,055.5	0.9	6.20	1	1	1
10/14/2022 02:00	1.3	12.5	2,056.0	0.9	6.20	1	1	1
10/14/2022 03:00	1.3	12.5	2,053.2	0.9	6.20	1	1	1
10/14/2022 04:00	1.4	12.3	2,098.1	1.0	8.40	1	1	1
10/14/2022 05:00	1.7	11.5	2,254.4	1.1	9.00	1	1	1
10/14/2022 06:00	1.4	11.5	2,261.5	0.9	6.80	1	1	1
10/14/2022 07:00	1.4	11.5	2,266.0	0.9	6.80	1	1	1
10/14/2022 08:00	1.3	12.5	2,033.0	0.9	6.10	1	1	1
10/14/2022 09:00	1.3	12.9	1,968.5	1.0	7.90	1	1	1
10/14/2022 10:00	1.3	12.7	1,978.5	0.9	5.90	1	1	1
10/14/2022 11:00	1.3	12.7	1,988.2	0.9	6.00	1	1	1
10/14/2022 12:00	1.3	12.7	1,992.9	0.9	6.00	1	1	1
10/14/2022 13:00	1.3	12.6	1,998.9	0.9	6.00	1	1	1
10/14/2022 14:00	1.4	12.2	2,104.1	0.9	6.30	1	1	1
10/14/2022 15:00	1.4	12.0	2,146.5	0.9	6.40	1	1	1
10/14/2022 16:00	1.4	12.0	2,145.1	0.9	6.40	1	1	1
10/14/2022 17:00	1.4	11.5	2,227.8	0.9	6.70	1	1	1
10/14/2022 18:00	1.4	11.9	2,153.4	0.9	6.50	1	1	1
10/14/2022 19:00	1.4	12.1	2,127.2	0.9	6.40	1	1	1
10/14/2022 20:00	1.4	12.0	2,134.2	0.9	6.40	1	1	1
10/14/2022 21:00	1.4	12.1	2,122.5	0.9	6.40	1	1	1
10/14/2022 22:00	1.3	12.3	2,095.3	0.9	6.30	1	1	1
10/14/2022 23:00	1.9	13.9	1,333.3	1.6	4.40	1	0	1
Average/Sum#:	1.4	12.3	2,069.0	0.9	155.90 #	24 #	23 #	24 #
Minimum:	1.3	11.5	1,333.3	0.9	4.40	1	0	1
Maximum:	1.9	13.9	2,266.0	1.6	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 23:00	25.7	17.8	305.8	48.9	27.50	1	0	0
Average/Sum#:	25.7	17.8	305.8	48.9	27.50 #	1 #	0 #	0 #
Minimum:	25.7	17.8	305.8	48.9	27.50	0	0	0
Maximum:	25.7	17.8	305.8	48.9	27.50	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	19.1	15.6	846.3	21.3	66.00	1	0	0
10/17/2022 01:00	1.2	13.8	1,704.0	1.0	6.80	1	1	0
10/17/2022 02:00	1.2	13.8	1,714.0	1.0	6.90	1	1	0
10/17/2022 03:00	1.2	13.7	1,810.2	1.0	7.20	1	1	1
10/17/2022 04:00	1.4	12.3	2,087.2	1.0	8.30	1	1	1
10/17/2022 05:00	1.6	11.9	2,182.2	1.0	8.70	1	1	1
10/17/2022 06:00	1.4	12.2	2,151.6	0.9	6.50	1	1	1
10/17/2022 07:00	1.3	12.4	2,100.6	0.9	6.30	1	1	1
10/17/2022 08:00	1.2	13.6	1,691.4	1.0	6.80	1	1	1
10/17/2022 09:00	1.2	13.8	1,644.4	1.0	6.60	1	1	0
10/17/2022 10:00	1.1	13.9	1,523.9	0.9	4.60	1	1	0
10/17/2022 11:00	1.1	13.8	1,608.2	0.9	4.80	1	1	0
10/17/2022 12:00	1.1	13.9	1,506.8	0.9	4.50	1	1	0
10/17/2022 13:00	1.2	13.9	1,513.1	1.0	6.10	1	1	0
10/17/2022 14:00	1.1	13.9	1,670.2	0.9	5.00	1	1	0
10/17/2022 15:00	1.2	13.7	1,713.7	1.0	6.90	1	1	1
10/17/2022 16:00	1.4	12.4	2,086.6	1.0	8.30	1	1	1
10/17/2022 17:00	1.4	11.6	2,242.9	0.9	6.70	1	1	1
10/17/2022 18:00	1.5	11.6	2,260.4	1.0	9.00	1	1	1
10/17/2022 19:00	1.4	11.7	2,236.0	0.9	6.70	1	1	1
10/17/2022 20:00	1.4	11.7	2,243.1	0.9	6.70	1	1	1
10/17/2022 21:00	1.5	11.6	2,256.3	1.0	9.00	1	1	1
10/17/2022 22:00	1.4	12.0	2,182.4	0.9	6.50	1	1	1
10/17/2022 23:00	1.4	12.0	2,180.6	0.9	6.50	1	1	1
Average/Sum#:	2.0	13.0	1,881.5	1.8	221.40 #	24 #	23 #	15 #
Minimum:	1.1	11.6	846.3	0.9	4.50	1	0	0
Maximum:	19.1	15.6	2,260.4	21.3	66.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.4	12.0	2,175.4	0.9	6.50	1	1	1
10/18/2022 01:00	1.4	12.1	2,166.0	0.9	6.50	1	1	1
10/18/2022 02:00	1.4	12.0	2,168.9	0.9	6.50	1	1	1
10/18/2022 03:00	1.4	11.9	2,193.4	0.9	6.60	1	1	1
10/18/2022 04:00	1.4	11.9	2,192.8	0.9	6.60	1	1	1
10/18/2022 05:00	1.4	12.0	2,173.8	0.9	6.50	1	1	1
10/18/2022 06:00	1.4	12.2	2,149.9	0.9	6.40	1	1	1
10/18/2022 07:00	1.4	12.1	2,148.0	0.9	6.40	1	1	1
10/18/2022 08:00	1.4	12.1	2,167.9	0.9	6.50	1	1	1
10/18/2022 09:00	1.4	12.1	2,165.6	0.9	6.50	1	1	1
10/18/2022 10:00	1.4	12.2	2,133.5	0.9	6.40	1	1	1
10/18/2022 11:00	1.4	12.3	2,107.8	1.0	8.40	1	1	1
10/18/2022 12:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
10/18/2022 13:00	1.4	12.3	2,109.2	1.0	8.40	1	1	1
10/18/2022 14:00	1.4	12.2	2,117.2	0.9	6.40	1	1	1
10/18/2022 15:00	1.4	12.1	2,149.3	0.9	6.40	1	1	1
10/18/2022 16:00	1.4	11.7	2,239.2	0.9	6.70	1	1	1
10/18/2022 17:00	1.4	11.9	2,202.8	0.9	6.60	1	1	1
10/18/2022 18:00	1.5	11.7	2,249.3	1.0	9.00	1	1	1
10/18/2022 19:00	1.4	11.6	2,271.7	0.9	6.80	1	1	1
10/18/2022 20:00	1.4	11.6	2,277.4	0.9	6.80	1	1	1
10/18/2022 21:00	1.4	11.6	2,277.9	0.9	6.80	1	1	1
10/18/2022 22:00	1.4	11.9	2,202.9	0.9	6.60	1	1	1
10/18/2022 23:00	1.4	11.9	2,201.6	0.9	6.60	1	1	1
Average/Sum#:	1.4	12.0	2,181.1	0.9	163.20 #	24 #	24 #	24 #
Minimum:	1.3	11.6	2,105.5	0.9	6.30	1	1	1
Maximum:	1.5	12.3	2,277.9	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2022 00:00	1.4	12.0	2,189.4	0.9	6.60	1	1	1
10/19/2022 01:00	1.3	12.4	2,117.8	0.9	6.40	1	1	1
10/19/2022 02:00	1.3	12.5	2,070.1	0.9	6.20	1	1	1
10/19/2022 03:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
10/19/2022 04:00	1.4	12.1	2,139.4	0.9	6.40	1	1	1
10/19/2022 05:00	1.4	11.7	2,201.4	0.9	6.60	1	1	1
10/19/2022 06:00	1.3	11.9	2,222.6	0.9	6.70	1	1	1
10/19/2022 07:00	1.4	12.2	2,151.9	0.9	6.50	1	1	1
10/19/2022 08:00	1.4	12.3	2,140.6	1.0	8.60	1	1	1
10/19/2022 09:00	1.3	12.4	2,101.5	0.9	6.30	1	1	1
10/19/2022 10:00	1.4	12.4	2,092.4	1.0	8.40	1	1	1
10/19/2022 11:00	1.3	12.2	2,121.8	0.9	6.40	1	1	1
10/19/2022 12:00	1.4	12.1	2,136.5	0.9	6.40	1	1	1
10/19/2022 13:00	1.4	12.0	2,154.1	0.9	6.50	1	1	1
10/19/2022 14:00	1.4	12.1	2,145.1	0.9	6.40	1	1	1
10/19/2022 15:00	1.4	11.8	2,185.0	0.9	6.60	1	1	1
10/19/2022 16:00	1.4	11.7	2,199.7	0.9	6.60	1	1	1
10/19/2022 17:00	1.4	12.1	2,124.9	0.9	6.40	1	1	1
10/19/2022 18:00	1.3	12.2	2,109.1	0.9	6.30	1	1	1
10/19/2022 19:00	1.4	12.2	2,115.7	0.9	6.30	1	1	1
10/19/2022 20:00	1.4	12.1	2,154.7	0.9	6.50	1	1	1
10/19/2022 21:00	1.3	12.3	2,120.2	0.9	6.40	1	1	1
10/19/2022 22:00	1.4	12.4	2,092.4	1.0	8.40	1	1	1
10/19/2022 23:00	1.4	12.3	2,111.2	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.2	2,137.6	0.9	162.60 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,070.1	0.9	6.20	1	1	1
Maximum:	1.4	12.5	2,222.6	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.3	12.3	2,129.2	0.9	6.40	1	1	1
10/20/2022 01:00	1.4	12.4	2,089.4	1.0	8.40	1	1	1
10/20/2022 02:00	1.3	12.5	2,083.4	0.9	6.30	1	1	1
10/20/2022 03:00	1.3	12.4	2,093.7	0.9	6.30	1	1	1
10/20/2022 04:00	1.4	12.3	2,133.0	1.0	8.50	1	1	1
10/20/2022 05:00	1.4	11.8	2,202.7	0.9	6.60	1	1	1
10/20/2022 06:00	1.4	12.0	2,196.1	0.9	6.60	1	1	1
10/20/2022 07:00	1.3	12.6	2,066.6	0.9	6.20	1	1	1
10/20/2022 08:00	1.3	12.6	2,058.0	0.9	6.20	1	1	1
10/20/2022 09:00	1.3	12.5	2,072.7	0.9	6.20	1	1	1
10/20/2022 10:00	1.3	12.5	2,068.4	0.9	6.20	1	1	1
10/20/2022 11:00	1.4	12.4	2,087.7	1.0	8.40	1	1	1
10/20/2022 12:00	1.4	12.3	2,089.8	1.0	8.40	1	1	1
10/20/2022 13:00	1.3	12.3	2,104.8	0.9	6.30	1	1	1
10/20/2022 14:00	1.4	12.2	2,117.9	0.9	6.40	1	1	1
10/20/2022 15:00	1.4	12.1	2,149.5	0.9	6.40	1	1	1
10/20/2022 16:00	1.4	11.5	2,255.7	0.9	6.80	1	1	1
10/20/2022 17:00	1.4	11.8	2,184.0	0.9	6.60	1	1	1
10/20/2022 18:00	1.4	11.7	2,231.4	0.9	6.70	1	1	1
10/20/2022 19:00	1.4	12.2	2,115.3	0.9	6.30	1	1	1
10/20/2022 20:00	1.4	12.2	2,110.7	0.9	6.30	1	1	1
10/20/2022 21:00	1.4	12.4	2,086.7	1.0	8.30	1	1	1
10/20/2022 22:00	1.3	12.4	2,088.4	0.9	6.30	1	1	1
10/20/2022 23:00	1.4	12.2	2,125.0	0.9	6.40	1	1	1
Average/Sum#:	1.4	12.2	2,122.5	0.9	163.50 #	24 #	24 #	24 #
Minimum:	1.3	11.5	2,058.0	0.9	6.20	1	1	1
Maximum:	1.4	12.6	2,255.7	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	1.2	12.8	1,944.1	0.9	5.80	1	1	1
10/21/2022 01:00	1.1	13.9	1,583.3	0.9	4.70	1	1	0
10/21/2022 02:00	1.1	13.9	1,597.9	0.9	4.80	1	1	0
10/21/2022 03:00	1.1	13.9	1,547.4	0.9	4.60	1	1	0
10/21/2022 04:00	1.1	13.9	1,708.6	0.9	5.10	1	1	0
10/21/2022 05:00	1.1	13.9	1,710.6	0.9	5.10	1	1	0
10/21/2022 06:00	1.1	13.9	1,608.8	0.9	4.80	1	1	0
10/21/2022 07:00	1.1	13.9	1,676.8	0.9	5.00	1	1	0
10/21/2022 08:00	1.1	13.9	1,716.7	0.9	5.20	1	1	0
10/21/2022 09:00	1.1	13.9	1,720.8	0.9	5.20	1	1	0
10/21/2022 10:00	1.1	13.9	1,719.5	0.9	5.20	1	1	0
10/21/2022 11:00	1.1	13.9	1,683.4	0.9	5.10	1	1	0
10/21/2022 12:00	1.1	13.8	1,661.0	0.9	5.00	1	1	0
10/21/2022 13:00	1.2	13.8	1,633.6	1.0	6.50	1	1	0
10/21/2022 14:00	1.2	13.8	1,692.1	1.0	6.80	1	1	0
10/21/2022 15:00	1.1	13.8	1,568.6	0.9	4.70	1	1	1
10/21/2022 16:00	1.4	12.2	2,099.1	0.9	6.30	1	1	1
10/21/2022 17:00	1.5	11.8	2,183.0	1.0	8.70	1	1	1
10/21/2022 18:00	1.4	12.0	2,142.7	0.9	6.40	1	1	1
10/21/2022 19:00	1.4	12.3	2,098.0	1.0	8.40	1	1	1
10/21/2022 20:00	1.4	12.2	2,114.4	0.9	6.30	1	1	1
10/21/2022 21:00	1.4	11.9	2,175.3	0.9	6.50	1	1	1
10/21/2022 22:00	2.4	14.0	1,230.6	2.1	4.70	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.3	13.4	1,774.6	1.0	130.90 #	23 #	22 #	9 #
Minimum:	1.1	11.8	1,230.6	0.9	4.60	0	0	0
Maximum:	2.4	14.0	2,183.0	2.1	8.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 12:00	0.3	21.0	2.2	0.3	0.00	1	0	0
10/24/2022 13:00	35.7	17.0	429.7	54.0	85.50	1	0	0
10/24/2022 14:00	8.3	14.1	1,572.3	7.2	42.50	1	0	0
10/24/2022 15:00	1.1	13.7	1,771.7	0.9	5.30	1	1	0
10/24/2022 16:00	1.2	13.7	1,770.8	1.0	7.10	1	1	0
10/24/2022 17:00	1.2	13.7	1,779.7	1.0	7.10	1	1	0
10/24/2022 18:00	1.1	13.7	1,791.6	0.9	5.40	1	1	0
10/24/2022 19:00	1.2	13.7	1,799.7	1.0	7.20	1	1	0
10/24/2022 20:00	1.2	13.7	1,806.0	1.0	7.20	1	1	0
10/24/2022 21:00	1.1	13.7	1,813.9	0.9	5.40	1	1	0
10/24/2022 22:00	1.2	13.7	1,810.6	1.0	7.20	1	1	0
10/24/2022 23:00	1.1	13.7	1,822.7	0.9	5.50	1	1	0
Average/Sum#:	4.6	14.6	1,514.2	5.8	185.40 #	12 #	9 #	0 #
Minimum:	0.3	13.7	2.2	0.3	0.00	0	0	0
Maximum:	35.7	21.0	1,822.7	54.0	85.50	1	1	0
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	1.2	13.7	1,809.3	1.0	7.20	1	1	0
10/25/2022 01:00	1.2	13.7	1,804.8	1.0	7.20	1	1	0
10/25/2022 02:00	1.1	13.8	1,804.4	0.9	5.40	1	1	0
10/25/2022 03:00	1.1	13.8	1,802.4	0.9	5.40	1	1	0
10/25/2022 04:00	1.2	13.8	1,805.0	1.0	7.20	1	1	0
10/25/2022 05:00	1.1	13.8	1,808.1	0.9	5.40	1	1	0
10/25/2022 06:00	1.1	13.8	1,808.2	0.9	5.40	1	1	0
10/25/2022 07:00	1.1	13.8	1,807.7	0.9	5.40	1	1	0
10/25/2022 08:00	1.1	13.7	1,812.1	0.9	5.40	1	1	0
10/25/2022 09:00	1.2	13.7	1,815.9	1.0	7.30	1	1	0
10/25/2022 10:00	1.2	13.7	1,814.8	1.0	7.30	1	1	0
10/25/2022 11:00	1.2	13.7	1,829.7	1.0	7.30	1	1	0
10/25/2022 12:00	1.2	13.7	1,832.3	1.0	7.30	1	1	0
10/25/2022 13:00	1.2	13.6	1,836.6	1.0	7.30	1	1	0
10/25/2022 14:00	1.2	13.6	1,831.6	1.0	7.30	1	1	0
10/25/2022 15:00	1.2	13.6	1,832.4	1.0	7.30	1	1	0
10/25/2022 16:00	1.2	13.6	1,831.0	1.0	7.30	1	1	0
10/25/2022 17:00	1.2	13.6	1,834.2	1.0	7.30	1	1	0
10/25/2022 18:00	1.2	13.7	1,826.1	1.0	7.30	1	1	0
10/25/2022 19:00	1.2	13.7	1,814.8	1.0	7.30	1	1	0
10/25/2022 20:00	1.2	13.7	1,807.6	1.0	7.20	1	1	0
10/25/2022 21:00	1.2	13.7	1,809.8	1.0	7.20	1	1	0
10/25/2022 22:00	1.1	13.7	1,804.5	0.9	5.40	1	1	0
10/25/2022 23:00	1.1	13.9	1,635.5	0.9	4.90	1	1	0
Average/Sum#:	1.2	13.7	1,809.1	1.0	159.00 #	24 #	24 #	0 #
Minimum:	1.1	13.6	1,635.5	0.9	4.90	1	1	0
Maximum:	1.2	13.9	1,836.6	1.0	7.30	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2022 00:00	1.1	13.8	1,630.9	0.9	4.90	1	1	0
10/26/2022 01:00	1.1	13.9	1,631.9	0.9	4.90	1	1	0
10/26/2022 02:00	1.1	13.9	1,628.9	0.9	4.90	1	1	0
10/26/2022 03:00	1.1	13.9	1,616.4	0.9	4.80	1	1	0
10/26/2022 04:00	1.1	13.8	1,794.6	0.9	5.40	1	1	0
10/26/2022 05:00	1.0	13.9	1,733.8	0.8	5.20	1	1	0
10/26/2022 06:00	1.1	13.9	1,691.8	0.9	5.10	1	1	0
10/26/2022 07:00	1.1	13.8	1,742.7	0.9	5.20	1	1	0
10/26/2022 08:00	3.4	15.4	735.2	3.6	2.59	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 16:00	20.6	18.3	240.1	46.7	13.22	1	0	0
10/26/2022 17:00	32.8	17.6	391.6	58.6	44.84	1	0	0
10/26/2022 18:00	23.7	15.4	828.0	25.4	77.80	1	0	0
10/26/2022 19:00	1.1	13.7	1,825.1	0.9	5.50	1	1	0
10/26/2022 20:00	1.2	13.7	1,820.3	1.0	7.30	1	1	0
10/26/2022 21:00	1.1	13.7	1,810.2	0.9	5.40	1	1	0
10/26/2022 22:00	1.1	13.7	1,764.5	0.9	5.30	1	1	0
10/26/2022 23:00	1.9	14.5	1,164.0	1.8	6.09	1	0	0
Average/Sum#:	5.6	14.5	1,414.7	8.6	208.44 #	17 #	12 #	0 #
Minimum:	1.0	13.7	240.1	0.8	2.59	0	0	0
Maximum:	32.8	18.3	1,825.1	58.6	77.80	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/31/2022 01:00	29.1	17.7	299.3	53.7	57.52	1	0	0
10/31/2022 02:00	14.2	16.0	725.0	17.1	45.70	1	0	0
10/31/2022 03:00	1.1	13.8	1,712.6	0.9	5.10	1	1	0
10/31/2022 04:00	1.1	13.8	1,726.3	0.9	5.20	1	1	0
10/31/2022 05:00	1.1	13.8	1,711.3	0.9	5.10	1	1	0
10/31/2022 06:00	1.1	13.8	1,692.8	0.9	5.10	1	1	0
10/31/2022 07:00	1.1	13.8	1,693.6	0.9	5.10	1	1	0
10/31/2022 08:00	1.1	13.8	1,704.5	0.9	5.10	1	1	0
10/31/2022 09:00	1.1	13.9	1,706.8	0.9	5.10	1	1	0
10/31/2022 10:00	1.1	13.9	1,708.4	0.9	5.10	1	1	0
10/31/2022 11:00	1.1	13.9	1,689.0	0.9	5.10	1	1	0
10/31/2022 12:00	1.1	13.9	1,687.9	0.9	5.10	1	1	0
10/31/2022 13:00	1.1	13.9	1,702.8	0.9	5.10	1	1	0
10/31/2022 14:00	1.2	13.7	1,767.7	1.0	7.10	1	1	1
10/31/2022 15:00	1.4	12.5	2,082.4	1.0	8.30	1	1	1
10/31/2022 16:00	1.3	12.3	2,105.6	0.9	6.30	1	1	1
10/31/2022 17:00	1.4	12.4	2,076.3	1.0	8.30	1	1	1
10/31/2022 18:00	1.3	12.4	2,082.4	0.9	6.20	1	1	1
10/31/2022 19:00	1.4	12.4	2,103.6	1.0	8.40	1	1	1
10/31/2022 20:00	1.3	12.4	2,089.0	0.9	6.30	1	1	1
10/31/2022 21:00	1.4	12.2	2,130.3	0.9	6.40	1	1	1
10/31/2022 22:00	1.3	12.3	2,096.7	0.9	6.30	1	1	1
10/31/2022 23:00	1.4	12.2	2,136.9	0.9	6.40	1	1	1
Average/Sum#:	3.0	13.5	1,757.9	3.9	229.42 #	23 #	21 #	10 #
Minimum:	1.1	12.2	299.3	0.9	5.10	0	0	0
Maximum:	29.1	17.7	2,136.9	53.7	57.52	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.4	12.2	2,154.2	0.9	6.50	1	1	1
11/01/2022 01:00	1.3	12.2	2,150.3	0.9	6.50	1	1	1
11/01/2022 02:00	1.4	12.2	2,158.5	0.9	6.50	1	1	1
11/01/2022 03:00	1.4	12.2	2,167.8	0.9	6.50	1	1	1
11/01/2022 04:00	1.4	12.2	2,175.8	0.9	6.50	1	1	1
11/01/2022 05:00	1.5	12.1	2,176.4	1.0	8.70	1	1	1
11/01/2022 06:00	1.4	11.8	2,250.2	0.9	6.80	1	1	1
11/01/2022 07:00	1.4	12.0	2,187.2	0.9	6.60	1	1	1
11/01/2022 08:00	1.4	11.7	2,240.2	0.9	6.70	1	1	1
11/01/2022 09:00	1.3	12.2	2,118.9	0.9	6.40	1	1	1
11/01/2022 10:00	1.3	12.3	2,123.0	0.9	6.40	1	1	1
11/01/2022 11:00	1.4	12.0	2,183.5	0.9	6.60	1	1	1
11/01/2022 12:00	1.4	11.9	2,189.4	0.9	6.60	1	1	1
11/01/2022 13:00	1.4	12.0	2,180.9	0.9	6.50	1	1	1
11/01/2022 14:00	1.3	12.4	2,089.8	0.9	6.30	1	1	1
11/01/2022 15:00	1.3	12.6	2,087.1	0.9	6.30	1	1	1
11/01/2022 16:00	1.4	12.1	2,204.2	0.9	6.60	1	1	1
11/01/2022 17:00	1.4	11.6	2,294.1	0.9	6.90	1	1	1
11/01/2022 18:00	1.3	12.1	2,186.6	0.9	6.60	1	1	1
11/01/2022 19:00	1.4	12.3	2,168.2	1.0	8.70	1	1	1
11/01/2022 20:00	1.4	12.1	2,209.2	0.9	6.60	1	1	1
11/01/2022 21:00	1.3	12.6	2,087.6	0.9	6.30	1	1	1
11/01/2022 22:00	1.3	12.7	2,075.1	0.9	6.20	1	1	1
11/01/2022 23:00	1.2	13.3	1,849.2	0.9	5.50	1	1	1
Average/Sum#:	1.4	12.2	2,154.5	0.9	159.80 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,849.2	0.9	5.50	1	1	1
Maximum:	1.5	13.3	2,294.1	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	1.1	13.9	1,353.8	0.9	4.10	1	1	0
11/02/2022 01:00	1.1	13.9	1,639.5	0.9	4.90	1	1	0
11/02/2022 02:00	1.1	13.8	1,709.9	0.9	5.10	1	1	0
11/02/2022 03:00	1.1	13.9	1,353.8	0.9	4.10	1	1	0
11/02/2022 04:00	1.1	13.8	1,683.4	0.9	5.10	1	1	0
11/02/2022 05:00	1.3	13.1	1,917.9	1.0	7.70	1	1	1
11/02/2022 06:00	1.3	12.5	2,169.6	0.9	6.50	1	1	1
11/02/2022 07:00	1.3	12.7	2,129.3	0.9	6.40	1	1	1
11/02/2022 08:00	1.3	12.9	2,028.9	1.0	8.10	1	1	1
11/02/2022 09:00	1.1	13.8	1,719.4	0.9	5.20	1	1	0
11/02/2022 10:00	1.1	13.9	1,549.8	0.9	4.60	1	1	0
11/02/2022 11:00	1.1	13.9	1,678.6	0.9	5.00	1	1	0
11/02/2022 12:00	1.1	13.9	1,558.6	0.9	4.70	1	1	0
11/02/2022 13:00	1.1	13.9	1,562.4	0.9	4.70	1	1	0
11/02/2022 14:00	1.1	13.9	1,544.2	0.9	4.60	1	1	0
11/02/2022 15:00	1.1	13.9	1,612.7	0.9	4.80	1	1	1
11/02/2022 16:00	1.3	12.6	2,080.8	0.9	6.20	1	1	1
11/02/2022 17:00	1.4	12.3	2,172.4	1.0	8.70	1	1	1
11/02/2022 18:00	1.4	12.4	2,164.8	1.0	8.70	1	1	1
11/02/2022 19:00	1.3	12.4	2,165.2	0.9	6.50	1	1	1
11/02/2022 20:00	1.3	12.4	2,166.8	0.9	6.50	1	1	1
11/02/2022 21:00	1.3	12.5	2,152.9	0.9	6.50	1	1	1
11/02/2022 22:00	1.3	12.4	2,163.4	0.9	6.50	1	1	1
11/02/2022 23:00	1.3	12.4	2,176.3	0.9	6.50	1	1	1
Average/Sum#:	1.2	13.2	1,852.3	0.9	141.70 #	24 #	24 #	13 #
Minimum:	1.1	12.3	1,353.8	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,176.3	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.4	12.4	2,167.7	1.0	8.70	1	1	1
11/03/2022 01:00	1.3	12.5	2,153.5	0.9	6.50	1	1	1
11/03/2022 02:00	1.3	12.3	2,199.7	0.9	6.60	1	1	1
11/03/2022 03:00	1.4	12.1	2,243.0	0.9	6.70	1	1	1
11/03/2022 04:00	1.4	12.4	2,170.3	1.0	8.70	1	1	1
11/03/2022 05:00	1.2	12.4	2,175.5	0.8	6.50	1	1	1
11/03/2022 06:00	1.4	12.1	2,246.8	0.9	6.70	1	1	1
11/03/2022 07:00	1.3	12.6	2,117.7	0.9	6.40	1	1	1
11/03/2022 08:00	1.1	13.9	1,461.2	0.9	4.40	1	1	0
11/03/2022 09:00	1.1	13.9	1,567.5	0.9	4.70	1	1	0
11/03/2022 10:00	1.1	13.9	1,581.7	0.9	4.70	1	1	0
11/03/2022 11:00	1.1	13.9	1,575.7	0.9	4.70	1	1	0
11/03/2022 12:00	1.1	13.9	1,587.6	0.9	4.80	1	1	0
11/03/2022 13:00	1.1	13.9	1,496.8	0.9	4.50	1	1	0
11/03/2022 14:00	1.1	13.9	1,564.2	0.9	4.70	1	1	0
11/03/2022 15:00	1.1	13.8	1,787.2	0.9	5.40	1	1	1
11/03/2022 16:00	1.3	12.7	2,081.8	0.9	6.20	1	1	1
11/03/2022 17:00	1.3	12.4	2,162.4	0.9	6.50	1	1	1
11/03/2022 18:00	1.3	12.3	2,178.2	0.9	6.50	1	1	1
11/03/2022 19:00	1.4	12.3	2,176.0	1.0	8.70	1	1	1
11/03/2022 20:00	1.3	12.3	2,164.2	0.9	6.50	1	1	1
11/03/2022 21:00	1.3	12.3	2,163.9	0.9	6.50	1	1	1
11/03/2022 22:00	1.4	12.3	2,163.3	1.0	8.70	1	1	1
11/03/2022 23:00	1.4	12.1	2,220.6	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.9	1,975.3	0.9	151.00 #	24 #	24 #	17 #
Minimum:	1.1	12.1	1,461.2	0.8	4.40	1	1	0
Maximum:	1.4	13.9	2,246.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.3	12.5	2,148.4	0.9	6.40	1	1	1
11/04/2022 01:00	1.3	12.6	2,120.9	0.9	6.40	1	1	1
11/04/2022 02:00	1.3	12.8	2,070.3	0.9	6.20	1	1	1
11/04/2022 03:00	1.3	12.8	2,074.1	0.9	6.20	1	1	1
11/04/2022 04:00	1.3	12.5	2,153.1	0.9	6.50	1	1	1
11/04/2022 05:00	1.4	12.0	2,266.7	0.9	6.80	1	1	1
11/04/2022 06:00	1.3	12.4	2,187.8	0.9	6.60	1	1	1
11/04/2022 07:00	1.3	12.8	2,062.9	0.9	6.20	1	1	1
11/04/2022 08:00	1.1	13.8	1,733.8	0.9	5.20	1	1	0
11/04/2022 09:00	1.1	13.9	1,557.3	0.9	4.70	1	1	0
11/04/2022 10:00	1.1	13.9	1,396.0	0.9	4.20	1	1	0
11/04/2022 11:00	1.1	14.0	1,324.8	0.9	4.00	1	1	0
11/04/2022 12:00	1.1	14.0	1,322.8	0.9	4.00	1	1	0
11/04/2022 13:00	1.1	14.0	1,324.0	0.9	4.00	1	1	0
11/04/2022 14:00	1.1	13.9	1,404.7	0.9	4.20	1	1	0
11/04/2022 15:00	1.1	13.8	1,636.8	0.9	4.90	1	1	1
11/04/2022 16:00	1.3	12.6	2,081.0	0.9	6.20	1	1	1
11/04/2022 17:00	1.3	12.4	2,119.5	0.9	6.40	1	1	1
11/04/2022 18:00	1.3	12.7	2,057.5	0.9	6.20	1	1	1
11/04/2022 19:00	1.3	12.7	2,056.8	0.9	6.20	1	1	1
11/04/2022 20:00	1.3	12.8	2,052.8	0.9	6.20	1	1	1
11/04/2022 21:00	1.3	12.8	2,054.4	0.9	6.20	1	1	1
11/04/2022 22:00	1.3	12.8	2,054.9	0.9	6.20	1	1	1
11/04/2022 23:00	1.2	13.3	1,952.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.1	1,883.9	0.9	136.00 #	24 #	24 #	17 #
Minimum:	1.1	12.0	1,322.8	0.9	4.00	1	1	0
Maximum:	1.4	14.0	2,266.7	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2022 00:00	1.2	13.3	1,950.5	0.9	5.90	1	1	1
11/05/2022 01:00	1.2	13.3	1,950.4	0.9	5.90	1	1	1
11/05/2022 02:00	1.2	13.3	1,950.1	0.9	5.90	1	1	1
11/05/2022 03:00	1.2	13.3	1,950.9	0.9	5.90	1	1	1
11/05/2022 04:00	1.2	13.3	1,954.3	0.9	5.90	1	1	1
11/05/2022 05:00	1.2	13.3	1,956.6	0.9	5.90	1	1	1
11/05/2022 06:00	1.2	13.3	1,927.6	0.9	5.80	1	1	1
11/05/2022 07:00	3.4	15.8	567.3	3.9	1.82	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 13:00	6.9	18.8	195.5	19.4	2.78	1	0	0
11/05/2022 14:00	27.9	16.1	711.5	34.3	89.60	1	0	0
11/05/2022 15:00	1.1	13.9	1,436.7	0.9	4.30	1	1	0
11/05/2022 16:00	1.2	13.4	1,707.2	0.9	5.10	1	1	1
11/05/2022 17:00	1.3	13.0	1,981.9	1.0	7.90	1	1	1
11/05/2022 18:00	1.3	13.0	1,971.9	1.0	7.90	1	1	1
11/05/2022 19:00	1.3	13.0	1,972.1	1.0	7.90	1	1	1
11/05/2022 20:00	1.3	13.0	1,975.2	1.0	7.90	1	1	1
11/05/2022 21:00	1.2	13.5	1,647.5	1.0	6.60	1	1	1
11/05/2022 22:00	1.1	13.9	1,409.8	0.9	4.20	1	1	0
11/05/2022 23:00	1.1	13.8	1,653.4	0.9	5.00	1	1	0
Average/Sum#:	3.0	13.9	1,624.8	3.8	192.20 #	19 #	16 #	13 #
Minimum:	1.1	13.0	195.5	0.9	1.82	0	0	0
Maximum:	27.9	18.8	1,981.9	34.3	89.60	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	1.1	13.8	1,564.1	0.9	4.70	1	1	0
11/06/2022 01:00	1.1	13.8	1,463.6	0.9	4.40	1	1	0
11/06/2022 02:00	2.7	16.3	377.6	3.5	0.88	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	14.6	1,135.1	1.8	9.98 #	3 #	2 #	0 #
Minimum:	1.1	13.8	377.6	0.9	0.88	0	0	0
Maximum:	2.7	16.3	1,564.1	3.5	4.70	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 03:00	22.6	18.1	281.0	47.6	19.68	1	0	0
11/07/2022 04:00	24.0	16.6	549.1	32.9	66.40	1	0	0
11/07/2022 05:00	1.7	13.7	1,723.5	1.4	8.60	1	0	0
11/07/2022 06:00	1.3	12.9	2,000.6	1.0	8.00	1	1	1
11/07/2022 07:00	1.4	12.1	2,210.3	0.9	6.60	1	1	1
11/07/2022 08:00	1.3	13.0	1,980.7	1.0	7.90	1	1	1
11/07/2022 09:00	1.2	13.0	1,964.2	0.9	5.90	1	1	1
11/07/2022 10:00	1.2	13.0	1,956.5	0.9	5.90	1	1	1
11/07/2022 11:00	1.2	13.1	1,957.6	0.9	5.90	1	1	1
11/07/2022 12:00	1.2	13.1	1,957.2	0.9	5.90	1	1	1
11/07/2022 13:00	1.2	13.1	1,960.7	0.9	5.90	1	1	1
11/07/2022 14:00	1.3	12.8	2,055.3	0.9	6.20	1	1	1
11/07/2022 15:00	1.3	12.2	2,186.1	0.9	6.60	1	1	1
11/07/2022 16:00	1.4	11.9	2,241.6	0.9	6.70	1	1	1
11/07/2022 17:00	1.5	11.8	2,276.8	1.0	9.10	1	1	1
11/07/2022 18:00	1.4	11.8	2,279.9	0.9	6.80	1	1	1
11/07/2022 19:00	1.4	11.8	2,279.4	0.9	6.80	1	1	1
11/07/2022 20:00	1.4	11.8	2,276.6	0.9	6.80	1	1	1
11/07/2022 21:00	1.4	11.8	2,272.9	0.9	6.80	1	1	1
11/07/2022 22:00	1.4	12.0	2,232.3	0.9	6.70	1	1	1
11/07/2022 23:00	1.4	12.4	2,159.5	1.0	8.60	1	1	1
Average/Sum#:	3.4	13.0	1,942.9	4.7	217.78 #	21 #	18 #	18 #
Minimum:	1.2	11.8	281.0	0.9	5.90	0	0	0
Maximum:	24.0	18.1	2,279.9	47.6	66.40	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	1.4	12.4	2,151.8	1.0	8.60	1	1	1
11/08/2022 01:00	1.3	12.4	2,149.8	0.9	6.40	1	1	1
11/08/2022 02:00	1.3	12.6	2,096.5	0.9	6.30	1	1	1
11/08/2022 03:00	1.3	12.4	2,143.2	0.9	6.40	1	1	1
11/08/2022 04:00	1.4	12.2	2,180.4	0.9	6.50	1	1	1
11/08/2022 05:00	1.5	12.1	2,197.5	1.0	8.80	1	1	1
11/08/2022 06:00	1.4	11.7	2,281.0	0.9	6.80	1	1	1
11/08/2022 07:00	1.4	12.1	2,193.7	0.9	6.60	1	1	1
11/08/2022 08:00	1.4	12.1	2,185.1	0.9	6.60	1	1	1
11/08/2022 09:00	1.4	12.2	2,181.7	0.9	6.50	1	1	1
11/08/2022 10:00	1.4	12.3	2,165.2	1.0	8.70	1	1	1
11/08/2022 11:00	1.3	12.9	2,016.4	1.0	8.10	1	1	1
11/08/2022 12:00	1.2	13.1	1,972.3	0.9	5.90	1	1	1
11/08/2022 13:00	1.2	13.2	1,972.1	0.9	5.90	1	1	1
11/08/2022 14:00	1.3	12.9	2,046.8	1.0	8.20	1	1	1
11/08/2022 15:00	1.3	12.9	2,043.8	1.0	8.20	1	1	1
11/08/2022 16:00	1.4	12.2	2,202.3	0.9	6.60	1	1	1
11/08/2022 17:00	1.4	12.2	2,181.5	0.9	6.50	1	1	1
11/08/2022 18:00	1.3	12.4	2,151.7	0.9	6.50	1	1	1
11/08/2022 19:00	1.4	12.2	2,186.1	0.9	6.60	1	1	1
11/08/2022 20:00	1.4	12.2	2,194.5	0.9	6.60	1	1	1
11/08/2022 21:00	1.4	12.2	2,195.9	0.9	6.60	1	1	1
11/08/2022 22:00	1.4	12.2	2,180.1	0.9	6.50	1	1	1
11/08/2022 23:00	1.4	12.4	2,137.2	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.4	2,141.9	0.9	168.90 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,972.1	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,281.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	1.3	12.4	2,147.1	0.9	6.40	1	1	1
11/09/2022 01:00	1.3	12.4	2,147.0	0.9	6.40	1	1	1
11/09/2022 02:00	1.4	12.3	2,184.9	1.0	8.70	1	1	1
11/09/2022 03:00	1.3	12.3	2,187.0	0.9	6.60	1	1	1
11/09/2022 04:00	1.3	12.5	2,154.3	0.9	6.50	1	1	1
11/09/2022 05:00	1.5	11.9	2,246.2	1.0	9.00	1	1	1
11/09/2022 06:00	1.4	11.9	2,284.3	0.9	6.90	1	1	1
11/09/2022 07:00	1.4	12.4	2,184.8	1.0	8.70	1	1	1
11/09/2022 08:00	1.4	12.5	2,147.6	1.0	8.60	1	1	1
11/09/2022 09:00	1.2	13.7	1,760.8	1.0	7.00	1	1	1
11/09/2022 10:00	1.1	13.9	1,725.2	0.9	5.20	1	1	0
11/09/2022 11:00	1.1	13.9	1,641.0	0.9	4.90	1	1	0
11/09/2022 12:00	1.1	13.9	1,716.3	0.9	5.10	1	1	0
11/09/2022 13:00	1.1	13.9	1,625.0	0.9	4.90	1	1	0
11/09/2022 14:00	1.1	13.9	1,698.0	0.9	5.10	1	1	0
11/09/2022 15:00	1.1	13.9	1,645.4	0.9	4.90	1	1	1
11/09/2022 16:00	1.3	12.8	2,074.2	0.9	6.20	1	1	1
11/09/2022 17:00	1.3	12.5	2,153.5	0.9	6.50	1	1	1
11/09/2022 18:00	1.2	13.1	2,009.9	0.9	6.00	1	1	1
11/09/2022 19:00	1.2	13.3	1,973.0	0.9	5.90	1	1	1
11/09/2022 20:00	1.2	13.3	1,976.7	0.9	5.90	1	1	1
11/09/2022 21:00	1.2	13.3	1,988.3	0.9	6.00	1	1	1
11/09/2022 22:00	1.2	13.3	1,979.1	0.9	5.90	1	1	1
11/09/2022 23:00	1.2	13.3	1,977.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.0	1,984.5	0.9	153.20 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,625.0	0.9	4.90	1	1	0
Maximum:	1.5	13.9	2,284.3	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.2	13.3	1,977.3	0.9	5.90	1	1	1
11/10/2022 01:00	1.2	13.3	1,975.5	0.9	5.90	1	1	1
11/10/2022 02:00	1.2	13.3	1,974.4	0.9	5.90	1	1	1
11/10/2022 03:00	1.2	13.3	1,977.4	0.9	5.90	1	1	1
11/10/2022 04:00	1.3	12.9	2,073.4	1.0	8.30	1	1	1
11/10/2022 05:00	1.5	12.3	2,174.8	1.0	8.70	1	1	1
11/10/2022 06:00	1.3	12.0	2,299.8	0.9	6.90	1	1	1
11/10/2022 07:00	1.3	12.7	2,110.5	0.9	6.30	1	1	1
11/10/2022 08:00	1.2	13.3	1,967.3	0.9	5.90	1	1	1
11/10/2022 09:00	1.2	13.3	1,948.5	0.9	5.80	1	1	1
11/10/2022 10:00	1.1	13.9	1,736.2	0.9	5.20	1	1	0
11/10/2022 11:00	1.2	13.9	1,728.1	1.0	6.90	1	1	0
11/10/2022 12:00	1.1	13.9	1,714.9	0.9	5.10	1	1	0
11/10/2022 13:00	1.1	14.0	1,570.6	0.9	4.70	1	1	0
11/10/2022 14:00	1.1	13.9	1,724.2	0.9	5.20	1	1	0
11/10/2022 15:00	1.1	13.9	1,723.1	0.9	5.20	1	1	1
11/10/2022 16:00	1.3	12.6	2,126.5	0.9	6.40	1	1	1
11/10/2022 17:00	1.4	11.9	2,271.9	0.9	6.80	1	1	1
11/10/2022 18:00	1.4	11.9	2,274.6	0.9	6.80	1	1	1
11/10/2022 19:00	1.4	11.9	2,278.5	0.9	6.80	1	1	1
11/10/2022 20:00	1.4	11.9	2,278.8	0.9	6.80	1	1	1
11/10/2022 21:00	1.4	11.9	2,281.7	0.9	6.80	1	1	1
11/10/2022 22:00	1.4	11.9	2,281.2	0.9	6.80	1	1	1
11/10/2022 23:00	1.4	12.0	2,256.4	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.9	2,030.2	0.9	151.80 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,570.6	0.9	4.70	1	1	0
Maximum:	1.5	14.0	2,299.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	1.4	12.0	2,281.8	0.9	6.80	1	1	1
11/11/2022 01:00	1.4	12.0	2,275.8	0.9	6.80	1	1	1
11/11/2022 02:00	1.3	12.6	2,145.1	0.9	6.40	1	1	1
11/11/2022 03:00	1.3	12.6	2,142.7	0.9	6.40	1	1	1
11/11/2022 04:00	1.4	12.1	2,271.6	0.9	6.80	1	1	1
11/11/2022 05:00	1.4	12.0	2,285.2	0.9	6.90	1	1	1
11/11/2022 06:00	1.4	12.0	2,284.1	0.9	6.90	1	1	1
11/11/2022 07:00	1.3	12.7	2,108.2	0.9	6.30	1	1	1
11/11/2022 08:00	1.2	13.3	1,940.2	0.9	5.80	1	1	1
11/11/2022 09:00	1.1	13.9	1,718.1	0.9	5.20	1	1	0
11/11/2022 10:00	1.1	13.9	1,724.0	0.9	5.20	1	1	0
11/11/2022 11:00	1.1	13.9	1,688.9	0.9	5.10	1	1	0
11/11/2022 12:00	1.1	13.9	1,687.5	0.9	5.10	1	1	0
11/11/2022 13:00	1.1	13.9	1,700.7	0.9	5.10	1	1	0
11/11/2022 14:00	1.1	13.9	1,582.3	0.9	4.70	1	1	0
11/11/2022 15:00	1.1	13.9	1,688.6	0.9	5.10	1	1	0
11/11/2022 16:00	1.3	13.0	1,979.8	1.0	7.90	1	1	1
11/11/2022 17:00	1.4	11.8	2,273.3	0.9	6.80	1	1	1
11/11/2022 18:00	1.4	11.9	2,266.1	0.9	6.80	1	1	1
11/11/2022 19:00	1.4	11.9	2,254.1	0.9	6.80	1	1	1
11/11/2022 20:00	1.4	11.9	2,250.8	0.9	6.80	1	1	1
11/11/2022 21:00	1.4	11.9	2,249.2	0.9	6.70	1	1	1
11/11/2022 22:00	1.4	12.1	2,243.3	0.9	6.70	1	1	1
11/11/2022 23:00	1.4	12.0	2,260.9	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.7	2,054.3	0.9	149.90 #	24 #	24 #	17 #
Minimum:	1.1	11.8	1,582.3	0.9	4.70	1	1	0
Maximum:	1.4	13.9	2,285.2	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	1.4	12.0	2,265.2	0.9	6.80	1	1	1
11/12/2022 01:00	1.4	12.0	2,268.8	0.9	6.80	1	1	1
11/12/2022 02:00	1.4	12.0	2,275.3	0.9	6.80	1	1	1
11/12/2022 03:00	1.4	12.0	2,278.8	0.9	6.80	1	1	1
11/12/2022 04:00	1.4	12.0	2,285.3	0.9	6.90	1	1	1
11/12/2022 05:00	1.4	12.0	2,286.6	0.9	6.90	1	1	1
11/12/2022 06:00	1.4	12.0	2,277.1	0.9	6.80	1	1	1
11/12/2022 07:00	1.3	12.7	2,119.5	0.9	6.40	1	1	1
11/12/2022 08:00	1.4	12.2	2,196.2	0.9	6.60	1	1	1
11/12/2022 09:00	1.1	13.7	1,755.8	0.9	5.30	1	1	1
11/12/2022 10:00	1.1	13.9	1,596.8	0.9	4.80	1	1	0
11/12/2022 11:00	1.1	13.9	1,557.9	0.9	4.70	1	1	0
11/12/2022 12:00	1.1	13.9	1,557.2	0.9	4.70	1	1	0
11/12/2022 13:00	1.1	13.9	1,580.9	0.9	4.70	1	1	0
11/12/2022 14:00	1.1	13.9	1,557.8	0.9	4.70	1	1	0
11/12/2022 15:00	1.1	13.8	1,793.1	0.9	5.40	1	1	1
11/12/2022 16:00	1.3	12.5	2,136.2	0.9	6.40	1	1	1
11/12/2022 17:00	1.4	11.8	2,289.6	0.9	6.90	1	1	1
11/12/2022 18:00	1.4	11.8	2,288.4	0.9	6.90	1	1	1
11/12/2022 19:00	1.4	11.8	2,294.2	0.9	6.90	1	1	1
11/12/2022 20:00	1.4	11.8	2,304.8	0.9	6.90	1	1	1
11/12/2022 21:00	1.4	11.8	2,300.6	0.9	6.90	1	1	1
11/12/2022 22:00	1.4	12.3	2,197.1	1.0	8.80	1	1	1
11/12/2022 23:00	1.3	12.3	2,192.7	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.6	2,069.0	0.9	151.40 #	24 #	24 #	19 #
Minimum:	1.1	11.8	1,557.2	0.9	4.70	1	1	0
Maximum:	1.4	13.9	2,304.8	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	1.3	12.4	2,183.0	0.9	6.50	1	1	1
11/13/2022 01:00	1.4	12.4	2,169.4	1.0	8.70	1	1	1
11/13/2022 02:00	1.3	12.5	2,162.2	0.9	6.50	1	1	1
11/13/2022 03:00	1.3	12.3	2,198.3	0.9	6.60	1	1	1
11/13/2022 04:00	1.4	12.4	2,192.5	1.0	8.80	1	1	1
11/13/2022 05:00	1.3	12.4	2,185.1	0.9	6.60	1	1	1
11/13/2022 06:00	1.4	12.3	2,201.5	1.0	8.80	1	1	1
11/13/2022 07:00	1.4	12.0	2,269.1	0.9	6.80	1	1	1
11/13/2022 08:00	1.2	12.9	1,972.8	0.9	5.90	1	1	1
11/13/2022 09:00	1.1	13.9	1,713.6	0.9	5.10	1	1	0
11/13/2022 10:00	1.1	13.9	1,714.5	0.9	5.10	1	1	0
11/13/2022 11:00	1.1	13.9	1,714.3	0.9	5.10	1	1	0
11/13/2022 12:00	1.1	13.9	1,712.3	0.9	5.10	1	1	0
11/13/2022 13:00	1.1	14.0	1,713.9	0.9	5.10	1	1	0
11/13/2022 14:00	1.1	14.0	1,686.9	0.9	5.10	1	1	0
11/13/2022 15:00	1.1	13.8	1,797.5	0.9	5.40	1	1	1
11/13/2022 16:00	1.4	12.6	2,132.3	1.0	8.50	1	1	1
11/13/2022 17:00	1.4	12.0	2,273.8	0.9	6.80	1	1	1
11/13/2022 18:00	1.4	12.0	2,273.5	0.9	6.80	1	1	1
11/13/2022 19:00	1.4	12.0	2,277.3	0.9	6.80	1	1	1
11/13/2022 20:00	1.3	12.0	2,280.0	0.9	6.80	1	1	1
11/13/2022 21:00	1.4	12.0	2,284.9	0.9	6.90	1	1	1
11/13/2022 22:00	1.3	12.0	2,287.2	0.9	6.90	1	1	1
11/13/2022 23:00	1.4	12.0	2,294.0	0.9	6.90	1	1	1
Average/Sum#:	1.3	12.7	2,070.4	0.9	157.60 #	24 #	24 #	18 #
Minimum:	1.1	12.0	1,686.9	0.9	5.10	1	1	0
Maximum:	1.4	14.0	2,294.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	1.3	12.1	2,288.4	0.9	6.90	1	1	1
11/14/2022 01:00	1.4	12.1	2,277.6	0.9	6.80	1	1	1
11/14/2022 02:00	1.3	12.2	2,265.6	0.9	6.80	1	1	1
11/14/2022 03:00	1.3	12.7	2,149.5	0.9	6.40	1	1	1
11/14/2022 04:00	1.4	12.4	2,230.6	1.0	8.90	1	1	1
11/14/2022 05:00	1.4	12.2	2,291.8	0.9	6.90	1	1	1
11/14/2022 06:00	1.4	12.2	2,286.5	0.9	6.90	1	1	1
11/14/2022 07:00	1.3	12.6	2,184.1	0.9	6.60	1	1	1
11/14/2022 08:00	1.3	12.7	2,143.2	0.9	6.40	1	1	1
11/14/2022 09:00	1.3	12.6	2,149.5	0.9	6.40	1	1	1
11/14/2022 10:00	1.3	12.6	2,141.4	0.9	6.40	1	1	1
11/14/2022 11:00	1.3	12.7	2,116.8	0.9	6.40	1	1	1
11/14/2022 12:00	1.3	12.7	2,106.1	0.9	6.30	1	1	1
11/14/2022 13:00	1.3	12.5	2,137.1	0.9	6.40	1	1	1
11/14/2022 14:00	1.3	12.5	2,137.4	0.9	6.40	1	1	1
11/14/2022 15:00	1.3	12.8	2,062.7	0.9	6.20	1	1	1
11/14/2022 16:00	1.4	12.1	2,229.8	0.9	6.70	1	1	1
11/14/2022 17:00	1.3	12.3	2,177.1	0.9	6.50	1	1	1
11/14/2022 18:00	1.3	12.5	2,159.1	0.9	6.50	1	1	1
11/14/2022 19:00	1.4	12.1	2,265.3	0.9	6.80	1	1	1
11/14/2022 20:00	1.3	12.0	2,281.3	0.9	6.80	1	1	1
11/14/2022 21:00	1.4	12.1	2,256.1	0.9	6.80	1	1	1
11/14/2022 22:00	1.3	12.1	2,259.7	0.9	6.80	1	1	1
11/14/2022 23:00	1.3	12.2	2,239.5	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,201.5	0.9	160.70 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,062.7	0.9	6.20	1	1	1
Maximum:	1.4	12.8	2,291.8	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2022 00:00	1.4	12.1	2,265.0	0.9	6.80	1	1	1
11/15/2022 01:00	1.3	12.1	2,268.0	0.9	6.80	1	1	1
11/15/2022 02:00	1.4	12.0	2,286.6	0.9	6.90	1	1	1
11/15/2022 03:00	1.4	12.0	2,296.0	0.9	6.90	1	1	1
11/15/2022 04:00	1.3	12.0	2,299.8	0.9	6.90	1	1	1
11/15/2022 05:00	1.3	11.7	2,332.5	0.8	7.00	1	1	1
11/15/2022 06:00	1.4	12.2	2,202.6	0.9	6.60	1	1	1
11/15/2022 07:00	1.4	11.8	2,323.2	0.9	7.00	1	1	1
11/15/2022 08:00	1.4	12.0	2,234.7	0.9	6.70	1	1	1
11/15/2022 09:00	1.3	12.6	2,114.0	0.9	6.30	1	1	1
11/15/2022 10:00	1.3	12.5	2,135.7	0.9	6.40	1	1	1
11/15/2022 11:00	1.2	12.9	2,037.3	0.9	6.10	1	1	1
11/15/2022 12:00	1.2	13.3	1,961.1	0.9	5.90	1	1	1
11/15/2022 13:00	1.2	13.3	1,967.3	0.9	5.90	1	1	1
11/15/2022 14:00	0.0	0.0	1,973.8	0.0	0.00	1	1	1
11/15/2022 15:00	0.0	0.0	2,007.0	0.0	0.00	1	1	1
11/15/2022 16:00	1.3	12.5	2,120.1	0.9	6.40	1	1	1
11/15/2022 17:00	1.4	12.4	2,133.8	1.0	8.50	1	1	1
11/15/2022 18:00	1.4	12.4	2,123.0	1.0	8.50	1	1	1
11/15/2022 19:00	1.3	12.3	2,137.1	0.9	6.40	1	1	1
11/15/2022 20:00	1.4	12.2	2,175.2	0.9	6.50	1	1	1
11/15/2022 21:00	1.4	11.9	2,237.4	0.9	6.70	1	1	1
11/15/2022 22:00	1.4	12.3	2,149.1	1.0	8.60	1	1	1
11/15/2022 23:00	1.4	12.3	2,148.1	1.0	8.60	1	1	1
Average/Sum#:	1.3	12.3	2,163.7	0.9	152.40 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,961.1	0.8	5.90	1	1	1
Maximum:	1.4	13.3	2,332.5	1.0	8.60	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	1.4	12.3	2,142.4	1.0	8.60	1	1	1
11/16/2022 01:00	1.3	12.5	2,116.0	0.9	6.30	1	1	1
11/16/2022 02:00	1.4	12.4	2,139.8	1.0	8.60	1	1	1
11/16/2022 03:00	1.4	12.4	2,144.4	1.0	8.60	1	1	1
11/16/2022 04:00	1.4	11.9	2,274.6	0.9	6.80	1	1	1
11/16/2022 05:00	1.5	11.5	2,340.0	0.9	7.00	1	1	1
11/16/2022 06:00	1.4	11.5	2,346.5	0.9	7.00	1	1	1
11/16/2022 07:00	1.4	11.9	2,254.3	0.9	6.80	1	1	1
11/16/2022 08:00	0.5	13.3	1,966.8	0.4	2.00	1	1	1
11/16/2022 09:00	0.0	13.6	1,997.0	0.0	0.00	1	1	1
11/16/2022 10:00	1.2	13.2	1,964.8	0.9	5.90	1	1	1
11/16/2022 11:00	1.2	13.2	1,969.2	0.9	5.90	1	1	1
11/16/2022 12:00	1.3	13.1	1,978.0	1.0	7.90	1	1	1
11/16/2022 13:00	1.2	13.1	1,980.5	0.9	5.90	1	1	1
11/16/2022 14:00	1.3	13.1	1,981.2	1.0	7.90	1	1	1
11/16/2022 15:00	1.3	12.6	2,101.9	0.9	6.30	1	1	1
11/16/2022 16:00	1.3	12.3	2,161.6	0.9	6.50	1	1	1
11/16/2022 17:00	1.4	12.3	2,165.8	1.0	8.70	1	1	1
11/16/2022 18:00	1.4	12.0	2,221.6	0.9	6.70	1	1	1
11/16/2022 19:00	1.4	11.9	2,228.4	0.9	6.70	1	1	1
11/16/2022 20:00	1.4	11.9	2,229.7	0.9	6.70	1	1	1
11/16/2022 21:00	1.4	12.0	2,244.6	0.9	6.70	1	1	1
11/16/2022 22:00	1.4	12.2	2,216.3	0.9	6.60	1	1	1
11/16/2022 23:00	1.4	12.0	2,243.9	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,142.1	0.9	156.80 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,964.8	0.0	0.00	1	1	1
Maximum:	1.5	13.6	2,346.5	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	1.3	12.4	2,159.1	0.9	6.50	1	1	1
11/17/2022 01:00	1.4	12.4	2,159.4	1.0	8.60	1	1	1
11/17/2022 02:00	1.3	12.5	2,146.1	0.9	6.40	1	1	1
11/17/2022 03:00	1.3	12.5	2,149.6	0.9	6.40	1	1	1
11/17/2022 04:00	1.4	12.2	2,231.0	0.9	6.70	1	1	1
11/17/2022 05:00	1.3	11.6	2,357.0	0.8	7.10	1	1	1
11/17/2022 06:00	1.4	11.9	2,276.3	0.9	6.80	1	1	1
11/17/2022 07:00	1.4	12.4	2,162.7	1.0	8.70	1	1	1
11/17/2022 08:00	1.3	13.1	1,985.4	1.0	7.90	1	1	1
11/17/2022 09:00	1.4	12.5	2,129.0	1.0	8.50	1	1	1
11/17/2022 10:00	1.3	12.5	2,110.8	0.9	6.30	1	1	1
11/17/2022 11:00	1.3	12.3	2,133.9	0.9	6.40	1	1	1
11/17/2022 12:00	1.4	12.1	2,171.5	0.9	6.50	1	1	1
11/17/2022 13:00	1.4	12.2	2,169.8	0.9	6.50	1	1	1
11/17/2022 14:00	1.3	12.9	2,005.0	1.0	8.00	1	1	1
11/17/2022 15:00	1.3	12.4	2,118.7	0.9	6.40	1	1	1
11/17/2022 16:00	1.4	11.9	2,234.9	0.9	6.70	1	1	1
11/17/2022 17:00	1.4	11.8	2,268.2	0.9	6.80	1	1	1
11/17/2022 18:00	1.4	11.8	2,255.7	0.9	6.80	1	1	1
11/17/2022 19:00	1.4	11.8	2,258.8	0.9	6.80	1	1	1
11/17/2022 20:00	1.4	11.8	2,260.2	0.9	6.80	1	1	1
11/17/2022 21:00	1.4	11.8	2,262.4	0.9	6.80	1	1	1
11/17/2022 22:00	1.4	11.9	2,246.4	0.9	6.70	1	1	1
11/17/2022 23:00	1.4	12.2	2,206.6	0.9	6.60	1	1	1
Average/Sum#:	1.4	12.2	2,185.8	0.9	167.70 #	24 #	24 #	24 #
Minimum:	1.3	11.6	1,985.4	0.8	6.30	1	1	1
Maximum:	1.4	13.1	2,357.0	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	1.3	12.4	2,157.1	0.9	6.50	1	1	1
11/18/2022 01:00	1.4	12.3	2,164.4	1.0	8.70	1	1	1
11/18/2022 02:00	1.4	12.2	2,166.7	0.9	6.50	1	1	1
11/18/2022 03:00	1.4	12.3	2,166.0	1.0	8.70	1	1	1
11/18/2022 04:00	1.4	11.6	2,308.1	0.9	6.90	1	1	1
11/18/2022 05:00	1.4	11.5	2,326.0	0.9	7.00	1	1	1
11/18/2022 06:00	1.4	11.5	2,333.1	0.9	7.00	1	1	1
11/18/2022 07:00	1.4	11.8	2,267.0	0.9	6.80	1	1	1
11/18/2022 08:00	1.4	12.3	2,145.7	1.0	8.60	1	1	1
11/18/2022 09:00	1.4	12.3	2,153.7	1.0	8.60	1	1	1
11/18/2022 10:00	1.4	12.2	2,162.8	0.9	6.50	1	1	1
11/18/2022 11:00	1.3	12.4	2,100.8	0.9	6.30	1	1	1
11/18/2022 12:00	1.3	13.1	1,958.4	1.0	7.80	1	1	1
11/18/2022 13:00	1.3	13.1	1,960.1	1.0	7.80	1	1	1
11/18/2022 14:00	1.2	13.0	1,964.5	0.9	5.90	1	1	1
11/18/2022 15:00	1.3	12.7	2,040.1	0.9	6.10	1	1	1
11/18/2022 16:00	1.4	12.0	2,220.5	0.9	6.70	1	1	1
11/18/2022 17:00	1.4	11.9	2,244.9	0.9	6.70	1	1	1
11/18/2022 18:00	1.4	11.9	2,243.3	0.9	6.70	1	1	1
11/18/2022 19:00	1.4	11.9	2,245.4	0.9	6.70	1	1	1
11/18/2022 20:00	1.4	11.8	2,276.3	0.9	6.80	1	1	1
11/18/2022 21:00	1.4	11.6	2,328.6	0.9	7.00	1	1	1
11/18/2022 22:00	1.4	11.6	2,341.0	0.9	7.00	1	1	1
11/18/2022 23:00	1.4	11.8	2,301.5	0.9	6.90	1	1	1
Average/Sum#:	1.4	12.1	2,190.7	0.9	170.20 #	24 #	24 #	24 #
Minimum:	1.2	11.5	1,958.4	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,341.0	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	1.3	12.3	2,163.6	0.9	6.50	1	1	1
11/19/2022 01:00	1.3	12.5	2,142.3	0.9	6.40	1	1	1
11/19/2022 02:00	1.3	12.5	2,139.1	0.9	6.40	1	1	1
11/19/2022 03:00	1.3	12.6	2,118.3	0.9	6.40	1	1	1
11/19/2022 04:00	1.4	12.1	2,231.5	0.9	6.70	1	1	1
11/19/2022 05:00	1.3	11.9	2,257.3	0.9	6.80	1	1	1
11/19/2022 06:00	1.4	12.3	2,191.6	1.0	8.80	1	1	1
11/19/2022 07:00	1.3	12.5	2,123.0	0.9	6.40	1	1	1
11/19/2022 08:00	1.2	13.2	1,963.6	0.9	5.90	1	1	1
11/19/2022 09:00	1.2	13.2	1,961.7	0.9	5.90	1	1	1
11/19/2022 10:00	1.2	13.2	1,956.6	0.9	5.90	1	1	1
11/19/2022 11:00	1.3	13.1	1,953.3	1.0	7.80	1	1	1
11/19/2022 12:00	1.2	13.1	1,953.3	0.9	5.90	1	1	1
11/19/2022 13:00	1.3	13.1	1,954.1	1.0	7.80	1	1	1
11/19/2022 14:00	1.3	13.1	1,960.9	1.0	7.80	1	1	1
11/19/2022 15:00	1.3	12.8	2,021.3	0.9	6.10	1	1	1
11/19/2022 16:00	1.4	12.2	2,156.6	0.9	6.50	1	1	1
11/19/2022 17:00	1.4	12.1	2,176.7	0.9	6.50	1	1	1
11/19/2022 18:00	1.4	12.2	2,169.1	0.9	6.50	1	1	1
11/19/2022 19:00	1.4	11.8	2,273.1	0.9	6.80	1	1	1
11/19/2022 20:00	1.4	11.6	2,305.7	0.9	6.90	1	1	1
11/19/2022 21:00	1.4	11.6	2,312.8	0.9	6.90	1	1	1
11/19/2022 22:00	1.4	11.7	2,340.7	0.9	7.00	1	1	1
11/19/2022 23:00	1.5	11.6	2,358.5	1.0	9.40	1	1	1
Average/Sum#:	1.3	12.4	2,132.7	0.9	164.00 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,953.3	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,358.5	1.0	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	1.4	12.0	2,254.8	0.9	6.80	1	1	1
11/20/2022 01:00	1.4	11.9	2,273.0	0.9	6.80	1	1	1
11/20/2022 02:00	1.4	11.8	2,301.3	0.9	6.90	1	1	1
11/20/2022 03:00	1.5	11.9	2,301.2	1.0	9.20	1	1	1
11/20/2022 04:00	1.4	11.9	2,306.4	0.9	6.90	1	1	1
11/20/2022 05:00	1.5	11.7	2,350.0	1.0	9.40	1	1	1
11/20/2022 06:00	1.4	12.1	2,254.5	0.9	6.80	1	1	1
11/20/2022 07:00	1.3	12.6	2,096.3	0.9	6.30	1	1	1
11/20/2022 08:00	1.2	13.8	1,722.3	1.0	6.90	1	1	0
11/20/2022 09:00	1.1	13.8	1,725.4	0.9	5.20	1	1	0
11/20/2022 10:00	1.2	13.8	1,571.5	1.0	6.30	1	1	0
11/20/2022 11:00	1.1	13.9	1,573.6	0.9	4.70	1	1	0
11/20/2022 12:00	1.1	13.9	1,545.9	0.9	4.60	1	1	0
11/20/2022 13:00	1.1	13.9	1,536.5	0.9	4.60	1	1	0
11/20/2022 14:00	1.2	13.8	1,695.0	1.0	6.80	1	1	0
11/20/2022 15:00	1.2	13.8	1,732.2	1.0	6.90	1	1	1
11/20/2022 16:00	1.3	12.3	2,147.2	0.9	6.40	1	1	1
11/20/2022 17:00	1.4	11.8	2,265.5	0.9	6.80	1	1	1
11/20/2022 18:00	1.4	11.8	2,252.2	0.9	6.80	1	1	1
11/20/2022 19:00	1.4	11.8	2,253.5	0.9	6.80	1	1	1
11/20/2022 20:00	1.4	11.8	2,257.4	0.9	6.80	1	1	1
11/20/2022 21:00	1.4	12.1	2,192.6	0.9	6.60	1	1	1
11/20/2022 22:00	1.3	12.4	2,157.4	0.9	6.50	1	1	1
11/20/2022 23:00	1.3	12.5	2,147.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.6	2,038.1	0.9	158.20 #	24 #	24 #	17 #
Minimum:	1.1	11.7	1,536.5	0.9	4.60	1	1	0
Maximum:	1.5	13.9	2,350.0	1.0	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2022 00:00	1.3	12.4	2,156.8	0.9	6.50	1	1	1
11/21/2022 01:00	1.3	12.6	2,130.5	0.9	6.40	1	1	1
11/21/2022 02:00	1.3	12.9	2,058.0	1.0	8.20	1	1	1
11/21/2022 03:00	1.4	12.4	2,172.2	1.0	8.70	1	1	1
11/21/2022 04:00	1.4	12.0	2,259.2	0.9	6.80	1	1	1
11/21/2022 05:00	1.5	12.0	2,267.5	1.0	9.10	1	1	1
11/21/2022 06:00	1.4	12.0	2,284.4	0.9	6.90	1	1	1
11/21/2022 07:00	1.3	12.5	2,147.1	0.9	6.40	1	1	1
11/21/2022 08:00	1.2	13.2	1,965.1	0.9	5.90	1	1	1
11/21/2022 09:00	1.2	13.2	1,965.2	0.9	5.90	1	1	1
11/21/2022 10:00	1.2	13.2	1,961.7	0.9	5.90	1	1	1
11/21/2022 11:00	1.3	13.1	1,958.9	1.0	7.80	1	1	1
11/21/2022 12:00	1.3	13.0	1,966.2	1.0	7.90	1	1	1
11/21/2022 13:00	1.2	13.0	1,977.7	0.9	5.90	1	1	1
11/21/2022 14:00	1.4	12.2	2,161.3	0.9	6.50	1	1	1
11/21/2022 15:00	1.4	11.8	2,272.0	0.9	6.80	1	1	1
11/21/2022 16:00	1.4	12.0	2,229.0	0.9	6.70	1	1	1
11/21/2022 17:00	1.4	11.9	2,230.9	0.9	6.70	1	1	1
11/21/2022 18:00	1.4	11.9	2,230.5	0.9	6.70	1	1	1
11/21/2022 19:00	1.4	11.8	2,258.6	0.9	6.80	1	1	1
11/21/2022 20:00	1.4	11.8	2,263.5	0.9	6.80	1	1	1
11/21/2022 21:00	1.4	11.8	2,264.2	0.9	6.80	1	1	1
11/21/2022 22:00	1.4	11.8	2,264.8	0.9	6.80	1	1	1
11/21/2022 23:00	1.4	12.0	2,226.0	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,153.0	0.9	165.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,958.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,284.4	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2022 00:00	1.3	12.4	2,143.9	0.9	6.40	1	1	1
11/22/2022 01:00	1.3	12.6	2,125.4	0.9	6.40	1	1	1
11/22/2022 02:00	1.3	12.6	2,094.4	0.9	6.30	1	1	1
11/22/2022 03:00	1.2	13.1	1,973.7	0.9	5.90	1	1	1
11/22/2022 04:00	1.3	13.1	1,977.2	1.0	7.90	1	1	1
11/22/2022 05:00	1.3	12.6	2,065.9	0.9	6.20	1	1	1
11/22/2022 06:00	1.3	12.5	2,149.0	0.9	6.40	1	1	1
11/22/2022 07:00	1.3	12.7	2,088.9	0.9	6.30	1	1	1
11/22/2022 08:00	1.3	12.9	2,051.0	1.0	8.20	1	1	1
11/22/2022 09:00	1.9	14.2	1,444.6	1.7	7.40	1	0	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2022 11:00	0.0	19.5	58.0	0.0	0.00	1	0	0
11/22/2022 12:00	12.6	15.8	756.7	14.6	40.90	1	0	0
11/22/2022 13:00	1.1	13.8	1,622.5	0.9	4.90	1	1	0
11/22/2022 14:00	1.1	13.8	1,790.4	0.9	5.40	1	1	0
11/22/2022 15:00	1.2	13.8	1,790.4	1.0	7.20	1	1	0
11/22/2022 16:00	1.3	13.2	1,897.6	1.0	7.60	1	1	1
11/22/2022 17:00	1.4	12.3	2,141.8	1.0	8.60	1	1	1
11/22/2022 18:00	1.3	12.7	2,035.3	0.9	6.10	1	1	1
11/22/2022 19:00	1.3	13.0	1,982.5	1.0	7.90	1	1	1
11/22/2022 20:00	1.4	12.4	2,138.7	1.0	8.60	1	1	1
11/22/2022 21:00	1.3	12.9	2,017.6	1.0	8.10	1	1	1
11/22/2022 22:00	1.3	12.8	2,028.8	0.9	6.10	1	1	1
11/22/2022 23:00	1.2	13.2	1,957.5	0.9	5.90	1	1	1
Average/Sum#:	1.7	13.4	1,840.5	1.5	184.70 #	23 #	20 #	18 #
Minimum:	0.0	12.3	58.0	0.0	0.00	0	0	0
Maximum:	12.6	19.5	2,149.0	14.6	40.90	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.2	13.2	1,958.7	0.9	5.90	1	1	1
11/23/2022 01:00	1.2	13.2	1,960.6	0.9	5.90	1	1	1
11/23/2022 02:00	1.2	13.2	1,958.4	0.9	5.90	1	1	1
11/23/2022 03:00	1.2	13.2	1,962.5	0.9	5.90	1	1	1
11/23/2022 04:00	1.2	13.1	1,969.2	0.9	5.90	1	1	1
11/23/2022 05:00	1.5	12.5	2,057.1	1.1	8.20	1	1	1
11/23/2022 06:00	1.3	12.8	2,048.5	0.9	6.10	1	1	1
11/23/2022 07:00	1.3	12.6	2,103.9	0.9	6.30	1	1	1
11/23/2022 08:00	1.3	13.0	1,993.7	1.0	8.00	1	1	1
11/23/2022 09:00	1.1	13.8	1,707.7	0.9	5.10	1	1	0
11/23/2022 10:00	1.1	13.8	1,562.1	0.9	4.70	1	1	0
11/23/2022 11:00	1.1	13.9	1,556.2	0.9	4.70	1	1	0
11/23/2022 12:00	1.1	13.9	1,424.7	0.9	4.30	1	1	0
11/23/2022 13:00	1.1	13.9	1,558.7	0.9	4.70	1	1	0
11/23/2022 14:00	1.1	13.9	1,628.7	0.9	4.90	1	1	0
11/23/2022 15:00	1.2	13.8	1,649.5	1.0	6.60	1	1	1
11/23/2022 16:00	1.3	12.5	2,097.1	0.9	6.30	1	1	1
11/23/2022 17:00	1.4	12.3	2,159.6	1.0	8.60	1	1	1
11/23/2022 18:00	1.3	12.6	2,078.6	0.9	6.20	1	1	1
11/23/2022 19:00	1.3	12.8	2,045.2	0.9	6.10	1	1	1
11/23/2022 20:00	1.4	12.3	2,155.0	1.0	8.60	1	1	1
11/23/2022 21:00	1.4	12.2	2,168.6	0.9	6.50	1	1	1
11/23/2022 22:00	1.4	12.4	2,143.6	1.0	8.60	1	1	1
11/23/2022 23:00	1.3	12.4	2,140.6	0.9	6.40	1	1	1
Average/Sum#:	1.3	13.1	1,920.4	0.9	150.40 #	24 #	24 #	18 #
Minimum:	1.1	12.2	1,424.7	0.9	4.30	1	1	0
Maximum:	1.5	13.9	2,168.6	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.3	13.1	1,975.4	1.0	7.90	1	1	1
11/24/2022 01:00	1.3	13.2	1,962.5	1.0	7.90	1	1	1
11/24/2022 02:00	1.2	13.2	1,963.6	0.9	5.90	1	1	1
11/24/2022 03:00	1.3	13.0	1,975.0	1.0	7.90	1	1	1
11/24/2022 04:00	1.3	12.9	1,985.5	1.0	7.90	1	1	1
11/24/2022 05:00	1.4	12.5	2,052.9	1.0	8.20	1	1	1
11/24/2022 06:00	1.4	12.2	2,165.6	0.9	6.50	1	1	1
11/24/2022 07:00	1.3	12.5	2,079.4	0.9	6.20	1	1	1
11/24/2022 08:00	1.1	13.8	1,712.0	0.9	5.10	1	1	0
11/24/2022 09:00	1.1	13.8	1,709.0	0.9	5.10	1	1	0
11/24/2022 10:00	1.2	13.8	1,716.4	1.0	6.90	1	1	0
11/24/2022 11:00	1.1	13.9	1,560.1	0.9	4.70	1	1	0
11/24/2022 12:00	1.1	13.9	1,351.9	0.9	4.10	1	1	0
11/24/2022 13:00	1.1	13.9	1,350.9	0.9	4.10	1	1	0
11/24/2022 14:00	1.1	13.9	1,562.2	0.9	4.70	1	1	0
11/24/2022 15:00	1.1	13.9	1,450.2	0.9	4.40	1	1	0
11/24/2022 16:00	1.2	13.8	1,769.5	1.0	7.10	1	1	0
11/24/2022 17:00	1.2	13.8	1,768.6	1.0	7.10	1	1	0
11/24/2022 18:00	1.1	13.8	1,745.4	0.9	5.20	1	1	0
11/24/2022 19:00	1.2	13.8	1,737.1	1.0	6.90	1	1	0
11/24/2022 20:00	1.1	13.8	1,746.5	0.9	5.20	1	1	0
11/24/2022 21:00	1.1	13.8	1,747.1	0.9	5.20	1	1	0
11/24/2022 22:00	1.2	13.8	1,751.3	1.0	7.00	1	1	0
11/24/2022 23:00	1.2	13.8	1,753.2	1.0	7.00	1	1	0
Average/Sum#:	1.2	13.5	1,774.6	0.9	148.20 #	24 #	24 #	8 #
Minimum:	1.1	12.2	1,350.9	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,165.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	1.1	13.8	1,757.2	0.9	5.30	1	1	0
11/25/2022 01:00	1.2	13.8	1,758.4	1.0	7.00	1	1	0
11/25/2022 02:00	1.1	13.8	1,761.0	0.9	5.30	1	1	0
11/25/2022 03:00	1.2	13.8	1,764.3	1.0	7.10	1	1	0
11/25/2022 04:00	1.2	13.8	1,775.1	1.0	7.10	1	1	0
11/25/2022 05:00	1.1	13.8	1,771.2	0.9	5.30	1	1	0
11/25/2022 06:00	1.2	13.8	1,766.8	1.0	7.10	1	1	0
11/25/2022 07:00	1.1	13.8	1,766.8	0.9	5.30	1	1	0
11/25/2022 08:00	1.2	13.4	1,882.1	0.9	5.60	1	1	1
11/25/2022 09:00	1.2	13.1	1,919.7	0.9	5.80	1	1	1
11/25/2022 10:00	1.1	13.8	1,668.0	0.9	5.00	1	1	0
11/25/2022 11:00	1.1	13.8	1,549.0	0.9	4.60	1	1	0
11/25/2022 12:00	1.1	13.8	1,574.7	0.9	4.70	1	1	0
11/25/2022 13:00	1.1	13.8	1,543.3	0.9	4.60	1	1	0
11/25/2022 14:00	1.1	13.8	1,531.6	0.9	4.60	1	1	0
11/25/2022 15:00	1.1	13.7	1,644.3	0.9	4.90	1	1	1
11/25/2022 16:00	1.4	12.6	2,082.1	1.0	8.30	1	1	1
11/25/2022 17:00	1.3	12.5	2,096.7	0.9	6.30	1	1	1
11/25/2022 18:00	1.3	13.0	1,970.2	1.0	7.90	1	1	1
11/25/2022 19:00	1.3	13.1	1,955.6	1.0	7.80	1	1	1
11/25/2022 20:00	1.2	13.1	1,955.0	0.9	5.90	1	1	1
11/25/2022 21:00	1.2	13.1	1,966.3	0.9	5.90	1	1	1
11/25/2022 22:00	1.3	12.5	2,118.6	0.9	6.40	1	1	1
11/25/2022 23:00	1.3	12.6	2,080.0	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.4	1,819.1	0.9	144.00 #	24 #	24 #	11 #
Minimum:	1.1	12.5	1,531.6	0.9	4.60	1	1	0
Maximum:	1.4	13.8	2,118.6	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.3	12.9	2,016.8	1.0	8.10	1	1	1
11/26/2022 01:00	1.3	12.7	2,062.0	0.9	6.20	1	1	1
11/26/2022 02:00	1.9	13.8	1,575.4	1.6	9.50	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	13.1	1,884.7	1.2	23.80 #	3 #	2 #	3 #
Minimum:	1.3	12.7	1,575.4	0.9	6.20	0	0	0
Maximum:	1.9	13.8	2,062.0	1.6	9.50	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2022 02:00	31.3	17.4	344.2	52.8	63.46	1	0	0
11/28/2022 03:00	11.2	15.2	949.6	11.6	40.80	1	0	0
11/28/2022 04:00	1.2	13.7	1,724.6	1.0	6.90	1	1	0
11/28/2022 05:00	1.2	13.7	1,654.5	1.0	6.60	1	1	1
11/28/2022 06:00	1.3	12.5	2,164.7	0.9	6.50	1	1	1
11/28/2022 07:00	1.4	12.0	2,260.4	0.9	6.80	1	1	1
11/28/2022 08:00	1.3	13.0	1,970.9	1.0	7.90	1	1	1
11/28/2022 09:00	1.2	13.8	1,613.8	1.0	6.50	1	1	0
11/28/2022 10:00	1.2	13.8	1,719.0	1.0	6.90	1	1	0
11/28/2022 11:00	1.1	13.8	1,526.4	0.9	4.60	1	1	0
11/28/2022 12:00	1.1	13.8	1,571.0	0.9	4.70	1	1	0
11/28/2022 13:00	1.2	13.8	1,644.0	1.0	6.60	1	1	0
11/28/2022 14:00	1.1	13.8	1,627.3	0.9	4.90	1	1	0
11/28/2022 15:00	1.2	13.7	1,623.7	1.0	6.50	1	1	1
11/28/2022 16:00	1.3	12.8	2,023.4	0.9	6.10	1	1	1
11/28/2022 17:00	1.3	12.5	2,090.0	0.9	6.30	1	1	1
11/28/2022 18:00	1.3	13.0	1,980.4	1.0	7.90	1	1	1
11/28/2022 19:00	1.2	13.1	1,958.5	0.9	5.90	1	1	1
11/28/2022 20:00	1.3	12.7	2,080.3	0.9	6.20	1	1	1
11/28/2022 21:00	1.4	12.1	2,212.4	0.9	6.60	1	1	1
11/28/2022 22:00	1.3	12.7	2,084.2	0.9	6.30	1	1	1
11/28/2022 23:00	1.3	13.1	1,981.7	1.0	7.90	1	1	1
Average/Sum#:	3.1	13.5	1,763.9	3.8	232.86 #	22 #	20 #	13 #
Minimum:	1.1	12.0	344.2	0.9	4.60	0	0	0
Maximum:	31.3	17.4	2,260.4	52.8	63.46	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	1.3	12.4	2,141.8	0.9	6.40	1	1	1
11/29/2022 01:00	1.4	12.3	2,186.9	1.0	8.70	1	1	1
11/29/2022 02:00	1.4	12.3	2,175.4	1.0	8.70	1	1	1
11/29/2022 03:00	1.3	12.7	2,087.1	0.9	6.30	1	1	1
11/29/2022 04:00	1.3	12.5	2,149.0	0.9	6.40	1	1	1
11/29/2022 05:00	1.3	12.3	2,196.7	0.9	6.60	1	1	1
11/29/2022 06:00	1.4	11.9	2,281.7	0.9	6.80	1	1	1
11/29/2022 07:00	1.4	11.9	2,281.4	0.9	6.80	1	1	1
11/29/2022 08:00	1.4	11.9	2,244.1	0.9	6.70	1	1	1
11/29/2022 09:00	1.4	12.3	2,150.7	1.0	8.60	1	1	1
11/29/2022 10:00	1.4	12.3	2,145.0	1.0	8.60	1	1	1
11/29/2022 11:00	1.4	12.3	2,136.9	1.0	8.50	1	1	1
11/29/2022 12:00	1.3	12.3	2,126.6	0.9	6.40	1	1	1
11/29/2022 13:00	1.4	12.3	2,125.1	1.0	8.50	1	1	1
11/29/2022 14:00	1.4	12.3	2,128.4	1.0	8.50	1	1	1
11/29/2022 15:00	1.4	12.3	2,146.5	1.0	8.60	1	1	1
11/29/2022 16:00	1.4	11.8	2,253.8	0.9	6.80	1	1	1
11/29/2022 17:00	1.4	11.8	2,262.7	0.9	6.80	1	1	1
11/29/2022 18:00	1.4	11.8	2,269.7	0.9	6.80	1	1	1
11/29/2022 19:00	1.4	11.8	2,270.4	0.9	6.80	1	1	1
11/29/2022 20:00	1.4	11.9	2,275.0	0.9	6.80	1	1	1
11/29/2022 21:00	1.4	11.9	2,279.4	0.9	6.80	1	1	1
11/29/2022 22:00	1.4	11.9	2,281.0	0.9	6.80	1	1	1
11/29/2022 23:00	1.4	11.9	2,279.2	0.9	6.80	1	1	1
Average/Sum#:	1.4	12.1	2,203.1	0.9	175.50 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,087.1	0.9	6.30	1	1	1
Maximum:	1.4	12.7	2,281.7	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2022 00:00	1.3	12.5	2,172.7	0.9	6.50	1	1	1
11/30/2022 01:00	1.3	12.5	2,154.2	0.9	6.50	1	1	1
11/30/2022 02:00	1.3	12.5	2,150.7	0.9	6.50	1	1	1
11/30/2022 03:00	1.3	12.5	2,151.7	0.9	6.50	1	1	1
11/30/2022 04:00	1.4	12.5	2,168.0	1.0	8.70	1	1	1
11/30/2022 05:00	1.5	12.5	2,165.1	1.1	8.70	1	1	1
11/30/2022 06:00	1.4	12.1	2,258.1	0.9	6.80	1	1	1
11/30/2022 07:00	1.3	12.5	2,146.1	0.9	6.40	1	1	1
11/30/2022 08:00	1.2	13.2	1,980.7	0.9	5.90	1	1	1
11/30/2022 09:00	1.3	13.1	1,994.5	1.0	8.00	1	1	1
11/30/2022 10:00	1.2	13.2	1,971.3	0.9	5.90	1	1	1
11/30/2022 11:00	1.2	13.1	1,965.9	0.9	5.90	1	1	1
11/30/2022 12:00	1.3	13.1	1,966.2	1.0	7.90	1	1	1
11/30/2022 13:00	1.3	13.0	1,964.4	1.0	7.90	1	1	1
11/30/2022 14:00	1.4	12.4	2,104.4	1.0	8.40	1	1	1
11/30/2022 15:00	1.4	12.3	2,113.2	1.0	8.50	1	1	1
11/30/2022 16:00	1.4	11.9	2,217.4	0.9	6.70	1	1	1
11/30/2022 17:00	1.4	11.7	2,265.7	0.9	6.80	1	1	1
11/30/2022 18:00	1.4	11.7	2,264.2	0.9	6.80	1	1	1
11/30/2022 19:00	1.4	11.7	2,263.8	0.9	6.80	1	1	1
11/30/2022 20:00	1.4	11.8	2,258.6	0.9	6.80	1	1	1
11/30/2022 21:00	1.4	11.9	2,224.8	0.9	6.70	1	1	1
11/30/2022 22:00	1.3	12.5	2,086.6	0.9	6.30	1	1	1
11/30/2022 23:00	1.8	13.7	1,584.9	1.5	7.90	1	0	1
Average/Sum#:	1.4	12.5	2,108.1	1.0	169.80 #	24 #	23 #	24 #
Minimum:	1.2	11.7	1,584.9	0.9	5.90	1	0	1
Maximum:	1.8	13.7	2,265.7	1.5	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 09:00	1.7	20.2	1.9	14.3	0.00	1	0	0
12/05/2022 10:00	31.0	16.6	470.2	42.5	73.80	1	0	0
12/05/2022 11:00	3.4	13.2	1,793.9	2.6	17.90	1	0	1
12/05/2022 12:00	1.4	12.2	2,140.7	0.9	6.40	1	1	1
12/05/2022 13:00	1.3	12.7	2,012.1	0.9	6.00	1	1	1
12/05/2022 14:00	1.3	12.7	2,032.3	0.9	6.10	1	1	1
12/05/2022 15:00	1.4	12.6	2,051.5	1.0	8.20	1	1	1
12/05/2022 16:00	1.3	12.0	2,193.6	0.9	6.60	1	1	1
12/05/2022 17:00	1.4	11.7	2,269.5	0.9	6.80	1	1	1
12/05/2022 18:00	1.4	11.7	2,271.5	0.9	6.80	1	1	1
12/05/2022 19:00	1.4	11.7	2,271.1	0.9	6.80	1	1	1
12/05/2022 20:00	1.4	11.8	2,272.1	0.9	6.80	1	1	1
12/05/2022 21:00	1.4	12.1	2,201.5	0.9	6.60	1	1	1
12/05/2022 22:00	1.3	12.7	2,067.0	0.9	6.20	1	1	1
12/05/2022 23:00	1.3	12.8	2,045.9	0.9	6.10	1	1	1
Average/Sum#:	3.5	13.1	1,873.0	4.7	171.10 #	15 #	12 #	13 #
Minimum:	1.3	11.7	1.9	0.9	0.00	0	0	0
Maximum:	31.0	20.2	2,272.1	42.5	73.80	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2022 00:00	1.2	13.2	1,967.2	0.9	5.90	1	1	1
12/06/2022 01:00	1.2	13.2	1,966.1	0.9	5.90	1	1	1
12/06/2022 02:00	1.2	13.2	1,965.7	0.9	5.90	1	1	1
12/06/2022 03:00	1.2	13.2	1,967.0	0.9	5.90	1	1	1
12/06/2022 04:00	1.3	13.1	1,982.2	1.0	7.90	1	1	1
12/06/2022 05:00	1.4	12.9	2,009.3	1.0	8.00	1	1	1
12/06/2022 06:00	1.2	13.1	1,982.0	0.9	5.90	1	1	1
12/06/2022 07:00	1.3	12.7	2,084.6	0.9	6.30	1	1	1
12/06/2022 08:00	1.4	11.9	2,259.2	0.9	6.80	1	1	1
12/06/2022 09:00	1.4	12.0	2,240.1	0.9	6.70	1	1	1
12/06/2022 10:00	1.4	12.0	2,234.8	0.9	6.70	1	1	1
12/06/2022 11:00	1.4	12.0	2,230.6	0.9	6.70	1	1	1
12/06/2022 12:00	1.4	12.0	2,217.9	0.9	6.70	1	1	1
12/06/2022 13:00	1.2	13.6	1,788.8	1.0	7.20	1	1	1
12/06/2022 14:00	1.1	13.9	1,318.8	0.9	4.00	1	1	0
12/06/2022 15:00	1.1	13.9	1,318.6	0.9	4.00	1	1	0
12/06/2022 16:00	1.1	13.8	1,520.8	0.9	4.60	1	1	0
12/06/2022 17:00	1.2	13.7	1,823.5	1.0	7.30	1	1	0
12/06/2022 18:00	1.2	13.7	1,825.1	1.0	7.30	1	1	0
12/06/2022 19:00	1.2	13.7	1,829.3	1.0	7.30	1	1	1
12/06/2022 20:00	1.3	12.5	2,123.4	0.9	6.40	1	1	1
12/06/2022 21:00	1.4	12.0	2,220.9	0.9	6.70	1	1	1
12/06/2022 22:00	1.3	12.5	2,096.6	0.9	6.30	1	1	1
12/06/2022 23:00	1.2	13.2	1,968.7	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,955.9	0.9	152.30 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,318.6	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,259.2	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	1.3	12.7	2,080.4	0.9	6.20	1	1	1
12/07/2022 01:00	1.3	13.1	1,983.5	1.0	7.90	1	1	1
12/07/2022 02:00	1.3	12.5	2,133.1	0.9	6.40	1	1	1
12/07/2022 03:00	1.3	12.5	2,140.6	0.9	6.40	1	1	1
12/07/2022 04:00	1.3	12.4	2,147.2	0.9	6.40	1	1	1
12/07/2022 05:00	1.5	12.3	2,161.2	1.0	8.60	1	1	1
12/07/2022 06:00	1.4	12.1	2,240.0	0.9	6.70	1	1	1
12/07/2022 07:00	1.4	12.0	2,240.5	0.9	6.70	1	1	1
12/07/2022 08:00	1.3	12.6	2,123.6	0.9	6.40	1	1	1
12/07/2022 09:00	1.4	12.5	2,160.5	1.0	8.60	1	1	1
12/07/2022 10:00	1.3	12.4	2,154.7	0.9	6.50	1	1	1
12/07/2022 11:00	1.3	12.4	2,152.0	0.9	6.50	1	1	1
12/07/2022 12:00	1.3	12.5	2,125.4	0.9	6.40	1	1	1
12/07/2022 13:00	1.3	12.5	2,105.1	0.9	6.30	1	1	1
12/07/2022 14:00	1.3	12.7	2,045.2	0.9	6.10	1	1	1
12/07/2022 15:00	1.3	12.6	2,072.9	0.9	6.20	1	1	1
12/07/2022 16:00	1.4	11.9	2,242.3	0.9	6.70	1	1	1
12/07/2022 17:00	1.4	11.8	2,263.1	0.9	6.80	1	1	1
12/07/2022 18:00	1.4	11.9	2,262.6	0.9	6.80	1	1	1
12/07/2022 19:00	1.4	11.9	2,259.5	0.9	6.80	1	1	1
12/07/2022 20:00	1.4	11.9	2,260.4	0.9	6.80	1	1	1
12/07/2022 21:00	1.4	12.0	2,254.9	0.9	6.80	1	1	1
12/07/2022 22:00	1.4	12.4	2,171.8	1.0	8.70	1	1	1
12/07/2022 23:00	1.3	12.4	2,171.2	0.9	6.50	1	1	1
Average/Sum#:	1.4	12.3	2,164.7	0.9	164.20 #	24 #	24 #	24 #
Minimum:	1.3	11.8	1,983.5	0.9	6.10	1	1	1
Maximum:	1.5	13.1	2,263.1	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	1.3	12.6	2,128.3	0.9	6.40	1	1	1
12/08/2022 01:00	1.4	12.6	2,124.0	1.0	8.50	1	1	1
12/08/2022 02:00	1.3	12.6	2,125.4	0.9	6.40	1	1	1
12/08/2022 03:00	1.3	12.6	2,126.6	0.9	6.40	1	1	1
12/08/2022 04:00	1.3	12.5	2,151.8	0.9	6.50	1	1	1
12/08/2022 05:00	1.5	12.1	2,206.3	1.0	8.80	1	1	1
12/08/2022 06:00	1.4	12.0	2,276.7	0.9	6.80	1	1	1
12/08/2022 07:00	1.4	12.2	2,235.9	0.9	6.70	1	1	1
12/08/2022 08:00	1.3	13.0	2,033.3	1.0	8.10	1	1	1
12/08/2022 09:00	1.3	12.7	2,119.8	0.9	6.40	1	1	1
12/08/2022 10:00	1.3	12.6	2,125.2	0.9	6.40	1	1	1
12/08/2022 11:00	1.4	12.5	2,152.4	1.0	8.60	1	1	1
12/08/2022 12:00	1.3	12.4	2,146.3	0.9	6.40	1	1	1
12/08/2022 13:00	1.3	12.3	2,151.6	0.9	6.50	1	1	1
12/08/2022 14:00	1.4	12.3	2,154.1	1.0	8.60	1	1	1
12/08/2022 15:00	1.4	12.3	2,161.0	1.0	8.60	1	1	1
12/08/2022 16:00	1.4	11.8	2,252.5	0.9	6.80	1	1	1
12/08/2022 17:00	1.4	11.9	2,253.7	0.9	6.80	1	1	1
12/08/2022 18:00	1.4	11.8	2,260.9	0.9	6.80	1	1	1
12/08/2022 19:00	1.4	11.8	2,258.9	0.9	6.80	1	1	1
12/08/2022 20:00	1.4	11.8	2,260.5	0.9	6.80	1	1	1
12/08/2022 21:00	1.4	11.8	2,262.3	0.9	6.80	1	1	1
12/08/2022 22:00	1.4	12.2	2,175.3	0.9	6.50	1	1	1
12/08/2022 23:00	1.4	12.3	2,175.7	1.0	8.70	1	1	1
Average/Sum#:	1.4	12.3	2,179.9	0.9	172.10 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,033.3	0.9	6.40	1	1	1
Maximum:	1.5	13.0	2,276.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2022 00:00	1.3	12.4	2,133.4	0.9	6.40	1	1	1
12/09/2022 01:00	1.3	12.9	2,049.3	1.0	8.20	1	1	1
12/09/2022 02:00	1.3	12.5	2,145.6	0.9	6.40	1	1	1
12/09/2022 03:00	1.3	12.5	2,141.8	0.9	6.40	1	1	1
12/09/2022 04:00	1.3	12.3	2,188.2	0.9	6.60	1	1	1
12/09/2022 05:00	1.5	11.9	2,279.0	1.0	9.10	1	1	1
12/09/2022 06:00	1.4	11.9	2,284.6	0.9	6.90	1	1	1
12/09/2022 07:00	1.4	12.0	2,273.6	0.9	6.80	1	1	1
12/09/2022 08:00	1.3	12.8	2,069.7	0.9	6.20	1	1	1
12/09/2022 09:00	1.3	13.0	2,024.0	1.0	8.10	1	1	1
12/09/2022 10:00	1.2	13.2	1,975.9	0.9	5.90	1	1	1
12/09/2022 11:00	1.3	12.8	2,071.4	0.9	6.20	1	1	1
12/09/2022 12:00	1.2	13.0	2,003.4	0.9	6.00	1	1	1
12/09/2022 13:00	1.3	12.4	2,147.1	0.9	6.40	1	1	1
12/09/2022 14:00	1.4	12.4	2,137.6	1.0	8.60	1	1	1
12/09/2022 15:00	1.3	12.8	2,036.0	0.9	6.10	1	1	1
12/09/2022 16:00	1.4	11.9	2,251.5	0.9	6.80	1	1	1
12/09/2022 17:00	1.4	11.9	2,251.1	0.9	6.80	1	1	1
12/09/2022 18:00	1.4	11.9	2,251.7	0.9	6.80	1	1	1
12/09/2022 19:00	1.4	11.9	2,253.6	0.9	6.80	1	1	1
12/09/2022 20:00	1.4	11.9	2,258.2	0.9	6.80	1	1	1
12/09/2022 21:00	1.4	11.9	2,257.3	0.9	6.80	1	1	1
12/09/2022 22:00	1.4	11.9	2,255.6	0.9	6.80	1	1	1
12/09/2022 23:00	1.4	11.9	2,249.1	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.3	2,166.2	0.9	164.60 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,975.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,284.6	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.3	12.9	2,006.4	1.0	8.00	1	1	1
12/10/2022 01:00	1.3	12.9	1,999.6	1.0	8.00	1	1	1
12/10/2022 02:00	1.2	13.1	1,963.4	0.9	5.90	1	1	1
12/10/2022 03:00	1.3	13.0	1,964.2	1.0	7.90	1	1	1
12/10/2022 04:00	1.3	13.0	1,959.0	1.0	7.80	1	1	1
12/10/2022 05:00	1.3	12.9	1,970.7	1.0	7.90	1	1	1
12/10/2022 06:00	1.3	13.0	1,958.3	1.0	7.80	1	1	1
12/10/2022 07:00	1.3	13.0	1,965.3	1.0	7.90	1	1	1
12/10/2022 08:00	1.3	12.8	2,005.5	0.9	6.00	1	1	1
12/10/2022 09:00	1.3	12.9	1,981.7	1.0	7.90	1	1	1
12/10/2022 10:00	1.3	13.0	1,958.2	1.0	7.80	1	1	1
12/10/2022 11:00	1.3	12.7	2,001.0	0.9	6.00	1	1	1
12/10/2022 12:00	1.4	12.3	2,097.7	1.0	8.40	1	1	1
12/10/2022 13:00	1.4	12.0	2,155.9	0.9	6.50	1	1	1
12/10/2022 14:00	1.3	12.6	2,002.4	0.9	6.00	1	1	1
12/10/2022 15:00	1.3	12.6	2,024.6	0.9	6.10	1	1	1
12/10/2022 16:00	1.4	12.3	2,094.2	1.0	8.40	1	1	1
12/10/2022 17:00	1.3	12.5	2,057.1	0.9	6.20	1	1	1
12/10/2022 18:00	1.3	12.5	2,058.1	0.9	6.20	1	1	1
12/10/2022 19:00	1.4	11.8	2,229.9	0.9	6.70	1	1	1
12/10/2022 20:00	1.4	12.1	2,153.8	0.9	6.50	1	1	1
12/10/2022 21:00	1.3	12.5	2,068.8	0.9	6.20	1	1	1
12/10/2022 22:00	1.3	12.8	2,009.3	0.9	6.00	1	1	1
12/10/2022 23:00	1.3	12.5	2,063.5	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.7	2,031.2	0.9	168.30 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,958.2	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,229.9	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.2	13.0	1,956.5	0.9	5.90	1	1	1
12/11/2022 01:00	1.3	13.1	1,954.5	1.0	7.80	1	1	1
12/11/2022 02:00	1.2	13.1	1,954.5	0.9	5.90	1	1	1
12/11/2022 03:00	1.2	13.1	1,953.0	0.9	5.90	1	1	1
12/11/2022 04:00	1.3	13.1	1,955.4	1.0	7.80	1	1	1
12/11/2022 05:00	1.1	13.1	1,956.0	0.8	5.90	1	1	1
12/11/2022 06:00	1.3	13.1	1,958.5	1.0	7.80	1	1	1
12/11/2022 07:00	1.2	13.1	1,960.5	0.9	5.90	1	1	1
12/11/2022 08:00	1.2	13.1	1,961.5	0.9	5.90	1	1	1
12/11/2022 09:00	1.3	13.1	1,964.5	1.0	7.90	1	1	1
12/11/2022 10:00	1.3	13.1	1,963.7	1.0	7.90	1	1	1
12/11/2022 11:00	1.2	13.1	1,959.8	0.9	5.90	1	1	1
12/11/2022 12:00	1.3	13.1	1,958.4	1.0	7.80	1	1	1
12/11/2022 13:00	1.2	13.0	1,960.6	0.9	5.90	1	1	1
12/11/2022 14:00	1.3	13.0	1,958.2	1.0	7.80	1	1	1
12/11/2022 15:00	1.3	12.7	2,050.1	0.9	6.20	1	1	1
12/11/2022 16:00	1.3	12.7	2,053.8	0.9	6.20	1	1	1
12/11/2022 17:00	1.3	12.4	2,123.8	0.9	6.40	1	1	1
12/11/2022 18:00	1.3	12.9	2,040.4	1.0	8.20	1	1	1
12/11/2022 19:00	1.3	12.8	2,068.4	0.9	6.20	1	1	1
12/11/2022 20:00	1.3	12.6	2,119.1	0.9	6.40	1	1	1
12/11/2022 21:00	1.2	13.1	2,002.7	0.9	6.00	1	1	1
12/11/2022 22:00	1.3	13.2	1,968.1	1.0	7.90	1	1	1
12/11/2022 23:00	1.2	13.2	1,965.9	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,990.3	0.9	161.40 #	24 #	24 #	24 #
Minimum:	1.1	12.4	1,953.0	0.8	5.90	1	1	1
Maximum:	1.3	13.2	2,123.8	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.3	13.2	1,974.6	1.0	7.90	1	1	1
12/12/2022 01:00	1.2	13.2	1,974.7	0.9	5.90	1	1	1
12/12/2022 02:00	1.3	13.2	1,974.6	1.0	7.90	1	1	1
12/12/2022 03:00	1.2	13.2	1,972.4	0.9	5.90	1	1	1
12/12/2022 04:00	1.3	13.2	1,975.3	1.0	7.90	1	1	1
12/12/2022 05:00	1.3	12.4	2,111.2	0.9	6.30	1	1	1
12/12/2022 06:00	1.4	12.3	2,205.4	1.0	8.80	1	1	1
12/12/2022 07:00	1.4	12.3	2,187.8	1.0	8.80	1	1	1
12/12/2022 08:00	1.3	12.8	2,074.1	0.9	6.20	1	1	1
12/12/2022 09:00	1.3	12.8	2,066.2	0.9	6.20	1	1	1
12/12/2022 10:00	1.2	13.2	1,973.4	0.9	5.90	1	1	1
12/12/2022 11:00	1.2	13.2	1,968.1	0.9	5.90	1	1	1
12/12/2022 12:00	1.2	13.2	1,964.0	0.9	5.90	1	1	1
12/12/2022 13:00	1.2	13.1	1,961.0	0.9	5.90	1	1	1
12/12/2022 14:00	1.2	13.1	1,953.7	0.9	5.90	1	1	1
12/12/2022 15:00	1.3	13.1	1,956.5	1.0	7.80	1	1	1
12/12/2022 16:00	1.3	12.4	2,131.9	0.9	6.40	1	1	1
12/12/2022 17:00	1.4	12.0	2,216.3	0.9	6.60	1	1	1
12/12/2022 18:00	1.4	11.8	2,275.3	0.9	6.80	1	1	1
12/12/2022 19:00	1.4	11.8	2,277.0	0.9	6.80	1	1	1
12/12/2022 20:00	1.4	11.8	2,281.0	0.9	6.80	1	1	1
12/12/2022 21:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/12/2022 22:00	1.4	12.3	2,188.8	1.0	8.80	1	1	1
12/12/2022 23:00	1.3	13.0	2,025.1	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.7	2,080.6	0.9	166.10 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,953.7	0.9	5.90	1	1	1
Maximum:	1.4	13.2	2,281.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	1.3	12.6	2,151.0	0.9	6.50	1	1	1
12/13/2022 01:00	1.3	12.5	2,157.4	0.9	6.50	1	1	1
12/13/2022 02:00	1.4	12.4	2,161.4	1.0	8.60	1	1	1
12/13/2022 03:00	1.3	12.5	2,146.4	0.9	6.40	1	1	1
12/13/2022 04:00	1.3	12.4	2,189.1	0.9	6.60	1	1	1
12/13/2022 05:00	1.3	12.0	2,273.8	0.9	6.80	1	1	1
12/13/2022 06:00	1.4	11.9	2,310.2	0.9	6.90	1	1	1
12/13/2022 07:00	1.4	11.9	2,287.8	0.9	6.90	1	1	1
12/13/2022 08:00	1.3	12.5	2,134.0	0.9	6.40	1	1	1
12/13/2022 09:00	1.3	13.0	2,010.3	1.0	8.00	1	1	1
12/13/2022 10:00	1.2	13.2	1,963.5	0.9	5.90	1	1	1
12/13/2022 11:00	1.2	13.2	1,966.2	0.9	5.90	1	1	1
12/13/2022 12:00	1.3	13.1	1,963.9	1.0	7.90	1	1	1
12/13/2022 13:00	1.2	13.1	1,958.8	0.9	5.90	1	1	1
12/13/2022 14:00	1.2	13.1	1,948.4	0.9	5.80	1	1	1
12/13/2022 15:00	1.3	12.7	2,055.9	0.9	6.20	1	1	1
12/13/2022 16:00	1.4	11.9	2,251.4	0.9	6.80	1	1	1
12/13/2022 17:00	1.4	11.8	2,271.2	0.9	6.80	1	1	1
12/13/2022 18:00	1.4	11.8	2,273.1	0.9	6.80	1	1	1
12/13/2022 19:00	1.4	11.9	2,270.7	0.9	6.80	1	1	1
12/13/2022 20:00	1.4	11.9	2,269.3	0.9	6.80	1	1	1
12/13/2022 21:00	1.4	12.0	2,274.0	0.9	6.80	1	1	1
12/13/2022 22:00	1.4	12.0	2,272.2	0.9	6.80	1	1	1
12/13/2022 23:00	1.4	11.9	2,268.0	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.4	2,159.5	0.9	161.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,948.4	0.9	5.80	1	1	1
Maximum:	1.4	13.2	2,310.2	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	1.4	12.3	2,186.8	1.0	8.70	1	1	1
12/14/2022 01:00	1.3	12.4	2,187.5	0.9	6.60	1	1	1
12/14/2022 02:00	1.3	12.4	2,188.4	0.9	6.60	1	1	1
12/14/2022 03:00	1.3	12.4	2,189.7	0.9	6.60	1	1	1
12/14/2022 04:00	1.4	12.4	2,186.4	1.0	8.70	1	1	1
12/14/2022 05:00	1.5	12.0	2,291.8	1.0	9.20	1	1	1
12/14/2022 06:00	1.4	12.0	2,297.1	0.9	6.90	1	1	1
12/14/2022 07:00	1.4	12.1	2,255.1	0.9	6.80	1	1	1
12/14/2022 08:00	1.3	12.9	2,069.6	1.0	8.30	1	1	1
12/14/2022 09:00	1.3	13.1	2,007.9	1.0	8.00	1	1	1
12/14/2022 10:00	1.2	13.0	2,023.9	0.9	6.10	1	1	1
12/14/2022 11:00	1.2	13.2	1,967.4	0.9	5.90	1	1	1
12/14/2022 12:00	1.2	13.2	1,967.7	0.9	5.90	1	1	1
12/14/2022 13:00	1.2	13.2	1,966.4	0.9	5.90	1	1	1
12/14/2022 14:00	1.2	13.2	1,961.9	0.9	5.90	1	1	1
12/14/2022 15:00	1.3	13.0	2,003.9	1.0	8.00	1	1	1
12/14/2022 16:00	1.4	12.2	2,196.7	0.9	6.60	1	1	1
12/14/2022 17:00	1.4	11.9	2,270.2	0.9	6.80	1	1	1
12/14/2022 18:00	1.4	11.9	2,263.7	0.9	6.80	1	1	1
12/14/2022 19:00	1.4	11.9	2,270.0	0.9	6.80	1	1	1
12/14/2022 20:00	1.4	11.9	2,269.8	0.9	6.80	1	1	1
12/14/2022 21:00	1.4	12.0	2,270.9	0.9	6.80	1	1	1
12/14/2022 22:00	1.4	12.1	2,250.1	0.9	6.80	1	1	1
12/14/2022 23:00	1.3	12.4	2,172.6	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.5	2,154.8	0.9	168.00 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,961.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,297.1	1.0	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2022 00:00	1.4	11.9	2,285.2	0.9	6.90	1	1	1
12/15/2022 01:00	1.4	11.9	2,294.2	0.9	6.90	1	1	1
12/15/2022 02:00	1.4	11.9	2,295.1	0.9	6.90	1	1	1
12/15/2022 03:00	1.4	11.9	2,296.8	0.9	6.90	1	1	1
12/15/2022 04:00	1.4	11.9	2,302.4	0.9	6.90	1	1	1
12/15/2022 05:00	1.2	11.8	2,305.6	0.8	6.90	1	1	1
12/15/2022 06:00	1.4	11.8	2,303.9	0.9	6.90	1	1	1
12/15/2022 07:00	1.4	11.9	2,297.7	0.9	6.90	1	1	1
12/15/2022 08:00	1.4	12.2	2,216.9	0.9	6.70	1	1	1
12/15/2022 09:00	1.4	12.1	2,210.5	0.9	6.60	1	1	1
12/15/2022 10:00	1.2	13.1	1,975.6	0.9	5.90	1	1	1
12/15/2022 11:00	1.3	13.0	1,984.0	1.0	7.90	1	1	1
12/15/2022 12:00	1.3	12.8	2,010.5	0.9	6.00	1	1	1
12/15/2022 13:00	1.3	12.8	2,027.3	0.9	6.10	1	1	1
12/15/2022 14:00	1.3	12.5	2,076.8	0.9	6.20	1	1	1
12/15/2022 15:00	1.4	11.9	2,224.3	0.9	6.70	1	1	1
12/15/2022 16:00	1.4	11.9	2,242.6	0.9	6.70	1	1	1
12/15/2022 17:00	1.4	11.9	2,240.4	0.9	6.70	1	1	1
12/15/2022 18:00	1.4	12.0	2,233.1	0.9	6.70	1	1	1
12/15/2022 19:00	1.4	12.0	2,230.3	0.9	6.70	1	1	1
12/15/2022 20:00	1.4	12.0	2,232.7	0.9	6.70	1	1	1
12/15/2022 21:00	1.4	12.1	2,238.4	0.9	6.70	1	1	1
12/15/2022 22:00	1.4	12.1	2,242.7	0.9	6.70	1	1	1
12/15/2022 23:00	1.4	12.2	2,230.3	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.2	2,208.2	0.9	160.90 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,975.6	0.8	5.90	1	1	1
Maximum:	1.4	13.1	2,305.6	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2022 00:00	1.3	13.1	1,993.7	1.0	8.00	1	1	1
12/16/2022 01:00	1.2	13.2	1,967.6	0.9	5.90	1	1	1
12/16/2022 02:00	1.3	13.2	1,966.9	1.0	7.90	1	1	1
12/16/2022 03:00	1.2	13.2	1,969.7	0.9	5.90	1	1	1
12/16/2022 04:00	1.3	13.2	1,968.6	1.0	7.90	1	1	1
12/16/2022 05:00	1.2	13.2	1,982.9	0.9	5.90	1	1	1
12/16/2022 06:00	1.3	12.7	2,114.1	0.9	6.30	1	1	1
12/16/2022 07:00	1.4	12.3	2,208.1	1.0	8.80	1	1	1
12/16/2022 08:00	1.3	12.6	2,142.7	0.9	6.40	1	1	1
12/16/2022 09:00	1.3	12.7	2,066.1	0.9	6.20	1	1	1
12/16/2022 10:00	1.1	13.8	1,542.9	0.9	4.60	1	1	0
12/16/2022 11:00	1.1	13.9	1,461.4	0.9	4.40	1	1	0
12/16/2022 12:00	1.1	13.9	1,324.4	0.9	4.00	1	1	0
12/16/2022 13:00	1.1	13.9	1,326.3	0.9	4.00	1	1	0
12/16/2022 14:00	1.1	13.8	1,587.9	0.9	4.80	1	1	0
12/16/2022 15:00	1.1	13.8	1,555.8	0.9	4.70	1	1	1
12/16/2022 16:00	1.4	12.4	2,147.0	1.0	8.60	1	1	1
12/16/2022 17:00	1.4	12.0	2,222.2	0.9	6.70	1	1	1
12/16/2022 18:00	1.4	12.4	2,150.0	1.0	8.60	1	1	1
12/16/2022 19:00	1.4	12.4	2,159.8	1.0	8.60	1	1	1
12/16/2022 20:00	1.4	11.9	2,243.7	0.9	6.70	1	1	1
12/16/2022 21:00	1.4	12.2	2,187.6	0.9	6.60	1	1	1
12/16/2022 22:00	1.3	12.7	2,087.4	0.9	6.30	1	1	1
12/16/2022 23:00	1.2	13.2	1,976.6	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,931.4	0.9	153.70 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,324.4	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,243.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	1.3	12.5	2,146.2	0.9	6.40	1	1	1
12/17/2022 01:00	1.3	12.5	2,148.8	0.9	6.40	1	1	1
12/17/2022 02:00	1.3	12.5	2,140.6	0.9	6.40	1	1	1
12/17/2022 03:00	1.3	12.5	2,153.2	0.9	6.50	1	1	1
12/17/2022 04:00	1.3	12.5	2,153.6	0.9	6.50	1	1	1
12/17/2022 05:00	1.2	12.5	2,151.4	0.8	6.50	1	1	1
12/17/2022 06:00	1.4	12.2	2,233.8	0.9	6.70	1	1	1
12/17/2022 07:00	1.3	12.7	2,099.2	0.9	6.30	1	1	1
12/17/2022 08:00	1.3	12.5	2,159.2	0.9	6.50	1	1	1
12/17/2022 09:00	1.3	12.6	2,117.2	0.9	6.40	1	1	1
12/17/2022 10:00	1.3	13.1	1,997.6	1.0	8.00	1	1	1
12/17/2022 11:00	1.2	13.2	1,964.4	0.9	5.90	1	1	1
12/17/2022 12:00	1.2	13.2	1,960.9	0.9	5.90	1	1	1
12/17/2022 13:00	1.2	13.1	1,956.6	0.9	5.90	1	1	1
12/17/2022 14:00	1.3	13.0	1,970.0	1.0	7.90	1	1	1
12/17/2022 15:00	1.3	12.5	2,100.3	0.9	6.30	1	1	1
12/17/2022 16:00	1.4	11.9	2,248.1	0.9	6.70	1	1	1
12/17/2022 17:00	1.4	12.0	2,217.8	0.9	6.70	1	1	1
12/17/2022 18:00	1.4	12.4	2,137.6	1.0	8.60	1	1	1
12/17/2022 19:00	1.4	11.8	2,260.0	0.9	6.80	1	1	1
12/17/2022 20:00	1.4	11.8	2,263.2	0.9	6.80	1	1	1
12/17/2022 21:00	1.4	11.8	2,264.7	0.9	6.80	1	1	1
12/17/2022 22:00	1.4	11.9	2,261.6	0.9	6.80	1	1	1
12/17/2022 23:00	1.4	12.3	2,180.2	1.0	8.70	1	1	1
Average/Sum#:	1.3	12.5	2,136.9	0.9	162.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,956.6	0.8	5.90	1	1	1
Maximum:	1.4	13.2	2,264.7	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	1.3	12.5	2,132.5	0.9	6.40	1	1	1
12/18/2022 01:00	1.3	12.6	2,135.5	0.9	6.40	1	1	1
12/18/2022 02:00	1.3	13.0	2,021.6	1.0	8.10	1	1	1
12/18/2022 03:00	1.2	13.2	1,975.9	0.9	5.90	1	1	1
12/18/2022 04:00	1.3	12.6	2,135.5	0.9	6.40	1	1	1
12/18/2022 05:00	1.4	12.5	2,156.2	1.0	8.60	1	1	1
12/18/2022 06:00	1.3	12.4	2,171.1	0.9	6.50	1	1	1
12/18/2022 07:00	1.4	12.3	2,208.2	1.0	8.80	1	1	1
12/18/2022 08:00	1.3	12.6	2,085.2	0.9	6.30	1	1	1
12/18/2022 09:00	1.1	13.8	1,618.7	0.9	4.90	1	1	0
12/18/2022 10:00	1.2	13.8	1,561.3	1.0	6.20	1	1	0
12/18/2022 11:00	1.1	13.8	1,559.0	0.9	4.70	1	1	0
12/18/2022 12:00	1.1	13.8	1,408.9	0.9	4.20	1	1	0
12/18/2022 13:00	1.1	13.8	1,399.2	0.9	4.20	1	1	0
12/18/2022 14:00	1.2	13.8	1,643.4	1.0	6.60	1	1	0
12/18/2022 15:00	1.1	13.8	1,651.7	0.9	5.00	1	1	1
12/18/2022 16:00	1.3	12.4	2,130.5	0.9	6.40	1	1	1
12/18/2022 17:00	1.4	12.0	2,242.0	0.9	6.70	1	1	1
12/18/2022 18:00	1.4	11.9	2,269.4	0.9	6.80	1	1	1
12/18/2022 19:00	1.4	11.9	2,270.4	0.9	6.80	1	1	1
12/18/2022 20:00	1.4	12.1	2,236.3	0.9	6.70	1	1	1
12/18/2022 21:00	1.4	12.3	2,210.2	1.0	8.80	1	1	1
12/18/2022 22:00	1.4	12.4	2,198.1	1.0	8.80	1	1	1
12/18/2022 23:00	1.3	12.9	2,049.0	1.0	8.20	1	1	1
Average/Sum#:	1.3	12.8	1,977.9	0.9	158.40 #	24 #	24 #	18 #
Minimum:	1.1	11.9	1,399.2	0.9	4.20	1	1	0
Maximum:	1.4	13.8	2,270.4	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2022 00:00	1.3	12.6	2,143.3	0.9	6.40	1	1	1
12/19/2022 01:00	1.3	12.5	2,153.6	0.9	6.50	1	1	1
12/19/2022 02:00	1.4	12.6	2,150.3	1.0	8.60	1	1	1
12/19/2022 03:00	1.4	12.6	2,151.5	1.0	8.60	1	1	1
12/19/2022 04:00	1.3	12.5	2,181.6	0.9	6.50	1	1	1
12/19/2022 05:00	1.3	12.0	2,296.4	0.9	6.90	1	1	1
12/19/2022 06:00	1.4	12.0	2,296.2	0.9	6.90	1	1	1
12/19/2022 07:00	1.4	12.0	2,295.5	0.9	6.90	1	1	1
12/19/2022 08:00	1.4	12.1	2,248.0	0.9	6.70	1	1	1
12/19/2022 09:00	1.4	12.1	2,257.3	0.9	6.80	1	1	1
12/19/2022 10:00	1.3	12.5	2,169.7	0.9	6.50	1	1	1
12/19/2022 11:00	1.3	12.5	2,172.8	0.9	6.50	1	1	1
12/19/2022 12:00	1.3	12.5	2,163.1	0.9	6.50	1	1	1
12/19/2022 13:00	1.3	12.5	2,154.7	0.9	6.50	1	1	1
12/19/2022 14:00	1.3	12.5	2,157.0	0.9	6.50	1	1	1
12/19/2022 15:00	1.4	12.3	2,218.7	1.0	8.90	1	1	1
12/19/2022 16:00	1.4	12.1	2,259.5	0.9	6.80	1	1	1
12/19/2022 17:00	1.4	12.1	2,264.7	0.9	6.80	1	1	1
12/19/2022 18:00	1.4	12.1	2,265.6	0.9	6.80	1	1	1
12/19/2022 19:00	1.4	12.1	2,264.2	0.9	6.80	1	1	1
12/19/2022 20:00	1.4	12.1	2,259.5	0.9	6.80	1	1	1
12/19/2022 21:00	1.4	12.1	2,259.7	0.9	6.80	1	1	1
12/19/2022 22:00	1.4	12.1	2,264.3	0.9	6.80	1	1	1
12/19/2022 23:00	1.4	12.1	2,263.6	0.9	6.80	1	1	1
Average/Sum#:	1.4	12.3	2,221.3	0.9	166.60 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,143.3	0.9	6.40	1	1	1
Maximum:	1.4	12.6	2,296.4	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	1.3	12.5	2,172.5	0.9	6.50	1	1	1
12/20/2022 01:00	1.4	12.5	2,169.3	1.0	8.70	1	1	1
12/20/2022 02:00	1.3	12.5	2,173.2	0.9	6.50	1	1	1
12/20/2022 03:00	1.3	12.5	2,179.2	0.9	6.50	1	1	1
12/20/2022 04:00	1.4	12.5	2,184.8	1.0	8.70	1	1	1
12/20/2022 05:00	1.4	12.5	2,186.9	1.0	8.70	1	1	1
12/20/2022 06:00	1.4	12.1	2,279.9	0.9	6.80	1	1	1
12/20/2022 07:00	1.4	12.1	2,273.5	0.9	6.80	1	1	1
12/20/2022 08:00	1.3	12.5	2,163.7	0.9	6.50	1	1	1
12/20/2022 09:00	1.4	12.5	2,161.4	1.0	8.60	1	1	1
12/20/2022 10:00	1.3	12.6	2,120.5	0.9	6.40	1	1	1
12/20/2022 11:00	1.3	12.7	2,088.3	0.9	6.30	1	1	1
12/20/2022 12:00	1.2	13.2	1,961.1	0.9	5.90	1	1	1
12/20/2022 13:00	1.2	13.2	1,963.4	0.9	5.90	1	1	1
12/20/2022 14:00	1.2	13.2	1,958.0	0.9	5.90	1	1	1
12/20/2022 15:00	1.3	12.9	2,030.5	1.0	8.10	1	1	1
12/20/2022 16:00	1.4	12.3	2,184.0	1.0	8.70	1	1	1
12/20/2022 17:00	1.4	12.0	2,248.1	0.9	6.70	1	1	1
12/20/2022 18:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/20/2022 19:00	1.4	12.0	2,239.7	0.9	6.70	1	1	1
12/20/2022 20:00	1.4	12.0	2,241.8	0.9	6.70	1	1	1
12/20/2022 21:00	1.3	12.4	2,154.7	0.9	6.50	1	1	1
12/20/2022 22:00	1.3	12.4	2,156.3	0.9	6.50	1	1	1
12/20/2022 23:00	1.4	12.2	2,209.3	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.5	2,156.1	0.9	167.90 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,958.0	0.9	5.90	1	1	1
Maximum:	1.4	13.2	2,279.9	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	1.4	11.9	2,265.8	0.9	6.80	1	1	1
12/21/2022 01:00	1.4	11.9	2,263.2	0.9	6.80	1	1	1
12/21/2022 02:00	1.4	12.0	2,261.3	0.9	6.80	1	1	1
12/21/2022 03:00	1.4	12.0	2,267.1	0.9	6.80	1	1	1
12/21/2022 04:00	1.4	12.0	2,267.5	0.9	6.80	1	1	1
12/21/2022 05:00	1.3	12.0	2,262.9	0.9	6.80	1	1	1
12/21/2022 06:00	1.4	12.0	2,262.6	0.9	6.80	1	1	1
12/21/2022 07:00	1.4	12.0	2,260.4	0.9	6.80	1	1	1
12/21/2022 08:00	1.4	12.1	2,249.7	0.9	6.70	1	1	1
12/21/2022 09:00	1.4	12.1	2,235.5	0.9	6.70	1	1	1
12/21/2022 10:00	1.4	12.1	2,227.8	0.9	6.70	1	1	1
12/21/2022 11:00	1.4	12.2	2,195.0	0.9	6.60	1	1	1
12/21/2022 12:00	1.4	12.1	2,213.1	0.9	6.60	1	1	1
12/21/2022 13:00	1.4	12.1	2,208.4	0.9	6.60	1	1	1
12/21/2022 14:00	1.4	12.4	2,133.5	1.0	8.50	1	1	1
12/21/2022 15:00	1.4	12.1	2,205.0	0.9	6.60	1	1	1
12/21/2022 16:00	1.4	12.0	2,227.3	0.9	6.70	1	1	1
12/21/2022 17:00	1.4	12.0	2,234.1	0.9	6.70	1	1	1
12/21/2022 18:00	1.4	12.0	2,239.9	0.9	6.70	1	1	1
12/21/2022 19:00	1.4	12.0	2,241.3	0.9	6.70	1	1	1
12/21/2022 20:00	1.4	12.0	2,238.6	0.9	6.70	1	1	1
12/21/2022 21:00	1.4	12.0	2,238.6	0.9	6.70	1	1	1
12/21/2022 22:00	1.4	12.1	2,239.1	0.9	6.70	1	1	1
12/21/2022 23:00	1.4	12.1	2,239.7	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.1	2,236.6	0.9	163.00 #	24 #	24 #	24 #
Minimum:	1.3	11.9	2,133.5	0.9	6.60	1	1	1
Maximum:	1.4	12.4	2,267.5	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2022 00:00	1.3	12.3	2,179.5	0.9	6.50	1	1	1
12/22/2022 01:00	1.3	13.1	1,980.0	1.0	7.90	1	1	1
12/22/2022 02:00	1.2	13.2	1,961.4	0.9	5.90	1	1	1
12/22/2022 03:00	1.3	13.2	1,964.7	1.0	7.90	1	1	1
12/22/2022 04:00	1.3	12.8	2,094.8	0.9	6.30	1	1	1
12/22/2022 05:00	1.2	12.1	2,222.3	0.8	6.70	1	1	1
12/22/2022 06:00	1.4	12.1	2,261.4	0.9	6.80	1	1	1
12/22/2022 07:00	1.4	12.1	2,259.7	0.9	6.80	1	1	1
12/22/2022 08:00	1.4	12.1	2,238.6	0.9	6.70	1	1	1
12/22/2022 09:00	1.3	12.5	2,150.2	0.9	6.50	1	1	1
12/22/2022 10:00	1.3	12.6	2,145.1	0.9	6.40	1	1	1
12/22/2022 11:00	1.3	12.5	2,140.3	0.9	6.40	1	1	1
12/22/2022 12:00	1.3	12.5	2,137.6	0.9	6.40	1	1	1
12/22/2022 13:00	1.3	12.5	2,137.2	0.9	6.40	1	1	1
12/22/2022 14:00	1.3	12.5	2,144.7	0.9	6.40	1	1	1
12/22/2022 15:00	1.4	12.2	2,203.3	0.9	6.60	1	1	1
12/22/2022 16:00	1.4	12.2	2,198.4	0.9	6.60	1	1	1
12/22/2022 17:00	1.4	12.0	2,238.8	0.9	6.70	1	1	1
12/22/2022 18:00	1.4	12.0	2,242.2	0.9	6.70	1	1	1
12/22/2022 19:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/22/2022 20:00	1.4	12.0	2,243.5	0.9	6.70	1	1	1
12/22/2022 21:00	1.4	12.0	2,241.4	0.9	6.70	1	1	1
12/22/2022 22:00	1.4	12.2	2,200.2	0.9	6.60	1	1	1
12/22/2022 23:00	1.3	12.8	2,068.8	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.4	2,162.5	0.9	159.50 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,961.4	0.8	5.90	1	1	1
Maximum:	1.4	13.2	2,261.4	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	1.4	12.2	2,215.5	0.9	6.60	1	1	1
12/23/2022 01:00	1.4	12.0	2,252.2	0.9	6.80	1	1	1
12/23/2022 02:00	1.4	12.0	2,250.3	0.9	6.80	1	1	1
12/23/2022 03:00	1.4	12.0	2,245.6	0.9	6.70	1	1	1
12/23/2022 04:00	1.4	12.0	2,248.2	0.9	6.70	1	1	1
12/23/2022 05:00	1.3	12.0	2,241.2	0.9	6.70	1	1	1
12/23/2022 06:00	1.4	12.0	2,250.7	0.9	6.80	1	1	1
12/23/2022 07:00	1.4	12.1	2,232.9	0.9	6.70	1	1	1
12/23/2022 08:00	1.4	12.3	2,172.6	1.0	8.70	1	1	1
12/23/2022 09:00	1.4	12.3	2,163.4	1.0	8.70	1	1	1
12/23/2022 10:00	1.3	12.5	2,122.9	0.9	6.40	1	1	1
12/23/2022 11:00	1.4	12.4	2,124.2	1.0	8.50	1	1	1
12/23/2022 12:00	1.3	12.8	2,017.4	0.9	6.10	1	1	1
12/23/2022 13:00	1.2	13.1	1,950.0	0.9	5.90	1	1	1
12/23/2022 14:00	1.3	13.1	1,941.4	1.0	7.80	1	1	1
12/23/2022 15:00	1.3	12.7	2,049.7	0.9	6.10	1	1	1
12/23/2022 16:00	1.4	11.9	2,228.2	0.9	6.70	1	1	1
12/23/2022 17:00	1.4	11.9	2,230.8	0.9	6.70	1	1	1
12/23/2022 18:00	1.4	11.9	2,231.0	0.9	6.70	1	1	1
12/23/2022 19:00	1.4	12.0	2,229.3	0.9	6.70	1	1	1
12/23/2022 20:00	1.4	12.0	2,230.7	0.9	6.70	1	1	1
12/23/2022 21:00	1.4	11.9	2,234.3	0.9	6.70	1	1	1
12/23/2022 22:00	1.4	11.9	2,233.5	0.9	6.70	1	1	1
12/23/2022 23:00	1.4	12.0	2,225.6	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.2	2,180.1	0.9	165.60 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,941.4	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,252.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	1.4	12.4	2,119.0	1.0	8.50	1	1	1
12/24/2022 01:00	1.3	12.5	2,113.9	0.9	6.30	1	1	1
12/24/2022 02:00	1.2	13.1	1,961.4	0.9	5.90	1	1	1
12/24/2022 03:00	1.2	13.2	1,955.3	0.9	5.90	1	1	1
12/24/2022 04:00	1.2	13.2	1,953.0	0.9	5.90	1	1	1
12/24/2022 05:00	1.3	13.2	1,951.1	1.0	7.80	1	1	1
12/24/2022 06:00	1.2	13.1	1,974.8	0.9	5.90	1	1	1
12/24/2022 07:00	1.3	13.0	1,998.9	1.0	8.00	1	1	1
12/24/2022 08:00	1.2	13.3	1,833.9	0.9	5.50	1	1	1
12/24/2022 09:00	1.1	13.8	1,320.7	0.9	4.00	1	1	0
12/24/2022 10:00	1.1	13.8	1,559.7	0.9	4.70	1	1	0
12/24/2022 11:00	1.1	13.8	1,555.6	0.9	4.70	1	1	0
12/24/2022 12:00	1.1	13.8	1,554.9	0.9	4.70	1	1	0
12/24/2022 13:00	1.2	13.8	1,558.8	1.0	6.20	1	1	0
12/24/2022 14:00	1.1	13.8	1,730.9	0.9	5.20	1	1	0
12/24/2022 15:00	1.1	13.8	1,739.5	0.9	5.20	1	1	0
12/24/2022 16:00	1.1	13.8	1,594.1	0.9	4.80	1	1	1
12/24/2022 17:00	1.2	13.1	1,944.9	0.9	5.80	1	1	1
12/24/2022 18:00	1.3	13.1	1,943.7	1.0	7.80	1	1	1
12/24/2022 19:00	1.2	13.1	1,944.1	0.9	5.80	1	1	1
12/24/2022 20:00	1.2	13.1	1,947.7	0.9	5.80	1	1	1
12/24/2022 21:00	1.3	13.1	1,944.2	1.0	7.80	1	1	1
12/24/2022 22:00	1.2	13.2	1,946.9	0.9	5.80	1	1	1
12/24/2022 23:00	1.2	13.2	1,949.6	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.3	1,837.4	0.9	143.80 #	24 #	24 #	17 #
Minimum:	1.1	12.4	1,320.7	0.9	4.00	1	1	0
Maximum:	1.4	13.8	2,119.0	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.2	13.2	1,930.0	0.9	5.80	1	1	1
12/25/2022 01:00	4.1	15.6	591.4	4.6	2.22	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.7	14.4	1,260.7	2.8	8.02 #	2 #	1 #	1 #
Minimum:	1.2	13.2	591.4	0.9	2.22	0	0	0
Maximum:	4.1	15.6	1,930.0	4.6	5.80	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2022 00:00	30.0	17.6	332.1	53.6	41.45	1	0	0
12/26/2022 01:00	14.9	15.1	969.8	15.2	54.30	1	0	0
12/26/2022 02:00	1.2	13.7	1,715.8	1.0	6.90	1	1	0
12/26/2022 03:00	1.2	13.7	1,736.0	1.0	6.90	1	1	0
12/26/2022 04:00	1.2	13.7	1,735.7	1.0	6.90	1	1	0
12/26/2022 05:00	1.2	13.7	1,750.8	1.0	7.00	1	1	0
12/26/2022 06:00	1.2	13.7	1,750.6	1.0	7.00	1	1	0
12/26/2022 07:00	1.2	13.7	1,742.3	1.0	7.00	1	1	0
12/26/2022 08:00	1.2	13.7	1,748.4	1.0	7.00	1	1	0
12/26/2022 09:00	1.1	13.8	1,563.8	0.9	4.70	1	1	0
12/26/2022 10:00	1.1	13.8	1,559.4	0.9	4.70	1	1	0
12/26/2022 11:00	1.1	13.8	1,550.2	0.9	4.70	1	1	0
12/26/2022 12:00	1.1	13.8	1,541.0	0.9	4.60	1	1	0
12/26/2022 13:00	1.1	13.8	1,561.8	0.9	4.70	1	1	0
12/26/2022 14:00	1.1	13.7	1,623.4	0.9	4.90	1	1	0
12/26/2022 15:00	1.2	13.7	1,751.1	1.0	7.00	1	1	0
12/26/2022 16:00	1.2	13.7	1,782.9	1.0	7.10	1	1	1
12/26/2022 17:00	1.3	12.5	2,103.9	0.9	6.30	1	1	1
12/26/2022 18:00	1.3	12.3	2,145.3	0.9	6.40	1	1	1
12/26/2022 19:00	1.3	12.9	2,004.1	1.0	8.00	1	1	1
12/26/2022 20:00	1.3	13.0	1,990.7	1.0	8.00	1	1	1
12/26/2022 21:00	1.2	13.1	1,960.1	0.9	5.90	1	1	1
12/26/2022 22:00	1.3	13.1	1,936.0	1.0	7.70	1	1	1
12/26/2022 23:00	3.2	15.6	602.1	3.6	1.79	1	0	0
Average/Sum#:	3.1	13.8	1,631.6	3.9	230.94 #	24 #	21 #	7 #
Minimum:	1.1	12.3	332.1	0.9	1.79	1	0	0
Maximum:	30.0	17.6	2,145.3	53.6	54.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 05:00	9.3	17.0	482.2	14.1	11.30	1	0	0
12/27/2022 06:00	6.3	14.3	1,185.6	5.6	24.90	1	0	0
12/27/2022 07:00	1.2	13.7	1,737.9	1.0	7.00	1	1	0
12/27/2022 08:00	1.2	13.6	1,714.6	1.0	6.90	1	1	1
12/27/2022 09:00	1.3	12.9	1,950.3	1.0	7.80	1	1	1
12/27/2022 10:00	1.2	12.9	1,947.7	0.9	5.80	1	1	1
12/27/2022 11:00	1.3	12.9	1,950.7	1.0	7.80	1	1	1
12/27/2022 12:00	1.3	12.9	1,949.0	1.0	7.80	1	1	1
12/27/2022 13:00	1.3	12.9	1,947.5	1.0	7.80	1	1	1
12/27/2022 14:00	1.3	12.9	1,948.0	1.0	7.80	1	1	1
12/27/2022 15:00	1.3	12.9	1,949.1	1.0	7.80	1	1	1
12/27/2022 16:00	1.3	12.9	1,950.9	1.0	7.80	1	1	1
12/27/2022 17:00	1.2	13.0	1,941.7	0.9	5.80	1	1	1
12/27/2022 18:00	1.3	13.1	1,938.3	1.0	7.80	1	1	1
12/27/2022 19:00	1.2	13.1	1,941.5	0.9	5.80	1	1	1
12/27/2022 20:00	1.2	13.1	1,950.2	0.9	5.90	1	1	1
12/27/2022 21:00	1.3	13.1	1,946.3	1.0	7.80	1	1	1
12/27/2022 22:00	1.2	13.1	1,927.1	0.9	5.80	1	1	1
12/27/2022 23:00	1.1	13.9	1,398.6	0.9	4.20	1	1	0
Average/Sum#:	1.9	13.4	1,776.7	1.9	153.60 #	19 #	17 #	15 #
Minimum:	1.1	12.9	482.2	0.9	4.20	0	0	0
Maximum:	9.3	17.0	1,950.9	14.1	24.90	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	1.1	13.8	1,551.1	0.9	4.70	1	1	0
12/28/2022 01:00	1.1	13.8	1,473.8	0.9	4.40	1	1	0
12/28/2022 02:00	1.1	13.8	1,538.3	0.9	4.60	1	1	0
12/28/2022 03:00	1.1	13.8	1,537.5	0.9	4.60	1	1	0
12/28/2022 04:00	1.2	13.8	1,543.0	1.0	6.20	1	1	0
12/28/2022 05:00	1.1	13.7	1,735.6	0.9	5.20	1	1	0
12/28/2022 06:00	1.2	13.7	1,753.7	1.0	7.00	1	1	0
12/28/2022 07:00	1.2	13.7	1,756.5	1.0	7.00	1	1	0
12/28/2022 08:00	1.2	13.7	1,732.6	1.0	6.90	1	1	0
12/28/2022 09:00	1.1	13.7	1,723.8	0.9	5.20	1	1	0
12/28/2022 10:00	1.1	13.8	1,562.0	0.9	4.70	1	1	0
12/28/2022 11:00	1.1	13.8	1,577.9	0.9	4.70	1	1	0
12/28/2022 12:00	1.1	13.8	1,560.7	0.9	4.70	1	1	0
12/28/2022 13:00	1.1	13.8	1,535.3	0.9	4.60	1	1	0
12/28/2022 14:00	1.1	13.8	1,554.0	0.9	4.70	1	1	0
12/28/2022 15:00	1.2	13.7	1,601.3	1.0	6.40	1	1	1
12/28/2022 16:00	1.3	12.5	2,087.1	0.9	6.30	1	1	1
12/28/2022 17:00	1.3	13.0	1,974.8	1.0	7.90	1	1	1
12/28/2022 18:00	1.2	13.1	1,954.9	0.9	5.90	1	1	1
12/28/2022 19:00	1.3	13.1	1,956.3	1.0	7.80	1	1	1
12/28/2022 20:00	1.2	13.1	1,955.8	0.9	5.90	1	1	1
12/28/2022 21:00	1.2	13.0	1,967.9	0.9	5.90	1	1	1
12/28/2022 22:00	1.3	13.1	1,952.9	1.0	7.80	1	1	1
12/28/2022 23:00	1.2	13.1	1,957.6	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.5	1,731.0	0.9	139.00 #	24 #	24 #	9 #
Minimum:	1.1	12.5	1,473.8	0.9	4.40	1	1	0
Maximum:	1.3	13.8	2,087.1	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2022 00:00	1.2	13.1	1,953.1	0.9	5.90	1	1	1
12/29/2022 01:00	1.2	13.1	1,953.2	0.9	5.90	1	1	1
12/29/2022 02:00	1.2	13.1	1,953.7	0.9	5.90	1	1	1
12/29/2022 03:00	1.3	13.1	1,955.0	1.0	7.80	1	1	1
12/29/2022 04:00	1.2	13.1	1,957.5	0.9	5.90	1	1	1
12/29/2022 05:00	1.2	12.7	2,029.7	0.9	6.10	1	1	1
12/29/2022 06:00	1.3	12.8	2,039.0	0.9	6.10	1	1	1
12/29/2022 07:00	1.3	12.8	2,042.7	0.9	6.10	1	1	1
12/29/2022 08:00	1.4	12.2	2,185.5	0.9	6.60	1	1	1
12/29/2022 09:00	1.4	11.9	2,234.1	0.9	6.70	1	1	1
12/29/2022 10:00	1.4	12.3	2,142.2	1.0	8.60	1	1	1
12/29/2022 11:00	1.3	12.9	2,012.8	1.0	8.10	1	1	1
12/29/2022 12:00	1.3	13.0	1,975.6	1.0	7.90	1	1	1
12/29/2022 13:00	1.2	13.1	1,962.0	0.9	5.90	1	1	1
12/29/2022 14:00	1.3	13.0	1,971.1	1.0	7.90	1	1	1
12/29/2022 15:00	1.2	13.0	1,977.5	0.9	5.90	1	1	1
12/29/2022 16:00	1.3	12.6	2,082.3	0.9	6.20	1	1	1
12/29/2022 17:00	1.3	12.3	2,149.3	0.9	6.40	1	1	1
12/29/2022 18:00	1.3	12.6	2,062.6	0.9	6.20	1	1	1
12/29/2022 19:00	1.3	13.1	1,956.5	1.0	7.80	1	1	1
12/29/2022 20:00	1.2	13.1	1,963.5	0.9	5.90	1	1	1
12/29/2022 21:00	1.3	13.0	1,973.9	1.0	7.90	1	1	1
12/29/2022 22:00	1.2	13.0	1,958.1	0.9	5.90	1	1	1
12/29/2022 23:00	1.3	13.1	1,930.3	1.0	7.70	1	1	1
Average/Sum#:	1.3	12.8	2,017.6	0.9	161.30 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,930.3	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,234.1	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	2.9	15.6	627.2	3.2	1.88	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.9	15.6	627.2	3.2	1.88 #	1 #	0 #	0 #
Minimum:	2.9	15.6	627.2	3.2	1.88	0	0	0
Maximum:	2.9	15.6	627.2	3.2	1.88	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	1.7	12.1	2,166.3	1.1	8.70	1	1	1
10/01/2022 01:00	3.0	14.2	1,202.0	2.6	5.76	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 12:00	25.8	17.7	308.0	47.6	38.81	1	0	0
10/01/2022 13:00	10.2	17.2	376.4	16.3	22.60	1	0	0
10/01/2022 14:00	14.9	15.5	875.8	16.3	52.50	1	0	0
10/01/2022 15:00	0.3	14.1	1,414.5	0.3	1.40	1	1	0
10/01/2022 16:00	0.8	13.6	1,717.8	0.6	3.40	1	1	1
10/01/2022 17:00	1.6	11.6	2,258.0	1.0	9.00	1	1	1
10/01/2022 18:00	1.7	11.9	2,188.3	1.1	8.80	1	1	1
10/01/2022 19:00	1.5	12.6	2,026.7	1.1	8.10	1	1	1
10/01/2022 20:00	1.7	11.9	2,210.8	1.1	8.80	1	1	1
10/01/2022 21:00	1.4	12.5	1,932.3	1.0	7.70	1	1	1
10/01/2022 22:00	0.7	13.8	1,569.8	0.6	3.10	1	1	0
10/01/2022 23:00	2.2	15.6	630.9	2.4	1.43	1	0	0
Average/Sum#:	4.8	13.9	1,491.3	6.7	180.10 #	14 #	9 #	8 #
Minimum:	0.3	11.6	308.0	0.3	1.40	0	0	0
Maximum:	25.8	17.7	2,258.0	47.6	52.50	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 11:00	24.6	17.7	311.4	45.4	34.84	1	0	0
10/02/2022 12:00	8.4	17.2	404.4	13.4	19.80	1	0	0
10/02/2022 13:00	10.0	15.6	880.7	11.1	36.10	1	0	0
10/02/2022 14:00	0.8	13.8	1,730.7	0.7	3.50	1	1	0
10/02/2022 15:00	0.9	13.2	1,719.8	0.7	5.20	1	1	1
10/02/2022 16:00	1.7	12.0	2,184.2	1.1	8.70	1	1	1
10/02/2022 17:00	1.7	11.6	2,265.0	1.1	9.10	1	1	1
10/02/2022 18:00	1.8	11.6	2,270.6	1.1	9.10	1	1	1
10/02/2022 19:00	1.8	11.6	2,272.9	1.1	9.10	1	1	1
10/02/2022 20:00	1.8	11.6	2,274.3	1.1	9.10	1	1	1
10/02/2022 21:00	1.5	12.4	2,098.7	1.0	8.40	1	1	1
10/02/2022 22:00	1.3	12.7	1,912.0	0.9	5.70	1	1	1
10/02/2022 23:00	0.6	13.9	1,550.6	0.5	3.10	1	1	0
Average/Sum#:	4.4	13.5	1,682.7	6.1	161.74 #	13 #	10 #	8 #
Minimum:	0.6	11.6	311.4	0.5	3.10	0	0	0
Maximum:	24.6	17.7	2,274.3	45.4	36.10	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.6	13.9	1,546.4	0.5	3.10	1	1	0
10/03/2022 01:00	0.6	13.9	1,550.3	0.5	3.10	1	1	0
10/03/2022 02:00	0.8	13.8	1,784.2	0.7	3.60	1	1	0
10/03/2022 03:00	0.6	13.9	1,582.9	0.5	3.20	1	1	0
10/03/2022 04:00	0.5	13.9	1,715.7	0.4	3.40	1	1	0
10/03/2022 05:00	0.5	13.9	1,713.6	0.4	3.40	1	1	0
10/03/2022 06:00	0.5	13.9	1,710.7	0.4	3.40	1	1	0
10/03/2022 07:00	0.5	13.9	1,711.1	0.4	3.40	1	1	0
10/03/2022 08:00	0.5	13.9	1,717.3	0.4	3.40	1	1	0
10/03/2022 09:00	0.6	13.9	1,722.1	0.5	3.40	1	1	0
10/03/2022 10:00	0.6	13.9	1,724.5	0.5	3.40	1	1	0
10/03/2022 11:00	0.6	13.9	1,724.7	0.5	3.40	1	1	0
10/03/2022 12:00	0.7	13.9	1,724.6	0.6	3.40	1	1	0
10/03/2022 13:00	0.7	13.9	1,725.3	0.6	3.50	1	1	0
10/03/2022 14:00	0.7	13.9	1,716.6	0.6	3.40	1	1	0
10/03/2022 15:00	0.7	13.8	1,754.9	0.6	3.50	1	1	1
10/03/2022 16:00	1.2	12.5	2,060.1	0.8	6.20	1	1	1
10/03/2022 17:00	1.5	12.0	2,170.1	1.0	8.70	1	1	1
10/03/2022 18:00	1.7	11.8	2,202.2	1.1	8.80	1	1	1
10/03/2022 19:00	1.6	12.0	2,175.9	1.1	8.70	1	1	1
10/03/2022 20:00	1.7	11.9	2,186.8	1.1	8.70	1	1	1
10/03/2022 21:00	1.6	12.0	2,178.8	1.1	8.70	1	1	1
10/03/2022 22:00	1.5	12.2	2,156.6	1.0	8.60	1	1	1
10/03/2022 23:00	1.6	12.1	2,174.0	1.1	8.70	1	1	1
Average/Sum#:	0.9	13.3	1,851.2	0.7	121.10 #	24 #	24 #	9 #
Minimum:	0.5	11.8	1,546.4	0.4	3.10	1	1	0
Maximum:	1.7	13.9	2,202.2	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	1.5	12.2	2,156.2	1.0	8.60	1	1	1
10/04/2022 01:00	1.6	12.2	2,159.9	1.1	8.60	1	1	1
10/04/2022 02:00	1.5	12.2	2,158.6	1.0	8.60	1	1	1
10/04/2022 03:00	1.5	12.1	2,168.6	1.0	8.70	1	1	1
10/04/2022 04:00	1.6	12.1	2,182.7	1.1	8.70	1	1	1
10/04/2022 05:00	1.6	12.0	2,216.4	1.1	8.90	1	1	1
10/04/2022 06:00	1.5	12.3	2,179.8	1.0	8.70	1	1	1
10/04/2022 07:00	1.3	12.7	2,043.5	0.9	6.10	1	1	1
10/04/2022 08:00	0.6	13.8	1,586.2	0.5	3.20	1	1	0
10/04/2022 09:00	0.5	13.9	1,548.5	0.4	3.10	1	1	0
10/04/2022 10:00	0.0	0.0	1,554.2	0.0	0.00	1	1	0
10/04/2022 11:00	0.6	13.9	1,562.4	0.5	3.10	1	1	0
10/04/2022 12:00	0.7	13.9	1,707.0	0.6	3.40	1	1	0
10/04/2022 13:00	0.9	13.8	1,733.0	0.7	5.20	1	1	1
10/04/2022 14:00	1.2	12.7	2,019.5	0.9	6.10	1	1	1
10/04/2022 15:00	1.5	12.1	2,136.1	1.0	8.50	1	1	1
10/04/2022 16:00	1.5	12.1	2,128.5	1.0	8.50	1	1	1
10/04/2022 17:00	1.6	12.1	2,140.4	1.1	8.60	1	1	1
10/04/2022 18:00	1.6	12.0	2,169.9	1.1	8.70	1	1	1
10/04/2022 19:00	1.7	11.9	2,188.2	1.1	8.80	1	1	1
10/04/2022 20:00	1.8	11.7	2,242.8	1.2	9.00	1	1	1
10/04/2022 21:00	1.7	11.9	2,190.4	1.1	8.80	1	1	1
10/04/2022 22:00	1.7	12.0	2,179.1	1.1	8.70	1	1	1
10/04/2022 23:00	1.5	12.2	2,143.7	1.0	8.60	1	1	1
Average/Sum#:	1.4	12.5	2,020.7	0.9	169.20 #	24 #	24 #	19 #
Minimum:	0.5	11.7	1,548.5	0.4	3.10	1	1	0
Maximum:	1.8	13.9	2,242.8	1.2	9.00	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.5	12.2	2,136.6	1.0	8.50	1	1	1
10/05/2022 01:00	1.3	12.8	1,995.6	0.9	6.00	1	1	1
10/05/2022 02:00	1.2	13.0	1,971.2	0.9	5.90	1	1	1
10/05/2022 03:00	1.3	12.5	2,088.5	0.9	6.30	1	1	1
10/05/2022 04:00	1.4	12.3	2,117.7	1.0	8.50	1	1	1
10/05/2022 05:00	1.6	12.0	2,204.8	1.1	8.80	1	1	1
10/05/2022 06:00	1.6	12.1	2,206.4	1.1	8.80	1	1	1
10/05/2022 07:00	1.2	12.9	1,980.3	0.9	5.90	1	1	1
10/05/2022 08:00	0.6	13.9	1,702.3	0.5	3.40	1	1	0
10/05/2022 09:00	0.6	13.9	1,667.6	0.5	3.30	1	1	0
10/05/2022 10:00	0.7	13.9	1,693.9	0.6	3.40	1	1	0
10/05/2022 11:00	0.7	13.9	1,706.3	0.6	3.40	1	1	0
10/05/2022 12:00	0.8	13.8	1,723.0	0.7	3.40	1	1	1
10/05/2022 13:00	1.2	12.5	2,064.2	0.8	6.20	1	1	1
10/05/2022 14:00	1.6	11.9	2,181.4	1.0	8.70	1	1	1
10/05/2022 15:00	1.5	12.1	2,135.0	1.0	8.50	1	1	1
10/05/2022 16:00	1.6	12.0	2,157.2	1.1	8.60	1	1	1
10/05/2022 17:00	1.7	11.8	2,196.1	1.1	8.80	1	1	1
10/05/2022 18:00	1.8	11.7	2,231.0	1.2	8.90	1	1	1
10/05/2022 19:00	1.8	11.7	2,237.6	1.2	9.00	1	1	1
10/05/2022 20:00	1.7	11.9	2,188.3	1.1	8.80	1	1	1
10/05/2022 21:00	1.8	11.7	2,234.5	1.2	8.90	1	1	1
10/05/2022 22:00	1.6	12.1	2,163.4	1.1	8.70	1	1	1
10/05/2022 23:00	1.6	12.1	2,172.8	1.1	8.70	1	1	1
Average/Sum#:	1.4	12.5	2,048.2	0.9	169.40 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,667.6	0.5	3.30	1	1	0
Maximum:	1.8	13.9	2,237.6	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.6	12.2	2,162.3	1.1	8.60	1	1	1
10/06/2022 01:00	1.5	12.1	2,166.4	1.0	8.70	1	1	1
10/06/2022 02:00	1.6	12.1	2,164.4	1.1	8.70	1	1	1
10/06/2022 03:00	1.5	12.2	2,142.9	1.0	8.60	1	1	1
10/06/2022 04:00	1.6	12.0	2,184.4	1.1	8.70	1	1	1
10/06/2022 05:00	1.7	11.8	2,246.2	1.1	9.00	1	1	1
10/06/2022 06:00	1.6	11.9	2,233.3	1.0	8.90	1	1	1
10/06/2022 07:00	1.4	12.3	2,131.1	1.0	8.50	1	1	1
10/06/2022 08:00	1.3	12.5	2,082.8	0.9	6.20	1	1	1
10/06/2022 09:00	1.3	12.6	2,065.4	0.9	6.20	1	1	1
10/06/2022 10:00	1.4	12.5	2,076.7	1.0	8.30	1	1	1
10/06/2022 11:00	1.5	12.3	2,113.6	1.0	8.50	1	1	1
10/06/2022 12:00	1.6	12.1	2,142.5	1.1	8.60	1	1	1
10/06/2022 13:00	1.7	11.9	2,198.7	1.1	8.80	1	1	1
10/06/2022 14:00	1.7	11.8	2,207.0	1.1	8.80	1	1	1
10/06/2022 15:00	1.6	12.0	2,158.9	1.1	8.60	1	1	1
10/06/2022 16:00	1.7	11.9	2,197.5	1.1	8.80	1	1	1
10/06/2022 17:00	1.8	11.7	2,245.6	1.2	9.00	1	1	1
10/06/2022 18:00	1.7	11.7	2,241.8	1.1	9.00	1	1	1
10/06/2022 19:00	1.8	11.7	2,251.9	1.2	9.00	1	1	1
10/06/2022 20:00	1.7	11.7	2,253.7	1.1	9.00	1	1	1
10/06/2022 21:00	1.8	11.8	2,243.5	1.2	9.00	1	1	1
10/06/2022 22:00	1.7	12.0	2,189.6	1.1	8.80	1	1	1
10/06/2022 23:00	1.6	12.1	2,168.9	1.1	8.70	1	1	1
Average/Sum#:	1.6	12.0	2,177.9	1.1	205.00 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,065.4	0.9	6.20	1	1	1
Maximum:	1.8	12.6	2,253.7	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.5	12.3	2,144.9	1.0	8.60	1	1	1
10/07/2022 01:00	1.6	12.2	2,158.5	1.1	8.60	1	1	1
10/07/2022 02:00	1.6	12.3	2,141.1	1.1	8.60	1	1	1
10/07/2022 03:00	1.4	12.4	2,115.0	1.0	8.50	1	1	1
10/07/2022 04:00	1.5	12.2	2,155.3	1.0	8.60	1	1	1
10/07/2022 05:00	1.6	12.1	2,191.5	1.1	8.80	1	1	1
10/07/2022 06:00	1.6	12.1	2,204.8	1.1	8.80	1	1	1
10/07/2022 07:00	1.4	12.4	2,111.6	1.0	8.40	1	1	1
10/07/2022 08:00	1.3	12.7	2,031.6	0.9	6.10	1	1	1
10/07/2022 09:00	1.5	12.3	2,132.5	1.0	8.50	1	1	1
10/07/2022 10:00	1.6	12.3	2,127.2	1.1	8.50	1	1	1
10/07/2022 11:00	1.5	12.3	2,117.0	1.0	8.50	1	1	1
10/07/2022 12:00	1.7	12.0	2,174.6	1.1	8.70	1	1	1
10/07/2022 13:00	1.6	12.1	2,147.2	1.1	8.60	1	1	1
10/07/2022 14:00	1.7	11.9	2,194.6	1.1	8.80	1	1	1
10/07/2022 15:00	1.7	11.8	2,203.8	1.1	8.80	1	1	1
10/07/2022 16:00	1.7	11.9	2,188.4	1.1	8.80	1	1	1
10/07/2022 17:00	1.8	11.7	2,238.4	1.2	9.00	1	1	1
10/07/2022 18:00	1.7	11.7	2,248.1	1.1	9.00	1	1	1
10/07/2022 19:00	1.8	11.7	2,254.3	1.2	9.00	1	1	1
10/07/2022 20:00	1.7	11.7	2,259.1	1.1	9.00	1	1	1
10/07/2022 21:00	1.7	11.7	2,262.1	1.1	9.00	1	1	1
10/07/2022 22:00	1.7	11.7	2,256.4	1.1	9.00	1	1	1
10/07/2022 23:00	1.7	12.0	2,191.4	1.1	8.80	1	1	1
Average/Sum#:	1.6	12.1	2,177.1	1.1	207.00 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,031.6	0.9	6.10	1	1	1
Maximum:	1.8	12.7	2,262.1	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.6	12.1	2,179.0	1.1	8.70	1	1	1
10/08/2022 01:00	1.6	12.1	2,173.7	1.1	8.70	1	1	1
10/08/2022 02:00	1.6	12.2	2,165.8	1.1	8.70	1	1	1
10/08/2022 03:00	1.6	12.1	2,178.8	1.1	8.70	1	1	1
10/08/2022 04:00	1.7	12.1	2,186.4	1.1	8.70	1	1	1
10/08/2022 05:00	1.6	12.2	2,175.0	1.1	8.70	1	1	1
10/08/2022 06:00	1.3	12.6	2,114.0	0.9	6.30	1	1	1
10/08/2022 07:00	0.8	13.7	1,700.8	0.7	3.40	1	1	1
10/08/2022 08:00	0.4	14.0	1,358.1	0.3	1.40	1	1	0
10/08/2022 09:00	0.3	14.1	1,309.6	0.3	1.30	1	1	0
10/08/2022 10:00	0.3	14.1	1,309.0	0.3	1.30	1	1	0
10/08/2022 11:00	0.3	14.1	1,314.2	0.3	1.30	1	1	0
10/08/2022 12:00	0.6	13.9	1,559.1	0.5	3.10	1	1	0
10/08/2022 13:00	0.7	13.9	1,711.4	0.6	3.40	1	1	0
10/08/2022 14:00	0.8	13.8	1,728.5	0.7	3.50	1	1	1
10/08/2022 15:00	1.3	12.3	2,093.4	0.9	6.30	1	1	1
10/08/2022 16:00	1.7	11.8	2,196.4	1.1	8.80	1	1	1
10/08/2022 17:00	1.7	11.8	2,200.9	1.1	8.80	1	1	1
10/08/2022 18:00	1.7	12.0	2,169.3	1.1	8.70	1	1	1
10/08/2022 19:00	1.7	12.0	2,176.3	1.1	8.70	1	1	1
10/08/2022 20:00	1.7	12.0	2,183.4	1.1	8.70	1	1	1
10/08/2022 21:00	1.7	12.0	2,182.8	1.1	8.70	1	1	1
10/08/2022 22:00	1.7	12.1	2,179.0	1.1	8.70	1	1	1
10/08/2022 23:00	1.6	12.2	2,177.1	1.1	8.70	1	1	1
Average/Sum#:	1.3	12.7	1,946.8	0.9	153.30 #	24 #	24 #	18 #
Minimum:	0.3	11.8	1,309.0	0.3	1.30	1	1	0
Maximum:	1.7	14.1	2,200.9	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.6	12.1	2,173.7	1.1	8.70	1	1	1
10/09/2022 01:00	1.6	12.2	2,176.5	1.1	8.70	1	1	1
10/09/2022 02:00	1.5	12.3	2,147.0	1.0	8.60	1	1	1
10/09/2022 03:00	1.5	12.3	2,158.6	1.0	8.60	1	1	1
10/09/2022 04:00	1.5	12.2	2,165.0	1.0	8.70	1	1	1
10/09/2022 05:00	1.5	12.2	2,156.0	1.0	8.60	1	1	1
10/09/2022 06:00	2.8	13.7	1,682.6	2.3	13.50	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 14:00	18.1	17.6	384.2	32.4	32.90	1	0	0
10/09/2022 15:00	10.0	14.5	1,309.2	9.2	44.50	1	0	0
10/09/2022 16:00	0.7	13.9	1,714.4	0.6	3.40	1	1	0
10/09/2022 17:00	0.9	13.7	1,764.8	0.7	5.30	1	1	1
10/09/2022 18:00	1.2	12.4	2,079.4	0.8	6.20	1	1	1
10/09/2022 19:00	1.7	11.8	2,207.7	1.1	8.80	1	1	1
10/09/2022 20:00	1.7	12.0	2,185.0	1.1	8.70	1	1	1
10/09/2022 21:00	1.6	12.1	2,173.4	1.1	8.70	1	1	1
10/09/2022 22:00	1.6	12.2	2,156.8	1.1	8.60	1	1	1
10/09/2022 23:00	1.5	12.2	2,148.5	1.0	8.60	1	1	1
Average/Sum#:	3.0	12.9	1,928.4	3.4	201.10 #	17 #	14 #	14 #
Minimum:	0.7	11.8	384.2	0.6	3.40	0	0	0
Maximum:	18.1	17.6	2,207.7	32.4	44.50	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.5	12.3	2,123.4	1.0	8.50	1	1	1
10/10/2022 01:00	1.3	12.5	2,095.3	0.9	6.30	1	1	1
10/10/2022 02:00	1.2	13.0	1,981.4	0.9	5.90	1	1	1
10/10/2022 03:00	1.3	12.5	2,093.7	0.9	6.30	1	1	1
10/10/2022 04:00	1.4	12.4	2,139.2	1.0	8.60	1	1	1
10/10/2022 05:00	1.6	12.0	2,225.5	1.1	8.90	1	1	1
10/10/2022 06:00	1.5	12.1	2,215.7	1.0	8.90	1	1	1
10/10/2022 07:00	0.9	13.4	1,803.1	0.7	5.40	1	1	1
10/10/2022 08:00	0.5	13.9	1,542.0	0.4	3.10	1	1	0
10/10/2022 09:00	0.5	14.0	1,535.7	0.4	3.10	1	1	0
10/10/2022 10:00	0.4	14.1	1,390.1	0.3	1.40	1	1	0
10/10/2022 11:00	0.5	14.0	1,562.7	0.4	3.10	1	1	0
10/10/2022 12:00	0.5	14.1	1,576.8	0.4	3.20	1	1	0
10/10/2022 13:00	0.8	13.9	1,704.6	0.7	3.40	1	1	0
10/10/2022 14:00	0.7	13.9	1,711.9	0.6	3.40	1	1	0
10/10/2022 15:00	0.8	13.9	1,584.5	0.7	3.20	1	1	0
10/10/2022 16:00	1.1	12.8	1,953.3	0.8	5.90	1	1	1
10/10/2022 17:00	1.5	12.0	2,159.8	1.0	8.60	1	1	1
10/10/2022 18:00	1.7	11.9	2,194.5	1.1	8.80	1	1	1
10/10/2022 19:00	1.6	12.0	2,171.3	1.1	8.70	1	1	1
10/10/2022 20:00	1.6	12.1	2,163.2	1.1	8.70	1	1	1
10/10/2022 21:00	1.5	12.3	2,109.3	1.0	8.40	1	1	1
10/10/2022 22:00	1.4	12.5	2,091.9	1.0	8.40	1	1	1
10/10/2022 23:00	1.2	13.0	1,947.6	0.9	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,919.9	0.8	146.00 #	24 #	24 #	16 #
Minimum:	0.4	11.9	1,390.1	0.3	1.40	1	1	0
Maximum:	1.7	14.1	2,225.5	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.5	14.0	1,368.8	0.4	2.70	1	1	0
10/11/2022 01:00	0.3	14.0	1,294.0	0.3	1.30	1	1	0
10/11/2022 02:00	0.3	14.0	1,293.9	0.3	1.30	1	1	0
10/11/2022 03:00	0.3	14.0	1,345.8	0.3	1.30	1	1	0
10/11/2022 04:00	0.4	14.0	1,489.9	0.3	1.50	1	1	0
10/11/2022 05:00	0.3	14.0	1,314.3	0.3	1.30	1	1	0
10/11/2022 06:00	0.3	14.0	1,303.1	0.3	1.30	1	1	0
10/11/2022 07:00	0.3	14.0	1,318.9	0.3	1.30	1	1	0
10/11/2022 08:00	0.6	13.9	1,748.2	0.5	3.50	1	1	0
10/11/2022 09:00	0.5	14.0	1,592.2	0.4	3.20	1	1	0
10/11/2022 10:00	0.9	13.8	1,729.7	0.7	5.20	1	1	0
10/11/2022 11:00	0.8	13.8	1,747.4	0.7	3.50	1	1	0
10/11/2022 12:00	0.7	13.9	1,748.6	0.6	3.50	1	1	0
10/11/2022 13:00	0.7	13.9	1,740.2	0.6	3.50	1	1	0
10/11/2022 14:00	0.7	13.9	1,733.2	0.6	3.50	1	1	0
10/11/2022 15:00	0.7	13.9	1,737.7	0.6	3.50	1	1	0
10/11/2022 16:00	0.8	13.8	1,760.7	0.7	3.50	1	1	0
10/11/2022 17:00	0.9	13.7	1,770.9	0.7	5.30	1	1	0
10/11/2022 18:00	0.9	13.7	1,775.7	0.7	5.30	1	1	1
10/11/2022 19:00	1.2	12.5	2,057.5	0.8	6.20	1	1	1
10/11/2022 20:00	1.4	12.3	2,104.9	1.0	8.40	1	1	1
10/11/2022 21:00	1.5	12.1	2,159.4	1.0	8.60	1	1	1
10/11/2022 22:00	1.4	12.4	2,094.6	1.0	8.40	1	1	1
10/11/2022 23:00	1.2	13.0	1,961.3	0.9	5.90	1	1	1
Average/Sum#:	0.7	13.6	1,674.6	0.6	93.00 #	24 #	24 #	6 #
Minimum:	0.3	12.1	1,293.9	0.3	1.30	1	1	0
Maximum:	1.5	14.0	2,159.4	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	1.2	13.1	1,948.6	0.9	5.80	1	1	1
10/12/2022 01:00	1.1	13.1	1,928.9	0.8	5.80	1	1	1
10/12/2022 02:00	0.5	13.9	1,512.2	0.4	3.00	1	1	0
10/12/2022 03:00	0.5	13.9	1,624.7	0.4	3.20	1	1	0
10/12/2022 04:00	0.7	13.8	1,746.5	0.6	3.50	1	1	0
10/12/2022 05:00	1.2	12.4	2,122.6	0.8	6.40	1	1	1
10/12/2022 06:00	1.6	11.9	2,254.3	1.0	9.00	1	1	1
10/12/2022 07:00	1.6	11.9	2,245.2	1.0	9.00	1	1	1
10/12/2022 08:00	1.6	11.9	2,243.2	1.0	9.00	1	1	1
10/12/2022 09:00	1.7	11.9	2,238.0	1.1	9.00	1	1	1
10/12/2022 10:00	1.6	11.9	2,234.1	1.0	8.90	1	1	1
10/12/2022 11:00	1.7	11.9	2,233.9	1.1	8.90	1	1	1
10/12/2022 12:00	1.7	11.9	2,231.6	1.1	8.90	1	1	1
10/12/2022 13:00	1.7	11.9	2,228.9	1.1	8.90	1	1	1
10/12/2022 14:00	1.7	11.9	2,229.7	1.1	8.90	1	1	1
10/12/2022 15:00	1.8	11.8	2,235.6	1.2	8.90	1	1	1
10/12/2022 16:00	1.8	11.6	2,251.1	1.1	9.00	1	1	1
10/12/2022 17:00	1.8	11.6	2,260.5	1.1	9.00	1	1	1
10/12/2022 18:00	1.7	11.8	2,224.2	1.1	8.90	1	1	1
10/12/2022 19:00	1.5	12.2	2,135.6	1.0	8.50	1	1	1
10/12/2022 20:00	1.6	12.2	2,150.7	1.1	8.60	1	1	1
10/12/2022 21:00	1.5	12.3	2,115.2	1.0	8.50	1	1	1
10/12/2022 22:00	1.4	12.5	2,084.9	1.0	8.30	1	1	1
10/12/2022 23:00	1.2	13.0	1,959.2	0.9	5.90	1	1	1
Average/Sum#:	1.4	12.3	2,101.6	1.0	183.80 #	24 #	24 #	21 #
Minimum:	0.5	11.6	1,512.2	0.4	3.00	1	1	0
Maximum:	1.8	13.9	2,260.5	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.2	13.0	1,956.6	0.9	5.90	1	1	1
10/13/2022 01:00	1.3	12.8	2,000.9	0.9	6.00	1	1	1
10/13/2022 02:00	1.2	13.1	1,947.1	0.9	5.80	1	1	1
10/13/2022 03:00	1.2	13.1	1,959.2	0.9	5.90	1	1	1
10/13/2022 04:00	1.2	13.1	1,939.6	0.9	5.80	1	1	1
10/13/2022 05:00	0.4	13.9	1,307.9	0.3	1.30	1	1	0
10/13/2022 06:00	0.4	13.9	1,308.4	0.3	1.30	1	1	0
10/13/2022 07:00	0.3	14.0	1,308.7	0.3	1.30	1	1	0
10/13/2022 08:00	0.5	13.9	1,486.8	0.4	3.00	1	1	0
10/13/2022 09:00	0.5	13.9	1,537.2	0.4	3.10	1	1	0
10/13/2022 10:00	0.8	13.8	1,712.7	0.7	3.40	1	1	0
10/13/2022 11:00	0.9	13.7	1,794.6	0.7	5.40	1	1	0
10/13/2022 12:00	0.9	13.7	1,790.4	0.7	5.40	1	1	0
10/13/2022 13:00	1.1	13.7	1,784.6	0.9	5.40	1	1	0
10/13/2022 14:00	1.3	13.7	1,779.9	1.1	7.10	1	1	0
10/13/2022 15:00	1.3	13.7	1,777.3	1.1	7.10	1	1	0
10/13/2022 16:00	1.2	13.7	1,779.0	1.0	7.10	1	1	0
10/13/2022 17:00	1.2	13.7	1,779.7	1.0	7.10	1	1	0
10/13/2022 18:00	1.2	13.7	1,784.4	1.0	7.10	1	1	0
10/13/2022 19:00	1.2	13.7	1,788.0	1.0	7.20	1	1	1
10/13/2022 20:00	1.4	12.6	2,057.0	1.0	8.20	1	1	1
10/13/2022 21:00	1.6	12.2	2,156.4	1.1	8.60	1	1	1
10/13/2022 22:00	1.6	12.5	2,080.5	1.1	8.30	1	1	1
10/13/2022 23:00	1.6	12.6	2,070.0	1.1	8.30	1	1	1
Average/Sum#:	1.1	13.4	1,787.0	0.8	135.10 #	24 #	24 #	10 #
Minimum:	0.3	12.2	1,307.9	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,156.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.5	12.7	2,061.1	1.1	8.20	1	1	1
10/14/2022 01:00	1.5	12.6	2,074.7	1.1	8.30	1	1	1
10/14/2022 02:00	1.6	12.6	2,074.6	1.1	8.30	1	1	1
10/14/2022 03:00	1.6	12.6	2,071.6	1.1	8.30	1	1	1
10/14/2022 04:00	1.6	12.4	2,112.7	1.1	8.50	1	1	1
10/14/2022 05:00	1.7	11.8	2,260.2	1.1	9.00	1	1	1
10/14/2022 06:00	1.6	11.8	2,253.5	1.0	9.00	1	1	1
10/14/2022 07:00	1.7	11.9	2,225.2	1.1	8.90	1	1	1
10/14/2022 08:00	1.6	12.7	2,025.4	1.2	8.10	1	1	1
10/14/2022 09:00	1.5	13.0	1,963.8	1.1	7.90	1	1	1
10/14/2022 10:00	1.6	12.9	1,974.2	1.2	7.90	1	1	1
10/14/2022 11:00	1.6	12.8	1,981.1	1.2	7.90	1	1	1
10/14/2022 12:00	1.6	12.8	1,989.4	1.2	8.00	1	1	1
10/14/2022 13:00	1.6	12.7	1,999.2	1.2	8.00	1	1	1
10/14/2022 14:00	1.7	12.3	2,098.0	1.2	8.40	1	1	1
10/14/2022 15:00	1.7	12.2	2,127.4	1.2	8.50	1	1	1
10/14/2022 16:00	1.7	12.2	2,119.3	1.2	8.50	1	1	1
10/14/2022 17:00	1.7	11.8	2,207.4	1.1	8.80	1	1	1
10/14/2022 18:00	1.7	12.1	2,149.5	1.1	8.60	1	1	1
10/14/2022 19:00	1.7	12.2	2,120.7	1.2	8.50	1	1	1
10/14/2022 20:00	1.7	12.2	2,129.6	1.2	8.50	1	1	1
10/14/2022 21:00	1.6	12.3	2,120.9	1.1	8.50	1	1	1
10/14/2022 22:00	1.6	12.4	2,093.7	1.1	8.40	1	1	1
10/14/2022 23:00	2.8	14.0	1,326.6	2.4	6.55	1	0	1
Average/Sum#:	1.7	12.5	2,065.0	1.2	199.55 #	24 #	23 #	24 #
Minimum:	1.5	11.8	1,326.6	1.0	6.55	1	0	1
Maximum:	2.8	14.0	2,260.2	2.4	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 17:00	27.1	17.7	328.5	50.0	44.09	1	0	0
10/16/2022 18:00	16.7	16.5	574.4	22.4	47.10	1	0	0
10/16/2022 19:00	12.3	15.1	965.7	12.5	44.40	1	0	0
10/16/2022 20:00	1.1	13.8	1,770.5	0.9	5.30	1	1	0
10/16/2022 21:00	1.2	13.8	1,686.0	1.0	6.70	1	1	0
10/16/2022 22:00	1.0	13.9	1,594.4	0.8	4.80	1	1	0
10/16/2022 23:00	1.2	13.8	1,803.8	1.0	7.20	1	1	0
Average/Sum#:	8.7	14.9	1,246.2	12.7	159.59 #	7 #	4 #	0 #
Minimum:	1.0	13.8	328.5	0.8	4.80	0	0	0
Maximum:	27.1	17.7	1,803.8	50.0	47.10	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	1.0	13.9	1,642.9	0.8	4.90	1	1	0
10/17/2022 01:00	1.0	13.9	1,698.6	0.8	5.10	1	1	0
10/17/2022 02:00	0.9	13.9	1,702.5	0.8	5.10	1	1	0
10/17/2022 03:00	1.1	13.8	1,794.9	0.9	5.40	1	1	1
10/17/2022 04:00	1.5	12.7	2,058.2	1.1	8.20	1	1	1
10/17/2022 05:00	1.6	12.2	2,160.0	1.1	8.60	1	1	1
10/17/2022 06:00	1.6	12.3	2,145.3	1.1	8.60	1	1	1
10/17/2022 07:00	1.6	12.5	2,099.6	1.1	8.40	1	1	1
10/17/2022 08:00	1.0	13.8	1,683.3	0.8	5.00	1	1	1
10/17/2022 09:00	0.9	13.9	1,632.3	0.8	4.90	1	1	0
10/17/2022 10:00	0.9	14.0	1,522.6	0.8	4.60	1	1	0
10/17/2022 11:00	0.9	14.0	1,609.1	0.8	4.80	1	1	0
10/17/2022 12:00	0.9	14.0	1,506.6	0.8	4.50	1	1	0
10/17/2022 13:00	0.9	14.0	1,501.4	0.8	4.50	1	1	0
10/17/2022 14:00	0.9	14.0	1,657.9	0.8	5.00	1	1	0
10/17/2022 15:00	1.1	13.8	1,696.8	0.9	5.10	1	1	1
10/17/2022 16:00	1.5	12.5	2,079.8	1.1	8.30	1	1	1
10/17/2022 17:00	1.7	11.8	2,230.9	1.1	8.90	1	1	1
10/17/2022 18:00	1.7	11.8	2,246.4	1.1	9.00	1	1	1
10/17/2022 19:00	1.7	11.9	2,223.6	1.1	8.90	1	1	1
10/17/2022 20:00	1.7	11.9	2,229.9	1.1	8.90	1	1	1
10/17/2022 21:00	1.7	11.8	2,239.7	1.1	9.00	1	1	1
10/17/2022 22:00	1.7	12.2	2,177.2	1.2	8.70	1	1	1
10/17/2022 23:00	1.7	12.2	2,183.6	1.2	8.70	1	1	1
Average/Sum#:	1.3	13.0	1,905.1	1.0	163.10 #	24 #	24 #	15 #
Minimum:	0.9	11.8	1,501.4	0.8	4.50	1	1	0
Maximum:	1.7	14.0	2,246.4	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.6	12.2	2,179.1	1.1	8.70	1	1	1
10/18/2022 01:00	1.7	12.3	2,170.9	1.2	8.70	1	1	1
10/18/2022 02:00	1.6	12.2	2,170.7	1.1	8.70	1	1	1
10/18/2022 03:00	1.6	12.1	2,176.9	1.1	8.70	1	1	1
10/18/2022 04:00	1.6	12.1	2,177.4	1.1	8.70	1	1	1
10/18/2022 05:00	1.7	12.2	2,182.6	1.2	8.70	1	1	1
10/18/2022 06:00	1.7	12.3	2,168.2	1.2	8.70	1	1	1
10/18/2022 07:00	1.6	12.3	2,166.7	1.1	8.70	1	1	1
10/18/2022 08:00	1.6	12.3	2,171.0	1.1	8.70	1	1	1
10/18/2022 09:00	1.6	12.4	2,155.8	1.1	8.60	1	1	1
10/18/2022 10:00	1.6	12.4	2,119.5	1.1	8.50	1	1	1
10/18/2022 11:00	1.6	12.5	2,098.2	1.1	8.40	1	1	1
10/18/2022 12:00	1.6	12.5	2,098.2	1.1	8.40	1	1	1
10/18/2022 13:00	1.6	12.5	2,102.8	1.1	8.40	1	1	1
10/18/2022 14:00	1.6	12.4	2,107.4	1.1	8.40	1	1	1
10/18/2022 15:00	1.6	12.3	2,134.7	1.1	8.50	1	1	1
10/18/2022 16:00	1.7	11.9	2,216.3	1.1	8.90	1	1	1
10/18/2022 17:00	1.7	12.1	2,188.4	1.1	8.80	1	1	1
10/18/2022 18:00	1.7	11.9	2,231.8	1.1	8.90	1	1	1
10/18/2022 19:00	1.7	11.8	2,253.5	1.1	9.00	1	1	1
10/18/2022 20:00	1.7	11.8	2,259.4	1.1	9.00	1	1	1
10/18/2022 21:00	1.7	11.8	2,259.3	1.1	9.00	1	1	1
10/18/2022 22:00	1.7	12.1	2,195.6	1.1	8.80	1	1	1
10/18/2022 23:00	1.7	12.1	2,192.8	1.1	8.80	1	1	1
Average/Sum#:	1.6	12.2	2,174.1	1.1	208.70 #	24 #	24 #	24 #
Minimum:	1.6	11.8	2,098.2	1.1	8.40	1	1	1
Maximum:	1.7	12.5	2,259.4	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	1.6	12.2	2,182.0	1.1	8.70	1	1	1
10/19/2022 01:00	1.6	12.5	2,136.3	1.1	8.50	1	1	1
10/19/2022 02:00	1.6	12.6	2,103.7	1.1	8.40	1	1	1
10/19/2022 03:00	1.6	12.5	2,144.5	1.1	8.60	1	1	1
10/19/2022 04:00	1.6	12.3	2,188.0	1.1	8.80	1	1	1
10/19/2022 05:00	1.7	12.0	2,237.9	1.1	9.00	1	1	1
10/19/2022 06:00	1.6	12.2	2,213.4	1.1	8.90	1	1	1
10/19/2022 07:00	1.6	12.4	2,148.6	1.1	8.60	1	1	1
10/19/2022 08:00	1.6	12.5	2,138.1	1.1	8.60	1	1	1
10/19/2022 09:00	1.6	12.6	2,094.9	1.1	8.40	1	1	1
10/19/2022 10:00	1.6	12.6	2,079.5	1.1	8.30	1	1	1
10/19/2022 11:00	1.6	12.4	2,110.0	1.1	8.40	1	1	1
10/19/2022 12:00	1.6	12.3	2,130.2	1.1	8.50	1	1	1
10/19/2022 13:00	1.6	12.2	2,149.0	1.1	8.60	1	1	1
10/19/2022 14:00	1.7	12.2	2,141.4	1.2	8.60	1	1	1
10/19/2022 15:00	1.7	12.0	2,178.1	1.1	8.70	1	1	1
10/19/2022 16:00	1.7	12.0	2,194.2	1.1	8.80	1	1	1
10/19/2022 17:00	1.6	12.3	2,123.6	1.1	8.50	1	1	1
10/19/2022 18:00	1.6	12.4	2,099.3	1.1	8.40	1	1	1
10/19/2022 19:00	1.6	12.4	2,108.5	1.1	8.40	1	1	1
10/19/2022 20:00	1.6	12.3	2,147.1	1.1	8.60	1	1	1
10/19/2022 21:00	1.6	12.5	2,114.2	1.1	8.50	1	1	1
10/19/2022 22:00	1.6	12.6	2,087.5	1.1	8.40	1	1	1
10/19/2022 23:00	1.6	12.5	2,105.2	1.1	8.40	1	1	1
Average/Sum#:	1.6	12.4	2,139.8	1.1	205.60 #	24 #	24 #	24 #
Minimum:	1.6	12.0	2,079.5	1.1	8.30	1	1	1
Maximum:	1.7	12.6	2,237.9	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.6	12.5	2,124.0	1.1	8.50	1	1	1
10/20/2022 01:00	1.6	12.6	2,087.9	1.1	8.40	1	1	1
10/20/2022 02:00	1.6	12.6	2,078.6	1.1	8.30	1	1	1
10/20/2022 03:00	1.6	12.6	2,089.3	1.1	8.40	1	1	1
10/20/2022 04:00	1.6	12.5	2,135.5	1.1	8.50	1	1	1
10/20/2022 05:00	1.7	12.1	2,217.9	1.1	8.90	1	1	1
10/20/2022 06:00	1.5	12.3	2,191.7	1.0	8.80	1	1	1
10/20/2022 07:00	1.5	12.8	2,069.5	1.1	8.30	1	1	1
10/20/2022 08:00	1.6	12.8	2,056.4	1.2	8.20	1	1	1
10/20/2022 09:00	1.6	12.7	2,066.1	1.2	8.30	1	1	1
10/20/2022 10:00	1.6	12.7	2,060.8	1.2	8.20	1	1	1
10/20/2022 11:00	1.6	12.5	2,079.4	1.1	8.30	1	1	1
10/20/2022 12:00	1.6	12.5	2,079.4	1.1	8.30	1	1	1
10/20/2022 13:00	1.6	12.4	2,099.7	1.1	8.40	1	1	1
10/20/2022 14:00	1.6	12.3	2,121.0	1.1	8.50	1	1	1
10/20/2022 15:00	1.6	12.2	2,147.2	1.1	8.60	1	1	1
10/20/2022 16:00	1.7	11.7	2,241.0	1.1	9.00	1	1	1
10/20/2022 17:00	1.7	12.0	2,178.6	1.1	8.70	1	1	1
10/20/2022 18:00	1.7	11.9	2,212.5	1.1	8.90	1	1	1
10/20/2022 19:00	1.6	12.3	2,107.9	1.1	8.40	1	1	1
10/20/2022 20:00	1.6	12.4	2,104.9	1.1	8.40	1	1	1
10/20/2022 21:00	1.6	12.6	2,083.3	1.1	8.30	1	1	1
10/20/2022 22:00	1.6	12.6	2,083.3	1.1	8.30	1	1	1
10/20/2022 23:00	1.6	12.4	2,136.7	1.1	8.50	1	1	1
Average/Sum#:	1.6	12.4	2,118.9	1.1	203.40 #	24 #	24 #	24 #
Minimum:	1.5	11.7	2,056.4	1.0	8.20	1	1	1
Maximum:	1.7	12.8	2,241.0	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	1.5	12.9	1,988.0	1.1	8.00	1	1	1
10/21/2022 01:00	1.0	14.0	1,577.0	0.9	4.70	1	1	0
10/21/2022 02:00	1.0	13.9	1,586.8	0.8	4.80	1	1	0
10/21/2022 03:00	0.9	13.9	1,543.4	0.8	4.60	1	1	0
10/21/2022 04:00	0.9	14.0	1,696.1	0.8	5.10	1	1	0
10/21/2022 05:00	0.9	14.0	1,698.2	0.8	5.10	1	1	0
10/21/2022 06:00	0.8	14.0	1,598.5	0.7	4.80	1	1	0
10/21/2022 07:00	0.9	14.0	1,668.5	0.8	5.00	1	1	0
10/21/2022 08:00	0.9	14.0	1,704.9	0.8	5.10	1	1	0
10/21/2022 09:00	0.9	14.0	1,708.4	0.8	5.10	1	1	0
10/21/2022 10:00	0.9	14.0	1,706.9	0.8	5.10	1	1	0
10/21/2022 11:00	0.9	14.0	1,671.9	0.8	5.00	1	1	0
10/21/2022 12:00	1.1	14.0	1,648.8	0.9	4.90	1	1	0
10/21/2022 13:00	1.0	14.0	1,624.1	0.9	4.90	1	1	0
10/21/2022 14:00	1.1	13.9	1,681.0	0.9	5.00	1	1	0
10/21/2022 15:00	1.0	13.9	1,556.4	0.8	4.70	1	1	1
10/21/2022 16:00	1.6	12.4	2,095.8	1.1	8.40	1	1	1
10/21/2022 17:00	1.7	12.0	2,180.2	1.1	8.70	1	1	1
10/21/2022 18:00	1.7	12.2	2,136.5	1.2	8.50	1	1	1
10/21/2022 19:00	1.6	12.4	2,098.4	1.1	8.40	1	1	1
10/21/2022 20:00	1.7	12.3	2,116.7	1.2	8.50	1	1	1
10/21/2022 21:00	1.7	12.0	2,176.0	1.1	8.70	1	1	1
10/21/2022 22:00	2.8	14.3	1,201.6	2.5	5.62	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.5	1,768.0	1.0	138.72 #	23 #	22 #	9 #
Minimum:	0.8	12.0	1,201.6	0.7	4.60	0	0	0
Maximum:	2.8	14.3	2,180.2	2.5	8.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 20:00	29.9	17.8	297.2	56.9	44.93	1	0	0
10/23/2022 21:00	14.6	17.3	370.7	23.9	32.60	1	0	0
10/23/2022 22:00	12.7	15.9	787.1	15.0	43.30	1	0	0
10/23/2022 23:00	0.6	14.1	1,353.7	0.5	2.70	1	1	0
Average/Sum#:	14.5	16.3	702.2	24.1	123.53 #	4 #	1 #	0 #
Minimum:	0.6	14.1	297.2	0.5	2.70	0	0	0
Maximum:	29.9	17.8	1,353.7	56.9	44.93	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.7	14.1	1,368.5	0.6	2.70	1	1	0
10/24/2022 01:00	0.7	14.1	1,359.7	0.6	2.70	1	1	0
10/24/2022 02:00	0.7	14.1	1,359.6	0.6	2.70	1	1	0
10/24/2022 03:00	0.7	14.1	1,359.6	0.6	2.70	1	1	0
10/24/2022 04:00	1.0	13.9	1,649.1	0.8	4.90	1	1	0
10/24/2022 05:00	1.1	13.8	1,820.4	0.9	5.50	1	1	0
10/24/2022 06:00	1.2	13.8	1,821.7	1.0	7.30	1	1	0
10/24/2022 07:00	1.1	13.8	1,819.3	0.9	5.50	1	1	0
10/24/2022 08:00	1.2	13.9	1,816.0	1.0	7.30	1	1	0
10/24/2022 09:00	1.1	13.9	1,793.7	0.9	5.40	1	1	0
10/24/2022 10:00	1.2	13.8	1,841.1	1.0	7.40	1	1	0
10/24/2022 11:00	1.2	13.8	1,831.5	1.0	7.30	1	1	0
10/24/2022 12:00	0.9	13.9	1,769.6	0.8	5.30	1	1	0
10/24/2022 13:00	0.9	13.9	1,746.6	0.8	5.20	1	1	0
10/24/2022 14:00	2.2	15.1	1,013.9	2.2	3.40	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	14.0	1,624.7	0.9	75.30 #	15 #	14 #	0 #
Minimum:	0.7	13.8	1,013.9	0.6	2.70	0	0	0
Maximum:	2.2	15.1	1,841.1	2.2	7.40	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 19:00	10.7	18.9	164.5	31.6	3.82	1	0	0
10/30/2022 20:00	29.2	17.3	372.9	47.9	65.60	1	0	0
10/30/2022 21:00	13.4	16.8	562.7	19.3	40.00	1	0	0
10/30/2022 22:00	15.3	16.0	878.4	18.4	59.70	1	0	0
10/30/2022 23:00	1.0	13.8	1,773.4	0.8	5.30	1	1	0
Average/Sum#:	13.9	16.6	750.4	23.6	174.42 #	5 #	1 #	0 #
Minimum:	1.0	13.8	164.5	0.8	3.82	0	0	0
Maximum:	29.2	18.9	1,773.4	47.9	65.60	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.9	14.0	1,565.8	0.8	4.70	1	1	0
10/31/2022 01:00	1.1	13.9	1,787.0	0.9	5.40	1	1	0
10/31/2022 02:00	0.9	14.0	1,671.4	0.8	5.00	1	1	0
10/31/2022 03:00	0.9	14.0	1,708.8	0.8	5.10	1	1	0
10/31/2022 04:00	0.9	14.0	1,723.8	0.8	5.20	1	1	0
10/31/2022 05:00	0.8	14.0	1,708.1	0.7	5.10	1	1	0
10/31/2022 06:00	0.8	14.0	1,699.3	0.7	5.10	1	1	0
10/31/2022 07:00	0.8	14.0	1,700.7	0.7	5.10	1	1	0
10/31/2022 08:00	0.8	14.0	1,704.0	0.7	5.10	1	1	0
10/31/2022 09:00	0.8	14.0	1,705.2	0.7	5.10	1	1	0
10/31/2022 10:00	0.9	14.0	1,708.1	0.8	5.10	1	1	0
10/31/2022 11:00	0.9	14.0	1,687.1	0.8	5.10	1	1	0
10/31/2022 12:00	0.9	14.0	1,677.9	0.8	5.00	1	1	0
10/31/2022 13:00	0.9	14.0	1,691.9	0.8	5.10	1	1	0
10/31/2022 14:00	1.1	13.9	1,760.4	0.9	5.30	1	1	1
10/31/2022 15:00	1.5	12.6	2,079.3	1.1	8.30	1	1	1
10/31/2022 16:00	1.6	12.5	2,105.8	1.1	8.40	1	1	1
10/31/2022 17:00	1.6	12.6	2,078.5	1.1	8.30	1	1	1
10/31/2022 18:00	1.6	12.6	2,081.3	1.1	8.30	1	1	1
10/31/2022 19:00	1.6	12.5	2,104.0	1.1	8.40	1	1	1
10/31/2022 20:00	1.6	12.5	2,108.1	1.1	8.40	1	1	1
10/31/2022 21:00	1.6	12.3	2,163.0	1.1	8.70	1	1	1
10/31/2022 22:00	1.6	12.5	2,119.3	1.1	8.50	1	1	1
10/31/2022 23:00	1.6	12.3	2,146.3	1.1	8.60	1	1	1
Average/Sum#:	1.2	13.4	1,853.5	0.9	152.40 #	24 #	24 #	10 #
Minimum:	0.8	12.3	1,565.8	0.7	4.70	1	1	0
Maximum:	1.6	14.0	2,163.0	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.6	12.4	2,163.8	1.1	8.70	1	1	1
11/01/2022 01:00	1.6	12.4	2,153.2	1.1	8.60	1	1	1
11/01/2022 02:00	1.6	12.4	2,162.1	1.1	8.60	1	1	1
11/01/2022 03:00	1.6	12.4	2,163.5	1.1	8.70	1	1	1
11/01/2022 04:00	1.6	12.4	2,167.9	1.1	8.70	1	1	1
11/01/2022 05:00	1.6	12.4	2,167.4	1.1	8.70	1	1	1
11/01/2022 06:00	1.7	12.1	2,232.9	1.1	8.90	1	1	1
11/01/2022 07:00	1.7	12.3	2,179.4	1.2	8.70	1	1	1
11/01/2022 08:00	1.7	12.0	2,231.6	1.1	8.90	1	1	1
11/01/2022 09:00	1.6	12.4	2,116.2	1.1	8.50	1	1	1
11/01/2022 10:00	1.6	12.5	2,121.2	1.1	8.50	1	1	1
11/01/2022 11:00	1.6	12.2	2,178.7	1.1	8.70	1	1	1
11/01/2022 12:00	1.6	12.2	2,182.8	1.1	8.70	1	1	1
11/01/2022 13:00	1.6	12.3	2,169.2	1.1	8.70	1	1	1
11/01/2022 14:00	1.5	12.6	2,083.1	1.1	8.30	1	1	1
11/01/2022 15:00	1.6	12.7	2,094.6	1.2	8.40	1	1	1
11/01/2022 16:00	1.7	12.2	2,225.8	1.2	8.90	1	1	1
11/01/2022 17:00	1.7	11.9	2,292.1	1.1	9.20	1	1	1
11/01/2022 18:00	1.6	12.3	2,192.0	1.1	8.80	1	1	1
11/01/2022 19:00	1.6	12.5	2,163.6	1.1	8.70	1	1	1
11/01/2022 20:00	1.6	12.3	2,201.7	1.1	8.80	1	1	1
11/01/2022 21:00	1.6	12.8	2,080.8	1.2	8.30	1	1	1
11/01/2022 22:00	1.4	12.9	2,070.4	1.0	8.30	1	1	1
11/01/2022 23:00	1.2	13.4	1,845.9	0.9	5.50	1	1	1
Average/Sum#:	1.6	12.4	2,151.7	1.1	204.80 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,845.9	0.9	5.50	1	1	1
Maximum:	1.7	13.4	2,292.1	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.6	14.1	1,347.9	0.5	2.70	1	1	0
11/02/2022 01:00	0.8	14.0	1,630.5	0.7	4.90	1	1	0
11/02/2022 02:00	0.8	14.0	1,698.9	0.7	5.10	1	1	0
11/02/2022 03:00	0.6	14.0	1,348.8	0.5	2.70	1	1	0
11/02/2022 04:00	0.9	14.0	1,665.7	0.8	5.00	1	1	0
11/02/2022 05:00	1.1	13.5	1,907.9	0.9	5.70	1	1	1
11/02/2022 06:00	1.4	12.7	2,175.1	1.0	8.70	1	1	1
11/02/2022 07:00	1.5	12.8	2,135.9	1.1	8.50	1	1	1
11/02/2022 08:00	1.4	13.1	2,040.3	1.1	8.20	1	1	1
11/02/2022 09:00	0.9	14.0	1,710.1	0.8	5.10	1	1	0
11/02/2022 10:00	0.8	14.0	1,543.3	0.7	4.60	1	1	0
11/02/2022 11:00	0.9	14.0	1,672.4	0.8	5.00	1	1	0
11/02/2022 12:00	0.8	14.0	1,549.7	0.7	4.60	1	1	0
11/02/2022 13:00	0.8	14.0	1,552.9	0.7	4.70	1	1	0
11/02/2022 14:00	0.8	14.0	1,535.2	0.7	4.60	1	1	0
11/02/2022 15:00	1.0	14.0	1,604.0	0.9	4.80	1	1	1
11/02/2022 16:00	1.5	12.8	2,092.6	1.1	8.40	1	1	1
11/02/2022 17:00	1.6	12.5	2,182.8	1.1	8.70	1	1	1
11/02/2022 18:00	1.6	12.5	2,177.3	1.1	8.70	1	1	1
11/02/2022 19:00	1.6	12.5	2,175.0	1.1	8.70	1	1	1
11/02/2022 20:00	1.6	12.6	2,175.1	1.1	8.70	1	1	1
11/02/2022 21:00	1.6	12.6	2,157.6	1.1	8.60	1	1	1
11/02/2022 22:00	1.6	12.6	2,164.2	1.1	8.70	1	1	1
11/02/2022 23:00	1.6	12.6	2,177.5	1.1	8.70	1	1	1
Average/Sum#:	1.2	13.4	1,850.9	0.9	154.10 #	24 #	24 #	13 #
Minimum:	0.6	12.5	1,347.9	0.5	2.70	1	1	0
Maximum:	1.6	14.1	2,182.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.6	12.6	2,169.0	1.1	8.70	1	1	1
11/03/2022 01:00	1.6	12.7	2,153.0	1.2	8.60	1	1	1
11/03/2022 02:00	1.6	12.5	2,194.3	1.1	8.80	1	1	1
11/03/2022 03:00	1.6	12.3	2,234.1	1.1	8.90	1	1	1
11/03/2022 04:00	1.6	12.6	2,163.9	1.1	8.70	1	1	1
11/03/2022 05:00	1.6	12.6	2,166.0	1.1	8.70	1	1	1
11/03/2022 06:00	1.3	12.4	2,231.2	0.9	6.70	1	1	1
11/03/2022 07:00	1.5	12.8	2,110.9	1.1	8.40	1	1	1
11/03/2022 08:00	0.8	14.1	1,456.2	0.7	4.40	1	1	0
11/03/2022 09:00	0.8	14.0	1,559.4	0.7	4.70	1	1	0
11/03/2022 10:00	0.8	14.0	1,574.2	0.7	4.70	1	1	0
11/03/2022 11:00	0.8	14.0	1,570.2	0.7	4.70	1	1	0
11/03/2022 12:00	0.8	14.0	1,579.0	0.7	4.70	1	1	0
11/03/2022 13:00	0.8	14.1	1,487.4	0.7	4.50	1	1	0
11/03/2022 14:00	0.8	14.1	1,553.3	0.7	4.70	1	1	0
11/03/2022 15:00	1.0	14.0	1,771.8	0.9	5.30	1	1	1
11/03/2022 16:00	1.5	12.8	2,084.1	1.1	8.30	1	1	1
11/03/2022 17:00	1.6	12.5	2,162.5	1.1	8.70	1	1	1
11/03/2022 18:00	1.6	12.5	2,175.5	1.1	8.70	1	1	1
11/03/2022 19:00	1.6	12.5	2,174.2	1.1	8.70	1	1	1
11/03/2022 20:00	1.5	12.5	2,163.4	1.1	8.70	1	1	1
11/03/2022 21:00	1.6	12.5	2,161.9	1.1	8.60	1	1	1
11/03/2022 22:00	1.6	12.5	2,161.6	1.1	8.60	1	1	1
11/03/2022 23:00	1.6	12.4	2,201.2	1.1	8.80	1	1	1
Average/Sum#:	1.3	13.0	1,969.1	1.0	174.30 #	24 #	24 #	17 #
Minimum:	0.8	12.3	1,456.2	0.7	4.40	1	1	0
Maximum:	1.6	14.1	2,234.1	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.5	12.7	2,139.4	1.1	8.60	1	1	1
11/04/2022 01:00	1.6	12.7	2,120.0	1.2	8.50	1	1	1
11/04/2022 02:00	1.5	12.9	2,069.1	1.1	8.30	1	1	1
11/04/2022 03:00	1.5	12.9	2,071.1	1.1	8.30	1	1	1
11/04/2022 04:00	1.6	12.7	2,149.6	1.2	8.60	1	1	1
11/04/2022 05:00	1.6	12.3	2,242.1	1.1	9.00	1	1	1
11/04/2022 06:00	1.5	12.6	2,177.1	1.1	8.70	1	1	1
11/04/2022 07:00	1.4	13.0	2,059.9	1.0	8.20	1	1	1
11/04/2022 08:00	0.8	14.0	1,718.3	0.7	5.20	1	1	1
11/04/2022 09:00	0.8	14.0	1,552.2	0.7	4.70	1	1	0
11/04/2022 10:00	0.7	14.1	1,390.6	0.6	2.80	1	1	0
11/04/2022 11:00	0.7	14.1	1,319.4	0.6	2.60	1	1	0
11/04/2022 12:00	0.7	14.1	1,316.8	0.6	2.60	1	1	0
11/04/2022 13:00	0.7	14.1	1,317.6	0.6	2.60	1	1	0
11/04/2022 14:00	0.8	14.1	1,398.3	0.7	4.20	1	1	0
11/04/2022 15:00	1.0	13.9	1,629.0	0.8	4.90	1	1	1
11/04/2022 16:00	1.6	12.7	2,105.1	1.2	8.40	1	1	1
11/04/2022 17:00	1.6	12.5	2,145.5	1.1	8.60	1	1	1
11/04/2022 18:00	1.5	12.8	2,089.4	1.1	8.40	1	1	1
11/04/2022 19:00	1.6	12.8	2,086.7	1.2	8.30	1	1	1
11/04/2022 20:00	1.5	12.8	2,076.1	1.1	8.30	1	1	1
11/04/2022 21:00	1.6	12.8	2,074.7	1.2	8.30	1	1	1
11/04/2022 22:00	1.5	12.8	2,082.6	1.1	8.30	1	1	1
11/04/2022 23:00	1.3	13.3	1,970.2	1.0	7.90	1	1	1
Average/Sum#:	1.3	13.2	1,887.5	1.0	164.30 #	24 #	24 #	18 #
Minimum:	0.7	12.3	1,316.8	0.6	2.60	1	1	0
Maximum:	1.6	14.1	2,242.1	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	1.3	13.3	1,965.0	1.0	7.90	1	1	1
11/05/2022 01:00	1.3	13.3	1,965.4	1.0	7.90	1	1	1
11/05/2022 02:00	1.2	13.3	1,965.9	0.9	5.90	1	1	1
11/05/2022 03:00	1.3	13.3	1,965.1	1.0	7.90	1	1	1
11/05/2022 04:00	1.3	13.3	1,973.7	1.0	7.90	1	1	1
11/05/2022 05:00	1.3	13.3	1,978.5	1.0	7.90	1	1	1
11/05/2022 06:00	1.4	13.3	1,948.0	1.1	7.80	1	1	1
11/05/2022 07:00	7.3	15.9	568.2	8.6	4.19	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	13.6	1,791.2	2.0	57.39 #	8 #	7 #	7 #
Minimum:	1.2	13.3	568.2	0.9	4.19	0	0	0
Maximum:	7.3	15.9	1,978.5	8.6	7.90	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 09:00	21.3	18.2	259.0	46.5	15.51	1	0	0
11/06/2022 10:00	18.5	17.4	380.5	31.2	43.80	1	0	0
11/06/2022 11:00	12.6	15.7	828.7	14.3	43.90	1	0	0
11/06/2022 12:00	0.7	14.0	1,401.7	0.6	2.80	1	1	0
11/06/2022 13:00	0.9	14.0	1,533.1	0.8	4.60	1	1	0
11/06/2022 14:00	1.1	13.9	1,606.7	0.9	4.80	1	1	0
11/06/2022 15:00	1.6	12.9	1,957.5	1.2	7.80	1	1	1
11/06/2022 16:00	1.7	11.8	2,286.9	1.1	9.10	1	1	1
11/06/2022 17:00	1.7	11.7	2,303.5	1.1	9.20	1	1	1
11/06/2022 18:00	1.5	12.9	2,010.4	1.1	8.00	1	1	1
11/06/2022 19:00	1.5	13.2	1,964.3	1.1	7.90	1	1	1
11/06/2022 20:00	1.5	13.1	1,989.1	1.1	8.00	1	1	1
11/06/2022 21:00	2.0	13.3	1,677.6	1.6	9.80	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.1	14.0	1,553.8	7.9	175.21 #	13 #	9 #	7 #
Minimum:	0.7	11.7	259.0	0.6	2.80	0	0	0
Maximum:	21.3	18.2	2,303.5	46.5	43.90	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	2.6	18.1	314.8	5.5	2.84	1	0	0
11/07/2022 01:00	10.4	15.3	1,013.6	11.0	40.50	1	0	0
11/07/2022 02:00	0.8	14.0	1,566.8	0.7	4.70	1	1	0
11/07/2022 03:00	0.9	14.0	1,619.9	0.8	4.90	1	1	0
11/07/2022 04:00	0.9	14.0	1,676.5	0.8	5.00	1	1	0
11/07/2022 05:00	1.0	13.9	1,708.4	0.8	5.10	1	1	0
11/07/2022 06:00	1.4	12.9	2,008.4	1.0	8.00	1	1	1
11/07/2022 07:00	1.7	12.2	2,239.0	1.2	9.00	1	1	1
11/07/2022 08:00	1.4	13.2	1,992.4	1.1	8.00	1	1	1
11/07/2022 09:00	1.4	13.2	1,975.3	1.1	7.90	1	1	1
11/07/2022 10:00	1.5	13.2	1,964.7	1.1	7.90	1	1	1
11/07/2022 11:00	1.5	13.2	1,962.6	1.1	7.90	1	1	1
11/07/2022 12:00	1.5	13.2	1,963.8	1.1	7.90	1	1	1
11/07/2022 13:00	1.4	13.2	1,962.7	1.1	7.90	1	1	1
11/07/2022 14:00	1.5	12.8	2,060.4	1.1	8.20	1	1	1
11/07/2022 15:00	1.6	12.3	2,192.5	1.1	8.80	1	1	1
11/07/2022 16:00	1.7	12.0	2,250.1	1.1	9.00	1	1	1
11/07/2022 17:00	1.7	11.9	2,290.9	1.1	9.20	1	1	1
11/07/2022 18:00	1.7	11.9	2,297.0	1.1	9.20	1	1	1
11/07/2022 19:00	1.7	11.9	2,293.7	1.1	9.20	1	1	1
11/07/2022 20:00	1.7	11.9	2,289.5	1.1	9.20	1	1	1
11/07/2022 21:00	1.7	11.9	2,293.4	1.1	9.20	1	1	1
11/07/2022 22:00	1.7	12.1	2,257.7	1.1	9.00	1	1	1
11/07/2022 23:00	1.6	12.4	2,181.0	1.1	8.70	1	1	1
Average/Sum#:	1.9	13.1	1,932.3	1.6	217.24 #	24 #	22 #	18 #
Minimum:	0.8	11.9	314.8	0.7	2.84	1	0	0
Maximum:	10.4	18.1	2,297.0	11.0	40.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	1.6	12.4	2,172.6	1.1	8.70	1	1	1
11/08/2022 01:00	1.6	12.5	2,167.5	1.1	8.70	1	1	1
11/08/2022 02:00	1.6	12.6	2,112.2	1.1	8.40	1	1	1
11/08/2022 03:00	1.6	12.5	2,160.9	1.1	8.60	1	1	1
11/08/2022 04:00	1.7	12.3	2,200.1	1.2	8.80	1	1	1
11/08/2022 05:00	1.7	12.2	2,219.7	1.2	8.90	1	1	1
11/08/2022 06:00	1.6	11.8	2,300.5	1.0	9.20	1	1	1
11/08/2022 07:00	1.7	12.2	2,213.6	1.2	8.90	1	1	1
11/08/2022 08:00	1.7	12.2	2,202.3	1.2	8.80	1	1	1
11/08/2022 09:00	1.6	12.2	2,200.4	1.1	8.80	1	1	1
11/08/2022 10:00	1.6	12.3	2,185.6	1.1	8.70	1	1	1
11/08/2022 11:00	1.5	13.0	2,032.7	1.1	8.10	1	1	1
11/08/2022 12:00	1.4	13.2	1,987.2	1.1	7.90	1	1	1
11/08/2022 13:00	1.3	13.2	1,985.1	1.0	7.90	1	1	1
11/08/2022 14:00	1.5	12.9	2,056.2	1.1	8.20	1	1	1
11/08/2022 15:00	1.4	12.9	2,056.3	1.0	8.20	1	1	1
11/08/2022 16:00	1.6	12.3	2,217.1	1.1	8.90	1	1	1
11/08/2022 17:00	1.7	12.3	2,201.6	1.2	8.80	1	1	1
11/08/2022 18:00	1.6	12.4	2,173.9	1.1	8.70	1	1	1
11/08/2022 19:00	1.6	12.3	2,206.4	1.1	8.80	1	1	1
11/08/2022 20:00	1.7	12.3	2,206.2	1.2	8.80	1	1	1
11/08/2022 21:00	1.6	12.3	2,204.5	1.1	8.80	1	1	1
11/08/2022 22:00	1.6	12.3	2,190.4	1.1	8.80	1	1	1
11/08/2022 23:00	1.6	12.5	2,146.3	1.1	8.60	1	1	1
Average/Sum#:	1.6	12.5	2,158.3	1.1	207.00 #	24 #	24 #	24 #
Minimum:	1.3	11.8	1,985.1	1.0	7.90	1	1	1
Maximum:	1.7	13.2	2,300.5	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2022 00:00	1.6	12.5	2,155.3	1.1	8.60	1	1	1
11/09/2022 01:00	1.6	12.5	2,154.5	1.1	8.60	1	1	1
11/09/2022 02:00	1.6	12.4	2,194.0	1.1	8.80	1	1	1
11/09/2022 03:00	1.6	12.4	2,195.1	1.1	8.80	1	1	1
11/09/2022 04:00	1.6	12.5	2,162.1	1.1	8.60	1	1	1
11/09/2022 05:00	1.7	12.2	2,258.0	1.2	9.00	1	1	1
11/09/2022 06:00	1.6	12.0	2,298.8	1.1	9.20	1	1	1
11/09/2022 07:00	1.5	12.4	2,203.8	1.0	8.80	1	1	1
11/09/2022 08:00	1.6	12.5	2,162.6	1.1	8.70	1	1	1
11/09/2022 09:00	1.0	13.8	1,742.9	0.8	5.20	1	1	1
11/09/2022 10:00	0.9	13.9	1,701.0	0.8	5.10	1	1	0
11/09/2022 11:00	0.9	13.9	1,628.8	0.8	4.90	1	1	0
11/09/2022 12:00	0.9	13.9	1,704.5	0.8	5.10	1	1	0
11/09/2022 13:00	0.8	14.0	1,617.1	0.7	4.90	1	1	0
11/09/2022 14:00	0.9	13.9	1,688.5	0.8	5.10	1	1	0
11/09/2022 15:00	0.9	13.9	1,636.8	0.8	4.90	1	1	1
11/09/2022 16:00	1.5	12.8	2,083.4	1.1	8.30	1	1	1
11/09/2022 17:00	1.6	12.5	2,158.5	1.1	8.60	1	1	1
11/09/2022 18:00	1.4	13.1	2,013.7	1.1	8.10	1	1	1
11/09/2022 19:00	1.3	13.3	1,976.3	1.0	7.90	1	1	1
11/09/2022 20:00	1.3	13.3	1,979.9	1.0	7.90	1	1	1
11/09/2022 21:00	1.3	13.3	2,004.2	1.0	8.00	1	1	1
11/09/2022 22:00	1.3	13.3	1,996.1	1.0	8.00	1	1	1
11/09/2022 23:00	1.3	13.3	1,995.5	1.0	8.00	1	1	1
Average/Sum#:	1.3	13.1	1,988.0	1.0	179.10 #	24 #	24 #	19 #
Minimum:	0.8	12.0	1,617.1	0.7	4.90	1	1	0
Maximum:	1.7	14.0	2,298.8	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.3	13.3	1,995.0	1.0	8.00	1	1	1
11/10/2022 01:00	1.3	13.3	1,993.3	1.0	8.00	1	1	1
11/10/2022 02:00	1.3	13.3	1,991.3	1.0	8.00	1	1	1
11/10/2022 03:00	1.3	13.3	1,994.2	1.0	8.00	1	1	1
11/10/2022 04:00	1.5	13.0	2,084.2	1.1	8.30	1	1	1
11/10/2022 05:00	1.6	12.6	2,176.6	1.1	8.70	1	1	1
11/10/2022 06:00	1.6	12.0	2,294.6	1.1	9.20	1	1	1
11/10/2022 07:00	1.5	12.8	2,120.5	1.1	8.50	1	1	1
11/10/2022 08:00	1.3	13.3	1,983.8	1.0	7.90	1	1	1
11/10/2022 09:00	1.3	13.3	1,965.9	1.0	7.90	1	1	1
11/10/2022 10:00	0.9	14.0	1,725.4	0.8	5.20	1	1	0
11/10/2022 11:00	0.9	14.0	1,712.5	0.8	5.10	1	1	0
11/10/2022 12:00	0.9	14.0	1,711.2	0.8	5.10	1	1	0
11/10/2022 13:00	0.8	14.0	1,562.8	0.7	4.70	1	1	0
11/10/2022 14:00	0.9	14.0	1,712.6	0.8	5.10	1	1	0
11/10/2022 15:00	0.9	13.9	1,716.1	0.8	5.10	1	1	1
11/10/2022 16:00	1.5	12.7	2,137.8	1.1	8.60	1	1	1
11/10/2022 17:00	1.6	12.2	2,271.9	1.1	9.10	1	1	1
11/10/2022 18:00	1.6	12.2	2,274.5	1.1	9.10	1	1	1
11/10/2022 19:00	1.6	12.2	2,277.9	1.1	9.10	1	1	1
11/10/2022 20:00	1.6	12.2	2,279.9	1.1	9.10	1	1	1
11/10/2022 21:00	1.6	12.2	2,281.1	1.1	9.10	1	1	1
11/10/2022 22:00	1.6	12.2	2,281.8	1.1	9.10	1	1	1
11/10/2022 23:00	1.6	12.3	2,260.5	1.1	9.00	1	1	1
Average/Sum#:	1.3	13.0	2,033.6	1.0	185.00 #	24 #	24 #	19 #
Minimum:	0.8	12.0	1,562.8	0.7	4.70	1	1	0
Maximum:	1.6	14.0	2,294.6	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	1.6	12.2	2,281.0	1.1	9.10	1	1	1
11/11/2022 01:00	1.6	12.2	2,270.4	1.1	9.10	1	1	1
11/11/2022 02:00	1.6	12.7	2,154.0	1.2	8.60	1	1	1
11/11/2022 03:00	1.6	12.7	2,151.7	1.2	8.60	1	1	1
11/11/2022 04:00	1.6	12.3	2,272.4	1.1	9.10	1	1	1
11/11/2022 05:00	1.6	12.2	2,285.8	1.1	9.10	1	1	1
11/11/2022 06:00	1.6	12.3	2,289.0	1.1	9.20	1	1	1
11/11/2022 07:00	1.4	12.9	2,119.2	1.0	8.50	1	1	1
11/11/2022 08:00	1.2	13.4	1,954.8	0.9	5.90	1	1	1
11/11/2022 09:00	0.8	14.0	1,708.7	0.7	5.10	1	1	0
11/11/2022 10:00	0.8	14.0	1,712.4	0.7	5.10	1	1	0
11/11/2022 11:00	0.8	14.0	1,684.1	0.7	5.10	1	1	0
11/11/2022 12:00	0.9	14.0	1,684.6	0.8	5.10	1	1	0
11/11/2022 13:00	0.9	14.0	1,694.9	0.8	5.10	1	1	0
11/11/2022 14:00	0.8	14.0	1,573.1	0.7	4.70	1	1	0
11/11/2022 15:00	0.9	14.0	1,687.2	0.8	5.10	1	1	0
11/11/2022 16:00	1.4	13.1	1,984.8	1.1	7.90	1	1	1
11/11/2022 17:00	1.7	12.1	2,268.3	1.1	9.10	1	1	1
11/11/2022 18:00	1.6	12.1	2,263.3	1.1	9.10	1	1	1
11/11/2022 19:00	1.6	12.2	2,260.6	1.1	9.00	1	1	1
11/11/2022 20:00	1.6	12.2	2,253.7	1.1	9.00	1	1	1
11/11/2022 21:00	1.6	12.2	2,252.9	1.1	9.00	1	1	1
11/11/2022 22:00	1.6	12.3	2,246.0	1.1	9.00	1	1	1
11/11/2022 23:00	1.6	12.2	2,259.7	1.1	9.00	1	1	1
Average/Sum#:	1.4	12.9	2,054.7	1.0	183.60 #	24 #	24 #	17 #
Minimum:	0.8	12.1	1,573.1	0.7	4.70	1	1	0
Maximum:	1.7	14.0	2,289.0	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	1.6	12.3	2,267.0	1.1	9.10	1	1	1
11/12/2022 01:00	1.6	12.3	2,275.6	1.1	9.10	1	1	1
11/12/2022 02:00	1.6	12.2	2,278.8	1.1	9.10	1	1	1
11/12/2022 03:00	1.7	12.2	2,280.4	1.2	9.10	1	1	1
11/12/2022 04:00	1.6	12.2	2,285.0	1.1	9.10	1	1	1
11/12/2022 05:00	1.7	12.2	2,285.3	1.2	9.10	1	1	1
11/12/2022 06:00	1.6	12.2	2,276.7	1.1	9.10	1	1	1
11/12/2022 07:00	1.5	12.8	2,103.5	1.1	8.40	1	1	1
11/12/2022 08:00	1.6	12.3	2,210.7	1.1	8.80	1	1	1
11/12/2022 09:00	1.0	13.8	1,747.7	0.8	5.20	1	1	1
11/12/2022 10:00	0.8	14.0	1,589.6	0.7	4.80	1	1	0
11/12/2022 11:00	0.8	14.0	1,554.3	0.7	4.70	1	1	0
11/12/2022 12:00	0.8	14.0	1,551.1	0.7	4.70	1	1	0
11/12/2022 13:00	0.8	14.0	1,570.2	0.7	4.70	1	1	0
11/12/2022 14:00	0.8	14.0	1,549.0	0.7	4.60	1	1	0
11/12/2022 15:00	1.0	13.9	1,791.5	0.8	5.40	1	1	1
11/12/2022 16:00	1.5	12.7	2,126.7	1.1	8.50	1	1	1
11/12/2022 17:00	1.6	12.2	2,245.9	1.1	9.00	1	1	1
11/12/2022 18:00	1.6	12.2	2,246.8	1.1	9.00	1	1	1
11/12/2022 19:00	1.6	12.2	2,251.2	1.1	9.00	1	1	1
11/12/2022 20:00	1.6	12.2	2,260.4	1.1	9.00	1	1	1
11/12/2022 21:00	1.6	12.2	2,259.8	1.1	9.00	1	1	1
11/12/2022 22:00	1.6	12.5	2,193.5	1.1	8.80	1	1	1
11/12/2022 23:00	1.6	12.5	2,190.6	1.1	8.80	1	1	1
Average/Sum#:	1.4	12.8	2,058.0	1.0	186.10 #	24 #	24 #	19 #
Minimum:	0.8	12.2	1,549.0	0.7	4.60	1	1	0
Maximum:	1.7	14.0	2,285.3	1.2	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	1.6	12.6	2,180.8	1.1	8.70	1	1	1
11/13/2022 01:00	1.6	12.6	2,170.0	1.1	8.70	1	1	1
11/13/2022 02:00	1.6	12.7	2,165.0	1.2	8.70	1	1	1
11/13/2022 03:00	1.6	12.5	2,194.5	1.1	8.80	1	1	1
11/13/2022 04:00	1.6	12.6	2,189.7	1.1	8.80	1	1	1
11/13/2022 05:00	1.6	12.6	2,184.1	1.1	8.70	1	1	1
11/13/2022 06:00	1.5	12.5	2,195.0	1.1	8.80	1	1	1
11/13/2022 07:00	1.6	12.4	2,240.2	1.1	9.00	1	1	1
11/13/2022 08:00	1.4	13.1	1,966.4	1.1	7.90	1	1	1
11/13/2022 09:00	0.8	14.0	1,706.5	0.7	5.10	1	1	0
11/13/2022 10:00	0.8	14.0	1,707.9	0.7	5.10	1	1	0
11/13/2022 11:00	0.8	14.0	1,707.9	0.7	5.10	1	1	0
11/13/2022 12:00	0.8	14.0	1,706.8	0.7	5.10	1	1	0
11/13/2022 13:00	0.8	14.0	1,709.5	0.7	5.10	1	1	0
11/13/2022 14:00	0.8	14.0	1,677.7	0.7	5.00	1	1	0
11/13/2022 15:00	1.1	13.9	1,782.8	0.9	5.30	1	1	1
11/13/2022 16:00	1.6	12.5	2,138.8	1.1	8.60	1	1	1
11/13/2022 17:00	1.6	11.9	2,280.1	1.0	9.10	1	1	1
11/13/2022 18:00	1.6	11.9	2,280.5	1.0	9.10	1	1	1
11/13/2022 19:00	1.6	11.9	2,284.4	1.0	9.10	1	1	1
11/13/2022 20:00	1.6	11.9	2,288.2	1.0	9.20	1	1	1
11/13/2022 21:00	1.6	11.9	2,292.8	1.0	9.20	1	1	1
11/13/2022 22:00	1.6	11.9	2,295.1	1.0	9.20	1	1	1
11/13/2022 23:00	1.7	11.9	2,299.3	1.1	9.20	1	1	1
Average/Sum#:	1.4	12.8	2,068.5	1.0	186.60 #	24 #	24 #	18 #
Minimum:	0.8	11.9	1,677.7	0.7	5.00	1	1	0
Maximum:	1.7	14.0	2,299.3	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	1.6	11.9	2,298.5	1.0	9.20	1	1	1
11/14/2022 01:00	1.7	12.0	2,289.5	1.1	9.20	1	1	1
11/14/2022 02:00	1.7	12.1	2,286.2	1.1	9.10	1	1	1
11/14/2022 03:00	1.6	12.6	2,166.7	1.1	8.70	1	1	1
11/14/2022 04:00	1.6	12.3	2,241.5	1.1	9.00	1	1	1
11/14/2022 05:00	1.7	12.0	2,303.2	1.1	9.20	1	1	1
11/14/2022 06:00	1.6	12.1	2,299.4	1.1	9.20	1	1	1
11/14/2022 07:00	1.5	12.5	2,194.7	1.1	8.80	1	1	1
11/14/2022 08:00	1.6	12.7	2,159.1	1.2	8.60	1	1	1
11/14/2022 09:00	1.6	12.6	2,167.7	1.1	8.70	1	1	1
11/14/2022 10:00	1.6	12.6	2,158.5	1.1	8.60	1	1	1
11/14/2022 11:00	1.6	12.6	2,130.2	1.1	8.50	1	1	1
11/14/2022 12:00	1.6	12.6	2,126.0	1.1	8.50	1	1	1
11/14/2022 13:00	1.6	12.5	2,154.3	1.1	8.60	1	1	1
11/14/2022 14:00	1.6	12.4	2,150.3	1.1	8.60	1	1	1
11/14/2022 15:00	1.5	12.8	2,079.7	1.1	8.30	1	1	1
11/14/2022 16:00	1.6	12.0	2,254.0	1.1	9.00	1	1	1
11/14/2022 17:00	1.6	12.3	2,198.1	1.1	8.80	1	1	1
11/14/2022 18:00	1.6	12.4	2,182.1	1.1	8.70	1	1	1
11/14/2022 19:00	1.6	12.1	2,240.9	1.1	9.00	1	1	1
11/14/2022 20:00	1.7	12.1	2,243.9	1.1	9.00	1	1	1
11/14/2022 21:00	1.6	12.0	2,288.0	1.1	9.20	1	1	1
11/14/2022 22:00	1.6	12.0	2,288.7	1.1	9.20	1	1	1
11/14/2022 23:00	1.6	12.1	2,271.0	1.1	9.10	1	1	1
Average/Sum#:	1.6	12.3	2,215.5	1.1	212.80 #	24 #	24 #	24 #
Minimum:	1.5	11.9	2,079.7	1.0	8.30	1	1	1
Maximum:	1.7	12.8	2,303.2	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	1.6	12.0	2,301.3	1.1	9.20	1	1	1
11/15/2022 01:00	1.6	11.9	2,300.4	1.0	9.20	1	1	1
11/15/2022 02:00	1.6	12.0	2,290.8	1.1	9.20	1	1	1
11/15/2022 03:00	1.6	12.0	2,281.4	1.1	9.10	1	1	1
11/15/2022 04:00	1.6	12.1	2,264.5	1.1	9.10	1	1	1
11/15/2022 05:00	1.7	12.2	2,243.0	1.2	9.00	1	1	1
11/15/2022 06:00	1.5	12.3	2,213.0	1.0	8.90	1	1	1
11/15/2022 07:00	1.6	12.4	2,183.3	1.1	8.70	1	1	1
11/15/2022 08:00	1.6	12.6	2,133.4	1.1	8.50	1	1	1
11/15/2022 09:00	1.5	12.7	2,108.5	1.1	8.40	1	1	1
11/15/2022 10:00	1.6	12.6	2,141.8	1.1	8.60	1	1	1
11/15/2022 11:00	1.5	12.9	2,056.8	1.1	8.20	1	1	1
11/15/2022 12:00	1.3	13.3	1,977.9	1.0	7.90	1	1	1
11/15/2022 13:00	1.4	13.3	1,979.2	1.1	7.90	1	1	1
11/15/2022 14:00	1.3	13.3	1,979.2	1.0	7.90	1	1	1
11/15/2022 15:00	1.4	13.1	2,018.4	1.1	8.10	1	1	1
11/15/2022 16:00	1.6	12.6	2,149.3	1.1	8.60	1	1	1
11/15/2022 17:00	1.6	12.5	2,177.7	1.1	8.70	1	1	1
11/15/2022 18:00	1.6	12.4	2,193.7	1.1	8.80	1	1	1
11/15/2022 19:00	1.6	12.4	2,188.4	1.1	8.80	1	1	1
11/15/2022 20:00	1.6	12.3	2,196.2	1.1	8.80	1	1	1
11/15/2022 21:00	1.6	12.1	2,244.0	1.1	9.00	1	1	1
11/15/2022 22:00	1.6	12.4	2,174.7	1.1	8.70	1	1	1
11/15/2022 23:00	1.5	12.5	2,174.2	1.1	8.70	1	1	1
Average/Sum#:	1.5	12.5	2,165.5	1.1	208.00 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,977.9	1.0	7.90	1	1	1
Maximum:	1.7	13.3	2,301.3	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2022 00:00	1.5	12.5	2,168.0	1.1	8.70	1	1	1
11/16/2022 01:00	1.6	12.6	2,140.8	1.1	8.60	1	1	1
11/16/2022 02:00	1.6	12.5	2,165.7	1.1	8.70	1	1	1
11/16/2022 03:00	1.6	12.5	2,167.5	1.1	8.70	1	1	1
11/16/2022 04:00	1.6	12.4	2,178.7	1.1	8.70	1	1	1
11/16/2022 05:00	1.6	12.5	2,174.9	1.1	8.70	1	1	1
11/16/2022 06:00	1.5	12.5	2,168.0	1.1	8.70	1	1	1
11/16/2022 07:00	1.5	12.2	2,241.0	1.0	9.00	1	1	1
11/16/2022 08:00	1.4	13.2	1,987.0	1.1	7.90	1	1	1
11/16/2022 09:00	1.4	13.2	2,018.8	1.1	8.10	1	1	1
11/16/2022 10:00	1.4	13.3	1,985.3	1.1	7.90	1	1	1
11/16/2022 11:00	0.0	0.0	1,986.8	0.0	0.00	1	1	1
11/16/2022 12:00	1.0	13.2	1,985.9	0.8	6.00	1	1	1
11/16/2022 13:00	1.0	13.2	1,986.9	0.8	6.00	1	1	1
11/16/2022 14:00	1.1	13.2	1,985.4	0.8	6.00	1	1	1
11/16/2022 15:00	1.4	12.6	2,113.3	1.0	8.50	1	1	1
11/16/2022 16:00	1.7	12.3	2,177.2	1.2	8.70	1	1	1
11/16/2022 17:00	1.7	12.3	2,192.8	1.2	8.80	1	1	1
11/16/2022 18:00	1.7	11.9	2,278.4	1.1	9.10	1	1	1
11/16/2022 19:00	1.7	11.9	2,286.5	1.1	9.10	1	1	1
11/16/2022 20:00	1.7	11.9	2,286.7	1.1	9.10	1	1	1
11/16/2022 21:00	1.6	12.0	2,266.9	1.1	9.10	1	1	1
11/16/2022 22:00	1.6	12.2	2,230.9	1.1	8.90	1	1	1
11/16/2022 23:00	1.6	12.0	2,257.4	1.1	9.00	1	1	1
Average/Sum#:	1.5	12.5	2,143.0	1.1	192.00 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,985.3	0.8	6.00	1	1	1
Maximum:	1.7	13.3	2,286.7	1.2	9.10	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	1.6	12.4	2,177.8	1.1	8.70	1	1	1
11/17/2022 01:00	1.6	12.3	2,181.0	1.1	8.70	1	1	1
11/17/2022 02:00	1.6	12.4	2,165.8	1.1	8.70	1	1	1
11/17/2022 03:00	1.6	12.5	2,166.0	1.1	8.70	1	1	1
11/17/2022 04:00	1.5	12.5	2,169.1	1.1	8.70	1	1	1
11/17/2022 05:00	1.3	12.4	2,181.8	0.9	6.50	1	1	1
11/17/2022 06:00	1.6	11.9	2,291.5	1.0	9.20	1	1	1
11/17/2022 07:00	1.6	12.4	2,182.1	1.1	8.70	1	1	1
11/17/2022 08:00	1.2	13.1	1,994.1	0.9	6.00	1	1	1
11/17/2022 09:00	1.6	12.5	2,150.8	1.1	8.60	1	1	1
11/17/2022 10:00	1.6	12.5	2,143.2	1.1	8.60	1	1	1
11/17/2022 11:00	1.6	12.3	2,174.6	1.1	8.70	1	1	1
11/17/2022 12:00	1.6	12.1	2,198.3	1.1	8.80	1	1	1
11/17/2022 13:00	1.6	12.2	2,183.9	1.1	8.70	1	1	1
11/17/2022 14:00	1.5	12.9	2,015.7	1.1	8.10	1	1	1
11/17/2022 15:00	1.6	12.4	2,130.6	1.1	8.50	1	1	1
11/17/2022 16:00	1.6	11.9	2,243.2	1.0	9.00	1	1	1
11/17/2022 17:00	1.6	11.8	2,276.9	1.0	9.10	1	1	1
11/17/2022 18:00	1.6	11.8	2,275.4	1.0	9.10	1	1	1
11/17/2022 19:00	1.6	11.8	2,278.6	1.0	9.10	1	1	1
11/17/2022 20:00	1.6	11.8	2,280.8	1.0	9.10	1	1	1
11/17/2022 21:00	1.6	11.8	2,282.5	1.0	9.10	1	1	1
11/17/2022 22:00	1.6	11.9	2,269.7	1.0	9.10	1	1	1
11/17/2022 23:00	1.6	12.2	2,226.9	1.1	8.90	1	1	1
Average/Sum#:	1.6	12.2	2,193.3	1.1	206.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,994.1	0.9	6.00	1	1	1
Maximum:	1.6	13.1	2,291.5	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	1.6	12.4	2,177.7	1.1	8.70	1	1	1
11/18/2022 01:00	1.6	12.3	2,188.2	1.1	8.80	1	1	1
11/18/2022 02:00	1.6	12.2	2,194.3	1.1	8.80	1	1	1
11/18/2022 03:00	1.6	12.3	2,188.5	1.1	8.80	1	1	1
11/18/2022 04:00	1.6	12.2	2,185.6	1.1	8.70	1	1	1
11/18/2022 05:00	1.5	12.3	2,173.7	1.0	8.70	1	1	1
11/18/2022 06:00	1.4	12.4	2,160.2	1.0	8.60	1	1	1
11/18/2022 07:00	1.6	12.0	2,255.3	1.1	9.00	1	1	1
11/18/2022 08:00	1.6	12.3	2,177.7	1.1	8.70	1	1	1
11/18/2022 09:00	1.6	12.3	2,185.0	1.1	8.70	1	1	1
11/18/2022 10:00	1.6	12.2	2,190.4	1.1	8.80	1	1	1
11/18/2022 11:00	1.5	12.5	2,120.3	1.1	8.50	1	1	1
11/18/2022 12:00	1.5	13.1	1,970.2	1.1	7.90	1	1	1
11/18/2022 13:00	1.5	13.1	1,973.1	1.1	7.90	1	1	1
11/18/2022 14:00	1.5	13.1	1,974.5	1.1	7.90	1	1	1
11/18/2022 15:00	1.5	12.8	2,058.5	1.1	8.20	1	1	1
11/18/2022 16:00	1.6	12.0	2,235.0	1.1	8.90	1	1	1
11/18/2022 17:00	1.6	11.9	2,257.9	1.0	9.00	1	1	1
11/18/2022 18:00	1.6	12.0	2,260.4	1.1	9.00	1	1	1
11/18/2022 19:00	1.6	12.0	2,263.4	1.1	9.10	1	1	1
11/18/2022 20:00	1.6	12.1	2,228.1	1.1	8.90	1	1	1
11/18/2022 21:00	1.5	12.3	2,181.4	1.0	8.70	1	1	1
11/18/2022 22:00	1.3	12.5	2,145.0	0.9	6.40	1	1	1
11/18/2022 23:00	1.5	12.1	2,239.0	1.0	9.00	1	1	1
Average/Sum#:	1.5	12.4	2,166.0	1.1	205.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,970.2	0.9	6.40	1	1	1
Maximum:	1.6	13.1	2,263.4	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	1.6	12.3	2,194.0	1.1	8.80	1	1	1
11/19/2022 01:00	1.6	12.4	2,172.4	1.1	8.70	1	1	1
11/19/2022 02:00	1.6	12.5	2,168.7	1.1	8.70	1	1	1
11/19/2022 03:00	1.6	12.6	2,144.8	1.1	8.60	1	1	1
11/19/2022 04:00	1.6	12.2	2,238.2	1.1	9.00	1	1	1
11/19/2022 05:00	1.6	12.1	2,271.6	1.1	9.10	1	1	1
11/19/2022 06:00	1.5	12.3	2,218.2	1.0	8.90	1	1	1
11/19/2022 07:00	1.5	12.6	2,132.0	1.1	8.50	1	1	1
11/19/2022 08:00	1.1	13.2	1,978.8	0.8	5.90	1	1	1
11/19/2022 09:00	1.3	13.2	1,978.8	1.0	7.90	1	1	1
11/19/2022 10:00	1.4	13.2	1,975.1	1.1	7.90	1	1	1
11/19/2022 11:00	1.5	13.2	1,970.6	1.1	7.90	1	1	1
11/19/2022 12:00	1.5	13.1	1,971.0	1.1	7.90	1	1	1
11/19/2022 13:00	1.5	13.1	1,971.9	1.1	7.90	1	1	1
11/19/2022 14:00	1.5	13.1	1,970.2	1.1	7.90	1	1	1
11/19/2022 15:00	1.5	12.8	2,050.9	1.1	8.20	1	1	1
11/19/2022 16:00	1.5	12.2	2,184.1	1.0	8.70	1	1	1
11/19/2022 17:00	1.6	12.1	2,201.8	1.1	8.80	1	1	1
11/19/2022 18:00	1.6	12.2	2,197.4	1.1	8.80	1	1	1
11/19/2022 19:00	1.6	11.9	2,260.7	1.0	9.00	1	1	1
11/19/2022 20:00	1.6	12.1	2,219.4	1.1	8.90	1	1	1
11/19/2022 21:00	1.5	12.3	2,177.5	1.0	8.70	1	1	1
11/19/2022 22:00	1.3	12.5	2,175.6	0.9	6.50	1	1	1
11/19/2022 23:00	1.2	12.6	2,143.8	0.9	6.40	1	1	1
Average/Sum#:	1.5	12.6	2,123.6	1.1	197.60 #	24 #	24 #	24 #
Minimum:	1.1	11.9	1,970.2	0.8	5.90	1	1	1
Maximum:	1.6	13.2	2,271.6	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	1.2	12.7	2,106.9	0.9	6.30	1	1	1
11/20/2022 01:00	1.1	12.8	2,078.9	0.8	6.20	1	1	1
11/20/2022 02:00	1.0	12.9	2,062.3	0.7	6.20	1	1	1
11/20/2022 03:00	0.9	12.9	2,063.5	0.7	4.10	1	1	1
11/20/2022 04:00	0.9	12.9	2,070.5	0.7	4.10	1	1	1
11/20/2022 05:00	1.2	12.5	2,183.5	0.8	6.60	1	1	1
11/20/2022 06:00	1.6	12.1	2,276.9	1.1	9.10	1	1	1
11/20/2022 07:00	1.4	12.6	2,113.0	1.0	8.50	1	1	1
11/20/2022 08:00	0.5	13.9	1,703.8	0.4	3.40	1	1	0
11/20/2022 09:00	0.5	13.9	1,708.6	0.4	3.40	1	1	0
11/20/2022 10:00	0.5	13.9	1,565.5	0.4	3.10	1	1	0
11/20/2022 11:00	0.5	13.9	1,563.6	0.4	3.10	1	1	0
11/20/2022 12:00	0.5	14.0	1,533.4	0.4	3.10	1	1	0
11/20/2022 13:00	0.5	14.0	1,523.9	0.4	3.00	1	1	0
11/20/2022 14:00	0.6	13.8	1,701.2	0.5	3.40	1	1	1
11/20/2022 15:00	0.7	13.8	1,723.3	0.6	3.40	1	1	1
11/20/2022 16:00	1.5	12.4	2,162.3	1.0	8.60	1	1	1
11/20/2022 17:00	1.6	11.9	2,276.4	1.0	9.10	1	1	1
11/20/2022 18:00	1.6	11.9	2,265.8	1.0	9.10	1	1	1
11/20/2022 19:00	1.6	11.9	2,256.8	1.0	9.00	1	1	1
11/20/2022 20:00	1.6	11.9	2,261.0	1.0	9.00	1	1	1
11/20/2022 21:00	1.6	12.2	2,204.5	1.1	8.80	1	1	1
11/20/2022 22:00	1.6	12.4	2,168.3	1.1	8.70	1	1	1
11/20/2022 23:00	1.6	12.5	2,153.3	1.1	8.60	1	1	1
Average/Sum#:	1.1	12.9	1,988.6	0.8	147.90 #	24 #	24 #	18 #
Minimum:	0.5	11.9	1,523.9	0.4	3.00	1	1	0
Maximum:	1.6	14.0	2,276.9	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	1.5	12.5	2,160.3	1.1	8.60	1	1	1
11/21/2022 01:00	1.6	12.6	2,137.5	1.1	8.60	1	1	1
11/21/2022 02:00	1.4	12.9	2,062.0	1.0	8.20	1	1	1
11/21/2022 03:00	1.6	12.4	2,174.4	1.1	8.70	1	1	1
11/21/2022 04:00	1.6	12.1	2,256.2	1.1	9.00	1	1	1
11/21/2022 05:00	1.6	12.1	2,267.1	1.1	9.10	1	1	1
11/21/2022 06:00	1.7	12.0	2,284.1	1.1	9.10	1	1	1
11/21/2022 07:00	1.4	12.5	2,150.4	1.0	8.60	1	1	1
11/21/2022 08:00	1.0	13.3	1,968.4	0.8	5.90	1	1	1
11/21/2022 09:00	1.0	13.3	1,968.7	0.8	5.90	1	1	1
11/21/2022 10:00	1.2	13.2	1,969.1	0.9	5.90	1	1	1
11/21/2022 11:00	1.4	13.2	1,979.0	1.1	7.90	1	1	1
11/21/2022 12:00	1.5	13.1	1,980.5	1.1	7.90	1	1	1
11/21/2022 13:00	1.5	13.1	1,980.3	1.1	7.90	1	1	1
11/21/2022 14:00	1.5	12.3	2,160.9	1.0	8.60	1	1	1
11/21/2022 15:00	1.6	11.9	2,251.4	1.0	9.00	1	1	1
11/21/2022 16:00	1.6	12.1	2,226.7	1.1	8.90	1	1	1
11/21/2022 17:00	1.7	11.9	2,273.3	1.1	9.10	1	1	1
11/21/2022 18:00	1.7	12.0	2,283.4	1.1	9.10	1	1	1
11/21/2022 19:00	1.7	11.9	2,265.1	1.1	9.10	1	1	1
11/21/2022 20:00	1.6	11.9	2,265.4	1.0	9.10	1	1	1
11/21/2022 21:00	1.7	11.9	2,267.8	1.1	9.10	1	1	1
11/21/2022 22:00	1.6	11.9	2,264.5	1.0	9.10	1	1	1
11/21/2022 23:00	1.6	12.1	2,228.8	1.1	8.90	1	1	1
Average/Sum#:	1.5	12.4	2,159.4	1.0	201.30 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,968.4	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,284.1	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	1.6	12.4	2,154.9	1.1	8.60	1	1	1
11/22/2022 01:00	1.6	12.6	2,130.2	1.1	8.50	1	1	1
11/22/2022 02:00	1.6	12.7	2,101.3	1.2	8.40	1	1	1
11/22/2022 03:00	1.1	13.1	1,980.1	0.8	5.90	1	1	1
11/22/2022 04:00	1.1	13.2	1,985.4	0.8	6.00	1	1	1
11/22/2022 05:00	1.3	12.8	2,071.1	0.9	6.20	1	1	1
11/22/2022 06:00	1.6	12.5	2,156.2	1.1	8.60	1	1	1
11/22/2022 07:00	1.2	12.8	2,097.2	0.9	6.30	1	1	1
11/22/2022 08:00	1.3	12.9	2,055.9	1.0	8.20	1	1	1
11/22/2022 09:00	0.7	13.8	1,648.0	0.6	3.30	1	1	1
11/22/2022 10:00	0.7	13.8	1,674.5	0.6	3.30	1	1	0
11/22/2022 11:00	0.7	13.9	1,795.0	0.6	3.60	1	1	0
11/22/2022 12:00	0.5	13.9	1,556.4	0.4	3.10	1	1	0
11/22/2022 13:00	0.6	13.9	1,617.1	0.5	3.20	1	1	0
11/22/2022 14:00	0.7	13.8	1,779.5	0.6	3.60	1	1	0
11/22/2022 15:00	0.6	13.8	1,781.6	0.5	3.60	1	1	0
11/22/2022 16:00	0.9	13.2	1,919.5	0.7	5.80	1	1	1
11/22/2022 17:00	1.6	12.3	2,191.5	1.1	8.80	1	1	1
11/22/2022 18:00	1.5	12.8	2,055.9	1.1	8.20	1	1	1
11/22/2022 19:00	1.3	13.1	1,999.0	1.0	8.00	1	1	1
11/22/2022 20:00	1.6	12.5	2,155.9	1.1	8.60	1	1	1
11/22/2022 21:00	1.3	12.9	2,034.0	1.0	8.10	1	1	1
11/22/2022 22:00	1.3	12.9	2,045.3	1.0	8.20	1	1	1
11/22/2022 23:00	1.1	13.2	1,973.0	0.8	5.90	1	1	1
Average/Sum#:	1.1	13.1	1,956.6	0.9	152.00 #	24 #	24 #	18 #
Minimum:	0.5	12.3	1,556.4	0.4	3.10	1	1	0
Maximum:	1.6	13.9	2,191.5	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.1	13.2	1,974.3	0.8	5.90	1	1	1
11/23/2022 01:00	1.1	13.2	1,975.1	0.8	5.90	1	1	1
11/23/2022 02:00	1.1	13.2	1,973.8	0.8	5.90	1	1	1
11/23/2022 03:00	1.0	13.2	1,976.4	0.8	5.90	1	1	1
11/23/2022 04:00	1.2	13.2	1,982.4	0.9	5.90	1	1	1
11/23/2022 05:00	1.5	12.7	2,074.5	1.1	8.30	1	1	1
11/23/2022 06:00	1.4	12.7	2,056.8	1.0	8.20	1	1	1
11/23/2022 07:00	1.5	12.7	2,111.0	1.1	8.40	1	1	1
11/23/2022 08:00	1.3	13.0	2,004.8	1.0	8.00	1	1	1
11/23/2022 09:00	0.6	13.9	1,703.0	0.5	3.40	1	1	0
11/23/2022 10:00	0.5	13.9	1,554.3	0.4	3.10	1	1	0
11/23/2022 11:00	0.5	13.9	1,550.6	0.4	3.10	1	1	0
11/23/2022 12:00	0.4	14.0	1,422.8	0.3	1.40	1	1	0
11/23/2022 13:00	0.5	14.0	1,559.1	0.4	3.10	1	1	0
11/23/2022 14:00	0.5	14.0	1,630.2	0.4	3.30	1	1	0
11/23/2022 15:00	0.8	13.9	1,636.5	0.7	3.30	1	1	1
11/23/2022 16:00	1.5	12.6	2,110.6	1.1	8.40	1	1	1
11/23/2022 17:00	1.6	12.3	2,185.3	1.1	8.70	1	1	1
11/23/2022 18:00	1.4	12.7	2,100.4	1.0	8.40	1	1	1
11/23/2022 19:00	1.3	12.9	2,063.5	1.0	8.30	1	1	1
11/23/2022 20:00	1.6	12.3	2,182.9	1.1	8.70	1	1	1
11/23/2022 21:00	1.7	12.3	2,201.9	1.2	8.80	1	1	1
11/23/2022 22:00	1.6	12.4	2,176.3	1.1	8.70	1	1	1
11/23/2022 23:00	1.6	12.4	2,171.5	1.1	8.70	1	1	1
Average/Sum#:	1.1	13.1	1,932.4	0.8	151.80 #	24 #	24 #	18 #
Minimum:	0.4	12.3	1,422.8	0.3	1.40	1	1	0
Maximum:	1.7	14.0	2,201.9	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.1	13.1	1,990.6	0.8	6.00	1	1	1
11/24/2022 01:00	1.0	13.2	1,976.9	0.8	5.90	1	1	1
11/24/2022 02:00	1.0	13.2	1,976.7	0.8	5.90	1	1	1
11/24/2022 03:00	1.3	13.1	2,019.5	1.0	8.10	1	1	1
11/24/2022 04:00	1.2	13.0	2,026.8	0.9	6.10	1	1	1
11/24/2022 05:00	1.3	12.8	2,102.0	0.9	6.30	1	1	1
11/24/2022 06:00	1.6	12.2	2,191.0	1.1	8.80	1	1	1
11/24/2022 07:00	1.5	12.5	2,097.3	1.1	8.40	1	1	1
11/24/2022 08:00	0.5	13.9	1,712.8	0.4	3.40	1	1	0
11/24/2022 09:00	0.5	13.9	1,696.5	0.4	3.40	1	1	0
11/24/2022 10:00	0.5	13.9	1,703.7	0.4	3.40	1	1	0
11/24/2022 11:00	0.5	14.0	1,549.0	0.4	3.10	1	1	0
11/24/2022 12:00	0.4	14.0	1,349.8	0.3	1.30	1	1	0
11/24/2022 13:00	0.4	14.0	1,345.2	0.3	1.30	1	1	0
11/24/2022 14:00	0.5	14.0	1,551.3	0.4	3.10	1	1	0
11/24/2022 15:00	0.5	14.0	1,440.8	0.4	2.90	1	1	0
11/24/2022 16:00	0.7	13.9	1,756.8	0.6	3.50	1	1	0
11/24/2022 17:00	0.6	13.9	1,755.3	0.5	3.50	1	1	0
11/24/2022 18:00	0.6	13.9	1,738.1	0.5	3.50	1	1	0
11/24/2022 19:00	0.6	13.9	1,735.7	0.5	3.50	1	1	0
11/24/2022 20:00	0.6	13.9	1,736.2	0.5	3.50	1	1	0
11/24/2022 21:00	0.6	13.9	1,739.4	0.5	3.50	1	1	0
11/24/2022 22:00	0.6	13.9	1,742.8	0.5	3.50	1	1	0
11/24/2022 23:00	0.6	13.9	1,744.5	0.5	3.50	1	1	0
Average/Sum#:	0.8	13.6	1,778.3	0.6	105.40 #	24 #	24 #	8 #
Minimum:	0.4	12.2	1,345.2	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,191.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.6	13.9	1,746.5	0.5	3.50	1	1	0
11/25/2022 01:00	0.6	13.9	1,746.8	0.5	3.50	1	1	0
11/25/2022 02:00	0.6	13.9	1,749.6	0.5	3.50	1	1	0
11/25/2022 03:00	0.6	13.9	1,753.4	0.5	3.50	1	1	0
11/25/2022 04:00	0.6	13.9	1,763.9	0.5	3.50	1	1	0
11/25/2022 05:00	0.6	13.9	1,761.2	0.5	3.50	1	1	0
11/25/2022 06:00	0.6	13.9	1,755.3	0.5	3.50	1	1	0
11/25/2022 07:00	0.6	13.9	1,755.9	0.5	3.50	1	1	0
11/25/2022 08:00	0.8	13.5	1,878.1	0.6	3.80	1	1	1
11/25/2022 09:00	1.1	13.2	1,927.0	0.8	5.80	1	1	1
11/25/2022 10:00	0.6	13.9	1,661.2	0.5	3.30	1	1	0
11/25/2022 11:00	0.5	13.9	1,538.8	0.4	3.10	1	1	0
11/25/2022 12:00	0.5	13.9	1,565.4	0.4	3.10	1	1	0
11/25/2022 13:00	0.5	13.9	1,534.3	0.4	3.10	1	1	0
11/25/2022 14:00	0.5	13.9	1,521.7	0.4	3.00	1	1	0
11/25/2022 15:00	0.8	13.8	1,630.3	0.7	3.30	1	1	1
11/25/2022 16:00	1.5	12.6	2,098.5	1.1	8.40	1	1	1
11/25/2022 17:00	1.6	12.5	2,115.1	1.1	8.50	1	1	1
11/25/2022 18:00	1.3	13.1	1,976.4	1.0	7.90	1	1	1
11/25/2022 19:00	1.2	13.2	1,966.1	0.9	5.90	1	1	1
11/25/2022 20:00	1.2	13.2	1,974.0	0.9	5.90	1	1	1
11/25/2022 21:00	1.1	13.2	1,977.2	0.8	5.90	1	1	1
11/25/2022 22:00	1.6	12.6	2,131.7	1.1	8.50	1	1	1
11/25/2022 23:00	1.6	12.7	2,091.1	1.2	8.40	1	1	1
Average/Sum#:	0.9	13.5	1,817.5	0.7	115.90 #	24 #	24 #	11 #
Minimum:	0.5	12.5	1,521.7	0.4	3.00	1	1	0
Maximum:	1.6	13.9	2,131.7	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.4	13.0	2,033.3	1.0	8.10	1	1	1
11/26/2022 01:00	1.5	12.8	2,080.1	1.1	8.30	1	1	1
11/26/2022 02:00	2.2	13.9	1,574.8	1.9	11.00	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	13.2	1,896.1	1.3	27.40 #	3 #	2 #	3 #
Minimum:	1.4	12.8	1,574.8	1.0	8.10	0	0	0
Maximum:	2.2	13.9	2,080.1	1.9	11.00	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 21:00	30.1	17.7	330.2	55.5	47.18	1	0	0
11/27/2022 22:00	14.6	17.3	396.9	23.9	34.90	1	0	0
11/27/2022 23:00	13.0	15.5	901.6	14.2	46.90	1	0	0
Average/Sum#:	19.2	16.8	542.9	31.2	128.98 #	3 #	0 #	0 #
Minimum:	13.0	15.5	330.2	14.2	34.90	0	0	0
Maximum:	30.1	17.7	901.6	55.5	47.18	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.4	13.9	1,574.9	0.3	1.60	1	1	0
11/28/2022 01:00	0.5	13.9	1,487.8	0.4	3.00	1	1	0
11/28/2022 02:00	0.7	13.8	1,745.5	0.6	3.50	1	1	0
11/28/2022 03:00	0.5	13.9	1,530.8	0.4	3.10	1	1	0
11/28/2022 04:00	0.6	13.9	1,710.5	0.5	3.40	1	1	0
11/28/2022 05:00	0.6	13.8	1,642.2	0.5	3.30	1	1	1
11/28/2022 06:00	1.4	12.3	2,173.2	1.0	8.70	1	1	1
11/28/2022 07:00	1.7	12.0	2,270.2	1.1	9.10	1	1	1
11/28/2022 08:00	1.1	13.1	1,972.1	0.8	5.90	1	1	1
11/28/2022 09:00	0.6	13.9	1,601.7	0.5	3.20	1	1	0
11/28/2022 10:00	0.6	13.9	1,699.0	0.5	3.40	1	1	0
11/28/2022 11:00	0.5	13.9	1,519.7	0.4	3.00	1	1	0
11/28/2022 12:00	0.6	13.9	1,566.4	0.5	3.10	1	1	0
11/28/2022 13:00	0.6	13.9	1,634.0	0.5	3.30	1	1	0
11/28/2022 14:00	0.5	13.9	1,616.9	0.4	3.20	1	1	0
11/28/2022 15:00	0.7	13.8	1,620.0	0.6	3.20	1	1	1
11/28/2022 16:00	1.3	12.8	2,041.1	0.9	6.10	1	1	1
11/28/2022 17:00	1.5	12.6	2,100.3	1.1	8.40	1	1	1
11/28/2022 18:00	1.3	13.1	1,988.5	1.0	8.00	1	1	1
11/28/2022 19:00	1.2	13.2	1,967.8	0.9	5.90	1	1	1
11/28/2022 20:00	1.5	12.7	2,094.0	1.1	8.40	1	1	1
11/28/2022 21:00	1.6	12.1	2,238.4	1.1	9.00	1	1	1
11/28/2022 22:00	1.4	12.7	2,095.4	1.0	8.40	1	1	1
11/28/2022 23:00	1.2	13.1	1,996.1	0.9	6.00	1	1	1
Average/Sum#:	0.9	13.3	1,828.6	0.7	124.20 #	24 #	24 #	13 #
Minimum:	0.4	12.0	1,487.8	0.3	1.60	1	1	0
Maximum:	1.7	13.9	2,270.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	1.6	12.5	2,165.2	1.1	8.70	1	1	1
11/29/2022 01:00	1.6	12.3	2,212.8	1.1	8.90	1	1	1
11/29/2022 02:00	1.6	12.4	2,192.2	1.1	8.80	1	1	1
11/29/2022 03:00	1.4	12.8	2,088.0	1.0	8.40	1	1	1
11/29/2022 04:00	1.6	12.5	2,152.8	1.1	8.60	1	1	1
11/29/2022 05:00	1.6	12.4	2,205.6	1.1	8.80	1	1	1
11/29/2022 06:00	1.6	11.9	2,296.9	1.0	9.20	1	1	1
11/29/2022 07:00	1.7	11.9	2,304.2	1.1	9.20	1	1	1
11/29/2022 08:00	1.7	12.0	2,274.9	1.1	9.10	1	1	1
11/29/2022 09:00	1.6	12.4	2,174.5	1.1	8.70	1	1	1
11/29/2022 10:00	1.6	12.4	2,167.1	1.1	8.70	1	1	1
11/29/2022 11:00	1.6	12.4	2,157.9	1.1	8.60	1	1	1
11/29/2022 12:00	1.6	12.4	2,151.2	1.1	8.60	1	1	1
11/29/2022 13:00	1.6	12.4	2,151.4	1.1	8.60	1	1	1
11/29/2022 14:00	1.6	12.4	2,156.0	1.1	8.60	1	1	1
11/29/2022 15:00	1.6	12.3	2,170.6	1.1	8.70	1	1	1
11/29/2022 16:00	1.6	11.9	2,281.5	1.0	9.10	1	1	1
11/29/2022 17:00	1.6	11.9	2,289.6	1.0	9.20	1	1	1
11/29/2022 18:00	1.7	11.9	2,292.8	1.1	9.20	1	1	1
11/29/2022 19:00	1.6	11.9	2,290.5	1.0	9.20	1	1	1
11/29/2022 20:00	1.7	12.0	2,289.3	1.1	9.20	1	1	1
11/29/2022 21:00	1.7	11.9	2,292.2	1.1	9.20	1	1	1
11/29/2022 22:00	1.6	12.0	2,297.8	1.1	9.20	1	1	1
11/29/2022 23:00	1.6	12.0	2,296.7	1.1	9.20	1	1	1
Average/Sum#:	1.6	12.2	2,223.0	1.1	213.70 #	24 #	24 #	24 #
Minimum:	1.4	11.9	2,088.0	1.0	8.40	1	1	1
Maximum:	1.7	12.8	2,304.2	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	1.5	12.6	2,170.7	1.1	8.70	1	1	1
11/30/2022 01:00	1.6	12.6	2,153.2	1.1	8.60	1	1	1
11/30/2022 02:00	1.6	12.6	2,153.8	1.1	8.60	1	1	1
11/30/2022 03:00	1.6	12.6	2,151.0	1.1	8.60	1	1	1
11/30/2022 04:00	1.6	12.6	2,169.6	1.1	8.70	1	1	1
11/30/2022 05:00	1.5	12.6	2,169.3	1.1	8.70	1	1	1
11/30/2022 06:00	1.3	12.1	2,268.0	0.9	6.80	1	1	1
11/30/2022 07:00	1.4	12.6	2,158.0	1.0	8.60	1	1	1
11/30/2022 08:00	1.0	13.3	1,984.3	0.8	6.00	1	1	1
11/30/2022 09:00	1.1	13.2	1,998.7	0.8	6.00	1	1	1
11/30/2022 10:00	1.0	13.2	1,980.3	0.8	5.90	1	1	1
11/30/2022 11:00	1.1	13.2	1,984.1	0.8	6.00	1	1	1
11/30/2022 12:00	1.3	13.2	1,983.8	1.0	7.90	1	1	1
11/30/2022 13:00	1.4	13.1	1,978.8	1.1	7.90	1	1	1
11/30/2022 14:00	1.6	12.5	2,132.5	1.1	8.50	1	1	1
11/30/2022 15:00	1.6	12.4	2,140.8	1.1	8.60	1	1	1
11/30/2022 16:00	1.7	11.9	2,251.8	1.1	9.00	1	1	1
11/30/2022 17:00	1.7	11.7	2,297.3	1.1	9.20	1	1	1
11/30/2022 18:00	1.7	11.8	2,289.4	1.1	9.20	1	1	1
11/30/2022 19:00	1.7	11.8	2,289.6	1.1	9.20	1	1	1
11/30/2022 20:00	1.7	11.8	2,288.9	1.1	9.20	1	1	1
11/30/2022 21:00	1.6	12.0	2,256.6	1.1	9.00	1	1	1
11/30/2022 22:00	1.5	12.6	2,106.9	1.1	8.40	1	1	1
11/30/2022 23:00	2.1	13.8	1,590.5	1.7	9.50	1	0	1
Average/Sum#:	1.5	12.6	2,122.8	1.1	196.80 #	24 #	23 #	24 #
Minimum:	1.0	11.7	1,590.5	0.8	5.90	1	0	1
Maximum:	2.1	13.8	2,297.3	1.7	9.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 02:00	2.4	17.9	301.9	4.7	2.40	1	0	0
12/01/2022 03:00	7.0	14.8	1,144.0	6.8	28.60	1	0	0
12/01/2022 04:00	0.6	13.8	1,703.6	0.5	3.40	1	1	0
12/01/2022 05:00	0.8	13.5	1,790.5	0.6	3.60	1	1	1
12/01/2022 06:00	1.7	11.7	2,291.0	1.1	9.20	1	1	1
12/01/2022 07:00	1.7	11.6	2,326.9	1.1	9.30	1	1	1
12/01/2022 08:00	1.7	12.1	2,203.6	1.1	8.80	1	1	1
12/01/2022 09:00	1.7	12.2	2,190.4	1.2	8.80	1	1	1
12/01/2022 10:00	1.7	12.2	2,195.3	1.2	8.80	1	1	1
12/01/2022 11:00	1.7	12.3	2,173.6	1.2	8.70	1	1	1
12/01/2022 12:00	1.7	12.2	2,176.8	1.2	8.70	1	1	1
12/01/2022 13:00	1.7	12.2	2,177.9	1.2	8.70	1	1	1
12/01/2022 14:00	1.7	12.1	2,192.3	1.1	8.80	1	1	1
12/01/2022 15:00	1.8	11.6	2,311.4	1.1	9.20	1	1	1
12/01/2022 16:00	1.7	11.6	2,338.6	1.1	9.40	1	1	1
12/01/2022 17:00	1.7	11.6	2,347.2	1.1	9.40	1	1	1
12/01/2022 18:00	1.7	11.6	2,335.6	1.1	9.30	1	1	1
12/01/2022 19:00	1.7	11.7	2,345.2	1.1	9.40	1	1	1
12/01/2022 20:00	1.7	11.7	2,349.1	1.1	9.40	1	1	1
12/01/2022 21:00	1.7	11.8	2,324.3	1.1	9.30	1	1	1
12/01/2022 22:00	1.7	12.4	2,184.7	1.2	8.70	1	1	1
12/01/2022 23:00	1.6	12.4	2,181.8	1.1	8.70	1	1	1
Average/Sum#:	1.9	12.5	2,072.1	1.5	200.60 #	22 #	20 #	19 #
Minimum:	0.6	11.6	301.9	0.5	2.40	0	0	0
Maximum:	7.0	17.9	2,349.1	6.8	28.60	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	1.7	12.4	2,181.7	1.2	8.70	1	1	1
12/02/2022 01:00	1.6	12.4	2,185.0	1.1	8.70	1	1	1
12/02/2022 02:00	1.6	12.4	2,189.6	1.1	8.80	1	1	1
12/02/2022 03:00	1.6	12.5	2,168.0	1.1	8.70	1	1	1
12/02/2022 04:00	1.6	12.5	2,177.5	1.1	8.70	1	1	1
12/02/2022 05:00	1.6	12.5	2,174.2	1.1	8.70	1	1	1
12/02/2022 06:00	1.7	12.0	2,312.0	1.1	9.20	1	1	1
12/02/2022 07:00	1.7	11.9	2,323.5	1.1	9.30	1	1	1
12/02/2022 08:00	1.7	12.0	2,321.3	1.1	9.30	1	1	1
12/02/2022 09:00	1.6	12.4	2,196.4	1.1	8.80	1	1	1
12/02/2022 10:00	1.7	12.4	2,196.5	1.2	8.80	1	1	1
12/02/2022 11:00	1.7	12.3	2,214.2	1.2	8.90	1	1	1
12/02/2022 12:00	1.7	12.3	2,217.5	1.2	8.90	1	1	1
12/02/2022 13:00	1.7	12.3	2,208.5	1.2	8.80	1	1	1
12/02/2022 14:00	1.7	12.3	2,186.0	1.2	8.70	1	1	1
12/02/2022 15:00	1.7	11.9	2,306.4	1.1	9.20	1	1	1
12/02/2022 16:00	1.7	11.7	2,337.6	1.1	9.40	1	1	1
12/02/2022 17:00	1.7	11.8	2,328.6	1.1	9.30	1	1	1
12/02/2022 18:00	1.7	11.9	2,318.8	1.1	9.30	1	1	1
12/02/2022 19:00	1.7	11.9	2,324.2	1.1	9.30	1	1	1
12/02/2022 20:00	1.7	11.9	2,321.7	1.1	9.30	1	1	1
12/02/2022 21:00	1.7	11.9	2,315.9	1.1	9.30	1	1	1
12/02/2022 22:00	1.7	11.9	2,313.3	1.1	9.30	1	1	1
12/02/2022 23:00	1.7	11.9	2,317.7	1.1	9.30	1	1	1
Average/Sum#:	1.7	12.1	2,255.7	1.1	216.70 #	24 #	24 #	24 #
Minimum:	1.6	11.7	2,168.0	1.1	8.70	1	1	1
Maximum:	1.7	12.5	2,337.6	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	1.7	12.0	2,310.3	1.1	9.20	1	1	1
12/03/2022 01:00	1.7	12.0	2,318.6	1.1	9.30	1	1	1
12/03/2022 02:00	1.7	11.9	2,322.5	1.1	9.30	1	1	1
12/03/2022 03:00	1.7	11.9	2,322.3	1.1	9.30	1	1	1
12/03/2022 04:00	1.7	11.9	2,317.9	1.1	9.30	1	1	1
12/03/2022 05:00	1.7	11.9	2,321.6	1.1	9.30	1	1	1
12/03/2022 06:00	1.6	11.9	2,325.5	1.0	9.30	1	1	1
12/03/2022 07:00	1.7	11.8	2,334.4	1.1	9.30	1	1	1
12/03/2022 08:00	1.7	11.9	2,328.6	1.1	9.30	1	1	1
12/03/2022 09:00	1.7	11.8	2,330.7	1.1	9.30	1	1	1
12/03/2022 10:00	1.7	11.9	2,311.2	1.1	9.20	1	1	1
12/03/2022 11:00	1.7	12.0	2,279.7	1.1	9.10	1	1	1
12/03/2022 12:00	1.7	11.9	2,308.6	1.1	9.20	1	1	1
12/03/2022 13:00	1.6	12.3	2,197.2	1.1	8.80	1	1	1
12/03/2022 14:00	1.7	12.4	2,185.4	1.2	8.70	1	1	1
12/03/2022 15:00	1.7	11.9	2,313.0	1.1	9.30	1	1	1
12/03/2022 16:00	1.7	11.7	2,334.9	1.1	9.30	1	1	1
12/03/2022 17:00	1.8	11.8	2,325.1	1.2	9.30	1	1	1
12/03/2022 18:00	1.7	11.8	2,312.8	1.1	9.30	1	1	1
12/03/2022 19:00	1.7	11.8	2,316.1	1.1	9.30	1	1	1
12/03/2022 20:00	1.7	11.7	2,329.1	1.1	9.30	1	1	1
12/03/2022 21:00	1.8	11.7	2,344.0	1.2	9.40	1	1	1
12/03/2022 22:00	1.8	11.7	2,350.9	1.2	9.40	1	1	1
12/03/2022 23:00	1.7	11.7	2,342.1	1.1	9.40	1	1	1
Average/Sum#:	1.7	11.9	2,311.8	1.1	221.90 #	24 #	24 #	24 #
Minimum:	1.6	11.7	2,185.4	1.0	8.70	1	1	1
Maximum:	1.8	12.4	2,350.9	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	1.6	12.3	2,200.3	1.1	8.80	1	1	1
12/04/2022 01:00	1.7	12.3	2,203.9	1.2	8.80	1	1	1
12/04/2022 02:00	1.7	12.3	2,208.7	1.2	8.80	1	1	1
12/04/2022 03:00	1.7	12.3	2,200.4	1.2	8.80	1	1	1
12/04/2022 04:00	1.7	12.3	2,211.5	1.2	8.80	1	1	1
12/04/2022 05:00	1.7	12.3	2,202.2	1.2	8.80	1	1	1
12/04/2022 06:00	1.7	11.8	2,326.8	1.1	9.30	1	1	1
12/04/2022 07:00	1.8	11.7	2,339.1	1.2	9.40	1	1	1
12/04/2022 08:00	1.7	12.3	2,214.8	1.2	8.90	1	1	1
12/04/2022 09:00	1.7	12.3	2,191.3	1.2	8.80	1	1	1
12/04/2022 10:00	1.7	12.2	2,206.1	1.2	8.80	1	1	1
12/04/2022 11:00	1.7	12.2	2,206.4	1.2	8.80	1	1	1
12/04/2022 12:00	1.7	12.1	2,197.7	1.1	8.80	1	1	1
12/04/2022 13:00	1.7	12.1	2,193.2	1.1	8.80	1	1	1
12/04/2022 14:00	1.7	12.1	2,207.4	1.1	8.80	1	1	1
12/04/2022 15:00	1.7	12.1	2,194.8	1.1	8.80	1	1	1
12/04/2022 16:00	1.8	11.6	2,322.7	1.1	9.30	1	1	1
12/04/2022 17:00	1.8	11.6	2,338.7	1.1	9.40	1	1	1
12/04/2022 18:00	1.7	11.6	2,323.4	1.1	9.30	1	1	1
12/04/2022 19:00	1.7	11.7	2,320.9	1.1	9.30	1	1	1
12/04/2022 20:00	1.8	11.7	2,321.9	1.2	9.30	1	1	1
12/04/2022 21:00	1.7	11.7	2,322.9	1.1	9.30	1	1	1
12/04/2022 22:00	1.7	11.8	2,311.7	1.1	9.20	1	1	1
12/04/2022 23:00	1.7	12.3	2,192.7	1.2	8.80	1	1	1
Average/Sum#:	1.7	12.0	2,248.3	1.2	215.90 #	24 #	24 #	24 #
Minimum:	1.6	11.6	2,191.3	1.1	8.80	1	1	1
Maximum:	1.8	12.3	2,339.1	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	1.7	12.3	2,194.3	1.2	8.80	1	1	1
12/05/2022 01:00	1.7	12.3	2,191.4	1.2	8.80	1	1	1
12/05/2022 02:00	1.7	12.3	2,196.4	1.2	8.80	1	1	1
12/05/2022 03:00	1.7	12.3	2,190.0	1.2	8.80	1	1	1
12/05/2022 04:00	1.7	12.2	2,215.9	1.2	8.90	1	1	1
12/05/2022 05:00	1.7	11.8	2,320.8	1.1	9.30	1	1	1
12/05/2022 06:00	1.7	11.6	2,344.1	1.1	9.40	1	1	1
12/05/2022 07:00	1.7	11.7	2,340.6	1.1	9.40	1	1	1
12/05/2022 08:00	1.7	11.6	2,351.7	1.1	9.40	1	1	1
12/05/2022 09:00	1.8	11.5	2,366.0	1.1	9.50	1	1	1
12/05/2022 10:00	1.6	11.9	2,141.8	1.0	8.60	1	1	1
12/05/2022 11:00	1.0	13.2	1,826.8	0.8	5.50	1	1	1
12/05/2022 12:00	1.7	12.2	2,161.8	1.2	8.60	1	1	1
12/05/2022 13:00	1.5	12.8	2,027.0	1.1	8.10	1	1	1
12/05/2022 14:00	1.5	12.7	2,056.5	1.1	8.20	1	1	1
12/05/2022 15:00	1.5	12.6	2,074.4	1.1	8.30	1	1	1
12/05/2022 16:00	1.6	12.0	2,222.7	1.1	8.90	1	1	1
12/05/2022 17:00	1.7	11.7	2,298.0	1.1	9.20	1	1	1
12/05/2022 18:00	1.7	11.7	2,298.7	1.1	9.20	1	1	1
12/05/2022 19:00	1.7	11.8	2,302.3	1.1	9.20	1	1	1
12/05/2022 20:00	1.7	11.8	2,299.3	1.1	9.20	1	1	1
12/05/2022 21:00	1.6	12.1	2,221.1	1.1	8.90	1	1	1
12/05/2022 22:00	1.4	12.7	2,074.3	1.0	8.30	1	1	1
12/05/2022 23:00	1.3	12.8	2,049.9	0.9	6.10	1	1	1
Average/Sum#:	1.6	12.2	2,198.6	1.1	207.40 #	24 #	24 #	24 #
Minimum:	1.0	11.5	1,826.8	0.8	5.50	1	1	1
Maximum:	1.8	13.2	2,366.0	1.2	9.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	1.0	13.2	1,968.4	0.8	5.90	1	1	1
12/06/2022 01:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/06/2022 02:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/06/2022 03:00	1.0	13.2	1,969.4	0.8	5.90	1	1	1
12/06/2022 04:00	1.1	13.1	1,984.1	0.8	6.00	1	1	1
12/06/2022 05:00	1.2	13.0	2,012.5	0.9	6.00	1	1	1
12/06/2022 06:00	1.2	13.1	1,985.5	0.9	6.00	1	1	1
12/06/2022 07:00	1.3	12.7	2,090.5	0.9	6.30	1	1	1
12/06/2022 08:00	1.7	11.9	2,283.2	1.1	9.10	1	1	1
12/06/2022 09:00	1.7	12.0	2,270.7	1.1	9.10	1	1	1
12/06/2022 10:00	1.7	12.0	2,264.3	1.1	9.10	1	1	1
12/06/2022 11:00	1.7	12.0	2,260.4	1.1	9.00	1	1	1
12/06/2022 12:00	1.6	12.0	2,241.0	1.1	9.00	1	1	1
12/06/2022 13:00	0.7	13.7	1,779.8	0.6	3.60	1	1	1
12/06/2022 14:00	0.3	14.0	1,314.5	0.3	1.30	1	1	0
12/06/2022 15:00	0.4	14.0	1,314.1	0.3	1.30	1	1	0
12/06/2022 16:00	0.5	13.9	1,512.4	0.4	3.00	1	1	0
12/06/2022 17:00	0.7	13.8	1,808.0	0.6	3.60	1	1	0
12/06/2022 18:00	0.7	13.8	1,807.8	0.6	3.60	1	1	0
12/06/2022 19:00	0.7	13.8	1,817.6	0.6	3.60	1	1	1
12/06/2022 20:00	1.4	12.5	2,137.3	1.0	8.50	1	1	1
12/06/2022 21:00	1.6	12.1	2,235.9	1.1	8.90	1	1	1
12/06/2022 22:00	1.4	12.6	2,105.7	1.0	8.40	1	1	1
12/06/2022 23:00	1.2	13.2	1,973.2	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.0	1,961.3	0.8	144.90 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,314.1	0.3	1.30	1	1	0
Maximum:	1.7	14.0	2,283.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	1.5	12.7	2,084.1	1.1	8.30	1	1	1
12/07/2022 01:00	1.2	13.1	1,990.9	0.9	6.00	1	1	1
12/07/2022 02:00	1.5	12.6	2,139.0	1.1	8.60	1	1	1
12/07/2022 03:00	1.6	12.5	2,147.2	1.1	8.60	1	1	1
12/07/2022 04:00	1.6	12.5	2,164.6	1.1	8.70	1	1	1
12/07/2022 05:00	1.6	12.4	2,173.1	1.1	8.70	1	1	1
12/07/2022 06:00	1.3	12.1	2,253.6	0.9	6.80	1	1	1
12/07/2022 07:00	1.6	12.1	2,265.4	1.1	9.10	1	1	1
12/07/2022 08:00	1.5	12.6	2,137.8	1.1	8.60	1	1	1
12/07/2022 09:00	1.6	12.5	2,172.2	1.1	8.70	1	1	1
12/07/2022 10:00	1.6	12.5	2,171.5	1.1	8.70	1	1	1
12/07/2022 11:00	1.6	12.5	2,169.0	1.1	8.70	1	1	1
12/07/2022 12:00	1.6	12.5	2,144.8	1.1	8.60	1	1	1
12/07/2022 13:00	1.6	12.5	2,120.6	1.1	8.50	1	1	1
12/07/2022 14:00	1.5	12.8	2,065.4	1.1	8.30	1	1	1
12/07/2022 15:00	1.5	12.7	2,088.9	1.1	8.40	1	1	1
12/07/2022 16:00	1.6	12.0	2,262.1	1.1	9.00	1	1	1
12/07/2022 17:00	1.7	11.9	2,276.0	1.1	9.10	1	1	1
12/07/2022 18:00	1.7	11.9	2,279.2	1.1	9.10	1	1	1
12/07/2022 19:00	1.7	11.9	2,277.8	1.1	9.10	1	1	1
12/07/2022 20:00	1.7	11.9	2,278.1	1.1	9.10	1	1	1
12/07/2022 21:00	1.7	12.0	2,272.8	1.1	9.10	1	1	1
12/07/2022 22:00	1.6	12.4	2,185.4	1.1	8.70	1	1	1
12/07/2022 23:00	1.6	12.4	2,181.8	1.1	8.70	1	1	1
Average/Sum#:	1.6	12.4	2,179.2	1.1	205.20 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,990.9	0.9	6.00	1	1	1
Maximum:	1.7	13.1	2,279.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	1.6	12.6	2,140.3	1.1	8.60	1	1	1
12/08/2022 01:00	1.6	12.6	2,134.5	1.1	8.50	1	1	1
12/08/2022 02:00	1.6	12.6	2,131.2	1.1	8.50	1	1	1
12/08/2022 03:00	1.6	12.7	2,128.7	1.2	8.50	1	1	1
12/08/2022 04:00	1.6	12.6	2,153.6	1.1	8.60	1	1	1
12/08/2022 05:00	1.6	12.4	2,211.4	1.1	8.80	1	1	1
12/08/2022 06:00	1.7	12.0	2,286.3	1.1	9.10	1	1	1
12/08/2022 07:00	1.6	12.2	2,241.1	1.1	9.00	1	1	1
12/08/2022 08:00	1.2	13.0	2,033.7	0.9	6.10	1	1	1
12/08/2022 09:00	1.4	12.8	2,111.2	1.0	8.40	1	1	1
12/08/2022 10:00	1.5	12.7	2,119.0	1.1	8.50	1	1	1
12/08/2022 11:00	1.5	12.5	2,150.5	1.1	8.60	1	1	1
12/08/2022 12:00	1.6	12.5	2,152.8	1.1	8.60	1	1	1
12/08/2022 13:00	1.6	12.4	2,166.9	1.1	8.70	1	1	1
12/08/2022 14:00	1.7	12.3	2,177.4	1.2	8.70	1	1	1
12/08/2022 15:00	1.6	12.3	2,183.9	1.1	8.70	1	1	1
12/08/2022 16:00	1.7	11.9	2,283.7	1.1	9.10	1	1	1
12/08/2022 17:00	1.7	11.9	2,284.7	1.1	9.10	1	1	1
12/08/2022 18:00	1.7	11.9	2,287.5	1.1	9.20	1	1	1
12/08/2022 19:00	1.7	11.9	2,285.8	1.1	9.10	1	1	1
12/08/2022 20:00	1.7	11.9	2,287.4	1.1	9.10	1	1	1
12/08/2022 21:00	1.7	11.9	2,285.0	1.1	9.10	1	1	1
12/08/2022 22:00	1.7	12.3	2,194.3	1.2	8.80	1	1	1
12/08/2022 23:00	1.7	12.3	2,195.7	1.2	8.80	1	1	1
Average/Sum#:	1.6	12.3	2,192.8	1.1	208.20 #	24 #	24 #	24 #
Minimum:	1.2	11.9	2,033.7	0.9	6.10	1	1	1
Maximum:	1.7	13.0	2,287.5	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	1.5	12.5	2,144.3	1.1	8.60	1	1	1
12/09/2022 01:00	1.3	12.9	2,046.2	1.0	8.20	1	1	1
12/09/2022 02:00	1.5	12.6	2,142.3	1.1	8.60	1	1	1
12/09/2022 03:00	1.6	12.6	2,144.2	1.1	8.60	1	1	1
12/09/2022 04:00	1.6	12.4	2,194.9	1.1	8.80	1	1	1
12/09/2022 05:00	1.7	12.0	2,296.2	1.1	9.20	1	1	1
12/09/2022 06:00	1.7	12.0	2,298.6	1.1	9.20	1	1	1
12/09/2022 07:00	1.7	12.0	2,286.8	1.1	9.10	1	1	1
12/09/2022 08:00	1.3	12.9	2,072.5	1.0	8.30	1	1	1
12/09/2022 09:00	1.2	13.0	2,032.9	0.9	6.10	1	1	1
12/09/2022 10:00	1.0	13.2	1,984.3	0.8	6.00	1	1	1
12/09/2022 11:00	1.4	12.8	2,074.2	1.0	8.30	1	1	1
12/09/2022 12:00	1.2	13.0	2,007.8	0.9	6.00	1	1	1
12/09/2022 13:00	1.6	12.4	2,160.2	1.1	8.60	1	1	1
12/09/2022 14:00	1.7	12.4	2,163.1	1.2	8.70	1	1	1
12/09/2022 15:00	1.4	12.9	2,055.6	1.0	8.20	1	1	1
12/09/2022 16:00	1.7	11.9	2,286.0	1.1	9.10	1	1	1
12/09/2022 17:00	1.7	11.9	2,285.5	1.1	9.10	1	1	1
12/09/2022 18:00	1.7	11.9	2,285.9	1.1	9.10	1	1	1
12/09/2022 19:00	1.7	11.9	2,287.2	1.1	9.10	1	1	1
12/09/2022 20:00	1.7	11.9	2,289.2	1.1	9.20	1	1	1
12/09/2022 21:00	1.7	11.9	2,287.9	1.1	9.20	1	1	1
12/09/2022 22:00	1.7	11.9	2,286.6	1.1	9.10	1	1	1
12/09/2022 23:00	1.7	11.9	2,280.4	1.1	9.10	1	1	1
Average/Sum#:	1.5	12.4	2,183.0	1.1	203.50 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,984.3	0.8	6.00	1	1	1
Maximum:	1.7	13.2	2,298.6	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.2	13.0	2,020.4	0.9	6.10	1	1	1
12/10/2022 01:00	1.2	13.0	2,016.4	0.9	6.00	1	1	1
12/10/2022 02:00	1.1	13.1	1,980.5	0.8	5.90	1	1	1
12/10/2022 03:00	1.2	13.1	1,981.2	0.9	5.90	1	1	1
12/10/2022 04:00	1.1	13.1	1,976.3	0.8	5.90	1	1	1
12/10/2022 05:00	1.2	13.0	1,986.7	0.9	6.00	1	1	1
12/10/2022 06:00	1.1	13.1	1,973.6	0.8	5.90	1	1	1
12/10/2022 07:00	1.1	13.1	1,981.0	0.8	5.90	1	1	1
12/10/2022 08:00	1.2	12.9	2,021.2	0.9	6.10	1	1	1
12/10/2022 09:00	1.2	12.9	1,998.2	0.9	6.00	1	1	1
12/10/2022 10:00	1.2	13.0	1,974.5	0.9	5.90	1	1	1
12/10/2022 11:00	1.3	12.8	2,015.4	0.9	6.00	1	1	1
12/10/2022 12:00	1.5	12.4	2,121.1	1.0	8.50	1	1	1
12/10/2022 13:00	1.7	12.0	2,182.6	1.1	8.70	1	1	1
12/10/2022 14:00	1.5	12.7	2,018.0	1.1	8.10	1	1	1
12/10/2022 15:00	1.5	12.6	2,043.8	1.1	8.20	1	1	1
12/10/2022 16:00	1.5	12.4	2,112.6	1.0	8.50	1	1	1
12/10/2022 17:00	1.5	12.5	2,071.9	1.1	8.30	1	1	1
12/10/2022 18:00	1.5	12.6	2,072.8	1.1	8.30	1	1	1
12/10/2022 19:00	1.7	11.8	2,252.8	1.1	9.00	1	1	1
12/10/2022 20:00	1.7	12.2	2,175.1	1.2	8.70	1	1	1
12/10/2022 21:00	1.5	12.5	2,080.6	1.1	8.30	1	1	1
12/10/2022 22:00	1.4	12.9	2,016.0	1.0	8.10	1	1	1
12/10/2022 23:00	1.5	12.6	2,077.4	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.7	2,047.9	1.0	172.60 #	24 #	24 #	24 #
Minimum:	1.1	11.8	1,973.6	0.8	5.90	1	1	1
Maximum:	1.7	13.1	2,252.8	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.2	13.1	1,967.5	0.9	5.90	1	1	1
12/11/2022 01:00	1.2	13.1	1,965.0	0.9	5.90	1	1	1
12/11/2022 02:00	1.2	13.1	1,964.9	0.9	5.90	1	1	1
12/11/2022 03:00	1.1	13.1	1,965.4	0.8	5.90	1	1	1
12/11/2022 04:00	1.1	13.1	1,969.0	0.8	5.90	1	1	1
12/11/2022 05:00	1.0	13.1	1,967.8	0.8	5.90	1	1	1
12/11/2022 06:00	1.0	13.1	1,969.4	0.8	5.90	1	1	1
12/11/2022 07:00	1.0	13.2	1,972.0	0.8	5.90	1	1	1
12/11/2022 08:00	1.0	13.2	1,973.7	0.8	5.90	1	1	1
12/11/2022 09:00	1.0	13.1	1,971.0	0.8	5.90	1	1	1
12/11/2022 10:00	1.2	13.1	1,969.2	0.9	5.90	1	1	1
12/11/2022 11:00	1.2	13.1	1,966.9	0.9	5.90	1	1	1
12/11/2022 12:00	1.2	13.1	1,966.8	0.9	5.90	1	1	1
12/11/2022 13:00	1.3	13.1	1,968.3	1.0	7.90	1	1	1
12/11/2022 14:00	1.4	13.1	1,963.5	1.1	7.90	1	1	1
12/11/2022 15:00	1.5	12.7	2,060.7	1.1	8.20	1	1	1
12/11/2022 16:00	1.4	12.8	2,068.6	1.0	8.30	1	1	1
12/11/2022 17:00	1.6	12.5	2,141.4	1.1	8.60	1	1	1
12/11/2022 18:00	1.3	12.9	2,048.1	1.0	8.20	1	1	1
12/11/2022 19:00	1.4	12.8	2,066.7	1.0	8.30	1	1	1
12/11/2022 20:00	1.5	12.6	2,120.2	1.1	8.50	1	1	1
12/11/2022 21:00	1.2	13.1	2,003.0	0.9	6.00	1	1	1
12/11/2022 22:00	1.0	13.2	1,972.7	0.8	5.90	1	1	1
12/11/2022 23:00	1.0	13.2	1,974.3	0.8	5.90	1	1	1
Average/Sum#:	1.2	13.0	1,999.0	0.9	160.40 #	24 #	24 #	24 #
Minimum:	1.0	12.5	1,963.5	0.8	5.90	1	1	1
Maximum:	1.6	13.2	2,141.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.0	13.2	1,981.6	0.8	5.90	1	1	1
12/12/2022 01:00	1.0	13.2	1,982.3	0.8	5.90	1	1	1
12/12/2022 02:00	1.0	13.2	1,981.4	0.8	5.90	1	1	1
12/12/2022 03:00	1.0	13.2	1,978.4	0.8	5.90	1	1	1
12/12/2022 04:00	1.0	13.2	1,977.9	0.8	5.90	1	1	1
12/12/2022 05:00	1.4	12.7	2,119.2	1.0	8.50	1	1	1
12/12/2022 06:00	1.6	12.2	2,218.1	1.1	8.90	1	1	1
12/12/2022 07:00	1.5	12.3	2,198.9	1.0	8.80	1	1	1
12/12/2022 08:00	1.3	12.8	2,076.7	0.9	6.20	1	1	1
12/12/2022 09:00	1.3	12.9	2,068.8	1.0	8.30	1	1	1
12/12/2022 10:00	1.0	13.3	1,973.0	0.8	5.90	1	1	1
12/12/2022 11:00	1.0	13.2	1,970.2	0.8	5.90	1	1	1
12/12/2022 12:00	1.0	13.2	1,970.6	0.8	5.90	1	1	1
12/12/2022 13:00	1.1	13.2	1,969.6	0.8	5.90	1	1	1
12/12/2022 14:00	1.1	13.2	1,968.0	0.8	5.90	1	1	1
12/12/2022 15:00	1.2	13.2	1,967.7	0.9	5.90	1	1	1
12/12/2022 16:00	1.5	12.5	2,153.9	1.1	8.60	1	1	1
12/12/2022 17:00	1.7	12.1	2,250.2	1.1	9.00	1	1	1
12/12/2022 18:00	1.6	11.8	2,314.5	1.0	9.30	1	1	1
12/12/2022 19:00	1.7	11.8	2,316.4	1.1	9.30	1	1	1
12/12/2022 20:00	1.6	11.8	2,320.3	1.0	9.30	1	1	1
12/12/2022 21:00	1.7	12.0	2,269.9	1.1	9.10	1	1	1
12/12/2022 22:00	1.6	12.3	2,201.9	1.1	8.80	1	1	1
12/12/2022 23:00	1.3	13.0	2,035.1	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.7	2,094.4	0.9	177.10 #	24 #	24 #	24 #
Minimum:	1.0	11.8	1,967.7	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,320.3	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	1.6	12.6	2,155.3	1.1	8.60	1	1	1
12/13/2022 01:00	1.6	12.5	2,162.4	1.1	8.60	1	1	1
12/13/2022 02:00	1.6	12.5	2,171.0	1.1	8.70	1	1	1
12/13/2022 03:00	1.6	12.5	2,161.4	1.1	8.60	1	1	1
12/13/2022 04:00	1.6	12.4	2,201.7	1.1	8.80	1	1	1
12/13/2022 05:00	1.6	12.1	2,286.6	1.1	9.10	1	1	1
12/13/2022 06:00	1.6	11.9	2,323.5	1.0	9.30	1	1	1
12/13/2022 07:00	1.7	11.9	2,314.5	1.1	9.30	1	1	1
12/13/2022 08:00	1.4	12.5	2,149.7	1.0	8.60	1	1	1
12/13/2022 09:00	1.2	13.1	2,013.4	0.9	6.00	1	1	1
12/13/2022 10:00	1.0	13.3	1,978.2	0.8	5.90	1	1	1
12/13/2022 11:00	1.1	13.2	1,972.8	0.8	5.90	1	1	1
12/13/2022 12:00	1.2	13.2	1,971.6	0.9	5.90	1	1	1
12/13/2022 13:00	1.2	13.2	1,969.9	0.9	5.90	1	1	1
12/13/2022 14:00	1.3	13.2	1,968.6	1.0	7.90	1	1	1
12/13/2022 15:00	1.5	12.8	2,076.2	1.1	8.30	1	1	1
12/13/2022 16:00	1.6	11.9	2,282.3	1.0	9.10	1	1	1
12/13/2022 17:00	1.7	11.8	2,299.2	1.1	9.20	1	1	1
12/13/2022 18:00	1.7	11.9	2,297.3	1.1	9.20	1	1	1
12/13/2022 19:00	1.6	11.9	2,296.7	1.0	9.20	1	1	1
12/13/2022 20:00	1.7	11.9	2,293.3	1.1	9.20	1	1	1
12/13/2022 21:00	1.7	12.0	2,293.3	1.1	9.20	1	1	1
12/13/2022 22:00	1.7	12.0	2,297.4	1.1	9.20	1	1	1
12/13/2022 23:00	1.6	11.9	2,293.5	1.0	9.20	1	1	1
Average/Sum#:	1.5	12.4	2,176.2	1.0	198.90 #	24 #	24 #	24 #
Minimum:	1.0	11.8	1,968.6	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,323.5	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	1.6	12.4	2,201.0	1.1	8.80	1	1	1
12/14/2022 01:00	1.6	12.4	2,205.8	1.1	8.80	1	1	1
12/14/2022 02:00	1.6	12.4	2,207.5	1.1	8.80	1	1	1
12/14/2022 03:00	1.6	12.5	2,202.0	1.1	8.80	1	1	1
12/14/2022 04:00	1.6	12.5	2,195.8	1.1	8.80	1	1	1
12/14/2022 05:00	1.6	12.0	2,307.3	1.1	9.20	1	1	1
12/14/2022 06:00	1.6	12.0	2,311.1	1.1	9.20	1	1	1
12/14/2022 07:00	1.6	12.1	2,277.8	1.1	9.10	1	1	1
12/14/2022 08:00	1.4	12.9	2,081.0	1.0	8.30	1	1	1
12/14/2022 09:00	1.2	13.1	2,011.1	0.9	6.00	1	1	1
12/14/2022 10:00	1.2	13.0	2,028.4	0.9	6.10	1	1	1
12/14/2022 11:00	1.0	13.2	1,974.9	0.8	5.90	1	1	1
12/14/2022 12:00	1.0	13.2	1,976.5	0.8	5.90	1	1	1
12/14/2022 13:00	1.0	13.2	1,978.3	0.8	5.90	1	1	1
12/14/2022 14:00	1.0	13.2	1,975.2	0.8	5.90	1	1	1
12/14/2022 15:00	1.2	13.1	2,018.4	0.9	6.10	1	1	1
12/14/2022 16:00	1.6	12.2	2,219.4	1.1	8.90	1	1	1
12/14/2022 17:00	1.7	11.9	2,291.2	1.1	9.20	1	1	1
12/14/2022 18:00	1.7	11.9	2,288.1	1.1	9.20	1	1	1
12/14/2022 19:00	1.7	11.9	2,292.6	1.1	9.20	1	1	1
12/14/2022 20:00	1.7	12.0	2,292.9	1.1	9.20	1	1	1
12/14/2022 21:00	1.6	12.0	2,291.3	1.1	9.20	1	1	1
12/14/2022 22:00	1.6	12.1	2,265.2	1.1	9.10	1	1	1
12/14/2022 23:00	1.6	12.5	2,178.6	1.1	8.70	1	1	1
Average/Sum#:	1.5	12.5	2,169.6	1.0	194.30 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,974.9	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,311.1	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2022 00:00	1.6	12.0	2,300.0	1.1	9.20	1	1	1
12/15/2022 01:00	1.7	11.9	2,310.7	1.1	9.20	1	1	1
12/15/2022 02:00	1.6	11.9	2,310.7	1.0	9.20	1	1	1
12/15/2022 03:00	1.7	11.9	2,312.5	1.1	9.30	1	1	1
12/15/2022 04:00	1.7	11.9	2,317.5	1.1	9.30	1	1	1
12/15/2022 05:00	1.7	11.9	2,320.2	1.1	9.30	1	1	1
12/15/2022 06:00	1.5	11.9	2,319.6	1.0	9.30	1	1	1
12/15/2022 07:00	1.7	11.9	2,314.8	1.1	9.30	1	1	1
12/15/2022 08:00	1.6	12.2	2,232.9	1.1	8.90	1	1	1
12/15/2022 09:00	1.6	12.1	2,231.2	1.1	8.90	1	1	1
12/15/2022 10:00	1.3	13.1	1,978.7	1.0	7.90	1	1	1
12/15/2022 11:00	1.4	13.1	1,990.3	1.1	8.00	1	1	1
12/15/2022 12:00	1.5	12.9	2,023.1	1.1	8.10	1	1	1
12/15/2022 13:00	1.5	12.8	2,045.1	1.1	8.20	1	1	1
12/15/2022 14:00	1.6	12.6	2,102.6	1.1	8.40	1	1	1
12/15/2022 15:00	1.6	11.9	2,258.0	1.0	9.00	1	1	1
12/15/2022 16:00	1.6	11.9	2,270.0	1.0	9.10	1	1	1
12/15/2022 17:00	1.6	11.9	2,268.1	1.0	9.10	1	1	1
12/15/2022 18:00	1.6	12.0	2,258.2	1.1	9.00	1	1	1
12/15/2022 19:00	1.7	12.0	2,251.3	1.1	9.00	1	1	1
12/15/2022 20:00	1.6	12.0	2,253.0	1.1	9.00	1	1	1
12/15/2022 21:00	1.6	12.1	2,254.6	1.1	9.00	1	1	1
12/15/2022 22:00	1.6	12.1	2,260.1	1.1	9.00	1	1	1
12/15/2022 23:00	1.6	12.2	2,242.5	1.1	9.00	1	1	1
Average/Sum#:	1.6	12.2	2,226.1	1.1	213.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,978.7	1.0	7.90	1	1	1
Maximum:	1.7	13.1	2,320.2	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	1.1	13.1	1,997.7	0.8	6.00	1	1	1
12/16/2022 01:00	1.0	13.2	1,975.0	0.8	5.90	1	1	1
12/16/2022 02:00	1.0	13.2	1,975.1	0.8	5.90	1	1	1
12/16/2022 03:00	1.0	13.2	1,977.9	0.8	5.90	1	1	1
12/16/2022 04:00	1.0	13.2	1,976.0	0.8	5.90	1	1	1
12/16/2022 05:00	1.1	13.2	1,986.3	0.8	6.00	1	1	1
12/16/2022 06:00	1.2	12.7	2,114.7	0.9	6.30	1	1	1
12/16/2022 07:00	1.5	12.4	2,213.4	1.0	8.90	1	1	1
12/16/2022 08:00	1.6	12.6	2,148.7	1.1	8.60	1	1	1
12/16/2022 09:00	1.4	12.8	2,073.1	1.0	8.30	1	1	1
12/16/2022 10:00	0.5	13.9	1,533.9	0.4	3.10	1	1	0
12/16/2022 11:00	0.5	14.0	1,455.0	0.4	2.90	1	1	0
12/16/2022 12:00	0.4	14.0	1,319.9	0.3	1.30	1	1	0
12/16/2022 13:00	0.4	14.0	1,322.2	0.3	1.30	1	1	0
12/16/2022 14:00	0.6	13.9	1,577.2	0.5	3.20	1	1	0
12/16/2022 15:00	0.6	13.9	1,550.0	0.5	3.10	1	1	1
12/16/2022 16:00	1.5	12.4	2,166.8	1.0	8.70	1	1	1
12/16/2022 17:00	1.6	12.1	2,236.7	1.1	8.90	1	1	1
12/16/2022 18:00	1.6	12.4	2,162.4	1.1	8.60	1	1	1
12/16/2022 19:00	1.6	12.4	2,168.7	1.1	8.70	1	1	1
12/16/2022 20:00	1.6	12.0	2,256.4	1.1	9.00	1	1	1
12/16/2022 21:00	1.6	12.2	2,198.9	1.1	8.80	1	1	1
12/16/2022 22:00	1.3	12.7	2,089.5	0.9	6.30	1	1	1
12/16/2022 23:00	1.1	13.2	1,975.1	0.8	5.90	1	1	1
Average/Sum#:	1.1	13.0	1,935.4	0.8	147.50 #	24 #	24 #	19 #
Minimum:	0.4	12.0	1,319.9	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,256.4	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	1.6	12.5	2,148.3	1.1	8.60	1	1	1
12/17/2022 01:00	1.6	12.5	2,151.2	1.1	8.60	1	1	1
12/17/2022 02:00	1.6	12.6	2,142.6	1.1	8.60	1	1	1
12/17/2022 03:00	1.6	12.6	2,153.4	1.1	8.60	1	1	1
12/17/2022 04:00	1.6	12.5	2,154.4	1.1	8.60	1	1	1
12/17/2022 05:00	1.6	12.6	2,151.3	1.1	8.60	1	1	1
12/17/2022 06:00	1.6	12.1	2,242.2	1.1	9.00	1	1	1
12/17/2022 07:00	1.4	12.7	2,099.3	1.0	8.40	1	1	1
12/17/2022 08:00	1.6	12.5	2,165.9	1.1	8.70	1	1	1
12/17/2022 09:00	1.5	12.7	2,124.8	1.1	8.50	1	1	1
12/17/2022 10:00	1.2	13.1	2,009.5	0.9	6.00	1	1	1
12/17/2022 11:00	1.0	13.2	1,977.3	0.8	5.90	1	1	1
12/17/2022 12:00	1.1	13.2	1,970.0	0.8	5.90	1	1	1
12/17/2022 13:00	1.2	13.2	1,970.2	0.9	5.90	1	1	1
12/17/2022 14:00	1.3	13.1	1,991.1	1.0	8.00	1	1	1
12/17/2022 15:00	1.6	12.6	2,124.4	1.1	8.50	1	1	1
12/17/2022 16:00	1.6	11.9	2,279.1	1.0	9.10	1	1	1
12/17/2022 17:00	1.6	12.0	2,247.4	1.1	9.00	1	1	1
12/17/2022 18:00	1.6	12.4	2,159.7	1.1	8.60	1	1	1
12/17/2022 19:00	1.6	11.9	2,288.0	1.0	9.20	1	1	1
12/17/2022 20:00	1.7	11.9	2,291.4	1.1	9.20	1	1	1
12/17/2022 21:00	1.6	11.9	2,292.3	1.0	9.20	1	1	1
12/17/2022 22:00	1.6	11.9	2,284.2	1.0	9.10	1	1	1
12/17/2022 23:00	1.6	12.3	2,192.5	1.1	8.80	1	1	1
Average/Sum#:	1.5	12.5	2,150.4	1.0	198.60 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,970.0	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,292.3	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	1.6	12.5	2,141.4	1.1	8.60	1	1	1
12/18/2022 01:00	1.6	12.6	2,140.8	1.1	8.60	1	1	1
12/18/2022 02:00	1.2	13.1	2,023.7	0.9	6.10	1	1	1
12/18/2022 03:00	1.1	13.3	1,985.2	0.9	6.00	1	1	1
12/18/2022 04:00	1.5	12.7	2,140.3	1.1	8.60	1	1	1
12/18/2022 05:00	1.6	12.6	2,162.0	1.1	8.60	1	1	1
12/18/2022 06:00	1.5	12.4	2,182.1	1.0	8.70	1	1	1
12/18/2022 07:00	1.7	12.3	2,219.3	1.2	8.90	1	1	1
12/18/2022 08:00	1.4	12.7	2,091.7	1.0	8.40	1	1	1
12/18/2022 09:00	0.6	13.9	1,607.9	0.5	3.20	1	1	0
12/18/2022 10:00	0.5	13.9	1,552.2	0.4	3.10	1	1	0
12/18/2022 11:00	0.5	13.9	1,544.4	0.4	3.10	1	1	0
12/18/2022 12:00	0.5	14.0	1,404.3	0.4	2.80	1	1	0
12/18/2022 13:00	0.5	14.0	1,395.8	0.4	2.80	1	1	0
12/18/2022 14:00	0.6	13.9	1,634.8	0.5	3.30	1	1	0
12/18/2022 15:00	0.6	13.9	1,645.9	0.5	3.30	1	1	1
12/18/2022 16:00	1.4	12.5	2,143.3	1.0	8.60	1	1	1
12/18/2022 17:00	1.6	12.0	2,254.0	1.1	9.00	1	1	1
12/18/2022 18:00	1.6	11.9	2,283.9	1.0	9.10	1	1	1
12/18/2022 19:00	1.7	11.9	2,288.7	1.1	9.20	1	1	1
12/18/2022 20:00	1.6	12.2	2,245.0	1.1	9.00	1	1	1
12/18/2022 21:00	1.6	12.4	2,208.9	1.1	8.80	1	1	1
12/18/2022 22:00	1.6	12.4	2,205.7	1.1	8.80	1	1	1
12/18/2022 23:00	1.2	13.0	2,049.4	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.9	1,981.3	0.9	162.70 #	24 #	24 #	18 #
Minimum:	0.5	11.9	1,395.8	0.4	2.80	1	1	0
Maximum:	1.7	14.0	2,288.7	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	1.5	12.7	2,141.9	1.1	8.60	1	1	1
12/19/2022 01:00	1.5	12.6	2,153.5	1.1	8.60	1	1	1
12/19/2022 02:00	1.5	12.6	2,149.7	1.1	8.60	1	1	1
12/19/2022 03:00	1.5	12.6	2,152.1	1.1	8.60	1	1	1
12/19/2022 04:00	1.6	12.5	2,185.5	1.1	8.70	1	1	1
12/19/2022 05:00	1.7	12.0	2,309.6	1.1	9.20	1	1	1
12/19/2022 06:00	1.6	12.0	2,310.1	1.1	9.20	1	1	1
12/19/2022 07:00	1.7	12.0	2,310.1	1.1	9.20	1	1	1
12/19/2022 08:00	1.6	12.2	2,262.0	1.1	9.00	1	1	1
12/19/2022 09:00	1.7	12.1	2,274.3	1.1	9.10	1	1	1
12/19/2022 10:00	1.6	12.5	2,181.5	1.1	8.70	1	1	1
12/19/2022 11:00	1.6	12.5	2,181.8	1.1	8.70	1	1	1
12/19/2022 12:00	1.6	12.6	2,174.1	1.1	8.70	1	1	1
12/19/2022 13:00	1.6	12.6	2,164.7	1.1	8.70	1	1	1
12/19/2022 14:00	1.6	12.6	2,166.8	1.1	8.70	1	1	1
12/19/2022 15:00	1.6	12.3	2,231.0	1.1	8.90	1	1	1
12/19/2022 16:00	1.6	12.1	2,274.5	1.1	9.10	1	1	1
12/19/2022 17:00	1.7	12.1	2,275.0	1.1	9.10	1	1	1
12/19/2022 18:00	1.7	12.1	2,277.1	1.1	9.10	1	1	1
12/19/2022 19:00	1.6	12.1	2,280.3	1.1	9.10	1	1	1
12/19/2022 20:00	1.7	12.2	2,277.2	1.2	9.10	1	1	1
12/19/2022 21:00	1.7	12.2	2,277.4	1.2	9.10	1	1	1
12/19/2022 22:00	1.7	12.1	2,283.3	1.1	9.10	1	1	1
12/19/2022 23:00	1.7	12.1	2,278.8	1.1	9.10	1	1	1
Average/Sum#:	1.6	12.3	2,232.2	1.1	214.00 #	24 #	24 #	24 #
Minimum:	1.5	12.0	2,141.9	1.1	8.60	1	1	1
Maximum:	1.7	12.7	2,310.1	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	1.6	12.6	2,180.6	1.1	8.70	1	1	1
12/20/2022 01:00	1.6	12.6	2,178.9	1.1	8.70	1	1	1
12/20/2022 02:00	1.6	12.5	2,184.2	1.1	8.70	1	1	1
12/20/2022 03:00	1.6	12.5	2,189.6	1.1	8.80	1	1	1
12/20/2022 04:00	1.6	12.5	2,190.7	1.1	8.80	1	1	1
12/20/2022 05:00	1.6	12.5	2,190.8	1.1	8.80	1	1	1
12/20/2022 06:00	1.5	12.1	2,291.6	1.0	9.20	1	1	1
12/20/2022 07:00	1.7	12.1	2,284.8	1.1	9.10	1	1	1
12/20/2022 08:00	1.5	12.6	2,170.4	1.1	8.70	1	1	1
12/20/2022 09:00	1.6	12.5	2,170.0	1.1	8.70	1	1	1
12/20/2022 10:00	1.5	12.7	2,128.2	1.1	8.50	1	1	1
12/20/2022 11:00	1.5	12.8	2,095.1	1.1	8.40	1	1	1
12/20/2022 12:00	1.0	13.3	1,961.4	0.8	5.90	1	1	1
12/20/2022 13:00	1.0	13.3	1,965.5	0.8	5.90	1	1	1
12/20/2022 14:00	1.0	13.3	1,964.0	0.8	5.90	1	1	1
12/20/2022 15:00	1.3	13.0	2,038.6	1.0	8.20	1	1	1
12/20/2022 16:00	1.6	12.3	2,199.8	1.1	8.80	1	1	1
12/20/2022 17:00	1.7	12.0	2,266.0	1.1	9.10	1	1	1
12/20/2022 18:00	1.6	12.0	2,265.9	1.1	9.10	1	1	1
12/20/2022 19:00	1.6	12.0	2,259.4	1.1	9.00	1	1	1
12/20/2022 20:00	1.7	12.0	2,259.9	1.1	9.00	1	1	1
12/20/2022 21:00	1.6	12.4	2,168.4	1.1	8.70	1	1	1
12/20/2022 22:00	1.6	12.4	2,167.9	1.1	8.70	1	1	1
12/20/2022 23:00	1.6	12.2	2,226.6	1.1	8.90	1	1	1
Average/Sum#:	1.5	12.5	2,166.6	1.1	202.30 #	24 #	24 #	24 #
Minimum:	1.0	12.0	1,961.4	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,291.6	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2022 00:00	1.7	12.0	2,286.1	1.1	9.10	1	1	1
12/21/2022 01:00	1.7	12.0	2,284.9	1.1	9.10	1	1	1
12/21/2022 02:00	1.7	12.0	2,281.3	1.1	9.10	1	1	1
12/21/2022 03:00	1.7	12.0	2,289.0	1.1	9.20	1	1	1
12/21/2022 04:00	1.7	12.0	2,282.4	1.1	9.10	1	1	1
12/21/2022 05:00	1.7	12.0	2,284.7	1.1	9.10	1	1	1
12/21/2022 06:00	1.6	12.0	2,284.5	1.1	9.10	1	1	1
12/21/2022 07:00	1.7	12.0	2,283.3	1.1	9.10	1	1	1
12/21/2022 08:00	0.0	0.0	2,268.8	0.0	0.00	1	1	1
12/21/2022 09:00	1.6	12.2	2,259.9	1.1	9.00	1	1	1
12/21/2022 10:00	1.6	12.2	2,253.9	1.1	9.00	1	1	1
12/21/2022 11:00	1.6	12.3	2,219.0	1.1	8.90	1	1	1
12/21/2022 12:00	1.6	12.2	2,236.9	1.1	8.90	1	1	1
12/21/2022 13:00	1.7	12.1	2,229.8	1.1	8.90	1	1	1
12/21/2022 14:00	1.6	12.5	2,160.3	1.1	8.60	1	1	1
12/21/2022 15:00	1.6	12.1	2,234.3	1.1	8.90	1	1	1
12/21/2022 16:00	1.6	12.0	2,257.4	1.1	9.00	1	1	1
12/21/2022 17:00	1.7	12.0	2,255.2	1.1	9.00	1	1	1
12/21/2022 18:00	1.6	12.0	2,258.5	1.1	9.00	1	1	1
12/21/2022 19:00	1.7	12.0	2,256.4	1.1	9.00	1	1	1
12/21/2022 20:00	1.7	12.1	2,252.8	1.1	9.00	1	1	1
12/21/2022 21:00	1.7	12.1	2,253.7	1.1	9.00	1	1	1
12/21/2022 22:00	1.6	12.1	2,250.9	1.1	9.00	1	1	1
12/21/2022 23:00	1.7	12.1	2,248.9	1.1	9.00	1	1	1
Average/Sum#:	1.7	12.1	2,257.2	1.1	207.10 #	24 #	24 #	24 #
Minimum:	1.6	12.0	2,160.3	1.1	8.60	1	1	1
Maximum:	1.7	12.5	2,289.0	1.1	9.20	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	1.6	12.4	2,185.3	1.1	8.70	1	1	1
12/22/2022 01:00	1.1	13.2	1,981.3	0.8	5.90	1	1	1
12/22/2022 02:00	1.0	13.2	1,968.8	0.8	5.90	1	1	1
12/22/2022 03:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/22/2022 04:00	1.3	12.8	2,091.8	0.9	6.30	1	1	1
12/22/2022 05:00	1.6	12.4	2,221.8	1.1	8.90	1	1	1
12/22/2022 06:00	1.7	12.1	2,268.5	1.1	9.10	1	1	1
12/22/2022 07:00	1.7	12.1	2,266.2	1.1	9.10	1	1	1
12/22/2022 08:00	1.7	12.2	2,248.9	1.2	9.00	1	1	1
12/22/2022 09:00	1.5	12.6	2,149.4	1.1	8.60	1	1	1
12/22/2022 10:00	1.5	12.6	2,146.2	1.1	8.60	1	1	1
12/22/2022 11:00	1.5	12.6	2,143.8	1.1	8.60	1	1	1
12/22/2022 12:00	1.5	12.6	2,141.5	1.1	8.60	1	1	1
12/22/2022 13:00	1.5	12.6	2,143.3	1.1	8.60	1	1	1
12/22/2022 14:00	1.5	12.6	2,149.6	1.1	8.60	1	1	1
12/22/2022 15:00	1.6	12.3	2,214.6	1.1	8.90	1	1	1
12/22/2022 16:00	1.6	12.3	2,209.7	1.1	8.80	1	1	1
12/22/2022 17:00	1.7	12.1	2,256.5	1.1	9.00	1	1	1
12/22/2022 18:00	1.7	12.1	2,261.1	1.1	9.00	1	1	1
12/22/2022 19:00	1.7	12.1	2,267.4	1.1	9.10	1	1	1
12/22/2022 20:00	1.7	12.1	2,262.7	1.1	9.10	1	1	1
12/22/2022 21:00	1.7	12.1	2,260.5	1.1	9.00	1	1	1
12/22/2022 22:00	1.7	12.3	2,215.3	1.2	8.90	1	1	1
12/22/2022 23:00	1.4	12.8	2,077.3	1.0	8.30	1	1	1
Average/Sum#:	1.5	12.5	2,170.8	1.1	200.50 #	24 #	24 #	24 #
Minimum:	1.0	12.1	1,968.0	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,268.5	1.2	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	1.6	12.3	2,228.2	1.1	8.90	1	1	1
12/23/2022 01:00	1.7	12.1	2,265.3	1.1	9.10	1	1	1
12/23/2022 02:00	1.7	12.1	2,261.5	1.1	9.00	1	1	1
12/23/2022 03:00	1.7	12.1	2,261.6	1.1	9.00	1	1	1
12/23/2022 04:00	1.7	12.1	2,262.1	1.1	9.00	1	1	1
12/23/2022 05:00	1.7	12.1	2,259.9	1.1	9.00	1	1	1
12/23/2022 06:00	1.6	12.1	2,259.7	1.1	9.00	1	1	1
12/23/2022 07:00	1.6	12.2	2,240.1	1.1	9.00	1	1	1
12/23/2022 08:00	1.6	12.4	2,187.9	1.1	8.80	1	1	1
12/23/2022 09:00	1.6	12.4	2,182.4	1.1	8.70	1	1	1
12/23/2022 10:00	1.6	12.5	2,137.6	1.1	8.60	1	1	1
12/23/2022 11:00	1.6	12.5	2,141.7	1.1	8.60	1	1	1
12/23/2022 12:00	1.4	12.9	2,027.4	1.0	8.10	1	1	1
12/23/2022 13:00	1.1	13.2	1,960.0	0.8	5.90	1	1	1
12/23/2022 14:00	1.1	13.2	1,953.8	0.8	5.90	1	1	1
12/23/2022 15:00	1.4	12.8	2,064.7	1.0	8.30	1	1	1
12/23/2022 16:00	1.7	12.0	2,253.1	1.1	9.00	1	1	1
12/23/2022 17:00	1.7	12.0	2,254.2	1.1	9.00	1	1	1
12/23/2022 18:00	1.7	12.0	2,260.1	1.1	9.00	1	1	1
12/23/2022 19:00	1.7	12.0	2,252.4	1.1	9.00	1	1	1
12/23/2022 20:00	1.7	12.0	2,248.8	1.1	9.00	1	1	1
12/23/2022 21:00	1.7	12.0	2,253.2	1.1	9.00	1	1	1
12/23/2022 22:00	1.7	12.0	2,252.2	1.1	9.00	1	1	1
12/23/2022 23:00	1.6	12.0	2,242.9	1.1	9.00	1	1	1
Average/Sum#:	1.6	12.3	2,196.3	1.1	206.90 #	24 #	24 #	24 #
Minimum:	1.1	12.0	1,953.8	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,265.3	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	1.6	12.5	2,130.9	1.1	8.50	1	1	1
12/24/2022 01:00	1.6	12.6	2,124.1	1.1	8.50	1	1	1
12/24/2022 02:00	1.1	13.2	1,963.2	0.8	5.90	1	1	1
12/24/2022 03:00	1.1	13.2	1,955.6	0.8	5.90	1	1	1
12/24/2022 04:00	1.1	13.2	1,955.0	0.8	5.90	1	1	1
12/24/2022 05:00	1.1	13.2	1,953.0	0.8	5.90	1	1	1
12/24/2022 06:00	1.2	13.1	1,979.9	0.9	5.90	1	1	1
12/24/2022 07:00	1.2	13.0	2,010.1	0.9	6.00	1	1	1
12/24/2022 08:00	0.9	13.4	1,837.3	0.7	5.50	1	1	1
12/24/2022 09:00	0.4	13.9	1,316.3	0.3	1.30	1	1	0
12/24/2022 10:00	0.6	13.9	1,548.3	0.5	3.10	1	1	0
12/24/2022 11:00	0.6	13.9	1,547.9	0.5	3.10	1	1	0
12/24/2022 12:00	0.6	13.9	1,552.0	0.5	3.10	1	1	0
12/24/2022 13:00	0.6	13.9	1,554.4	0.5	3.10	1	1	0
12/24/2022 14:00	0.7	13.9	1,730.3	0.6	3.50	1	1	0
12/24/2022 15:00	0.7	13.9	1,734.3	0.6	3.50	1	1	0
12/24/2022 16:00	0.6	13.9	1,590.2	0.5	3.20	1	1	1
12/24/2022 17:00	1.1	13.1	1,969.4	0.8	5.90	1	1	1
12/24/2022 18:00	1.1	13.1	1,965.8	0.8	5.90	1	1	1
12/24/2022 19:00	1.1	13.1	1,965.9	0.8	5.90	1	1	1
12/24/2022 20:00	1.1	13.1	1,967.3	0.8	5.90	1	1	1
12/24/2022 21:00	1.1	13.1	1,962.5	0.8	5.90	1	1	1
12/24/2022 22:00	1.1	13.2	1,965.3	0.8	5.90	1	1	1
12/24/2022 23:00	1.1	13.1	1,967.2	0.8	5.90	1	1	1
Average/Sum#:	1.0	13.4	1,843.6	0.7	123.20 #	24 #	24 #	17 #
Minimum:	0.4	12.5	1,316.3	0.3	1.30	1	1	0
Maximum:	1.6	13.9	2,130.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.1	13.1	1,946.8	0.8	5.80	1	1	1
12/25/2022 01:00	6.3	15.6	592.2	7.0	3.39	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 18:00	28.4	17.7	345.3	52.4	47.95	1	0	0
12/25/2022 19:00	9.6	17.3	411.1	15.7	23.80	1	0	0
12/25/2022 20:00	10.3	15.9	780.4	12.2	35.10	1	0	0
12/25/2022 21:00	0.4	13.9	1,417.5	0.3	1.40	1	1	0
12/25/2022 22:00	0.6	13.9	1,455.7	0.5	2.90	1	1	0
12/25/2022 23:00	0.6	13.9	1,477.4	0.5	3.00	1	1	0
Average/Sum#:	7.2	15.2	1,053.3	11.2	123.34 #	8 #	4 #	1 #
Minimum:	0.4	13.1	345.3	0.3	1.40	0	0	0
Maximum:	28.4	17.7	1,946.8	52.4	47.95	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.8	13.8	1,763.9	0.7	3.50	1	1	0
12/26/2022 01:00	0.5	13.8	1,543.0	0.4	3.10	1	1	0
12/26/2022 02:00	0.6	13.8	1,700.6	0.5	3.40	1	1	0
12/26/2022 03:00	0.6	13.8	1,721.9	0.5	3.40	1	1	0
12/26/2022 04:00	0.6	13.8	1,721.7	0.5	3.40	1	1	0
12/26/2022 05:00	0.6	13.8	1,737.5	0.5	3.50	1	1	0
12/26/2022 06:00	0.6	13.8	1,736.8	0.5	3.50	1	1	0
12/26/2022 07:00	0.6	13.8	1,728.0	0.5	3.50	1	1	0
12/26/2022 08:00	0.6	13.8	1,734.8	0.5	3.50	1	1	0
12/26/2022 09:00	0.5	13.9	1,548.8	0.4	3.10	1	1	0
12/26/2022 10:00	0.5	13.9	1,544.0	0.4	3.10	1	1	0
12/26/2022 11:00	0.5	13.9	1,535.6	0.4	3.10	1	1	0
12/26/2022 12:00	0.5	13.9	1,526.6	0.4	3.10	1	1	0
12/26/2022 13:00	0.6	13.9	1,547.1	0.5	3.10	1	1	0
12/26/2022 14:00	0.6	13.8	1,610.5	0.5	3.20	1	1	0
12/26/2022 15:00	0.6	13.8	1,740.0	0.5	3.50	1	1	0
12/26/2022 16:00	0.7	13.8	1,774.3	0.6	3.50	1	1	1
12/26/2022 17:00	1.3	12.6	2,122.6	0.9	6.40	1	1	1
12/26/2022 18:00	1.6	12.4	2,163.9	1.1	8.70	1	1	1
12/26/2022 19:00	1.2	13.0	2,015.8	0.9	6.00	1	1	1
12/26/2022 20:00	1.2	13.1	2,000.4	0.9	6.00	1	1	1
12/26/2022 21:00	1.1	13.2	1,969.8	0.8	5.90	1	1	1
12/26/2022 22:00	1.1	13.2	1,947.6	0.8	5.80	1	1	1
12/26/2022 23:00	4.9	15.6	609.2	5.5	2.81	1	0	0
Average/Sum#:	0.9	13.7	1,710.2	0.8	98.11 #	24 #	23 #	7 #
Minimum:	0.5	12.4	609.2	0.4	2.81	1	0	0
Maximum:	4.9	15.6	2,163.9	5.5	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 01:00	0.1	18.8	198.2	0.3	0.04	1	0	0
12/27/2022 02:00	7.2	16.0	756.8	8.7	24.20	1	0	0
12/27/2022 03:00	0.5	13.8	1,538.4	0.4	3.10	1	1	0
12/27/2022 04:00	0.6	13.9	1,539.3	0.5	3.10	1	1	0
12/27/2022 05:00	0.7	13.8	1,685.4	0.6	3.40	1	1	0
12/27/2022 06:00	0.5	13.9	1,397.3	0.4	2.80	1	1	0
12/27/2022 07:00	0.8	13.8	1,731.2	0.7	3.50	1	1	0
12/27/2022 08:00	0.7	13.8	1,701.6	0.6	3.40	1	1	1
12/27/2022 09:00	1.1	12.9	1,972.8	0.8	5.90	1	1	1
12/27/2022 10:00	1.3	12.9	1,967.9	1.0	7.90	1	1	1
12/27/2022 11:00	1.4	12.9	1,970.4	1.0	7.90	1	1	1
12/27/2022 12:00	1.5	12.9	1,969.6	1.1	7.90	1	1	1
12/27/2022 13:00	1.5	12.9	1,969.2	1.1	7.90	1	1	1
12/27/2022 14:00	1.5	12.9	1,970.6	1.1	7.90	1	1	1
12/27/2022 15:00	1.5	12.9	1,970.8	1.1	7.90	1	1	1
12/27/2022 16:00	1.5	13.0	1,970.5	1.1	7.90	1	1	1
12/27/2022 17:00	1.4	13.0	1,962.5	1.0	7.90	1	1	1
12/27/2022 18:00	1.4	13.1	1,960.1	1.1	7.80	1	1	1
12/27/2022 19:00	1.3	13.1	1,959.5	1.0	7.80	1	1	1
12/27/2022 20:00	1.4	13.1	1,971.6	1.1	7.90	1	1	1
12/27/2022 21:00	1.4	13.1	1,972.6	1.1	7.90	1	1	1
12/27/2022 22:00	1.1	13.2	1,945.8	0.8	5.80	1	1	1
12/27/2022 23:00	0.5	14.0	1,392.3	0.4	2.80	1	1	0
Average/Sum#:	1.3	13.6	1,716.3	1.2	152.64 #	23 #	21 #	15 #
Minimum:	0.1	12.9	198.2	0.3	0.04	0	0	0
Maximum:	7.2	18.8	1,972.8	8.7	24.20	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.6	13.9	1,539.7	0.5	3.10	1	1	0
12/28/2022 01:00	0.5	13.9	1,465.2	0.4	2.90	1	1	0
12/28/2022 02:00	0.6	13.9	1,520.9	0.5	3.00	1	1	0
12/28/2022 03:00	0.5	13.9	1,518.1	0.4	3.00	1	1	0
12/28/2022 04:00	0.5	13.9	1,528.2	0.4	3.10	1	1	0
12/28/2022 05:00	0.6	13.8	1,718.9	0.5	3.40	1	1	0
12/28/2022 06:00	0.6	13.8	1,735.9	0.5	3.50	1	1	0
12/28/2022 07:00	0.6	13.8	1,738.4	0.5	3.50	1	1	0
12/28/2022 08:00	0.6	13.8	1,716.3	0.5	3.40	1	1	0
12/28/2022 09:00	0.6	13.8	1,707.8	0.5	3.40	1	1	0
12/28/2022 10:00	0.5	13.9	1,547.7	0.4	3.10	1	1	0
12/28/2022 11:00	0.5	13.9	1,563.0	0.4	3.10	1	1	0
12/28/2022 12:00	0.6	13.9	1,545.4	0.5	3.10	1	1	0
12/28/2022 13:00	0.5	13.9	1,525.3	0.4	3.10	1	1	0
12/28/2022 14:00	0.6	13.9	1,549.1	0.5	3.10	1	1	0
12/28/2022 15:00	0.6	13.9	1,592.4	0.5	3.20	1	1	1
12/28/2022 16:00	1.4	12.6	2,095.4	1.0	8.40	1	1	1
12/28/2022 17:00	1.2	13.1	1,976.0	0.9	5.90	1	1	1
12/28/2022 18:00	1.1	13.2	1,956.1	0.8	5.90	1	1	1
12/28/2022 19:00	1.1	13.2	1,957.5	0.8	5.90	1	1	1
12/28/2022 20:00	1.1	13.2	1,959.0	0.8	5.90	1	1	1
12/28/2022 21:00	1.2	13.1	1,970.4	0.9	5.90	1	1	1
12/28/2022 22:00	1.1	13.2	1,956.0	0.8	5.90	1	1	1
12/28/2022 23:00	1.1	13.2	1,960.9	0.8	5.90	1	1	1
Average/Sum#:	0.8	13.6	1,722.7	0.6	100.70 #	24 #	24 #	9 #
Minimum:	0.5	12.6	1,465.2	0.4	2.90	1	1	0
Maximum:	1.4	13.9	2,095.4	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	1.1	13.2	1,956.9	0.8	5.90	1	1	1
12/29/2022 01:00	1.1	13.2	1,961.0	0.8	5.90	1	1	1
12/29/2022 02:00	1.1	13.2	1,965.0	0.8	5.90	1	1	1
12/29/2022 03:00	1.1	13.2	1,964.8	0.8	5.90	1	1	1
12/29/2022 04:00	1.1	13.2	1,969.1	0.8	5.90	1	1	1
12/29/2022 05:00	1.3	12.9	2,038.0	1.0	8.20	1	1	1
12/29/2022 06:00	1.5	12.6	2,047.5	1.1	8.20	1	1	1
12/29/2022 07:00	1.3	12.8	2,051.3	0.9	6.20	1	1	1
12/29/2022 08:00	1.6	12.2	2,206.4	1.1	8.80	1	1	1
12/29/2022 09:00	1.7	11.9	2,259.5	1.1	9.00	1	1	1
12/29/2022 10:00	1.6	12.4	2,161.9	1.1	8.60	1	1	1
12/29/2022 11:00	1.3	12.9	2,024.3	1.0	8.10	1	1	1
12/29/2022 12:00	1.2	13.1	1,986.2	0.9	6.00	1	1	1
12/29/2022 13:00	1.1	13.2	1,975.5	0.8	5.90	1	1	1
12/29/2022 14:00	1.2	13.1	1,985.1	0.9	6.00	1	1	1
12/29/2022 15:00	1.2	13.1	1,989.5	0.9	6.00	1	1	1
12/29/2022 16:00	1.4	12.7	2,100.3	1.0	8.40	1	1	1
12/29/2022 17:00	1.6	12.3	2,176.8	1.1	8.70	1	1	1
12/29/2022 18:00	1.4	12.6	2,085.5	1.0	8.30	1	1	1
12/29/2022 19:00	1.1	13.2	1,968.4	0.8	5.90	1	1	1
12/29/2022 20:00	1.1	13.2	1,977.8	0.8	5.90	1	1	1
12/29/2022 21:00	1.1	13.1	1,989.3	0.8	6.00	1	1	1
12/29/2022 22:00	1.1	13.1	1,972.1	0.8	5.90	1	1	1
12/29/2022 23:00	1.0	13.1	1,943.3	0.8	5.80	1	1	1
Average/Sum#:	1.3	12.9	2,031.5	0.9	165.40 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,943.3	0.8	5.80	1	1	1
Maximum:	1.7	13.2	2,259.5	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	5.0	15.9	561.7	5.9	2.85	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.0	15.9	561.7	5.9	2.85 #	1 #	0 #	0 #
Minimum:	5.0	15.9	561.7	5.9	2.85	0	0	0
Maximum:	5.0	15.9	561.7	5.9	2.85	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.8	11.9	2,165.1	0.6	2.5	1	1	1
10/01/2022 01:00	12.5	14.1	1,211.1	0.0	14.1	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.7	13.0	1,688.1	0.6	16.6 #	2 #	9 #	2 #
Minimum:	0.8	11.9	1,211.1	0.6	2.5	0	0	0
Maximum:	12.5	14.1	2,165.1	0.6	14.1	1	1	1
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	10 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/03/2022 02:00	60.6	17.5	336.0	0.0	64.9	1	1	0
10/03/2022 03:00	24.8	15.5	867.5	0.0	52.6	1	1	0
10/03/2022 04:00	0.4	13.8	1,711.7	0.0	1.3	1	1	0
10/03/2022 05:00	0.4	13.8	1,704.2	0.0	1.3	1	1	0
10/03/2022 06:00	0.4	13.8	1,701.6	0.3	1.3	1	1	0
10/03/2022 07:00	0.4	13.8	1,708.6	0.3	1.3	1	1	0
10/03/2022 08:00	0.3	13.8	1,718.8	0.3	1.0	1	1	0
10/03/2022 09:00	0.3	13.8	1,725.0	0.2	1.0	1	1	0
10/03/2022 10:00	0.5	13.9	1,728.2	0.3	1.6	1	1	0
10/03/2022 11:00	0.5	13.9	1,728.3	0.3	1.6	1	1	0
10/03/2022 12:00	0.5	13.9	1,728.4	0.4	1.6	1	1	0
10/03/2022 13:00	0.5	13.9	1,730.3	0.4	1.6	1	1	0
10/03/2022 14:00	0.5	13.9	1,724.6	0.4	1.6	1	1	0
10/03/2022 15:00	0.5	13.6	1,766.0	0.4	1.6	1	1	1
10/03/2022 16:00	1.2	12.3	2,061.1	0.5	3.8	1	1	1
10/03/2022 17:00	1.1	11.8	2,172.2	0.6	3.5	1	1	1
10/03/2022 18:00	1.0	11.6	2,206.8	0.7	3.1	1	1	1
10/03/2022 19:00	1.0	11.8	2,173.9	0.6	3.2	1	1	1
10/03/2022 20:00	1.0	11.7	2,187.2	0.6	3.1	1	1	1
10/03/2022 21:00	1.0	11.8	2,174.5	0.6	3.2	1	1	1
10/03/2022 22:00	1.0	12.0	2,152.4	0.6	3.2	1	1	1
10/03/2022 23:00	1.0	11.9	2,171.8	0.7	3.2	1	1	1
Average/Sum#:	4.5	13.4	1,780.9	0.5	160.6 #	22 #	24 #	9 #
Minimum:	0.3	11.6	336.0	0.2	1.0	0	1	0
Maximum:	60.6	17.5	2,206.8	0.7	64.9	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	1.0	12.0	2,154.5	0.7	3.2	1	1	1
10/04/2022 01:00	1.0	12.0	2,158.5	0.7	3.2	1	1	1
10/04/2022 02:00	1.0	12.0	2,156.3	0.7	3.2	1	1	1
10/04/2022 03:00	1.0	12.0	2,166.2	0.7	3.2	1	1	1
10/04/2022 04:00	1.0	12.0	2,173.6	0.7	3.2	1	1	1
10/04/2022 05:00	0.9	11.8	2,201.6	0.7	2.9	1	1	1
10/04/2022 06:00	0.9	12.0	2,166.7	0.6	2.9	1	1	1
10/04/2022 07:00	0.9	12.6	2,035.8	0.6	2.9	1	1	1
10/04/2022 08:00	0.4	13.7	1,595.1	0.5	1.2	1	1	0
10/04/2022 09:00	0.5	13.8	1,547.9	0.4	1.4	1	1	0
10/04/2022 10:00	0.6	13.7	1,555.2	0.4	1.7	1	1	0
10/04/2022 11:00	0.6	13.7	1,564.0	0.5	1.7	1	1	0
10/04/2022 12:00	0.5	13.7	1,722.8	0.5	1.6	1	1	0
10/04/2022 13:00	0.5	13.8	1,747.1	0.4	1.6	1	1	1
10/04/2022 14:00	1.3	12.8	2,032.9	0.6	4.3	1	1	1
10/04/2022 15:00	1.1	12.0	2,150.2	0.7	3.5	1	1	1
10/04/2022 16:00	1.0	12.1	2,131.5	0.8	3.2	1	1	1
10/04/2022 17:00	1.0	12.0	2,143.7	0.7	3.2	1	1	1
10/04/2022 18:00	1.0	11.9	2,169.2	0.7	3.2	1	1	1
10/04/2022 19:00	1.0	11.9	2,185.2	0.7	3.2	1	1	1
10/04/2022 20:00	0.9	11.6	2,243.7	0.7	2.9	1	1	1
10/04/2022 21:00	0.9	11.9	2,190.4	0.6	2.9	1	1	1
10/04/2022 22:00	0.9	11.9	2,177.9	0.6	2.9	1	1	1
10/04/2022 23:00	1.0	12.2	2,144.8	0.6	3.3	1	1	1
Average/Sum#:	0.9	12.5	2,021.5	0.6	66.5 #	24 #	24 #	19 #
Minimum:	0.4	11.6	1,547.9	0.4	1.2	1	1	0
Maximum:	1.3	13.8	2,243.7	0.8	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.0	12.2	2,136.7	0.7	3.2	1	1	1
10/05/2022 01:00	1.0	12.8	1,998.7	0.7	3.3	1	1	1
10/05/2022 02:00	1.1	13.0	1,971.1	0.7	3.6	1	1	1
10/05/2022 03:00	1.1	12.5	2,085.4	0.8	3.6	1	1	1
10/05/2022 04:00	1.1	12.3	2,111.1	0.8	3.6	1	1	1
10/05/2022 05:00	1.0	11.9	2,200.3	0.8	3.2	1	1	1
10/05/2022 06:00	0.9	11.9	2,201.4	0.7	2.9	1	1	1
10/05/2022 07:00	1.1	12.9	1,985.2	0.7	3.6	1	1	1
10/05/2022 08:00	0.4	13.9	1,718.1	0.6	1.3	1	1	0
10/05/2022 09:00	0.4	13.9	1,682.9	0.5	1.3	1	1	0
10/05/2022 10:00	0.5	13.9	1,710.7	0.3	1.6	1	1	0
10/05/2022 11:00	0.5	13.9	1,722.4	0.4	1.6	1	1	0
10/05/2022 12:00	0.7	13.8	1,738.9	0.5	2.3	1	1	1
10/05/2022 13:00	1.3	12.4	2,080.5	0.6	4.2	1	1	1
10/05/2022 14:00	1.1	11.8	2,190.4	0.7	3.5	1	1	1
10/05/2022 15:00	1.1	12.1	2,137.1	0.8	3.5	1	1	1
10/05/2022 16:00	1.0	11.9	2,159.1	0.7	3.2	1	1	1
10/05/2022 17:00	0.9	11.7	2,198.2	0.7	2.8	1	1	1
10/05/2022 18:00	0.9	11.6	2,230.9	0.6	2.9	1	1	1
10/05/2022 19:00	0.9	11.6	2,240.8	0.6	2.9	1	1	1
10/05/2022 20:00	0.9	11.9	2,190.7	0.6	2.9	1	1	1
10/05/2022 21:00	0.9	11.6	2,237.8	0.6	2.9	1	1	1
10/05/2022 22:00	1.0	12.0	2,166.4	0.6	3.2	1	1	1
10/05/2022 23:00	1.0	12.0	2,176.0	0.7	3.2	1	1	1
Average/Sum#:	0.9	12.5	2,053.0	0.6	70.3 #	24 #	24 #	20 #
Minimum:	0.4	11.6	1,682.9	0.3	1.3	1	1	0
Maximum:	1.3	13.9	2,240.8	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.0	12.1	2,165.7	0.7	3.3	1	1	1
10/06/2022 01:00	1.0	12.1	2,167.7	0.7	3.3	1	1	1
10/06/2022 02:00	1.0	12.1	2,165.0	0.7	3.2	1	1	1
10/06/2022 03:00	1.0	12.2	2,141.6	0.7	3.3	1	1	1
10/06/2022 04:00	0.8	12.0	2,181.3	0.6	2.6	1	1	1
10/06/2022 05:00	0.9	11.6	2,250.8	0.6	2.9	1	1	1
10/06/2022 06:00	0.8	11.8	2,238.5	0.5	2.6	1	1	1
10/06/2022 07:00	1.0	12.2	2,135.9	0.6	3.2	1	1	1
10/06/2022 08:00	1.0	12.4	2,082.9	0.6	3.2	1	1	1
10/06/2022 09:00	1.0	12.5	2,071.3	0.7	3.3	1	1	1
10/06/2022 10:00	1.0	12.5	2,082.0	0.7	3.3	1	1	1
10/06/2022 11:00	1.0	12.3	2,114.5	0.7	3.2	1	1	1
10/06/2022 12:00	1.0	12.1	2,136.7	0.7	3.2	1	1	1
10/06/2022 13:00	0.9	11.8	2,192.4	0.7	2.9	1	1	1
10/06/2022 14:00	0.9	11.8	2,197.6	0.6	2.9	1	1	1
10/06/2022 15:00	0.9	12.0	2,150.8	0.6	2.9	1	1	1
10/06/2022 16:00	0.9	11.8	2,191.5	0.6	2.9	1	1	1
10/06/2022 17:00	0.8	11.6	2,240.1	0.6	2.5	1	1	1
10/06/2022 18:00	0.8	11.7	2,239.0	0.5	2.6	1	1	1
10/06/2022 19:00	0.8	11.6	2,255.1	0.5	2.6	1	1	1
10/06/2022 20:00	0.8	11.6	2,259.5	0.5	2.6	1	1	1
10/06/2022 21:00	0.8	11.7	2,245.4	0.5	2.6	1	1	1
10/06/2022 22:00	0.9	12.0	2,190.1	0.5	2.9	1	1	1
10/06/2022 23:00	1.0	12.1	2,168.8	0.6	3.3	1	1	1
Average/Sum#:	0.9	12.0	2,177.7	0.6	71.3 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,071.3	0.5	2.5	1	1	1
Maximum:	1.0	12.5	2,259.5	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.0	12.2	2,143.9	0.7	3.3	1	1	1
10/07/2022 01:00	1.0	12.2	2,159.9	0.7	3.3	1	1	1
10/07/2022 02:00	1.0	12.2	2,141.6	0.7	3.3	1	1	1
10/07/2022 03:00	1.0	12.3	2,114.7	0.7	3.2	1	1	1
10/07/2022 04:00	1.0	12.2	2,155.6	0.7	3.3	1	1	1
10/07/2022 05:00	1.0	12.0	2,191.6	0.7	3.3	1	1	1
10/07/2022 06:00	0.9	12.0	2,204.6	0.7	2.9	1	1	1
10/07/2022 07:00	1.0	12.4	2,110.8	0.7	3.3	1	1	1
10/07/2022 08:00	1.0	12.7	2,030.0	0.7	3.3	1	1	1
10/07/2022 09:00	1.0	12.3	2,127.6	0.7	3.3	1	1	1
10/07/2022 10:00	1.0	12.3	2,127.5	0.7	3.3	1	1	1
10/07/2022 11:00	1.0	12.3	2,111.0	0.7	3.2	1	1	1
10/07/2022 12:00	1.0	12.0	2,168.6	0.7	3.2	1	1	1
10/07/2022 13:00	1.0	12.1	2,136.9	0.7	3.2	1	1	1
10/07/2022 14:00	0.9	11.9	2,182.3	0.7	2.9	1	1	1
10/07/2022 15:00	0.9	11.8	2,193.0	0.6	2.9	1	1	1
10/07/2022 16:00	0.9	11.9	2,179.2	0.6	2.9	1	1	1
10/07/2022 17:00	0.9	11.6	2,229.9	0.6	2.9	1	1	1
10/07/2022 18:00	0.8	11.6	2,243.3	0.6	2.5	1	1	1
10/07/2022 19:00	0.8	11.6	2,258.3	0.5	2.6	1	1	1
10/07/2022 20:00	0.8	11.6	2,262.5	0.5	2.6	1	1	1
10/07/2022 21:00	0.8	11.6	2,265.6	0.5	2.6	1	1	1
10/07/2022 22:00	0.8	11.7	2,257.3	0.5	2.6	1	1	1
10/07/2022 23:00	0.9	12.0	2,184.9	0.5	2.9	1	1	1
Average/Sum#:	0.9	12.0	2,174.2	0.6	72.8 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,030.0	0.5	2.5	1	1	1
Maximum:	1.0	12.7	2,265.6	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.0	12.1	2,173.3	0.6	3.3	1	1	1
10/08/2022 01:00	1.0	12.1	2,176.2	0.7	3.3	1	1	1
10/08/2022 02:00	1.0	12.1	2,167.4	0.7	3.3	1	1	1
10/08/2022 03:00	1.0	12.1	2,178.3	0.7	3.3	1	1	1
10/08/2022 04:00	1.0	12.0	2,176.1	0.7	3.2	1	1	1
10/08/2022 05:00	1.0	12.1	2,170.4	0.7	3.3	1	1	1
10/08/2022 06:00	1.0	12.3	2,110.4	0.7	3.2	1	1	1
10/08/2022 07:00	0.5	13.8	1,711.8	0.6	1.6	1	1	1
10/08/2022 08:00	0.6	13.9	1,365.6	0.5	1.5	1	1	0
10/08/2022 09:00	0.4	13.9	1,315.8	0.4	1.0	1	1	0
10/08/2022 10:00	0.4	14.0	1,312.6	0.4	1.0	1	1	0
10/08/2022 11:00	0.4	14.0	1,318.8	0.3	1.0	1	1	0
10/08/2022 12:00	0.5	13.8	1,569.8	0.3	1.5	1	1	0
10/08/2022 13:00	0.5	13.8	1,728.0	0.4	1.6	1	1	0
10/08/2022 14:00	0.5	13.7	1,745.1	0.4	1.6	1	1	1
10/08/2022 15:00	1.1	12.2	2,069.6	0.5	3.5	1	1	1
10/08/2022 16:00	1.0	11.7	2,201.9	0.6	3.2	1	1	1
10/08/2022 17:00	0.9	11.7	2,201.4	0.6	2.8	1	1	1
10/08/2022 18:00	1.0	11.9	2,167.0	0.6	3.2	1	1	1
10/08/2022 19:00	1.0	11.9	2,177.6	0.7	3.2	1	1	1
10/08/2022 20:00	1.0	11.9	2,180.4	0.7	3.2	1	1	1
10/08/2022 21:00	1.0	11.9	2,177.9	0.7	3.2	1	1	1
10/08/2022 22:00	1.0	12.0	2,173.3	0.7	3.2	1	1	1
10/08/2022 23:00	1.0	12.1	2,170.3	0.7	3.3	1	1	1
Average/Sum#:	0.8	12.6	1,947.5	0.6	62.5 #	24 #	24 #	18 #
Minimum:	0.4	11.7	1,312.6	0.3	1.0	1	1	0
Maximum:	1.1	14.0	2,201.9	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.0	12.0	2,166.8	0.7	3.2	1	1	1
10/09/2022 01:00	1.0	12.1	2,167.0	0.7	3.3	1	1	1
10/09/2022 02:00	1.0	12.2	2,138.4	0.7	3.2	1	1	1
10/09/2022 03:00	1.1	12.2	2,147.8	0.7	3.6	1	1	1
10/09/2022 04:00	1.0	12.1	2,158.6	0.7	3.2	1	1	1
10/09/2022 05:00	1.0	12.1	2,149.2	0.7	3.2	1	1	1
10/09/2022 06:00	6.4	13.0	1,685.1	0.0	18.0	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	14.0	18.7	209.6	0.0	3.9	1	0	0
10/09/2022 11:00	34.6	15.6	799.9	0.0	69.0	1	0	0
10/09/2022 12:00	0.4	13.9	1,387.0	0.0	1.0	1	0	0
10/09/2022 13:00	0.4	14.0	1,390.9	0.0	1.1	1	0	0
10/09/2022 14:00	0.5	13.7	1,726.4	0.3	1.6	1	0	0
10/09/2022 15:00	0.5	13.8	1,562.3	0.4	1.5	1	0	0
10/09/2022 16:00	0.5	13.8	1,729.7	0.4	1.6	1	1	0
10/09/2022 17:00	0.5	13.6	1,781.5	0.4	1.6	1	1	1
10/09/2022 18:00	1.3	12.3	2,081.7	0.6	4.2	1	1	1
10/09/2022 19:00	1.0	11.7	2,209.0	0.6	3.2	1	1	1
10/09/2022 20:00	1.0	11.8	2,188.3	0.7	3.2	1	1	1
10/09/2022 21:00	1.0	11.9	2,174.8	0.6	3.2	1	1	1
10/09/2022 22:00	1.0	12.0	2,156.1	0.7	3.2	1	1	1
10/09/2022 23:00	1.0	12.1	2,147.1	0.7	3.2	1	1	1
Average/Sum#:	3.3	13.1	1,817.0	0.6	139.2 #	21 #	14 #	14 #
Minimum:	0.4	11.7	209.6	0.3	1.0	0	0	0
Maximum:	34.6	18.7	2,209.0	0.7	69.0	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.0	12.2	2,121.9	0.7	3.2	1	1	1
10/10/2022 01:00	1.0	12.4	2,092.6	0.7	3.3	1	1	1
10/10/2022 02:00	1.2	12.9	1,980.8	0.8	3.9	1	1	1
10/10/2022 03:00	1.1	12.4	2,083.6	0.8	3.6	1	1	1
10/10/2022 04:00	1.0	12.3	2,127.1	0.8	3.3	1	1	1
10/10/2022 05:00	0.9	11.8	2,214.2	0.7	2.9	1	1	1
10/10/2022 06:00	0.9	11.9	2,205.4	0.6	2.9	1	1	1
10/10/2022 07:00	0.7	13.3	1,816.6	0.6	2.2	1	1	1
10/10/2022 08:00	0.6	13.8	1,551.8	0.5	1.7	1	1	0
10/10/2022 09:00	0.4	13.9	1,545.1	0.4	1.2	1	1	0
10/10/2022 10:00	0.4	14.0	1,390.8	0.4	1.1	1	1	0
10/10/2022 11:00	0.4	13.9	1,560.6	0.3	1.2	1	1	0
10/10/2022 12:00	0.4	13.9	1,574.2	0.3	1.2	1	1	0
10/10/2022 13:00	0.4	13.8	1,729.9	0.3	1.3	1	1	0
10/10/2022 14:00	0.5	13.8	1,718.4	0.3	1.6	1	1	0
10/10/2022 15:00	0.5	13.8	1,602.6	0.4	1.5	1	1	0
10/10/2022 16:00	1.2	12.6	1,973.3	0.6	3.8	1	1	1
10/10/2022 17:00	1.1	11.9	2,163.0	0.7	3.5	1	1	1
10/10/2022 18:00	1.0	11.7	2,198.7	0.7	3.2	1	1	1
10/10/2022 19:00	1.1	11.8	2,169.1	0.7	3.5	1	1	1
10/10/2022 20:00	1.1	11.9	2,160.6	0.7	3.5	1	1	1
10/10/2022 21:00	1.2	12.2	2,102.8	0.7	3.8	1	1	1
10/10/2022 22:00	1.2	12.4	2,085.4	0.8	3.9	1	1	1
10/10/2022 23:00	1.2	12.9	1,953.3	0.8	3.9	1	1	1
Average/Sum#:	0.9	12.8	1,921.7	0.6	65.2 #	24 #	24 #	16 #
Minimum:	0.4	11.7	1,390.8	0.3	1.1	1	1	0
Maximum:	1.2	14.0	2,214.2	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.7	13.9	1,376.2	0.8	1.8	1	1	0
10/11/2022 01:00	0.5	13.9	1,300.5	0.6	1.2	1	1	0
10/11/2022 02:00	0.5	13.9	1,300.2	0.5	1.2	1	1	0
10/11/2022 03:00	0.6	13.9	1,352.3	0.4	1.5	1	1	0
10/11/2022 04:00	0.5	13.9	1,495.7	0.4	1.4	1	1	0
10/11/2022 05:00	0.7	13.9	1,319.9	0.5	1.7	1	1	0
10/11/2022 06:00	0.8	13.9	1,313.8	0.6	2.0	1	1	0
10/11/2022 07:00	0.7	13.9	1,315.9	0.6	1.7	1	1	0
10/11/2022 08:00	0.6	13.9	1,317.2	0.6	1.5	1	1	0
10/11/2022 09:00	0.5	13.9	1,480.0	0.5	1.4	1	1	0
10/11/2022 10:00	0.5	13.9	1,548.1	0.4	1.5	1	1	0
10/11/2022 11:00	0.4	13.8	1,635.9	0.4	1.2	1	1	0
10/11/2022 12:00	0.5	13.6	1,802.5	0.4	1.6	1	1	0
10/11/2022 13:00	0.5	13.6	1,793.7	0.4	1.6	1	1	0
10/11/2022 14:00	0.5	13.6	1,789.9	0.4	1.6	1	1	0
10/11/2022 15:00	0.5	13.6	1,787.5	0.4	1.6	1	1	0
10/11/2022 16:00	0.5	13.6	1,788.3	0.4	1.6	1	1	0
10/11/2022 17:00	0.5	13.6	1,789.6	0.4	1.6	1	1	0
10/11/2022 18:00	0.5	13.6	1,794.2	0.4	1.6	1	1	1
10/11/2022 19:00	1.2	12.6	2,005.4	0.6	3.8	1	1	1
10/11/2022 20:00	1.1	12.1	2,131.3	0.7	3.5	1	1	1
10/11/2022 21:00	1.0	12.4	2,034.7	0.8	3.2	1	1	1
10/11/2022 22:00	1.0	12.2	2,102.6	0.7	3.2	1	1	1
10/11/2022 23:00	0.9	12.8	1,971.1	0.7	2.9	1	1	1
Average/Sum#:	0.7	13.5	1,647.8	0.5	45.9 #	24 #	24 #	6 #
Minimum:	0.4	12.1	1,300.2	0.4	1.2	1	1	0
Maximum:	1.2	13.9	2,131.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	1.1	13.0	1,958.1	0.7	3.6	1	1	1
10/12/2022 01:00	1.1	13.0	1,935.0	0.8	3.6	1	1	1
10/12/2022 02:00	0.6	13.8	1,519.8	0.7	1.7	1	1	0
10/12/2022 03:00	0.5	13.9	1,637.4	0.6	1.5	1	1	0
10/12/2022 04:00	0.5	13.7	1,768.9	0.4	1.6	1	1	0
10/12/2022 05:00	1.2	12.0	2,131.1	0.5	3.8	1	1	1
10/12/2022 06:00	1.0	11.7	2,260.0	0.6	3.2	1	1	1
10/12/2022 07:00	0.9	11.7	2,255.1	0.7	2.9	1	1	1
10/12/2022 08:00	0.9	11.7	2,247.7	0.6	2.9	1	1	1
10/12/2022 09:00	0.9	11.7	2,246.9	0.6	2.9	1	1	1
10/12/2022 10:00	0.9	11.7	2,242.0	0.6	2.9	1	1	1
10/12/2022 11:00	0.9	11.7	2,245.9	0.6	2.9	1	1	1
10/12/2022 12:00	0.8	11.6	2,250.7	0.6	2.6	1	1	1
10/12/2022 13:00	0.8	11.6	2,248.0	0.5	2.6	1	1	1
10/12/2022 14:00	0.9	11.6	2,249.4	0.5	2.9	1	1	1
10/12/2022 15:00	0.9	11.6	2,250.4	0.6	2.9	1	1	1
10/12/2022 16:00	0.9	11.4	2,266.7	0.6	2.8	1	1	1
10/12/2022 17:00	0.9	11.4	2,274.9	0.6	2.8	1	1	1
10/12/2022 18:00	0.9	11.6	2,233.1	0.6	2.9	1	1	1
10/12/2022 19:00	1.1	12.1	2,138.2	0.6	3.5	1	1	1
10/12/2022 20:00	1.1	12.0	2,147.6	0.7	3.5	1	1	1
10/12/2022 21:00	1.1	12.2	2,119.1	0.7	3.5	1	1	1
10/12/2022 22:00	1.2	12.4	2,086.8	0.7	3.9	1	1	1
10/12/2022 23:00	1.3	12.9	1,967.8	0.8	4.2	1	1	1
Average/Sum#:	0.9	12.2	2,111.7	0.6	71.6 #	24 #	24 #	21 #
Minimum:	0.5	11.4	1,519.8	0.4	1.5	1	1	0
Maximum:	1.3	13.9	2,274.9	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.4	12.9	1,961.3	0.9	4.5	1	1	1
10/13/2022 01:00	1.3	12.7	2,005.0	1.0	4.2	1	1	1
10/13/2022 02:00	1.5	13.0	1,953.3	1.0	4.9	1	1	1
10/13/2022 03:00	1.4	13.0	1,959.2	1.0	4.6	1	1	1
10/13/2022 04:00	1.3	13.0	1,926.0	1.0	4.2	1	1	1
10/13/2022 05:00	0.8	13.9	1,311.2	0.9	2.0	1	1	0
10/13/2022 06:00	0.8	13.9	1,311.4	0.8	2.0	1	1	0
10/13/2022 07:00	0.7	13.9	1,339.8	0.7	1.8	1	1	0
10/13/2022 08:00	0.5	13.8	1,587.0	0.6	1.5	1	1	0
10/13/2022 09:00	0.5	13.8	1,535.6	0.5	1.4	1	1	0
10/13/2022 10:00	0.5	13.6	1,804.0	0.4	1.6	1	1	0
10/13/2022 11:00	0.5	13.5	1,810.3	0.4	1.6	1	1	0
10/13/2022 12:00	0.5	13.6	1,808.3	0.4	1.6	1	1	0
10/13/2022 13:00	0.5	13.6	1,802.3	0.4	1.6	1	1	0
10/13/2022 14:00	0.5	13.6	1,793.3	0.4	1.6	1	1	0
10/13/2022 15:00	0.5	13.6	1,792.5	0.4	1.6	1	1	0
10/13/2022 16:00	0.5	13.6	1,790.7	0.4	1.6	1	1	0
10/13/2022 17:00	0.5	13.6	1,796.8	0.4	1.6	1	1	0
10/13/2022 18:00	0.5	13.5	1,804.3	0.4	1.6	1	1	0
10/13/2022 19:00	0.6	13.5	1,807.0	0.4	1.9	1	1	1
10/13/2022 20:00	1.3	12.4	2,059.6	0.6	4.2	1	1	1
10/13/2022 21:00	1.2	12.0	2,159.9	0.7	3.8	1	1	1
10/13/2022 22:00	1.1	12.4	2,083.7	0.8	3.6	1	1	1
10/13/2022 23:00	1.1	12.5	2,071.5	0.8	3.6	1	1	1
Average/Sum#:	0.8	13.3	1,803.1	0.6	62.6 #	24 #	24 #	10 #
Minimum:	0.5	12.0	1,311.2	0.4	1.4	1	1	0
Maximum:	1.5	13.9	2,159.9	1.0	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.0	12.6	2,061.0	0.8	3.3	1	1	1
10/14/2022 01:00	1.0	12.5	2,055.5	0.7	3.2	1	1	1
10/14/2022 02:00	1.0	12.5	2,056.0	0.7	3.2	1	1	1
10/14/2022 03:00	0.9	12.5	2,053.2	0.7	2.9	1	1	1
10/14/2022 04:00	0.9	12.3	2,098.1	0.6	2.9	1	1	1
10/14/2022 05:00	0.8	11.5	2,254.4	0.6	2.5	1	1	1
10/14/2022 06:00	0.7	11.5	2,261.5	0.5	2.2	1	1	1
10/14/2022 07:00	0.7	11.5	2,266.0	0.4	2.2	1	1	1
10/14/2022 08:00	0.9	12.5	2,033.0	0.5	2.9	1	1	1
10/14/2022 09:00	1.0	12.9	1,968.5	0.6	3.2	1	1	1
10/14/2022 10:00	1.0	12.7	1,978.5	0.7	3.2	1	1	1
10/14/2022 11:00	1.0	12.7	1,988.2	0.7	3.2	1	1	1
10/14/2022 12:00	1.0	12.7	1,992.9	0.7	3.2	1	1	1
10/14/2022 13:00	1.0	12.6	1,998.9	0.7	3.2	1	1	1
10/14/2022 14:00	1.0	12.2	2,104.1	0.7	3.2	1	1	1
10/14/2022 15:00	1.0	12.0	2,146.5	0.7	3.2	1	1	1
10/14/2022 16:00	0.9	12.0	2,145.1	0.7	2.9	1	1	1
10/14/2022 17:00	0.9	11.5	2,227.8	0.6	2.8	1	1	1
10/14/2022 18:00	1.0	11.9	2,153.4	0.6	3.2	1	1	1
10/14/2022 19:00	1.0	12.1	2,127.2	0.7	3.2	1	1	1
10/14/2022 20:00	1.0	12.0	2,134.2	0.7	3.2	1	1	1
10/14/2022 21:00	1.0	12.1	2,122.5	0.7	3.2	1	1	1
10/14/2022 22:00	1.0	12.3	2,095.3	0.7	3.2	1	1	1
10/14/2022 23:00	10.2	13.9	1,333.3	0.0	14.1	1	0	1
Average/Sum#:	1.3	12.3	2,069.0	0.7	83.5 #	24 #	23 #	24 #
Minimum:	0.7	11.5	1,333.3	0.4	2.2	1	0	1
Maximum:	10.2	13.9	2,266.0	0.8	14.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 23:00	97.7	17.8	305.8	0.0	63.7	1	1	0
Average/Sum#:	97.7	17.8	305.8	0.0	63.7 #	1 #	4 #	0 #
Minimum:	97.7	17.8	305.8	0.0	63.7	0	0	0
Maximum:	97.7	17.8	305.8	0.0	63.7	1	1	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	34.8	15.6	846.3	0.0	73.4	1	1	0
10/17/2022 01:00	0.5	13.8	1,704.0	0.0	1.6	1	1	0
10/17/2022 02:00	0.5	13.8	1,714.0	0.0	1.6	1	1	0
10/17/2022 03:00	0.5	13.7	1,810.2	0.4	1.7	1	1	1
10/17/2022 04:00	1.1	12.3	2,087.2	0.5	3.5	1	1	1
10/17/2022 05:00	1.0	11.9	2,182.2	0.6	3.2	1	1	1
10/17/2022 06:00	1.0	12.2	2,151.6	0.7	3.3	1	1	1
10/17/2022 07:00	1.0	12.4	2,100.6	0.7	3.3	1	1	1
10/17/2022 08:00	0.6	13.6	1,691.4	0.6	1.8	1	1	1
10/17/2022 09:00	0.4	13.8	1,644.4	0.5	1.2	1	1	0
10/17/2022 10:00	0.5	13.9	1,523.9	0.4	1.4	1	1	0
10/17/2022 11:00	0.4	13.8	1,608.2	0.3	1.2	1	1	0
10/17/2022 12:00	0.5	13.9	1,506.8	0.4	1.4	1	1	0
10/17/2022 13:00	0.5	13.9	1,513.1	0.4	1.4	1	1	0
10/17/2022 14:00	0.4	13.9	1,670.2	0.4	1.3	1	1	0
10/17/2022 15:00	0.5	13.7	1,713.7	0.4	1.6	1	1	1
10/17/2022 16:00	1.1	12.4	2,086.6	0.5	3.6	1	1	1
10/17/2022 17:00	0.9	11.6	2,242.9	0.6	2.9	1	1	1
10/17/2022 18:00	0.9	11.6	2,260.4	0.7	2.9	1	1	1
10/17/2022 19:00	0.9	11.7	2,236.0	0.6	2.9	1	1	1
10/17/2022 20:00	0.9	11.7	2,243.1	0.6	2.9	1	1	1
10/17/2022 21:00	0.9	11.6	2,256.3	0.6	2.9	1	1	1
10/17/2022 22:00	1.0	12.0	2,182.4	0.6	3.2	1	1	1
10/17/2022 23:00	1.0	12.0	2,180.6	0.7	3.2	1	1	1
Average/Sum#:	2.2	13.0	1,881.5	0.5	127.4 #	24 #	24 #	15 #
Minimum:	0.4	11.6	846.3	0.3	1.2	1	1	0
Maximum:	34.8	15.6	2,260.4	0.7	73.4	1	1	1
%SI	0.00	0.00	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.0	12.0	2,175.4	0.7	3.2	1	1	1
10/18/2022 01:00	0.9	12.1	2,166.0	0.7	2.9	1	1	1
10/18/2022 02:00	0.8	12.0	2,168.9	0.6	2.6	1	1	1
10/18/2022 03:00	0.8	11.9	2,193.4	0.5	2.6	1	1	1
10/18/2022 04:00	0.8	11.9	2,192.8	0.5	2.6	1	1	1
10/18/2022 05:00	0.8	12.0	2,173.8	0.5	2.6	1	1	1
10/18/2022 06:00	0.9	12.2	2,149.9	0.5	2.9	1	1	1
10/18/2022 07:00	0.9	12.1	2,148.0	0.6	2.9	1	1	1
10/18/2022 08:00	1.0	12.1	2,167.9	0.6	3.3	1	1	1
10/18/2022 09:00	1.0	12.1	2,165.6	0.7	3.3	1	1	1
10/18/2022 10:00	1.1	12.2	2,133.5	0.7	3.6	1	1	1
10/18/2022 11:00	1.1	12.3	2,107.8	0.7	3.6	1	1	1
10/18/2022 12:00	1.0	12.3	2,105.5	0.7	3.2	1	1	1
10/18/2022 13:00	1.1	12.3	2,109.2	0.8	3.6	1	1	1
10/18/2022 14:00	1.1	12.2	2,117.2	0.7	3.5	1	1	1
10/18/2022 15:00	1.1	12.1	2,149.3	0.7	3.5	1	1	1
10/18/2022 16:00	0.9	11.7	2,239.2	0.7	2.9	1	1	1
10/18/2022 17:00	1.0	11.9	2,202.8	0.7	3.2	1	1	1
10/18/2022 18:00	0.9	11.7	2,249.3	0.6	2.9	1	1	1
10/18/2022 19:00	0.9	11.6	2,271.7	0.6	2.9	1	1	1
10/18/2022 20:00	0.9	11.6	2,277.4	0.6	2.9	1	1	1
10/18/2022 21:00	0.9	11.6	2,277.9	0.6	2.9	1	1	1
10/18/2022 22:00	1.0	11.9	2,202.9	0.6	3.2	1	1	1
10/18/2022 23:00	1.0	11.9	2,201.6	0.7	3.2	1	1	1
Average/Sum#:	1.0	12.0	2,181.1	0.6	74.0 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,105.5	0.5	2.6	1	1	1
Maximum:	1.1	12.3	2,277.9	0.8	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	1.1	12.0	2,189.4	0.7	3.6	1	1	1
10/19/2022 01:00	1.0	12.4	2,117.8	0.7	3.3	1	1	1
10/19/2022 02:00	0.9	12.5	2,070.1	0.7	2.9	1	1	1
10/19/2022 03:00	0.8	12.3	2,105.5	0.6	2.6	1	1	1
10/19/2022 04:00	0.8	12.1	2,139.4	0.5	2.6	1	1	1
10/19/2022 05:00	0.7	11.7	2,201.4	0.5	2.2	1	1	1
10/19/2022 06:00	1.0	11.9	2,222.6	0.5	3.3	1	1	1
10/19/2022 07:00	1.1	12.2	2,151.9	0.6	3.6	1	1	1
10/19/2022 08:00	1.1	12.3	2,140.6	0.7	3.6	1	1	1
10/19/2022 09:00	1.1	12.4	2,101.5	0.8	3.6	1	1	1
10/19/2022 10:00	1.1	12.4	2,092.4	0.8	3.6	1	1	1
10/19/2022 11:00	1.1	12.2	2,121.8	0.8	3.5	1	1	1
10/19/2022 12:00	1.1	12.1	2,136.5	0.7	3.5	1	1	1
10/19/2022 13:00	1.0	12.0	2,154.1	0.7	3.2	1	1	1
10/19/2022 14:00	1.0	12.1	2,145.1	0.7	3.2	1	1	1
10/19/2022 15:00	1.0	11.8	2,185.0	0.7	3.2	1	1	1
10/19/2022 16:00	1.0	11.7	2,199.7	0.6	3.2	1	1	1
10/19/2022 17:00	1.1	12.1	2,124.9	0.6	3.5	1	1	1
10/19/2022 18:00	1.1	12.2	2,109.1	0.7	3.5	1	1	1
10/19/2022 19:00	1.1	12.2	2,115.7	0.7	3.5	1	1	1
10/19/2022 20:00	1.1	12.1	2,154.7	0.7	3.6	1	1	1
10/19/2022 21:00	1.1	12.3	2,120.2	0.7	3.6	1	1	1
10/19/2022 22:00	1.1	12.4	2,092.4	0.8	3.6	1	1	1
10/19/2022 23:00	1.1	12.3	2,111.2	0.8	3.6	1	1	1
Average/Sum#:	1.0	12.2	2,137.6	0.7	79.6 #	24 #	24 #	24 #
Minimum:	0.7	11.7	2,070.1	0.5	2.2	1	1	1
Maximum:	1.1	12.5	2,222.6	0.8	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.1	12.3	2,129.2	0.8	3.6	1	1	1
10/20/2022 01:00	1.1	12.4	2,089.4	0.8	3.6	1	1	1
10/20/2022 02:00	1.1	12.5	2,083.4	0.8	3.6	1	1	1
10/20/2022 03:00	1.2	12.4	2,093.7	0.8	3.9	1	1	1
10/20/2022 04:00	1.1	12.3	2,133.0	0.8	3.6	1	1	1
10/20/2022 05:00	0.9	11.8	2,202.7	0.7	2.9	1	1	1
10/20/2022 06:00	1.0	12.0	2,196.1	0.7	3.3	1	1	1
10/20/2022 07:00	1.1	12.6	2,066.6	0.7	3.6	1	1	1
10/20/2022 08:00	1.1	12.6	2,058.0	0.8	3.6	1	1	1
10/20/2022 09:00	1.1	12.5	2,072.7	0.8	3.6	1	1	1
10/20/2022 10:00	1.1	12.5	2,068.4	0.8	3.6	1	1	1
10/20/2022 11:00	1.1	12.4	2,087.7	0.8	3.6	1	1	1
10/20/2022 12:00	1.1	12.3	2,089.8	0.8	3.5	1	1	1
10/20/2022 13:00	1.1	12.3	2,104.8	0.8	3.6	1	1	1
10/20/2022 14:00	1.1	12.2	2,117.9	0.8	3.5	1	1	1
10/20/2022 15:00	1.0	12.1	2,149.5	0.7	3.2	1	1	1
10/20/2022 16:00	0.9	11.5	2,255.7	0.7	2.9	1	1	1
10/20/2022 17:00	1.0	11.8	2,184.0	0.6	3.2	1	1	1
10/20/2022 18:00	1.0	11.7	2,231.4	0.6	3.2	1	1	1
10/20/2022 19:00	1.1	12.2	2,115.3	0.6	3.5	1	1	1
10/20/2022 20:00	1.1	12.2	2,110.7	0.7	3.5	1	1	1
10/20/2022 21:00	1.1	12.4	2,086.7	0.7	3.6	1	1	1
10/20/2022 22:00	1.1	12.4	2,088.4	0.8	3.6	1	1	1
10/20/2022 23:00	1.0	12.2	2,125.0	0.8	3.2	1	1	1
Average/Sum#:	1.1	12.2	2,122.5	0.7	83.0 #	24 #	24 #	24 #
Minimum:	0.9	11.5	2,058.0	0.6	2.9	1	1	1
Maximum:	1.2	12.6	2,255.7	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	0.8	12.8	1,944.1	0.7	2.5	1	1	1
10/21/2022 01:00	0.4	13.9	1,583.3	0.5	1.2	1	1	0
10/21/2022 02:00	0.4	13.9	1,597.9	0.4	1.2	1	1	0
10/21/2022 03:00	0.5	13.9	1,547.4	0.3	1.5	1	1	0
10/21/2022 04:00	0.4	13.9	1,708.6	0.3	1.3	1	1	0
10/21/2022 05:00	0.5	13.9	1,710.6	0.4	1.6	1	1	0
10/21/2022 06:00	0.5	13.9	1,608.8	0.4	1.5	1	1	0
10/21/2022 07:00	0.5	13.9	1,676.8	0.4	1.6	1	1	0
10/21/2022 08:00	0.4	13.9	1,716.7	0.4	1.3	1	1	0
10/21/2022 09:00	0.4	13.9	1,720.8	0.3	1.3	1	1	0
10/21/2022 10:00	0.4	13.9	1,719.5	0.3	1.3	1	1	0
10/21/2022 11:00	0.4	13.9	1,683.4	0.3	1.3	1	1	0
10/21/2022 12:00	0.5	13.8	1,661.0	0.3	1.5	1	1	0
10/21/2022 13:00	0.5	13.8	1,633.6	0.4	1.5	1	1	0
10/21/2022 14:00	0.6	13.8	1,692.1	0.4	1.9	1	1	0
10/21/2022 15:00	0.7	13.8	1,568.6	0.5	2.0	1	1	1
10/21/2022 16:00	1.2	12.2	2,099.1	0.6	3.8	1	1	1
10/21/2022 17:00	1.1	11.8	2,183.0	0.7	3.5	1	1	1
10/21/2022 18:00	1.1	12.0	2,142.7	0.7	3.5	1	1	1
10/21/2022 19:00	1.2	12.3	2,098.0	0.7	3.9	1	1	1
10/21/2022 20:00	1.1	12.2	2,114.4	0.7	3.5	1	1	1
10/21/2022 21:00	1.1	11.9	2,175.3	0.7	3.5	1	1	1
10/21/2022 22:00	12.5	14.0	1,230.6	0.0	14.1	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.2	13.4	1,774.6	0.5	60.3 #	23 #	22 #	9 #
Minimum:	0.4	11.8	1,230.6	0.3	1.2	0	0	0
Maximum:	12.5	14.0	2,183.0	0.7	14.1	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 12:00	16.3	21.0	2.2	0.0	0.0	1	1	0
10/24/2022 13:00	51.2	17.0	429.7	0.0	74.5	1	1	0
10/24/2022 14:00	10.1	14.1	1,572.3	0.0	30.8	1	0	0
10/24/2022 15:00	0.4	13.7	1,771.7	0.0	1.3	1	0	0
10/24/2022 16:00	0.4	13.7	1,770.8	0.0	1.3	1	0	0
10/24/2022 17:00	0.4	13.7	1,779.7	0.3	1.3	1	0	0
10/24/2022 18:00	0.4	13.7	1,791.6	0.3	1.3	1	0	0
10/24/2022 19:00	0.4	13.7	1,799.7	0.3	1.3	1	0	0
10/24/2022 20:00	0.4	13.7	1,806.0	0.3	1.3	1	0	0
10/24/2022 21:00	0.4	13.7	1,813.9	0.3	1.3	1	0	0
10/24/2022 22:00	0.4	13.7	1,810.6	0.3	1.3	1	0	0
10/24/2022 23:00	0.4	13.7	1,822.7	0.3	1.3	1	0	0
Average/Sum#:	6.8	14.6	1,514.2	0.3	117.0 #	12 #	14 #	0 #
Minimum:	0.4	13.7	2.2	0.3	0.0	0	0	0
Maximum:	51.2	21.0	1,822.7	0.3	74.5	1	1	0
%SI	50.00	50.00	50.00	70.83	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.4	13.7	1,809.3	0.3	1.3	1	0	0
10/25/2022 01:00	0.4	13.7	1,804.8	0.3	1.3	1	0	0
10/25/2022 02:00	0.4	13.8	1,804.4	0.3	1.3	1	0	0
10/25/2022 03:00	0.4	13.8	1,802.4	0.3	1.3	1	0	0
10/25/2022 04:00	0.4	13.8	1,805.0	0.3	1.3	1	0	0
10/25/2022 05:00	0.4	13.8	1,808.1	0.3	1.3	1	0	0
10/25/2022 06:00	0.4	13.8	1,808.2	0.3	1.3	1	0	0
10/25/2022 07:00	0.4	13.8	1,807.7	0.3	1.3	1	0	0
10/25/2022 08:00	0.4	13.7	1,812.1	0.3	1.3	1	0	0
10/25/2022 09:00	0.4	13.7	1,815.9	0.3	1.3	1	0	0
10/25/2022 10:00	0.4	13.7	1,814.8	0.3	1.3	1	0	0
10/25/2022 11:00	0.5	13.7	1,829.7	0.3	1.7	1	0	0
10/25/2022 12:00	0.5	13.7	1,832.3	0.4	1.7	1	0	0
10/25/2022 13:00	0.5	13.6	1,836.6	0.4	1.7	1	0	0
10/25/2022 14:00	0.5	13.6	1,831.6	0.4	1.7	1	0	0
10/25/2022 15:00	0.5	13.6	1,832.4	0.4	1.7	1	0	0
10/25/2022 16:00	0.5	13.6	1,831.0	0.4	1.7	1	0	0
10/25/2022 17:00	0.5	13.6	1,834.2	0.4	1.7	1	0	0
10/25/2022 18:00	0.5	13.7	1,826.1	0.4	1.7	1	0	0
10/25/2022 19:00	0.5	13.7	1,814.8	0.4	1.7	1	0	0
10/25/2022 20:00	0.5	13.7	1,807.6	0.4	1.7	1	0	0
10/25/2022 21:00	0.5	13.7	1,809.8	0.4	1.7	1	0	0
10/25/2022 22:00	0.4	13.7	1,804.5	0.4	1.3	1	0	0
10/25/2022 23:00	0.4	13.9	1,635.5	0.3	1.2	1	0	0
Average/Sum#:	0.4	13.7	1,809.1	0.3	35.5 #	24 #	0 #	0 #
Minimum:	0.4	13.6	1,635.5	0.3	1.2	1	0	0
Maximum:	0.5	13.9	1,836.6	0.4	1.7	1	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	0.4	13.8	1,630.9	0.3	1.2	1	0	0
10/26/2022 01:00	0.4	13.9	1,631.9	0.3	1.2	1	0	0
10/26/2022 02:00	0.4	13.9	1,628.9	0.3	1.2	1	0	0
10/26/2022 03:00	0.4	13.9	1,616.4	0.3	1.2	1	0	0
10/26/2022 04:00	0.4	13.8	1,794.6	0.3	1.3	1	0	0
10/26/2022 05:00	0.4	13.9	1,733.8	0.3	1.3	1	0	0
10/26/2022 06:00	0.4	13.9	1,691.8	0.3	1.3	1	0	0
10/26/2022 07:00	0.4	13.8	1,742.7	0.3	1.3	1	0	0
10/26/2022 08:00	14.0	15.4	735.2	0.0	6.7	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	36.8	18.3	240.1	0.0	14.4	1	0	0
10/26/2022 17:00	30.7	17.6	391.6	0.0	25.5	1	0	0
10/26/2022 18:00	61.2	15.4	828.0	0.0	121.7	1	0	0
10/26/2022 19:00	0.5	13.7	1,825.1	0.0	1.7	1	0	0
10/26/2022 20:00	0.5	13.7	1,820.3	0.0	1.7	1	0	0
10/26/2022 21:00	0.5	13.7	1,810.2	0.4	1.7	1	0	0
10/26/2022 22:00	0.5	13.7	1,764.5	0.4	1.6	1	0	0
10/26/2022 23:00	6.0	14.5	1,164.0	0.0	12.5	1	0	0
Average/Sum#:	9.1	14.5	1,414.7	0.3	197.5 #	17 #	0 #	0 #
Minimum:	0.4	13.7	240.1	0.3	1.2	0	0	0
Maximum:	61.2	18.3	1,825.1	0.4	121.7	1	0	0
%SI	29.17	29.17	29.17	58.33	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/31/2022 01:00	64.0	17.7	299.3	0.0	76.7	1	1	0
10/31/2022 02:00	38.7	16.0	725.0	0.0	75.6	1	1	0
10/31/2022 03:00	0.5	13.8	1,712.6	0.0	1.6	1	1	0
10/31/2022 04:00	0.5	13.8	1,726.3	0.0	1.6	1	1	0
10/31/2022 05:00	0.5	13.8	1,711.3	0.4	1.6	1	1	0
10/31/2022 06:00	0.5	13.8	1,692.8	0.4	1.6	1	1	0
10/31/2022 07:00	0.5	13.8	1,693.6	0.4	1.6	1	1	0
10/31/2022 08:00	0.5	13.8	1,704.5	0.4	1.6	1	1	0
10/31/2022 09:00	0.5	13.9	1,706.8	0.4	1.6	1	1	0
10/31/2022 10:00	0.5	13.9	1,708.4	0.4	1.6	1	1	0
10/31/2022 11:00	0.5	13.9	1,689.0	0.4	1.6	1	1	0
10/31/2022 12:00	0.4	13.9	1,687.9	0.4	1.3	1	1	0
10/31/2022 13:00	0.4	13.9	1,702.8	0.3	1.3	1	1	0
10/31/2022 14:00	0.6	13.7	1,767.7	0.4	1.9	1	1	1
10/31/2022 15:00	1.3	12.5	2,082.4	0.6	4.3	1	1	1
10/31/2022 16:00	1.2	12.3	2,105.6	0.7	3.9	1	1	1
10/31/2022 17:00	1.2	12.4	2,076.3	0.8	3.9	1	1	1
10/31/2022 18:00	1.2	12.4	2,082.4	0.8	3.9	1	1	1
10/31/2022 19:00	1.2	12.4	2,103.6	0.8	3.9	1	1	1
10/31/2022 20:00	1.1	12.4	2,089.0	0.8	3.6	1	1	1
10/31/2022 21:00	1.0	12.2	2,130.3	0.8	3.2	1	1	1
10/31/2022 22:00	1.0	12.3	2,096.7	0.7	3.2	1	1	1
10/31/2022 23:00	1.0	12.2	2,136.9	0.7	3.2	1	1	1
Average/Sum#:	5.2	13.5	1,757.9	0.6	204.3 #	23 #	24 #	10 #
Minimum:	0.4	12.2	299.3	0.3	1.3	0	1	0
Maximum:	64.0	17.7	2,136.9	0.8	76.7	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.0	12.2	2,154.2	0.7	3.3	1	1	1
11/01/2022 01:00	1.0	12.2	2,150.3	0.7	3.3	1	1	1
11/01/2022 02:00	1.0	12.2	2,158.5	0.7	3.3	1	1	1
11/01/2022 03:00	1.0	12.2	2,167.8	0.7	3.3	1	1	1
11/01/2022 04:00	1.0	12.2	2,175.8	0.7	3.3	1	1	1
11/01/2022 05:00	1.0	12.1	2,176.4	0.7	3.3	1	1	1
11/01/2022 06:00	0.9	11.8	2,250.2	0.7	2.9	1	1	1
11/01/2022 07:00	0.9	12.0	2,187.2	0.6	2.9	1	1	1
11/01/2022 08:00	0.8	11.7	2,240.2	0.6	2.6	1	1	1
11/01/2022 09:00	0.9	12.2	2,118.9	0.6	2.9	1	1	1
11/01/2022 10:00	1.0	12.3	2,123.0	0.6	3.3	1	1	1
11/01/2022 11:00	0.9	12.0	2,183.5	0.6	2.9	1	1	1
11/01/2022 12:00	0.9	11.9	2,189.4	0.6	2.9	1	1	1
11/01/2022 13:00	0.8	12.0	2,180.9	0.6	2.6	1	1	1
11/01/2022 14:00	0.9	12.4	2,089.8	0.6	2.9	1	1	1
11/01/2022 15:00	1.1	12.6	2,087.1	0.6	3.7	1	1	1
11/01/2022 16:00	0.9	12.1	2,204.2	0.7	3.0	1	1	1
11/01/2022 17:00	0.8	11.6	2,294.1	0.6	2.6	1	1	1
11/01/2022 18:00	0.9	12.1	2,186.6	0.6	3.0	1	1	1
11/01/2022 19:00	0.9	12.3	2,168.2	0.6	3.0	1	1	1
11/01/2022 20:00	0.9	12.1	2,209.2	0.6	3.0	1	1	1
11/01/2022 21:00	0.9	12.6	2,087.6	0.6	3.0	1	1	1
11/01/2022 22:00	0.9	12.7	2,075.1	0.6	3.0	1	1	1
11/01/2022 23:00	0.8	13.3	1,849.2	0.6	2.6	1	1	1
Average/Sum#:	0.9	12.2	2,154.5	0.6	72.6 #	24 #	24 #	24 #
Minimum:	0.8	11.6	1,849.2	0.6	2.6	1	1	1
Maximum:	1.1	13.3	2,294.1	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.7	13.9	1,353.8	0.6	1.8	1	1	0
11/02/2022 01:00	0.5	13.9	1,639.5	0.5	1.5	1	1	0
11/02/2022 02:00	0.5	13.8	1,709.9	0.5	1.6	1	1	0
11/02/2022 03:00	1.0	13.9	1,353.8	0.5	2.6	1	1	0
11/02/2022 04:00	0.5	13.8	1,683.4	0.5	1.6	1	1	0
11/02/2022 05:00	1.0	13.1	1,917.9	0.7	3.2	1	1	1
11/02/2022 06:00	1.1	12.5	2,169.6	0.7	3.8	1	1	1
11/02/2022 07:00	1.0	12.7	2,129.3	0.8	3.4	1	1	1
11/02/2022 08:00	1.0	12.9	2,028.9	0.7	3.3	1	1	1
11/02/2022 09:00	0.5	13.8	1,719.4	0.6	1.6	1	1	0
11/02/2022 10:00	0.5	13.9	1,549.8	0.5	1.5	1	1	0
11/02/2022 11:00	0.5	13.9	1,678.6	0.4	1.6	1	1	0
11/02/2022 12:00	0.5	13.9	1,558.6	0.4	1.5	1	1	0
11/02/2022 13:00	0.5	13.9	1,562.4	0.4	1.5	1	1	0
11/02/2022 14:00	0.5	13.9	1,544.2	0.4	1.5	1	1	0
11/02/2022 15:00	0.5	13.9	1,612.7	0.4	1.5	1	1	1
11/02/2022 16:00	1.1	12.6	2,080.8	0.5	3.6	1	1	1
11/02/2022 17:00	1.0	12.3	2,172.4	0.6	3.3	1	1	1
11/02/2022 18:00	1.0	12.4	2,164.8	0.7	3.4	1	1	1
11/02/2022 19:00	1.0	12.4	2,165.2	0.7	3.4	1	1	1
11/02/2022 20:00	1.0	12.4	2,166.8	0.7	3.4	1	1	1
11/02/2022 21:00	1.0	12.5	2,152.9	0.7	3.4	1	1	1
11/02/2022 22:00	1.0	12.4	2,163.4	0.7	3.4	1	1	1
11/02/2022 23:00	1.0	12.4	2,176.3	0.7	3.4	1	1	1
Average/Sum#:	0.8	13.2	1,852.3	0.6	60.8 #	24 #	24 #	13 #
Minimum:	0.5	12.3	1,353.8	0.4	1.5	1	1	0
Maximum:	1.1	13.9	2,176.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.0	12.4	2,167.7	0.7	3.4	1	1	1
11/03/2022 01:00	1.0	12.5	2,153.5	0.7	3.4	1	1	1
11/03/2022 02:00	1.0	12.3	2,199.7	0.7	3.4	1	1	1
11/03/2022 03:00	0.9	12.1	2,243.0	0.7	3.0	1	1	1
11/03/2022 04:00	1.0	12.4	2,170.3	0.7	3.4	1	1	1
11/03/2022 05:00	1.0	12.4	2,175.5	0.7	3.4	1	1	1
11/03/2022 06:00	0.9	12.1	2,246.8	0.7	3.0	1	1	1
11/03/2022 07:00	0.9	12.6	2,117.7	0.6	3.0	1	1	1
11/03/2022 08:00	0.5	13.9	1,461.2	0.5	1.4	1	1	0
11/03/2022 09:00	0.5	13.9	1,567.5	0.5	1.5	1	1	0
11/03/2022 10:00	0.5	13.9	1,581.7	0.4	1.5	1	1	0
11/03/2022 11:00	0.4	13.9	1,575.7	0.4	1.2	1	1	0
11/03/2022 12:00	0.4	13.9	1,587.6	0.3	1.2	1	1	0
11/03/2022 13:00	0.5	13.9	1,496.8	0.3	1.4	1	1	0
11/03/2022 14:00	0.4	13.9	1,564.2	0.3	1.2	1	1	0
11/03/2022 15:00	0.4	13.8	1,787.2	0.3	1.3	1	1	1
11/03/2022 16:00	1.1	12.7	2,081.8	0.5	3.7	1	1	1
11/03/2022 17:00	1.0	12.4	2,162.4	0.6	3.4	1	1	1
11/03/2022 18:00	1.0	12.3	2,178.2	0.7	3.3	1	1	1
11/03/2022 19:00	0.9	12.3	2,176.0	0.7	3.0	1	1	1
11/03/2022 20:00	0.9	12.3	2,164.2	0.6	3.0	1	1	1
11/03/2022 21:00	0.9	12.3	2,163.9	0.6	3.0	1	1	1
11/03/2022 22:00	0.9	12.3	2,163.3	0.6	3.0	1	1	1
11/03/2022 23:00	0.9	12.1	2,220.6	0.6	3.0	1	1	1
Average/Sum#:	0.8	12.9	1,975.3	0.6	62.1 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,461.2	0.3	1.2	1	1	0
Maximum:	1.1	13.9	2,246.8	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.0	12.5	2,148.4	0.6	3.4	1	1	1
11/04/2022 01:00	1.0	12.6	2,120.9	0.7	3.4	1	1	1
11/04/2022 02:00	0.9	12.8	2,070.3	0.7	3.0	1	1	1
11/04/2022 03:00	1.0	12.8	2,074.1	0.7	3.4	1	1	1
11/04/2022 04:00	1.0	12.5	2,153.1	0.7	3.4	1	1	1
11/04/2022 05:00	0.9	12.0	2,266.7	0.7	3.0	1	1	1
11/04/2022 06:00	1.0	12.4	2,187.8	0.7	3.4	1	1	1
11/04/2022 07:00	1.0	12.8	2,062.9	0.7	3.4	1	1	1
11/04/2022 08:00	0.4	13.8	1,733.8	0.6	1.3	1	1	0
11/04/2022 09:00	0.5	13.9	1,557.3	0.5	1.5	1	1	0
11/04/2022 10:00	0.5	13.9	1,396.0	0.4	1.3	1	1	0
11/04/2022 11:00	0.6	14.0	1,324.8	0.4	1.5	1	1	0
11/04/2022 12:00	0.6	14.0	1,322.8	0.5	1.5	1	1	0
11/04/2022 13:00	0.5	14.0	1,324.0	0.5	1.3	1	1	0
11/04/2022 14:00	0.6	13.9	1,404.7	0.5	1.6	1	1	0
11/04/2022 15:00	0.6	13.8	1,636.8	0.5	1.8	1	1	1
11/04/2022 16:00	1.1	12.6	2,081.0	0.6	3.6	1	1	1
11/04/2022 17:00	1.0	12.4	2,119.5	0.7	3.3	1	1	1
11/04/2022 18:00	0.9	12.7	2,057.5	0.7	3.0	1	1	1
11/04/2022 19:00	0.9	12.7	2,056.8	0.6	3.0	1	1	1
11/04/2022 20:00	0.9	12.8	2,052.8	0.6	3.0	1	1	1
11/04/2022 21:00	0.9	12.8	2,054.4	0.7	3.0	1	1	1
11/04/2022 22:00	0.9	12.8	2,054.9	0.7	3.0	1	1	1
11/04/2022 23:00	1.1	13.3	1,952.5	0.8	3.7	1	1	1
Average/Sum#:	0.8	13.1	1,883.9	0.6	63.8 #	24 #	24 #	17 #
Minimum:	0.4	12.0	1,322.8	0.4	1.3	1	1	0
Maximum:	1.1	14.0	2,266.7	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	1.2	13.3	1,950.5	0.8	4.1	1	1	1
11/05/2022 01:00	1.2	13.3	1,950.4	0.9	4.1	1	1	1
11/05/2022 02:00	1.2	13.3	1,950.1	0.9	4.1	1	1	1
11/05/2022 03:00	1.3	13.3	1,950.9	0.9	4.4	1	1	1
11/05/2022 04:00	1.3	13.3	1,954.3	1.0	4.4	1	1	1
11/05/2022 05:00	1.3	13.3	1,956.6	1.0	4.4	1	1	1
11/05/2022 06:00	1.3	13.3	1,927.6	1.0	4.4	1	1	1
11/05/2022 07:00	21.2	15.8	567.3	0.0	7.2	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	19.1	18.8	195.5	0.0	4.7	1	0	0
11/05/2022 14:00	38.9	16.1	711.5	0.0	76.2	1	0	0
11/05/2022 15:00	0.5	13.9	1,436.7	0.0	1.4	1	0	0
11/05/2022 16:00	1.1	13.4	1,707.2	0.0	3.3	1	0	1
11/05/2022 17:00	1.2	13.0	1,981.9	0.7	4.0	1	0	1
11/05/2022 18:00	1.3	13.0	1,971.9	0.9	4.3	1	0	1
11/05/2022 19:00	1.4	13.0	1,972.1	1.0	4.6	1	0	1
11/05/2022 20:00	1.5	13.0	1,975.2	1.0	5.0	1	0	1
11/05/2022 21:00	1.1	13.5	1,647.5	1.0	3.2	1	0	1
11/05/2022 22:00	0.7	13.9	1,409.8	0.9	1.9	1	0	0
11/05/2022 23:00	0.5	13.8	1,653.4	0.6	1.5	1	0	0
Average/Sum#:	5.1	13.9	1,624.8	0.9	147.2 #	19 #	7 #	13 #
Minimum:	0.5	13.0	195.5	0.6	1.4	0	0	0
Maximum:	38.9	18.8	1,981.9	1.0	76.2	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.5	13.8	1,564.1	0.5	1.5	1	0	0
11/06/2022 01:00	0.6	13.8	1,463.6	0.4	1.6	1	0	0
11/06/2022 02:00	29.7	16.3	377.6	0.0	5.8	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	10.3	14.6	1,135.1	0.5	8.9 #	3 #	9 #	0 #
Minimum:	0.5	13.8	377.6	0.4	1.5	0	0	0
Maximum:	29.7	16.3	1,564.1	0.5	5.8	1	1	0
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/07/2022 03:00	85.1	18.1	281.0	0.0	45.1	1	1	0
11/07/2022 04:00	40.7	16.6	549.1	0.0	68.6	1	1	0
11/07/2022 05:00	0.6	13.7	1,723.5	0.0	1.9	1	1	0
11/07/2022 06:00	1.0	12.9	2,000.6	0.0	3.3	1	1	1
11/07/2022 07:00	1.0	12.1	2,210.3	0.0	3.3	1	1	1
11/07/2022 08:00	1.0	13.0	1,980.7	0.7	3.3	1	1	1
11/07/2022 09:00	1.1	13.0	1,964.2	0.7	3.6	1	1	1
11/07/2022 10:00	1.0	13.0	1,956.5	0.7	3.3	1	1	1
11/07/2022 11:00	0.8	13.1	1,957.6	0.7	2.7	1	1	1
11/07/2022 12:00	0.7	13.1	1,957.2	0.6	2.3	1	1	1
11/07/2022 13:00	0.8	13.1	1,960.7	0.6	2.7	1	1	1
11/07/2022 14:00	0.9	12.8	2,055.3	0.6	3.0	1	1	1
11/07/2022 15:00	0.9	12.2	2,186.1	0.6	3.0	1	1	1
11/07/2022 16:00	0.8	11.9	2,241.6	0.6	2.6	1	1	1
11/07/2022 17:00	0.7	11.8	2,276.8	0.5	2.3	1	1	1
11/07/2022 18:00	0.7	11.8	2,279.9	0.5	2.3	1	1	1
11/07/2022 19:00	0.7	11.8	2,279.4	0.5	2.3	1	1	1
11/07/2022 20:00	0.7	11.8	2,276.6	0.5	2.3	1	1	1
11/07/2022 21:00	0.7	11.8	2,272.9	0.5	2.3	1	1	1
11/07/2022 22:00	0.8	12.0	2,232.3	0.5	2.7	1	1	1
11/07/2022 23:00	0.8	12.4	2,159.5	0.5	2.7	1	1	1
Average/Sum#:	6.7	13.0	1,942.9	0.6	165.6 #	21 #	22 #	18 #
Minimum:	0.6	11.8	281.0	0.5	1.9	0	0	0
Maximum:	85.1	18.1	2,279.9	0.7	68.6	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.9	12.4	2,151.8	0.6	3.0	1	1	1
11/08/2022 01:00	0.9	12.4	2,149.8	0.6	3.0	1	1	1
11/08/2022 02:00	0.8	12.6	2,096.5	0.6	2.7	1	1	1
11/08/2022 03:00	0.9	12.4	2,143.2	0.6	3.0	1	1	1
11/08/2022 04:00	0.9	12.2	2,180.4	0.6	3.0	1	1	1
11/08/2022 05:00	0.8	12.1	2,197.5	0.6	2.6	1	1	1
11/08/2022 06:00	0.7	11.7	2,281.0	0.5	2.3	1	1	1
11/08/2022 07:00	0.8	12.1	2,193.7	0.5	2.6	1	1	1
11/08/2022 08:00	0.8	12.1	2,185.1	0.5	2.6	1	1	1
11/08/2022 09:00	0.8	12.2	2,181.7	0.5	2.6	1	1	1
11/08/2022 10:00	0.9	12.3	2,165.2	0.5	3.0	1	1	1
11/08/2022 11:00	0.8	12.9	2,016.4	0.6	2.7	1	1	1
11/08/2022 12:00	0.8	13.1	1,972.3	0.6	2.7	1	1	1
11/08/2022 13:00	0.8	13.2	1,972.1	0.6	2.7	1	1	1
11/08/2022 14:00	0.9	12.9	2,046.8	0.6	3.0	1	1	1
11/08/2022 15:00	0.8	12.9	2,043.8	0.6	2.7	1	1	1
11/08/2022 16:00	0.8	12.2	2,202.3	0.6	2.7	1	1	1
11/08/2022 17:00	0.8	12.2	2,181.5	0.5	2.6	1	1	1
11/08/2022 18:00	0.9	12.4	2,151.7	0.5	3.0	1	1	1
11/08/2022 19:00	0.8	12.2	2,186.1	0.5	2.7	1	1	1
11/08/2022 20:00	0.8	12.2	2,194.5	0.5	2.7	1	1	1
11/08/2022 21:00	0.8	12.2	2,195.9	0.5	2.7	1	1	1
11/08/2022 22:00	0.8	12.2	2,180.1	0.5	2.6	1	1	1
11/08/2022 23:00	0.9	12.4	2,137.2	0.5	3.0	1	1	1
Average/Sum#:	0.8	12.4	2,141.9	0.6	66.2 #	24 #	24 #	24 #
Minimum:	0.7	11.7	1,972.1	0.5	2.3	1	1	1
Maximum:	0.9	13.2	2,281.0	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	0.9	12.4	2,147.1	0.6	3.0	1	1	1
11/09/2022 01:00	0.9	12.4	2,147.0	0.6	3.0	1	1	1
11/09/2022 02:00	0.9	12.3	2,184.9	0.6	3.0	1	1	1
11/09/2022 03:00	0.9	12.3	2,187.0	0.6	3.0	1	1	1
11/09/2022 04:00	0.9	12.5	2,154.3	0.6	3.0	1	1	1
11/09/2022 05:00	0.8	11.9	2,246.2	0.6	2.6	1	1	1
11/09/2022 06:00	0.7	11.9	2,284.3	0.5	2.3	1	1	1
11/09/2022 07:00	0.8	12.4	2,184.8	0.5	2.7	1	1	1
11/09/2022 08:00	0.8	12.5	2,147.6	0.6	2.7	1	1	1
11/09/2022 09:00	0.4	13.7	1,760.8	0.5	1.3	1	1	1
11/09/2022 10:00	0.3	13.9	1,725.2	0.4	1.0	1	1	0
11/09/2022 11:00	0.3	13.9	1,641.0	0.3	0.9	1	1	0
11/09/2022 12:00	0.3	13.9	1,716.3	0.3	1.0	1	1	0
11/09/2022 13:00	0.3	13.9	1,625.0	0.3	0.9	1	1	0
11/09/2022 14:00	0.3	13.9	1,698.0	0.3	1.0	1	1	0
11/09/2022 15:00	0.4	13.9	1,645.4	0.3	1.2	1	1	1
11/09/2022 16:00	1.0	12.8	2,074.2	0.4	3.4	1	1	1
11/09/2022 17:00	0.9	12.5	2,153.5	0.5	3.0	1	1	1
11/09/2022 18:00	0.9	13.1	2,009.9	0.7	3.1	1	1	1
11/09/2022 19:00	1.1	13.3	1,973.0	0.7	3.8	1	1	1
11/09/2022 20:00	1.1	13.3	1,976.7	0.8	3.8	1	1	1
11/09/2022 21:00	1.1	13.3	1,988.3	0.9	3.8	1	1	1
11/09/2022 22:00	1.1	13.3	1,979.1	0.9	3.8	1	1	1
11/09/2022 23:00	1.1	13.3	1,977.5	0.9	3.8	1	1	1
Average/Sum#:	0.8	13.0	1,984.5	0.6	61.1 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,625.0	0.3	0.9	1	1	0
Maximum:	1.1	13.9	2,284.3	0.9	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.1	13.3	1,977.3	0.9	3.8	1	1	1
11/10/2022 01:00	1.1	13.3	1,975.5	0.9	3.8	1	1	1
11/10/2022 02:00	1.1	13.3	1,974.4	0.9	3.8	1	1	1
11/10/2022 03:00	1.1	13.3	1,977.4	0.9	3.8	1	1	1
11/10/2022 04:00	1.0	12.9	2,073.4	0.8	3.4	1	1	1
11/10/2022 05:00	0.8	12.3	2,174.8	0.7	2.7	1	1	1
11/10/2022 06:00	0.8	12.0	2,299.8	0.6	2.7	1	1	1
11/10/2022 07:00	0.9	12.7	2,110.5	0.5	3.1	1	1	1
11/10/2022 08:00	1.1	13.3	1,967.3	0.7	3.8	1	1	1
11/10/2022 09:00	1.1	13.3	1,948.5	0.8	3.7	1	1	1
11/10/2022 10:00	0.3	13.9	1,736.2	0.7	1.0	1	1	0
11/10/2022 11:00	0.3	13.9	1,728.1	0.5	1.0	1	1	0
11/10/2022 12:00	0.3	13.9	1,714.9	0.3	1.0	1	1	0
11/10/2022 13:00	0.3	14.0	1,570.6	0.3	0.9	1	1	0
11/10/2022 14:00	0.3	13.9	1,724.2	0.3	1.0	1	1	0
11/10/2022 15:00	0.3	13.9	1,723.1	0.3	1.0	1	1	1
11/10/2022 16:00	1.2	12.6	2,126.5	0.5	4.1	1	1	1
11/10/2022 17:00	0.7	11.9	2,271.9	0.6	2.3	1	1	1
11/10/2022 18:00	0.7	11.9	2,274.6	0.6	2.3	1	1	1
11/10/2022 19:00	0.7	11.9	2,278.5	0.5	2.3	1	1	1
11/10/2022 20:00	0.7	11.9	2,278.8	0.5	2.3	1	1	1
11/10/2022 21:00	0.7	11.9	2,281.7	0.5	2.3	1	1	1
11/10/2022 22:00	0.7	11.9	2,281.2	0.5	2.3	1	1	1
11/10/2022 23:00	0.7	12.0	2,256.4	0.5	2.3	1	1	1
Average/Sum#:	0.8	12.9	2,030.2	0.6	60.7 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,570.6	0.3	0.9	1	1	0
Maximum:	1.2	14.0	2,299.8	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.7	12.0	2,281.8	0.5	2.4	1	1	1
11/11/2022 01:00	0.7	12.0	2,275.8	0.5	2.4	1	1	1
11/11/2022 02:00	0.8	12.6	2,145.1	0.5	2.7	1	1	1
11/11/2022 03:00	0.8	12.6	2,142.7	0.6	2.7	1	1	1
11/11/2022 04:00	0.8	12.1	2,271.6	0.6	2.7	1	1	1
11/11/2022 05:00	0.8	12.0	2,285.2	0.5	2.7	1	1	1
11/11/2022 06:00	0.7	12.0	2,284.1	0.5	2.4	1	1	1
11/11/2022 07:00	0.9	12.7	2,108.2	0.5	3.1	1	1	1
11/11/2022 08:00	1.1	13.3	1,940.2	0.7	3.7	1	1	1
11/11/2022 09:00	0.3	13.9	1,718.1	0.6	1.0	1	1	0
11/11/2022 10:00	0.3	13.9	1,724.0	0.5	1.0	1	1	0
11/11/2022 11:00	0.3	13.9	1,688.9	0.3	1.0	1	1	0
11/11/2022 12:00	0.3	13.9	1,687.5	0.3	1.0	1	1	0
11/11/2022 13:00	0.3	13.9	1,700.7	0.3	1.0	1	1	0
11/11/2022 14:00	0.3	13.9	1,582.3	0.3	0.9	1	1	0
11/11/2022 15:00	0.3	13.9	1,688.6	0.3	1.0	1	1	0
11/11/2022 16:00	1.0	13.0	1,979.8	0.4	3.3	1	1	1
11/11/2022 17:00	0.7	11.8	2,273.3	0.5	2.3	1	1	1
11/11/2022 18:00	0.7	11.9	2,266.1	0.6	2.3	1	1	1
11/11/2022 19:00	0.7	11.9	2,254.1	0.5	2.3	1	1	1
11/11/2022 20:00	0.7	11.9	2,250.8	0.5	2.3	1	1	1
11/11/2022 21:00	0.7	11.9	2,249.2	0.5	2.3	1	1	1
11/11/2022 22:00	0.8	12.1	2,243.3	0.5	2.7	1	1	1
11/11/2022 23:00	0.8	12.0	2,260.9	0.5	2.7	1	1	1
Average/Sum#:	0.6	12.7	2,054.3	0.5	51.9 #	24 #	24 #	17 #
Minimum:	0.3	11.8	1,582.3	0.3	0.9	1	1	0
Maximum:	1.1	13.9	2,285.2	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.8	12.0	2,265.2	0.5	2.7	1	1	1
11/12/2022 01:00	0.8	12.0	2,268.8	0.5	2.7	1	1	1
11/12/2022 02:00	0.8	12.0	2,275.3	0.5	2.7	1	1	1
11/12/2022 03:00	0.8	12.0	2,278.8	0.5	2.7	1	1	1
11/12/2022 04:00	0.8	12.0	2,285.3	0.5	2.7	1	1	1
11/12/2022 05:00	0.8	12.0	2,286.6	0.5	2.7	1	1	1
11/12/2022 06:00	0.8	12.0	2,277.1	0.5	2.7	1	1	1
11/12/2022 07:00	0.8	12.7	2,119.5	0.5	2.7	1	1	1
11/12/2022 08:00	0.8	12.2	2,196.2	0.5	2.7	1	1	1
11/12/2022 09:00	0.4	13.7	1,755.8	0.5	1.3	1	1	1
11/12/2022 10:00	0.3	13.9	1,596.8	0.4	0.9	1	1	0
11/12/2022 11:00	0.3	13.9	1,557.9	0.3	0.9	1	1	0
11/12/2022 12:00	0.3	13.9	1,557.2	0.3	0.9	1	1	0
11/12/2022 13:00	0.3	13.9	1,580.9	0.3	0.9	1	1	0
11/12/2022 14:00	0.3	13.9	1,557.8	0.3	0.9	1	1	0
11/12/2022 15:00	0.3	13.8	1,793.1	0.3	1.0	1	1	1
11/12/2022 16:00	1.2	12.5	2,136.2	0.4	4.0	1	1	1
11/12/2022 17:00	0.7	11.8	2,289.6	0.5	2.3	1	1	1
11/12/2022 18:00	0.7	11.8	2,288.4	0.6	2.3	1	1	1
11/12/2022 19:00	0.7	11.8	2,294.2	0.5	2.3	1	1	1
11/12/2022 20:00	0.7	11.8	2,304.8	0.5	2.3	1	1	1
11/12/2022 21:00	0.7	11.8	2,300.6	0.5	2.3	1	1	1
11/12/2022 22:00	0.8	12.3	2,197.1	0.5	2.7	1	1	1
11/12/2022 23:00	0.8	12.3	2,192.7	0.5	2.7	1	1	1
Average/Sum#:	0.7	12.6	2,069.0	0.5	52.0 #	24 #	24 #	19 #
Minimum:	0.3	11.8	1,557.2	0.3	0.9	1	1	0
Maximum:	1.2	13.9	2,304.8	0.6	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.8	12.4	2,183.0	0.5	2.7	1	1	1
11/13/2022 01:00	0.8	12.4	2,169.4	0.6	2.7	1	1	1
11/13/2022 02:00	0.8	12.5	2,162.2	0.6	2.7	1	1	1
11/13/2022 03:00	0.8	12.3	2,198.3	0.6	2.7	1	1	1
11/13/2022 04:00	0.8	12.4	2,192.5	0.6	2.7	1	1	1
11/13/2022 05:00	0.8	12.4	2,185.1	0.6	2.7	1	1	1
11/13/2022 06:00	0.8	12.3	2,201.5	0.6	2.7	1	1	1
11/13/2022 07:00	0.7	12.0	2,269.1	0.5	2.4	1	1	1
11/13/2022 08:00	0.6	12.9	1,972.8	0.5	2.0	1	1	1
11/13/2022 09:00	0.3	13.9	1,713.6	0.4	1.0	1	1	0
11/13/2022 10:00	0.3	13.9	1,714.5	0.3	1.0	1	1	0
11/13/2022 11:00	0.3	13.9	1,714.3	0.3	1.0	1	1	0
11/13/2022 12:00	0.3	13.9	1,712.3	0.3	1.0	1	1	0
11/13/2022 13:00	0.3	14.0	1,713.9	0.3	1.0	1	1	0
11/13/2022 14:00	0.3	14.0	1,686.9	0.3	1.0	1	1	0
11/13/2022 15:00	0.3	13.8	1,797.5	0.3	1.0	1	1	1
11/13/2022 16:00	0.8	12.6	2,132.3	0.4	2.7	1	1	1
11/13/2022 17:00	0.6	12.0	2,273.8	0.4	2.0	1	1	1
11/13/2022 18:00	0.6	12.0	2,273.5	0.5	2.0	1	1	1
11/13/2022 19:00	0.6	12.0	2,277.3	0.4	2.0	1	1	1
11/13/2022 20:00	0.6	12.0	2,280.0	0.4	2.0	1	1	1
11/13/2022 21:00	0.6	12.0	2,284.9	0.4	2.0	1	1	1
11/13/2022 22:00	0.6	12.0	2,287.2	0.4	2.0	1	1	1
11/13/2022 23:00	0.6	12.0	2,294.0	0.4	2.0	1	1	1
Average/Sum#:	0.6	12.7	2,070.4	0.4	47.0 #	24 #	24 #	18 #
Minimum:	0.3	12.0	1,686.9	0.3	1.0	1	1	0
Maximum:	0.8	14.0	2,294.0	0.6	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.6	12.1	2,288.4	0.4	2.1	1	1	1
11/14/2022 01:00	0.7	12.1	2,277.6	0.4	2.4	1	1	1
11/14/2022 02:00	0.7	12.2	2,265.6	0.5	2.4	1	1	1
11/14/2022 03:00	0.8	12.7	2,149.5	0.5	2.8	1	1	1
11/14/2022 04:00	0.8	12.4	2,230.6	0.6	2.8	1	1	1
11/14/2022 05:00	0.7	12.2	2,291.8	0.6	2.4	1	1	1
11/14/2022 06:00	0.7	12.2	2,286.5	0.5	2.4	1	1	1
11/14/2022 07:00	0.8	12.6	2,184.1	0.5	2.8	1	1	1
11/14/2022 08:00	0.8	12.7	2,143.2	0.6	2.8	1	1	1
11/14/2022 09:00	0.8	12.6	2,149.5	0.6	2.7	1	1	1
11/14/2022 10:00	0.8	12.6	2,141.4	0.6	2.7	1	1	1
11/14/2022 11:00	0.7	12.7	2,116.8	0.6	2.4	1	1	1
11/14/2022 12:00	0.7	12.7	2,106.1	0.5	2.4	1	1	1
11/14/2022 13:00	0.7	12.5	2,137.1	0.5	2.4	1	1	1
11/14/2022 14:00	0.7	12.5	2,137.4	0.5	2.4	1	1	1
11/14/2022 15:00	0.7	12.8	2,062.7	0.5	2.4	1	1	1
11/14/2022 16:00	0.6	12.1	2,229.8	0.5	2.0	1	1	1
11/14/2022 17:00	0.7	12.3	2,177.1	0.5	2.3	1	1	1
11/14/2022 18:00	0.7	12.5	2,159.1	0.5	2.4	1	1	1
11/14/2022 19:00	0.6	12.1	2,265.3	0.5	2.0	1	1	1
11/14/2022 20:00	0.6	12.0	2,281.3	0.4	2.0	1	1	1
11/14/2022 21:00	0.6	12.1	2,256.1	0.4	2.0	1	1	1
11/14/2022 22:00	0.6	12.1	2,259.7	0.4	2.0	1	1	1
11/14/2022 23:00	0.6	12.2	2,239.5	0.4	2.0	1	1	1
Average/Sum#:	0.7	12.4	2,201.5	0.5	57.0 #	24 #	24 #	24 #
Minimum:	0.6	12.0	2,062.7	0.4	2.0	1	1	1
Maximum:	0.8	12.8	2,291.8	0.6	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	0.6	12.1	2,265.0	0.4	2.0	1	1	1
11/15/2022 01:00	0.6	12.1	2,268.0	0.4	2.0	1	1	1
11/15/2022 02:00	0.6	12.0	2,286.6	0.4	2.0	1	1	1
11/15/2022 03:00	0.6	12.0	2,296.0	0.4	2.0	1	1	1
11/15/2022 04:00	0.6	12.0	2,299.8	0.4	2.0	1	1	1
11/15/2022 05:00	0.6	11.7	2,332.5	0.4	2.0	1	1	1
11/15/2022 06:00	0.7	12.2	2,202.6	0.4	2.3	1	1	1
11/15/2022 07:00	0.6	11.8	2,323.2	0.4	2.0	1	1	1
11/15/2022 08:00	0.6	12.0	2,234.7	0.4	2.0	1	1	1
11/15/2022 09:00	0.7	12.6	2,114.0	0.4	2.4	1	1	1
11/15/2022 10:00	0.8	12.5	2,135.7	0.5	2.7	1	1	1
11/15/2022 11:00	0.9	12.9	2,037.3	0.6	3.0	1	1	1
11/15/2022 12:00	1.3	13.3	1,961.1	0.8	4.4	1	1	1
11/15/2022 13:00	1.3	13.3	1,967.3	0.9	4.4	1	1	1
11/15/2022 14:00	0.0	0.0	1,973.8	0.0	0.0	1	1	1
11/15/2022 15:00	0.0	0.0	2,007.0	0.0	0.0	1	1	1
11/15/2022 16:00	0.9	12.5	2,120.1	0.0	3.0	1	1	1
11/15/2022 17:00	0.9	12.4	2,133.8	0.0	3.0	1	1	1
11/15/2022 18:00	0.8	12.4	2,123.0	0.6	2.6	1	1	1
11/15/2022 19:00	0.8	12.3	2,137.1	0.6	2.6	1	1	1
11/15/2022 20:00	0.8	12.2	2,175.2	0.5	2.6	1	1	1
11/15/2022 21:00	0.7	11.9	2,237.4	0.5	2.3	1	1	1
11/15/2022 22:00	0.8	12.3	2,149.1	0.5	2.6	1	1	1
11/15/2022 23:00	0.8	12.3	2,148.1	0.5	2.6	1	1	1
Average/Sum#:	0.8	12.3	2,163.7	0.5	56.5 #	24 #	24 #	24 #
Minimum:	0.6	11.7	1,961.1	0.4	2.0	1	1	1
Maximum:	1.3	13.3	2,332.5	0.9	4.4	1	1	1
%SI	8.33	8.33	0.00	16.67	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	0.8	12.3	2,142.4	0.5	2.6	1	1	1
11/16/2022 01:00	0.8	12.5	2,116.0	0.5	2.7	1	1	1
11/16/2022 02:00	0.8	12.4	2,139.8	0.6	2.7	1	1	1
11/16/2022 03:00	0.8	12.4	2,144.4	0.6	2.7	1	1	1
11/16/2022 04:00	0.8	11.9	2,274.6	0.6	2.7	1	1	1
11/16/2022 05:00	0.7	11.5	2,340.0	0.5	2.3	1	1	1
11/16/2022 06:00	0.6	11.5	2,346.5	0.4	2.0	1	1	1
11/16/2022 07:00	0.7	11.9	2,254.3	0.4	2.3	1	1	1
11/16/2022 08:00	1.0	13.3	1,966.8	0.6	3.4	1	1	1
11/16/2022 09:00	1.2	13.6	1,997.0	0.8	4.3	1	1	1
11/16/2022 10:00	1.2	13.2	1,964.8	0.9	4.0	1	1	1
11/16/2022 11:00	1.2	13.2	1,969.2	0.9	4.1	1	1	1
11/16/2022 12:00	1.2	13.1	1,978.0	0.9	4.0	1	1	1
11/16/2022 13:00	1.2	13.1	1,980.5	0.9	4.0	1	1	1
11/16/2022 14:00	1.2	13.1	1,981.2	0.9	4.0	1	1	1
11/16/2022 15:00	1.0	12.6	2,101.9	0.8	3.3	1	1	1
11/16/2022 16:00	0.8	12.3	2,161.6	0.7	2.7	1	1	1
11/16/2022 17:00	0.8	12.3	2,165.8	0.6	2.7	1	1	1
11/16/2022 18:00	0.7	12.0	2,221.6	0.5	2.3	1	1	1
11/16/2022 19:00	0.7	11.9	2,228.4	0.5	2.3	1	1	1
11/16/2022 20:00	0.7	11.9	2,229.7	0.5	2.3	1	1	1
11/16/2022 21:00	0.8	12.0	2,244.6	0.5	2.7	1	1	1
11/16/2022 22:00	0.8	12.2	2,216.3	0.5	2.7	1	1	1
11/16/2022 23:00	0.8	12.0	2,243.9	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.4	2,142.1	0.6	71.5 #	24 #	24 #	24 #
Minimum:	0.6	11.5	1,964.8	0.4	2.0	1	1	1
Maximum:	1.2	13.6	2,346.5	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.8	12.4	2,159.1	0.5	2.7	1	1	1
11/17/2022 01:00	0.8	12.4	2,159.4	0.6	2.7	1	1	1
11/17/2022 02:00	0.8	12.5	2,146.1	0.6	2.7	1	1	1
11/17/2022 03:00	0.8	12.5	2,149.6	0.6	2.7	1	1	1
11/17/2022 04:00	0.8	12.2	2,231.0	0.6	2.7	1	1	1
11/17/2022 05:00	0.7	11.6	2,357.0	0.5	2.3	1	1	1
11/17/2022 06:00	0.7	11.9	2,276.3	0.5	2.3	1	1	1
11/17/2022 07:00	0.8	12.4	2,162.7	0.5	2.7	1	1	1
11/17/2022 08:00	1.0	13.1	1,985.4	0.6	3.4	1	1	1
11/17/2022 09:00	0.8	12.5	2,129.0	0.7	2.7	1	1	1
11/17/2022 10:00	0.8	12.5	2,110.8	0.7	2.7	1	1	1
11/17/2022 11:00	0.8	12.3	2,133.9	0.6	2.6	1	1	1
11/17/2022 12:00	0.7	12.1	2,171.5	0.5	2.3	1	1	1
11/17/2022 13:00	0.7	12.2	2,169.8	0.5	2.3	1	1	1
11/17/2022 14:00	0.7	12.9	2,005.0	0.5	2.3	1	1	1
11/17/2022 15:00	0.7	12.4	2,118.7	0.5	2.3	1	1	1
11/17/2022 16:00	0.7	11.9	2,234.9	0.5	2.3	1	1	1
11/17/2022 17:00	0.6	11.8	2,268.2	0.5	2.0	1	1	1
11/17/2022 18:00	0.6	11.8	2,255.7	0.4	2.0	1	1	1
11/17/2022 19:00	0.6	11.8	2,258.8	0.4	2.0	1	1	1
11/17/2022 20:00	0.7	11.8	2,260.2	0.4	2.3	1	1	1
11/17/2022 21:00	0.6	11.8	2,262.4	0.4	2.0	1	1	1
11/17/2022 22:00	0.7	11.9	2,246.4	0.5	2.3	1	1	1
11/17/2022 23:00	0.8	12.2	2,206.6	0.5	2.7	1	1	1
Average/Sum#:	0.7	12.2	2,185.8	0.5	59.0 #	24 #	24 #	24 #
Minimum:	0.6	11.6	1,985.4	0.4	2.0	1	1	1
Maximum:	1.0	13.1	2,357.0	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.8	12.4	2,157.1	0.5	2.7	1	1	1
11/18/2022 01:00	0.8	12.3	2,164.4	0.5	2.7	1	1	1
11/18/2022 02:00	0.8	12.2	2,166.7	0.5	2.6	1	1	1
11/18/2022 03:00	0.8	12.3	2,166.0	0.5	2.7	1	1	1
11/18/2022 04:00	0.6	11.6	2,308.1	0.5	2.0	1	1	1
11/18/2022 05:00	0.6	11.5	2,326.0	0.4	2.0	1	1	1
11/18/2022 06:00	0.6	11.5	2,333.1	0.4	2.0	1	1	1
11/18/2022 07:00	0.7	11.8	2,267.0	0.4	2.3	1	1	1
11/18/2022 08:00	0.8	12.3	2,145.7	0.5	2.6	1	1	1
11/18/2022 09:00	0.8	12.3	2,153.7	0.5	2.6	1	1	1
11/18/2022 10:00	0.7	12.2	2,162.8	0.5	2.3	1	1	1
11/18/2022 11:00	0.7	12.4	2,100.8	0.5	2.3	1	1	1
11/18/2022 12:00	0.8	13.1	1,958.4	0.5	2.7	1	1	1
11/18/2022 13:00	0.8	13.1	1,960.1	0.6	2.7	1	1	1
11/18/2022 14:00	0.8	13.0	1,964.5	0.6	2.6	1	1	1
11/18/2022 15:00	0.8	12.7	2,040.1	0.6	2.6	1	1	1
11/18/2022 16:00	0.7	12.0	2,220.5	0.6	2.3	1	1	1
11/18/2022 17:00	0.7	11.9	2,244.9	0.5	2.3	1	1	1
11/18/2022 18:00	0.7	11.9	2,243.3	0.5	2.3	1	1	1
11/18/2022 19:00	0.7	11.9	2,245.4	0.5	2.3	1	1	1
11/18/2022 20:00	0.7	11.8	2,276.3	0.5	2.3	1	1	1
11/18/2022 21:00	0.6	11.6	2,328.6	0.5	2.0	1	1	1
11/18/2022 22:00	0.6	11.6	2,341.0	0.4	2.0	1	1	1
11/18/2022 23:00	0.6	11.8	2,301.5	0.4	2.0	1	1	1
Average/Sum#:	0.7	12.1	2,190.7	0.5	56.9 #	24 #	24 #	24 #
Minimum:	0.6	11.5	1,958.4	0.4	2.0	1	1	1
Maximum:	0.8	13.1	2,341.0	0.6	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.8	12.3	2,163.6	0.4	2.7	1	1	1
11/19/2022 01:00	0.8	12.5	2,142.3	0.5	2.7	1	1	1
11/19/2022 02:00	0.8	12.5	2,139.1	0.6	2.7	1	1	1
11/19/2022 03:00	0.8	12.6	2,118.3	0.6	2.7	1	1	1
11/19/2022 04:00	0.8	12.1	2,231.5	0.6	2.7	1	1	1
11/19/2022 05:00	0.7	11.9	2,257.3	0.5	2.3	1	1	1
11/19/2022 06:00	0.8	12.3	2,191.6	0.5	2.7	1	1	1
11/19/2022 07:00	0.8	12.5	2,123.0	0.5	2.7	1	1	1
11/19/2022 08:00	1.1	13.2	1,963.6	0.6	3.7	1	1	1
11/19/2022 09:00	1.1	13.2	1,961.7	0.7	3.7	1	1	1
11/19/2022 10:00	1.1	13.2	1,956.6	0.8	3.7	1	1	1
11/19/2022 11:00	1.1	13.1	1,953.3	0.8	3.6	1	1	1
11/19/2022 12:00	1.0	13.1	1,953.3	0.8	3.3	1	1	1
11/19/2022 13:00	0.9	13.1	1,954.1	0.8	3.0	1	1	1
11/19/2022 14:00	0.9	13.1	1,960.9	0.7	3.0	1	1	1
11/19/2022 15:00	0.8	12.8	2,021.3	0.7	2.6	1	1	1
11/19/2022 16:00	0.7	12.2	2,156.6	0.6	2.3	1	1	1
11/19/2022 17:00	0.7	12.1	2,176.7	0.5	2.3	1	1	1
11/19/2022 18:00	0.7	12.2	2,169.1	0.5	2.3	1	1	1
11/19/2022 19:00	0.6	11.8	2,273.1	0.5	2.0	1	1	1
11/19/2022 20:00	0.6	11.6	2,305.7	0.4	2.0	1	1	1
11/19/2022 21:00	0.6	11.6	2,312.8	0.4	2.0	1	1	1
11/19/2022 22:00	0.7	11.7	2,340.7	0.4	2.4	1	1	1
11/19/2022 23:00	0.7	11.6	2,358.5	0.4	2.3	1	1	1
Average/Sum#:	0.8	12.4	2,132.7	0.6	65.4 #	24 #	24 #	24 #
Minimum:	0.6	11.6	1,953.3	0.4	2.0	1	1	1
Maximum:	1.1	13.2	2,358.5	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.8	12.0	2,254.8	0.4	2.7	1	1	1
11/20/2022 01:00	0.7	11.9	2,273.0	0.5	2.3	1	1	1
11/20/2022 02:00	0.7	11.8	2,301.3	0.5	2.3	1	1	1
11/20/2022 03:00	0.7	11.9	2,301.2	0.5	2.4	1	1	1
11/20/2022 04:00	0.7	11.9	2,306.4	0.5	2.4	1	1	1
11/20/2022 05:00	0.7	11.7	2,350.0	0.5	2.4	1	1	1
11/20/2022 06:00	0.8	12.1	2,254.5	0.5	2.7	1	1	1
11/20/2022 07:00	0.8	12.6	2,096.3	0.5	2.7	1	1	1
11/20/2022 08:00	0.3	13.8	1,722.3	0.4	1.0	1	1	0
11/20/2022 09:00	0.3	13.8	1,725.4	0.3	1.0	1	1	0
11/20/2022 10:00	0.3	13.8	1,571.5	0.2	0.9	1	1	0
11/20/2022 11:00	0.3	13.9	1,573.6	0.2	0.9	1	1	0
11/20/2022 12:00	0.3	13.9	1,545.9	0.3	0.9	1	1	0
11/20/2022 13:00	0.3	13.9	1,536.5	0.3	0.9	1	1	0
11/20/2022 14:00	0.3	13.8	1,695.0	0.3	0.9	1	1	0
11/20/2022 15:00	0.3	13.8	1,732.2	0.2	1.0	1	1	1
11/20/2022 16:00	0.8	12.3	2,147.2	0.3	2.6	1	1	1
11/20/2022 17:00	0.7	11.8	2,265.5	0.4	2.3	1	1	1
11/20/2022 18:00	0.7	11.8	2,252.2	0.5	2.3	1	1	1
11/20/2022 19:00	0.7	11.8	2,253.5	0.5	2.3	1	1	1
11/20/2022 20:00	0.7	11.8	2,257.4	0.5	2.3	1	1	1
11/20/2022 21:00	0.7	12.1	2,192.6	0.5	2.3	1	1	1
11/20/2022 22:00	0.8	12.4	2,157.4	0.5	2.7	1	1	1
11/20/2022 23:00	0.9	12.5	2,147.5	0.6	3.0	1	1	1
Average/Sum#:	0.6	12.6	2,038.1	0.4	47.2 #	24 #	24 #	17 #
Minimum:	0.3	11.7	1,536.5	0.2	0.9	1	1	0
Maximum:	0.9	13.9	2,350.0	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	0.8	12.4	2,156.8	0.6	2.7	1	1	1
11/21/2022 01:00	0.8	12.6	2,130.5	0.6	2.7	1	1	1
11/21/2022 02:00	1.0	12.9	2,058.0	0.6	3.4	1	1	1
11/21/2022 03:00	0.9	12.4	2,172.2	0.6	3.0	1	1	1
11/21/2022 04:00	0.8	12.0	2,259.2	0.6	2.7	1	1	1
11/21/2022 05:00	0.8	12.0	2,267.5	0.5	2.7	1	1	1
11/21/2022 06:00	0.8	12.0	2,284.4	0.5	2.7	1	1	1
11/21/2022 07:00	0.9	12.5	2,147.1	0.5	3.0	1	1	1
11/21/2022 08:00	1.2	13.2	1,965.1	0.7	4.0	1	1	1
11/21/2022 09:00	1.3	13.2	1,965.2	0.8	4.4	1	1	1
11/21/2022 10:00	1.2	13.2	1,961.7	0.9	4.0	1	1	1
11/21/2022 11:00	1.0	13.1	1,958.9	0.9	3.3	1	1	1
11/21/2022 12:00	0.9	13.0	1,966.2	0.8	3.0	1	1	1
11/21/2022 13:00	0.8	13.0	1,977.7	0.7	2.6	1	1	1
11/21/2022 14:00	0.8	12.2	2,161.3	0.6	2.6	1	1	1
11/21/2022 15:00	0.6	11.8	2,272.0	0.5	2.0	1	1	1
11/21/2022 16:00	0.8	12.0	2,229.0	0.5	2.6	1	1	1
11/21/2022 17:00	0.7	11.9	2,230.9	0.5	2.3	1	1	1
11/21/2022 18:00	0.7	11.9	2,230.5	0.5	2.3	1	1	1
11/21/2022 19:00	0.7	11.8	2,258.6	0.5	2.3	1	1	1
11/21/2022 20:00	0.7	11.8	2,263.5	0.5	2.3	1	1	1
11/21/2022 21:00	0.7	11.8	2,264.2	0.5	2.3	1	1	1
11/21/2022 22:00	0.7	11.8	2,264.8	0.5	2.3	1	1	1
11/21/2022 23:00	0.7	12.0	2,226.0	0.5	2.3	1	1	1
Average/Sum#:	0.8	12.4	2,153.0	0.6	67.5 #	24 #	24 #	24 #
Minimum:	0.6	11.8	1,958.9	0.5	2.0	1	1	1
Maximum:	1.3	13.2	2,284.4	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	0.8	12.4	2,143.9	0.5	2.7	1	1	1
11/22/2022 01:00	0.9	12.6	2,125.4	0.6	3.0	1	1	1
11/22/2022 02:00	0.9	12.6	2,094.4	0.6	3.0	1	1	1
11/22/2022 03:00	1.0	13.1	1,973.7	0.7	3.3	1	1	1
11/22/2022 04:00	1.1	13.1	1,977.2	0.7	3.7	1	1	1
11/22/2022 05:00	1.0	12.6	2,065.9	0.8	3.3	1	1	1
11/22/2022 06:00	0.9	12.5	2,149.0	0.7	3.0	1	1	1
11/22/2022 07:00	1.0	12.7	2,088.9	0.7	3.4	1	1	1
11/22/2022 08:00	1.1	12.9	2,051.0	0.7	3.7	1	1	1
11/22/2022 09:00	6.2	14.2	1,444.6	0.0	15.0	1	1	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/22/2022 11:00	1.0	19.5	58.0	0.0	0.1	1	1	0
11/22/2022 12:00	42.6	15.8	756.7	0.0	83.5	1	1	0
11/22/2022 13:00	0.4	13.8	1,622.5	0.0	1.2	1	1	0
11/22/2022 14:00	0.3	13.8	1,790.4	0.0	1.0	1	1	0
11/22/2022 15:00	0.3	13.8	1,790.4	0.2	1.0	1	1	0
11/22/2022 16:00	0.7	13.2	1,897.6	0.3	2.3	1	1	1
11/22/2022 17:00	0.9	12.3	2,141.8	0.4	3.0	1	1	1
11/22/2022 18:00	0.9	12.7	2,035.3	0.6	3.0	1	1	1
11/22/2022 19:00	1.0	13.0	1,982.5	0.6	3.3	1	1	1
11/22/2022 20:00	0.9	12.4	2,138.7	0.6	3.0	1	1	1
11/22/2022 21:00	1.0	12.9	2,017.6	0.7	3.3	1	1	1
11/22/2022 22:00	1.0	12.8	2,028.8	0.7	3.3	1	1	1
11/22/2022 23:00	1.2	13.2	1,957.5	0.8	4.0	1	1	1
Average/Sum#:	2.9	13.4	1,840.5	0.6	156.1 #	23 #	24 #	18 #
Minimum:	0.3	12.3	58.0	0.2	0.1	0	1	0
Maximum:	42.6	19.5	2,149.0	0.8	83.5	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.2	13.2	1,958.7	0.8	4.0	1	1	1
11/23/2022 01:00	1.2	13.2	1,960.6	0.9	4.0	1	1	1
11/23/2022 02:00	1.2	13.2	1,958.4	0.9	4.0	1	1	1
11/23/2022 03:00	1.2	13.2	1,962.5	0.9	4.0	1	1	1
11/23/2022 04:00	1.2	13.1	1,969.2	0.9	4.0	1	1	1
11/23/2022 05:00	0.9	12.5	2,057.1	0.8	2.9	1	1	1
11/23/2022 06:00	1.0	12.8	2,048.5	0.7	3.3	1	1	1
11/23/2022 07:00	0.9	12.6	2,103.9	0.6	3.0	1	1	1
11/23/2022 08:00	1.0	13.0	1,993.7	0.7	3.3	1	1	1
11/23/2022 09:00	0.3	13.8	1,707.7	0.5	1.0	1	1	0
11/23/2022 10:00	0.3	13.8	1,562.1	0.4	0.9	1	1	0
11/23/2022 11:00	0.3	13.9	1,556.2	0.2	0.9	1	1	0
11/23/2022 12:00	0.3	13.9	1,424.7	0.3	0.8	1	1	0
11/23/2022 13:00	0.3	13.9	1,558.7	0.3	0.9	1	1	0
11/23/2022 14:00	0.3	13.9	1,628.7	0.3	0.9	1	1	0
11/23/2022 15:00	0.3	13.8	1,649.5	0.3	0.9	1	1	1
11/23/2022 16:00	1.0	12.5	2,097.1	0.4	3.3	1	1	1
11/23/2022 17:00	0.9	12.3	2,159.6	0.5	3.0	1	1	1
11/23/2022 18:00	1.0	12.6	2,078.6	0.7	3.3	1	1	1
11/23/2022 19:00	1.1	12.8	2,045.2	0.7	3.7	1	1	1
11/23/2022 20:00	0.9	12.3	2,155.0	0.7	3.0	1	1	1
11/23/2022 21:00	0.9	12.2	2,168.6	0.7	3.0	1	1	1
11/23/2022 22:00	0.9	12.4	2,143.6	0.6	3.0	1	1	1
11/23/2022 23:00	0.9	12.4	2,140.6	0.6	3.0	1	1	1
Average/Sum#:	0.8	13.1	1,920.4	0.6	64.1 #	24 #	24 #	18 #
Minimum:	0.3	12.2	1,424.7	0.2	0.8	1	1	0
Maximum:	1.2	13.9	2,168.6	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.2	13.1	1,975.4	0.7	4.0	1	1	1
11/24/2022 01:00	1.4	13.2	1,962.5	0.9	4.7	1	1	1
11/24/2022 02:00	1.4	13.2	1,963.6	1.0	4.7	1	1	1
11/24/2022 03:00	1.0	13.0	1,975.0	1.0	3.3	1	1	1
11/24/2022 04:00	0.9	12.9	1,985.5	0.8	3.0	1	1	1
11/24/2022 05:00	0.9	12.5	2,052.9	0.7	2.9	1	1	1
11/24/2022 06:00	0.8	12.2	2,165.6	0.6	2.6	1	1	1
11/24/2022 07:00	0.8	12.5	2,079.4	0.6	2.6	1	1	1
11/24/2022 08:00	0.3	13.8	1,712.0	0.4	1.0	1	1	0
11/24/2022 09:00	0.3	13.8	1,709.0	0.3	1.0	1	1	0
11/24/2022 10:00	0.3	13.8	1,716.4	0.2	1.0	1	1	0
11/24/2022 11:00	0.3	13.9	1,560.1	0.2	0.9	1	1	0
11/24/2022 12:00	0.3	13.9	1,351.9	0.3	0.8	1	1	0
11/24/2022 13:00	0.3	13.9	1,350.9	0.3	0.8	1	1	0
11/24/2022 14:00	0.3	13.9	1,562.2	0.3	0.9	1	1	0
11/24/2022 15:00	0.3	13.9	1,450.2	0.3	0.8	1	1	0
11/24/2022 16:00	0.3	13.8	1,769.5	0.3	1.0	1	1	0
11/24/2022 17:00	0.3	13.8	1,768.6	0.2	1.0	1	1	0
11/24/2022 18:00	0.3	13.8	1,745.4	0.2	1.0	1	1	0
11/24/2022 19:00	0.3	13.8	1,737.1	0.2	1.0	1	1	0
11/24/2022 20:00	0.4	13.8	1,746.5	0.2	1.3	1	1	0
11/24/2022 21:00	0.4	13.8	1,747.1	0.3	1.3	1	1	0
11/24/2022 22:00	0.4	13.8	1,751.3	0.3	1.3	1	1	0
11/24/2022 23:00	0.4	13.8	1,753.2	0.3	1.3	1	1	0
Average/Sum#:	0.6	13.5	1,774.6	0.4	44.2 #	24 #	24 #	8 #
Minimum:	0.3	12.2	1,350.9	0.2	0.8	1	1	0
Maximum:	1.4	13.9	2,165.6	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.4	13.8	1,757.2	0.3	1.3	1	1	0
11/25/2022 01:00	0.4	13.8	1,758.4	0.3	1.3	1	1	0
11/25/2022 02:00	0.4	13.8	1,761.0	0.3	1.3	1	1	0
11/25/2022 03:00	0.4	13.8	1,764.3	0.3	1.3	1	1	0
11/25/2022 04:00	0.3	13.8	1,775.1	0.3	1.0	1	1	0
11/25/2022 05:00	0.4	13.8	1,771.2	0.3	1.3	1	1	0
11/25/2022 06:00	0.4	13.8	1,766.8	0.3	1.3	1	1	0
11/25/2022 07:00	0.4	13.8	1,766.8	0.3	1.3	1	1	0
11/25/2022 08:00	0.8	13.4	1,882.1	0.4	2.7	1	1	1
11/25/2022 09:00	0.9	13.1	1,919.7	0.5	2.9	1	1	1
11/25/2022 10:00	0.3	13.8	1,668.0	0.5	0.9	1	1	0
11/25/2022 11:00	0.4	13.8	1,549.0	0.4	1.2	1	1	0
11/25/2022 12:00	0.3	13.8	1,574.7	0.2	0.9	1	1	0
11/25/2022 13:00	0.3	13.8	1,543.3	0.2	0.9	1	1	0
11/25/2022 14:00	0.4	13.8	1,531.6	0.2	1.1	1	1	0
11/25/2022 15:00	0.4	13.7	1,644.3	0.3	1.2	1	1	1
11/25/2022 16:00	1.0	12.6	2,082.1	0.4	3.3	1	1	1
11/25/2022 17:00	0.9	12.5	2,096.7	0.5	3.0	1	1	1
11/25/2022 18:00	1.0	13.0	1,970.2	0.7	3.3	1	1	1
11/25/2022 19:00	1.1	13.1	1,955.6	0.7	3.6	1	1	1
11/25/2022 20:00	1.1	13.1	1,955.0	0.8	3.6	1	1	1
11/25/2022 21:00	1.2	13.1	1,966.3	0.8	4.0	1	1	1
11/25/2022 22:00	0.9	12.5	2,118.6	0.8	3.0	1	1	1
11/25/2022 23:00	0.9	12.6	2,080.0	0.7	3.0	1	1	1
Average/Sum#:	0.6	13.4	1,819.1	0.4	48.7 #	24 #	24 #	11 #
Minimum:	0.3	12.5	1,531.6	0.2	0.9	1	1	0
Maximum:	1.2	13.8	2,118.6	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.0	12.9	2,016.8	0.6	3.3	1	1	1
11/26/2022 01:00	1.0	12.7	2,062.0	0.7	3.3	1	1	1
11/26/2022 02:00	5.6	13.8	1,575.4	0.0	16.4	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.5	13.1	1,884.7	0.7	23.0 #	3 #	2 #	3 #
Minimum:	1.0	12.7	1,575.4	0.6	3.3	0	0	0
Maximum:	5.6	13.8	2,062.0	0.7	16.4	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/28/2022 02:00	54.8	17.4	344.2	0.0	67.6	1	1	0
11/28/2022 03:00	28.0	15.2	949.6	0.0	61.6	1	1	0
11/28/2022 04:00	0.4	13.7	1,724.6	0.0	1.3	1	1	0
11/28/2022 05:00	0.5	13.7	1,654.5	0.0	1.5	1	1	1
11/28/2022 06:00	1.1	12.5	2,164.7	0.5	3.7	1	1	1
11/28/2022 07:00	0.9	12.0	2,260.4	0.6	3.0	1	1	1
11/28/2022 08:00	1.0	13.0	1,970.9	0.7	3.3	1	1	1
11/28/2022 09:00	0.4	13.8	1,613.8	0.5	1.2	1	1	0
11/28/2022 10:00	0.4	13.8	1,719.0	0.4	1.3	1	1	0
11/28/2022 11:00	0.4	13.8	1,526.4	0.3	1.1	1	1	0
11/28/2022 12:00	0.3	13.8	1,571.0	0.3	0.9	1	1	0
11/28/2022 13:00	0.3	13.8	1,644.0	0.2	0.9	1	1	0
11/28/2022 14:00	0.3	13.8	1,627.3	0.2	0.9	1	1	0
11/28/2022 15:00	0.4	13.7	1,623.7	0.2	1.2	1	1	1
11/28/2022 16:00	1.0	12.8	2,023.4	0.4	3.3	1	1	1
11/28/2022 17:00	0.9	12.5	2,090.0	0.5	3.0	1	1	1
11/28/2022 18:00	0.9	13.0	1,980.4	0.7	3.0	1	1	1
11/28/2022 19:00	1.1	13.1	1,958.5	0.7	3.6	1	1	1
11/28/2022 20:00	1.0	12.7	2,080.3	0.7	3.4	1	1	1
11/28/2022 21:00	0.8	12.1	2,212.4	0.7	2.7	1	1	1
11/28/2022 22:00	0.9	12.7	2,084.2	0.6	3.0	1	1	1
11/28/2022 23:00	1.0	13.1	1,981.7	0.6	3.4	1	1	1
Average/Sum#:	4.4	13.5	1,763.9	0.5	174.9 #	22 #	24 #	13 #
Minimum:	0.3	12.0	344.2	0.2	0.9	0	1	0
Maximum:	54.8	17.4	2,260.4	0.7	67.6	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.9	12.4	2,141.8	0.7	3.0	1	1	1
11/29/2022 01:00	0.9	12.3	2,186.9	0.7	3.0	1	1	1
11/29/2022 02:00	0.9	12.3	2,175.4	0.6	3.0	1	1	1
11/29/2022 03:00	1.0	12.7	2,087.1	0.6	3.4	1	1	1
11/29/2022 04:00	0.9	12.5	2,149.0	0.6	3.0	1	1	1
11/29/2022 05:00	0.9	12.3	2,196.7	0.6	3.0	1	1	1
11/29/2022 06:00	0.8	11.9	2,281.7	0.6	2.7	1	1	1
11/29/2022 07:00	0.8	11.9	2,281.4	0.5	2.7	1	1	1
11/29/2022 08:00	0.8	11.9	2,244.1	0.5	2.6	1	1	1
11/29/2022 09:00	0.8	12.3	2,150.7	0.5	2.6	1	1	1
11/29/2022 10:00	0.8	12.3	2,145.0	0.5	2.6	1	1	1
11/29/2022 11:00	0.8	12.3	2,136.9	0.5	2.6	1	1	1
11/29/2022 12:00	0.8	12.3	2,126.6	0.5	2.6	1	1	1
11/29/2022 13:00	0.8	12.3	2,125.1	0.5	2.6	1	1	1
11/29/2022 14:00	0.8	12.3	2,128.4	0.5	2.6	1	1	1
11/29/2022 15:00	0.8	12.3	2,146.5	0.5	2.6	1	1	1
11/29/2022 16:00	0.7	11.8	2,253.8	0.5	2.3	1	1	1
11/29/2022 17:00	0.7	11.8	2,262.7	0.5	2.3	1	1	1
11/29/2022 18:00	0.7	11.8	2,269.7	0.5	2.3	1	1	1
11/29/2022 19:00	0.7	11.8	2,270.4	0.5	2.3	1	1	1
11/29/2022 20:00	0.8	11.9	2,275.0	0.5	2.7	1	1	1
11/29/2022 21:00	0.8	11.9	2,279.4	0.5	2.7	1	1	1
11/29/2022 22:00	0.8	11.9	2,281.0	0.5	2.7	1	1	1
11/29/2022 23:00	0.8	11.9	2,279.2	0.5	2.7	1	1	1
Average/Sum#:	0.8	12.1	2,203.1	0.5	64.6 #	24 #	24 #	24 #
Minimum:	0.7	11.8	2,087.1	0.5	2.3	1	1	1
Maximum:	1.0	12.7	2,281.7	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	0.9	12.5	2,172.7	0.5	3.1	1	1	1
11/30/2022 01:00	0.9	12.5	2,154.2	0.6	3.0	1	1	1
11/30/2022 02:00	0.9	12.5	2,150.7	0.6	3.0	1	1	1
11/30/2022 03:00	0.9	12.5	2,151.7	0.6	3.0	1	1	1
11/30/2022 04:00	0.9	12.5	2,168.0	0.6	3.1	1	1	1
11/30/2022 05:00	1.0	12.5	2,165.1	0.6	3.4	1	1	1
11/30/2022 06:00	0.9	12.1	2,258.1	0.6	3.1	1	1	1
11/30/2022 07:00	0.9	12.5	2,146.1	0.6	3.0	1	1	1
11/30/2022 08:00	1.3	13.2	1,980.7	0.7	4.4	1	1	1
11/30/2022 09:00	1.3	13.1	1,994.5	0.9	4.4	1	1	1
11/30/2022 10:00	1.2	13.2	1,971.3	1.0	4.1	1	1	1
11/30/2022 11:00	1.2	13.1	1,965.9	0.9	4.0	1	1	1
11/30/2022 12:00	1.2	13.1	1,966.2	0.9	4.0	1	1	1
11/30/2022 13:00	1.1	13.0	1,964.4	0.9	3.6	1	1	1
11/30/2022 14:00	0.9	12.4	2,104.4	0.8	2.9	1	1	1
11/30/2022 15:00	0.9	12.3	2,113.2	0.7	2.9	1	1	1
11/30/2022 16:00	0.8	11.9	2,217.4	0.6	2.6	1	1	1
11/30/2022 17:00	0.7	11.7	2,265.7	0.5	2.3	1	1	1
11/30/2022 18:00	0.7	11.7	2,264.2	0.4	2.3	1	1	1
11/30/2022 19:00	0.7	11.7	2,263.8	0.4	2.3	1	1	1
11/30/2022 20:00	0.7	11.8	2,258.6	0.4	2.3	1	1	1
11/30/2022 21:00	0.8	11.9	2,224.8	0.5	2.6	1	1	1
11/30/2022 22:00	0.9	12.5	2,086.6	0.5	3.0	1	1	1
11/30/2022 23:00	5.9	13.7	1,584.9	0.0	17.2	1	0	1
Average/Sum#:	1.2	12.5	2,108.1	0.6	89.6 #	24 #	23 #	24 #
Minimum:	0.7	11.7	1,584.9	0.4	2.3	1	0	1
Maximum:	5.9	13.7	2,265.7	1.0	17.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	20 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 09:00	115.0	20.2	1.9	0.0	0.5	1	1	0
12/05/2022 10:00	62.0	16.6	470.2	0.0	89.5	1	1	0
12/05/2022 11:00	2.2	13.2	1,793.9	0.0	6.8	1	1	1
12/05/2022 12:00	0.9	12.2	2,140.7	0.0	2.9	1	1	1
12/05/2022 13:00	0.9	12.7	2,012.1	0.0	2.9	1	1	1
12/05/2022 14:00	0.9	12.7	2,032.3	0.6	2.9	1	1	1
12/05/2022 15:00	0.8	12.6	2,051.5	0.6	2.6	1	1	1
12/05/2022 16:00	0.8	12.0	2,193.6	0.6	2.6	1	1	1
12/05/2022 17:00	0.7	11.7	2,269.5	0.5	2.3	1	1	1
12/05/2022 18:00	0.7	11.7	2,271.5	0.4	2.3	1	1	1
12/05/2022 19:00	0.7	11.7	2,271.1	0.4	2.3	1	1	1
12/05/2022 20:00	0.8	11.8	2,272.1	0.4	2.6	1	1	1
12/05/2022 21:00	0.8	12.1	2,201.5	0.5	2.6	1	1	1
12/05/2022 22:00	1.0	12.7	2,067.0	0.6	3.3	1	1	1
12/05/2022 23:00	1.0	12.8	2,045.9	0.6	3.3	1	1	1
Average/Sum#:	12.6	13.1	1,873.0	0.5	129.4 #	15 #	24 #	13 #
Minimum:	0.7	11.7	1.9	0.4	0.5	0	1	0
Maximum:	115.0	20.2	2,272.1	0.6	89.5	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	1.2	13.2	1,967.2	0.8	4.0	1	1	1
12/06/2022 01:00	1.3	13.2	1,966.1	0.9	4.4	1	1	1
12/06/2022 02:00	1.3	13.2	1,965.7	1.0	4.4	1	1	1
12/06/2022 03:00	1.3	13.2	1,967.0	1.0	4.4	1	1	1
12/06/2022 04:00	1.2	13.1	1,982.2	1.0	4.0	1	1	1
12/06/2022 05:00	1.0	12.9	2,009.3	0.9	3.3	1	1	1
12/06/2022 06:00	1.2	13.1	1,982.0	0.8	4.0	1	1	1
12/06/2022 07:00	1.0	12.7	2,084.6	0.8	3.4	1	1	1
12/06/2022 08:00	0.9	11.9	2,259.2	0.7	3.0	1	1	1
12/06/2022 09:00	0.8	12.0	2,240.1	0.6	2.7	1	1	1
12/06/2022 10:00	0.8	12.0	2,234.8	0.5	2.7	1	1	1
12/06/2022 11:00	0.8	12.0	2,230.6	0.5	2.6	1	1	1
12/06/2022 12:00	0.8	12.0	2,217.9	0.5	2.6	1	1	1
12/06/2022 13:00	0.4	13.6	1,788.8	0.4	1.3	1	1	1
12/06/2022 14:00	0.4	13.9	1,318.8	0.4	1.0	1	1	0
12/06/2022 15:00	0.4	13.9	1,318.6	0.3	1.0	1	1	0
12/06/2022 16:00	0.4	13.8	1,520.8	0.3	1.1	1	1	0
12/06/2022 17:00	0.3	13.7	1,823.5	0.3	1.0	1	1	0
12/06/2022 18:00	0.3	13.7	1,825.1	0.2	1.0	1	1	0
12/06/2022 19:00	0.4	13.7	1,829.3	0.2	1.3	1	1	1
12/06/2022 20:00	1.0	12.5	2,123.4	0.4	3.3	1	1	1
12/06/2022 21:00	0.8	12.0	2,220.9	0.5	2.6	1	1	1
12/06/2022 22:00	0.9	12.5	2,096.6	0.6	3.0	1	1	1
12/06/2022 23:00	1.0	13.2	1,968.7	0.6	3.4	1	1	1
Average/Sum#:	0.8	13.0	1,955.9	0.6	65.5 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,318.6	0.2	1.0	1	1	0
Maximum:	1.3	13.9	2,259.2	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.9	12.7	2,080.4	0.7	3.0	1	1	1
12/07/2022 01:00	1.0	13.1	1,983.5	0.7	3.4	1	1	1
12/07/2022 02:00	0.9	12.5	2,133.1	0.7	3.0	1	1	1
12/07/2022 03:00	0.9	12.5	2,140.6	0.7	3.0	1	1	1
12/07/2022 04:00	0.9	12.4	2,147.2	0.6	3.0	1	1	1
12/07/2022 05:00	0.9	12.3	2,161.2	0.6	3.0	1	1	1
12/07/2022 06:00	0.9	12.1	2,240.0	0.6	3.0	1	1	1
12/07/2022 07:00	0.8	12.0	2,240.5	0.6	2.7	1	1	1
12/07/2022 08:00	0.9	12.6	2,123.6	0.6	3.0	1	1	1
12/07/2022 09:00	0.9	12.5	2,160.5	0.6	3.1	1	1	1
12/07/2022 10:00	0.9	12.4	2,154.7	0.6	3.0	1	1	1
12/07/2022 11:00	0.9	12.4	2,152.0	0.6	3.0	1	1	1
12/07/2022 12:00	0.9	12.5	2,125.4	0.6	3.0	1	1	1
12/07/2022 13:00	0.8	12.5	2,105.1	0.6	2.6	1	1	1
12/07/2022 14:00	0.9	12.7	2,045.2	0.6	3.0	1	1	1
12/07/2022 15:00	0.9	12.6	2,072.9	0.6	3.0	1	1	1
12/07/2022 16:00	0.8	11.9	2,242.3	0.6	2.6	1	1	1
12/07/2022 17:00	0.8	11.8	2,263.1	0.5	2.6	1	1	1
12/07/2022 18:00	0.8	11.9	2,262.6	0.5	2.7	1	1	1
12/07/2022 19:00	0.8	11.9	2,259.5	0.5	2.7	1	1	1
12/07/2022 20:00	0.8	11.9	2,260.4	0.5	2.7	1	1	1
12/07/2022 21:00	0.8	12.0	2,254.9	0.5	2.7	1	1	1
12/07/2022 22:00	0.9	12.4	2,171.8	0.5	3.0	1	1	1
12/07/2022 23:00	0.9	12.4	2,171.2	0.6	3.0	1	1	1
Average/Sum#:	0.9	12.3	2,164.7	0.6	69.8 #	24 #	24 #	24 #
Minimum:	0.8	11.8	1,983.5	0.5	2.6	1	1	1
Maximum:	1.0	13.1	2,263.1	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.9	12.6	2,128.3	0.6	3.0	1	1	1
12/08/2022 01:00	0.9	12.6	2,124.0	0.6	3.0	1	1	1
12/08/2022 02:00	0.9	12.6	2,125.4	0.6	3.0	1	1	1
12/08/2022 03:00	0.9	12.6	2,126.6	0.6	3.0	1	1	1
12/08/2022 04:00	0.9	12.5	2,151.8	0.6	3.0	1	1	1
12/08/2022 05:00	1.0	12.1	2,206.3	0.6	3.3	1	1	1
12/08/2022 06:00	0.9	12.0	2,276.7	0.6	3.0	1	1	1
12/08/2022 07:00	0.9	12.2	2,235.9	0.6	3.1	1	1	1
12/08/2022 08:00	1.1	13.0	2,033.3	0.7	3.7	1	1	1
12/08/2022 09:00	1.0	12.7	2,119.8	0.7	3.4	1	1	1
12/08/2022 10:00	0.9	12.6	2,125.2	0.7	3.0	1	1	1
12/08/2022 11:00	0.9	12.5	2,152.4	0.6	3.0	1	1	1
12/08/2022 12:00	0.9	12.4	2,146.3	0.6	3.0	1	1	1
12/08/2022 13:00	0.9	12.3	2,151.6	0.6	3.0	1	1	1
12/08/2022 14:00	0.9	12.3	2,154.1	0.6	3.0	1	1	1
12/08/2022 15:00	0.9	12.3	2,161.0	0.6	3.0	1	1	1
12/08/2022 16:00	0.8	11.8	2,252.5	0.6	2.6	1	1	1
12/08/2022 17:00	0.8	11.9	2,253.7	0.5	2.6	1	1	1
12/08/2022 18:00	0.8	11.8	2,260.9	0.5	2.6	1	1	1
12/08/2022 19:00	0.8	11.8	2,258.9	0.5	2.6	1	1	1
12/08/2022 20:00	0.8	11.8	2,260.5	0.5	2.6	1	1	1
12/08/2022 21:00	0.8	11.8	2,262.3	0.5	2.6	1	1	1
12/08/2022 22:00	0.9	12.2	2,175.3	0.5	3.0	1	1	1
12/08/2022 23:00	0.9	12.3	2,175.7	0.6	3.0	1	1	1
Average/Sum#:	0.9	12.3	2,179.9	0.6	71.1 #	24 #	24 #	24 #
Minimum:	0.8	11.8	2,033.3	0.5	2.6	1	1	1
Maximum:	1.1	13.0	2,276.7	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	0.9	12.4	2,133.4	0.6	3.0	1	1	1
12/09/2022 01:00	1.0	12.9	2,049.3	0.6	3.4	1	1	1
12/09/2022 02:00	0.9	12.5	2,145.6	0.6	3.0	1	1	1
12/09/2022 03:00	0.9	12.5	2,141.8	0.6	3.0	1	1	1
12/09/2022 04:00	0.9	12.3	2,188.2	0.6	3.0	1	1	1
12/09/2022 05:00	0.9	11.9	2,279.0	0.6	3.0	1	1	1
12/09/2022 06:00	0.9	11.9	2,284.6	0.6	3.0	1	1	1
12/09/2022 07:00	0.9	12.0	2,273.6	0.6	3.0	1	1	1
12/09/2022 08:00	1.1	12.8	2,069.7	0.7	3.7	1	1	1
12/09/2022 09:00	1.1	13.0	2,024.0	0.7	3.7	1	1	1
12/09/2022 10:00	1.3	13.2	1,975.9	0.9	4.4	1	1	1
12/09/2022 11:00	1.0	12.8	2,071.4	0.8	3.4	1	1	1
12/09/2022 12:00	1.1	13.0	2,003.4	0.8	3.7	1	1	1
12/09/2022 13:00	0.9	12.4	2,147.1	0.7	3.0	1	1	1
12/09/2022 14:00	0.9	12.4	2,137.6	0.7	3.0	1	1	1
12/09/2022 15:00	1.1	12.8	2,036.0	0.7	3.7	1	1	1
12/09/2022 16:00	0.8	11.9	2,251.5	0.6	2.6	1	1	1
12/09/2022 17:00	0.8	11.9	2,251.1	0.6	2.6	1	1	1
12/09/2022 18:00	0.8	11.9	2,251.7	0.5	2.6	1	1	1
12/09/2022 19:00	0.8	11.9	2,253.6	0.5	2.6	1	1	1
12/09/2022 20:00	0.8	11.9	2,258.2	0.5	2.7	1	1	1
12/09/2022 21:00	0.8	11.9	2,257.3	0.5	2.6	1	1	1
12/09/2022 22:00	0.8	11.9	2,255.6	0.5	2.6	1	1	1
12/09/2022 23:00	0.8	11.9	2,249.1	0.5	2.6	1	1	1
Average/Sum#:	0.9	12.3	2,166.2	0.6	73.9 #	24 #	24 #	24 #
Minimum:	0.8	11.9	1,975.9	0.5	2.6	1	1	1
Maximum:	1.3	13.2	2,284.6	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.1	12.9	2,006.4	0.6	3.6	1	1	1
12/10/2022 01:00	1.1	12.9	1,999.6	0.7	3.6	1	1	1
12/10/2022 02:00	1.2	13.1	1,963.4	0.8	4.0	1	1	1
12/10/2022 03:00	1.2	13.0	1,964.2	0.9	3.9	1	1	1
12/10/2022 04:00	1.2	13.0	1,959.0	0.9	3.9	1	1	1
12/10/2022 05:00	1.2	12.9	1,970.7	0.9	3.9	1	1	1
12/10/2022 06:00	1.3	13.0	1,958.3	0.9	4.3	1	1	1
12/10/2022 07:00	1.3	13.0	1,965.3	1.0	4.3	1	1	1
12/10/2022 08:00	1.1	12.8	2,005.5	0.9	3.6	1	1	1
12/10/2022 09:00	1.2	12.9	1,981.7	0.9	3.9	1	1	1
12/10/2022 10:00	1.3	13.0	1,958.2	0.9	4.3	1	1	1
12/10/2022 11:00	1.1	12.7	2,001.0	0.9	3.5	1	1	1
12/10/2022 12:00	0.9	12.3	2,097.7	0.8	2.9	1	1	1
12/10/2022 13:00	0.8	12.0	2,155.9	0.6	2.6	1	1	1
12/10/2022 14:00	0.9	12.6	2,002.4	0.6	2.9	1	1	1
12/10/2022 15:00	0.9	12.6	2,024.6	0.6	2.9	1	1	1
12/10/2022 16:00	0.9	12.3	2,094.2	0.6	2.9	1	1	1
12/10/2022 17:00	0.9	12.5	2,057.1	0.6	2.9	1	1	1
12/10/2022 18:00	1.0	12.5	2,058.1	0.6	3.2	1	1	1
12/10/2022 19:00	0.8	11.8	2,229.9	0.6	2.6	1	1	1
12/10/2022 20:00	0.8	12.1	2,153.8	0.6	2.6	1	1	1
12/10/2022 21:00	0.9	12.5	2,068.8	0.5	2.9	1	1	1
12/10/2022 22:00	1.0	12.8	2,009.3	0.6	3.3	1	1	1
12/10/2022 23:00	0.9	12.5	2,063.5	0.6	2.9	1	1	1
Average/Sum#:	1.0	12.7	2,031.2	0.7	81.4 #	24 #	24 #	24 #
Minimum:	0.8	11.8	1,958.2	0.5	2.6	1	1	1
Maximum:	1.3	13.1	2,229.9	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.1	13.0	1,956.5	0.7	3.6	1	1	1
12/11/2022 01:00	1.2	13.1	1,954.5	0.8	4.0	1	1	1
12/11/2022 02:00	1.2	13.1	1,954.5	0.9	4.0	1	1	1
12/11/2022 03:00	1.2	13.1	1,953.0	0.9	4.0	1	1	1
12/11/2022 04:00	1.3	13.1	1,955.4	0.9	4.3	1	1	1
12/11/2022 05:00	1.3	13.1	1,956.0	1.0	4.3	1	1	1
12/11/2022 06:00	1.3	13.1	1,958.5	1.0	4.3	1	1	1
12/11/2022 07:00	1.3	13.1	1,960.5	1.0	4.3	1	1	1
12/11/2022 08:00	1.3	13.1	1,961.5	1.0	4.3	1	1	1
12/11/2022 09:00	1.3	13.1	1,964.5	1.0	4.3	1	1	1
12/11/2022 10:00	1.3	13.1	1,963.7	1.0	4.3	1	1	1
12/11/2022 11:00	1.2	13.1	1,959.8	1.0	4.0	1	1	1
12/11/2022 12:00	1.2	13.1	1,958.4	0.9	4.0	1	1	1
12/11/2022 13:00	1.2	13.0	1,960.6	0.9	3.9	1	1	1
12/11/2022 14:00	1.2	13.0	1,958.2	0.9	3.9	1	1	1
12/11/2022 15:00	1.0	12.7	2,050.1	0.8	3.3	1	1	1
12/11/2022 16:00	1.0	12.7	2,053.8	0.8	3.3	1	1	1
12/11/2022 17:00	0.9	12.4	2,123.8	0.7	3.0	1	1	1
12/11/2022 18:00	1.1	12.9	2,040.4	0.7	3.7	1	1	1
12/11/2022 19:00	1.0	12.8	2,068.4	0.7	3.4	1	1	1
12/11/2022 20:00	1.0	12.6	2,119.1	0.7	3.4	1	1	1
12/11/2022 21:00	1.2	13.1	2,002.7	0.8	4.1	1	1	1
12/11/2022 22:00	1.3	13.2	1,968.1	0.9	4.4	1	1	1
12/11/2022 23:00	1.3	13.2	1,965.9	1.0	4.4	1	1	1
Average/Sum#:	1.2	13.0	1,990.3	0.9	94.5 #	24 #	24 #	24 #
Minimum:	0.9	12.4	1,953.0	0.7	3.0	1	1	1
Maximum:	1.3	13.2	2,123.8	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.3	13.2	1,974.6	1.0	4.4	1	1	1
12/12/2022 01:00	1.3	13.2	1,974.7	1.0	4.4	1	1	1
12/12/2022 02:00	1.3	13.2	1,974.6	1.0	4.4	1	1	1
12/12/2022 03:00	1.3	13.2	1,972.4	1.0	4.4	1	1	1
12/12/2022 04:00	1.3	13.2	1,975.3	1.0	4.4	1	1	1
12/12/2022 05:00	1.0	12.4	2,111.2	0.9	3.3	1	1	1
12/12/2022 06:00	0.9	12.3	2,205.4	0.8	3.0	1	1	1
12/12/2022 07:00	0.9	12.3	2,187.8	0.6	3.0	1	1	1
12/12/2022 08:00	1.1	12.8	2,074.1	0.7	3.7	1	1	1
12/12/2022 09:00	1.0	12.8	2,066.2	0.7	3.4	1	1	1
12/12/2022 10:00	1.3	13.2	1,973.4	0.8	4.4	1	1	1
12/12/2022 11:00	1.3	13.2	1,968.1	0.9	4.4	1	1	1
12/12/2022 12:00	1.3	13.2	1,964.0	1.0	4.4	1	1	1
12/12/2022 13:00	1.2	13.1	1,961.0	1.0	4.0	1	1	1
12/12/2022 14:00	1.2	13.1	1,953.7	0.9	4.0	1	1	1
12/12/2022 15:00	1.2	13.1	1,956.5	0.9	4.0	1	1	1
12/12/2022 16:00	0.9	12.4	2,131.9	0.8	3.0	1	1	1
12/12/2022 17:00	0.8	12.0	2,216.3	0.7	2.6	1	1	1
12/12/2022 18:00	0.7	11.8	2,275.3	0.5	2.3	1	1	1
12/12/2022 19:00	0.7	11.8	2,277.0	0.5	2.3	1	1	1
12/12/2022 20:00	0.7	11.8	2,281.0	0.5	2.3	1	1	1
12/12/2022 21:00	0.8	12.0	2,246.6	0.5	2.7	1	1	1
12/12/2022 22:00	0.8	12.3	2,188.8	0.5	2.7	1	1	1
12/12/2022 23:00	1.0	13.0	2,025.1	0.6	3.4	1	1	1
Average/Sum#:	1.1	12.7	2,080.6	0.8	84.9 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,953.7	0.5	2.3	1	1	1
Maximum:	1.3	13.2	2,281.0	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.9	12.6	2,151.0	0.6	3.1	1	1	1
12/13/2022 01:00	0.9	12.5	2,157.4	0.6	3.1	1	1	1
12/13/2022 02:00	0.9	12.4	2,161.4	0.6	3.0	1	1	1
12/13/2022 03:00	0.9	12.5	2,146.4	0.6	3.0	1	1	1
12/13/2022 04:00	0.9	12.4	2,189.1	0.6	3.1	1	1	1
12/13/2022 05:00	0.9	12.0	2,273.8	0.6	3.0	1	1	1
12/13/2022 06:00	0.8	11.9	2,310.2	0.6	2.7	1	1	1
12/13/2022 07:00	0.8	11.9	2,287.8	0.5	2.7	1	1	1
12/13/2022 08:00	0.9	12.5	2,134.0	0.5	3.0	1	1	1
12/13/2022 09:00	1.1	13.0	2,010.3	0.6	3.7	1	1	1
12/13/2022 10:00	1.2	13.2	1,963.5	0.8	4.0	1	1	1
12/13/2022 11:00	1.2	13.2	1,966.2	0.9	4.0	1	1	1
12/13/2022 12:00	1.2	13.1	1,963.9	0.9	4.0	1	1	1
12/13/2022 13:00	1.2	13.1	1,958.8	0.9	4.0	1	1	1
12/13/2022 14:00	1.2	13.1	1,948.4	0.9	4.0	1	1	1
12/13/2022 15:00	1.0	12.7	2,055.9	0.8	3.3	1	1	1
12/13/2022 16:00	0.7	11.9	2,251.4	0.7	2.3	1	1	1
12/13/2022 17:00	0.7	11.8	2,271.2	0.6	2.3	1	1	1
12/13/2022 18:00	0.7	11.8	2,273.1	0.5	2.3	1	1	1
12/13/2022 19:00	0.7	11.9	2,270.7	0.5	2.3	1	1	1
12/13/2022 20:00	0.8	11.9	2,269.3	0.5	2.7	1	1	1
12/13/2022 21:00	0.8	12.0	2,274.0	0.5	2.7	1	1	1
12/13/2022 22:00	0.8	12.0	2,272.2	0.5	2.7	1	1	1
12/13/2022 23:00	0.8	11.9	2,268.0	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.4	2,159.5	0.6	73.7 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,948.4	0.5	2.3	1	1	1
Maximum:	1.2	13.2	2,310.2	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.8	12.3	2,186.8	0.5	2.7	1	1	1
12/14/2022 01:00	0.9	12.4	2,187.5	0.5	3.1	1	1	1
12/14/2022 02:00	0.9	12.4	2,188.4	0.6	3.1	1	1	1
12/14/2022 03:00	0.9	12.4	2,189.7	0.6	3.1	1	1	1
12/14/2022 04:00	0.9	12.4	2,186.4	0.6	3.1	1	1	1
12/14/2022 05:00	0.9	12.0	2,291.8	0.6	3.1	1	1	1
12/14/2022 06:00	0.8	12.0	2,297.1	0.6	2.7	1	1	1
12/14/2022 07:00	0.8	12.1	2,255.1	0.5	2.7	1	1	1
12/14/2022 08:00	1.0	12.9	2,069.6	0.6	3.4	1	1	1
12/14/2022 09:00	1.1	13.1	2,007.9	0.7	3.7	1	1	1
12/14/2022 10:00	1.0	13.0	2,023.9	0.7	3.4	1	1	1
12/14/2022 11:00	1.1	13.2	1,967.4	0.8	3.7	1	1	1
12/14/2022 12:00	1.2	13.2	1,967.7	0.8	4.0	1	1	1
12/14/2022 13:00	1.1	13.2	1,966.4	0.8	3.7	1	1	1
12/14/2022 14:00	1.1	13.2	1,961.9	0.8	3.7	1	1	1
12/14/2022 15:00	1.1	13.0	2,003.9	0.8	3.7	1	1	1
12/14/2022 16:00	0.8	12.2	2,196.7	0.7	2.7	1	1	1
12/14/2022 17:00	0.8	11.9	2,270.2	0.6	2.7	1	1	1
12/14/2022 18:00	0.8	11.9	2,263.7	0.5	2.7	1	1	1
12/14/2022 19:00	0.8	11.9	2,270.0	0.5	2.7	1	1	1
12/14/2022 20:00	0.8	11.9	2,269.8	0.5	2.7	1	1	1
12/14/2022 21:00	0.8	12.0	2,270.9	0.5	2.7	1	1	1
12/14/2022 22:00	0.8	12.1	2,250.1	0.5	2.7	1	1	1
12/14/2022 23:00	0.8	12.4	2,172.6	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,154.8	0.6	74.5 #	24 #	24 #	24 #
Minimum:	0.8	11.9	1,961.9	0.5	2.7	1	1	1
Maximum:	1.2	13.2	2,297.1	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0.8	11.9	2,285.2	0.5	2.7	1	1	1
12/15/2022 01:00	0.8	11.9	2,294.2	0.5	2.7	1	1	1
12/15/2022 02:00	0.7	11.9	2,295.1	0.5	2.4	1	1	1
12/15/2022 03:00	0.8	11.9	2,296.8	0.5	2.7	1	1	1
12/15/2022 04:00	0.7	11.9	2,302.4	0.5	2.4	1	1	1
12/15/2022 05:00	0.7	11.8	2,305.6	0.5	2.3	1	1	1
12/15/2022 06:00	0.7	11.8	2,303.9	0.5	2.3	1	1	1
12/15/2022 07:00	0.7	11.9	2,297.7	0.5	2.4	1	1	1
12/15/2022 08:00	0.7	12.2	2,216.9	0.5	2.4	1	1	1
12/15/2022 09:00	0.8	12.1	2,210.5	0.5	2.7	1	1	1
12/15/2022 10:00	1.0	13.1	1,975.6	0.6	3.3	1	1	1
12/15/2022 11:00	1.0	13.0	1,984.0	0.7	3.3	1	1	1
12/15/2022 12:00	0.9	12.8	2,010.5	0.7	3.0	1	1	1
12/15/2022 13:00	0.9	12.8	2,027.3	0.7	3.0	1	1	1
12/15/2022 14:00	0.7	12.5	2,076.8	0.6	2.3	1	1	1
12/15/2022 15:00	0.7	11.9	2,224.3	0.6	2.3	1	1	1
12/15/2022 16:00	0.6	11.9	2,242.6	0.5	2.0	1	1	1
12/15/2022 17:00	0.7	11.9	2,240.4	0.5	2.3	1	1	1
12/15/2022 18:00	0.7	12.0	2,233.1	0.5	2.3	1	1	1
12/15/2022 19:00	0.8	12.0	2,230.3	0.5	2.6	1	1	1
12/15/2022 20:00	0.7	12.0	2,232.7	0.5	2.3	1	1	1
12/15/2022 21:00	0.8	12.1	2,238.4	0.5	2.7	1	1	1
12/15/2022 22:00	0.8	12.1	2,242.7	0.5	2.7	1	1	1
12/15/2022 23:00	0.8	12.2	2,230.3	0.5	2.7	1	1	1
Average/Sum#:	0.8	12.2	2,208.2	0.5	61.8 #	24 #	24 #	24 #
Minimum:	0.6	11.8	1,975.6	0.5	2.0	1	1	1
Maximum:	1.0	13.1	2,305.6	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	1.1	13.1	1,993.7	0.6	3.7	1	1	1
12/16/2022 01:00	1.2	13.2	1,967.6	0.7	4.0	1	1	1
12/16/2022 02:00	1.2	13.2	1,966.9	0.9	4.0	1	1	1
12/16/2022 03:00	1.2	13.2	1,969.7	0.9	4.1	1	1	1
12/16/2022 04:00	1.2	13.2	1,968.6	0.9	4.1	1	1	1
12/16/2022 05:00	1.2	13.2	1,982.9	0.9	4.1	1	1	1
12/16/2022 06:00	1.0	12.7	2,114.1	0.8	3.4	1	1	1
12/16/2022 07:00	0.8	12.3	2,208.1	0.7	2.7	1	1	1
12/16/2022 08:00	0.8	12.6	2,142.7	0.6	2.7	1	1	1
12/16/2022 09:00	0.9	12.7	2,066.1	0.6	3.0	1	1	1
12/16/2022 10:00	0.3	13.8	1,542.9	0.5	0.9	1	1	0
12/16/2022 11:00	0.4	13.9	1,461.4	0.4	1.1	1	1	0
12/16/2022 12:00	0.5	13.9	1,324.4	0.3	1.2	1	1	0
12/16/2022 13:00	0.4	13.9	1,326.3	0.3	1.0	1	1	0
12/16/2022 14:00	0.3	13.8	1,587.9	0.3	0.9	1	1	0
12/16/2022 15:00	0.4	13.8	1,555.8	0.3	1.2	1	1	1
12/16/2022 16:00	0.9	12.4	2,147.0	0.4	3.0	1	1	1
12/16/2022 17:00	0.8	12.0	2,222.2	0.5	2.6	1	1	1
12/16/2022 18:00	0.8	12.4	2,150.0	0.6	2.7	1	1	1
12/16/2022 19:00	0.8	12.4	2,159.8	0.6	2.7	1	1	1
12/16/2022 20:00	0.7	11.9	2,243.7	0.6	2.3	1	1	1
12/16/2022 21:00	0.8	12.2	2,187.6	0.5	2.7	1	1	1
12/16/2022 22:00	0.9	12.7	2,087.4	0.5	3.0	1	1	1
12/16/2022 23:00	1.1	13.2	1,976.6	0.6	3.7	1	1	1
Average/Sum#:	0.8	13.0	1,931.4	0.6	64.8 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,324.4	0.3	0.9	1	1	0
Maximum:	1.2	13.9	2,243.7	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.9	12.5	2,146.2	0.7	3.0	1	1	1
12/17/2022 01:00	0.9	12.5	2,148.8	0.7	3.0	1	1	1
12/17/2022 02:00	0.9	12.5	2,140.6	0.6	3.0	1	1	1
12/17/2022 03:00	0.9	12.5	2,153.2	0.6	3.0	1	1	1
12/17/2022 04:00	0.9	12.5	2,153.6	0.6	3.0	1	1	1
12/17/2022 05:00	0.9	12.5	2,151.4	0.6	3.0	1	1	1
12/17/2022 06:00	0.8	12.2	2,233.8	0.6	2.7	1	1	1
12/17/2022 07:00	0.9	12.7	2,099.2	0.6	3.0	1	1	1
12/17/2022 08:00	0.9	12.5	2,159.2	0.6	3.1	1	1	1
12/17/2022 09:00	0.9	12.6	2,117.2	0.6	3.0	1	1	1
12/17/2022 10:00	1.0	13.1	1,997.6	0.7	3.4	1	1	1
12/17/2022 11:00	1.1	13.2	1,964.4	0.7	3.7	1	1	1
12/17/2022 12:00	1.1	13.2	1,960.9	0.8	3.7	1	1	1
12/17/2022 13:00	1.0	13.1	1,956.6	0.8	3.3	1	1	1
12/17/2022 14:00	1.0	13.0	1,970.0	0.8	3.3	1	1	1
12/17/2022 15:00	0.8	12.5	2,100.3	0.7	2.6	1	1	1
12/17/2022 16:00	0.7	11.9	2,248.1	0.6	2.3	1	1	1
12/17/2022 17:00	0.8	12.0	2,217.8	0.5	2.6	1	1	1
12/17/2022 18:00	0.8	12.4	2,137.6	0.5	2.7	1	1	1
12/17/2022 19:00	0.8	11.8	2,260.0	0.5	2.6	1	1	1
12/17/2022 20:00	0.7	11.8	2,263.2	0.5	2.3	1	1	1
12/17/2022 21:00	0.7	11.8	2,264.7	0.5	2.3	1	1	1
12/17/2022 22:00	0.7	11.9	2,261.6	0.5	2.3	1	1	1
12/17/2022 23:00	0.8	12.3	2,180.2	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,136.9	0.6	69.6 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,956.6	0.5	2.3	1	1	1
Maximum:	1.1	13.2	2,264.7	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.8	12.5	2,132.5	0.5	2.7	1	1	1
12/18/2022 01:00	0.9	12.6	2,135.5	0.6	3.1	1	1	1
12/18/2022 02:00	1.1	13.0	2,021.6	0.7	3.7	1	1	1
12/18/2022 03:00	1.2	13.2	1,975.9	0.8	4.1	1	1	1
12/18/2022 04:00	0.9	12.6	2,135.5	0.8	3.1	1	1	1
12/18/2022 05:00	0.9	12.5	2,156.2	0.7	3.1	1	1	1
12/18/2022 06:00	0.9	12.4	2,171.1	0.6	3.0	1	1	1
12/18/2022 07:00	0.9	12.3	2,208.2	0.6	3.1	1	1	1
12/18/2022 08:00	0.9	12.6	2,085.2	0.6	3.0	1	1	1
12/18/2022 09:00	0.4	13.8	1,618.7	0.5	1.2	1	1	0
12/18/2022 10:00	0.4	13.8	1,561.3	0.4	1.2	1	1	0
12/18/2022 11:00	0.4	13.8	1,559.0	0.3	1.2	1	1	0
12/18/2022 12:00	0.5	13.8	1,408.9	0.3	1.3	1	1	0
12/18/2022 13:00	0.5	13.8	1,399.2	0.4	1.3	1	1	0
12/18/2022 14:00	0.4	13.8	1,643.4	0.4	1.2	1	1	0
12/18/2022 15:00	0.4	13.8	1,651.7	0.3	1.2	1	1	1
12/18/2022 16:00	1.0	12.4	2,130.5	0.4	3.3	1	1	1
12/18/2022 17:00	0.8	12.0	2,242.0	0.5	2.7	1	1	1
12/18/2022 18:00	0.8	11.9	2,269.4	0.6	2.7	1	1	1
12/18/2022 19:00	0.8	11.9	2,270.4	0.5	2.7	1	1	1
12/18/2022 20:00	0.9	12.1	2,236.3	0.5	3.0	1	1	1
12/18/2022 21:00	0.9	12.3	2,210.2	0.6	3.1	1	1	1
12/18/2022 22:00	0.9	12.4	2,198.1	0.6	3.1	1	1	1
12/18/2022 23:00	1.1	12.9	2,049.0	0.7	3.7	1	1	1
Average/Sum#:	0.8	12.8	1,977.9	0.5	61.8 #	24 #	24 #	18 #
Minimum:	0.4	11.9	1,399.2	0.3	1.2	1	1	0
Maximum:	1.2	13.8	2,270.4	0.8	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	1.0	12.6	2,143.3	0.7	3.4	1	1	1
12/19/2022 01:00	0.9	12.5	2,153.6	0.7	3.0	1	1	1
12/19/2022 02:00	0.9	12.6	2,150.3	0.6	3.1	1	1	1
12/19/2022 03:00	0.9	12.6	2,151.5	0.6	3.1	1	1	1
12/19/2022 04:00	1.0	12.5	2,181.6	0.6	3.4	1	1	1
12/19/2022 05:00	0.9	12.0	2,296.4	0.6	3.1	1	1	1
12/19/2022 06:00	0.9	12.0	2,296.2	0.6	3.1	1	1	1
12/19/2022 07:00	0.9	12.0	2,295.5	0.6	3.1	1	1	1
12/19/2022 08:00	0.9	12.1	2,248.0	0.6	3.0	1	1	1
12/19/2022 09:00	0.9	12.1	2,257.3	0.6	3.0	1	1	1
12/19/2022 10:00	0.9	12.5	2,169.7	0.6	3.1	1	1	1
12/19/2022 11:00	0.9	12.5	2,172.8	0.6	3.1	1	1	1
12/19/2022 12:00	0.9	12.5	2,163.1	0.6	3.1	1	1	1
12/19/2022 13:00	0.9	12.5	2,154.7	0.6	3.0	1	1	1
12/19/2022 14:00	0.9	12.5	2,157.0	0.6	3.1	1	1	1
12/19/2022 15:00	0.9	12.3	2,218.7	0.6	3.1	1	1	1
12/19/2022 16:00	0.9	12.1	2,259.5	0.6	3.1	1	1	1
12/19/2022 17:00	0.9	12.1	2,264.7	0.6	3.1	1	1	1
12/19/2022 18:00	0.9	12.1	2,265.6	0.6	3.1	1	1	1
12/19/2022 19:00	0.9	12.1	2,264.2	0.6	3.1	1	1	1
12/19/2022 20:00	0.9	12.1	2,259.5	0.6	3.1	1	1	1
12/19/2022 21:00	0.9	12.1	2,259.7	0.6	3.1	1	1	1
12/19/2022 22:00	0.9	12.1	2,264.3	0.6	3.1	1	1	1
12/19/2022 23:00	0.9	12.1	2,263.6	0.6	3.1	1	1	1
Average/Sum#:	0.9	12.3	2,221.3	0.6	74.6 #	24 #	24 #	24 #
Minimum:	0.9	12.0	2,143.3	0.6	3.0	1	1	1
Maximum:	1.0	12.6	2,296.4	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.9	12.5	2,172.5	0.6	3.1	1	1	1
12/20/2022 01:00	0.9	12.5	2,169.3	0.6	3.1	1	1	1
12/20/2022 02:00	0.9	12.5	2,173.2	0.6	3.1	1	1	1
12/20/2022 03:00	0.9	12.5	2,179.2	0.6	3.1	1	1	1
12/20/2022 04:00	0.9	12.5	2,184.8	0.6	3.1	1	1	1
12/20/2022 05:00	0.9	12.5	2,186.9	0.6	3.1	1	1	1
12/20/2022 06:00	0.9	12.1	2,279.9	0.6	3.1	1	1	1
12/20/2022 07:00	0.9	12.1	2,273.5	0.6	3.1	1	1	1
12/20/2022 08:00	0.9	12.5	2,163.7	0.6	3.1	1	1	1
12/20/2022 09:00	0.9	12.5	2,161.4	0.6	3.1	1	1	1
12/20/2022 10:00	0.9	12.6	2,120.5	0.6	3.0	1	1	1
12/20/2022 11:00	0.9	12.7	2,088.3	0.6	3.0	1	1	1
12/20/2022 12:00	1.2	13.2	1,961.1	0.7	4.0	1	1	1
12/20/2022 13:00	1.2	13.2	1,963.4	0.8	4.0	1	1	1
12/20/2022 14:00	1.2	13.2	1,958.0	0.9	4.0	1	1	1
12/20/2022 15:00	1.1	12.9	2,030.5	0.9	3.7	1	1	1
12/20/2022 16:00	0.8	12.3	2,184.0	0.7	2.7	1	1	1
12/20/2022 17:00	0.8	12.0	2,248.1	0.6	2.7	1	1	1
12/20/2022 18:00	0.8	12.0	2,246.6	0.5	2.7	1	1	1
12/20/2022 19:00	0.8	12.0	2,239.7	0.5	2.7	1	1	1
12/20/2022 20:00	0.8	12.0	2,241.8	0.5	2.7	1	1	1
12/20/2022 21:00	0.8	12.4	2,154.7	0.5	2.7	1	1	1
12/20/2022 22:00	0.8	12.4	2,156.3	0.6	2.7	1	1	1
12/20/2022 23:00	0.8	12.2	2,209.3	0.6	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,156.1	0.6	74.3 #	24 #	24 #	24 #
Minimum:	0.8	12.0	1,958.0	0.5	2.7	1	1	1
Maximum:	1.2	13.2	2,279.9	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	0.8	11.9	2,265.8	0.5	2.7	1	1	1
12/21/2022 01:00	0.8	11.9	2,263.2	0.5	2.7	1	1	1
12/21/2022 02:00	0.8	12.0	2,261.3	0.5	2.7	1	1	1
12/21/2022 03:00	0.8	12.0	2,267.1	0.5	2.7	1	1	1
12/21/2022 04:00	0.8	12.0	2,267.5	0.5	2.7	1	1	1
12/21/2022 05:00	0.8	12.0	2,262.9	0.5	2.7	1	1	1
12/21/2022 06:00	0.8	12.0	2,262.6	0.5	2.7	1	1	1
12/21/2022 07:00	0.8	12.0	2,260.4	0.5	2.7	1	1	1
12/21/2022 08:00	0.8	12.1	2,249.7	0.5	2.7	1	1	1
12/21/2022 09:00	0.9	12.1	2,235.5	0.5	3.0	1	1	1
12/21/2022 10:00	0.8	12.1	2,227.8	0.5	2.7	1	1	1
12/21/2022 11:00	0.8	12.2	2,195.0	0.5	2.7	1	1	1
12/21/2022 12:00	0.8	12.1	2,213.1	0.5	2.7	1	1	1
12/21/2022 13:00	0.8	12.1	2,208.4	0.5	2.7	1	1	1
12/21/2022 14:00	0.8	12.4	2,133.5	0.5	2.7	1	1	1
12/21/2022 15:00	0.8	12.1	2,205.0	0.5	2.6	1	1	1
12/21/2022 16:00	0.8	12.0	2,227.3	0.5	2.6	1	1	1
12/21/2022 17:00	0.8	12.0	2,234.1	0.5	2.7	1	1	1
12/21/2022 18:00	0.8	12.0	2,239.9	0.5	2.7	1	1	1
12/21/2022 19:00	0.8	12.0	2,241.3	0.5	2.7	1	1	1
12/21/2022 20:00	0.8	12.0	2,238.6	0.5	2.7	1	1	1
12/21/2022 21:00	0.8	12.0	2,238.6	0.5	2.7	1	1	1
12/21/2022 22:00	0.8	12.1	2,239.1	0.5	2.7	1	1	1
12/21/2022 23:00	0.9	12.1	2,239.7	0.5	3.0	1	1	1
Average/Sum#:	0.8	12.1	2,236.6	0.5	65.2 #	24 #	24 #	24 #
Minimum:	0.8	11.9	2,133.5	0.5	2.6	1	1	1
Maximum:	0.9	12.4	2,267.5	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	0.9	12.3	2,179.5	0.6	3.0	1	1	1
12/22/2022 01:00	1.2	13.1	1,980.0	0.7	4.0	1	1	1
12/22/2022 02:00	1.4	13.2	1,961.4	0.9	4.7	1	1	1
12/22/2022 03:00	1.4	13.2	1,964.7	1.0	4.7	1	1	1
12/22/2022 04:00	1.2	12.8	2,094.8	1.0	4.1	1	1	1
12/22/2022 05:00	1.0	12.1	2,222.3	0.9	3.3	1	1	1
12/22/2022 06:00	0.9	12.1	2,261.4	0.7	3.1	1	1	1
12/22/2022 07:00	0.9	12.1	2,259.7	0.6	3.1	1	1	1
12/22/2022 08:00	0.9	12.1	2,238.6	0.6	3.0	1	1	1
12/22/2022 09:00	0.9	12.5	2,150.2	0.6	3.0	1	1	1
12/22/2022 10:00	0.9	12.6	2,145.1	0.6	3.1	1	1	1
12/22/2022 11:00	0.9	12.5	2,140.3	0.6	3.0	1	1	1
12/22/2022 12:00	0.9	12.5	2,137.6	0.6	3.0	1	1	1
12/22/2022 13:00	0.9	12.5	2,137.2	0.6	3.0	1	1	1
12/22/2022 14:00	0.9	12.5	2,144.7	0.6	3.0	1	1	1
12/22/2022 15:00	0.9	12.2	2,203.3	0.6	3.0	1	1	1
12/22/2022 16:00	0.9	12.2	2,198.4	0.6	3.0	1	1	1
12/22/2022 17:00	0.9	12.0	2,238.8	0.6	3.0	1	1	1
12/22/2022 18:00	0.9	12.0	2,242.2	0.6	3.0	1	1	1
12/22/2022 19:00	0.9	12.0	2,246.6	0.6	3.0	1	1	1
12/22/2022 20:00	0.9	12.0	2,243.5	0.6	3.0	1	1	1
12/22/2022 21:00	0.9	12.0	2,241.4	0.6	3.0	1	1	1
12/22/2022 22:00	0.9	12.2	2,200.2	0.6	3.0	1	1	1
12/22/2022 23:00	1.0	12.8	2,068.8	0.6	3.4	1	1	1
Average/Sum#:	1.0	12.4	2,162.5	0.7	78.5 #	24 #	24 #	24 #
Minimum:	0.9	12.0	1,961.4	0.6	3.0	1	1	1
Maximum:	1.4	13.2	2,261.4	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.9	12.2	2,215.5	0.6	3.0	1	1	1
12/23/2022 01:00	0.9	12.0	2,252.2	0.6	3.0	1	1	1
12/23/2022 02:00	0.9	12.0	2,250.3	0.6	3.0	1	1	1
12/23/2022 03:00	0.9	12.0	2,245.6	0.6	3.0	1	1	1
12/23/2022 04:00	0.9	12.0	2,248.2	0.6	3.0	1	1	1
12/23/2022 05:00	0.9	12.0	2,241.2	0.6	3.0	1	1	1
12/23/2022 06:00	0.9	12.0	2,250.7	0.6	3.0	1	1	1
12/23/2022 07:00	0.9	12.1	2,232.9	0.6	3.0	1	1	1
12/23/2022 08:00	0.9	12.3	2,172.6	0.6	3.0	1	1	1
12/23/2022 09:00	0.9	12.3	2,163.4	0.6	3.0	1	1	1
12/23/2022 10:00	0.9	12.5	2,122.9	0.6	3.0	1	1	1
12/23/2022 11:00	0.8	12.4	2,124.2	0.6	2.6	1	1	1
12/23/2022 12:00	1.0	12.8	2,017.4	0.6	3.3	1	1	1
12/23/2022 13:00	1.1	13.1	1,950.0	0.7	3.6	1	1	1
12/23/2022 14:00	1.2	13.1	1,941.4	0.8	3.9	1	1	1
12/23/2022 15:00	1.0	12.7	2,049.7	0.8	3.3	1	1	1
12/23/2022 16:00	0.8	11.9	2,228.2	0.7	2.6	1	1	1
12/23/2022 17:00	0.8	11.9	2,230.8	0.6	2.6	1	1	1
12/23/2022 18:00	0.8	11.9	2,231.0	0.5	2.6	1	1	1
12/23/2022 19:00	0.7	12.0	2,229.3	0.5	2.3	1	1	1
12/23/2022 20:00	0.7	12.0	2,230.7	0.5	2.3	1	1	1
12/23/2022 21:00	0.7	11.9	2,234.3	0.5	2.3	1	1	1
12/23/2022 22:00	0.8	11.9	2,233.5	0.5	2.6	1	1	1
12/23/2022 23:00	0.8	12.0	2,225.6	0.5	2.6	1	1	1
Average/Sum#:	0.9	12.2	2,180.1	0.6	69.6 #	24 #	24 #	24 #
Minimum:	0.7	11.9	1,941.4	0.5	2.3	1	1	1
Maximum:	1.2	13.1	2,252.2	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.8	12.4	2,119.0	0.5	2.6	1	1	1
12/24/2022 01:00	0.8	12.5	2,113.9	0.6	2.7	1	1	1
12/24/2022 02:00	1.1	13.1	1,961.4	0.7	3.7	1	1	1
12/24/2022 03:00	1.2	13.2	1,955.3	0.8	4.0	1	1	1
12/24/2022 04:00	1.2	13.2	1,953.0	0.9	4.0	1	1	1
12/24/2022 05:00	1.2	13.2	1,951.1	0.9	4.0	1	1	1
12/24/2022 06:00	1.2	13.1	1,974.8	0.9	4.0	1	1	1
12/24/2022 07:00	1.1	13.0	1,998.9	0.9	3.7	1	1	1
12/24/2022 08:00	1.0	13.3	1,833.9	0.8	3.2	1	1	1
12/24/2022 09:00	0.6	13.8	1,320.7	0.7	1.5	1	1	0
12/24/2022 10:00	0.4	13.8	1,559.7	0.5	1.2	1	1	0
12/24/2022 11:00	0.4	13.8	1,555.6	0.4	1.2	1	1	0
12/24/2022 12:00	0.4	13.8	1,554.9	0.3	1.2	1	1	0
12/24/2022 13:00	0.3	13.8	1,558.8	0.3	0.9	1	1	0
12/24/2022 14:00	0.3	13.8	1,730.9	0.2	1.0	1	1	0
12/24/2022 15:00	0.3	13.8	1,739.5	0.2	1.0	1	1	0
12/24/2022 16:00	0.4	13.8	1,594.1	0.2	1.2	1	1	1
12/24/2022 17:00	1.2	13.1	1,944.9	0.5	4.0	1	1	1
12/24/2022 18:00	1.1	13.1	1,943.7	0.7	3.6	1	1	1
12/24/2022 19:00	1.1	13.1	1,944.1	0.8	3.6	1	1	1
12/24/2022 20:00	1.1	13.1	1,947.7	0.8	3.6	1	1	1
12/24/2022 21:00	1.1	13.1	1,944.2	0.8	3.6	1	1	1
12/24/2022 22:00	1.2	13.2	1,946.9	0.8	4.0	1	1	1
12/24/2022 23:00	1.2	13.2	1,949.6	0.9	4.0	1	1	1
Average/Sum#:	0.9	13.3	1,837.4	0.6	67.5 #	24 #	24 #	17 #
Minimum:	0.3	12.4	1,320.7	0.2	0.9	1	1	0
Maximum:	1.2	13.8	2,119.0	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.2	13.2	1,930.0	0.9	4.0	1	1	1
12/25/2022 01:00	22.2	15.6	591.4	0.0	7.2	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	11.7	14.4	1,260.7	0.9	11.2 #	2 #	4 #	1 #
Minimum:	1.2	13.2	591.4	0.9	4.0	0	0	0
Maximum:	22.2	15.6	1,930.0	0.9	7.2	1	1	1
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	60.1	17.6	332.1	0.0	50.3	1	1	0
12/26/2022 01:00	38.4	15.1	969.8	0.0	84.8	1	1	0
12/26/2022 02:00	0.5	13.7	1,715.8	0.0	1.6	1	1	0
12/26/2022 03:00	0.5	13.7	1,736.0	0.0	1.6	1	1	0
12/26/2022 04:00	0.5	13.7	1,735.7	0.4	1.6	1	1	0
12/26/2022 05:00	0.5	13.7	1,750.8	0.4	1.6	1	1	0
12/26/2022 06:00	0.5	13.7	1,750.6	0.4	1.6	1	1	0
12/26/2022 07:00	0.5	13.7	1,742.3	0.4	1.6	1	1	0
12/26/2022 08:00	0.5	13.7	1,748.4	0.4	1.6	1	1	0
12/26/2022 09:00	0.5	13.8	1,563.8	0.4	1.5	1	1	0
12/26/2022 10:00	0.5	13.8	1,559.4	0.4	1.5	1	1	0
12/26/2022 11:00	0.5	13.8	1,550.2	0.4	1.4	1	1	0
12/26/2022 12:00	0.6	13.8	1,541.0	0.4	1.7	1	1	0
12/26/2022 13:00	0.5	13.8	1,561.8	0.4	1.5	1	1	0
12/26/2022 14:00	0.5	13.7	1,623.4	0.4	1.5	1	1	0
12/26/2022 15:00	0.5	13.7	1,751.1	0.4	1.6	1	1	0
12/26/2022 16:00	0.5	13.7	1,782.9	0.4	1.6	1	1	1
12/26/2022 17:00	1.3	12.5	2,103.9	0.6	4.3	1	1	1
12/26/2022 18:00	1.0	12.3	2,145.3	0.7	3.3	1	1	1
12/26/2022 19:00	1.2	12.9	2,004.1	0.8	4.0	1	1	1
12/26/2022 20:00	1.2	13.0	1,990.7	0.8	4.0	1	1	1
12/26/2022 21:00	1.4	13.1	1,960.1	1.0	4.6	1	1	1
12/26/2022 22:00	1.4	13.1	1,936.0	1.0	4.6	1	1	1
12/26/2022 23:00	21.0	15.6	602.1	0.0	7.2	1	0	0
Average/Sum#:	5.6	13.8	1,631.6	0.5	190.6 #	24 #	23 #	7 #
Minimum:	0.5	12.3	332.1	0.4	1.4	1	0	0
Maximum:	60.1	17.6	2,145.3	1.0	84.8	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/27/2022 05:00	59.8	17.0	482.2	0.0	43.9	1	1	0
12/27/2022 06:00	25.6	14.3	1,185.6	0.0	60.7	1	1	0
12/27/2022 07:00	0.4	13.7	1,737.9	0.0	1.3	1	1	0
12/27/2022 08:00	0.5	13.6	1,714.6	0.0	1.6	1	1	1
12/27/2022 09:00	1.4	12.9	1,950.3	0.6	4.5	1	1	1
12/27/2022 10:00	1.2	12.9	1,947.7	0.8	3.9	1	1	1
12/27/2022 11:00	1.0	12.9	1,950.7	0.9	3.2	1	1	1
12/27/2022 12:00	0.9	12.9	1,949.0	0.8	2.9	1	1	1
12/27/2022 13:00	0.9	12.9	1,947.5	0.7	2.9	1	1	1
12/27/2022 14:00	0.9	12.9	1,948.0	0.7	2.9	1	1	1
12/27/2022 15:00	0.9	12.9	1,949.1	0.7	2.9	1	1	1
12/27/2022 16:00	1.0	12.9	1,950.9	0.7	3.2	1	1	1
12/27/2022 17:00	1.2	13.0	1,941.7	0.8	3.9	1	1	1
12/27/2022 18:00	1.2	13.1	1,938.3	0.8	3.9	1	1	1
12/27/2022 19:00	1.2	13.1	1,941.5	0.9	3.9	1	1	1
12/27/2022 20:00	1.3	13.1	1,950.2	0.9	4.3	1	1	1
12/27/2022 21:00	1.2	13.1	1,946.3	0.9	4.0	1	1	1
12/27/2022 22:00	1.2	13.1	1,927.1	0.9	3.9	1	1	1
12/27/2022 23:00	0.5	13.9	1,398.6	0.7	1.3	1	1	0
Average/Sum#:	5.4	13.4	1,776.7	0.8	159.1 #	19 #	21 #	15 #
Minimum:	0.4	12.9	482.2	0.6	1.3	0	0	0
Maximum:	59.8	17.0	1,950.9	0.9	60.7	1	1	1
%SI	20.83	20.83	20.83	37.50	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.4	13.8	1,551.1	0.5	1.2	1	1	0
12/28/2022 01:00	0.5	13.8	1,473.8	0.4	1.4	1	1	0
12/28/2022 02:00	0.5	13.8	1,538.3	0.4	1.4	1	1	0
12/28/2022 03:00	0.5	13.8	1,537.5	0.4	1.4	1	1	0
12/28/2022 04:00	0.5	13.8	1,543.0	0.4	1.4	1	1	0
12/28/2022 05:00	0.4	13.7	1,735.6	0.4	1.3	1	1	0
12/28/2022 06:00	0.4	13.7	1,753.7	0.3	1.3	1	1	0
12/28/2022 07:00	0.4	13.7	1,756.5	0.3	1.3	1	1	0
12/28/2022 08:00	0.4	13.7	1,732.6	0.3	1.3	1	1	0
12/28/2022 09:00	0.4	13.7	1,723.8	0.3	1.3	1	1	0
12/28/2022 10:00	0.4	13.8	1,562.0	0.3	1.2	1	1	0
12/28/2022 11:00	0.4	13.8	1,577.9	0.3	1.2	1	1	0
12/28/2022 12:00	0.4	13.8	1,560.7	0.3	1.2	1	1	0
12/28/2022 13:00	0.4	13.8	1,535.3	0.3	1.1	1	1	0
12/28/2022 14:00	0.4	13.8	1,554.0	0.3	1.2	1	1	0
12/28/2022 15:00	0.5	13.7	1,601.3	0.3	1.5	1	1	1
12/28/2022 16:00	1.2	12.5	2,087.1	0.5	3.9	1	1	1
12/28/2022 17:00	1.1	13.0	1,974.8	0.7	3.6	1	1	1
12/28/2022 18:00	1.2	13.1	1,954.9	0.8	4.0	1	1	1
12/28/2022 19:00	1.2	13.1	1,956.3	0.9	4.0	1	1	1
12/28/2022 20:00	1.3	13.1	1,955.8	0.9	4.3	1	1	1
12/28/2022 21:00	1.2	13.0	1,967.9	0.9	3.9	1	1	1
12/28/2022 22:00	1.3	13.1	1,952.9	1.0	4.3	1	1	1
12/28/2022 23:00	1.3	13.1	1,957.6	1.0	4.3	1	1	1
Average/Sum#:	0.7	13.5	1,731.0	0.5	53.0 #	24 #	24 #	9 #
Minimum:	0.4	12.5	1,473.8	0.3	1.1	1	1	0
Maximum:	1.3	13.8	2,087.1	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	1.3	13.1	1,953.1	1.0	4.3	1	1	1
12/29/2022 01:00	1.3	13.1	1,953.2	1.0	4.3	1	1	1
12/29/2022 02:00	1.3	13.1	1,953.7	1.0	4.3	1	1	1
12/29/2022 03:00	1.3	13.1	1,955.0	1.0	4.3	1	1	1
12/29/2022 04:00	1.3	13.1	1,957.5	1.0	4.3	1	1	1
12/29/2022 05:00	1.1	12.7	2,029.7	0.9	3.6	1	1	1
12/29/2022 06:00	1.1	12.8	2,039.0	0.9	3.7	1	1	1
12/29/2022 07:00	1.1	12.8	2,042.7	0.8	3.7	1	1	1
12/29/2022 08:00	1.0	12.2	2,185.5	0.8	3.3	1	1	1
12/29/2022 09:00	0.9	11.9	2,234.1	0.7	3.0	1	1	1
12/29/2022 10:00	0.9	12.3	2,142.2	0.6	3.0	1	1	1
12/29/2022 11:00	1.1	12.9	2,012.8	0.7	3.7	1	1	1
12/29/2022 12:00	1.2	13.0	1,975.6	0.8	4.0	1	1	1
12/29/2022 13:00	1.4	13.1	1,962.0	0.9	4.7	1	1	1
12/29/2022 14:00	1.3	13.0	1,971.1	1.0	4.3	1	1	1
12/29/2022 15:00	1.3	13.0	1,977.5	1.0	4.3	1	1	1
12/29/2022 16:00	1.2	12.6	2,082.3	1.0	4.0	1	1	1
12/29/2022 17:00	0.9	12.3	2,149.3	0.8	3.0	1	1	1
12/29/2022 18:00	1.0	12.6	2,062.6	0.7	3.3	1	1	1
12/29/2022 19:00	1.4	13.1	1,956.5	0.8	4.6	1	1	1
12/29/2022 20:00	1.4	13.1	1,963.5	1.0	4.7	1	1	1
12/29/2022 21:00	1.3	13.0	1,973.9	1.1	4.3	1	1	1
12/29/2022 22:00	1.4	13.0	1,958.1	1.0	4.6	1	1	1
12/29/2022 23:00	1.4	13.1	1,930.3	1.0	4.6	1	1	1
Average/Sum#:	1.2	12.8	2,017.6	0.9	95.9 #	24 #	24 #	24 #
Minimum:	0.9	11.9	1,930.3	0.6	3.0	1	1	1
Maximum:	1.4	13.1	2,234.1	1.1	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	19.6	15.6	627.2	0.0	7.7	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	19.6	15.6	627.2	0.0	7.7 #	1 #	0 #	0 #
Minimum:	19.6	15.6	627.2	0.0	7.7	0	0	0
Maximum:	19.6	15.6	627.2	0.0	7.7	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.3	12.1	2,166.3	0.2	1.0	1	1	1
10/01/2022 01:00	8.5	14.2	1,202.0	0.0	9.6	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	21.9	17.7	308.0	0.0	20.0	1	0	0
10/01/2022 13:00	12.2	17.2	376.4	0.0	16.4	1	0	0
10/01/2022 14:00	17.3	15.5	875.8	0.0	37.1	1	0	0
10/01/2022 15:00	0.2	14.1	1,414.5	0.0	0.5	1	1	0
10/01/2022 16:00	0.4	13.6	1,717.8	0.0	1.2	1	1	1
10/01/2022 17:00	0.4	11.6	2,258.0	0.3	1.3	1	1	1
10/01/2022 18:00	0.4	11.9	2,188.3	0.3	1.3	1	1	1
10/01/2022 19:00	0.6	12.6	2,026.7	0.3	1.9	1	1	1
10/01/2022 20:00	0.4	11.9	2,210.8	0.3	1.3	1	1	1
10/01/2022 21:00	0.4	12.5	1,932.3	0.3	1.2	1	1	1
10/01/2022 22:00	0.3	13.8	1,569.8	0.3	0.9	1	1	0
10/01/2022 23:00	17.4	15.6	630.9	0.0	6.9	1	0	0
Average/Sum#:	5.8	13.9	1,491.3	0.3	100.6 #	14 #	9 #	8 #
Minimum:	0.2	11.6	308.0	0.2	0.5	0	0	0
Maximum:	21.9	17.7	2,258.0	0.3	37.1	1	1	1
%SI	41.67	41.67	41.67	70.83	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	46.2	17.7	311.4	0.0	39.8	1	0	0
10/02/2022 12:00	16.4	17.2	404.4	0.0	23.7	1	0	0
10/02/2022 13:00	22.5	15.6	880.7	0.0	49.4	1	0	0
10/02/2022 14:00	0.3	13.8	1,730.7	0.0	1.0	1	1	0
10/02/2022 15:00	0.6	13.2	1,719.8	0.0	1.8	1	1	1
10/02/2022 16:00	0.6	12.0	2,184.2	0.4	1.9	1	1	1
10/02/2022 17:00	0.4	11.6	2,265.0	0.4	1.3	1	1	1
10/02/2022 18:00	0.4	11.6	2,270.6	0.3	1.3	1	1	1
10/02/2022 19:00	0.3	11.6	2,272.9	0.3	1.0	1	1	1
10/02/2022 20:00	0.3	11.6	2,274.3	0.2	1.0	1	1	1
10/02/2022 21:00	0.5	12.4	2,098.7	0.2	1.6	1	1	1
10/02/2022 22:00	0.4	12.7	1,912.0	0.3	1.2	1	1	1
10/02/2022 23:00	0.3	13.9	1,550.6	0.3	0.9	1	1	0
Average/Sum#:	6.9	13.5	1,682.7	0.3	125.9 #	13 #	10 #	8 #
Minimum:	0.3	11.6	311.4	0.2	0.9	0	0	0
Maximum:	46.2	17.7	2,274.3	0.4	49.4	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.3	13.9	1,546.4	0.3	0.9	1	1	0
10/03/2022 01:00	0.3	13.9	1,550.3	0.3	0.9	1	1	0
10/03/2022 02:00	0.3	13.8	1,784.2	0.3	1.0	1	1	0
10/03/2022 03:00	0.3	13.9	1,582.9	0.3	0.9	1	1	0
10/03/2022 04:00	0.2	13.9	1,715.7	0.2	0.6	1	1	0
10/03/2022 05:00	0.2	13.9	1,713.6	0.2	0.6	1	1	0
10/03/2022 06:00	0.2	13.9	1,710.7	0.2	0.6	1	1	0
10/03/2022 07:00	0.2	13.9	1,711.1	0.2	0.6	1	1	0
10/03/2022 08:00	0.2	13.9	1,717.3	0.2	0.6	1	1	0
10/03/2022 09:00	0.2	13.9	1,722.1	0.2	0.6	1	1	0
10/03/2022 10:00	0.3	13.9	1,724.5	0.2	1.0	1	1	0
10/03/2022 11:00	0.3	13.9	1,724.7	0.3	1.0	1	1	0
10/03/2022 12:00	0.3	13.9	1,724.6	0.3	1.0	1	1	0
10/03/2022 13:00	0.3	13.9	1,725.3	0.3	1.0	1	1	0
10/03/2022 14:00	0.3	13.9	1,716.6	0.3	1.0	1	1	0
10/03/2022 15:00	0.3	13.8	1,754.9	0.3	1.0	1	1	1
10/03/2022 16:00	0.6	12.5	2,060.1	0.3	1.9	1	1	1
10/03/2022 17:00	0.4	12.0	2,170.1	0.3	1.3	1	1	1
10/03/2022 18:00	0.3	11.8	2,202.2	0.3	1.0	1	1	1
10/03/2022 19:00	0.3	12.0	2,175.9	0.2	1.0	1	1	1
10/03/2022 20:00	0.3	11.9	2,186.8	0.2	1.0	1	1	1
10/03/2022 21:00	0.3	12.0	2,178.8	0.2	1.0	1	1	1
10/03/2022 22:00	0.3	12.2	2,156.6	0.2	1.0	1	1	1
10/03/2022 23:00	0.3	12.1	2,174.0	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.3	1,851.2	0.3	22.5 #	24 #	24 #	9 #
Minimum:	0.2	11.8	1,546.4	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,202.2	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	0.3	12.2	2,156.2	0.2	1.0	1	1	1
10/04/2022 01:00	0.3	12.2	2,159.9	0.2	1.0	1	1	1
10/04/2022 02:00	0.3	12.2	2,158.6	0.2	1.0	1	1	1
10/04/2022 03:00	0.3	12.1	2,168.6	0.2	1.0	1	1	1
10/04/2022 04:00	0.3	12.1	2,182.7	0.2	1.0	1	1	1
10/04/2022 05:00	0.2	12.0	2,216.4	0.2	0.7	1	1	1
10/04/2022 06:00	0.3	12.3	2,179.8	0.2	1.0	1	1	1
10/04/2022 07:00	0.3	12.7	2,043.5	0.2	1.0	1	1	1
10/04/2022 08:00	0.2	13.8	1,586.2	0.2	0.6	1	1	0
10/04/2022 09:00	0.2	13.9	1,548.5	0.2	0.6	1	1	0
10/04/2022 10:00	0.0	0.0	1,554.2	0.0	0.0	1	1	0
10/04/2022 11:00	0.3	13.9	1,562.4	0.0	0.9	1	1	0
10/04/2022 12:00	0.3	13.9	1,707.0	0.0	1.0	1	1	0
10/04/2022 13:00	0.5	13.8	1,733.0	0.3	1.6	1	1	1
10/04/2022 14:00	0.6	12.7	2,019.5	0.4	2.0	1	1	1
10/04/2022 15:00	0.4	12.1	2,136.1	0.4	1.3	1	1	1
10/04/2022 16:00	0.4	12.1	2,128.5	0.3	1.3	1	1	1
10/04/2022 17:00	0.3	12.1	2,140.4	0.3	1.0	1	1	1
10/04/2022 18:00	0.3	12.0	2,169.9	0.2	1.0	1	1	1
10/04/2022 19:00	0.3	11.9	2,188.2	0.2	1.0	1	1	1
10/04/2022 20:00	0.2	11.7	2,242.8	0.2	0.6	1	1	1
10/04/2022 21:00	0.2	11.9	2,190.4	0.1	0.6	1	1	1
10/04/2022 22:00	0.3	12.0	2,179.1	0.1	1.0	1	1	1
10/04/2022 23:00	0.3	12.2	2,143.7	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,020.7	0.2	23.2 #	24 #	24 #	19 #
Minimum:	0.2	11.7	1,548.5	0.1	0.6	1	1	0
Maximum:	0.6	13.9	2,242.8	0.4	2.0	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	0.3	12.2	2,136.6	0.2	1.0	1	1	1
10/05/2022 01:00	0.4	12.8	1,995.6	0.2	1.3	1	1	1
10/05/2022 02:00	0.5	13.0	1,971.2	0.3	1.6	1	1	1
10/05/2022 03:00	0.4	12.5	2,088.5	0.3	1.3	1	1	1
10/05/2022 04:00	0.3	12.3	2,117.7	0.3	1.0	1	1	1
10/05/2022 05:00	0.2	12.0	2,204.8	0.2	0.7	1	1	1
10/05/2022 06:00	0.2	12.1	2,206.4	0.1	0.7	1	1	1
10/05/2022 07:00	0.4	12.9	1,980.3	0.2	1.3	1	1	1
10/05/2022 08:00	0.1	13.9	1,702.3	0.2	0.3	1	1	0
10/05/2022 09:00	0.2	13.9	1,667.6	0.2	0.6	1	1	0
10/05/2022 10:00	0.3	13.9	1,693.9	0.2	1.0	1	1	0
10/05/2022 11:00	0.3	13.9	1,706.3	0.3	1.0	1	1	0
10/05/2022 12:00	0.3	13.8	1,723.0	0.3	1.0	1	1	1
10/05/2022 13:00	0.5	12.5	2,064.2	0.3	1.6	1	1	1
10/05/2022 14:00	0.3	11.9	2,181.4	0.3	1.0	1	1	1
10/05/2022 15:00	0.3	12.1	2,135.0	0.3	1.0	1	1	1
10/05/2022 16:00	0.3	12.0	2,157.2	0.2	1.0	1	1	1
10/05/2022 17:00	0.3	11.8	2,196.1	0.2	1.0	1	1	1
10/05/2022 18:00	0.2	11.7	2,231.0	0.2	0.6	1	1	1
10/05/2022 19:00	0.2	11.7	2,237.6	0.1	0.6	1	1	1
10/05/2022 20:00	0.3	11.9	2,188.3	0.1	1.0	1	1	1
10/05/2022 21:00	0.2	11.7	2,234.5	0.1	0.6	1	1	1
10/05/2022 22:00	0.3	12.1	2,163.4	0.2	1.0	1	1	1
10/05/2022 23:00	0.3	12.1	2,172.8	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,048.2	0.2	23.2 #	24 #	24 #	20 #
Minimum:	0.1	11.7	1,667.6	0.1	0.3	1	1	0
Maximum:	0.5	13.9	2,237.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	0.3	12.2	2,162.3	0.2	1.0	1	1	1
10/06/2022 01:00	0.3	12.1	2,166.4	0.2	1.0	1	1	1
10/06/2022 02:00	0.3	12.1	2,164.4	0.2	1.0	1	1	1
10/06/2022 03:00	0.3	12.2	2,142.9	0.2	1.0	1	1	1
10/06/2022 04:00	0.2	12.0	2,184.4	0.2	0.6	1	1	1
10/06/2022 05:00	0.2	11.8	2,246.2	0.1	0.7	1	1	1
10/06/2022 06:00	0.2	11.9	2,233.3	0.1	0.7	1	1	1
10/06/2022 07:00	0.3	12.3	2,131.1	0.1	1.0	1	1	1
10/06/2022 08:00	0.4	12.5	2,082.8	0.2	1.3	1	1	1
10/06/2022 09:00	0.4	12.6	2,065.4	0.3	1.3	1	1	1
10/06/2022 10:00	0.4	12.5	2,076.7	0.3	1.3	1	1	1
10/06/2022 11:00	0.4	12.3	2,113.6	0.3	1.3	1	1	1
10/06/2022 12:00	0.3	12.1	2,142.5	0.3	1.0	1	1	1
10/06/2022 13:00	0.2	11.9	2,198.7	0.2	0.6	1	1	1
10/06/2022 14:00	0.2	11.8	2,207.0	0.1	0.6	1	1	1
10/06/2022 15:00	0.3	12.0	2,158.9	0.1	1.0	1	1	1
10/06/2022 16:00	0.3	11.9	2,197.5	0.2	1.0	1	1	1
10/06/2022 17:00	0.2	11.7	2,245.6	0.2	0.6	1	1	1
10/06/2022 18:00	0.2	11.7	2,241.8	0.1	0.6	1	1	1
10/06/2022 19:00	0.2	11.7	2,251.9	0.1	0.6	1	1	1
10/06/2022 20:00	0.2	11.7	2,253.7	0.1	0.6	1	1	1
10/06/2022 21:00	0.2	11.8	2,243.5	0.1	0.7	1	1	1
10/06/2022 22:00	0.2	12.0	2,189.6	0.1	0.6	1	1	1
10/06/2022 23:00	0.3	12.1	2,168.9	0.1	1.0	1	1	1
Average/Sum#:	0.3	12.0	2,177.9	0.2	21.1 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,065.4	0.1	0.6	1	1	1
Maximum:	0.4	12.6	2,253.7	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	0.3	12.3	2,144.9	0.2	1.0	1	1	1
10/07/2022 01:00	0.3	12.2	2,158.5	0.2	1.0	1	1	1
10/07/2022 02:00	0.3	12.3	2,141.1	0.2	1.0	1	1	1
10/07/2022 03:00	0.3	12.4	2,115.0	0.2	1.0	1	1	1
10/07/2022 04:00	0.3	12.2	2,155.3	0.2	1.0	1	1	1
10/07/2022 05:00	0.3	12.1	2,191.5	0.2	1.0	1	1	1
10/07/2022 06:00	0.2	12.1	2,204.8	0.2	0.7	1	1	1
10/07/2022 07:00	0.3	12.4	2,111.6	0.2	1.0	1	1	1
10/07/2022 08:00	0.4	12.7	2,031.6	0.2	1.3	1	1	1
10/07/2022 09:00	0.3	12.3	2,132.5	0.2	1.0	1	1	1
10/07/2022 10:00	0.3	12.3	2,127.2	0.2	1.0	1	1	1
10/07/2022 11:00	0.3	12.3	2,117.0	0.2	1.0	1	1	1
10/07/2022 12:00	0.3	12.0	2,174.6	0.2	1.0	1	1	1
10/07/2022 13:00	0.3	12.1	2,147.2	0.2	1.0	1	1	1
10/07/2022 14:00	0.3	11.9	2,194.6	0.2	1.0	1	1	1
10/07/2022 15:00	0.2	11.8	2,203.8	0.2	0.6	1	1	1
10/07/2022 16:00	0.3	11.9	2,188.4	0.2	1.0	1	1	1
10/07/2022 17:00	0.2	11.7	2,238.4	0.1	0.6	1	1	1
10/07/2022 18:00	0.2	11.7	2,248.1	0.1	0.6	1	1	1
10/07/2022 19:00	0.2	11.7	2,254.3	0.1	0.6	1	1	1
10/07/2022 20:00	0.2	11.7	2,259.1	0.1	0.6	1	1	1
10/07/2022 21:00	0.2	11.7	2,262.1	0.1	0.6	1	1	1
10/07/2022 22:00	0.2	11.7	2,256.4	0.1	0.6	1	1	1
10/07/2022 23:00	0.2	12.0	2,191.4	0.1	0.7	1	1	1
Average/Sum#:	0.3	12.1	2,177.1	0.2	20.9 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,031.6	0.1	0.6	1	1	1
Maximum:	0.4	12.7	2,262.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	0.3	12.1	2,179.0	0.1	1.0	1	1	1
10/08/2022 01:00	0.3	12.1	2,173.7	0.2	1.0	1	1	1
10/08/2022 02:00	0.3	12.2	2,165.8	0.2	1.0	1	1	1
10/08/2022 03:00	0.3	12.1	2,178.8	0.2	1.0	1	1	1
10/08/2022 04:00	0.3	12.1	2,186.4	0.2	1.0	1	1	1
10/08/2022 05:00	0.3	12.2	2,175.0	0.2	1.0	1	1	1
10/08/2022 06:00	0.4	12.6	2,114.0	0.2	1.3	1	1	1
10/08/2022 07:00	0.3	13.7	1,700.8	0.2	0.9	1	1	1
10/08/2022 08:00	0.2	14.0	1,358.1	0.2	0.5	1	1	0
10/08/2022 09:00	0.1	14.1	1,309.6	0.2	0.3	1	1	0
10/08/2022 10:00	0.1	14.1	1,309.0	0.1	0.3	1	1	0
10/08/2022 11:00	0.1	14.1	1,314.2	0.1	0.3	1	1	0
10/08/2022 12:00	0.3	13.9	1,559.1	0.2	0.9	1	1	0
10/08/2022 13:00	0.3	13.9	1,711.4	0.2	1.0	1	1	0
10/08/2022 14:00	0.3	13.8	1,728.5	0.3	1.0	1	1	1
10/08/2022 15:00	0.5	12.3	2,093.4	0.3	1.6	1	1	1
10/08/2022 16:00	0.3	11.8	2,196.4	0.2	1.0	1	1	1
10/08/2022 17:00	0.3	11.8	2,200.9	0.2	1.0	1	1	1
10/08/2022 18:00	0.3	12.0	2,169.3	0.2	1.0	1	1	1
10/08/2022 19:00	0.3	12.0	2,176.3	0.2	1.0	1	1	1
10/08/2022 20:00	0.3	12.0	2,183.4	0.2	1.0	1	1	1
10/08/2022 21:00	0.3	12.0	2,182.8	0.2	1.0	1	1	1
10/08/2022 22:00	0.3	12.1	2,179.0	0.2	1.0	1	1	1
10/08/2022 23:00	0.3	12.2	2,177.1	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.7	1,946.8	0.2	22.1 #	24 #	24 #	18 #
Minimum:	0.1	11.8	1,309.0	0.1	0.3	1	1	0
Maximum:	0.5	14.1	2,200.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	0.3	12.1	2,173.7	0.2	1.0	1	1	1
10/09/2022 01:00	0.3	12.2	2,176.5	0.2	1.0	1	1	1
10/09/2022 02:00	0.3	12.3	2,147.0	0.2	1.0	1	1	1
10/09/2022 03:00	0.3	12.3	2,158.6	0.2	1.0	1	1	1
10/09/2022 04:00	0.3	12.2	2,165.0	0.2	1.0	1	1	1
10/09/2022 05:00	0.3	12.2	2,156.0	0.2	1.0	1	1	1
10/09/2022 06:00	6.8	13.7	1,682.6	0.0	21.0	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 14:00	20.9	17.6	384.2	0.0	23.1	1	0	0
10/09/2022 15:00	12.9	14.5	1,309.2	0.0	34.9	1	0	0
10/09/2022 16:00	0.3	13.9	1,714.4	0.0	1.0	1	1	0
10/09/2022 17:00	0.3	13.7	1,764.8	0.0	1.0	1	1	1
10/09/2022 18:00	0.5	12.4	2,079.4	0.3	1.6	1	1	1
10/09/2022 19:00	0.2	11.8	2,207.7	0.2	0.6	1	1	1
10/09/2022 20:00	0.2	12.0	2,185.0	0.2	0.6	1	1	1
10/09/2022 21:00	0.3	12.1	2,173.4	0.1	1.0	1	1	1
10/09/2022 22:00	0.3	12.2	2,156.8	0.2	1.0	1	1	1
10/09/2022 23:00	0.3	12.2	2,148.5	0.2	1.0	1	1	1
Average/Sum#:	2.6	12.9	1,928.4	0.2	92.8 #	17 #	14 #	14 #
Minimum:	0.2	11.8	384.2	0.1	0.6	0	0	0
Maximum:	20.9	17.6	2,207.7	0.3	34.9	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	0.3	12.3	2,123.4	0.2	1.0	1	1	1
10/10/2022 01:00	0.3	12.5	2,095.3	0.2	1.0	1	1	1
10/10/2022 02:00	0.5	13.0	1,981.4	0.3	1.7	1	1	1
10/10/2022 03:00	0.4	12.5	2,093.7	0.3	1.3	1	1	1
10/10/2022 04:00	0.3	12.4	2,139.2	0.3	1.0	1	1	1
10/10/2022 05:00	0.2	12.0	2,225.5	0.2	0.7	1	1	1
10/10/2022 06:00	0.2	12.1	2,215.7	0.1	0.7	1	1	1
10/10/2022 07:00	0.3	13.4	1,803.1	0.1	1.0	1	1	1
10/10/2022 08:00	0.2	13.9	1,542.0	0.2	0.6	1	1	0
10/10/2022 09:00	0.2	14.0	1,535.7	0.2	0.6	1	1	0
10/10/2022 10:00	0.1	14.1	1,390.1	0.2	0.3	1	1	0
10/10/2022 11:00	0.2	14.0	1,562.7	0.2	0.6	1	1	0
10/10/2022 12:00	0.2	14.1	1,576.8	0.2	0.6	1	1	0
10/10/2022 13:00	0.2	13.9	1,704.6	0.2	0.6	1	1	0
10/10/2022 14:00	0.2	13.9	1,711.9	0.2	0.6	1	1	0
10/10/2022 15:00	0.3	13.9	1,584.5	0.2	0.9	1	1	0
10/10/2022 16:00	0.5	12.8	1,953.3	0.3	1.6	1	1	1
10/10/2022 17:00	0.3	12.0	2,159.8	0.3	1.0	1	1	1
10/10/2022 18:00	0.3	11.9	2,194.5	0.3	1.0	1	1	1
10/10/2022 19:00	0.3	12.0	2,171.3	0.2	1.0	1	1	1
10/10/2022 20:00	0.3	12.1	2,163.2	0.2	1.0	1	1	1
10/10/2022 21:00	0.4	12.3	2,109.3	0.2	1.3	1	1	1
10/10/2022 22:00	0.4	12.5	2,091.9	0.3	1.3	1	1	1
10/10/2022 23:00	0.5	13.0	1,947.6	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,919.9	0.2	23.0 #	24 #	24 #	16 #
Minimum:	0.1	11.9	1,390.1	0.1	0.3	1	1	0
Maximum:	0.5	14.1	2,225.5	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.2	14.0	1,368.8	0.3	0.5	1	1	0
10/11/2022 01:00	0.2	14.0	1,294.0	0.3	0.5	1	1	0
10/11/2022 02:00	0.1	14.0	1,293.9	0.2	0.2	1	1	0
10/11/2022 03:00	0.2	14.0	1,345.8	0.2	0.5	1	1	0
10/11/2022 04:00	0.2	14.0	1,489.9	0.2	0.6	1	1	0
10/11/2022 05:00	0.2	14.0	1,314.3	0.2	0.5	1	1	0
10/11/2022 06:00	0.2	14.0	1,303.1	0.2	0.5	1	1	0
10/11/2022 07:00	0.2	14.0	1,318.9	0.2	0.5	1	1	0
10/11/2022 08:00	0.2	13.9	1,748.2	0.2	0.7	1	1	0
10/11/2022 09:00	0.2	14.0	1,592.2	0.2	0.6	1	1	0
10/11/2022 10:00	0.3	13.8	1,729.7	0.2	1.0	1	1	0
10/11/2022 11:00	0.3	13.8	1,747.4	0.2	1.0	1	1	0
10/11/2022 12:00	0.3	13.9	1,748.6	0.2	1.0	1	1	0
10/11/2022 13:00	0.3	13.9	1,740.2	0.3	1.0	1	1	0
10/11/2022 14:00	0.3	13.9	1,733.2	0.3	1.0	1	1	0
10/11/2022 15:00	0.3	13.9	1,737.7	0.3	1.0	1	1	0
10/11/2022 16:00	0.3	13.8	1,760.7	0.3	1.0	1	1	0
10/11/2022 17:00	0.3	13.7	1,770.9	0.2	1.0	1	1	0
10/11/2022 18:00	0.3	13.7	1,775.7	0.2	1.0	1	1	1
10/11/2022 19:00	0.6	12.5	2,057.5	0.3	1.9	1	1	1
10/11/2022 20:00	0.4	12.3	2,104.9	0.3	1.3	1	1	1
10/11/2022 21:00	0.4	12.1	2,159.4	0.3	1.3	1	1	1
10/11/2022 22:00	0.4	12.4	2,094.6	0.3	1.3	1	1	1
10/11/2022 23:00	0.5	13.0	1,961.3	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.6	1,674.6	0.2	21.5 #	24 #	24 #	6 #
Minimum:	0.1	12.1	1,293.9	0.2	0.2	1	1	0
Maximum:	0.6	14.0	2,159.4	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	0.7	13.1	1,948.6	0.4	2.3	1	1	1
10/12/2022 01:00	0.7	13.1	1,928.9	0.5	2.3	1	1	1
10/12/2022 02:00	0.2	13.9	1,512.2	0.4	0.6	1	1	0
10/12/2022 03:00	0.2	13.9	1,624.7	0.3	0.6	1	1	0
10/12/2022 04:00	0.2	13.8	1,746.5	0.2	0.6	1	1	0
10/12/2022 05:00	0.5	12.4	2,122.6	0.2	1.6	1	1	1
10/12/2022 06:00	0.3	11.9	2,254.3	0.2	1.0	1	1	1
10/12/2022 07:00	0.2	11.9	2,245.2	0.2	0.7	1	1	1
10/12/2022 08:00	0.2	11.9	2,243.2	0.1	0.7	1	1	1
10/12/2022 09:00	0.2	11.9	2,238.0	0.1	0.7	1	1	1
10/12/2022 10:00	0.2	11.9	2,234.1	0.1	0.7	1	1	1
10/12/2022 11:00	0.2	11.9	2,233.9	0.1	0.7	1	1	1
10/12/2022 12:00	0.2	11.9	2,231.6	0.1	0.7	1	1	1
10/12/2022 13:00	0.2	11.9	2,228.9	0.1	0.7	1	1	1
10/12/2022 14:00	0.2	11.9	2,229.7	0.1	0.7	1	1	1
10/12/2022 15:00	0.2	11.8	2,235.6	0.1	0.6	1	1	1
10/12/2022 16:00	0.2	11.6	2,251.1	0.1	0.6	1	1	1
10/12/2022 17:00	0.2	11.6	2,260.5	0.1	0.6	1	1	1
10/12/2022 18:00	0.2	11.8	2,224.2	0.1	0.6	1	1	1
10/12/2022 19:00	0.3	12.2	2,135.6	0.1	1.0	1	1	1
10/12/2022 20:00	0.3	12.2	2,150.7	0.2	1.0	1	1	1
10/12/2022 21:00	0.4	12.3	2,115.2	0.2	1.3	1	1	1
10/12/2022 22:00	0.4	12.5	2,084.9	0.3	1.3	1	1	1
10/12/2022 23:00	0.6	13.0	1,959.2	0.3	2.0	1	1	1
Average/Sum#:	0.3	12.3	2,101.6	0.2	23.6 #	24 #	24 #	21 #
Minimum:	0.2	11.6	1,512.2	0.1	0.6	1	1	0
Maximum:	0.7	13.9	2,260.5	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	0.6	13.0	1,956.6	0.4	2.0	1	1	1
10/13/2022 01:00	0.6	12.8	2,000.9	0.4	2.0	1	1	1
10/13/2022 02:00	0.8	13.1	1,947.1	0.5	2.6	1	1	1
10/13/2022 03:00	0.7	13.1	1,959.2	0.5	2.3	1	1	1
10/13/2022 04:00	0.8	13.1	1,939.6	0.6	2.6	1	1	1
10/13/2022 05:00	0.2	13.9	1,307.9	0.4	0.5	1	1	0
10/13/2022 06:00	0.2	13.9	1,308.4	0.3	0.5	1	1	0
10/13/2022 07:00	0.2	14.0	1,308.7	0.2	0.5	1	1	0
10/13/2022 08:00	0.2	13.9	1,486.8	0.2	0.6	1	1	0
10/13/2022 09:00	0.2	13.9	1,537.2	0.2	0.6	1	1	0
10/13/2022 10:00	0.3	13.8	1,712.7	0.2	1.0	1	1	0
10/13/2022 11:00	0.3	13.7	1,794.6	0.2	1.0	1	1	0
10/13/2022 12:00	0.3	13.7	1,790.4	0.2	1.0	1	1	0
10/13/2022 13:00	0.3	13.7	1,784.6	0.2	1.0	1	1	0
10/13/2022 14:00	0.3	13.7	1,779.9	0.2	1.0	1	1	0
10/13/2022 15:00	0.3	13.7	1,777.3	0.2	1.0	1	1	0
10/13/2022 16:00	0.3	13.7	1,779.0	0.2	1.0	1	1	0
10/13/2022 17:00	0.3	13.7	1,779.7	0.2	1.0	1	1	0
10/13/2022 18:00	0.3	13.7	1,784.4	0.2	1.0	1	1	0
10/13/2022 19:00	0.3	13.7	1,788.0	0.2	1.0	1	1	1
10/13/2022 20:00	0.6	12.6	2,057.0	0.3	2.0	1	1	1
10/13/2022 21:00	0.4	12.2	2,156.4	0.3	1.3	1	1	1
10/13/2022 22:00	0.4	12.5	2,080.5	0.3	1.3	1	1	1
10/13/2022 23:00	0.4	12.6	2,070.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.4	1,787.0	0.3	30.1 #	24 #	24 #	10 #
Minimum:	0.2	12.2	1,307.9	0.2	0.5	1	1	0
Maximum:	0.8	14.0	2,156.4	0.6	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	0.4	12.7	2,061.1	0.3	1.3	1	1	1
10/14/2022 01:00	0.4	12.6	2,074.7	0.3	1.3	1	1	1
10/14/2022 02:00	0.4	12.6	2,074.6	0.3	1.3	1	1	1
10/14/2022 03:00	0.4	12.6	2,071.6	0.3	1.3	1	1	1
10/14/2022 04:00	0.3	12.4	2,112.7	0.3	1.0	1	1	1
10/14/2022 05:00	0.2	11.8	2,260.2	0.2	0.7	1	1	1
10/14/2022 06:00	0.2	11.8	2,253.5	0.1	0.7	1	1	1
10/14/2022 07:00	0.2	11.9	2,225.2	0.1	0.7	1	1	1
10/14/2022 08:00	0.3	12.7	2,025.4	0.1	1.0	1	1	1
10/14/2022 09:00	0.4	13.0	1,963.8	0.2	1.3	1	1	1
10/14/2022 10:00	0.4	12.9	1,974.2	0.3	1.3	1	1	1
10/14/2022 11:00	0.4	12.8	1,981.1	0.3	1.3	1	1	1
10/14/2022 12:00	0.5	12.8	1,989.4	0.3	1.6	1	1	1
10/14/2022 13:00	0.4	12.7	1,999.2	0.3	1.3	1	1	1
10/14/2022 14:00	0.4	12.3	2,098.0	0.3	1.3	1	1	1
10/14/2022 15:00	0.3	12.2	2,127.4	0.3	1.0	1	1	1
10/14/2022 16:00	0.3	12.2	2,119.3	0.2	1.0	1	1	1
10/14/2022 17:00	0.2	11.8	2,207.4	0.2	0.6	1	1	1
10/14/2022 18:00	0.3	12.1	2,149.5	0.2	1.0	1	1	1
10/14/2022 19:00	0.3	12.2	2,120.7	0.2	1.0	1	1	1
10/14/2022 20:00	0.3	12.2	2,129.6	0.2	1.0	1	1	1
10/14/2022 21:00	0.3	12.3	2,120.9	0.2	1.0	1	1	1
10/14/2022 22:00	0.3	12.4	2,093.7	0.2	1.0	1	1	1
10/14/2022 23:00	6.4	14.0	1,326.6	0.0	9.0	1	0	1
Average/Sum#:	0.6	12.5	2,065.0	0.2	34.0 #	24 #	23 #	24 #
Minimum:	0.2	11.8	1,326.6	0.1	0.6	1	0	1
Maximum:	6.4	14.0	2,260.2	0.3	9.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	75.4	17.7	328.5	0.0	74.6	1	0	0
10/16/2022 18:00	35.0	16.5	574.4	0.0	60.3	1	0	0
10/16/2022 19:00	36.7	15.1	965.7	0.0	80.7	1	0	0
10/16/2022 20:00	0.2	13.8	1,770.5	0.0	0.7	1	1	0
10/16/2022 21:00	0.2	13.8	1,686.0	0.0	0.6	1	1	0
10/16/2022 22:00	0.2	13.9	1,594.4	0.2	0.6	1	1	0
10/16/2022 23:00	0.2	13.8	1,803.8	0.2	0.7	1	1	0
Average/Sum#:	21.1	14.9	1,246.2	0.2	218.2 #	7 #	4 #	0 #
Minimum:	0.2	13.8	328.5	0.2	0.6	0	0	0
Maximum:	75.4	17.7	1,803.8	0.2	80.7	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.2	13.9	1,642.9	0.2	0.6	1	1	0
10/17/2022 01:00	0.2	13.9	1,698.6	0.2	0.6	1	1	0
10/17/2022 02:00	0.2	13.9	1,702.5	0.2	0.6	1	1	0
10/17/2022 03:00	0.2	13.8	1,794.9	0.2	0.7	1	1	1
10/17/2022 04:00	0.4	12.7	2,058.2	0.2	1.3	1	1	1
10/17/2022 05:00	0.2	12.2	2,160.0	0.2	0.7	1	1	1
10/17/2022 06:00	0.2	12.3	2,145.3	0.2	0.7	1	1	1
10/17/2022 07:00	0.3	12.5	2,099.6	0.1	1.0	1	1	1
10/17/2022 08:00	0.2	13.8	1,683.3	0.2	0.6	1	1	1
10/17/2022 09:00	0.1	13.9	1,632.3	0.2	0.3	1	1	0
10/17/2022 10:00	0.2	14.0	1,522.6	0.2	0.6	1	1	0
10/17/2022 11:00	0.2	14.0	1,609.1	0.2	0.6	1	1	0
10/17/2022 12:00	0.2	14.0	1,506.6	0.2	0.6	1	1	0
10/17/2022 13:00	0.2	14.0	1,501.4	0.2	0.6	1	1	0
10/17/2022 14:00	0.2	14.0	1,657.9	0.2	0.6	1	1	0
10/17/2022 15:00	0.3	13.8	1,696.8	0.2	0.9	1	1	1
10/17/2022 16:00	0.5	12.5	2,079.8	0.3	1.6	1	1	1
10/17/2022 17:00	0.3	11.8	2,230.9	0.3	1.0	1	1	1
10/17/2022 18:00	0.2	11.8	2,246.4	0.2	0.7	1	1	1
10/17/2022 19:00	0.2	11.9	2,223.6	0.1	0.7	1	1	1
10/17/2022 20:00	0.2	11.9	2,229.9	0.1	0.7	1	1	1
10/17/2022 21:00	0.2	11.8	2,239.7	0.1	0.7	1	1	1
10/17/2022 22:00	0.3	12.2	2,177.2	0.1	1.0	1	1	1
10/17/2022 23:00	0.3	12.2	2,183.6	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.0	1,905.1	0.2	18.4 #	24 #	24 #	15 #
Minimum:	0.1	11.8	1,501.4	0.1	0.3	1	1	0
Maximum:	0.5	14.0	2,246.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	0.3	12.2	2,179.1	0.2	1.0	1	1	1
10/18/2022 01:00	0.2	12.3	2,170.9	0.2	0.7	1	1	1
10/18/2022 02:00	0.2	12.2	2,170.7	0.1	0.7	1	1	1
10/18/2022 03:00	0.2	12.1	2,176.9	0.1	0.7	1	1	1
10/18/2022 04:00	0.2	12.1	2,177.4	0.1	0.7	1	1	1
10/18/2022 05:00	0.3	12.2	2,182.6	0.1	1.0	1	1	1
10/18/2022 06:00	0.3	12.3	2,168.2	0.2	1.0	1	1	1
10/18/2022 07:00	0.3	12.3	2,166.7	0.2	1.0	1	1	1
10/18/2022 08:00	0.3	12.3	2,171.0	0.2	1.0	1	1	1
10/18/2022 09:00	0.3	12.4	2,155.8	0.2	1.0	1	1	1
10/18/2022 10:00	0.4	12.4	2,119.5	0.2	1.3	1	1	1
10/18/2022 11:00	0.4	12.5	2,098.2	0.3	1.3	1	1	1
10/18/2022 12:00	0.4	12.5	2,098.2	0.3	1.3	1	1	1
10/18/2022 13:00	0.4	12.5	2,102.8	0.3	1.3	1	1	1
10/18/2022 14:00	0.4	12.4	2,107.4	0.3	1.3	1	1	1
10/18/2022 15:00	0.4	12.3	2,134.7	0.3	1.3	1	1	1
10/18/2022 16:00	0.3	11.9	2,216.3	0.3	1.0	1	1	1
10/18/2022 17:00	0.3	12.1	2,188.4	0.2	1.0	1	1	1
10/18/2022 18:00	0.3	11.9	2,231.8	0.2	1.0	1	1	1
10/18/2022 19:00	0.2	11.8	2,253.5	0.2	0.7	1	1	1
10/18/2022 20:00	0.2	11.8	2,259.4	0.1	0.7	1	1	1
10/18/2022 21:00	0.2	11.8	2,259.3	0.1	0.7	1	1	1
10/18/2022 22:00	0.3	12.1	2,195.6	0.1	1.0	1	1	1
10/18/2022 23:00	0.3	12.1	2,192.8	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.2	2,174.1	0.2	23.7 #	24 #	24 #	24 #
Minimum:	0.2	11.8	2,098.2	0.1	0.7	1	1	1
Maximum:	0.4	12.5	2,259.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	0.3	12.2	2,182.0	0.2	1.0	1	1	1
10/19/2022 01:00	0.4	12.5	2,136.3	0.2	1.3	1	1	1
10/19/2022 02:00	0.4	12.6	2,103.7	0.3	1.3	1	1	1
10/19/2022 03:00	0.4	12.5	2,144.5	0.3	1.3	1	1	1
10/19/2022 04:00	0.3	12.3	2,188.0	0.3	1.0	1	1	1
10/19/2022 05:00	0.3	12.0	2,237.9	0.2	1.0	1	1	1
10/19/2022 06:00	0.3	12.2	2,213.4	0.2	1.0	1	1	1
10/19/2022 07:00	0.4	12.4	2,148.6	0.2	1.3	1	1	1
10/19/2022 08:00	0.4	12.5	2,138.1	0.3	1.3	1	1	1
10/19/2022 09:00	0.4	12.6	2,094.9	0.3	1.3	1	1	1
10/19/2022 10:00	0.4	12.6	2,079.5	0.3	1.3	1	1	1
10/19/2022 11:00	0.4	12.4	2,110.0	0.3	1.3	1	1	1
10/19/2022 12:00	0.4	12.3	2,130.2	0.3	1.3	1	1	1
10/19/2022 13:00	0.4	12.2	2,149.0	0.3	1.3	1	1	1
10/19/2022 14:00	0.4	12.2	2,141.4	0.3	1.3	1	1	1
10/19/2022 15:00	0.3	12.0	2,178.1	0.3	1.0	1	1	1
10/19/2022 16:00	0.3	12.0	2,194.2	0.2	1.0	1	1	1
10/19/2022 17:00	0.4	12.3	2,123.6	0.2	1.3	1	1	1
10/19/2022 18:00	0.4	12.4	2,099.3	0.3	1.3	1	1	1
10/19/2022 19:00	0.4	12.4	2,108.5	0.3	1.3	1	1	1
10/19/2022 20:00	0.4	12.3	2,147.1	0.3	1.3	1	1	1
10/19/2022 21:00	0.4	12.5	2,114.2	0.3	1.3	1	1	1
10/19/2022 22:00	0.4	12.6	2,087.5	0.3	1.3	1	1	1
10/19/2022 23:00	0.4	12.5	2,105.2	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,139.8	0.3	29.4 #	24 #	24 #	24 #
Minimum:	0.3	12.0	2,079.5	0.2	1.0	1	1	1
Maximum:	0.4	12.6	2,237.9	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	0.4	12.5	2,124.0	0.3	1.3	1	1	1
10/20/2022 01:00	0.4	12.6	2,087.9	0.3	1.3	1	1	1
10/20/2022 02:00	0.4	12.6	2,078.6	0.3	1.3	1	1	1
10/20/2022 03:00	0.5	12.6	2,089.3	0.3	1.7	1	1	1
10/20/2022 04:00	0.4	12.5	2,135.5	0.3	1.3	1	1	1
10/20/2022 05:00	0.3	12.1	2,217.9	0.3	1.0	1	1	1
10/20/2022 06:00	0.3	12.3	2,191.7	0.2	1.0	1	1	1
10/20/2022 07:00	0.4	12.8	2,069.5	0.2	1.3	1	1	1
10/20/2022 08:00	0.4	12.8	2,056.4	0.3	1.3	1	1	1
10/20/2022 09:00	0.5	12.7	2,066.1	0.3	1.7	1	1	1
10/20/2022 10:00	0.4	12.7	2,060.8	0.3	1.3	1	1	1
10/20/2022 11:00	0.4	12.5	2,079.4	0.3	1.3	1	1	1
10/20/2022 12:00	0.4	12.5	2,079.4	0.3	1.3	1	1	1
10/20/2022 13:00	0.4	12.4	2,099.7	0.3	1.3	1	1	1
10/20/2022 14:00	0.4	12.3	2,121.0	0.3	1.3	1	1	1
10/20/2022 15:00	0.4	12.2	2,147.2	0.3	1.3	1	1	1
10/20/2022 16:00	0.3	11.7	2,241.0	0.3	1.0	1	1	1
10/20/2022 17:00	0.3	12.0	2,178.6	0.2	1.0	1	1	1
10/20/2022 18:00	0.3	11.9	2,212.5	0.2	1.0	1	1	1
10/20/2022 19:00	0.4	12.3	2,107.9	0.2	1.3	1	1	1
10/20/2022 20:00	0.4	12.4	2,104.9	0.3	1.3	1	1	1
10/20/2022 21:00	0.4	12.6	2,083.3	0.3	1.3	1	1	1
10/20/2022 22:00	0.4	12.6	2,083.3	0.3	1.3	1	1	1
10/20/2022 23:00	0.4	12.4	2,136.7	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,118.9	0.3	30.5 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,056.4	0.2	1.0	1	1	1
Maximum:	0.5	12.8	2,241.0	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	0.5	12.9	1,988.0	0.3	1.6	1	1	1
10/21/2022 01:00	0.2	14.0	1,577.0	0.3	0.6	1	1	0
10/21/2022 02:00	0.3	13.9	1,586.8	0.3	0.9	1	1	0
10/21/2022 03:00	0.3	13.9	1,543.4	0.3	0.9	1	1	0
10/21/2022 04:00	0.2	14.0	1,696.1	0.3	0.6	1	1	0
10/21/2022 05:00	0.2	14.0	1,698.2	0.2	0.7	1	1	0
10/21/2022 06:00	0.2	14.0	1,598.5	0.2	0.6	1	1	0
10/21/2022 07:00	0.2	14.0	1,668.5	0.2	0.6	1	1	0
10/21/2022 08:00	0.2	14.0	1,704.9	0.2	0.7	1	1	0
10/21/2022 09:00	0.2	14.0	1,708.4	0.2	0.7	1	1	0
10/21/2022 10:00	0.2	14.0	1,706.9	0.2	0.7	1	1	0
10/21/2022 11:00	0.2	14.0	1,671.9	0.2	0.6	1	1	0
10/21/2022 12:00	0.3	14.0	1,648.8	0.2	0.9	1	1	0
10/21/2022 13:00	0.3	14.0	1,624.1	0.3	0.9	1	1	0
10/21/2022 14:00	0.3	13.9	1,681.0	0.3	1.0	1	1	0
10/21/2022 15:00	0.3	13.9	1,556.4	0.3	0.9	1	1	1
10/21/2022 16:00	0.5	12.4	2,095.8	0.3	1.6	1	1	1
10/21/2022 17:00	0.3	12.0	2,180.2	0.3	1.0	1	1	1
10/21/2022 18:00	0.4	12.2	2,136.5	0.3	1.3	1	1	1
10/21/2022 19:00	0.4	12.4	2,098.4	0.3	1.3	1	1	1
10/21/2022 20:00	0.4	12.3	2,116.7	0.3	1.3	1	1	1
10/21/2022 21:00	0.3	12.0	2,176.0	0.3	1.0	1	1	1
10/21/2022 22:00	7.8	14.3	1,201.6	0.0	9.8	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.5	1,768.0	0.3	30.2 #	23 #	22 #	9 #
Minimum:	0.2	12.0	1,201.6	0.2	0.6	0	0	0
Maximum:	7.8	14.3	2,180.2	0.3	9.8	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	68.5	17.8	297.2	0.0	62.4	1	0	0
10/23/2022 21:00	15.2	17.3	370.7	0.0	20.7	1	0	0
10/23/2022 22:00	20.3	15.9	787.1	0.0	42.2	1	0	0
10/23/2022 23:00	0.1	14.1	1,353.7	0.0	0.3	1	1	0
Average/Sum#:	26.0	16.3	702.2	0.0	125.6 #	4 #	1 #	0 #
Minimum:	0.1	14.1	297.2	0.0	0.3	0	0	0
Maximum:	68.5	17.8	1,353.7	0.0	62.4	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.1	14.1	1,368.5	0.0	0.3	1	1	0
10/24/2022 01:00	0.1	14.1	1,359.7	0.1	0.3	1	1	0
10/24/2022 02:00	0.1	14.1	1,359.6	0.1	0.3	1	1	0
10/24/2022 03:00	0.1	14.1	1,359.6	0.1	0.3	1	1	0
10/24/2022 04:00	0.1	13.9	1,649.1	0.1	0.3	1	1	0
10/24/2022 05:00	0.1	13.8	1,820.4	0.1	0.3	1	1	0
10/24/2022 06:00	0.1	13.8	1,821.7	0.1	0.3	1	1	0
10/24/2022 07:00	0.1	13.8	1,819.3	0.1	0.3	1	1	0
10/24/2022 08:00	0.1	13.9	1,816.0	0.1	0.3	1	1	0
10/24/2022 09:00	0.2	13.9	1,793.7	0.1	0.7	1	1	0
10/24/2022 10:00	0.2	13.8	1,841.1	0.2	0.7	1	1	0
10/24/2022 11:00	0.2	13.8	1,831.5	0.2	0.7	1	1	0
10/24/2022 12:00	0.2	13.9	1,769.6	0.2	0.7	1	1	0
10/24/2022 13:00	0.2	13.9	1,746.6	0.2	0.7	1	1	0
10/24/2022 14:00	8.8	15.1	1,013.9	0.0	8.5	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.7	14.0	1,624.7	0.1	14.7 #	15 #	14 #	0 #
Minimum:	0.1	13.8	1,013.9	0.1	0.3	0	0	0
Maximum:	8.8	15.1	1,841.1	0.2	8.5	1	1	0
%SI	37.50	37.50	37.50	45.83	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	119.2	18.9	164.5	0.0	25.9	1	0	0
10/30/2022 20:00	36.5	17.3	372.9	0.0	49.9	1	0	0
10/30/2022 21:00	29.3	16.8	562.7	0.0	53.1	1	0	0
10/30/2022 22:00	37.6	16.0	878.4	0.0	89.0	1	0	0
10/30/2022 23:00	0.2	13.8	1,773.4	0.0	0.7	1	1	0
Average/Sum#:	44.6	16.6	750.4	0.0	218.6 #	5 #	1 #	0 #
Minimum:	0.2	13.8	164.5	0.0	0.7	0	0	0
Maximum:	119.2	18.9	1,773.4	0.0	89.0	1	1	0
%SI	79.17	79.17	79.17	100.00	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.2	14.0	1,565.8	0.0	0.6	1	1	0
10/31/2022 01:00	0.2	13.9	1,787.0	0.2	0.7	1	1	0
10/31/2022 02:00	0.2	14.0	1,671.4	0.2	0.6	1	1	0
10/31/2022 03:00	0.2	14.0	1,708.8	0.2	0.7	1	1	0
10/31/2022 04:00	0.2	14.0	1,723.8	0.2	0.7	1	1	0
10/31/2022 05:00	0.2	14.0	1,708.1	0.2	0.7	1	1	0
10/31/2022 06:00	0.2	14.0	1,699.3	0.2	0.7	1	1	0
10/31/2022 07:00	0.2	14.0	1,700.7	0.2	0.7	1	1	0
10/31/2022 08:00	0.2	14.0	1,704.0	0.2	0.7	1	1	0
10/31/2022 09:00	0.2	14.0	1,705.2	0.2	0.7	1	1	0
10/31/2022 10:00	0.2	14.0	1,708.1	0.2	0.7	1	1	0
10/31/2022 11:00	0.2	14.0	1,687.1	0.2	0.6	1	1	0
10/31/2022 12:00	0.2	14.0	1,677.9	0.2	0.6	1	1	0
10/31/2022 13:00	0.2	14.0	1,691.9	0.2	0.6	1	1	0
10/31/2022 14:00	0.3	13.9	1,760.4	0.2	1.0	1	1	1
10/31/2022 15:00	0.6	12.6	2,079.3	0.3	2.0	1	1	1
10/31/2022 16:00	0.5	12.5	2,105.8	0.4	1.7	1	1	1
10/31/2022 17:00	0.5	12.6	2,078.5	0.4	1.7	1	1	1
10/31/2022 18:00	0.5	12.6	2,081.3	0.4	1.7	1	1	1
10/31/2022 19:00	0.4	12.5	2,104.0	0.4	1.3	1	1	1
10/31/2022 20:00	0.4	12.5	2,108.1	0.3	1.3	1	1	1
10/31/2022 21:00	0.4	12.3	2,163.0	0.3	1.3	1	1	1
10/31/2022 22:00	0.3	12.5	2,119.3	0.3	1.0	1	1	1
10/31/2022 23:00	0.3	12.3	2,146.3	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.4	1,853.5	0.3	23.3 #	24 #	24 #	10 #
Minimum:	0.2	12.3	1,565.8	0.2	0.6	1	1	0
Maximum:	0.6	14.0	2,163.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	0.3	12.4	2,163.8	0.2	1.0	1	1	1
11/01/2022 01:00	0.3	12.4	2,153.2	0.2	1.0	1	1	1
11/01/2022 02:00	0.3	12.4	2,162.1	0.2	1.0	1	1	1
11/01/2022 03:00	0.3	12.4	2,163.5	0.2	1.0	1	1	1
11/01/2022 04:00	0.3	12.4	2,167.9	0.2	1.0	1	1	1
11/01/2022 05:00	0.3	12.4	2,167.4	0.2	1.0	1	1	1
11/01/2022 06:00	0.2	12.1	2,232.9	0.2	0.7	1	1	1
11/01/2022 07:00	0.2	12.3	2,179.4	0.1	0.7	1	1	1
11/01/2022 08:00	0.2	12.0	2,231.6	0.1	0.7	1	1	1
11/01/2022 09:00	0.2	12.4	2,116.2	0.1	0.7	1	1	1
11/01/2022 10:00	0.3	12.5	2,121.2	0.1	1.0	1	1	1
11/01/2022 11:00	0.2	12.2	2,178.7	0.1	0.7	1	1	1
11/01/2022 12:00	0.2	12.2	2,182.8	0.1	0.7	1	1	1
11/01/2022 13:00	0.2	12.3	2,169.2	0.1	0.7	1	1	1
11/01/2022 14:00	0.2	12.6	2,083.1	0.1	0.7	1	1	1
11/01/2022 15:00	0.4	12.7	2,094.6	0.2	1.3	1	1	1
11/01/2022 16:00	0.3	12.2	2,225.8	0.2	1.0	1	1	1
11/01/2022 17:00	0.1	11.9	2,292.1	0.2	0.3	1	1	1
11/01/2022 18:00	0.2	12.3	2,192.0	0.1	0.7	1	1	1
11/01/2022 19:00	0.2	12.5	2,163.6	0.1	0.7	1	1	1
11/01/2022 20:00	0.2	12.3	2,201.7	0.1	0.7	1	1	1
11/01/2022 21:00	0.3	12.8	2,080.8	0.1	1.0	1	1	1
11/01/2022 22:00	0.3	12.9	2,070.4	0.2	1.0	1	1	1
11/01/2022 23:00	0.2	13.4	1,845.9	0.2	0.7	1	1	1
Average/Sum#:	0.2	12.4	2,151.7	0.2	20.0 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,845.9	0.1	0.3	1	1	1
Maximum:	0.4	13.4	2,292.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.1	14.1	1,347.9	0.2	0.3	1	1	0
11/02/2022 01:00	0.1	14.0	1,630.5	0.1	0.3	1	1	0
11/02/2022 02:00	0.2	14.0	1,698.9	0.1	0.7	1	1	0
11/02/2022 03:00	0.2	14.0	1,348.8	0.2	0.5	1	1	0
11/02/2022 04:00	0.2	14.0	1,665.7	0.2	0.6	1	1	0
11/02/2022 05:00	0.3	13.5	1,907.9	0.2	1.0	1	1	1
11/02/2022 06:00	0.4	12.7	2,175.1	0.2	1.4	1	1	1
11/02/2022 07:00	0.3	12.8	2,135.9	0.2	1.0	1	1	1
11/02/2022 08:00	0.4	13.1	2,040.3	0.3	1.4	1	1	1
11/02/2022 09:00	0.1	14.0	1,710.1	0.2	0.3	1	1	0
11/02/2022 10:00	0.1	14.0	1,543.3	0.2	0.3	1	1	0
11/02/2022 11:00	0.1	14.0	1,672.4	0.1	0.3	1	1	0
11/02/2022 12:00	0.1	14.0	1,549.7	0.1	0.3	1	1	0
11/02/2022 13:00	0.1	14.0	1,552.9	0.1	0.3	1	1	0
11/02/2022 14:00	0.2	14.0	1,535.2	0.1	0.6	1	1	0
11/02/2022 15:00	0.2	14.0	1,604.0	0.2	0.6	1	1	1
11/02/2022 16:00	0.4	12.8	2,092.6	0.2	1.4	1	1	1
11/02/2022 17:00	0.3	12.5	2,182.8	0.2	1.0	1	1	1
11/02/2022 18:00	0.3	12.5	2,177.3	0.2	1.0	1	1	1
11/02/2022 19:00	0.3	12.5	2,175.0	0.2	1.0	1	1	1
11/02/2022 20:00	0.3	12.6	2,175.1	0.2	1.0	1	1	1
11/02/2022 21:00	0.3	12.6	2,157.6	0.2	1.0	1	1	1
11/02/2022 22:00	0.3	12.6	2,164.2	0.2	1.0	1	1	1
11/02/2022 23:00	0.3	12.6	2,177.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.4	1,850.9	0.2	18.3 #	24 #	24 #	13 #
Minimum:	0.1	12.5	1,347.9	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,182.8	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	0.3	12.6	2,169.0	0.2	1.0	1	1	1
11/03/2022 01:00	0.3	12.7	2,153.0	0.2	1.0	1	1	1
11/03/2022 02:00	0.3	12.5	2,194.3	0.2	1.0	1	1	1
11/03/2022 03:00	0.2	12.3	2,234.1	0.2	0.7	1	1	1
11/03/2022 04:00	0.3	12.6	2,163.9	0.2	1.0	1	1	1
11/03/2022 05:00	0.3	12.6	2,166.0	0.2	1.0	1	1	1
11/03/2022 06:00	0.2	12.4	2,231.2	0.2	0.7	1	1	1
11/03/2022 07:00	0.3	12.8	2,110.9	0.2	1.0	1	1	1
11/03/2022 08:00	0.1	14.1	1,456.2	0.1	0.3	1	1	0
11/03/2022 09:00	0.1	14.0	1,559.4	0.1	0.3	1	1	0
11/03/2022 10:00	0.1	14.0	1,574.2	0.1	0.3	1	1	0
11/03/2022 11:00	0.1	14.0	1,570.2	0.1	0.3	1	1	0
11/03/2022 12:00	0.1	14.0	1,579.0	0.1	0.3	1	1	0
11/03/2022 13:00	0.1	14.1	1,487.4	0.1	0.3	1	1	0
11/03/2022 14:00	0.2	14.1	1,553.3	0.1	0.6	1	1	0
11/03/2022 15:00	0.2	14.0	1,771.8	0.2	0.7	1	1	1
11/03/2022 16:00	0.4	12.8	2,084.1	0.2	1.4	1	1	1
11/03/2022 17:00	0.3	12.5	2,162.5	0.2	1.0	1	1	1
11/03/2022 18:00	0.2	12.5	2,175.5	0.2	0.7	1	1	1
11/03/2022 19:00	0.2	12.5	2,174.2	0.1	0.7	1	1	1
11/03/2022 20:00	0.2	12.5	2,163.4	0.1	0.7	1	1	1
11/03/2022 21:00	0.2	12.5	2,161.9	0.1	0.7	1	1	1
11/03/2022 22:00	0.2	12.5	2,161.6	0.1	0.7	1	1	1
11/03/2022 23:00	0.2	12.4	2,201.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	13.0	1,969.1	0.2	17.1 #	24 #	24 #	17 #
Minimum:	0.1	12.3	1,456.2	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,234.1	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	0.3	12.7	2,139.4	0.1	1.0	1	1	1
11/04/2022 01:00	0.3	12.7	2,120.0	0.2	1.0	1	1	1
11/04/2022 02:00	0.3	12.9	2,069.1	0.2	1.0	1	1	1
11/04/2022 03:00	0.3	12.9	2,071.1	0.2	1.0	1	1	1
11/04/2022 04:00	0.3	12.7	2,149.6	0.2	1.0	1	1	1
11/04/2022 05:00	0.2	12.3	2,242.1	0.2	0.7	1	1	1
11/04/2022 06:00	0.3	12.6	2,177.1	0.2	1.0	1	1	1
11/04/2022 07:00	0.3	13.0	2,059.9	0.2	1.0	1	1	1
11/04/2022 08:00	0.1	14.0	1,718.3	0.2	0.3	1	1	1
11/04/2022 09:00	0.1	14.0	1,552.2	0.1	0.3	1	1	0
11/04/2022 10:00	0.1	14.1	1,390.6	0.1	0.3	1	1	0
11/04/2022 11:00	0.1	14.1	1,319.4	0.1	0.3	1	1	0
11/04/2022 12:00	0.1	14.1	1,316.8	0.1	0.3	1	1	0
11/04/2022 13:00	0.1	14.1	1,317.6	0.1	0.3	1	1	0
11/04/2022 14:00	0.2	14.1	1,398.3	0.1	0.5	1	1	0
11/04/2022 15:00	0.3	13.9	1,629.0	0.2	0.9	1	1	1
11/04/2022 16:00	0.4	12.7	2,105.1	0.3	1.4	1	1	1
11/04/2022 17:00	0.3	12.5	2,145.5	0.3	1.0	1	1	1
11/04/2022 18:00	0.3	12.8	2,089.4	0.2	1.0	1	1	1
11/04/2022 19:00	0.3	12.8	2,086.7	0.2	1.0	1	1	1
11/04/2022 20:00	0.3	12.8	2,076.1	0.2	1.0	1	1	1
11/04/2022 21:00	0.3	12.8	2,074.7	0.2	1.0	1	1	1
11/04/2022 22:00	0.3	12.8	2,082.6	0.2	1.0	1	1	1
11/04/2022 23:00	0.3	13.3	1,970.2	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.2	1,887.5	0.2	19.3 #	24 #	24 #	18 #
Minimum:	0.1	12.3	1,316.8	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,242.1	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	0.4	13.3	1,965.0	0.2	1.4	1	1	1
11/05/2022 01:00	0.3	13.3	1,965.4	0.2	1.0	1	1	1
11/05/2022 02:00	0.4	13.3	1,965.9	0.3	1.4	1	1	1
11/05/2022 03:00	0.4	13.3	1,965.1	0.3	1.4	1	1	1
11/05/2022 04:00	0.4	13.3	1,973.7	0.3	1.4	1	1	1
11/05/2022 05:00	0.4	13.3	1,978.5	0.3	1.4	1	1	1
11/05/2022 06:00	0.4	13.3	1,948.0	0.3	1.4	1	1	1
11/05/2022 07:00	15.9	15.9	568.2	0.0	5.5	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.3	13.6	1,791.2	0.3	14.9 #	8 #	7 #	7 #
Minimum:	0.3	13.3	568.2	0.2	1.0	0	0	0
Maximum:	15.9	15.9	1,978.5	0.3	5.5	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	92.3	18.2	259.0	0.0	40.9	1	0	0
11/06/2022 10:00	18.7	17.4	380.5	0.0	26.8	1	0	0
11/06/2022 11:00	34.4	15.7	828.7	0.0	72.4	1	0	0
11/06/2022 12:00	0.2	14.0	1,401.7	0.0	0.5	1	1	0
11/06/2022 13:00	0.2	14.0	1,533.1	0.0	0.6	1	1	0
11/06/2022 14:00	0.2	13.9	1,606.7	0.2	0.6	1	1	0
11/06/2022 15:00	0.4	12.9	1,957.5	0.2	1.3	1	1	1
11/06/2022 16:00	0.3	11.8	2,286.9	0.2	1.0	1	1	1
11/06/2022 17:00	0.2	11.7	2,303.5	0.2	0.7	1	1	1
11/06/2022 18:00	0.4	12.9	2,010.4	0.2	1.3	1	1	1
11/06/2022 19:00	0.5	13.2	1,964.3	0.3	1.7	1	1	1
11/06/2022 20:00	0.5	13.1	1,989.1	0.4	1.7	1	1	1
11/06/2022 21:00	4.4	13.3	1,677.6	0.0	12.4	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	11.7	14.0	1,553.8	0.2	161.9 #	13 #	9 #	7 #
Minimum:	0.2	11.7	259.0	0.2	0.5	0	0	0
Maximum:	92.3	18.2	2,303.5	0.4	72.4	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	14.2	18.1	314.8	0.0	9.5	1	0	0
11/07/2022 01:00	32.2	15.3	1,013.6	0.0	77.0	1	0	0
11/07/2022 02:00	0.2	14.0	1,566.8	0.0	0.6	1	1	0
11/07/2022 03:00	0.2	14.0	1,619.9	0.0	0.6	1	1	0
11/07/2022 04:00	0.2	14.0	1,676.5	0.2	0.6	1	1	0
11/07/2022 05:00	0.2	13.9	1,708.4	0.2	0.6	1	1	0
11/07/2022 06:00	0.4	12.9	2,008.4	0.2	1.3	1	1	1
11/07/2022 07:00	0.3	12.2	2,239.0	0.2	1.0	1	1	1
11/07/2022 08:00	0.4	13.2	1,992.4	0.3	1.4	1	1	1
11/07/2022 09:00	0.4	13.2	1,975.3	0.3	1.4	1	1	1
11/07/2022 10:00	0.4	13.2	1,964.7	0.3	1.3	1	1	1
11/07/2022 11:00	0.4	13.2	1,962.6	0.3	1.3	1	1	1
11/07/2022 12:00	0.4	13.2	1,963.8	0.3	1.3	1	1	1
11/07/2022 13:00	0.4	13.2	1,962.7	0.3	1.3	1	1	1
11/07/2022 14:00	0.4	12.8	2,060.4	0.3	1.3	1	1	1
11/07/2022 15:00	0.3	12.3	2,192.5	0.3	1.0	1	1	1
11/07/2022 16:00	0.2	12.0	2,250.1	0.2	0.7	1	1	1
11/07/2022 17:00	0.1	11.9	2,290.9	0.1	0.3	1	1	1
11/07/2022 18:00	0.1	11.9	2,297.0	0.1	0.3	1	1	1
11/07/2022 19:00	0.1	11.9	2,293.7	0.1	0.3	1	1	1
11/07/2022 20:00	0.1	11.9	2,289.5	0.1	0.3	1	1	1
11/07/2022 21:00	0.1	11.9	2,293.4	0.1	0.3	1	1	1
11/07/2022 22:00	0.2	12.1	2,257.7	0.1	0.7	1	1	1
11/07/2022 23:00	0.3	12.4	2,181.0	0.1	1.0	1	1	1
Average/Sum#:	2.2	13.1	1,932.3	0.2	105.4 #	24 #	22 #	18 #
Minimum:	0.1	11.9	314.8	0.1	0.3	1	0	0
Maximum:	32.2	18.1	2,297.0	0.3	77.0	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.3	12.4	2,172.6	0.2	1.0	1	1	1
11/08/2022 01:00	0.3	12.5	2,167.5	0.2	1.0	1	1	1
11/08/2022 02:00	0.3	12.6	2,112.2	0.2	1.0	1	1	1
11/08/2022 03:00	0.3	12.5	2,160.9	0.2	1.0	1	1	1
11/08/2022 04:00	0.2	12.3	2,200.1	0.2	0.7	1	1	1
11/08/2022 05:00	0.2	12.2	2,219.7	0.1	0.7	1	1	1
11/08/2022 06:00	0.1	11.8	2,300.5	0.1	0.3	1	1	1
11/08/2022 07:00	0.2	12.2	2,213.6	0.1	0.7	1	1	1
11/08/2022 08:00	0.2	12.2	2,202.3	0.1	0.7	1	1	1
11/08/2022 09:00	0.2	12.2	2,200.4	0.1	0.7	1	1	1
11/08/2022 10:00	0.2	12.3	2,185.6	0.1	0.7	1	1	1
11/08/2022 11:00	0.3	13.0	2,032.7	0.1	1.0	1	1	1
11/08/2022 12:00	0.4	13.2	1,987.2	0.2	1.4	1	1	1
11/08/2022 13:00	0.4	13.2	1,985.1	0.3	1.4	1	1	1
11/08/2022 14:00	0.4	12.9	2,056.2	0.3	1.4	1	1	1
11/08/2022 15:00	0.4	12.9	2,056.3	0.3	1.4	1	1	1
11/08/2022 16:00	0.3	12.3	2,217.1	0.3	1.0	1	1	1
11/08/2022 17:00	0.2	12.3	2,201.6	0.2	0.7	1	1	1
11/08/2022 18:00	0.3	12.4	2,173.9	0.2	1.0	1	1	1
11/08/2022 19:00	0.2	12.3	2,206.4	0.1	0.7	1	1	1
11/08/2022 20:00	0.2	12.3	2,206.2	0.1	0.7	1	1	1
11/08/2022 21:00	0.2	12.3	2,204.5	0.1	0.7	1	1	1
11/08/2022 22:00	0.2	12.3	2,190.4	0.1	0.7	1	1	1
11/08/2022 23:00	0.3	12.5	2,146.3	0.1	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,158.3	0.2	21.6 #	24 #	24 #	24 #
Minimum:	0.1	11.8	1,985.1	0.1	0.3	1	1	1
Maximum:	0.4	13.2	2,300.5	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	0.3	12.5	2,155.3	0.2	1.0	1	1	1
11/09/2022 01:00	0.3	12.5	2,154.5	0.2	1.0	1	1	1
11/09/2022 02:00	0.2	12.4	2,194.0	0.2	0.7	1	1	1
11/09/2022 03:00	0.2	12.4	2,195.1	0.1	0.7	1	1	1
11/09/2022 04:00	0.3	12.5	2,162.1	0.1	1.0	1	1	1
11/09/2022 05:00	0.2	12.2	2,258.0	0.1	0.7	1	1	1
11/09/2022 06:00	0.2	12.0	2,298.8	0.1	0.7	1	1	1
11/09/2022 07:00	0.2	12.4	2,203.8	0.1	0.7	1	1	1
11/09/2022 08:00	0.2	12.5	2,162.6	0.1	0.7	1	1	1
11/09/2022 09:00	0.2	13.8	1,742.9	0.1	0.6	1	1	1
11/09/2022 10:00	0.1	13.9	1,701.0	0.1	0.3	1	1	0
11/09/2022 11:00	0.1	13.9	1,628.8	0.1	0.3	1	1	0
11/09/2022 12:00	0.1	13.9	1,704.5	0.1	0.3	1	1	0
11/09/2022 13:00	0.1	14.0	1,617.1	0.1	0.3	1	1	0
11/09/2022 14:00	0.1	13.9	1,688.5	0.1	0.3	1	1	0
11/09/2022 15:00	0.1	13.9	1,636.8	0.1	0.3	1	1	1
11/09/2022 16:00	0.4	12.8	2,083.4	0.2	1.4	1	1	1
11/09/2022 17:00	0.3	12.5	2,158.5	0.2	1.0	1	1	1
11/09/2022 18:00	0.3	13.1	2,013.7	0.2	1.0	1	1	1
11/09/2022 19:00	0.3	13.3	1,976.3	0.2	1.0	1	1	1
11/09/2022 20:00	0.3	13.3	1,979.9	0.2	1.0	1	1	1
11/09/2022 21:00	0.3	13.3	2,004.2	0.2	1.0	1	1	1
11/09/2022 22:00	0.3	13.3	1,996.1	0.2	1.0	1	1	1
11/09/2022 23:00	0.3	13.3	1,995.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.1	1,988.0	0.1	18.0 #	24 #	24 #	19 #
Minimum:	0.1	12.0	1,617.1	0.1	0.3	1	1	0
Maximum:	0.4	14.0	2,298.8	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	0.3	13.3	1,995.0	0.2	1.0	1	1	1
11/10/2022 01:00	0.3	13.3	1,993.3	0.2	1.0	1	1	1
11/10/2022 02:00	0.3	13.3	1,991.3	0.2	1.0	1	1	1
11/10/2022 03:00	0.3	13.3	1,994.2	0.2	1.0	1	1	1
11/10/2022 04:00	0.3	13.0	2,084.2	0.2	1.0	1	1	1
11/10/2022 05:00	0.3	12.6	2,176.6	0.2	1.0	1	1	1
11/10/2022 06:00	0.2	12.0	2,294.6	0.2	0.7	1	1	1
11/10/2022 07:00	0.3	12.8	2,120.5	0.2	1.0	1	1	1
11/10/2022 08:00	0.3	13.3	1,983.8	0.2	1.0	1	1	1
11/10/2022 09:00	0.3	13.3	1,965.9	0.2	1.0	1	1	1
11/10/2022 10:00	0.1	14.0	1,725.4	0.2	0.3	1	1	0
11/10/2022 11:00	0.1	14.0	1,712.5	0.1	0.3	1	1	0
11/10/2022 12:00	0.1	14.0	1,711.2	0.1	0.3	1	1	0
11/10/2022 13:00	0.1	14.0	1,562.8	0.1	0.3	1	1	0
11/10/2022 14:00	0.1	14.0	1,712.6	0.1	0.3	1	1	0
11/10/2022 15:00	0.2	13.9	1,716.1	0.1	0.6	1	1	1
11/10/2022 16:00	0.3	12.7	2,137.8	0.2	1.0	1	1	1
11/10/2022 17:00	0.1	12.2	2,271.9	0.2	0.3	1	1	1
11/10/2022 18:00	0.1	12.2	2,274.5	0.1	0.3	1	1	1
11/10/2022 19:00	0.1	12.2	2,277.9	0.1	0.3	1	1	1
11/10/2022 20:00	0.1	12.2	2,279.9	0.1	0.3	1	1	1
11/10/2022 21:00	0.1	12.2	2,281.1	0.1	0.3	1	1	1
11/10/2022 22:00	0.1	12.2	2,281.8	0.1	0.3	1	1	1
11/10/2022 23:00	0.1	12.3	2,260.5	0.1	0.3	1	1	1
Average/Sum#:	0.2	13.0	2,033.6	0.2	14.9 #	24 #	24 #	19 #
Minimum:	0.1	12.0	1,562.8	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,294.6	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.1	12.2	2,281.0	0.1	0.3	1	1	1
11/11/2022 01:00	0.1	12.2	2,270.4	0.1	0.3	1	1	1
11/11/2022 02:00	0.2	12.7	2,154.0	0.1	0.7	1	1	1
11/11/2022 03:00	0.2	12.7	2,151.7	0.1	0.7	1	1	1
11/11/2022 04:00	0.1	12.3	2,272.4	0.1	0.3	1	1	1
11/11/2022 05:00	0.1	12.2	2,285.8	0.1	0.3	1	1	1
11/11/2022 06:00	0.1	12.3	2,289.0	0.1	0.4	1	1	1
11/11/2022 07:00	0.2	12.9	2,119.2	0.1	0.7	1	1	1
11/11/2022 08:00	0.3	13.4	1,954.8	0.1	1.0	1	1	1
11/11/2022 09:00	0.1	14.0	1,708.7	0.1	0.3	1	1	0
11/11/2022 10:00	0.1	14.0	1,712.4	0.1	0.3	1	1	0
11/11/2022 11:00	0.1	14.0	1,684.1	0.1	0.3	1	1	0
11/11/2022 12:00	0.1	14.0	1,684.6	0.1	0.3	1	1	0
11/11/2022 13:00	0.2	14.0	1,694.9	0.1	0.6	1	1	0
11/11/2022 14:00	0.2	14.0	1,573.1	0.2	0.6	1	1	0
11/11/2022 15:00	0.2	14.0	1,687.2	0.2	0.6	1	1	0
11/11/2022 16:00	0.3	13.1	1,984.8	0.2	1.0	1	1	1
11/11/2022 17:00	0.1	12.1	2,268.3	0.2	0.3	1	1	1
11/11/2022 18:00	0.1	12.1	2,263.3	0.1	0.3	1	1	1
11/11/2022 19:00	0.1	12.2	2,260.6	0.1	0.3	1	1	1
11/11/2022 20:00	0.1	12.2	2,253.7	0.1	0.3	1	1	1
11/11/2022 21:00	0.1	12.2	2,252.9	0.1	0.3	1	1	1
11/11/2022 22:00	0.1	12.3	2,246.0	0.1	0.3	1	1	1
11/11/2022 23:00	0.1	12.2	2,259.7	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.9	2,054.7	0.1	10.8 #	24 #	24 #	17 #
Minimum:	0.1	12.1	1,573.1	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,289.0	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.1	12.3	2,267.0	0.1	0.3	1	1	1
11/12/2022 01:00	0.1	12.3	2,275.6	0.1	0.3	1	1	1
11/12/2022 02:00	0.1	12.2	2,278.8	0.1	0.3	1	1	1
11/12/2022 03:00	0.1	12.2	2,280.4	0.1	0.3	1	1	1
11/12/2022 04:00	0.1	12.2	2,285.0	0.1	0.3	1	1	1
11/12/2022 05:00	0.1	12.2	2,285.3	0.1	0.3	1	1	1
11/12/2022 06:00	0.1	12.2	2,276.7	0.1	0.3	1	1	1
11/12/2022 07:00	0.3	12.8	2,103.5	0.1	1.0	1	1	1
11/12/2022 08:00	0.2	12.3	2,210.7	0.1	0.7	1	1	1
11/12/2022 09:00	0.1	13.8	1,747.7	0.1	0.3	1	1	1
11/12/2022 10:00	0.1	14.0	1,589.6	0.1	0.3	1	1	0
11/12/2022 11:00	0.1	14.0	1,554.3	0.1	0.3	1	1	0
11/12/2022 12:00	0.1	14.0	1,551.1	0.1	0.3	1	1	0
11/12/2022 13:00	0.1	14.0	1,570.2	0.1	0.3	1	1	0
11/12/2022 14:00	0.1	14.0	1,549.0	0.1	0.3	1	1	0
11/12/2022 15:00	0.2	13.9	1,791.5	0.1	0.7	1	1	1
11/12/2022 16:00	0.3	12.7	2,126.7	0.2	1.0	1	1	1
11/12/2022 17:00	0.1	12.2	2,245.9	0.2	0.3	1	1	1
11/12/2022 18:00	0.1	12.2	2,246.8	0.1	0.3	1	1	1
11/12/2022 19:00	0.1	12.2	2,251.2	0.1	0.3	1	1	1
11/12/2022 20:00	0.1	12.2	2,260.4	0.1	0.3	1	1	1
11/12/2022 21:00	0.1	12.2	2,259.8	0.1	0.3	1	1	1
11/12/2022 22:00	0.1	12.5	2,193.5	0.1	0.3	1	1	1
11/12/2022 23:00	0.1	12.5	2,190.6	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.8	2,058.0	0.1	9.4 #	24 #	24 #	19 #
Minimum:	0.1	12.2	1,549.0	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,285.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.2	12.6	2,180.8	0.1	0.7	1	1	1
11/13/2022 01:00	0.2	12.6	2,170.0	0.1	0.7	1	1	1
11/13/2022 02:00	0.2	12.7	2,165.0	0.1	0.7	1	1	1
11/13/2022 03:00	0.1	12.5	2,194.5	0.1	0.3	1	1	1
11/13/2022 04:00	0.1	12.6	2,189.7	0.1	0.3	1	1	1
11/13/2022 05:00	0.2	12.6	2,184.1	0.1	0.7	1	1	1
11/13/2022 06:00	0.1	12.5	2,195.0	0.1	0.3	1	1	1
11/13/2022 07:00	0.1	12.4	2,240.2	0.1	0.3	1	1	1
11/13/2022 08:00	0.1	13.1	1,966.4	0.1	0.3	1	1	1
11/13/2022 09:00	0.1	14.0	1,706.5	0.1	0.3	1	1	0
11/13/2022 10:00	0.1	14.0	1,707.9	0.1	0.3	1	1	0
11/13/2022 11:00	0.1	14.0	1,707.9	0.1	0.3	1	1	0
11/13/2022 12:00	0.1	14.0	1,706.8	0.1	0.3	1	1	0
11/13/2022 13:00	0.2	14.0	1,709.5	0.1	0.7	1	1	0
11/13/2022 14:00	0.2	14.0	1,677.7	0.2	0.6	1	1	0
11/13/2022 15:00	0.2	13.9	1,782.8	0.2	0.7	1	1	1
11/13/2022 16:00	0.3	12.5	2,138.8	0.2	1.0	1	1	1
11/13/2022 17:00	0.1	11.9	2,280.1	0.2	0.3	1	1	1
11/13/2022 18:00	0.1	11.9	2,280.5	0.1	0.3	1	1	1
11/13/2022 19:00	0.1	11.9	2,284.4	0.1	0.3	1	1	1
11/13/2022 20:00	0.1	11.9	2,288.2	0.1	0.3	1	1	1
11/13/2022 21:00	0.1	11.9	2,292.8	0.1	0.3	1	1	1
11/13/2022 22:00	0.1	11.9	2,295.1	0.1	0.3	1	1	1
11/13/2022 23:00	0.1	11.9	2,299.3	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.8	2,068.5	0.1	10.6 #	24 #	24 #	18 #
Minimum:	0.1	11.9	1,677.7	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,299.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.1	11.9	2,298.5	0.1	0.3	1	1	1
11/14/2022 01:00	0.1	12.0	2,289.5	0.1	0.3	1	1	1
11/14/2022 02:00	0.2	12.1	2,286.2	0.1	0.7	1	1	1
11/14/2022 03:00	0.3	12.6	2,166.7	0.1	1.0	1	1	1
11/14/2022 04:00	0.2	12.3	2,241.5	0.1	0.7	1	1	1
11/14/2022 05:00	0.2	12.0	2,303.2	0.1	0.7	1	1	1
11/14/2022 06:00	0.2	12.1	2,299.4	0.1	0.7	1	1	1
11/14/2022 07:00	0.3	12.5	2,194.7	0.1	1.0	1	1	1
11/14/2022 08:00	0.3	12.7	2,159.1	0.2	1.0	1	1	1
11/14/2022 09:00	0.3	12.6	2,167.7	0.2	1.0	1	1	1
11/14/2022 10:00	0.3	12.6	2,158.5	0.2	1.0	1	1	1
11/14/2022 11:00	0.3	12.6	2,130.2	0.2	1.0	1	1	1
11/14/2022 12:00	0.3	12.6	2,126.0	0.2	1.0	1	1	1
11/14/2022 13:00	0.2	12.5	2,154.3	0.2	0.7	1	1	1
11/14/2022 14:00	0.2	12.4	2,150.3	0.1	0.7	1	1	1
11/14/2022 15:00	0.3	12.8	2,079.7	0.1	1.0	1	1	1
11/14/2022 16:00	0.2	12.0	2,254.0	0.1	0.7	1	1	1
11/14/2022 17:00	0.2	12.3	2,198.1	0.1	0.7	1	1	1
11/14/2022 18:00	0.2	12.4	2,182.1	0.1	0.7	1	1	1
11/14/2022 19:00	0.2	12.1	2,240.9	0.1	0.7	1	1	1
11/14/2022 20:00	0.2	12.1	2,243.9	0.1	0.7	1	1	1
11/14/2022 21:00	0.1	12.0	2,288.0	0.1	0.3	1	1	1
11/14/2022 22:00	0.1	12.0	2,288.7	0.1	0.3	1	1	1
11/14/2022 23:00	0.1	12.1	2,271.0	0.1	0.3	1	1	1
Average/Sum#:	0.2	12.3	2,215.5	0.1	17.2 #	24 #	24 #	24 #
Minimum:	0.1	11.9	2,079.7	0.1	0.3	1	1	1
Maximum:	0.3	12.8	2,303.2	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	0.1	12.0	2,301.3	0.1	0.3	1	1	1
11/15/2022 01:00	0.1	11.9	2,300.4	0.1	0.3	1	1	1
11/15/2022 02:00	0.1	12.0	2,290.8	0.1	0.3	1	1	1
11/15/2022 03:00	0.1	12.0	2,281.4	0.1	0.3	1	1	1
11/15/2022 04:00	0.1	12.1	2,264.5	0.1	0.3	1	1	1
11/15/2022 05:00	0.2	12.2	2,243.0	0.1	0.7	1	1	1
11/15/2022 06:00	0.2	12.3	2,213.0	0.1	0.7	1	1	1
11/15/2022 07:00	0.2	12.4	2,183.3	0.1	0.7	1	1	1
11/15/2022 08:00	0.2	12.6	2,133.4	0.1	0.7	1	1	1
11/15/2022 09:00	0.2	12.7	2,108.5	0.1	0.7	1	1	1
11/15/2022 10:00	0.3	12.6	2,141.8	0.1	1.0	1	1	1
11/15/2022 11:00	0.3	12.9	2,056.8	0.2	1.0	1	1	1
11/15/2022 12:00	0.4	13.3	1,977.9	0.2	1.4	1	1	1
11/15/2022 13:00	0.4	13.3	1,979.2	0.3	1.4	1	1	1
11/15/2022 14:00	0.4	13.3	1,979.2	0.3	1.4	1	1	1
11/15/2022 15:00	0.4	13.1	2,018.4	0.3	1.4	1	1	1
11/15/2022 16:00	0.3	12.6	2,149.3	0.3	1.0	1	1	1
11/15/2022 17:00	0.3	12.5	2,177.7	0.2	1.0	1	1	1
11/15/2022 18:00	0.3	12.4	2,193.7	0.2	1.0	1	1	1
11/15/2022 19:00	0.2	12.4	2,188.4	0.2	0.7	1	1	1
11/15/2022 20:00	0.2	12.3	2,196.2	0.1	0.7	1	1	1
11/15/2022 21:00	0.1	12.1	2,244.0	0.1	0.3	1	1	1
11/15/2022 22:00	0.2	12.4	2,174.7	0.1	0.7	1	1	1
11/15/2022 23:00	0.2	12.5	2,174.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,165.5	0.2	18.7 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,977.9	0.1	0.3	1	1	1
Maximum:	0.4	13.3	2,301.3	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	0.2	12.5	2,168.0	0.1	0.7	1	1	1
11/16/2022 01:00	0.2	12.6	2,140.8	0.1	0.7	1	1	1
11/16/2022 02:00	0.2	12.5	2,165.7	0.1	0.7	1	1	1
11/16/2022 03:00	0.2	12.5	2,167.5	0.1	0.7	1	1	1
11/16/2022 04:00	0.2	12.4	2,178.7	0.1	0.7	1	1	1
11/16/2022 05:00	0.2	12.5	2,174.9	0.1	0.7	1	1	1
11/16/2022 06:00	0.2	12.5	2,168.0	0.1	0.7	1	1	1
11/16/2022 07:00	0.1	12.2	2,241.0	0.1	0.3	1	1	1
11/16/2022 08:00	0.3	13.2	1,987.0	0.1	1.0	1	1	1
11/16/2022 09:00	0.3	13.2	2,018.8	0.2	1.0	1	1	1
11/16/2022 10:00	0.4	13.3	1,985.3	0.2	1.4	1	1	1
11/16/2022 11:00	0.0	0.0	1,986.8	0.0	0.0	1	1	1
11/16/2022 12:00	0.0	13.2	1,985.9	0.0	0.0	1	1	1
11/16/2022 13:00	0.0	13.2	1,986.9	0.0	0.0	1	1	1
11/16/2022 14:00	0.0	13.2	1,985.4	0.0	0.0	1	1	1
11/16/2022 15:00	0.0	12.6	2,113.3	0.0	0.0	1	1	1
11/16/2022 16:00	0.0	12.3	2,177.2	0.0	0.0	1	1	1
11/16/2022 17:00	0.0	12.3	2,192.8	0.0	0.0	1	1	1
11/16/2022 18:00	0.0	11.9	2,278.4	0.0	0.0	1	1	1
11/16/2022 19:00	0.0	11.9	2,286.5	0.0	0.0	1	1	1
11/16/2022 20:00	0.0	11.9	2,286.7	0.0	0.0	1	1	1
11/16/2022 21:00	0.0	12.0	2,266.9	0.0	0.0	1	1	1
11/16/2022 22:00	0.0	12.2	2,230.9	0.0	0.0	1	1	1
11/16/2022 23:00	0.0	12.0	2,257.4	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.5	2,143.0	0.1	8.6 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,985.3	0.0	0.0	1	1	1
Maximum:	0.4	13.3	2,286.7	0.2	1.4	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.0	12.4	2,177.8	0.0	0.0	1	1	1
11/17/2022 01:00	0.0	12.3	2,181.0	0.0	0.0	1	1	1
11/17/2022 02:00	0.0	12.4	2,165.8	0.0	0.0	1	1	1
11/17/2022 03:00	0.0	12.5	2,166.0	0.0	0.0	1	1	1
11/17/2022 04:00	0.0	12.5	2,169.1	0.0	0.0	1	1	1
11/17/2022 05:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
11/17/2022 06:00	0.0	11.9	2,291.5	0.0	0.0	1	1	1
11/17/2022 07:00	0.0	12.4	2,182.1	0.0	0.0	1	1	1
11/17/2022 08:00	0.0	13.1	1,994.1	0.0	0.0	1	1	1
11/17/2022 09:00	0.0	12.5	2,150.8	0.0	0.0	1	1	1
11/17/2022 10:00	0.0	12.5	2,143.2	0.0	0.0	1	1	1
11/17/2022 11:00	0.0	12.3	2,174.6	0.0	0.0	1	1	1
11/17/2022 12:00	0.0	12.1	2,198.3	0.0	0.0	1	1	1
11/17/2022 13:00	0.0	12.2	2,183.9	0.0	0.0	1	1	1
11/17/2022 14:00	0.0	12.9	2,015.7	0.0	0.0	1	1	1
11/17/2022 15:00	0.0	12.4	2,130.6	0.0	0.0	1	1	1
11/17/2022 16:00	0.0	11.9	2,243.2	0.0	0.0	1	1	1
11/17/2022 17:00	0.0	11.8	2,276.9	0.0	0.0	1	1	1
11/17/2022 18:00	0.0	11.8	2,275.4	0.0	0.0	1	1	1
11/17/2022 19:00	0.0	11.8	2,278.6	0.0	0.0	1	1	1
11/17/2022 20:00	0.0	11.8	2,280.8	0.0	0.0	1	1	1
11/17/2022 21:00	0.0	11.8	2,282.5	0.0	0.0	1	1	1
11/17/2022 22:00	0.0	11.9	2,269.7	0.0	0.0	1	1	1
11/17/2022 23:00	0.0	12.2	2,226.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,193.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,994.1	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,291.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.0	12.4	2,177.7	0.0	0.0	1	1	1
11/18/2022 01:00	0.0	12.3	2,188.2	0.0	0.0	1	1	1
11/18/2022 02:00	0.0	12.2	2,194.3	0.0	0.0	1	1	1
11/18/2022 03:00	0.0	12.3	2,188.5	0.0	0.0	1	1	1
11/18/2022 04:00	0.0	12.2	2,185.6	0.0	0.0	1	1	1
11/18/2022 05:00	0.0	12.3	2,173.7	0.0	0.0	1	1	1
11/18/2022 06:00	0.0	12.4	2,160.2	0.0	0.0	1	1	1
11/18/2022 07:00	0.0	12.0	2,255.3	0.0	0.0	1	1	1
11/18/2022 08:00	0.0	12.3	2,177.7	0.0	0.0	1	1	1
11/18/2022 09:00	0.0	12.3	2,185.0	0.0	0.0	1	1	1
11/18/2022 10:00	0.0	12.2	2,190.4	0.0	0.0	1	1	1
11/18/2022 11:00	0.0	12.5	2,120.3	0.0	0.0	1	1	1
11/18/2022 12:00	0.0	13.1	1,970.2	0.0	0.0	1	1	1
11/18/2022 13:00	0.0	13.1	1,973.1	0.0	0.0	1	1	1
11/18/2022 14:00	0.0	13.1	1,974.5	0.0	0.0	1	1	1
11/18/2022 15:00	0.0	12.8	2,058.5	0.0	0.0	1	1	1
11/18/2022 16:00	0.0	12.0	2,235.0	0.0	0.0	1	1	1
11/18/2022 17:00	0.0	11.9	2,257.9	0.0	0.0	1	1	1
11/18/2022 18:00	0.0	12.0	2,260.4	0.0	0.0	1	1	1
11/18/2022 19:00	0.0	12.0	2,263.4	0.0	0.0	1	1	1
11/18/2022 20:00	0.0	12.1	2,228.1	0.0	0.0	1	1	1
11/18/2022 21:00	0.0	12.3	2,181.4	0.0	0.0	1	1	1
11/18/2022 22:00	0.0	12.5	2,145.0	0.0	0.0	1	1	1
11/18/2022 23:00	0.0	12.1	2,239.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,166.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.2	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,263.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.0	12.3	2,194.0	0.0	0.0	1	1	1
11/19/2022 01:00	0.0	12.4	2,172.4	0.0	0.0	1	1	1
11/19/2022 02:00	0.0	12.5	2,168.7	0.0	0.0	1	1	1
11/19/2022 03:00	0.0	12.6	2,144.8	0.0	0.0	1	1	1
11/19/2022 04:00	0.0	12.2	2,238.2	0.0	0.0	1	1	1
11/19/2022 05:00	0.0	12.1	2,271.6	0.0	0.0	1	1	1
11/19/2022 06:00	0.0	12.3	2,218.2	0.0	0.0	1	1	1
11/19/2022 07:00	0.0	12.6	2,132.0	0.0	0.0	1	1	1
11/19/2022 08:00	0.0	13.2	1,978.8	0.0	0.0	1	1	1
11/19/2022 09:00	0.0	13.2	1,978.8	0.0	0.0	1	1	1
11/19/2022 10:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
11/19/2022 11:00	0.0	13.2	1,970.6	0.0	0.0	1	1	1
11/19/2022 12:00	0.0	13.1	1,971.0	0.0	0.0	1	1	1
11/19/2022 13:00	0.0	13.1	1,971.9	0.0	0.0	1	1	1
11/19/2022 14:00	0.0	13.1	1,970.2	0.0	0.0	1	1	1
11/19/2022 15:00	0.0	12.8	2,050.9	0.0	0.0	1	1	1
11/19/2022 16:00	0.0	12.2	2,184.1	0.0	0.0	1	1	1
11/19/2022 17:00	0.0	12.1	2,201.8	0.0	0.0	1	1	1
11/19/2022 18:00	0.0	12.2	2,197.4	0.0	0.0	1	1	1
11/19/2022 19:00	0.0	11.9	2,260.7	0.0	0.0	1	1	1
11/19/2022 20:00	0.0	12.1	2,219.4	0.0	0.0	1	1	1
11/19/2022 21:00	0.0	12.3	2,177.5	0.0	0.0	1	1	1
11/19/2022 22:00	0.0	12.5	2,175.6	0.0	0.0	1	1	1
11/19/2022 23:00	0.0	12.6	2,143.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,123.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.2	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,271.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.0	12.7	2,106.9	0.0	0.0	1	1	1
11/20/2022 01:00	0.0	12.8	2,078.9	0.0	0.0	1	1	1
11/20/2022 02:00	0.0	12.9	2,062.3	0.0	0.0	1	1	1
11/20/2022 03:00	0.0	12.9	2,063.5	0.0	0.0	1	1	1
11/20/2022 04:00	0.0	12.9	2,070.5	0.0	0.0	1	1	1
11/20/2022 05:00	0.0	12.5	2,183.5	0.0	0.0	1	1	1
11/20/2022 06:00	0.0	12.1	2,276.9	0.0	0.0	1	1	1
11/20/2022 07:00	0.0	12.6	2,113.0	0.0	0.0	1	1	1
11/20/2022 08:00	0.0	13.9	1,703.8	0.0	0.0	1	1	0
11/20/2022 09:00	0.0	13.9	1,708.6	0.0	0.0	1	1	0
11/20/2022 10:00	0.0	13.9	1,565.5	0.0	0.0	1	1	0
11/20/2022 11:00	0.0	13.9	1,563.6	0.0	0.0	1	1	0
11/20/2022 12:00	0.0	14.0	1,533.4	0.0	0.0	1	1	0
11/20/2022 13:00	0.0	14.0	1,523.9	0.0	0.0	1	1	0
11/20/2022 14:00	0.0	13.8	1,701.2	0.0	0.0	1	1	1
11/20/2022 15:00	0.0	13.8	1,723.3	0.0	0.0	1	1	1
11/20/2022 16:00	0.0	12.4	2,162.3	0.0	0.0	1	1	1
11/20/2022 17:00	0.0	11.9	2,276.4	0.0	0.0	1	1	1
11/20/2022 18:00	0.0	11.9	2,265.8	0.0	0.0	1	1	1
11/20/2022 19:00	0.0	11.9	2,256.8	0.0	0.0	1	1	1
11/20/2022 20:00	0.0	11.9	2,261.0	0.0	0.0	1	1	1
11/20/2022 21:00	0.0	12.2	2,204.5	0.0	0.0	1	1	1
11/20/2022 22:00	0.0	12.4	2,168.3	0.0	0.0	1	1	1
11/20/2022 23:00	0.0	12.5	2,153.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,988.6	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,523.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,276.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	0.0	12.5	2,160.3	0.0	0.0	1	1	1
11/21/2022 01:00	0.0	12.6	2,137.5	0.0	0.0	1	1	1
11/21/2022 02:00	0.0	12.9	2,062.0	0.0	0.0	1	1	1
11/21/2022 03:00	0.0	12.4	2,174.4	0.0	0.0	1	1	1
11/21/2022 04:00	0.0	12.1	2,256.2	0.0	0.0	1	1	1
11/21/2022 05:00	0.0	12.1	2,267.1	0.0	0.0	1	1	1
11/21/2022 06:00	0.0	12.0	2,284.1	0.0	0.0	1	1	1
11/21/2022 07:00	0.0	12.5	2,150.4	0.0	0.0	1	1	1
11/21/2022 08:00	0.0	13.3	1,968.4	0.0	0.0	1	1	1
11/21/2022 09:00	0.0	13.3	1,968.7	0.0	0.0	1	1	1
11/21/2022 10:00	0.0	13.2	1,969.1	0.0	0.0	1	1	1
11/21/2022 11:00	0.0	13.2	1,979.0	0.0	0.0	1	1	1
11/21/2022 12:00	0.0	13.1	1,980.5	0.0	0.0	1	1	1
11/21/2022 13:00	0.0	13.1	1,980.3	0.0	0.0	1	1	1
11/21/2022 14:00	0.0	12.3	2,160.9	0.0	0.0	1	1	1
11/21/2022 15:00	0.0	11.9	2,251.4	0.0	0.0	1	1	1
11/21/2022 16:00	0.0	12.1	2,226.7	0.0	0.0	1	1	1
11/21/2022 17:00	0.0	11.9	2,273.3	0.0	0.0	1	1	1
11/21/2022 18:00	0.0	12.0	2,283.4	0.0	0.0	1	1	1
11/21/2022 19:00	0.0	11.9	2,265.1	0.0	0.0	1	1	1
11/21/2022 20:00	0.0	11.9	2,265.4	0.0	0.0	1	1	1
11/21/2022 21:00	0.0	11.9	2,267.8	0.0	0.0	1	1	1
11/21/2022 22:00	0.0	11.9	2,264.5	0.0	0.0	1	1	1
11/21/2022 23:00	0.0	12.1	2,228.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,159.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,968.4	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,284.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	0.0	12.4	2,154.9	0.0	0.0	1	1	1
11/22/2022 01:00	0.0	12.6	2,130.2	0.0	0.0	1	1	1
11/22/2022 02:00	0.0	12.7	2,101.3	0.0	0.0	1	1	1
11/22/2022 03:00	0.0	13.1	1,980.1	0.0	0.0	1	1	1
11/22/2022 04:00	0.0	13.2	1,985.4	0.0	0.0	1	1	1
11/22/2022 05:00	0.0	12.8	2,071.1	0.0	0.0	1	1	1
11/22/2022 06:00	0.0	12.5	2,156.2	0.0	0.0	1	1	1
11/22/2022 07:00	0.0	12.8	2,097.2	0.0	0.0	1	1	1
11/22/2022 08:00	0.0	12.9	2,055.9	0.0	0.0	1	1	1
11/22/2022 09:00	0.0	13.8	1,648.0	0.0	0.0	1	1	1
11/22/2022 10:00	0.0	13.8	1,674.5	0.0	0.0	1	1	0
11/22/2022 11:00	0.0	13.9	1,795.0	0.0	0.0	1	1	0
11/22/2022 12:00	0.0	13.9	1,556.4	0.0	0.0	1	1	0
11/22/2022 13:00	0.0	13.9	1,617.1	0.0	0.0	1	1	0
11/22/2022 14:00	0.0	13.8	1,779.5	0.0	0.0	1	1	0
11/22/2022 15:00	0.0	13.8	1,781.6	0.0	0.0	1	1	0
11/22/2022 16:00	0.0	13.2	1,919.5	0.0	0.0	1	1	1
11/22/2022 17:00	0.0	12.3	2,191.5	0.0	0.0	1	1	1
11/22/2022 18:00	0.0	12.8	2,055.9	0.0	0.0	1	1	1
11/22/2022 19:00	0.0	13.1	1,999.0	0.0	0.0	1	1	1
11/22/2022 20:00	0.0	12.5	2,155.9	0.0	0.0	1	1	1
11/22/2022 21:00	0.0	12.9	2,034.0	0.0	0.0	1	1	1
11/22/2022 22:00	0.0	12.9	2,045.3	0.0	0.0	1	1	1
11/22/2022 23:00	0.0	13.2	1,973.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,956.6	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.3	1,556.4	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,191.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	0.0	13.2	1,974.3	0.0	0.0	1	1	1
11/23/2022 01:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
11/23/2022 02:00	0.0	13.2	1,973.8	0.0	0.0	1	1	1
11/23/2022 03:00	0.0	13.2	1,976.4	0.0	0.0	1	1	1
11/23/2022 04:00	0.0	13.2	1,982.4	0.0	0.0	1	1	1
11/23/2022 05:00	0.0	12.7	2,074.5	0.0	0.0	1	1	1
11/23/2022 06:00	0.0	12.7	2,056.8	0.0	0.0	1	1	1
11/23/2022 07:00	0.0	12.7	2,111.0	0.0	0.0	1	1	1
11/23/2022 08:00	0.0	13.0	2,004.8	0.0	0.0	1	1	1
11/23/2022 09:00	0.0	13.9	1,703.0	0.0	0.0	1	1	0
11/23/2022 10:00	0.0	13.9	1,554.3	0.0	0.0	1	1	0
11/23/2022 11:00	0.0	13.9	1,550.6	0.0	0.0	1	1	0
11/23/2022 12:00	0.0	14.0	1,422.8	0.0	0.0	1	1	0
11/23/2022 13:00	0.0	14.0	1,559.1	0.0	0.0	1	1	0
11/23/2022 14:00	0.0	14.0	1,630.2	0.0	0.0	1	1	0
11/23/2022 15:00	0.0	13.9	1,636.5	0.0	0.0	1	1	1
11/23/2022 16:00	0.1	12.6	2,110.6	0.0	0.3	1	1	1
11/23/2022 17:00	0.0	12.3	2,185.3	0.0	0.0	1	1	1
11/23/2022 18:00	0.0	12.7	2,100.4	0.0	0.0	1	1	1
11/23/2022 19:00	0.1	12.9	2,063.5	0.0	0.3	1	1	1
11/23/2022 20:00	0.0	12.3	2,182.9	0.0	0.0	1	1	1
11/23/2022 21:00	0.0	12.3	2,201.9	0.0	0.0	1	1	1
11/23/2022 22:00	0.0	12.4	2,176.3	0.0	0.0	1	1	1
11/23/2022 23:00	0.0	12.4	2,171.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,932.4	0.0	0.6 #	24 #	24 #	18 #
Minimum:	0.0	12.3	1,422.8	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,201.9	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	0.1	13.1	1,990.6	0.0	0.3	1	1	1
11/24/2022 01:00	0.2	13.2	1,976.9	0.1	0.7	1	1	1
11/24/2022 02:00	0.2	13.2	1,976.7	0.2	0.7	1	1	1
11/24/2022 03:00	0.0	13.1	2,019.5	0.1	0.0	1	1	1
11/24/2022 04:00	0.1	13.0	2,026.8	0.1	0.3	1	1	1
11/24/2022 05:00	0.0	12.8	2,102.0	0.0	0.0	1	1	1
11/24/2022 06:00	0.0	12.2	2,191.0	0.0	0.0	1	1	1
11/24/2022 07:00	0.0	12.5	2,097.3	0.0	0.0	1	1	1
11/24/2022 08:00	0.0	13.9	1,712.8	0.0	0.0	1	1	0
11/24/2022 09:00	0.0	13.9	1,696.5	0.0	0.0	1	1	0
11/24/2022 10:00	0.0	13.9	1,703.7	0.0	0.0	1	1	0
11/24/2022 11:00	0.0	14.0	1,549.0	0.0	0.0	1	1	0
11/24/2022 12:00	0.0	14.0	1,349.8	0.0	0.0	1	1	0
11/24/2022 13:00	0.0	14.0	1,345.2	0.0	0.0	1	1	0
11/24/2022 14:00	0.0	14.0	1,551.3	0.0	0.0	1	1	0
11/24/2022 15:00	0.0	14.0	1,440.8	0.0	0.0	1	1	0
11/24/2022 16:00	0.0	13.9	1,756.8	0.0	0.0	1	1	0
11/24/2022 17:00	0.0	13.9	1,755.3	0.0	0.0	1	1	0
11/24/2022 18:00	0.0	13.9	1,738.1	0.0	0.0	1	1	0
11/24/2022 19:00	0.0	13.9	1,735.7	0.0	0.0	1	1	0
11/24/2022 20:00	0.0	13.9	1,736.2	0.0	0.0	1	1	0
11/24/2022 21:00	0.0	13.9	1,739.4	0.0	0.0	1	1	0
11/24/2022 22:00	0.0	13.9	1,742.8	0.0	0.0	1	1	0
11/24/2022 23:00	0.0	13.9	1,744.5	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.6	1,778.3	0.0	2.0 #	24 #	24 #	8 #
Minimum:	0.0	12.2	1,345.2	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,191.0	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.0	13.9	1,746.5	0.0	0.0	1	1	0
11/25/2022 01:00	0.0	13.9	1,746.8	0.0	0.0	1	1	0
11/25/2022 02:00	0.0	13.9	1,749.6	0.0	0.0	1	1	0
11/25/2022 03:00	0.0	13.9	1,753.4	0.0	0.0	1	1	0
11/25/2022 04:00	0.0	13.9	1,763.9	0.0	0.0	1	1	0
11/25/2022 05:00	0.0	13.9	1,761.2	0.0	0.0	1	1	0
11/25/2022 06:00	0.0	13.9	1,755.3	0.0	0.0	1	1	0
11/25/2022 07:00	0.0	13.9	1,755.9	0.0	0.0	1	1	0
11/25/2022 08:00	0.0	13.5	1,878.1	0.0	0.0	1	1	1
11/25/2022 09:00	0.0	13.2	1,927.0	0.0	0.0	1	1	1
11/25/2022 10:00	0.0	13.9	1,661.2	0.0	0.0	1	1	0
11/25/2022 11:00	0.0	13.9	1,538.8	0.0	0.0	1	1	0
11/25/2022 12:00	0.0	13.9	1,565.4	0.0	0.0	1	1	0
11/25/2022 13:00	0.0	13.9	1,534.3	0.0	0.0	1	1	0
11/25/2022 14:00	0.0	13.9	1,521.7	0.0	0.0	1	1	0
11/25/2022 15:00	0.0	13.8	1,630.3	0.0	0.0	1	1	1
11/25/2022 16:00	0.1	12.6	2,098.5	0.0	0.3	1	1	1
11/25/2022 17:00	0.0	12.5	2,115.1	0.0	0.0	1	1	1
11/25/2022 18:00	0.0	13.1	1,976.4	0.0	0.0	1	1	1
11/25/2022 19:00	0.0	13.2	1,966.1	0.0	0.0	1	1	1
11/25/2022 20:00	0.0	13.2	1,974.0	0.0	0.0	1	1	1
11/25/2022 21:00	0.0	13.2	1,977.2	0.0	0.0	1	1	1
11/25/2022 22:00	0.0	12.6	2,131.7	0.0	0.0	1	1	1
11/25/2022 23:00	0.0	12.7	2,091.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,817.5	0.0	0.3 #	24 #	24 #	11 #
Minimum:	0.0	12.5	1,521.7	0.0	0.0	1	1	0
Maximum:	0.1	13.9	2,131.7	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	0.0	13.0	2,033.3	0.0	0.0	1	1	1
11/26/2022 01:00	0.0	12.8	2,080.1	0.0	0.0	1	1	1
11/26/2022 02:00	3.3	13.9	1,574.8	0.0	9.8	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.1	13.2	1,896.1	0.0	9.8 #	3 #	2 #	3 #
Minimum:	0.0	12.8	1,574.8	0.0	0.0	0	0	0
Maximum:	3.3	13.9	2,080.1	0.0	9.8	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	59.2	17.7	330.2	0.0	56.5	1	0	0
11/27/2022 22:00	14.4	17.3	396.9	0.0	21.0	1	0	0
11/27/2022 23:00	30.9	15.5	901.6	0.0	68.1	1	0	0
Average/Sum#:	34.8	16.8	542.9	0.0	145.6 #	3 #	0 #	0 #
Minimum:	14.4	15.5	330.2	0.0	21.0	0	0	0
Maximum:	59.2	17.7	901.6	0.0	68.1	1	0	0
%SI	87.50	87.50	87.50	100.00	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	0.0	13.9	1,574.9	0.0	0.0	1	1	0
11/28/2022 01:00	0.0	13.9	1,487.8	0.0	0.0	1	1	0
11/28/2022 02:00	0.0	13.8	1,745.5	0.0	0.0	1	1	0
11/28/2022 03:00	0.0	13.9	1,530.8	0.0	0.0	1	1	0
11/28/2022 04:00	0.0	13.9	1,710.5	0.0	0.0	1	1	0
11/28/2022 05:00	0.0	13.8	1,642.2	0.0	0.0	1	1	1
11/28/2022 06:00	0.0	12.3	2,173.2	0.0	0.0	1	1	1
11/28/2022 07:00	0.0	12.0	2,270.2	0.0	0.0	1	1	1
11/28/2022 08:00	0.0	13.1	1,972.1	0.0	0.0	1	1	1
11/28/2022 09:00	0.0	13.9	1,601.7	0.0	0.0	1	1	0
11/28/2022 10:00	0.0	13.9	1,699.0	0.0	0.0	1	1	0
11/28/2022 11:00	0.0	13.9	1,519.7	0.0	0.0	1	1	0
11/28/2022 12:00	0.0	13.9	1,566.4	0.0	0.0	1	1	0
11/28/2022 13:00	0.0	13.9	1,634.0	0.0	0.0	1	1	0
11/28/2022 14:00	0.0	13.9	1,616.9	0.0	0.0	1	1	0
11/28/2022 15:00	0.0	13.8	1,620.0	0.0	0.0	1	1	1
11/28/2022 16:00	0.0	12.8	2,041.1	0.0	0.0	1	1	1
11/28/2022 17:00	0.0	12.6	2,100.3	0.0	0.0	1	1	1
11/28/2022 18:00	0.0	13.1	1,988.5	0.0	0.0	1	1	1
11/28/2022 19:00	0.0	13.2	1,967.8	0.0	0.0	1	1	1
11/28/2022 20:00	0.0	12.7	2,094.0	0.0	0.0	1	1	1
11/28/2022 21:00	0.0	12.1	2,238.4	0.0	0.0	1	1	1
11/28/2022 22:00	0.0	12.7	2,095.4	0.0	0.0	1	1	1
11/28/2022 23:00	0.0	13.1	1,996.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,828.6	0.0	0.0 #	24 #	24 #	13 #
Minimum:	0.0	12.0	1,487.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,270.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.0	12.5	2,165.2	0.0	0.0	1	1	1
11/29/2022 01:00	0.0	12.3	2,212.8	0.0	0.0	1	1	1
11/29/2022 02:00	0.0	12.4	2,192.2	0.0	0.0	1	1	1
11/29/2022 03:00	0.0	12.8	2,088.0	0.0	0.0	1	1	1
11/29/2022 04:00	0.0	12.5	2,152.8	0.0	0.0	1	1	1
11/29/2022 05:00	0.0	12.4	2,205.6	0.0	0.0	1	1	1
11/29/2022 06:00	0.0	11.9	2,296.9	0.0	0.0	1	1	1
11/29/2022 07:00	0.0	11.9	2,304.2	0.0	0.0	1	1	1
11/29/2022 08:00	0.0	12.0	2,274.9	0.0	0.0	1	1	1
11/29/2022 09:00	0.0	12.4	2,174.5	0.0	0.0	1	1	1
11/29/2022 10:00	0.0	12.4	2,167.1	0.0	0.0	1	1	1
11/29/2022 11:00	0.0	12.4	2,157.9	0.0	0.0	1	1	1
11/29/2022 12:00	0.0	12.4	2,151.2	0.0	0.0	1	1	1
11/29/2022 13:00	0.0	12.4	2,151.4	0.0	0.0	1	1	1
11/29/2022 14:00	0.0	12.4	2,156.0	0.0	0.0	1	1	1
11/29/2022 15:00	0.0	12.3	2,170.6	0.0	0.0	1	1	1
11/29/2022 16:00	0.0	11.9	2,281.5	0.0	0.0	1	1	1
11/29/2022 17:00	0.0	11.9	2,289.6	0.0	0.0	1	1	1
11/29/2022 18:00	0.0	11.9	2,292.8	0.0	0.0	1	1	1
11/29/2022 19:00	0.0	11.9	2,290.5	0.0	0.0	1	1	1
11/29/2022 20:00	0.0	12.0	2,289.3	0.0	0.0	1	1	1
11/29/2022 21:00	0.0	11.9	2,292.2	0.0	0.0	1	1	1
11/29/2022 22:00	0.0	12.0	2,297.8	0.0	0.0	1	1	1
11/29/2022 23:00	0.0	12.0	2,296.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,223.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	2,088.0	0.0	0.0	1	1	1
Maximum:	0.0	12.8	2,304.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	0.0	12.6	2,170.7	0.0	0.0	1	1	1
11/30/2022 01:00	0.0	12.6	2,153.2	0.0	0.0	1	1	1
11/30/2022 02:00	0.0	12.6	2,153.8	0.0	0.0	1	1	1
11/30/2022 03:00	0.0	12.6	2,151.0	0.0	0.0	1	1	1
11/30/2022 04:00	0.0	12.6	2,169.6	0.0	0.0	1	1	1
11/30/2022 05:00	0.0	12.6	2,169.3	0.0	0.0	1	1	1
11/30/2022 06:00	0.0	12.1	2,268.0	0.0	0.0	1	1	1
11/30/2022 07:00	0.0	12.6	2,158.0	0.0	0.0	1	1	1
11/30/2022 08:00	0.1	13.3	1,984.3	0.0	0.3	1	1	1
11/30/2022 09:00	0.1	13.2	1,998.7	0.1	0.3	1	1	1
11/30/2022 10:00	0.1	13.2	1,980.3	0.1	0.3	1	1	1
11/30/2022 11:00	0.1	13.2	1,984.1	0.1	0.3	1	1	1
11/30/2022 12:00	0.1	13.2	1,983.8	0.1	0.3	1	1	1
11/30/2022 13:00	0.0	13.1	1,978.8	0.1	0.0	1	1	1
11/30/2022 14:00	0.0	12.5	2,132.5	0.0	0.0	1	1	1
11/30/2022 15:00	0.0	12.4	2,140.8	0.0	0.0	1	1	1
11/30/2022 16:00	0.0	11.9	2,251.8	0.0	0.0	1	1	1
11/30/2022 17:00	0.0	11.7	2,297.3	0.0	0.0	1	1	1
11/30/2022 18:00	0.0	11.8	2,289.4	0.0	0.0	1	1	1
11/30/2022 19:00	0.0	11.8	2,289.6	0.0	0.0	1	1	1
11/30/2022 20:00	0.0	11.8	2,288.9	0.0	0.0	1	1	1
11/30/2022 21:00	0.0	12.0	2,256.6	0.0	0.0	1	1	1
11/30/2022 22:00	0.0	12.6	2,106.9	0.0	0.0	1	1	1
11/30/2022 23:00	3.5	13.8	1,590.5	0.0	10.4	1	0	1
Average/Sum#:	0.2	12.6	2,122.8	0.0	11.9 #	24 #	23 #	24 #
Minimum:	0.0	11.7	1,590.5	0.0	0.0	1	0	1
Maximum:	3.5	13.8	2,297.3	0.1	10.4	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	12.9	17.9	301.9	0.0	8.0	1	0	0
12/01/2022 03:00	23.2	14.8	1,144.0	0.0	57.5	1	0	0
12/01/2022 04:00	0.0	13.8	1,703.6	0.0	0.0	1	1	0
12/01/2022 05:00	0.0	13.5	1,790.5	0.0	0.0	1	1	1
12/01/2022 06:00	0.0	11.7	2,291.0	0.0	0.0	1	1	1
12/01/2022 07:00	0.0	11.6	2,326.9	0.0	0.0	1	1	1
12/01/2022 08:00	0.0	12.1	2,203.6	0.0	0.0	1	1	1
12/01/2022 09:00	0.0	12.2	2,190.4	0.0	0.0	1	1	1
12/01/2022 10:00	0.0	12.2	2,195.3	0.0	0.0	1	1	1
12/01/2022 11:00	0.0	12.3	2,173.6	0.0	0.0	1	1	1
12/01/2022 12:00	0.0	12.2	2,176.8	0.0	0.0	1	1	1
12/01/2022 13:00	0.0	12.2	2,177.9	0.0	0.0	1	1	1
12/01/2022 14:00	0.0	12.1	2,192.3	0.0	0.0	1	1	1
12/01/2022 15:00	0.0	11.6	2,311.4	0.0	0.0	1	1	1
12/01/2022 16:00	0.0	11.6	2,338.6	0.0	0.0	1	1	1
12/01/2022 17:00	0.0	11.6	2,347.2	0.0	0.0	1	1	1
12/01/2022 18:00	0.0	11.6	2,335.6	0.0	0.0	1	1	1
12/01/2022 19:00	0.0	11.7	2,345.2	0.0	0.0	1	1	1
12/01/2022 20:00	0.0	11.7	2,349.1	0.0	0.0	1	1	1
12/01/2022 21:00	0.0	11.8	2,324.3	0.0	0.0	1	1	1
12/01/2022 22:00	0.0	12.4	2,184.7	0.0	0.0	1	1	1
12/01/2022 23:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
Average/Sum#:	1.6	12.5	2,072.1	0.0	65.5 #	22 #	20 #	19 #
Minimum:	0.0	11.6	301.9	0.0	0.0	0	0	0
Maximum:	23.2	17.9	2,349.1	0.0	57.5	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	12.4	2,181.7	0.0	0.0	1	1	1
12/02/2022 01:00	0.0	12.4	2,185.0	0.0	0.0	1	1	1
12/02/2022 02:00	0.1	12.4	2,189.6	0.0	0.3	1	1	1
12/02/2022 03:00	0.1	12.5	2,168.0	0.1	0.3	1	1	1
12/02/2022 04:00	0.1	12.5	2,177.5	0.1	0.3	1	1	1
12/02/2022 05:00	0.1	12.5	2,174.2	0.1	0.3	1	1	1
12/02/2022 06:00	0.0	12.0	2,312.0	0.1	0.0	1	1	1
12/02/2022 07:00	0.0	11.9	2,323.5	0.0	0.0	1	1	1
12/02/2022 08:00	0.0	12.0	2,321.3	0.0	0.0	1	1	1
12/02/2022 09:00	0.1	12.4	2,196.4	0.0	0.3	1	1	1
12/02/2022 10:00	0.1	12.4	2,196.5	0.1	0.3	1	1	1
12/02/2022 11:00	0.0	12.3	2,214.2	0.1	0.0	1	1	1
12/02/2022 12:00	0.0	12.3	2,217.5	0.0	0.0	1	1	1
12/02/2022 13:00	0.0	12.3	2,208.5	0.0	0.0	1	1	1
12/02/2022 14:00	0.0	12.3	2,186.0	0.0	0.0	1	1	1
12/02/2022 15:00	0.0	11.9	2,306.4	0.0	0.0	1	1	1
12/02/2022 16:00	0.0	11.7	2,337.6	0.0	0.0	1	1	1
12/02/2022 17:00	0.0	11.8	2,328.6	0.0	0.0	1	1	1
12/02/2022 18:00	0.0	11.9	2,318.8	0.0	0.0	1	1	1
12/02/2022 19:00	0.0	11.9	2,324.2	0.0	0.0	1	1	1
12/02/2022 20:00	0.0	11.9	2,321.7	0.0	0.0	1	1	1
12/02/2022 21:00	0.0	11.9	2,315.9	0.0	0.0	1	1	1
12/02/2022 22:00	0.0	11.9	2,313.3	0.0	0.0	1	1	1
12/02/2022 23:00	0.0	11.9	2,317.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,255.7	0.0	1.8 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,168.0	0.0	0.0	1	1	1
Maximum:	0.1	12.5	2,337.6	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	12.0	2,310.3	0.0	0.0	1	1	1
12/03/2022 01:00	0.0	12.0	2,318.6	0.0	0.0	1	1	1
12/03/2022 02:00	0.0	11.9	2,322.5	0.0	0.0	1	1	1
12/03/2022 03:00	0.0	11.9	2,322.3	0.0	0.0	1	1	1
12/03/2022 04:00	0.0	11.9	2,317.9	0.0	0.0	1	1	1
12/03/2022 05:00	0.0	11.9	2,321.6	0.0	0.0	1	1	1
12/03/2022 06:00	0.0	11.9	2,325.5	0.0	0.0	1	1	1
12/03/2022 07:00	0.0	11.8	2,334.4	0.0	0.0	1	1	1
12/03/2022 08:00	0.0	11.9	2,328.6	0.0	0.0	1	1	1
12/03/2022 09:00	0.0	11.8	2,330.7	0.0	0.0	1	1	1
12/03/2022 10:00	0.0	11.9	2,311.2	0.0	0.0	1	1	1
12/03/2022 11:00	0.0	12.0	2,279.7	0.0	0.0	1	1	1
12/03/2022 12:00	0.0	11.9	2,308.6	0.0	0.0	1	1	1
12/03/2022 13:00	0.0	12.3	2,197.2	0.0	0.0	1	1	1
12/03/2022 14:00	0.1	12.4	2,185.4	0.0	0.3	1	1	1
12/03/2022 15:00	0.0	11.9	2,313.0	0.0	0.0	1	1	1
12/03/2022 16:00	0.0	11.7	2,334.9	0.0	0.0	1	1	1
12/03/2022 17:00	0.0	11.8	2,325.1	0.0	0.0	1	1	1
12/03/2022 18:00	0.0	11.8	2,312.8	0.0	0.0	1	1	1
12/03/2022 19:00	0.0	11.8	2,316.1	0.0	0.0	1	1	1
12/03/2022 20:00	0.0	11.7	2,329.1	0.0	0.0	1	1	1
12/03/2022 21:00	0.0	11.7	2,344.0	0.0	0.0	1	1	1
12/03/2022 22:00	0.0	11.7	2,350.9	0.0	0.0	1	1	1
12/03/2022 23:00	0.0	11.7	2,342.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.9	2,311.8	0.0	0.3 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,185.4	0.0	0.0	1	1	1
Maximum:	0.1	12.4	2,350.9	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	12.3	2,200.3	0.0	0.0	1	1	1
12/04/2022 01:00	0.0	12.3	2,203.9	0.0	0.0	1	1	1
12/04/2022 02:00	0.0	12.3	2,208.7	0.0	0.0	1	1	1
12/04/2022 03:00	0.1	12.3	2,200.4	0.0	0.3	1	1	1
12/04/2022 04:00	0.0	12.3	2,211.5	0.0	0.0	1	1	1
12/04/2022 05:00	0.0	12.3	2,202.2	0.0	0.0	1	1	1
12/04/2022 06:00	0.0	11.8	2,326.8	0.0	0.0	1	1	1
12/04/2022 07:00	0.0	11.7	2,339.1	0.0	0.0	1	1	1
12/04/2022 08:00	0.0	12.3	2,214.8	0.0	0.0	1	1	1
12/04/2022 09:00	0.1	12.3	2,191.3	0.0	0.3	1	1	1
12/04/2022 10:00	0.0	12.2	2,206.1	0.0	0.0	1	1	1
12/04/2022 11:00	0.0	12.2	2,206.4	0.0	0.0	1	1	1
12/04/2022 12:00	0.0	12.1	2,197.7	0.0	0.0	1	1	1
12/04/2022 13:00	0.0	12.1	2,193.2	0.0	0.0	1	1	1
12/04/2022 14:00	0.0	12.1	2,207.4	0.0	0.0	1	1	1
12/04/2022 15:00	0.0	12.1	2,194.8	0.0	0.0	1	1	1
12/04/2022 16:00	0.0	11.6	2,322.7	0.0	0.0	1	1	1
12/04/2022 17:00	0.0	11.6	2,338.7	0.0	0.0	1	1	1
12/04/2022 18:00	0.0	11.6	2,323.4	0.0	0.0	1	1	1
12/04/2022 19:00	0.0	11.7	2,320.9	0.0	0.0	1	1	1
12/04/2022 20:00	0.0	11.7	2,321.9	0.0	0.0	1	1	1
12/04/2022 21:00	0.0	11.7	2,322.9	0.0	0.0	1	1	1
12/04/2022 22:00	0.0	11.8	2,311.7	0.0	0.0	1	1	1
12/04/2022 23:00	0.0	12.3	2,192.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.0	2,248.3	0.0	0.6 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,191.3	0.0	0.0	1	1	1
Maximum:	0.1	12.3	2,339.1	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	12.3	2,194.3	0.0	0.0	1	1	1
12/05/2022 01:00	0.0	12.3	2,191.4	0.0	0.0	1	1	1
12/05/2022 02:00	0.0	12.3	2,196.4	0.0	0.0	1	1	1
12/05/2022 03:00	0.0	12.3	2,190.0	0.0	0.0	1	1	1
12/05/2022 04:00	0.0	12.2	2,215.9	0.0	0.0	1	1	1
12/05/2022 05:00	0.0	11.8	2,320.8	0.0	0.0	1	1	1
12/05/2022 06:00	0.0	11.6	2,344.1	0.0	0.0	1	1	1
12/05/2022 07:00	0.0	11.7	2,340.6	0.0	0.0	1	1	1
12/05/2022 08:00	0.0	11.6	2,351.7	0.0	0.0	1	1	1
12/05/2022 09:00	0.0	11.5	2,366.0	0.0	0.0	1	1	1
12/05/2022 10:00	0.0	11.9	2,141.8	0.0	0.0	1	1	1
12/05/2022 11:00	0.0	13.2	1,826.8	0.0	0.0	1	1	1
12/05/2022 12:00	0.0	12.2	2,161.8	0.0	0.0	1	1	1
12/05/2022 13:00	0.0	12.8	2,027.0	0.0	0.0	1	1	1
12/05/2022 14:00	0.0	12.7	2,056.5	0.0	0.0	1	1	1
12/05/2022 15:00	0.0	12.6	2,074.4	0.0	0.0	1	1	1
12/05/2022 16:00	0.0	12.0	2,222.7	0.0	0.0	1	1	1
12/05/2022 17:00	0.0	11.7	2,298.0	0.0	0.0	1	1	1
12/05/2022 18:00	0.0	11.7	2,298.7	0.0	0.0	1	1	1
12/05/2022 19:00	0.0	11.8	2,302.3	0.0	0.0	1	1	1
12/05/2022 20:00	0.0	11.8	2,299.3	0.0	0.0	1	1	1
12/05/2022 21:00	0.0	12.1	2,221.1	0.0	0.0	1	1	1
12/05/2022 22:00	0.0	12.7	2,074.3	0.0	0.0	1	1	1
12/05/2022 23:00	0.0	12.8	2,049.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,198.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,826.8	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,366.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	0.0	13.2	1,968.4	0.0	0.0	1	1	1
12/06/2022 01:00	0.0	13.2	1,968.0	0.0	0.0	1	1	1
12/06/2022 02:00	0.1	13.2	1,968.0	0.0	0.3	1	1	1
12/06/2022 03:00	0.1	13.2	1,969.4	0.1	0.3	1	1	1
12/06/2022 04:00	0.0	13.1	1,984.1	0.1	0.0	1	1	1
12/06/2022 05:00	0.0	13.0	2,012.5	0.0	0.0	1	1	1
12/06/2022 06:00	0.0	13.1	1,985.5	0.0	0.0	1	1	1
12/06/2022 07:00	0.0	12.7	2,090.5	0.0	0.0	1	1	1
12/06/2022 08:00	0.0	11.9	2,283.2	0.0	0.0	1	1	1
12/06/2022 09:00	0.0	12.0	2,270.7	0.0	0.0	1	1	1
12/06/2022 10:00	0.0	12.0	2,264.3	0.0	0.0	1	1	1
12/06/2022 11:00	0.0	12.0	2,260.4	0.0	0.0	1	1	1
12/06/2022 12:00	0.0	12.0	2,241.0	0.0	0.0	1	1	1
12/06/2022 13:00	0.0	13.7	1,779.8	0.0	0.0	1	1	1
12/06/2022 14:00	0.0	14.0	1,314.5	0.0	0.0	1	1	0
12/06/2022 15:00	0.0	14.0	1,314.1	0.0	0.0	1	1	0
12/06/2022 16:00	0.0	13.9	1,512.4	0.0	0.0	1	1	0
12/06/2022 17:00	0.0	13.8	1,808.0	0.0	0.0	1	1	0
12/06/2022 18:00	0.0	13.8	1,807.8	0.0	0.0	1	1	0
12/06/2022 19:00	0.0	13.8	1,817.6	0.0	0.0	1	1	1
12/06/2022 20:00	0.0	12.5	2,137.3	0.0	0.0	1	1	1
12/06/2022 21:00	0.0	12.1	2,235.9	0.0	0.0	1	1	1
12/06/2022 22:00	0.0	12.6	2,105.7	0.0	0.0	1	1	1
12/06/2022 23:00	0.0	13.2	1,973.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,961.3	0.0	0.6 #	24 #	24 #	19 #
Minimum:	0.0	11.9	1,314.1	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,283.2	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.0	12.7	2,084.1	0.0	0.0	1	1	1
12/07/2022 01:00	0.0	13.1	1,990.9	0.0	0.0	1	1	1
12/07/2022 02:00	0.0	12.6	2,139.0	0.0	0.0	1	1	1
12/07/2022 03:00	0.0	12.5	2,147.2	0.0	0.0	1	1	1
12/07/2022 04:00	0.0	12.5	2,164.6	0.0	0.0	1	1	1
12/07/2022 05:00	0.0	12.4	2,173.1	0.0	0.0	1	1	1
12/07/2022 06:00	0.0	12.1	2,253.6	0.0	0.0	1	1	1
12/07/2022 07:00	0.0	12.1	2,265.4	0.0	0.0	1	1	1
12/07/2022 08:00	0.0	12.6	2,137.8	0.0	0.0	1	1	1
12/07/2022 09:00	0.0	12.5	2,172.2	0.0	0.0	1	1	1
12/07/2022 10:00	0.0	12.5	2,171.5	0.0	0.0	1	1	1
12/07/2022 11:00	0.0	12.5	2,169.0	0.0	0.0	1	1	1
12/07/2022 12:00	0.0	12.5	2,144.8	0.0	0.0	1	1	1
12/07/2022 13:00	0.0	12.5	2,120.6	0.0	0.0	1	1	1
12/07/2022 14:00	0.0	12.8	2,065.4	0.0	0.0	1	1	1
12/07/2022 15:00	0.0	12.7	2,088.9	0.0	0.0	1	1	1
12/07/2022 16:00	0.0	12.0	2,262.1	0.0	0.0	1	1	1
12/07/2022 17:00	0.0	11.9	2,276.0	0.0	0.0	1	1	1
12/07/2022 18:00	0.0	11.9	2,279.2	0.0	0.0	1	1	1
12/07/2022 19:00	0.0	11.9	2,277.8	0.0	0.0	1	1	1
12/07/2022 20:00	0.0	11.9	2,278.1	0.0	0.0	1	1	1
12/07/2022 21:00	0.0	12.0	2,272.8	0.0	0.0	1	1	1
12/07/2022 22:00	0.0	12.4	2,185.4	0.0	0.0	1	1	1
12/07/2022 23:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,179.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,990.9	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,279.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.0	12.6	2,140.3	0.0	0.0	1	1	1
12/08/2022 01:00	0.0	12.6	2,134.5	0.0	0.0	1	1	1
12/08/2022 02:00	0.0	12.6	2,131.2	0.0	0.0	1	1	1
12/08/2022 03:00	0.0	12.7	2,128.7	0.0	0.0	1	1	1
12/08/2022 04:00	0.0	12.6	2,153.6	0.0	0.0	1	1	1
12/08/2022 05:00	0.0	12.4	2,211.4	0.0	0.0	1	1	1
12/08/2022 06:00	0.0	12.0	2,286.3	0.0	0.0	1	1	1
12/08/2022 07:00	0.0	12.2	2,241.1	0.0	0.0	1	1	1
12/08/2022 08:00	0.0	13.0	2,033.7	0.0	0.0	1	1	1
12/08/2022 09:00	0.0	12.8	2,111.2	0.0	0.0	1	1	1
12/08/2022 10:00	0.0	12.7	2,119.0	0.0	0.0	1	1	1
12/08/2022 11:00	0.0	12.5	2,150.5	0.0	0.0	1	1	1
12/08/2022 12:00	0.0	12.5	2,152.8	0.0	0.0	1	1	1
12/08/2022 13:00	0.0	12.4	2,166.9	0.0	0.0	1	1	1
12/08/2022 14:00	0.0	12.3	2,177.4	0.0	0.0	1	1	1
12/08/2022 15:00	0.0	12.3	2,183.9	0.0	0.0	1	1	1
12/08/2022 16:00	0.0	11.9	2,283.7	0.0	0.0	1	1	1
12/08/2022 17:00	0.0	11.9	2,284.7	0.0	0.0	1	1	1
12/08/2022 18:00	0.0	11.9	2,287.5	0.0	0.0	1	1	1
12/08/2022 19:00	0.0	11.9	2,285.8	0.0	0.0	1	1	1
12/08/2022 20:00	0.0	11.9	2,287.4	0.0	0.0	1	1	1
12/08/2022 21:00	0.0	11.9	2,285.0	0.0	0.0	1	1	1
12/08/2022 22:00	0.0	12.3	2,194.3	0.0	0.0	1	1	1
12/08/2022 23:00	0.0	12.3	2,195.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,192.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	2,033.7	0.0	0.0	1	1	1
Maximum:	0.0	13.0	2,287.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	0.0	12.5	2,144.3	0.0	0.0	1	1	1
12/09/2022 01:00	0.0	12.9	2,046.2	0.0	0.0	1	1	1
12/09/2022 02:00	0.0	12.6	2,142.3	0.0	0.0	1	1	1
12/09/2022 03:00	0.0	12.6	2,144.2	0.0	0.0	1	1	1
12/09/2022 04:00	0.0	12.4	2,194.9	0.0	0.0	1	1	1
12/09/2022 05:00	0.0	12.0	2,296.2	0.0	0.0	1	1	1
12/09/2022 06:00	0.0	12.0	2,298.6	0.0	0.0	1	1	1
12/09/2022 07:00	0.0	12.0	2,286.8	0.0	0.0	1	1	1
12/09/2022 08:00	0.0	12.9	2,072.5	0.0	0.0	1	1	1
12/09/2022 09:00	0.0	13.0	2,032.9	0.0	0.0	1	1	1
12/09/2022 10:00	0.1	13.2	1,984.3	0.0	0.3	1	1	1
12/09/2022 11:00	0.0	12.8	2,074.2	0.0	0.0	1	1	1
12/09/2022 12:00	0.0	13.0	2,007.8	0.0	0.0	1	1	1
12/09/2022 13:00	0.0	12.4	2,160.2	0.0	0.0	1	1	1
12/09/2022 14:00	0.0	12.4	2,163.1	0.0	0.0	1	1	1
12/09/2022 15:00	0.0	12.9	2,055.6	0.0	0.0	1	1	1
12/09/2022 16:00	0.0	11.9	2,286.0	0.0	0.0	1	1	1
12/09/2022 17:00	0.0	11.9	2,285.5	0.0	0.0	1	1	1
12/09/2022 18:00	0.0	11.9	2,285.9	0.0	0.0	1	1	1
12/09/2022 19:00	0.0	11.9	2,287.2	0.0	0.0	1	1	1
12/09/2022 20:00	0.0	11.9	2,289.2	0.0	0.0	1	1	1
12/09/2022 21:00	0.0	11.9	2,287.9	0.0	0.0	1	1	1
12/09/2022 22:00	0.0	11.9	2,286.6	0.0	0.0	1	1	1
12/09/2022 23:00	0.0	11.9	2,280.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,183.0	0.0	0.3 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,984.3	0.0	0.0	1	1	1
Maximum:	0.1	13.2	2,298.6	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	0.0	13.0	2,020.4	0.0	0.0	1	1	1
12/10/2022 01:00	0.0	13.0	2,016.4	0.0	0.0	1	1	1
12/10/2022 02:00	0.0	13.1	1,980.5	0.0	0.0	1	1	1
12/10/2022 03:00	0.0	13.1	1,981.2	0.0	0.0	1	1	1
12/10/2022 04:00	0.0	13.1	1,976.3	0.0	0.0	1	1	1
12/10/2022 05:00	0.0	13.0	1,986.7	0.0	0.0	1	1	1
12/10/2022 06:00	0.0	13.1	1,973.6	0.0	0.0	1	1	1
12/10/2022 07:00	0.0	13.1	1,981.0	0.0	0.0	1	1	1
12/10/2022 08:00	0.0	12.9	2,021.2	0.0	0.0	1	1	1
12/10/2022 09:00	0.0	12.9	1,998.2	0.0	0.0	1	1	1
12/10/2022 10:00	0.0	13.0	1,974.5	0.0	0.0	1	1	1
12/10/2022 11:00	0.0	12.8	2,015.4	0.0	0.0	1	1	1
12/10/2022 12:00	0.0	12.4	2,121.1	0.0	0.0	1	1	1
12/10/2022 13:00	0.0	12.0	2,182.6	0.0	0.0	1	1	1
12/10/2022 14:00	0.0	12.7	2,018.0	0.0	0.0	1	1	1
12/10/2022 15:00	0.0	12.6	2,043.8	0.0	0.0	1	1	1
12/10/2022 16:00	0.0	12.4	2,112.6	0.0	0.0	1	1	1
12/10/2022 17:00	0.0	12.5	2,071.9	0.0	0.0	1	1	1
12/10/2022 18:00	0.0	12.6	2,072.8	0.0	0.0	1	1	1
12/10/2022 19:00	0.0	11.8	2,252.8	0.0	0.0	1	1	1
12/10/2022 20:00	0.0	12.2	2,175.1	0.0	0.0	1	1	1
12/10/2022 21:00	0.0	12.5	2,080.6	0.0	0.0	1	1	1
12/10/2022 22:00	0.0	12.9	2,016.0	0.0	0.0	1	1	1
12/10/2022 23:00	0.0	12.6	2,077.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	2,047.9	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,973.6	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,252.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	0.0	13.1	1,967.5	0.0	0.0	1	1	1
12/11/2022 01:00	0.0	13.1	1,965.0	0.0	0.0	1	1	1
12/11/2022 02:00	0.0	13.1	1,964.9	0.0	0.0	1	1	1
12/11/2022 03:00	0.0	13.1	1,965.4	0.0	0.0	1	1	1
12/11/2022 04:00	0.0	13.1	1,969.0	0.0	0.0	1	1	1
12/11/2022 05:00	0.0	13.1	1,967.8	0.0	0.0	1	1	1
12/11/2022 06:00	0.0	13.1	1,969.4	0.0	0.0	1	1	1
12/11/2022 07:00	0.0	13.2	1,972.0	0.0	0.0	1	1	1
12/11/2022 08:00	0.0	13.2	1,973.7	0.0	0.0	1	1	1
12/11/2022 09:00	0.0	13.1	1,971.0	0.0	0.0	1	1	1
12/11/2022 10:00	0.0	13.1	1,969.2	0.0	0.0	1	1	1
12/11/2022 11:00	0.0	13.1	1,966.9	0.0	0.0	1	1	1
12/11/2022 12:00	0.0	13.1	1,966.8	0.0	0.0	1	1	1
12/11/2022 13:00	0.0	13.1	1,968.3	0.0	0.0	1	1	1
12/11/2022 14:00	0.0	13.1	1,963.5	0.0	0.0	1	1	1
12/11/2022 15:00	0.0	12.7	2,060.7	0.0	0.0	1	1	1
12/11/2022 16:00	0.0	12.8	2,068.6	0.0	0.0	1	1	1
12/11/2022 17:00	0.0	12.5	2,141.4	0.0	0.0	1	1	1
12/11/2022 18:00	0.0	12.9	2,048.1	0.0	0.0	1	1	1
12/11/2022 19:00	0.0	12.8	2,066.7	0.0	0.0	1	1	1
12/11/2022 20:00	0.0	12.6	2,120.2	0.0	0.0	1	1	1
12/11/2022 21:00	0.0	13.1	2,003.0	0.0	0.0	1	1	1
12/11/2022 22:00	0.0	13.2	1,972.7	0.0	0.0	1	1	1
12/11/2022 23:00	0.0	13.2	1,974.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,999.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.5	1,963.5	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,141.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	0.0	13.2	1,981.6	0.0	0.0	1	1	1
12/12/2022 01:00	0.0	13.2	1,982.3	0.0	0.0	1	1	1
12/12/2022 02:00	0.0	13.2	1,981.4	0.0	0.0	1	1	1
12/12/2022 03:00	0.0	13.2	1,978.4	0.0	0.0	1	1	1
12/12/2022 04:00	0.0	13.2	1,977.9	0.0	0.0	1	1	1
12/12/2022 05:00	0.0	12.7	2,119.2	0.0	0.0	1	1	1
12/12/2022 06:00	0.0	12.2	2,218.1	0.0	0.0	1	1	1
12/12/2022 07:00	0.0	12.3	2,198.9	0.0	0.0	1	1	1
12/12/2022 08:00	0.0	12.8	2,076.7	0.0	0.0	1	1	1
12/12/2022 09:00	0.0	12.9	2,068.8	0.0	0.0	1	1	1
12/12/2022 10:00	0.1	13.3	1,973.0	0.0	0.3	1	1	1
12/12/2022 11:00	0.1	13.2	1,970.2	0.1	0.3	1	1	1
12/12/2022 12:00	0.1	13.2	1,970.6	0.1	0.3	1	1	1
12/12/2022 13:00	0.1	13.2	1,969.6	0.1	0.3	1	1	1
12/12/2022 14:00	0.1	13.2	1,968.0	0.1	0.3	1	1	1
12/12/2022 15:00	0.0	13.2	1,967.7	0.1	0.0	1	1	1
12/12/2022 16:00	0.0	12.5	2,153.9	0.0	0.0	1	1	1
12/12/2022 17:00	0.0	12.1	2,250.2	0.0	0.0	1	1	1
12/12/2022 18:00	0.0	11.8	2,314.5	0.0	0.0	1	1	1
12/12/2022 19:00	0.0	11.8	2,316.4	0.0	0.0	1	1	1
12/12/2022 20:00	0.0	11.8	2,320.3	0.0	0.0	1	1	1
12/12/2022 21:00	0.0	12.0	2,269.9	0.0	0.0	1	1	1
12/12/2022 22:00	0.0	12.3	2,201.9	0.0	0.0	1	1	1
12/12/2022 23:00	0.0	13.0	2,035.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	2,094.4	0.0	1.5 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,967.7	0.0	0.0	1	1	1
Maximum:	0.1	13.3	2,320.3	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.0	12.6	2,155.3	0.0	0.0	1	1	1
12/13/2022 01:00	0.0	12.5	2,162.4	0.0	0.0	1	1	1
12/13/2022 02:00	0.0	12.5	2,171.0	0.0	0.0	1	1	1
12/13/2022 03:00	0.0	12.5	2,161.4	0.0	0.0	1	1	1
12/13/2022 04:00	0.0	12.4	2,201.7	0.0	0.0	1	1	1
12/13/2022 05:00	0.0	12.1	2,286.6	0.0	0.0	1	1	1
12/13/2022 06:00	0.0	11.9	2,323.5	0.0	0.0	1	1	1
12/13/2022 07:00	0.0	11.9	2,314.5	0.0	0.0	1	1	1
12/13/2022 08:00	0.0	12.5	2,149.7	0.0	0.0	1	1	1
12/13/2022 09:00	0.0	13.1	2,013.4	0.0	0.0	1	1	1
12/13/2022 10:00	0.0	13.3	1,978.2	0.0	0.0	1	1	1
12/13/2022 11:00	0.0	13.2	1,972.8	0.0	0.0	1	1	1
12/13/2022 12:00	0.0	13.2	1,971.6	0.0	0.0	1	1	1
12/13/2022 13:00	0.0	13.2	1,969.9	0.0	0.0	1	1	1
12/13/2022 14:00	0.0	13.2	1,968.6	0.0	0.0	1	1	1
12/13/2022 15:00	0.0	12.8	2,076.2	0.0	0.0	1	1	1
12/13/2022 16:00	0.0	11.9	2,282.3	0.0	0.0	1	1	1
12/13/2022 17:00	0.0	11.8	2,299.2	0.0	0.0	1	1	1
12/13/2022 18:00	0.0	11.9	2,297.3	0.0	0.0	1	1	1
12/13/2022 19:00	0.0	11.9	2,296.7	0.0	0.0	1	1	1
12/13/2022 20:00	0.0	11.9	2,293.3	0.0	0.0	1	1	1
12/13/2022 21:00	0.0	12.0	2,293.3	0.0	0.0	1	1	1
12/13/2022 22:00	0.0	12.0	2,297.4	0.0	0.0	1	1	1
12/13/2022 23:00	0.0	11.9	2,293.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,176.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,968.6	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,323.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.0	12.4	2,201.0	0.0	0.0	1	1	1
12/14/2022 01:00	0.0	12.4	2,205.8	0.0	0.0	1	1	1
12/14/2022 02:00	0.0	12.4	2,207.5	0.0	0.0	1	1	1
12/14/2022 03:00	0.0	12.5	2,202.0	0.0	0.0	1	1	1
12/14/2022 04:00	0.0	12.5	2,195.8	0.0	0.0	1	1	1
12/14/2022 05:00	0.0	12.0	2,307.3	0.0	0.0	1	1	1
12/14/2022 06:00	0.0	12.0	2,311.1	0.0	0.0	1	1	1
12/14/2022 07:00	0.0	12.1	2,277.8	0.0	0.0	1	1	1
12/14/2022 08:00	0.0	12.9	2,081.0	0.0	0.0	1	1	1
12/14/2022 09:00	0.0	13.1	2,011.1	0.0	0.0	1	1	1
12/14/2022 10:00	0.0	13.0	2,028.4	0.0	0.0	1	1	1
12/14/2022 11:00	0.0	13.2	1,974.9	0.0	0.0	1	1	1
12/14/2022 12:00	0.0	13.2	1,976.5	0.0	0.0	1	1	1
12/14/2022 13:00	0.0	13.2	1,978.3	0.0	0.0	1	1	1
12/14/2022 14:00	0.0	13.2	1,975.2	0.0	0.0	1	1	1
12/14/2022 15:00	0.0	13.1	2,018.4	0.0	0.0	1	1	1
12/14/2022 16:00	0.0	12.2	2,219.4	0.0	0.0	1	1	1
12/14/2022 17:00	0.0	11.9	2,291.2	0.0	0.0	1	1	1
12/14/2022 18:00	0.0	11.9	2,288.1	0.0	0.0	1	1	1
12/14/2022 19:00	0.0	11.9	2,292.6	0.0	0.0	1	1	1
12/14/2022 20:00	0.0	12.0	2,292.9	0.0	0.0	1	1	1
12/14/2022 21:00	0.0	12.0	2,291.3	0.0	0.0	1	1	1
12/14/2022 22:00	0.0	12.1	2,265.2	0.0	0.0	1	1	1
12/14/2022 23:00	0.0	12.5	2,178.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,169.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,974.9	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,311.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0.0	12.0	2,300.0	0.0	0.0	1	1	1
12/15/2022 01:00	0.0	11.9	2,310.7	0.0	0.0	1	1	1
12/15/2022 02:00	0.0	11.9	2,310.7	0.0	0.0	1	1	1
12/15/2022 03:00	0.0	11.9	2,312.5	0.0	0.0	1	1	1
12/15/2022 04:00	0.0	11.9	2,317.5	0.0	0.0	1	1	1
12/15/2022 05:00	0.0	11.9	2,320.2	0.0	0.0	1	1	1
12/15/2022 06:00	0.0	11.9	2,319.6	0.0	0.0	1	1	1
12/15/2022 07:00	0.0	11.9	2,314.8	0.0	0.0	1	1	1
12/15/2022 08:00	0.0	12.2	2,232.9	0.0	0.0	1	1	1
12/15/2022 09:00	0.0	12.1	2,231.2	0.0	0.0	1	1	1
12/15/2022 10:00	0.0	13.1	1,978.7	0.0	0.0	1	1	1
12/15/2022 11:00	0.0	13.1	1,990.3	0.0	0.0	1	1	1
12/15/2022 12:00	0.0	12.9	2,023.1	0.0	0.0	1	1	1
12/15/2022 13:00	0.0	12.8	2,045.1	0.0	0.0	1	1	1
12/15/2022 14:00	0.0	12.6	2,102.6	0.0	0.0	1	1	1
12/15/2022 15:00	0.0	11.9	2,258.0	0.0	0.0	1	1	1
12/15/2022 16:00	0.0	11.9	2,270.0	0.0	0.0	1	1	1
12/15/2022 17:00	0.0	11.9	2,268.1	0.0	0.0	1	1	1
12/15/2022 18:00	0.0	12.0	2,258.2	0.0	0.0	1	1	1
12/15/2022 19:00	0.0	12.0	2,251.3	0.0	0.0	1	1	1
12/15/2022 20:00	0.0	12.0	2,253.0	0.0	0.0	1	1	1
12/15/2022 21:00	0.0	12.1	2,254.6	0.0	0.0	1	1	1
12/15/2022 22:00	0.0	12.1	2,260.1	0.0	0.0	1	1	1
12/15/2022 23:00	0.0	12.2	2,242.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,226.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,978.7	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,320.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	0.0	13.1	1,997.7	0.0	0.0	1	1	1
12/16/2022 01:00	0.0	13.2	1,975.0	0.0	0.0	1	1	1
12/16/2022 02:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
12/16/2022 03:00	0.0	13.2	1,977.9	0.0	0.0	1	1	1
12/16/2022 04:00	0.0	13.2	1,976.0	0.0	0.0	1	1	1
12/16/2022 05:00	0.0	13.2	1,986.3	0.0	0.0	1	1	1
12/16/2022 06:00	0.0	12.7	2,114.7	0.0	0.0	1	1	1
12/16/2022 07:00	0.0	12.4	2,213.4	0.0	0.0	1	1	1
12/16/2022 08:00	0.0	12.6	2,148.7	0.0	0.0	1	1	1
12/16/2022 09:00	0.0	12.8	2,073.1	0.0	0.0	1	1	1
12/16/2022 10:00	0.0	13.9	1,533.9	0.0	0.0	1	1	0
12/16/2022 11:00	0.0	14.0	1,455.0	0.0	0.0	1	1	0
12/16/2022 12:00	0.0	14.0	1,319.9	0.0	0.0	1	1	0
12/16/2022 13:00	0.0	14.0	1,322.2	0.0	0.0	1	1	0
12/16/2022 14:00	0.0	13.9	1,577.2	0.0	0.0	1	1	0
12/16/2022 15:00	0.0	13.9	1,550.0	0.0	0.0	1	1	1
12/16/2022 16:00	0.0	12.4	2,166.8	0.0	0.0	1	1	1
12/16/2022 17:00	0.0	12.1	2,236.7	0.0	0.0	1	1	1
12/16/2022 18:00	0.0	12.4	2,162.4	0.0	0.0	1	1	1
12/16/2022 19:00	0.0	12.4	2,168.7	0.0	0.0	1	1	1
12/16/2022 20:00	0.0	12.0	2,256.4	0.0	0.0	1	1	1
12/16/2022 21:00	0.0	12.2	2,198.9	0.0	0.0	1	1	1
12/16/2022 22:00	0.0	12.7	2,089.5	0.0	0.0	1	1	1
12/16/2022 23:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,935.4	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.0	1,319.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,256.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.0	12.5	2,148.3	0.0	0.0	1	1	1
12/17/2022 01:00	0.0	12.5	2,151.2	0.0	0.0	1	1	1
12/17/2022 02:00	0.0	12.6	2,142.6	0.0	0.0	1	1	1
12/17/2022 03:00	0.0	12.6	2,153.4	0.0	0.0	1	1	1
12/17/2022 04:00	0.0	12.5	2,154.4	0.0	0.0	1	1	1
12/17/2022 05:00	0.0	12.6	2,151.3	0.0	0.0	1	1	1
12/17/2022 06:00	0.0	12.1	2,242.2	0.0	0.0	1	1	1
12/17/2022 07:00	0.0	12.7	2,099.3	0.0	0.0	1	1	1
12/17/2022 08:00	0.0	12.5	2,165.9	0.0	0.0	1	1	1
12/17/2022 09:00	0.0	12.7	2,124.8	0.0	0.0	1	1	1
12/17/2022 10:00	0.0	13.1	2,009.5	0.0	0.0	1	1	1
12/17/2022 11:00	0.0	13.2	1,977.3	0.0	0.0	1	1	1
12/17/2022 12:00	0.0	13.2	1,970.0	0.0	0.0	1	1	1
12/17/2022 13:00	0.0	13.2	1,970.2	0.0	0.0	1	1	1
12/17/2022 14:00	0.0	13.1	1,991.1	0.0	0.0	1	1	1
12/17/2022 15:00	0.0	12.6	2,124.4	0.0	0.0	1	1	1
12/17/2022 16:00	0.0	11.9	2,279.1	0.0	0.0	1	1	1
12/17/2022 17:00	0.0	12.0	2,247.4	0.0	0.0	1	1	1
12/17/2022 18:00	0.0	12.4	2,159.7	0.0	0.0	1	1	1
12/17/2022 19:00	0.0	11.9	2,288.0	0.0	0.0	1	1	1
12/17/2022 20:00	0.0	11.9	2,291.4	0.0	0.0	1	1	1
12/17/2022 21:00	0.0	11.9	2,292.3	0.0	0.0	1	1	1
12/17/2022 22:00	0.0	11.9	2,284.2	0.0	0.0	1	1	1
12/17/2022 23:00	0.0	12.3	2,192.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,150.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.0	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,292.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.0	12.5	2,141.4	0.0	0.0	1	1	1
12/18/2022 01:00	0.0	12.6	2,140.8	0.0	0.0	1	1	1
12/18/2022 02:00	0.0	13.1	2,023.7	0.0	0.0	1	1	1
12/18/2022 03:00	0.0	13.3	1,985.2	0.0	0.0	1	1	1
12/18/2022 04:00	0.0	12.7	2,140.3	0.0	0.0	1	1	1
12/18/2022 05:00	0.0	12.6	2,162.0	0.0	0.0	1	1	1
12/18/2022 06:00	0.0	12.4	2,182.1	0.0	0.0	1	1	1
12/18/2022 07:00	0.0	12.3	2,219.3	0.0	0.0	1	1	1
12/18/2022 08:00	0.0	12.7	2,091.7	0.0	0.0	1	1	1
12/18/2022 09:00	0.0	13.9	1,607.9	0.0	0.0	1	1	0
12/18/2022 10:00	0.0	13.9	1,552.2	0.0	0.0	1	1	0
12/18/2022 11:00	0.0	13.9	1,544.4	0.0	0.0	1	1	0
12/18/2022 12:00	0.0	14.0	1,404.3	0.0	0.0	1	1	0
12/18/2022 13:00	0.0	14.0	1,395.8	0.0	0.0	1	1	0
12/18/2022 14:00	0.0	13.9	1,634.8	0.0	0.0	1	1	0
12/18/2022 15:00	0.0	13.9	1,645.9	0.0	0.0	1	1	1
12/18/2022 16:00	0.0	12.5	2,143.3	0.0	0.0	1	1	1
12/18/2022 17:00	0.0	12.0	2,254.0	0.0	0.0	1	1	1
12/18/2022 18:00	0.0	11.9	2,283.9	0.0	0.0	1	1	1
12/18/2022 19:00	0.0	11.9	2,288.7	0.0	0.0	1	1	1
12/18/2022 20:00	0.0	12.2	2,245.0	0.0	0.0	1	1	1
12/18/2022 21:00	0.0	12.4	2,208.9	0.0	0.0	1	1	1
12/18/2022 22:00	0.0	12.4	2,205.7	0.0	0.0	1	1	1
12/18/2022 23:00	0.0	13.0	2,049.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,981.3	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,395.8	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,288.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	0.0	12.7	2,141.9	0.0	0.0	1	1	1
12/19/2022 01:00	0.0	12.6	2,153.5	0.0	0.0	1	1	1
12/19/2022 02:00	0.0	12.6	2,149.7	0.0	0.0	1	1	1
12/19/2022 03:00	0.0	12.6	2,152.1	0.0	0.0	1	1	1
12/19/2022 04:00	0.0	12.5	2,185.5	0.0	0.0	1	1	1
12/19/2022 05:00	0.0	12.0	2,309.6	0.0	0.0	1	1	1
12/19/2022 06:00	0.0	12.0	2,310.1	0.0	0.0	1	1	1
12/19/2022 07:00	0.0	12.0	2,310.1	0.0	0.0	1	1	1
12/19/2022 08:00	0.0	12.2	2,262.0	0.0	0.0	1	1	1
12/19/2022 09:00	0.0	12.1	2,274.3	0.0	0.0	1	1	1
12/19/2022 10:00	0.0	12.5	2,181.5	0.0	0.0	1	1	1
12/19/2022 11:00	0.0	12.5	2,181.8	0.0	0.0	1	1	1
12/19/2022 12:00	0.0	12.6	2,174.1	0.0	0.0	1	1	1
12/19/2022 13:00	0.0	12.6	2,164.7	0.0	0.0	1	1	1
12/19/2022 14:00	0.0	12.6	2,166.8	0.0	0.0	1	1	1
12/19/2022 15:00	0.0	12.3	2,231.0	0.0	0.0	1	1	1
12/19/2022 16:00	0.0	12.1	2,274.5	0.0	0.0	1	1	1
12/19/2022 17:00	0.0	12.1	2,275.0	0.0	0.0	1	1	1
12/19/2022 18:00	0.0	12.1	2,277.1	0.0	0.0	1	1	1
12/19/2022 19:00	0.0	12.1	2,280.3	0.0	0.0	1	1	1
12/19/2022 20:00	0.0	12.2	2,277.2	0.0	0.0	1	1	1
12/19/2022 21:00	0.0	12.2	2,277.4	0.0	0.0	1	1	1
12/19/2022 22:00	0.0	12.1	2,283.3	0.0	0.0	1	1	1
12/19/2022 23:00	0.0	12.1	2,278.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,232.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,141.9	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,310.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.0	12.6	2,180.6	0.0	0.0	1	1	1
12/20/2022 01:00	0.0	12.6	2,178.9	0.0	0.0	1	1	1
12/20/2022 02:00	0.0	12.5	2,184.2	0.0	0.0	1	1	1
12/20/2022 03:00	0.0	12.5	2,189.6	0.0	0.0	1	1	1
12/20/2022 04:00	0.0	12.5	2,190.7	0.0	0.0	1	1	1
12/20/2022 05:00	0.0	12.5	2,190.8	0.0	0.0	1	1	1
12/20/2022 06:00	0.0	12.1	2,291.6	0.0	0.0	1	1	1
12/20/2022 07:00	0.0	12.1	2,284.8	0.0	0.0	1	1	1
12/20/2022 08:00	0.0	12.6	2,170.4	0.0	0.0	1	1	1
12/20/2022 09:00	0.0	12.5	2,170.0	0.0	0.0	1	1	1
12/20/2022 10:00	0.0	12.7	2,128.2	0.0	0.0	1	1	1
12/20/2022 11:00	0.0	12.8	2,095.1	0.0	0.0	1	1	1
12/20/2022 12:00	0.0	13.3	1,961.4	0.0	0.0	1	1	1
12/20/2022 13:00	0.0	13.3	1,965.5	0.0	0.0	1	1	1
12/20/2022 14:00	0.0	13.3	1,964.0	0.0	0.0	1	1	1
12/20/2022 15:00	0.0	13.0	2,038.6	0.0	0.0	1	1	1
12/20/2022 16:00	0.0	12.3	2,199.8	0.0	0.0	1	1	1
12/20/2022 17:00	0.0	12.0	2,266.0	0.0	0.0	1	1	1
12/20/2022 18:00	0.0	12.0	2,265.9	0.0	0.0	1	1	1
12/20/2022 19:00	0.0	12.0	2,259.4	0.0	0.0	1	1	1
12/20/2022 20:00	0.0	12.0	2,259.9	0.0	0.0	1	1	1
12/20/2022 21:00	0.0	12.4	2,168.4	0.0	0.0	1	1	1
12/20/2022 22:00	0.0	12.4	2,167.9	0.0	0.0	1	1	1
12/20/2022 23:00	0.0	12.2	2,226.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,166.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,961.4	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,291.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	0.0	12.0	2,286.1	0.0	0.0	1	1	1
12/21/2022 01:00	0.0	12.0	2,284.9	0.0	0.0	1	1	1
12/21/2022 02:00	0.0	12.0	2,281.3	0.0	0.0	1	1	1
12/21/2022 03:00	0.0	12.0	2,289.0	0.0	0.0	1	1	1
12/21/2022 04:00	0.0	12.0	2,282.4	0.0	0.0	1	1	1
12/21/2022 05:00	0.0	12.0	2,284.7	0.0	0.0	1	1	1
12/21/2022 06:00	0.0	12.0	2,284.5	0.0	0.0	1	1	1
12/21/2022 07:00	0.0	12.0	2,283.3	0.0	0.0	1	1	1
12/21/2022 08:00	0.0	0.0	2,268.8	0.0	0.0	1	1	1
12/21/2022 09:00	0.1	12.2	2,259.9	0.0	0.3	1	1	1
12/21/2022 10:00	0.1	12.2	2,253.9	0.0	0.3	1	1	1
12/21/2022 11:00	0.1	12.3	2,219.0	0.1	0.3	1	1	1
12/21/2022 12:00	0.1	12.2	2,236.9	0.1	0.3	1	1	1
12/21/2022 13:00	0.1	12.1	2,229.8	0.1	0.3	1	1	1
12/21/2022 14:00	0.1	12.5	2,160.3	0.1	0.3	1	1	1
12/21/2022 15:00	0.1	12.1	2,234.3	0.1	0.3	1	1	1
12/21/2022 16:00	0.0	12.0	2,257.4	0.1	0.0	1	1	1
12/21/2022 17:00	0.1	12.0	2,255.2	0.1	0.3	1	1	1
12/21/2022 18:00	0.1	12.0	2,258.5	0.1	0.3	1	1	1
12/21/2022 19:00	0.0	12.0	2,256.4	0.1	0.0	1	1	1
12/21/2022 20:00	0.1	12.1	2,252.8	0.1	0.3	1	1	1
12/21/2022 21:00	0.1	12.1	2,253.7	0.1	0.3	1	1	1
12/21/2022 22:00	0.1	12.1	2,250.9	0.1	0.3	1	1	1
12/21/2022 23:00	0.1	12.1	2,248.9	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.1	2,257.2	0.1	3.9 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,160.3	0.0	0.0	1	1	1
Maximum:	0.1	12.5	2,289.0	0.1	0.3	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	0.2	12.4	2,185.3	0.1	0.7	1	1	1
12/22/2022 01:00	0.3	13.2	1,981.3	0.1	1.0	1	1	1
12/22/2022 02:00	0.3	13.2	1,968.8	0.2	1.0	1	1	1
12/22/2022 03:00	0.3	13.2	1,968.0	0.2	1.0	1	1	1
12/22/2022 04:00	0.3	12.8	2,091.8	0.2	1.0	1	1	1
12/22/2022 05:00	0.1	12.4	2,221.8	0.2	0.3	1	1	1
12/22/2022 06:00	0.1	12.1	2,268.5	0.1	0.3	1	1	1
12/22/2022 07:00	0.1	12.1	2,266.2	0.1	0.3	1	1	1
12/22/2022 08:00	0.1	12.2	2,248.9	0.1	0.3	1	1	1
12/22/2022 09:00	0.2	12.6	2,149.4	0.1	0.7	1	1	1
12/22/2022 10:00	0.2	12.6	2,146.2	0.1	0.7	1	1	1
12/22/2022 11:00	0.2	12.6	2,143.8	0.1	0.7	1	1	1
12/22/2022 12:00	0.2	12.6	2,141.5	0.1	0.7	1	1	1
12/22/2022 13:00	0.1	12.6	2,143.3	0.1	0.3	1	1	1
12/22/2022 14:00	0.2	12.6	2,149.6	0.1	0.7	1	1	1
12/22/2022 15:00	0.1	12.3	2,214.6	0.1	0.3	1	1	1
12/22/2022 16:00	0.1	12.3	2,209.7	0.1	0.3	1	1	1
12/22/2022 17:00	0.1	12.1	2,256.5	0.1	0.3	1	1	1
12/22/2022 18:00	0.1	12.1	2,261.1	0.1	0.3	1	1	1
12/22/2022 19:00	0.1	12.1	2,267.4	0.1	0.3	1	1	1
12/22/2022 20:00	0.1	12.1	2,262.7	0.1	0.3	1	1	1
12/22/2022 21:00	0.0	12.1	2,260.5	0.1	0.0	1	1	1
12/22/2022 22:00	0.1	12.3	2,215.3	0.1	0.3	1	1	1
12/22/2022 23:00	0.2	12.8	2,077.3	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,170.8	0.1	12.5 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,968.0	0.1	0.0	1	1	1
Maximum:	0.3	13.2	2,268.5	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.1	12.3	2,228.2	0.1	0.3	1	1	1
12/23/2022 01:00	0.1	12.1	2,265.3	0.1	0.3	1	1	1
12/23/2022 02:00	0.1	12.1	2,261.5	0.1	0.3	1	1	1
12/23/2022 03:00	0.1	12.1	2,261.6	0.1	0.3	1	1	1
12/23/2022 04:00	0.1	12.1	2,262.1	0.1	0.3	1	1	1
12/23/2022 05:00	0.1	12.1	2,259.9	0.1	0.3	1	1	1
12/23/2022 06:00	0.1	12.1	2,259.7	0.1	0.3	1	1	1
12/23/2022 07:00	0.1	12.2	2,240.1	0.1	0.3	1	1	1
12/23/2022 08:00	0.1	12.4	2,187.9	0.1	0.3	1	1	1
12/23/2022 09:00	0.1	12.4	2,182.4	0.1	0.3	1	1	1
12/23/2022 10:00	0.1	12.5	2,137.6	0.1	0.3	1	1	1
12/23/2022 11:00	0.1	12.5	2,141.7	0.1	0.3	1	1	1
12/23/2022 12:00	0.2	12.9	2,027.4	0.1	0.7	1	1	1
12/23/2022 13:00	0.2	13.2	1,960.0	0.1	0.7	1	1	1
12/23/2022 14:00	0.2	13.2	1,953.8	0.2	0.7	1	1	1
12/23/2022 15:00	0.2	12.8	2,064.7	0.2	0.7	1	1	1
12/23/2022 16:00	0.0	12.0	2,253.1	0.1	0.0	1	1	1
12/23/2022 17:00	0.0	12.0	2,254.2	0.0	0.0	1	1	1
12/23/2022 18:00	0.0	12.0	2,260.1	0.0	0.0	1	1	1
12/23/2022 19:00	0.0	12.0	2,252.4	0.0	0.0	1	1	1
12/23/2022 20:00	0.0	12.0	2,248.8	0.0	0.0	1	1	1
12/23/2022 21:00	0.0	12.0	2,253.2	0.0	0.0	1	1	1
12/23/2022 22:00	0.0	12.0	2,252.2	0.0	0.0	1	1	1
12/23/2022 23:00	0.0	12.0	2,242.9	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.3	2,196.3	0.1	6.4 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,953.8	0.0	0.0	1	1	1
Maximum:	0.2	13.2	2,265.3	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.1	12.5	2,130.9	0.0	0.3	1	1	1
12/24/2022 01:00	0.1	12.6	2,124.1	0.1	0.3	1	1	1
12/24/2022 02:00	0.2	13.2	1,963.2	0.1	0.7	1	1	1
12/24/2022 03:00	0.2	13.2	1,955.6	0.2	0.7	1	1	1
12/24/2022 04:00	0.2	13.2	1,955.0	0.2	0.7	1	1	1
12/24/2022 05:00	0.2	13.2	1,953.0	0.2	0.7	1	1	1
12/24/2022 06:00	0.2	13.1	1,979.9	0.2	0.7	1	1	1
12/24/2022 07:00	0.2	13.0	2,010.1	0.2	0.7	1	1	1
12/24/2022 08:00	0.2	13.4	1,837.3	0.2	0.6	1	1	1
12/24/2022 09:00	0.0	13.9	1,316.3	0.1	0.0	1	1	0
12/24/2022 10:00	0.1	13.9	1,548.3	0.1	0.3	1	1	0
12/24/2022 11:00	0.1	13.9	1,547.9	0.1	0.3	1	1	0
12/24/2022 12:00	0.1	13.9	1,552.0	0.1	0.3	1	1	0
12/24/2022 13:00	0.0	13.9	1,554.4	0.1	0.0	1	1	0
12/24/2022 14:00	0.0	13.9	1,730.3	0.0	0.0	1	1	0
12/24/2022 15:00	0.0	13.9	1,734.3	0.0	0.0	1	1	0
12/24/2022 16:00	0.0	13.9	1,590.2	0.0	0.0	1	1	1
12/24/2022 17:00	0.3	13.1	1,969.4	0.1	1.0	1	1	1
12/24/2022 18:00	0.2	13.1	1,965.8	0.1	0.7	1	1	1
12/24/2022 19:00	0.1	13.1	1,965.9	0.2	0.3	1	1	1
12/24/2022 20:00	0.1	13.1	1,967.3	0.1	0.3	1	1	1
12/24/2022 21:00	0.1	13.1	1,962.5	0.1	0.3	1	1	1
12/24/2022 22:00	0.1	13.2	1,965.3	0.1	0.3	1	1	1
12/24/2022 23:00	0.1	13.1	1,967.2	0.1	0.3	1	1	1
Average/Sum#:	0.1	13.4	1,843.6	0.1	9.5 #	24 #	24 #	17 #
Minimum:	0.0	12.5	1,316.3	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,130.9	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	0.1	13.1	1,946.8	0.1	0.3	1	1	1
12/25/2022 01:00	16.2	15.6	592.2	0.0	5.3	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	42.7	17.7	345.3	0.0	43.8	1	0	0
12/25/2022 19:00	16.8	17.3	411.1	0.0	25.3	1	0	0
12/25/2022 20:00	27.2	15.9	780.4	0.0	56.1	1	0	0
12/25/2022 21:00	0.1	13.9	1,417.5	0.0	0.3	1	1	0
12/25/2022 22:00	0.0	13.9	1,455.7	0.0	0.0	1	1	0
12/25/2022 23:00	0.1	13.9	1,477.4	0.1	0.3	1	1	0
Average/Sum#:	12.9	15.2	1,053.3	0.1	131.4 #	8 #	4 #	1 #
Minimum:	0.0	13.1	345.3	0.1	0.0	0	0	0
Maximum:	42.7	17.7	1,946.8	0.1	56.1	1	1	1
%SI	66.67	66.67	66.67	91.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	0.1	13.8	1,763.9	0.1	0.3	1	1	0
12/26/2022 01:00	0.1	13.8	1,543.0	0.1	0.3	1	1	0
12/26/2022 02:00	0.1	13.8	1,700.6	0.1	0.3	1	1	0
12/26/2022 03:00	0.1	13.8	1,721.9	0.1	0.3	1	1	0
12/26/2022 04:00	0.1	13.8	1,721.7	0.1	0.3	1	1	0
12/26/2022 05:00	0.1	13.8	1,737.5	0.1	0.3	1	1	0
12/26/2022 06:00	0.1	13.8	1,736.8	0.1	0.3	1	1	0
12/26/2022 07:00	0.1	13.8	1,728.0	0.1	0.3	1	1	0
12/26/2022 08:00	0.1	13.8	1,734.8	0.1	0.3	1	1	0
12/26/2022 09:00	0.1	13.9	1,548.8	0.1	0.3	1	1	0
12/26/2022 10:00	0.1	13.9	1,544.0	0.1	0.3	1	1	0
12/26/2022 11:00	0.1	13.9	1,535.6	0.1	0.3	1	1	0
12/26/2022 12:00	0.1	13.9	1,526.6	0.1	0.3	1	1	0
12/26/2022 13:00	0.1	13.9	1,547.1	0.1	0.3	1	1	0
12/26/2022 14:00	0.1	13.8	1,610.5	0.1	0.3	1	1	0
12/26/2022 15:00	0.1	13.8	1,740.0	0.1	0.3	1	1	0
12/26/2022 16:00	0.1	13.8	1,774.3	0.1	0.3	1	1	1
12/26/2022 17:00	0.3	12.6	2,122.6	0.1	1.0	1	1	1
12/26/2022 18:00	0.2	12.4	2,163.9	0.1	0.7	1	1	1
12/26/2022 19:00	0.3	13.0	2,015.8	0.2	1.0	1	1	1
12/26/2022 20:00	0.3	13.1	2,000.4	0.2	1.0	1	1	1
12/26/2022 21:00	0.3	13.2	1,969.8	0.2	1.0	1	1	1
12/26/2022 22:00	0.3	13.2	1,947.6	0.2	1.0	1	1	1
12/26/2022 23:00	13.9	15.6	609.2	0.0	4.9	1	0	0
Average/Sum#:	0.7	13.7	1,710.2	0.1	15.7 #	24 #	23 #	7 #
Minimum:	0.1	12.4	609.2	0.1	0.3	1	0	0
Maximum:	13.9	15.6	2,163.9	0.2	4.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	6.6	18.8	198.2	0.0	1.6	1	0	0
12/27/2022 02:00	20.5	16.0	756.8	0.0	41.8	1	0	0
12/27/2022 03:00	0.0	13.8	1,538.4	0.0	0.0	1	1	0
12/27/2022 04:00	0.0	13.9	1,539.3	0.0	0.0	1	1	0
12/27/2022 05:00	0.0	13.8	1,685.4	0.0	0.0	1	1	0
12/27/2022 06:00	0.0	13.9	1,397.3	0.0	0.0	1	1	0
12/27/2022 07:00	0.0	13.8	1,731.2	0.0	0.0	1	1	0
12/27/2022 08:00	0.1	13.8	1,701.6	0.0	0.3	1	1	1
12/27/2022 09:00	0.3	12.9	1,972.8	0.1	1.0	1	1	1
12/27/2022 10:00	0.3	12.9	1,967.9	0.2	1.0	1	1	1
12/27/2022 11:00	0.2	12.9	1,970.4	0.2	0.7	1	1	1
12/27/2022 12:00	0.2	12.9	1,969.6	0.1	0.7	1	1	1
12/27/2022 13:00	0.2	12.9	1,969.2	0.1	0.7	1	1	1
12/27/2022 14:00	0.2	12.9	1,970.6	0.1	0.7	1	1	1
12/27/2022 15:00	0.2	12.9	1,970.8	0.1	0.7	1	1	1
12/27/2022 16:00	0.2	13.0	1,970.5	0.1	0.7	1	1	1
12/27/2022 17:00	0.2	13.0	1,962.5	0.1	0.7	1	1	1
12/27/2022 18:00	0.2	13.1	1,960.1	0.1	0.7	1	1	1
12/27/2022 19:00	0.2	13.1	1,959.5	0.2	0.7	1	1	1
12/27/2022 20:00	0.2	13.1	1,971.6	0.2	0.7	1	1	1
12/27/2022 21:00	0.2	13.1	1,972.6	0.2	0.7	1	1	1
12/27/2022 22:00	0.2	13.2	1,945.8	0.2	0.7	1	1	1
12/27/2022 23:00	0.0	14.0	1,392.3	0.1	0.0	1	1	0
Average/Sum#:	1.3	13.6	1,716.3	0.1	54.1 #	23 #	21 #	15 #
Minimum:	0.0	12.9	198.2	0.0	0.0	0	0	0
Maximum:	20.5	18.8	1,972.8	0.2	41.8	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.0	13.9	1,539.7	0.1	0.0	1	1	0
12/28/2022 01:00	0.0	13.9	1,465.2	0.0	0.0	1	1	0
12/28/2022 02:00	0.0	13.9	1,520.9	0.0	0.0	1	1	0
12/28/2022 03:00	0.0	13.9	1,518.1	0.0	0.0	1	1	0
12/28/2022 04:00	0.0	13.9	1,528.2	0.0	0.0	1	1	0
12/28/2022 05:00	0.1	13.8	1,718.9	0.0	0.3	1	1	0
12/28/2022 06:00	0.0	13.8	1,735.9	0.0	0.0	1	1	0
12/28/2022 07:00	0.1	13.8	1,738.4	0.1	0.3	1	1	0
12/28/2022 08:00	0.0	13.8	1,716.3	0.0	0.0	1	1	0
12/28/2022 09:00	0.1	13.8	1,707.8	0.1	0.3	1	1	0
12/28/2022 10:00	0.1	13.9	1,547.7	0.1	0.3	1	1	0
12/28/2022 11:00	0.0	13.9	1,563.0	0.1	0.0	1	1	0
12/28/2022 12:00	0.0	13.9	1,545.4	0.0	0.0	1	1	0
12/28/2022 13:00	0.0	13.9	1,525.3	0.0	0.0	1	1	0
12/28/2022 14:00	0.0	13.9	1,549.1	0.0	0.0	1	1	0
12/28/2022 15:00	0.1	13.9	1,592.4	0.0	0.3	1	1	1
12/28/2022 16:00	0.3	12.6	2,095.4	0.1	1.0	1	1	1
12/28/2022 17:00	0.3	13.1	1,976.0	0.2	1.0	1	1	1
12/28/2022 18:00	0.3	13.2	1,956.1	0.2	1.0	1	1	1
12/28/2022 19:00	0.3	13.2	1,957.5	0.2	1.0	1	1	1
12/28/2022 20:00	0.3	13.2	1,959.0	0.2	1.0	1	1	1
12/28/2022 21:00	0.3	13.1	1,970.4	0.2	1.0	1	1	1
12/28/2022 22:00	0.3	13.2	1,956.0	0.2	1.0	1	1	1
12/28/2022 23:00	0.3	13.2	1,960.9	0.2	1.0	1	1	1
Average/Sum#:	0.1	13.6	1,722.7	0.1	9.5 #	24 #	24 #	9 #
Minimum:	0.0	12.6	1,465.2	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,095.4	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	0.3	13.2	1,956.9	0.2	1.0	1	1	1
12/29/2022 01:00	0.3	13.2	1,961.0	0.2	1.0	1	1	1
12/29/2022 02:00	0.3	13.2	1,965.0	0.2	1.0	1	1	1
12/29/2022 03:00	0.3	13.2	1,964.8	0.2	1.0	1	1	1
12/29/2022 04:00	0.3	13.2	1,969.1	0.2	1.0	1	1	1
12/29/2022 05:00	0.3	12.9	2,038.0	0.2	1.0	1	1	1
12/29/2022 06:00	0.3	12.6	2,047.5	0.2	1.0	1	1	1
12/29/2022 07:00	0.3	12.8	2,051.3	0.2	1.0	1	1	1
12/29/2022 08:00	0.2	12.2	2,206.4	0.2	0.7	1	1	1
12/29/2022 09:00	0.1	11.9	2,259.5	0.1	0.3	1	1	1
12/29/2022 10:00	0.1	12.4	2,161.9	0.1	0.3	1	1	1
12/29/2022 11:00	0.3	12.9	2,024.3	0.1	1.0	1	1	1
12/29/2022 12:00	0.3	13.1	1,986.2	0.2	1.0	1	1	1
12/29/2022 13:00	0.3	13.2	1,975.5	0.2	1.0	1	1	1
12/29/2022 14:00	0.3	13.1	1,985.1	0.2	1.0	1	1	1
12/29/2022 15:00	0.3	13.1	1,989.5	0.2	1.0	1	1	1
12/29/2022 16:00	0.3	12.7	2,100.3	0.2	1.0	1	1	1
12/29/2022 17:00	0.1	12.3	2,176.8	0.2	0.3	1	1	1
12/29/2022 18:00	0.2	12.6	2,085.5	0.1	0.7	1	1	1
12/29/2022 19:00	0.4	13.2	1,968.4	0.2	1.4	1	1	1
12/29/2022 20:00	0.4	13.2	1,977.8	0.2	1.4	1	1	1
12/29/2022 21:00	0.3	13.1	1,989.3	0.3	1.0	1	1	1
12/29/2022 22:00	0.4	13.1	1,972.1	0.3	1.3	1	1	1
12/29/2022 23:00	0.4	13.1	1,943.3	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	2,031.5	0.2	22.7 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,943.3	0.1	0.3	1	1	1
Maximum:	0.4	13.2	2,259.5	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	16.1	15.9	561.7	0.0	5.5	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	16.1	15.9	561.7	0.0	5.5 #	1 #	0 #	0 #
Minimum:	16.1	15.9	561.7	0.0	5.5	0	0	0
Maximum:	16.1	15.9	561.7	0.0	5.5	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:24 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:24 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/01/2022 00:00	10.7	13.1	8.1	192.6	3,294,378.6	2,165.1	2.0	1.7
10/01/2022 01:00	16.4	14.7	15.6	173.5	2,438,985.1	1,211.1	2.4	1.1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.6	13.9	11.9	183.1	2,866,681.9	1,688.1	2.2	1.4
Minimum:	10.7	13.1	8.1	173.5	2,438,985.1	1,211.1	2.0	1.1
Maximum:	16.4	14.7	15.6	192.6	3,294,378.6	2,165.1	2.4	1.7
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2022 02:00	37.1	17.5	64.4	39.0	1,353,313.5	336.0	0.0	0.0
10/03/2022 03:00	33.3	15.6	37.1	244.5	2,199,954.9	867.5	3.6	1.2
10/03/2022 04:00	10.1	13.9	8.5	145.7	3,301,470.0	1,711.7	1.5	1.0
10/03/2022 05:00	10.4	13.9	8.8	151.1	3,287,004.3	1,704.2	1.6	1.0
10/03/2022 06:00	10.6	13.9	8.9	146.4	3,281,989.5	1,701.6	1.5	1.0
10/03/2022 07:00	11.0	13.9	9.3	149.4	3,295,490.8	1,708.6	1.5	1.0
10/03/2022 08:00	10.7	13.9	9.0	148.8	3,315,164.3	1,718.8	1.5	1.0
10/03/2022 09:00	10.3	13.9	8.7	160.2	3,327,122.6	1,725.0	1.6	1.0
10/03/2022 10:00	11.3	13.7	9.3	206.3	3,380,913.2	1,728.2	2.1	1.4
10/03/2022 11:00	11.3	13.8	9.4	115.1	3,381,108.8	1,728.3	1.1	0.7
10/03/2022 12:00	11.2	13.8	9.3	123.1	3,381,304.4	1,728.4	1.2	0.9
10/03/2022 13:00	11.1	13.8	9.2	122.2	3,385,021.4	1,730.3	1.2	0.9
10/03/2022 14:00	11.1	13.8	9.2	120.8	3,373,870.4	1,724.6	1.2	0.9
10/03/2022 15:00	10.5	13.7	8.6	176.9	3,312,881.5	1,766.0	1.8	1.2
10/03/2022 16:00	11.3	13.3	8.8	192.2	3,282,000.7	2,061.1	2.0	1.6
10/03/2022 17:00	11.3	13.2	8.7	216.5	3,268,861.2	2,172.2	2.3	2.0
10/03/2022 18:00	11.3	13.1	8.5	222.5	3,249,511.5	2,206.8	2.4	2.0
10/03/2022 19:00	11.4	13.1	8.6	210.7	3,271,419.4	2,173.9	2.2	1.7
10/03/2022 20:00	11.3	13.1	8.5	222.0	3,255,657.6	2,187.2	2.4	2.0
10/03/2022 21:00	11.3	13.1	8.5	218.0	3,272,322.3	2,174.5	2.3	2.0
10/03/2022 22:00	11.1	13.2	8.5	210.0	3,311,852.9	2,152.4	2.2	1.7
10/03/2022 23:00	11.1	13.2	8.5	210.2	3,304,573.2	2,171.8	2.2	1.7
Average/Sum#:	13.2	13.8	12.7	170.5	3,172,400.4	1,780.9	1.8	1.3
Minimum:	10.1	13.1	8.5	39.0	1,353,313.5	336.0	0.0	0.0
Maximum:	37.1	17.5	64.4	244.5	3,385,021.4	2,206.8	3.6	2.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/04/2022 00:00	11.0	13.2	8.4	208.6	3,315,084.1	2,154.5	2.2	1.7
10/04/2022 01:00	11.0	13.2	8.4	214.8	3,321,238.8	2,158.5	2.3	1.9
10/04/2022 02:00	11.0	13.2	8.4	215.2	3,317,853.7	2,156.3	2.3	1.9
10/04/2022 03:00	11.0	13.2	8.4	213.0	3,333,086.6	2,166.2	2.2	1.7
10/04/2022 04:00	10.8	13.2	8.3	207.6	3,344,472.9	2,173.6	2.2	1.7
10/04/2022 05:00	10.7	13.2	8.2	238.1	3,313,104.1	2,201.6	2.5	2.2
10/04/2022 06:00	10.9	13.2	8.4	205.2	3,333,856.0	2,166.7	2.1	1.7
10/04/2022 07:00	10.6	13.3	8.2	183.2	3,358,884.5	2,035.8	1.9	1.4
10/04/2022 08:00	10.7	13.8	8.9	157.4	3,033,845.6	1,595.1	1.8	1.1
10/04/2022 09:00	11.1	13.8	9.2	142.7	2,985,538.0	1,547.9	1.6	0.9
10/04/2022 10:00	11.5	13.7	9.4	142.0	2,957,956.7	1,555.2	1.6	0.9
10/04/2022 11:00	11.5	13.7	9.4	142.9	2,974,694.1	1,564.0	1.6	0.9
10/04/2022 12:00	10.9	13.7	8.9	153.5	3,276,728.2	1,722.8	1.6	1.0
10/04/2022 13:00	10.5	13.6	8.5	154.7	3,369,748.4	1,747.1	1.5	1.0
10/04/2022 14:00	11.2	13.3	8.7	168.0	3,436,917.1	2,032.9	1.6	1.2
10/04/2022 15:00	11.3	13.2	8.7	159.1	3,308,467.8	2,150.2	1.6	1.3
10/04/2022 16:00	11.2	13.2	8.6	157.3	3,316,963.7	2,131.5	1.6	1.3
10/04/2022 17:00	11.2	13.2	8.6	161.5	3,298,466.4	2,143.7	1.7	1.5
10/04/2022 18:00	11.2	13.1	8.5	163.5	3,300,617.1	2,169.2	1.7	1.5
10/04/2022 19:00	11.2	13.1	8.5	166.1	3,324,962.4	2,185.2	1.7	1.5
10/04/2022 20:00	11.3	13.1	8.5	179.4	3,303,846.8	2,243.7	1.9	1.6
10/04/2022 21:00	11.1	13.1	8.4	164.2	3,332,874.6	2,190.4	1.7	1.5
10/04/2022 22:00	11.0	13.1	8.3	163.7	3,313,854.9	2,177.9	1.7	1.5
10/04/2022 23:00	10.8	13.2	8.3	156.5	3,376,024.6	2,144.8	1.6	1.3
Average/Sum#:	11.0	13.3	8.6	175.8	3,272,878.6	2,021.5	1.8	1.4
Minimum:	10.5	13.1	8.2	142.0	2,957,956.7	1,547.9	1.5	0.9
Maximum:	11.5	13.8	9.4	238.1	3,436,917.1	2,243.7	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/05/2022 00:00	10.8	13.2	8.3	152.8	3,363,274.8	2,136.7	1.5	1.3
10/05/2022 01:00	10.7	13.3	8.3	138.9	3,379,096.9	1,998.7	1.4	1.0
10/05/2022 02:00	10.8	13.3	8.4	137.8	3,416,800.5	1,971.1	1.3	1.0
10/05/2022 03:00	10.8	13.2	8.3	144.5	3,399,759.1	2,085.4	1.4	1.0
10/05/2022 04:00	10.8	13.2	8.3	150.2	3,361,618.4	2,111.1	1.5	1.3
10/05/2022 05:00	10.9	13.2	8.4	174.5	3,347,938.3	2,200.3	1.8	1.5
10/05/2022 06:00	11.1	13.1	8.4	163.0	3,349,612.0	2,201.4	1.7	1.5
10/05/2022 07:00	10.7	13.3	8.3	140.1	3,398,226.6	1,985.2	1.4	1.0
10/05/2022 08:00	10.6	13.7	8.7	121.3	3,361,154.3	1,718.1	1.2	0.9
10/05/2022 09:00	10.8	13.8	9.0	114.0	3,292,291.9	1,682.9	1.1	0.7
10/05/2022 10:00	11.3	13.7	9.3	128.3	3,346,677.6	1,710.7	1.3	0.9
10/05/2022 11:00	11.2	13.7	9.2	203.2	3,369,566.5	1,722.4	2.1	1.4
10/05/2022 12:00	11.2	13.7	9.2	153.0	3,353,932.5	1,738.9	1.5	1.0
10/05/2022 13:00	11.5	13.2	8.8	147.2	3,351,867.6	2,080.5	1.5	1.2
10/05/2022 14:00	11.5	13.1	8.7	171.0	3,296,249.6	2,190.4	1.8	1.5
10/05/2022 15:00	11.4	13.2	8.7	164.6	3,325,678.2	2,137.1	1.7	1.5
10/05/2022 16:00	11.4	13.2	8.7	168.8	3,285,249.1	2,159.1	1.8	1.5
10/05/2022 17:00	11.4	13.1	8.6	173.7	3,272,031.2	2,198.2	1.8	1.5
10/05/2022 18:00	11.5	13.1	8.7	180.0	3,284,998.8	2,230.9	1.9	1.6
10/05/2022 19:00	11.4	13.1	8.6	176.9	3,299,576.5	2,240.8	1.8	1.6
10/05/2022 20:00	11.3	13.1	8.5	170.2	3,333,331.1	2,190.7	1.7	1.5
10/05/2022 21:00	11.3	13.1	8.5	174.1	3,295,159.0	2,237.8	1.8	1.6
10/05/2022 22:00	11.1	13.1	8.4	163.2	3,333,394.4	2,166.4	1.7	1.5
10/05/2022 23:00	11.1	13.1	8.4	162.0	3,348,165.7	2,176.0	1.7	1.5
Average/Sum#:	11.1	13.3	8.6	157.2	3,340,235.4	2,053.0	1.6	1.3
Minimum:	10.6	13.1	8.3	114.0	3,272,031.2	1,682.9	1.1	0.7
Maximum:	11.5	13.8	9.3	203.2	3,416,800.5	2,240.8	2.1	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/06/2022 00:00	10.8	13.2	8.3	159.0	3,370,184.5	2,165.7	1.6	1.3
10/06/2022 01:00	10.9	13.2	8.4	160.4	3,373,296.9	2,167.7	1.6	1.3
10/06/2022 02:00	11.0	13.2	8.4	157.0	3,369,095.2	2,165.0	1.6	1.3
10/06/2022 03:00	11.0	13.2	8.4	157.5	3,370,987.7	2,141.6	1.6	1.3
10/06/2022 04:00	10.8	13.2	8.3	163.4	3,356,320.7	2,181.3	1.7	1.5
10/06/2022 05:00	11.1	13.1	8.4	169.4	3,314,301.5	2,250.8	1.7	1.6
10/06/2022 06:00	11.4	13.1	8.6	172.5	3,368,633.5	2,238.5	1.8	1.6
10/06/2022 07:00	11.1	13.2	8.5	152.9	3,362,015.6	2,135.9	1.5	1.3
10/06/2022 08:00	11.0	13.2	8.4	150.9	3,355,734.2	2,082.9	1.5	1.2
10/06/2022 09:00	11.0	13.2	8.4	145.9	3,376,772.3	2,071.3	1.5	1.2
10/06/2022 10:00	11.1	13.2	8.5	150.1	3,394,216.2	2,082.0	1.5	1.2
10/06/2022 11:00	11.2	13.2	8.6	155.8	3,367,032.4	2,114.5	1.6	1.3
10/06/2022 12:00	11.3	13.2	8.7	158.0	3,325,055.8	2,136.7	1.6	1.3
10/06/2022 13:00	11.3	13.1	8.5	169.6	3,299,259.4	2,192.4	1.8	1.5
10/06/2022 14:00	11.1	13.1	8.4	173.7	3,307,084.6	2,197.6	1.8	1.5
10/06/2022 15:00	11.0	13.2	8.4	162.7	3,309,391.0	2,150.8	1.7	1.5
10/06/2022 16:00	11.1	13.2	8.5	171.8	3,297,905.0	2,191.5	1.8	1.5
10/06/2022 17:00	11.1	13.1	8.4	181.9	3,298,545.8	2,240.1	1.9	1.6
10/06/2022 18:00	11.1	13.1	8.4	175.8	3,332,762.2	2,239.0	1.8	1.6
10/06/2022 19:00	11.1	13.1	8.4	181.4	3,320,633.3	2,255.1	1.9	1.6
10/06/2022 20:00	11.0	13.1	8.3	177.1	3,327,112.3	2,259.5	1.8	1.6
10/06/2022 21:00	11.0	13.1	8.3	178.6	3,342,288.6	2,245.4	1.8	1.6
10/06/2022 22:00	10.9	13.2	8.4	162.2	3,369,861.1	2,190.1	1.6	1.3
10/06/2022 23:00	10.8	13.2	8.3	160.3	3,375,008.6	2,168.8	1.6	1.3
Average/Sum#:	11.1	13.2	8.4	164.5	3,345,145.8	2,177.7	1.7	1.4
Minimum:	10.8	13.1	8.3	145.9	3,297,905.0	2,071.3	1.5	1.2
Maximum:	11.4	13.2	8.7	181.9	3,394,216.2	2,259.5	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/07/2022 00:00	10.8	13.2	8.3	155.6	3,374,608.0	2,143.9	1.6	1.3
10/07/2022 01:00	10.8	13.2	8.3	155.0	3,399,792.8	2,159.9	1.5	1.3
10/07/2022 02:00	11.0	13.2	8.4	156.3	3,370,987.7	2,141.6	1.6	1.3
10/07/2022 03:00	11.0	13.2	8.4	153.9	3,367,350.9	2,114.7	1.5	1.3
10/07/2022 04:00	11.0	13.2	8.4	155.5	3,393,024.4	2,155.6	1.6	1.3
10/07/2022 05:00	10.9	13.2	8.4	159.0	3,372,169.1	2,191.6	1.6	1.3
10/07/2022 06:00	11.3	13.1	8.5	167.1	3,392,171.9	2,204.6	1.7	1.5
10/07/2022 07:00	11.0	13.2	8.4	152.4	3,400,683.5	2,110.8	1.5	1.3
10/07/2022 08:00	11.0	13.3	8.5	144.4	3,390,160.4	2,030.0	1.4	1.0
10/07/2022 09:00	11.1	13.2	8.5	154.2	3,387,892.2	2,127.6	1.5	1.3
10/07/2022 10:00	11.1	13.2	8.5	152.8	3,387,733.0	2,127.5	1.5	1.3
10/07/2022 11:00	11.1	13.2	8.5	155.9	3,361,459.2	2,111.0	1.6	1.3
10/07/2022 12:00	11.2	13.2	8.6	167.5	3,336,779.5	2,168.6	1.7	1.5
10/07/2022 13:00	11.1	13.2	8.5	159.4	3,325,367.0	2,136.9	1.6	1.3
10/07/2022 14:00	11.3	13.2	8.7	171.6	3,320,549.8	2,182.3	1.8	1.5
10/07/2022 15:00	11.2	13.1	8.5	171.7	3,300,162.3	2,193.0	1.8	1.5
10/07/2022 16:00	11.3	13.2	8.7	170.3	3,315,832.9	2,179.2	1.8	1.5
10/07/2022 17:00	11.3	13.1	8.5	180.6	3,283,526.3	2,229.9	1.9	1.6
10/07/2022 18:00	11.2	13.1	8.5	180.7	3,303,257.8	2,243.3	1.9	1.6
10/07/2022 19:00	11.2	13.1	8.5	184.5	3,325,345.3	2,258.3	1.9	1.6
10/07/2022 20:00	11.2	13.1	8.5	180.2	3,331,529.8	2,262.5	1.9	1.6
10/07/2022 21:00	11.1	13.1	8.4	183.4	3,336,094.5	2,265.6	1.9	1.6
10/07/2022 22:00	11.0	13.1	8.3	176.7	3,360,001.8	2,257.3	1.8	1.6
10/07/2022 23:00	11.0	13.2	8.4	166.4	3,361,859.9	2,184.9	1.7	1.5
Average/Sum#:	11.1	13.2	8.5	164.8	3,354,097.5	2,174.2	1.7	1.4
Minimum:	10.8	13.1	8.3	144.4	3,283,526.3	2,030.0	1.4	1.0
Maximum:	11.3	13.3	8.7	184.5	3,400,683.5	2,265.6	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/08/2022 00:00	10.9	13.2	8.4	162.7	3,382,011.4	2,173.3	1.6	1.3
10/08/2022 01:00	11.0	13.2	8.4	159.6	3,386,524.3	2,176.2	1.6	1.3
10/08/2022 02:00	10.9	13.2	8.4	159.4	3,372,830.0	2,167.4	1.6	1.3
10/08/2022 03:00	11.0	13.2	8.4	161.5	3,389,792.2	2,178.3	1.6	1.3
10/08/2022 04:00	11.0	13.2	8.4	162.6	3,348,319.6	2,176.1	1.7	1.5
10/08/2022 05:00	11.0	13.2	8.4	158.2	3,377,498.5	2,170.4	1.6	1.3
10/08/2022 06:00	11.1	13.3	8.6	153.5	3,360,503.7	2,110.4	1.5	1.3
10/08/2022 07:00	11.2	13.7	9.2	167.4	3,301,662.9	1,711.8	1.7	1.2
10/08/2022 08:00	11.5	13.9	9.7	126.8	2,671,551.3	1,365.6	1.6	0.8
10/08/2022 09:00	11.2	14.0	9.6	127.9	2,574,126.6	1,315.8	1.7	0.9
10/08/2022 10:00	10.9	14.0	9.3	128.1	2,605,081.8	1,312.6	1.7	0.9
10/08/2022 11:00	10.9	14.0	9.3	125.5	2,617,386.8	1,318.8	1.6	0.8
10/08/2022 12:00	11.5	13.8	9.6	177.1	3,027,778.0	1,569.8	2.0	1.3
10/08/2022 13:00	10.7	13.8	8.9	182.4	3,332,908.9	1,728.0	1.9	1.2
10/08/2022 14:00	10.7	13.7	8.8	178.7	3,319,142.4	1,745.1	1.8	1.2
10/08/2022 15:00	11.4	13.2	8.7	210.1	3,257,656.0	2,069.6	2.2	1.7
10/08/2022 16:00	11.5	13.1	8.7	217.6	3,277,538.6	2,201.9	2.3	2.0
10/08/2022 17:00	11.4	13.1	8.6	224.4	3,276,794.4	2,201.4	2.4	2.0
10/08/2022 18:00	11.2	13.2	8.6	222.8	3,297,269.6	2,167.0	2.4	2.0
10/08/2022 19:00	11.2	13.2	8.6	217.9	3,313,398.4	2,177.6	2.3	2.0
10/08/2022 20:00	11.1	13.2	8.5	215.5	3,317,658.8	2,180.4	2.3	2.0
10/08/2022 21:00	11.2	13.2	8.6	219.5	3,313,854.9	2,177.9	2.3	2.0
10/08/2022 22:00	11.1	13.2	8.5	218.1	3,344,011.3	2,173.3	2.3	2.0
10/08/2022 23:00	10.9	13.2	8.4	213.8	3,377,342.9	2,170.3	2.2	1.7
Average/Sum#:	11.1	13.4	8.8	178.8	3,201,776.8	1,947.5	1.9	1.5
Minimum:	10.7	13.1	8.4	125.5	2,574,126.6	1,312.6	1.5	0.8
Maximum:	11.5	14.0	9.7	224.4	3,389,792.2	2,201.9	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/09/2022 00:00	11.0	13.2	8.4	211.0	3,334,009.8	2,166.8	2.2	1.7
10/09/2022 01:00	10.9	13.2	8.4	207.1	3,372,207.5	2,167.0	2.1	1.7
10/09/2022 02:00	10.8	13.2	8.3	210.4	3,365,950.7	2,138.4	2.2	1.7
10/09/2022 03:00	10.8	13.2	8.3	209.5	3,380,746.8	2,147.8	2.2	1.7
10/09/2022 04:00	11.0	13.2	8.4	216.2	3,359,135.8	2,158.6	2.3	1.9
10/09/2022 05:00	11.0	13.2	8.4	224.4	3,344,507.8	2,149.2	2.4	1.9
10/09/2022 06:00	14.2	13.9	12.0	203.8	2,921,034.2	1,685.1	2.4	1.5
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	22.6	18.0	46.0	167.6	1,304,688.0	209.6	0.0	0.0
10/09/2022 11:00	43.4	15.6	48.3	260.4	2,066,797.3	799.9	3.9	1.2
10/09/2022 12:00	11.0	13.9	9.3	132.0	2,713,416.6	1,387.0	1.6	0.8
10/09/2022 13:00	11.2	13.9	9.4	132.9	2,760,481.7	1,390.9	1.6	0.8
10/09/2022 14:00	11.0	13.7	9.0	199.2	3,283,575.4	1,726.4	2.1	1.4
10/09/2022 15:00	11.4	13.8	9.5	165.5	3,013,312.3	1,562.3	1.9	1.1
10/09/2022 16:00	10.9	13.8	9.1	191.9	3,336,187.8	1,729.7	2.0	1.4
10/09/2022 17:00	11.0	13.5	8.8	184.2	3,341,958.3	1,781.5	1.9	1.2
10/09/2022 18:00	11.4	13.2	8.7	196.8	3,314,803.2	2,081.7	2.1	1.7
10/09/2022 19:00	11.4	13.1	8.6	220.8	3,288,107.0	2,209.0	2.4	2.0
10/09/2022 20:00	11.2	13.2	8.6	212.4	3,293,089.4	2,188.3	2.3	2.0
10/09/2022 21:00	11.1	13.2	8.5	212.6	3,309,137.9	2,174.8	2.2	1.7
10/09/2022 22:00	11.0	13.2	8.4	210.7	3,317,546.0	2,156.1	2.2	1.7
10/09/2022 23:00	11.0	13.2	8.4	210.1	3,341,239.9	2,147.1	2.2	1.7
Average/Sum#:	13.3	13.7	12.5	199.0	3,083,901.6	1,817.0	2.1	1.5
Minimum:	10.8	13.1	8.3	132.0	1,304,688.0	209.6	0.0	0.0
Maximum:	43.4	18.0	48.3	260.4	3,380,746.8	2,209.0	3.9	2.0
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/10/2022 00:00	10.9	13.2	8.4	205.7	3,339,978.9	2,121.9	2.1	1.7
10/10/2022 01:00	10.8	13.3	8.4	195.3	3,371,361.7	2,092.6	2.0	1.7
10/10/2022 02:00	10.7	13.3	8.3	179.8	3,390,694.8	1,980.8	1.8	1.4
10/10/2022 03:00	10.8	13.2	8.3	194.6	3,356,861.9	2,083.6	2.0	1.7
10/10/2022 04:00	10.8	13.2	8.3	203.5	3,387,096.1	2,127.1	2.1	1.7
10/10/2022 05:00	11.0	13.2	8.4	217.8	3,332,065.4	2,214.2	2.3	2.0
10/10/2022 06:00	11.2	13.1	8.5	214.6	3,355,698.4	2,205.4	2.2	1.8
10/10/2022 07:00	10.8	13.5	8.6	191.5	3,273,284.7	1,816.6	2.0	1.5
10/10/2022 08:00	11.4	13.7	9.3	154.6	2,993,060.2	1,551.8	1.8	1.1
10/10/2022 09:00	11.2	13.8	9.3	147.5	3,022,710.9	1,545.1	1.6	0.9
10/10/2022 10:00	11.1	13.9	9.4	127.7	2,760,283.2	1,390.8	1.5	0.8
10/10/2022 11:00	10.8	13.9	9.1	151.0	3,053,033.8	1,560.6	1.7	1.1
10/10/2022 12:00	10.5	13.9	8.9	142.5	3,079,639.8	1,574.2	1.6	0.9
10/10/2022 13:00	10.5	13.8	8.7	177.4	3,336,573.6	1,729.9	1.8	1.2
10/10/2022 14:00	10.7	13.8	8.9	182.1	3,314,392.8	1,718.4	1.9	1.2
10/10/2022 15:00	11.3	13.8	9.4	159.6	3,091,041.6	1,602.6	1.8	1.1
10/10/2022 16:00	11.3	13.3	8.8	196.0	3,255,765.2	1,973.3	2.1	1.6
10/10/2022 17:00	11.3	13.2	8.7	212.1	3,291,183.3	2,163.0	2.2	1.7
10/10/2022 18:00	11.4	13.1	8.6	221.5	3,272,775.4	2,198.7	2.4	2.0
10/10/2022 19:00	11.4	13.1	8.6	223.9	3,264,196.1	2,169.1	2.4	2.0
10/10/2022 20:00	11.2	13.2	8.6	215.6	3,287,531.5	2,160.6	2.3	1.9
10/10/2022 21:00	11.1	13.2	8.5	202.8	3,309,914.5	2,102.8	2.1	1.7
10/10/2022 22:00	10.9	13.3	8.5	202.5	3,359,761.9	2,085.4	2.1	1.7
10/10/2022 23:00	10.7	13.4	8.4	190.9	3,343,620.8	1,953.3	2.0	1.6
Average/Sum#:	11.0	13.4	8.7	187.9	3,243,438.6	1,921.7	2.0	1.5
Minimum:	10.5	13.1	8.3	127.7	2,760,283.2	1,390.8	1.5	0.8
Maximum:	11.4	13.9	9.4	223.9	3,390,694.8	2,214.2	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/11/2022 00:00	11.2	13.9	9.4	131.0	2,692,288.3	1,376.2	1.6	0.8
10/11/2022 01:00	11.1	13.9	9.4	124.4	2,544,194.9	1,300.5	1.6	0.8
10/11/2022 02:00	11.1	13.9	9.4	128.6	2,543,608.0	1,300.2	1.7	0.9
10/11/2022 03:00	11.3	13.9	9.5	139.0	2,645,532.3	1,352.3	1.8	0.9
10/11/2022 04:00	11.1	13.8	9.2	149.0	2,926,068.6	1,495.7	1.7	1.0
10/11/2022 05:00	11.2	13.9	9.4	122.2	2,582,147.5	1,319.9	1.6	0.8
10/11/2022 06:00	11.5	13.9	9.7	129.4	2,570,213.9	1,313.8	1.7	0.9
10/11/2022 07:00	11.4	13.9	9.6	126.4	2,574,322.2	1,315.9	1.7	0.9
10/11/2022 08:00	11.3	13.9	9.5	137.4	2,576,865.4	1,317.2	1.8	0.9
10/11/2022 09:00	11.4	13.8	9.5	147.6	2,895,354.4	1,480.0	1.7	1.0
10/11/2022 10:00	11.3	13.8	9.4	152.2	3,028,579.8	1,548.1	1.7	1.1
10/11/2022 11:00	11.1	13.7	9.1	156.8	3,155,269.5	1,635.9	1.7	1.1
10/11/2022 12:00	10.8	13.5	8.6	188.2	3,381,352.7	1,802.5	1.9	1.3
10/11/2022 13:00	10.9	13.5	8.7	189.6	3,364,844.5	1,793.7	1.9	1.3
10/11/2022 14:00	10.9	13.5	8.7	185.5	3,357,716.0	1,789.9	1.9	1.3
10/11/2022 15:00	10.9	13.5	8.7	183.9	3,353,213.8	1,787.5	1.9	1.3
10/11/2022 16:00	10.9	13.5	8.7	181.4	3,354,714.6	1,788.3	1.9	1.3
10/11/2022 17:00	10.9	13.5	8.7	182.0	3,357,153.3	1,789.6	1.9	1.3
10/11/2022 18:00	10.9	13.5	8.7	184.0	3,365,782.5	1,794.2	1.9	1.3
10/11/2022 19:00	11.1	13.3	8.6	186.3	3,308,727.3	2,005.4	1.9	1.4
10/11/2022 20:00	11.1	13.2	8.5	207.6	3,316,652.5	2,131.3	2.2	1.7
10/11/2022 21:00	10.9	13.3	8.5	195.9	3,278,079.8	2,034.7	2.1	1.6
10/11/2022 22:00	11.0	13.2	8.4	199.9	3,309,599.7	2,102.6	2.1	1.7
10/11/2022 23:00	10.7	13.3	8.3	193.3	3,332,435.1	1,971.1	2.0	1.6
Average/Sum#:	11.1	13.6	9.0	163.4	3,033,946.5	1,647.8	1.8	1.2
Minimum:	10.7	13.2	8.3	122.2	2,543,608.0	1,300.2	1.6	0.8
Maximum:	11.5	13.9	9.7	207.6	3,381,352.7	2,131.3	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/12/2022 00:00	10.7	13.3	8.3	180.5	3,394,265.7	1,958.1	1.8	1.4
10/12/2022 01:00	10.5	13.4	8.3	185.5	3,354,223.0	1,935.0	1.9	1.4
10/12/2022 02:00	11.1	13.8	9.2	147.8	2,931,339.7	1,519.8	1.7	1.1
10/12/2022 03:00	10.2	13.8	8.5	147.7	3,203,279.3	1,637.4	1.6	1.0
10/12/2022 04:00	10.4	13.6	8.4	170.3	3,364,409.4	1,768.9	1.7	1.2
10/12/2022 05:00	10.9	13.3	8.5	201.1	3,279,079.0	2,131.1	2.1	1.7
10/12/2022 06:00	11.3	13.1	8.5	225.8	3,364,020.8	2,260.0	2.4	2.0
10/12/2022 07:00	11.1	13.1	8.4	225.3	3,356,727.1	2,255.1	2.4	2.0
10/12/2022 08:00	11.1	13.1	8.4	223.5	3,345,712.2	2,247.7	2.3	2.0
10/12/2022 09:00	11.0	13.1	8.3	213.3	3,344,521.4	2,246.9	2.2	1.8
10/12/2022 10:00	11.0	13.1	8.3	223.4	3,337,227.7	2,242.0	2.3	2.0
10/12/2022 11:00	11.0	13.1	8.3	226.3	3,343,032.9	2,245.9	2.4	2.0
10/12/2022 12:00	11.0	13.1	8.3	225.0	3,314,154.3	2,250.7	2.4	2.0
10/12/2022 13:00	11.1	13.1	8.4	219.9	3,310,178.5	2,248.0	2.3	2.0
10/12/2022 14:00	11.1	13.1	8.4	227.9	3,312,240.0	2,249.4	2.4	2.0
10/12/2022 15:00	11.2	13.1	8.5	231.7	3,313,712.5	2,250.4	2.5	2.3
10/12/2022 16:00	11.4	13.1	8.6	222.2	3,267,446.6	2,266.7	2.4	2.0
10/12/2022 17:00	11.4	13.1	8.6	236.8	3,279,266.9	2,274.9	2.5	2.3
10/12/2022 18:00	11.4	13.1	8.6	224.6	3,288,238.3	2,233.1	2.4	2.0
10/12/2022 19:00	11.2	13.2	8.6	209.4	3,327,390.0	2,138.2	2.2	1.7
10/12/2022 20:00	11.3	13.2	8.7	220.5	3,304,467.2	2,147.6	2.3	1.9
10/12/2022 21:00	11.3	13.2	8.7	210.7	3,335,571.5	2,119.1	2.2	1.7
10/12/2022 22:00	11.1	13.2	8.5	197.9	3,362,017.4	2,086.8	2.0	1.7
10/12/2022 23:00	11.0	13.3	8.5	198.9	3,368,441.6	1,967.8	2.1	1.6
Average/Sum#:	11.0	13.2	8.5	208.2	3,308,373.5	2,111.7	2.2	1.8
Minimum:	10.2	13.1	8.3	147.7	2,931,339.7	1,519.8	1.6	1.0
Maximum:	11.4	13.8	9.2	236.8	3,394,265.7	2,274.9	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/13/2022 00:00	11.2	13.3	8.7	185.7	3,357,315.1	1,961.3	1.9	1.4
10/13/2022 01:00	11.2	13.3	8.7	197.5	3,348,409.6	2,005.0	2.0	1.6
10/13/2022 02:00	11.1	13.3	8.6	185.5	3,385,945.1	1,953.3	1.9	1.4
10/13/2022 03:00	11.1	13.3	8.6	187.5	3,396,172.5	1,959.2	1.9	1.4
10/13/2022 04:00	10.6	13.4	8.3	173.1	3,338,622.0	1,926.0	1.8	1.3
10/13/2022 05:00	11.4	13.9	9.6	129.1	2,565,127.5	1,311.2	1.7	0.9
10/13/2022 06:00	11.5	13.9	9.7	126.7	2,565,518.8	1,311.4	1.7	0.9
10/13/2022 07:00	11.6	13.9	9.8	135.2	2,621,078.3	1,339.8	1.7	0.9
10/13/2022 08:00	11.0	13.8	9.1	155.8	3,060,952.8	1,587.0	1.7	1.1
10/13/2022 09:00	11.3	13.8	9.4	158.7	2,961,814.2	1,535.6	1.8	1.1
10/13/2022 10:00	10.8	13.5	8.6	188.8	3,384,166.6	1,804.0	1.9	1.3
10/13/2022 11:00	10.9	13.5	8.7	186.2	3,350,093.2	1,810.3	1.9	1.3
10/13/2022 12:00	10.8	13.5	8.6	185.8	3,392,233.0	1,808.3	1.9	1.3
10/13/2022 13:00	10.9	13.5	8.7	188.3	3,380,977.5	1,802.3	1.9	1.3
10/13/2022 14:00	10.9	13.5	8.7	185.0	3,364,094.2	1,793.3	1.9	1.3
10/13/2022 15:00	10.9	13.5	8.7	187.5	3,362,593.4	1,792.5	1.9	1.3
10/13/2022 16:00	10.9	13.5	8.7	188.8	3,359,216.8	1,790.7	1.9	1.3
10/13/2022 17:00	10.9	13.5	8.7	180.7	3,370,659.9	1,796.8	1.8	1.3
10/13/2022 18:00	10.8	13.5	8.6	181.4	3,338,989.8	1,804.3	1.9	1.3
10/13/2022 19:00	10.7	13.5	8.5	178.6	3,343,986.3	1,807.0	1.8	1.3
10/13/2022 20:00	11.0	13.2	8.4	175.7	3,318,195.8	2,059.6	1.8	1.4
10/13/2022 21:00	11.0	13.2	8.4	203.9	3,323,393.0	2,159.9	2.1	1.7
10/13/2022 22:00	10.7	13.3	8.3	190.3	3,357,023.0	2,083.7	2.0	1.7
10/13/2022 23:00	10.6	13.3	8.2	187.5	3,377,098.3	2,071.5	1.9	1.5
Average/Sum#:	11.0	13.5	8.8	176.8	3,234,319.9	1,803.1	1.9	1.3
Minimum:	10.6	13.2	8.2	126.7	2,565,127.5	1,311.2	1.7	0.9
Maximum:	11.6	13.9	9.8	203.9	3,396,172.5	2,159.9	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/14/2022 00:00	10.4	13.3	8.1	177.5	3,400,462.2	2,061.0	1.8	1.4
10/14/2022 01:00	10.4	13.3	8.1	182.0	3,351,014.1	2,055.5	1.9	1.4
10/14/2022 02:00	10.4	13.3	8.1	183.9	3,351,829.2	2,056.0	1.9	1.4
10/14/2022 03:00	10.3	13.3	8.0	183.0	3,347,264.5	2,053.2	1.9	1.4
10/14/2022 04:00	10.4	13.3	8.1	190.5	3,340,917.8	2,098.1	2.0	1.7
10/14/2022 05:00	10.6	13.2	8.1	217.5	3,284,287.6	2,254.4	2.3	2.0
10/14/2022 06:00	11.0	13.1	8.3	212.9	3,294,631.1	2,261.5	2.3	2.0
10/14/2022 07:00	10.8	13.1	8.2	225.1	3,301,186.9	2,266.0	2.4	2.0
10/14/2022 08:00	10.5	13.3	8.2	197.9	3,314,333.1	2,033.0	2.1	1.6
10/14/2022 09:00	10.6	13.3	8.2	176.8	3,369,639.9	1,968.5	1.8	1.4
10/14/2022 10:00	10.8	13.3	8.4	190.1	3,304,153.8	1,978.5	2.0	1.6
10/14/2022 11:00	10.8	13.3	8.4	180.5	3,320,353.1	1,988.2	1.9	1.4
10/14/2022 12:00	10.8	13.3	8.4	193.1	3,328,202.3	1,992.9	2.0	1.6
10/14/2022 13:00	10.8	13.3	8.4	181.3	3,298,002.9	1,998.9	1.9	1.4
10/14/2022 14:00	10.9	13.3	8.5	202.0	3,311,960.7	2,104.1	2.1	1.7
10/14/2022 15:00	10.8	13.2	8.3	212.1	3,302,774.7	2,146.5	2.2	1.7
10/14/2022 16:00	10.8	13.2	8.3	208.8	3,300,620.5	2,145.1	2.2	1.7
10/14/2022 17:00	11.0	13.1	8.3	216.4	3,245,535.8	2,227.8	2.3	2.0
10/14/2022 18:00	10.8	13.2	8.3	215.6	3,276,576.1	2,153.4	2.3	1.9
10/14/2022 19:00	10.8	13.2	8.3	206.7	3,310,272.2	2,127.2	2.2	1.7
10/14/2022 20:00	10.8	13.2	8.3	199.2	3,283,848.9	2,134.2	2.1	1.7
10/14/2022 21:00	10.9	13.2	8.4	200.2	3,302,958.2	2,122.5	2.1	1.7
10/14/2022 22:00	10.7	13.2	8.2	196.7	3,336,459.2	2,095.3	2.1	1.7
10/14/2022 23:00	15.7	14.5	14.5	185.2	2,608,362.2	1,333.3	2.4	1.2
Average/Sum#:	10.9	13.3	8.5	197.3	3,286,902.0	2,069.0	2.1	1.6
Minimum:	10.3	13.1	8.0	176.8	2,608,362.2	1,333.3	1.8	1.2
Maximum:	15.7	14.5	14.5	225.1	3,400,462.2	2,266.0	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 23:00	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Average/Sum#:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Minimum:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Maximum:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/17/2022 00:00	36.4	15.5	39.8	190.2	2,186,686.5	846.3	2.9	0.9
10/17/2022 01:00	10.6	13.8	8.8	190.1	3,286,618.5	1,704.0	2.0	1.4
10/17/2022 02:00	10.9	13.8	9.1	178.0	3,305,906.2	1,714.0	1.8	1.2
10/17/2022 03:00	10.1	13.6	8.2	166.2	3,442,961.1	1,810.2	1.7	1.3
10/17/2022 04:00	10.9	13.3	8.5	199.0	3,323,561.1	2,087.2	2.1	1.7
10/17/2022 05:00	11.0	13.2	8.4	181.5	3,320,397.7	2,182.2	1.9	1.5
10/17/2022 06:00	11.1	13.2	8.5	193.2	3,386,728.2	2,151.6	2.0	1.7
10/17/2022 07:00	10.8	13.3	8.4	199.0	3,384,250.4	2,100.6	2.0	1.7
10/17/2022 08:00	10.7	13.7	8.8	169.2	3,172,937.5	1,691.4	1.8	1.2
10/17/2022 09:00	11.2	13.8	9.3	172.3	3,171,664.0	1,644.4	1.9	1.2
10/17/2022 10:00	11.4	13.8	9.5	150.8	2,981,236.9	1,523.9	1.7	1.1
10/17/2022 11:00	11.3	13.8	9.4	168.6	3,101,842.7	1,608.2	1.9	1.1
10/17/2022 12:00	11.4	13.8	9.5	151.1	2,947,783.8	1,506.8	1.7	1.1
10/17/2022 13:00	11.4	13.8	9.5	152.8	2,960,108.6	1,513.1	1.8	1.1
10/17/2022 14:00	10.6	13.8	8.8	166.4	3,267,446.6	1,670.2	1.7	1.2
10/17/2022 15:00	11.1	13.7	9.1	187.1	3,259,420.2	1,713.7	2.0	1.4
10/17/2022 16:00	11.4	13.2	8.7	191.6	3,361,695.2	2,086.6	2.0	1.7
10/17/2022 17:00	11.4	13.1	8.6	226.8	3,302,668.8	2,242.9	2.4	2.0
10/17/2022 18:00	11.3	13.1	8.5	231.9	3,328,437.5	2,260.4	2.4	2.0
10/17/2022 19:00	11.2	13.1	8.5	218.0	3,328,296.7	2,236.0	2.3	2.0
10/17/2022 20:00	11.1	13.1	8.4	229.0	3,338,865.0	2,243.1	2.4	2.0
10/17/2022 21:00	11.1	13.1	8.4	228.3	3,322,400.3	2,256.3	2.4	2.0
10/17/2022 22:00	11.0	13.2	8.4	213.7	3,358,013.2	2,182.4	2.2	1.7
10/17/2022 23:00	11.0	13.2	8.4	218.7	3,355,243.6	2,180.6	2.3	2.0
Average/Sum#:	12.1	13.5	10.1	190.6	3,216,465.4	1,881.5	2.1	1.5
Minimum:	10.1	13.1	8.2	150.8	2,186,686.5	846.3	1.7	0.9
Maximum:	36.4	15.5	39.8	231.9	3,442,961.1	2,260.4	2.9	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/18/2022 00:00	10.8	13.2	8.3	213.5	3,347,242.5	2,175.4	2.2	1.7
10/18/2022 01:00	10.5	13.2	8.0	199.4	3,370,651.4	2,166.0	2.1	1.7
10/18/2022 02:00	10.6	13.2	8.1	204.1	3,337,241.1	2,168.9	2.1	1.7
10/18/2022 03:00	10.6	13.2	8.1	210.5	3,337,439.4	2,193.4	2.2	1.8
10/18/2022 04:00	10.5	13.2	8.0	210.9	3,336,526.4	2,192.8	2.2	1.8
10/18/2022 05:00	10.5	13.2	8.0	192.3	3,344,780.6	2,173.8	2.0	1.7
10/18/2022 06:00	10.7	13.2	8.2	201.7	3,384,052.3	2,149.9	2.1	1.7
10/18/2022 07:00	10.6	13.2	8.1	204.8	3,342,640.4	2,148.0	2.1	1.7
10/18/2022 08:00	10.8	13.2	8.3	209.1	3,373,608.1	2,167.9	2.2	1.7
10/18/2022 09:00	10.8	13.2	8.3	213.4	3,370,028.9	2,165.6	2.2	1.7
10/18/2022 10:00	10.9	13.2	8.4	214.5	3,358,237.8	2,133.5	2.2	1.7
10/18/2022 11:00	10.9	13.3	8.5	201.2	3,356,363.6	2,107.8	2.1	1.7
10/18/2022 12:00	10.9	13.3	8.5	211.4	3,352,701.2	2,105.5	2.2	1.7
10/18/2022 13:00	10.9	13.3	8.5	208.6	3,358,592.9	2,109.2	2.2	1.7
10/18/2022 14:00	11.0	13.3	8.5	203.1	3,332,580.8	2,117.2	2.1	1.7
10/18/2022 15:00	11.0	13.3	8.5	218.5	3,344,663.4	2,149.3	2.3	1.9
10/18/2022 16:00	11.1	13.2	8.5	220.0	3,333,059.9	2,239.2	2.3	2.0
10/18/2022 17:00	11.0	13.2	8.4	221.9	3,351,742.3	2,202.8	2.3	2.0
10/18/2022 18:00	11.0	13.2	8.4	233.3	3,348,093.8	2,249.3	2.5	2.2
10/18/2022 19:00	11.0	13.2	8.4	222.0	3,345,076.7	2,271.7	2.3	2.0
10/18/2022 20:00	11.0	13.1	8.3	235.4	3,353,470.0	2,277.4	2.5	2.3
10/18/2022 21:00	11.0	13.1	8.3	223.4	3,354,206.2	2,277.9	2.3	2.1
10/18/2022 22:00	10.9	13.2	8.4	225.3	3,351,894.4	2,202.9	2.4	2.0
10/18/2022 23:00	10.9	13.2	8.4	222.2	3,349,916.4	2,201.6	2.3	2.0
Average/Sum#:	10.8	13.2	8.3	213.4	3,351,450.4	2,181.1	2.2	1.8
Minimum:	10.5	13.1	8.0	192.3	3,332,580.8	2,105.5	2.0	1.7
Maximum:	11.1	13.3	8.5	235.4	3,384,052.3	2,277.9	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/19/2022 00:00	10.8	13.2	8.3	213.4	3,368,784.0	2,189.4	2.2	1.8
10/19/2022 01:00	10.5	13.3	8.2	198.2	3,411,961.1	2,117.8	2.0	1.7
10/19/2022 02:00	10.4	13.4	8.2	190.2	3,374,816.0	2,070.1	2.0	1.7
10/19/2022 03:00	10.3	13.3	8.0	195.8	3,352,701.2	2,105.5	2.0	1.7
10/19/2022 04:00	10.4	13.3	8.1	204.4	3,329,257.4	2,139.4	2.1	1.7
10/19/2022 05:00	10.5	13.3	8.2	243.7	3,276,794.4	2,201.4	2.6	2.2
10/19/2022 06:00	11.0	13.2	8.4	215.0	3,381,869.6	2,222.6	2.2	1.8
10/19/2022 07:00	10.8	13.3	8.4	215.8	3,387,200.4	2,151.9	2.2	1.7
10/19/2022 08:00	10.8	13.3	8.4	200.7	3,408,592.8	2,140.6	2.0	1.7
10/19/2022 09:00	10.9	13.3	8.5	209.8	3,385,700.4	2,101.5	2.2	1.7
10/19/2022 10:00	10.9	13.3	8.5	199.3	3,371,039.5	2,092.4	2.1	1.7
10/19/2022 11:00	11.0	13.3	8.5	210.8	3,339,821.4	2,121.8	2.2	1.7
10/19/2022 12:00	11.1	13.3	8.6	216.6	3,324,744.5	2,136.5	2.3	1.9
10/19/2022 13:00	11.1	13.3	8.6	211.7	3,314,468.6	2,154.1	2.2	1.7
10/19/2022 14:00	11.1	13.3	8.6	222.6	3,338,127.6	2,145.1	2.3	1.9
10/19/2022 15:00	11.2	13.2	8.6	221.4	3,288,123.4	2,185.0	2.4	2.0
10/19/2022 16:00	11.3	13.2	8.7	227.2	3,274,263.9	2,199.7	2.4	2.0
10/19/2022 17:00	11.1	13.2	8.5	219.5	3,306,693.0	2,124.9	2.3	1.9
10/19/2022 18:00	11.1	13.3	8.6	204.5	3,319,831.0	2,109.1	2.1	1.7
10/19/2022 19:00	11.0	13.3	8.5	216.6	3,330,219.7	2,115.7	2.3	1.9
10/19/2022 20:00	11.0	13.2	8.4	210.9	3,353,066.7	2,154.7	2.2	1.7
10/19/2022 21:00	10.8	13.3	8.4	204.6	3,376,108.8	2,120.2	2.1	1.7
10/19/2022 22:00	10.9	13.3	8.5	207.9	3,371,039.5	2,092.4	2.1	1.7
10/19/2022 23:00	10.9	13.3	8.5	204.3	3,361,777.6	2,111.2	2.1	1.7
Average/Sum#:	10.9	13.3	8.4	211.0	3,347,791.8	2,137.6	2.2	1.8
Minimum:	10.3	13.2	8.0	190.2	3,274,263.9	2,070.1	2.0	1.7
Maximum:	11.3	13.4	8.7	243.7	3,411,961.1	2,222.6	2.6	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/20/2022 00:00	10.8	13.3	8.4	204.9	3,390,440.0	2,129.2	2.1	1.7
10/20/2022 01:00	10.8	13.3	8.4	208.3	3,366,206.2	2,089.4	2.2	1.7
10/20/2022 02:00	10.9	13.3	8.5	195.6	3,396,498.5	2,083.4	2.0	1.7
10/20/2022 03:00	10.9	13.3	8.5	208.5	3,373,133.9	2,093.7	2.2	1.7
10/20/2022 04:00	10.8	13.3	8.4	205.1	3,396,490.9	2,133.0	2.1	1.7
10/20/2022 05:00	10.8	13.3	8.4	227.9	3,314,759.4	2,202.7	2.4	2.0
10/20/2022 06:00	11.2	13.2	8.6	217.2	3,379,093.1	2,196.1	2.2	1.8
10/20/2022 07:00	10.8	13.3	8.4	196.8	3,409,701.7	2,066.6	2.0	1.7
10/20/2022 08:00	10.9	13.3	8.5	197.2	3,395,512.5	2,058.0	2.0	1.6
10/20/2022 09:00	11.0	13.3	8.5	203.5	3,379,054.7	2,072.7	2.1	1.7
10/20/2022 10:00	11.0	13.3	8.5	195.4	3,372,044.5	2,068.4	2.0	1.7
10/20/2022 11:00	11.1	13.3	8.6	209.4	3,363,467.4	2,087.7	2.2	1.7
10/20/2022 12:00	11.0	13.3	8.5	199.2	3,327,701.3	2,089.8	2.1	1.7
10/20/2022 13:00	11.0	13.3	8.5	213.3	3,351,586.6	2,104.8	2.2	1.7
10/20/2022 14:00	11.0	13.3	8.5	210.6	3,333,682.6	2,117.9	2.2	1.7
10/20/2022 15:00	11.0	13.3	8.5	210.2	3,344,974.7	2,149.5	2.2	1.7
10/20/2022 16:00	11.3	13.1	8.5	237.0	3,286,181.5	2,255.7	2.5	2.3
10/20/2022 17:00	11.2	13.2	8.6	218.0	3,286,618.5	2,184.0	2.3	2.0
10/20/2022 18:00	11.1	13.2	8.5	230.4	3,321,449.5	2,231.4	2.4	2.0
10/20/2022 19:00	10.9	13.3	8.5	205.0	3,329,590.1	2,115.3	2.1	1.7
10/20/2022 20:00	10.9	13.3	8.5	207.4	3,322,349.5	2,110.7	2.2	1.7
10/20/2022 21:00	10.7	13.3	8.3	204.4	3,361,856.3	2,086.7	2.1	1.7
10/20/2022 22:00	10.8	13.3	8.4	195.8	3,364,595.2	2,088.4	2.0	1.7
10/20/2022 23:00	10.6	13.3	8.2	196.6	3,344,858.4	2,125.0	2.0	1.7
Average/Sum#:	10.9	13.3	8.5	208.2	3,354,660.3	2,122.5	2.2	1.8
Minimum:	10.6	13.1	8.2	195.4	3,286,181.5	2,058.0	2.0	1.6
Maximum:	11.3	13.3	8.6	237.0	3,409,701.7	2,255.7	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/21/2022 00:00	10.3	13.4	8.1	180.1	3,286,787.6	1,944.1	1.9	1.4
10/21/2022 01:00	10.3	13.8	8.6	144.9	3,097,442.3	1,583.3	1.6	0.9
10/21/2022 02:00	10.7	13.8	8.9	155.3	3,126,004.6	1,597.9	1.7	1.1
10/21/2022 03:00	11.0	13.8	9.1	152.2	3,027,210.4	1,547.4	1.7	1.1
10/21/2022 04:00	10.2	13.8	8.5	160.9	3,342,569.3	1,708.6	1.6	1.0
10/21/2022 05:00	10.2	13.8	8.5	163.8	3,346,481.9	1,710.6	1.7	1.2
10/21/2022 06:00	10.3	13.8	8.6	139.3	3,147,328.5	1,608.8	1.5	1.0
10/21/2022 07:00	10.5	13.8	8.7	156.8	3,280,358.3	1,676.8	1.6	1.0
10/21/2022 08:00	9.8	13.8	8.1	145.5	3,358,415.5	1,716.7	1.5	1.0
10/21/2022 09:00	9.5	13.8	7.9	146.9	3,366,436.4	1,720.8	1.5	1.0
10/21/2022 10:00	9.7	13.8	8.1	145.2	3,363,893.2	1,719.5	1.5	1.0
10/21/2022 11:00	9.8	13.9	8.3	141.1	3,293,270.0	1,683.4	1.4	0.8
10/21/2022 12:00	10.2	13.8	8.5	158.4	3,203,681.6	1,661.0	1.7	1.2
10/21/2022 13:00	10.7	13.8	8.9	169.8	3,150,833.3	1,633.6	1.8	1.1
10/21/2022 14:00	10.8	13.8	9.0	181.1	3,263,666.2	1,692.1	1.9	1.2
10/21/2022 15:00	11.3	13.7	9.3	156.8	3,025,463.5	1,568.6	1.8	1.1
10/21/2022 16:00	11.5	13.2	8.8	203.7	3,304,090.5	2,099.1	2.1	1.7
10/21/2022 17:00	11.4	13.2	8.7	219.2	3,285,113.7	2,183.0	2.3	2.0
10/21/2022 18:00	11.2	13.2	8.6	208.3	3,296,927.7	2,142.7	2.2	1.7
10/21/2022 19:00	11.1	13.2	8.5	211.6	3,340,758.6	2,098.0	2.2	1.7
10/21/2022 20:00	11.1	13.2	8.5	206.1	3,328,173.5	2,114.4	2.2	1.7
10/21/2022 21:00	11.1	13.2	8.5	211.3	3,309,898.7	2,175.3	2.2	1.7
10/21/2022 22:00	16.4	14.7	15.6	181.9	2,442,338.6	1,230.6	2.5	1.2
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.7	8.9	171.3	3,216,832.3	1,774.6	1.8	1.3
Minimum:	9.5	13.2	7.9	139.3	2,442,338.6	1,230.6	1.4	0.8
Maximum:	16.4	14.7	15.6	219.2	3,366,436.4	2,183.0	2.5	2.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 12:00	6.1	19.7	30.0	11.1	0.0	2.2	0.0	0.0
10/24/2022 13:00	48.3	17.0	73.1	88.9	1,508,824.8	429.7	0.0	0.0
10/24/2022 14:00	22.5	14.0	19.2	217.4	3,166,391.1	1,572.3	2.3	1.4
10/24/2022 15:00	10.4	13.7	8.5	176.1	3,369,735.0	1,771.7	1.8	1.2
10/24/2022 16:00	10.3	13.7	8.4	161.4	3,368,023.2	1,770.8	1.6	1.1
10/24/2022 17:00	10.3	13.7	8.4	169.1	3,384,950.8	1,779.7	1.7	1.2
10/24/2022 18:00	10.3	13.7	8.4	159.1	3,407,584.3	1,791.6	1.6	1.1
10/24/2022 19:00	10.4	13.7	8.5	167.9	3,422,990.4	1,799.7	1.7	1.3
10/24/2022 20:00	10.3	13.7	8.4	159.6	3,434,972.8	1,806.0	1.6	1.1
10/24/2022 21:00	10.2	13.7	8.4	164.8	3,449,998.5	1,813.9	1.6	1.1
10/24/2022 22:00	10.2	13.7	8.4	160.2	3,443,721.9	1,810.6	1.6	1.1
10/24/2022 23:00	10.1	13.7	8.3	159.0	3,466,735.9	1,822.7	1.6	1.1
Average/Sum#:	14.1	14.5	16.5	149.6	2,951,994.1	1,514.2	1.4	1.0
Minimum:	6.1	13.7	8.3	11.1	0.0	2.2	0.0	0.0
Maximum:	48.3	19.7	73.1	217.4	3,466,735.9	1,822.7	2.3	1.4
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/25/2022 00:00	9.6	13.7	7.9	148.0	3,441,249.4	1,809.3	1.5	1.1
10/25/2022 01:00	9.6	13.7	7.9	144.3	3,432,690.5	1,804.8	1.4	0.9
10/25/2022 02:00	9.5	13.7	7.8	144.3	3,480,266.7	1,804.4	1.4	0.9
10/25/2022 03:00	9.4	13.7	7.7	145.0	3,476,409.2	1,802.4	1.4	0.9
10/25/2022 04:00	9.4	13.7	7.7	143.6	3,481,424.0	1,805.0	1.4	0.9
10/25/2022 05:00	9.4	13.7	7.7	153.5	3,487,403.1	1,808.1	1.5	1.1
10/25/2022 06:00	9.7	13.7	7.9	144.2	3,487,596.0	1,808.2	1.4	0.9
10/25/2022 07:00	9.8	13.7	8.0	154.5	3,486,631.6	1,807.7	1.5	1.1
10/25/2022 08:00	9.9	13.7	8.1	153.4	3,446,574.9	1,812.1	1.5	1.1
10/25/2022 09:00	10.2	13.6	8.2	162.1	3,453,802.4	1,815.9	1.6	1.1
10/25/2022 10:00	10.2	13.6	8.2	160.9	3,451,710.2	1,814.8	1.6	1.1
10/25/2022 11:00	10.2	13.6	8.2	174.6	3,480,049.7	1,829.7	1.7	1.3
10/25/2022 12:00	10.3	13.6	8.3	166.6	3,484,994.9	1,832.3	1.6	1.1
10/25/2022 13:00	10.5	13.6	8.5	175.0	3,445,321.7	1,836.6	1.7	1.3
10/25/2022 14:00	10.6	13.6	8.6	178.5	3,435,942.1	1,831.6	1.8	1.3
10/25/2022 15:00	10.5	13.6	8.5	172.1	3,437,442.8	1,832.4	1.7	1.3
10/25/2022 16:00	10.5	13.6	8.5	169.9	3,434,816.5	1,831.0	1.7	1.3
10/25/2022 17:00	10.5	13.6	8.5	175.8	3,440,819.5	1,834.2	1.8	1.3
10/25/2022 18:00	10.3	13.6	8.3	162.5	3,473,202.6	1,826.1	1.6	1.1
10/25/2022 19:00	10.1	13.6	8.2	162.3	3,451,710.2	1,814.8	1.6	1.1
10/25/2022 20:00	10.2	13.6	8.2	165.7	3,438,016.0	1,807.6	1.7	1.3
10/25/2022 21:00	9.9	13.7	8.1	152.5	3,442,200.3	1,809.8	1.5	1.1
10/25/2022 22:00	9.8	13.7	8.0	149.1	3,432,119.9	1,804.5	1.5	1.1
10/25/2022 23:00	10.7	13.8	8.9	147.5	3,199,562.3	1,635.5	1.6	1.0
Average/Sum#:	10.0	13.7	8.2	158.6	3,446,748.2	1,809.1	1.6	1.1
Minimum:	9.4	13.6	7.7	143.6	3,199,562.3	1,635.5	1.4	0.9
Maximum:	10.7	13.8	8.9	178.5	3,487,596.0	1,836.6	1.8	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/26/2022 00:00	10.6	13.8	8.8	150.1	3,145,625.7	1,630.9	1.6	1.0
10/26/2022 01:00	10.5	13.8	8.7	143.7	3,192,519.5	1,631.9	1.5	1.0
10/26/2022 02:00	10.6	13.8	8.8	150.2	3,186,650.5	1,628.9	1.6	1.0
10/26/2022 03:00	10.6	13.8	8.8	149.1	3,162,196.5	1,616.4	1.6	1.0
10/26/2022 04:00	9.5	13.7	7.8	144.8	3,461,364.8	1,794.6	1.4	0.9
10/26/2022 05:00	9.8	13.8	8.1	156.9	3,391,868.6	1,733.8	1.6	1.0
10/26/2022 06:00	10.4	13.8	8.6	149.4	3,309,703.1	1,691.8	1.5	1.0
10/26/2022 07:00	9.8	13.8	8.1	138.6	3,361,261.8	1,742.7	1.4	0.9
10/26/2022 08:00	22.9	15.8	26.5	182.1	1,830,546.9	735.2	3.2	0.9
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	33.0	17.9	64.9	10.2	1,264,610.7	240.1	0.0	0.0
10/26/2022 17:00	42.6	17.3	69.8	56.4	1,625,050.3	391.6	0.0	0.0
10/26/2022 18:00	52.9	15.3	55.7	266.8	2,061,606.2	828.0	4.2	1.3
10/26/2022 19:00	10.3	13.6	8.3	193.7	3,471,300.6	1,825.1	1.9	1.3
10/26/2022 20:00	9.9	13.7	8.1	170.6	3,462,171.1	1,820.3	1.7	1.3
10/26/2022 21:00	10.2	13.7	8.4	170.5	3,442,961.1	1,810.2	1.7	1.3
10/26/2022 22:00	10.6	13.7	8.7	160.8	3,356,040.7	1,764.5	1.6	1.1
10/26/2022 23:00	15.1	14.5	13.9	135.5	2,490,640.6	1,164.0	1.8	0.8
Average/Sum#:	17.0	14.5	19.5	148.8	2,895,065.8	1,414.7	1.7	0.9
Minimum:	9.5	13.6	7.8	10.2	1,264,610.7	240.1	0.0	0.0
Maximum:	52.9	17.9	69.8	266.8	3,471,300.6	1,825.1	4.2	1.3
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/31/2022 01:00	35.5	17.5	61.6	31.7	1,280,839.7	299.3	0.0	0.0
10/31/2022 02:00	44.6	15.9	52.6	265.1	2,026,189.1	725.0	4.1	1.2
10/31/2022 03:00	10.2	13.8	8.5	169.6	3,303,205.9	1,712.6	1.8	1.2
10/31/2022 04:00	10.3	13.8	8.6	165.3	3,329,630.0	1,726.3	1.7	1.2
10/31/2022 05:00	10.6	13.8	8.8	182.2	3,300,698.5	1,711.3	1.9	1.2
10/31/2022 06:00	10.9	13.8	9.1	159.1	3,265,016.3	1,692.8	1.6	1.0
10/31/2022 07:00	10.9	13.8	9.1	164.8	3,266,559.3	1,693.6	1.7	1.2
10/31/2022 08:00	10.6	13.8	8.8	154.8	3,287,582.9	1,704.5	1.6	1.0
10/31/2022 09:00	10.3	13.8	8.6	151.7	3,339,047.9	1,706.8	1.5	1.0
10/31/2022 10:00	10.4	13.8	8.6	161.5	3,342,178.0	1,708.4	1.6	1.0
10/31/2022 11:00	10.2	13.8	8.5	144.8	3,304,225.4	1,689.0	1.5	1.0
10/31/2022 12:00	10.0	13.9	8.4	145.0	3,302,073.5	1,687.9	1.5	1.0
10/31/2022 13:00	9.8	13.9	8.3	143.4	3,331,222.6	1,702.8	1.5	1.0
10/31/2022 14:00	10.6	13.7	8.7	177.5	3,362,127.1	1,767.7	1.8	1.2
10/31/2022 15:00	11.2	13.3	8.7	191.8	3,394,868.3	2,082.4	2.0	1.7
10/31/2022 16:00	11.1	13.3	8.6	195.9	3,352,860.4	2,105.6	2.0	1.7
10/31/2022 17:00	11.0	13.3	8.5	204.1	3,345,101.0	2,076.3	2.1	1.7
10/31/2022 18:00	11.0	13.3	8.5	192.2	3,354,928.6	2,082.4	2.0	1.7
10/31/2022 19:00	11.0	13.3	8.5	209.0	3,389,083.7	2,103.6	2.1	1.7
10/31/2022 20:00	10.6	13.3	8.2	184.1	3,365,561.8	2,089.0	1.9	1.5
10/31/2022 21:00	10.6	13.3	8.2	194.4	3,353,200.9	2,130.3	2.0	1.7
10/31/2022 22:00	10.4	13.3	8.1	194.5	3,338,688.5	2,096.7	2.0	1.7
10/31/2022 23:00	10.6	13.3	8.2	203.5	3,363,589.6	2,136.9	2.1	1.7
Average/Sum#:	13.1	13.9	12.8	173.3	3,186,890.4	1,757.9	1.8	1.3
Minimum:	9.8	13.3	8.1	31.7	1,280,839.7	299.3	0.0	0.0
Maximum:	44.6	17.5	61.6	265.1	3,394,868.3	2,136.9	4.1	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/01/2022 00:00	10.5	13.3	8.2	196.6	3,390,820.7	2,154.2	2.0	1.7
11/01/2022 01:00	10.5	13.3	8.2	196.4	3,384,681.9	2,150.3	2.0	1.7
11/01/2022 02:00	10.6	13.2	8.1	204.9	3,397,589.1	2,158.5	2.1	1.7
11/01/2022 03:00	10.7	13.2	8.2	195.3	3,412,227.8	2,167.8	2.0	1.7
11/01/2022 04:00	10.6	13.2	8.1	201.4	3,424,820.2	2,175.8	2.0	1.7
11/01/2022 05:00	10.7	13.2	8.2	193.9	3,386,835.5	2,176.4	2.0	1.7
11/01/2022 06:00	11.1	13.2	8.5	212.9	3,386,240.4	2,250.2	2.2	1.8
11/01/2022 07:00	10.8	13.2	8.3	211.6	3,365,398.9	2,187.2	2.2	1.7
11/01/2022 08:00	10.9	13.1	8.2	215.3	3,334,548.4	2,240.2	2.3	2.0
11/01/2022 09:00	10.7	13.2	8.2	194.4	3,335,256.7	2,118.9	2.0	1.7
11/01/2022 10:00	10.6	13.2	8.1	196.5	3,380,567.4	2,123.0	2.0	1.7
11/01/2022 11:00	10.7	13.2	8.2	208.0	3,359,705.8	2,183.5	2.2	1.7
11/01/2022 12:00	10.7	13.2	8.2	205.2	3,331,353.1	2,189.4	2.2	1.8
11/01/2022 13:00	10.6	13.3	8.2	210.1	3,355,705.2	2,180.9	2.2	1.7
11/01/2022 14:00	10.6	13.4	8.3	202.5	3,366,850.7	2,089.8	2.1	1.7
11/01/2022 15:00	10.6	13.3	8.2	195.0	3,443,524.9	2,087.1	2.0	1.7
11/01/2022 16:00	10.7	13.3	8.3	215.2	3,430,096.8	2,204.2	2.2	1.8
11/01/2022 17:00	10.5	13.2	8.0	221.4	3,378,060.7	2,294.1	2.3	2.1
11/01/2022 18:00	10.3	13.3	8.0	204.1	3,402,708.4	2,186.6	2.1	1.7
11/01/2022 19:00	10.3	13.3	8.0	200.0	3,452,541.8	2,168.2	2.0	1.7
11/01/2022 20:00	10.4	13.3	8.1	212.0	3,437,877.7	2,209.2	2.2	1.8
11/01/2022 21:00	10.3	13.3	8.0	181.6	3,444,349.8	2,087.6	1.8	1.5
11/01/2022 22:00	10.1	13.4	7.9	179.0	3,465,478.7	2,075.1	1.8	1.5
11/01/2022 23:00	9.6	13.7	7.9	163.9	3,332,025.8	1,849.2	1.7	1.3
Average/Sum#:	10.5	13.3	8.2	200.7	3,391,636.1	2,154.5	2.1	1.7
Minimum:	9.6	13.1	7.9	163.9	3,331,353.1	1,849.2	1.7	1.3
Maximum:	11.1	13.7	8.5	221.4	3,465,478.7	2,294.1	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/02/2022 00:00	11.0	13.9	9.3	123.0	2,648,466.8	1,353.8	1.6	0.8
11/02/2022 01:00	10.8	13.8	9.0	158.0	3,207,387.5	1,639.5	1.7	1.1
11/02/2022 02:00	10.8	13.8	9.0	169.2	3,297,998.2	1,709.9	1.7	1.2
11/02/2022 03:00	11.2	13.9	9.4	122.7	2,648,466.8	1,353.8	1.6	0.8
11/02/2022 04:00	11.0	13.8	9.1	167.3	3,246,885.9	1,683.4	1.8	1.2
11/02/2022 05:00	9.9	13.7	8.1	166.4	3,367,203.9	1,917.9	1.7	1.3
11/02/2022 06:00	10.6	13.3	8.2	181.3	3,537,027.6	2,169.6	1.8	1.5
11/02/2022 07:00	10.2	13.3	7.9	186.6	3,555,994.3	2,129.3	1.8	1.5
11/02/2022 08:00	10.1	13.5	8.1	177.7	3,473,031.4	2,028.9	1.8	1.4
11/02/2022 09:00	10.4	13.8	8.6	164.2	3,316,321.5	1,719.4	1.7	1.2
11/02/2022 10:00	11.1	13.8	9.2	146.4	3,031,905.6	1,549.8	1.6	0.9
11/02/2022 11:00	10.8	13.8	9.0	164.9	3,283,879.7	1,678.6	1.7	1.2
11/02/2022 12:00	10.8	13.8	9.0	145.2	3,049,121.2	1,558.6	1.6	0.9
11/02/2022 13:00	10.6	13.8	8.8	139.8	3,056,555.2	1,562.4	1.5	0.9
11/02/2022 14:00	10.7	13.8	8.9	138.9	3,020,950.2	1,544.2	1.5	0.9
11/02/2022 15:00	10.5	13.8	8.7	154.2	3,154,958.1	1,612.7	1.7	1.1
11/02/2022 16:00	10.4	13.4	8.2	177.8	3,433,130.4	2,080.8	1.8	1.5
11/02/2022 17:00	10.4	13.3	8.1	196.5	3,459,229.7	2,172.4	2.0	1.7
11/02/2022 18:00	10.3	13.3	8.0	191.8	3,487,682.2	2,164.8	1.9	1.5
11/02/2022 19:00	10.4	13.3	8.1	190.0	3,488,326.7	2,165.2	1.9	1.5
11/02/2022 20:00	10.4	13.3	8.1	195.8	3,490,904.4	2,166.8	1.9	1.5
11/02/2022 21:00	10.4	13.3	8.1	193.3	3,509,802.1	2,152.9	1.9	1.5
11/02/2022 22:00	10.3	13.3	8.0	186.5	3,485,426.7	2,163.4	1.9	1.5
11/02/2022 23:00	10.4	13.3	8.1	194.8	3,506,209.7	2,176.3	1.9	1.5
Average/Sum#:	10.6	13.6	8.5	168.0	3,281,536.1	1,852.3	1.8	1.3
Minimum:	9.9	13.3	7.9	122.7	2,648,466.8	1,353.8	1.5	0.8
Maximum:	11.2	13.9	9.4	196.5	3,555,994.3	2,176.3	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/03/2022 00:00	10.4	13.3	8.1	195.4	3,492,354.4	2,167.7	1.9	1.5
11/03/2022 01:00	10.3	13.3	8.0	186.0	3,510,780.3	2,153.5	1.8	1.5
11/03/2022 02:00	10.2	13.3	7.9	194.0	3,502,701.0	2,199.7	1.9	1.5
11/03/2022 03:00	10.3	13.3	8.0	211.8	3,490,476.0	2,243.0	2.1	1.8
11/03/2022 04:00	10.1	13.3	7.8	191.3	3,496,543.2	2,170.3	1.9	1.5
11/03/2022 05:00	10.2	13.3	7.9	228.1	3,504,920.9	2,175.5	2.3	2.0
11/03/2022 06:00	10.6	13.3	8.2	208.9	3,496,389.4	2,246.8	2.1	1.8
11/03/2022 07:00	10.3	13.4	8.1	190.2	3,494,012.1	2,117.7	1.9	1.5
11/03/2022 08:00	10.6	13.9	8.9	127.9	2,858,575.6	1,461.2	1.5	0.9
11/03/2022 09:00	10.9	13.8	9.1	151.3	3,066,532.5	1,567.5	1.7	1.1
11/03/2022 10:00	10.8	13.8	9.0	150.8	3,094,312.2	1,581.7	1.7	1.1
11/03/2022 11:00	10.8	13.8	9.0	143.5	3,082,574.3	1,575.7	1.6	0.9
11/03/2022 12:00	10.8	13.8	9.0	144.3	3,105,854.5	1,587.6	1.6	1.0
11/03/2022 13:00	10.8	13.9	9.1	138.1	2,928,220.6	1,496.8	1.6	0.9
11/03/2022 14:00	10.7	13.9	9.0	143.9	3,060,076.6	1,564.2	1.6	0.9
11/03/2022 15:00	10.0	13.8	8.3	157.7	3,447,091.9	1,787.2	1.6	1.1
11/03/2022 16:00	10.6	13.4	8.3	188.2	3,476,667.9	2,081.8	1.9	1.5
11/03/2022 17:00	10.5	13.4	8.3	194.1	3,483,815.6	2,162.4	1.9	1.5
11/03/2022 18:00	10.5	13.3	8.2	208.9	3,468,465.3	2,178.2	2.1	1.7
11/03/2022 19:00	10.5	13.3	8.2	211.9	3,464,962.2	2,176.0	2.1	1.7
11/03/2022 20:00	10.4	13.3	8.1	199.9	3,446,172.4	2,164.2	2.0	1.7
11/03/2022 21:00	10.4	13.3	8.1	211.2	3,445,694.7	2,163.9	2.1	1.7
11/03/2022 22:00	10.4	13.4	8.2	210.6	3,444,739.3	2,163.3	2.1	1.7
11/03/2022 23:00	10.2	13.3	7.9	203.6	3,455,617.9	2,220.6	2.1	1.8
Average/Sum#:	10.5	13.5	8.4	183.0	3,346,564.6	1,975.3	1.9	1.4
Minimum:	10.0	13.3	7.8	127.9	2,858,575.6	1,461.2	1.5	0.9
Maximum:	10.9	13.9	9.1	228.1	3,510,780.3	2,246.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/04/2022 00:00	10.0	13.3	7.8	197.4	3,502,465.9	2,148.4	2.0	1.7
11/04/2022 01:00	10.1	13.4	7.9	190.8	3,499,291.8	2,120.9	1.9	1.5
11/04/2022 02:00	10.1	13.4	7.9	179.7	3,500,147.3	2,070.3	1.8	1.4
11/04/2022 03:00	10.0	13.4	7.9	186.0	3,506,571.7	2,074.1	1.8	1.5
11/04/2022 04:00	10.1	13.4	7.9	195.8	3,510,128.1	2,153.1	1.9	1.5
11/04/2022 05:00	10.3	13.3	8.0	211.1	3,487,723.9	2,266.7	2.1	1.8
11/04/2022 06:00	10.5	13.3	8.2	190.4	3,524,737.3	2,187.8	1.9	1.5
11/04/2022 07:00	9.9	13.4	7.8	182.2	3,487,636.5	2,062.9	1.8	1.4
11/04/2022 08:00	10.4	13.8	8.6	163.9	3,344,095.8	1,733.8	1.7	1.2
11/04/2022 09:00	10.9	13.8	9.1	139.9	3,046,578.0	1,557.3	1.5	0.9
11/04/2022 10:00	11.3	13.9	9.5	132.3	2,731,023.5	1,396.0	1.6	0.8
11/04/2022 11:00	11.0	14.0	9.4	127.6	2,629,294.8	1,324.8	1.6	0.8
11/04/2022 12:00	10.9	14.0	9.3	128.9	2,625,325.5	1,322.8	1.7	0.9
11/04/2022 13:00	11.0	14.0	9.4	127.3	2,627,707.1	1,324.0	1.6	0.8
11/04/2022 14:00	11.3	13.9	9.5	135.4	2,748,043.5	1,404.7	1.7	1.0
11/04/2022 15:00	10.7	13.8	8.9	166.1	3,157,005.4	1,636.8	1.8	1.1
11/04/2022 16:00	10.7	13.4	8.4	182.3	3,433,460.4	2,081.0	1.8	1.5
11/04/2022 17:00	10.6	13.3	8.2	203.0	3,414,700.0	2,119.5	2.1	1.7
11/04/2022 18:00	10.5	13.4	8.3	183.9	3,436,086.2	2,057.5	1.8	1.4
11/04/2022 19:00	10.3	13.4	8.1	185.4	3,434,917.2	2,056.8	1.9	1.4
11/04/2022 20:00	10.3	13.4	8.1	189.9	3,470,561.0	2,052.8	1.9	1.4
11/04/2022 21:00	10.3	13.4	8.1	180.4	3,473,266.0	2,054.4	1.8	1.4
11/04/2022 22:00	10.3	13.4	8.1	186.7	3,474,111.3	2,054.9	1.9	1.4
11/04/2022 23:00	9.5	13.6	7.7	162.6	3,518,159.4	1,952.5	1.6	1.2
Average/Sum#:	10.5	13.6	8.4	172.0	3,274,293.2	1,883.9	1.8	1.3
Minimum:	9.5	13.3	7.7	127.3	2,625,325.5	1,322.8	1.5	0.8
Maximum:	11.3	14.0	9.5	211.1	3,524,737.3	2,266.7	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/05/2022 00:00	9.4	13.6	7.6	155.9	3,514,555.6	1,950.5	1.5	1.2
11/05/2022 01:00	9.5	13.6	7.7	162.6	3,514,375.4	1,950.4	1.6	1.2
11/05/2022 02:00	9.6	13.6	7.8	161.2	3,513,834.9	1,950.1	1.6	1.2
11/05/2022 03:00	9.5	13.6	7.7	157.1	3,515,276.4	1,950.9	1.5	1.2
11/05/2022 04:00	9.4	13.6	7.6	157.5	3,521,402.7	1,954.3	1.5	1.2
11/05/2022 05:00	9.4	13.6	7.6	169.6	3,525,547.0	1,956.6	1.7	1.4
11/05/2022 06:00	9.8	13.6	7.9	157.6	3,473,292.7	1,927.6	1.5	1.2
11/05/2022 07:00	24.6	16.2	30.9	171.4	1,523,283.2	567.3	3.6	0.8
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	23.7	18.0	48.2	0.1	1,274,868.9	195.5	0.0	0.0
11/05/2022 14:00	40.6	16.0	48.9	123.6	2,029,886.4	711.5	0.0	0.0
11/05/2022 15:00	11.4	13.8	9.5	149.1	2,810,645.7	1,436.7	1.8	1.0
11/05/2022 16:00	11.1	13.6	9.0	170.5	3,117,175.1	1,707.2	1.9	1.2
11/05/2022 17:00	10.9	13.4	8.6	196.0	3,435,521.8	1,981.9	2.0	1.6
11/05/2022 18:00	10.9	13.4	8.6	193.3	3,418,187.3	1,971.9	2.0	1.6
11/05/2022 19:00	10.9	13.4	8.6	192.3	3,418,534.0	1,972.1	1.9	1.4
11/05/2022 20:00	10.9	13.4	8.6	187.1	3,423,907.6	1,975.2	1.9	1.4
11/05/2022 21:00	11.2	13.6	9.1	154.5	3,048,819.8	1,647.5	1.7	1.2
11/05/2022 22:00	11.6	13.8	9.6	134.0	2,758,020.7	1,409.8	1.6	0.8
11/05/2022 23:00	10.8	13.7	8.9	159.0	3,189,022.9	1,653.4	1.7	1.2
Average/Sum#:	13.4	14.1	13.8	155.4	3,054,008.3	1,624.8	1.6	1.1
Minimum:	9.4	13.4	7.6	0.1	1,274,868.9	195.5	0.0	0.0
Maximum:	40.6	18.0	48.9	196.0	3,525,547.0	1,981.9	3.6	1.6
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/06/2022 00:00	11.2	13.8	9.3	150.2	3,016,784.1	1,564.1	1.7	1.1
11/06/2022 01:00	11.5	13.8	9.6	143.1	2,822,943.0	1,463.6	1.7	1.0
11/06/2022 02:00	26.9	16.9	39.7	190.9	1,124,118.8	377.6	5.6	0.8
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.5	14.8	19.5	161.4	2,321,282.0	1,135.1	3.0	1.0
Minimum:	11.2	13.8	9.3	143.1	1,124,118.8	377.6	1.7	0.8
Maximum:	26.9	16.9	39.7	190.9	3,016,784.1	1,564.1	5.6	1.1
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 03:00	34.1	17.7	62.9	0.0	1,374,315.2	281.0	0.0	0.0
11/07/2022 04:00	49.4	16.5	66.2	190.8	1,748,723.1	549.1	3.4	0.7
11/07/2022 05:00	10.3	13.7	8.4	188.6	3,278,059.6	1,723.5	2.0	1.4
11/07/2022 06:00	10.1	13.6	8.2	174.7	3,424,588.0	2,000.6	1.8	1.4
11/07/2022 07:00	10.3	13.5	8.2	216.0	3,439,589.4	2,210.3	2.2	1.8
11/07/2022 08:00	10.2	13.6	8.2	156.3	3,433,441.6	1,980.7	1.6	1.2
11/07/2022 09:00	10.0	13.5	8.0	172.7	3,404,839.7	1,964.2	1.7	1.4
11/07/2022 10:00	10.2	13.6	8.2	168.6	3,391,492.2	1,956.5	1.7	1.4
11/07/2022 11:00	10.4	13.6	8.4	181.3	3,436,904.1	1,957.6	1.8	1.4
11/07/2022 12:00	10.3	13.6	8.3	171.2	3,436,201.8	1,957.2	1.7	1.4
11/07/2022 13:00	10.0	13.7	8.2	173.8	3,442,346.7	1,960.7	1.7	1.4
11/07/2022 14:00	10.1	13.6	8.2	179.5	3,474,787.6	2,055.3	1.8	1.4
11/07/2022 15:00	10.2	13.6	8.2	203.7	3,441,032.9	2,186.1	2.1	1.7
11/07/2022 16:00	10.0	13.6	8.1	221.7	3,410,779.7	2,241.6	2.3	2.0
11/07/2022 17:00	10.1	13.5	8.1	223.3	3,426,269.7	2,276.8	2.3	2.0
11/07/2022 18:00	10.1	13.5	8.1	221.3	3,430,934.8	2,279.9	2.3	2.1
11/07/2022 19:00	10.1	13.5	8.1	228.5	3,430,182.4	2,279.4	2.3	2.1
11/07/2022 20:00	10.1	13.5	8.1	221.5	3,425,968.7	2,276.6	2.3	2.0
11/07/2022 21:00	10.1	13.5	8.1	219.3	3,420,400.7	2,272.9	2.2	1.8
11/07/2022 22:00	10.0	13.5	8.0	217.0	3,434,793.3	2,232.3	2.2	1.8
11/07/2022 23:00	10.1	13.5	8.1	203.8	3,479,143.5	2,159.5	2.0	1.7
Average/Sum#:	13.2	13.9	13.5	187.3	3,246,895.0	1,942.9	2.0	1.5
Minimum:	10.0	13.5	8.0	0.0	1,374,315.2	281.0	0.0	0.0
Maximum:	49.4	17.7	66.2	228.5	3,479,143.5	2,279.9	3.4	2.1
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/08/2022 00:00	10.1	13.5	8.1	193.6	3,466,738.1	2,151.8	1.9	1.5
11/08/2022 01:00	10.2	13.5	8.1	199.1	3,463,515.9	2,149.8	2.0	1.7
11/08/2022 02:00	10.2	13.5	8.1	196.1	3,459,034.0	2,096.5	2.0	1.7
11/08/2022 03:00	10.1	13.5	8.1	190.8	3,452,882.8	2,143.2	1.9	1.5
11/08/2022 04:00	10.1	13.5	8.1	207.7	3,432,060.8	2,180.4	2.1	1.7
11/08/2022 05:00	10.0	13.5	8.0	188.9	3,419,670.5	2,197.5	1.9	1.5
11/08/2022 06:00	10.3	13.5	8.2	216.6	3,395,279.4	2,281.0	2.2	1.8
11/08/2022 07:00	10.1	13.5	8.1	208.3	3,413,757.1	2,193.7	2.1	1.8
11/08/2022 08:00	10.1	13.5	8.1	198.5	3,400,374.1	2,185.1	2.0	1.7
11/08/2022 09:00	10.0	13.5	8.0	206.0	3,434,107.1	2,181.7	2.1	1.7
11/08/2022 10:00	10.1	13.5	8.1	203.3	3,447,764.7	2,165.2	2.1	1.7
11/08/2022 11:00	9.9	13.6	8.0	172.3	3,451,634.2	2,016.4	1.7	1.4
11/08/2022 12:00	9.9	13.6	8.0	174.4	3,462,712.5	1,972.3	1.7	1.4
11/08/2022 13:00	9.8	13.6	7.9	162.7	3,507,327.0	1,972.1	1.6	1.2
11/08/2022 14:00	10.1	13.6	8.2	184.3	3,503,672.3	2,046.8	1.8	1.4
11/08/2022 15:00	10.1	13.6	8.2	173.0	3,498,536.9	2,043.8	1.7	1.4
11/08/2022 16:00	10.2	13.5	8.1	212.0	3,466,532.6	2,202.3	2.1	1.8
11/08/2022 17:00	10.1	13.5	8.1	201.4	3,433,792.3	2,181.5	2.0	1.7
11/08/2022 18:00	10.1	13.5	8.1	192.7	3,466,577.0	2,151.7	1.9	1.5
11/08/2022 19:00	10.0	13.5	8.0	209.1	3,441,032.9	2,186.1	2.1	1.7
11/08/2022 20:00	10.1	13.5	8.1	205.1	3,454,255.0	2,194.5	2.1	1.8
11/08/2022 21:00	10.1	13.5	8.1	202.6	3,456,458.6	2,195.9	2.0	1.8
11/08/2022 22:00	10.1	13.5	8.1	209.0	3,431,588.6	2,180.1	2.1	1.7
11/08/2022 23:00	10.1	13.5	8.1	194.2	3,443,216.2	2,137.2	2.0	1.7
Average/Sum#:	10.1	13.5	8.1	195.9	3,450,105.0	2,141.9	2.0	1.6
Minimum:	9.8	13.5	7.9	162.7	3,395,279.4	1,972.1	1.6	1.2
Maximum:	10.3	13.6	8.2	216.6	3,507,327.0	2,281.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/09/2022 00:00	10.0	13.5	8.0	194.5	3,459,166.0	2,147.1	2.0	1.7
11/09/2022 01:00	9.9	13.5	7.9	200.1	3,459,004.9	2,147.0	2.0	1.7
11/09/2022 02:00	9.9	13.5	7.9	197.1	3,479,134.1	2,184.9	2.0	1.7
11/09/2022 03:00	9.9	13.5	7.9	201.1	3,482,478.1	2,187.0	2.0	1.7
11/09/2022 04:00	10.0	13.5	8.0	199.9	3,512,084.5	2,154.3	2.0	1.7
11/09/2022 05:00	10.0	13.5	8.0	188.4	3,417,778.9	2,246.2	1.9	1.6
11/09/2022 06:00	10.3	13.5	8.2	212.2	3,475,751.2	2,284.3	2.1	1.8
11/09/2022 07:00	10.1	13.5	8.1	205.2	3,519,904.0	2,184.8	2.0	1.7
11/09/2022 08:00	10.0	13.5	8.0	194.7	3,501,161.7	2,147.6	1.9	1.5
11/09/2022 09:00	10.6	13.8	8.8	183.3	3,349,003.4	1,760.8	1.9	1.2
11/09/2022 10:00	11.0	13.8	9.1	179.6	3,375,044.2	1,725.2	1.8	1.2
11/09/2022 11:00	11.1	13.8	9.2	166.6	3,210,322.0	1,641.0	1.8	1.1
11/09/2022 12:00	10.9	13.8	9.1	176.5	3,357,633.0	1,716.3	1.8	1.2
11/09/2022 13:00	11.1	13.8	9.2	163.8	3,179,020.9	1,625.0	1.8	1.1
11/09/2022 14:00	11.0	13.8	9.1	172.9	3,321,832.3	1,698.0	1.8	1.2
11/09/2022 15:00	10.4	13.8	8.6	149.1	3,218,929.8	1,645.4	1.6	1.0
11/09/2022 16:00	10.4	13.4	8.2	182.6	3,506,740.8	2,074.2	1.8	1.5
11/09/2022 17:00	10.6	13.3	8.2	192.3	3,510,780.3	2,153.5	1.9	1.5
11/09/2022 18:00	10.0	13.5	8.0	180.0	3,528,725.7	2,009.9	1.8	1.4
11/09/2022 19:00	9.9	13.6	8.0	166.9	3,555,097.8	1,973.0	1.6	1.2
11/09/2022 20:00	9.9	13.6	8.0	175.1	3,561,764.7	1,976.7	1.7	1.4
11/09/2022 21:00	10.0	13.6	8.1	167.7	3,582,666.5	1,988.3	1.6	1.2
11/09/2022 22:00	9.9	13.6	8.0	176.9	3,566,089.2	1,979.1	1.7	1.4
11/09/2022 23:00	9.9	13.6	8.0	165.0	3,563,206.2	1,977.5	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	183.0	3,445,555.0	1,984.5	1.8	1.4
Minimum:	9.9	13.3	7.9	149.1	3,179,020.9	1,625.0	1.6	1.0
Maximum:	11.1	13.8	9.2	212.2	3,582,666.5	2,284.3	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/10/2022 00:00	10.0	13.6	8.1	178.4	3,562,845.8	1,977.3	1.7	1.4
11/10/2022 01:00	9.9	13.6	8.0	167.1	3,559,602.5	1,975.5	1.6	1.2
11/10/2022 02:00	9.9	13.6	8.0	177.6	3,557,620.4	1,974.4	1.7	1.4
11/10/2022 03:00	9.8	13.6	7.9	165.1	3,563,026.0	1,977.4	1.6	1.2
11/10/2022 04:00	10.3	13.4	8.1	189.4	3,549,205.6	2,073.4	1.8	1.5
11/10/2022 05:00	10.5	13.4	8.3	182.6	3,463,051.3	2,174.8	1.8	1.5
11/10/2022 06:00	11.0	13.2	8.4	213.9	3,538,654.2	2,299.8	2.1	1.8
11/10/2022 07:00	10.2	13.4	8.0	192.9	3,524,597.8	2,110.5	1.9	1.5
11/10/2022 08:00	9.7	13.7	7.9	162.6	3,544,827.1	1,967.3	1.6	1.2
11/10/2022 09:00	9.6	13.6	7.8	166.8	3,510,951.9	1,948.5	1.6	1.2
11/10/2022 10:00	10.5	13.8	8.7	169.3	3,396,563.7	1,736.2	1.7	1.2
11/10/2022 11:00	10.3	13.9	8.7	161.6	3,380,717.5	1,728.1	1.6	1.0
11/10/2022 12:00	10.2	13.9	8.6	162.3	3,354,894.1	1,714.9	1.6	1.0
11/10/2022 13:00	10.7	13.9	9.0	144.5	3,117,127.4	1,570.6	1.6	0.9
11/10/2022 14:00	10.0	13.9	8.4	152.0	3,373,087.9	1,724.2	1.5	1.0
11/10/2022 15:00	10.2	13.8	8.5	156.3	3,370,935.9	1,723.1	1.6	1.0
11/10/2022 16:00	10.4	13.4	8.2	195.7	3,508,531.3	2,126.5	1.9	1.5
11/10/2022 17:00	10.6	13.3	8.2	217.4	3,456,883.6	2,271.9	2.2	1.8
11/10/2022 18:00	10.4	13.3	8.1	219.1	3,460,991.9	2,274.6	2.2	1.8
11/10/2022 19:00	10.4	13.3	8.1	225.8	3,466,926.1	2,278.5	2.3	2.1
11/10/2022 20:00	10.4	13.3	8.1	218.2	3,467,382.5	2,278.8	2.2	1.8
11/10/2022 21:00	10.4	13.3	8.1	219.0	3,471,795.1	2,281.7	2.2	1.8
11/10/2022 22:00	10.3	13.3	8.0	225.3	3,471,034.3	2,281.2	2.3	2.1
11/10/2022 23:00	10.3	13.3	8.0	209.4	3,471,875.5	2,256.4	2.1	1.8
Average/Sum#:	10.3	13.5	8.2	186.3	3,464,297.1	2,030.2	1.9	1.4
Minimum:	9.6	13.2	7.8	144.5	3,117,127.4	1,570.6	1.5	0.9
Maximum:	11.0	13.9	9.0	225.8	3,563,026.0	2,299.8	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/11/2022 00:00	10.3	13.3	8.0	223.0	3,510,957.9	2,281.8	2.2	1.8
11/11/2022 01:00	10.3	13.3	8.0	221.4	3,501,725.9	2,275.8	2.2	1.8
11/11/2022 02:00	10.2	13.4	8.0	187.4	3,539,219.6	2,145.1	1.8	1.5
11/11/2022 03:00	10.3	13.4	8.1	194.3	3,535,259.8	2,142.7	1.9	1.5
11/11/2022 04:00	10.5	13.3	8.2	218.9	3,534,982.3	2,271.6	2.2	1.8
11/11/2022 05:00	10.3	13.3	8.0	198.5	3,516,189.4	2,285.2	2.0	1.8
11/11/2022 06:00	10.6	13.3	8.2	212.4	3,514,496.9	2,284.1	2.1	1.8
11/11/2022 07:00	10.0	13.5	8.0	188.3	3,520,756.7	2,108.2	1.9	1.5
11/11/2022 08:00	9.6	13.7	7.9	162.4	3,495,996.3	1,940.2	1.6	1.2
11/11/2022 09:00	10.5	13.8	8.7	170.2	3,361,154.3	1,718.1	1.7	1.2
11/11/2022 10:00	10.5	13.8	8.7	164.3	3,372,696.6	1,724.0	1.7	1.2
11/11/2022 11:00	10.6	13.8	8.8	163.0	3,304,029.8	1,688.9	1.7	1.2
11/11/2022 12:00	10.6	13.8	8.8	167.3	3,301,290.9	1,687.5	1.7	1.2
11/11/2022 13:00	10.4	13.8	8.6	164.9	3,327,114.4	1,700.7	1.7	1.2
11/11/2022 14:00	10.8	13.9	9.1	148.5	3,095,486.0	1,582.3	1.6	0.9
11/11/2022 15:00	10.2	13.8	8.5	155.4	3,303,442.9	1,688.6	1.6	1.0
11/11/2022 16:00	10.2	13.5	8.1	171.8	3,431,881.5	1,979.8	1.7	1.4
11/11/2022 17:00	10.7	13.2	8.2	228.1	3,421,002.7	2,273.3	2.3	2.0
11/11/2022 18:00	10.6	13.2	8.1	218.7	3,448,058.4	2,266.1	2.2	1.8
11/11/2022 19:00	10.5	13.2	8.0	219.6	3,429,799.4	2,254.1	2.2	1.8
11/11/2022 20:00	10.5	13.2	8.0	225.9	3,424,778.2	2,250.8	2.3	2.0
11/11/2022 21:00	10.4	13.2	8.0	217.1	3,422,343.7	2,249.2	2.2	1.8
11/11/2022 22:00	10.3	13.3	8.0	213.5	3,490,942.9	2,243.3	2.1	1.8
11/11/2022 23:00	10.4	13.2	8.0	221.7	3,478,799.5	2,260.9	2.2	1.8
Average/Sum#:	10.4	13.5	8.3	194.0	3,428,433.6	2,054.3	2.0	1.5
Minimum:	9.6	13.2	7.9	148.5	3,095,486.0	1,582.3	1.6	0.9
Maximum:	10.8	13.9	9.1	228.1	3,539,219.6	2,285.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/12/2022 00:00	10.3	13.2	7.9	216.7	3,485,415.9	2,265.2	2.2	1.8
11/12/2022 01:00	10.3	13.2	7.9	208.8	3,490,955.1	2,268.8	2.1	1.8
11/12/2022 02:00	10.3	13.2	7.9	218.5	3,500,956.5	2,275.3	2.2	1.8
11/12/2022 03:00	10.4	13.2	8.0	221.1	3,506,341.9	2,278.8	2.2	1.8
11/12/2022 04:00	10.4	13.2	8.0	212.3	3,516,343.3	2,285.3	2.1	1.8
11/12/2022 05:00	10.5	13.2	8.0	227.9	3,518,343.6	2,286.6	2.3	2.1
11/12/2022 06:00	10.8	13.2	8.3	212.8	3,503,726.1	2,277.1	2.1	1.8
11/12/2022 07:00	10.4	13.3	8.1	197.3	3,539,628.0	2,119.5	1.9	1.5
11/12/2022 08:00	10.5	13.3	8.2	206.7	3,456,930.8	2,196.2	2.1	1.8
11/12/2022 09:00	10.0	13.8	8.3	168.8	3,339,493.5	1,755.8	1.7	1.2
11/12/2022 10:00	10.8	13.8	9.0	152.1	3,123,852.7	1,596.8	1.6	1.0
11/12/2022 11:00	10.8	13.8	9.0	144.6	3,047,751.8	1,557.9	1.6	0.9
11/12/2022 12:00	10.9	13.8	9.1	151.8	3,046,382.4	1,557.2	1.7	1.1
11/12/2022 13:00	10.8	13.9	9.1	152.3	3,092,747.2	1,580.9	1.7	1.1
11/12/2022 14:00	10.8	13.9	9.1	144.2	3,047,556.2	1,557.8	1.6	0.9
11/12/2022 15:00	9.8	13.8	8.1	160.0	3,458,471.6	1,793.1	1.6	1.1
11/12/2022 16:00	10.4	13.4	8.2	195.8	3,482,576.6	2,136.2	1.9	1.5
11/12/2022 17:00	10.6	13.2	8.1	219.3	3,445,531.9	2,289.6	2.2	1.8
11/12/2022 18:00	10.5	13.2	8.0	223.2	3,443,726.1	2,288.4	2.3	2.1
11/12/2022 19:00	10.5	13.2	8.0	227.9	3,452,454.3	2,294.2	2.3	2.1
11/12/2022 20:00	10.5	13.2	8.0	218.0	3,468,405.8	2,304.8	2.2	1.8
11/12/2022 21:00	10.5	13.2	8.0	228.5	3,462,085.4	2,300.6	2.3	2.1
11/12/2022 22:00	10.3	13.3	8.0	205.4	3,498,560.8	2,197.1	2.0	1.8
11/12/2022 23:00	10.3	13.3	8.0	202.5	3,491,554.5	2,192.7	2.0	1.8
Average/Sum#:	10.5	13.4	8.3	196.5	3,392,491.3	2,069.0	2.0	1.6
Minimum:	9.8	13.2	7.9	144.2	3,046,382.4	1,557.2	1.6	0.9
Maximum:	10.9	13.9	9.1	228.5	3,539,628.0	2,304.8	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/13/2022 00:00	10.4	13.3	8.1	204.8	3,517,004.0	2,183.0	2.0	1.7
11/13/2022 01:00	10.4	13.3	8.1	200.2	3,495,093.2	2,169.4	2.0	1.7
11/13/2022 02:00	10.4	13.3	8.1	195.4	3,524,963.6	2,162.2	1.9	1.5
11/13/2022 03:00	10.5	13.3	8.2	211.3	3,500,471.7	2,198.3	2.1	1.8
11/13/2022 04:00	10.4	13.3	8.1	204.9	3,532,309.4	2,192.5	2.0	1.8
11/13/2022 05:00	10.4	13.3	8.1	227.8	3,520,387.3	2,185.1	2.3	2.0
11/13/2022 06:00	10.8	13.3	8.4	209.5	3,505,567.2	2,201.5	2.1	1.8
11/13/2022 07:00	10.7	13.3	8.3	214.9	3,491,416.7	2,269.1	2.1	1.8
11/13/2022 08:00	10.1	13.5	8.1	187.4	3,377,000.5	1,972.8	1.9	1.4
11/13/2022 09:00	10.5	13.8	8.7	166.9	3,352,350.9	1,713.6	1.7	1.2
11/13/2022 10:00	10.5	13.8	8.7	168.7	3,354,111.6	1,714.5	1.7	1.2
11/13/2022 11:00	10.4	13.9	8.8	160.7	3,353,720.3	1,714.3	1.6	1.0
11/13/2022 12:00	10.3	13.9	8.7	156.6	3,349,807.7	1,712.3	1.6	1.0
11/13/2022 13:00	10.1	13.9	8.5	153.9	3,401,531.1	1,713.9	1.5	1.0
11/13/2022 14:00	10.2	13.9	8.6	156.5	3,347,944.9	1,686.9	1.6	1.0
11/13/2022 15:00	9.9	13.8	8.2	160.4	3,466,958.2	1,797.5	1.6	1.1
11/13/2022 16:00	10.7	13.4	8.4	189.5	3,518,100.7	2,132.3	1.9	1.5
11/13/2022 17:00	10.7	13.2	8.2	213.4	3,498,648.5	2,273.8	2.1	1.8
11/13/2022 18:00	10.6	13.2	8.1	224.1	3,498,186.9	2,273.5	2.2	1.8
11/13/2022 19:00	10.6	13.2	8.1	215.0	3,504,033.9	2,277.3	2.1	1.8
11/13/2022 20:00	10.5	13.2	8.0	222.1	3,508,188.3	2,280.0	2.2	1.8
11/13/2022 21:00	10.5	13.2	8.0	218.6	3,515,727.8	2,284.9	2.2	1.8
11/13/2022 22:00	10.5	13.2	8.0	221.0	3,519,266.8	2,287.2	2.2	1.8
11/13/2022 23:00	10.8	13.2	8.3	224.6	3,529,729.8	2,294.0	2.2	1.8
Average/Sum#:	10.5	13.4	8.3	196.2	3,465,938.4	2,070.4	2.0	1.5
Minimum:	9.9	13.2	8.0	153.9	3,347,944.9	1,686.9	1.5	1.0
Maximum:	10.8	13.9	8.8	227.8	3,532,309.4	2,294.0	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/14/2022 00:00	10.4	13.2	8.0	219.4	3,561,125.9	2,288.4	2.2	1.8
11/14/2022 01:00	10.3	13.2	7.9	211.9	3,544,319.3	2,277.6	2.1	1.8
11/14/2022 02:00	10.3	13.2	7.9	208.5	3,566,170.0	2,265.6	2.0	1.8
11/14/2022 03:00	10.1	13.3	7.8	192.4	3,589,728.9	2,149.5	1.9	1.5
11/14/2022 04:00	10.3	13.2	7.9	205.0	3,593,691.8	2,230.6	2.0	1.8
11/14/2022 05:00	10.6	13.2	8.1	228.5	3,607,410.1	2,291.8	2.2	1.8
11/14/2022 06:00	10.7	13.2	8.2	214.2	3,599,067.6	2,286.5	2.1	1.8
11/14/2022 07:00	10.3	13.3	8.0	193.1	3,603,566.0	2,184.1	1.9	1.5
11/14/2022 08:00	10.3	13.3	8.0	184.7	3,579,207.7	2,143.2	1.8	1.5
11/14/2022 09:00	10.3	13.3	8.0	198.4	3,546,479.2	2,149.5	1.9	1.5
11/14/2022 10:00	10.4	13.3	8.1	192.5	3,533,114.9	2,141.4	1.9	1.5
11/14/2022 11:00	10.4	13.3	8.1	188.0	3,535,118.9	2,116.8	1.8	1.5
11/14/2022 12:00	10.4	13.4	8.2	195.0	3,517,249.6	2,106.1	1.9	1.5
11/14/2022 13:00	10.4	13.4	8.2	196.8	3,484,043.9	2,137.1	2.0	1.7
11/14/2022 14:00	10.4	13.4	8.2	196.4	3,484,533.0	2,137.4	2.0	1.7
11/14/2022 15:00	10.3	13.4	8.1	192.3	3,487,298.4	2,062.7	1.9	1.4
11/14/2022 16:00	10.6	13.3	8.2	209.6	3,469,934.6	2,229.8	2.1	1.8
11/14/2022 17:00	10.4	13.3	8.1	208.9	3,466,713.8	2,177.1	2.1	1.7
11/14/2022 18:00	10.4	13.3	8.1	201.1	3,519,909.7	2,159.1	2.0	1.7
11/14/2022 19:00	10.6	13.2	8.1	215.3	3,525,178.5	2,265.3	2.1	1.8
11/14/2022 20:00	10.5	13.2	8.0	224.5	3,510,188.6	2,281.3	2.2	1.8
11/14/2022 21:00	10.4	13.2	8.0	216.6	3,510,861.8	2,256.1	2.2	1.8
11/14/2022 22:00	10.4	13.2	8.0	210.2	3,516,464.0	2,259.7	2.1	1.8
11/14/2022 23:00	10.4	13.2	8.0	213.7	3,525,087.3	2,239.5	2.1	1.8
Average/Sum#:	10.4	13.3	8.1	204.9	3,536,519.3	2,201.5	2.0	1.7
Minimum:	10.1	13.2	7.8	184.7	3,466,713.8	2,062.7	1.8	1.4
Maximum:	10.7	13.4	8.2	228.5	3,607,410.1	2,291.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/15/2022 00:00	10.5	13.2	8.0	222.8	3,524,711.6	2,265.0	2.2	1.8
11/15/2022 01:00	10.5	13.2	8.0	212.4	3,529,380.1	2,268.0	2.1	1.8
11/15/2022 02:00	10.5	13.2	8.0	225.5	3,518,343.6	2,286.6	2.2	1.8
11/15/2022 03:00	10.5	13.2	8.0	223.2	3,532,807.2	2,296.0	2.2	1.8
11/15/2022 04:00	10.5	13.2	8.0	222.4	3,538,654.2	2,299.8	2.2	1.8
11/15/2022 05:00	10.6	13.2	8.1	214.1	3,471,937.4	2,332.5	2.2	1.9
11/15/2022 06:00	10.7	13.3	8.3	210.1	3,467,004.8	2,202.6	2.1	1.8
11/15/2022 07:00	10.7	13.2	8.2	221.5	3,496,095.3	2,323.2	2.2	1.9
11/15/2022 08:00	10.6	13.3	8.2	219.3	3,438,486.1	2,234.7	2.2	1.8
11/15/2022 09:00	10.4	13.4	8.2	198.9	3,487,907.4	2,114.0	2.0	1.7
11/15/2022 10:00	10.5	13.4	8.3	214.0	3,481,761.5	2,135.7	2.1	1.7
11/15/2022 11:00	10.1	13.5	8.1	184.5	3,487,410.4	2,037.3	1.8	1.4
11/15/2022 12:00	9.8	13.6	7.9	169.3	3,533,655.5	1,961.1	1.6	1.2
11/15/2022 13:00	9.9	13.6	8.0	257.6	3,544,827.1	1,967.3	2.6	2.0
11/15/2022 14:00	0.0	0.0	0.0	215.4	1,293,287.0	1,973.8	6.3	4.7
11/15/2022 15:00	10.5	13.4	8.3	145.1	1,315,040.5	2,007.0	4.0	3.0
11/15/2022 16:00	10.5	13.3	8.2	204.6	3,456,329.3	2,120.1	2.1	1.7
11/15/2022 17:00	10.4	13.3	8.1	199.3	3,437,738.5	2,133.8	2.0	1.7
11/15/2022 18:00	10.6	13.4	8.3	201.8	3,420,338.8	2,123.0	2.1	1.7
11/15/2022 19:00	10.7	13.4	8.4	208.4	3,403,019.6	2,137.1	2.1	1.7
11/15/2022 20:00	10.6	13.4	8.3	214.0	3,423,875.8	2,175.2	2.2	1.7
11/15/2022 21:00	10.5	13.3	8.2	222.1	3,404,389.0	2,237.4	2.3	2.0
11/15/2022 22:00	10.4	13.4	8.2	210.5	3,422,127.8	2,149.1	2.2	1.7
11/15/2022 23:00	10.4	13.4	8.2	208.9	3,420,535.5	2,148.1	2.1	1.7
Average/Sum#:	10.5	13.3	8.2	209.4	3,474,606.2	2,163.7	2.1	1.7
Minimum:	9.8	13.2	7.9	145.1	3,403,019.6	1,961.1	1.6	1.2
Maximum:	10.7	13.6	8.4	257.6	3,544,827.1	2,332.5	2.6	2.0
%SI	4.17	4.17	4.17	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/16/2022 00:00	10.4	13.4	8.2	202.0	3,411,459.1	2,142.4	2.1	1.7
11/16/2022 01:00	10.4	13.4	8.2	202.6	3,449,645.2	2,116.0	2.0	1.7
11/16/2022 02:00	10.4	13.4	8.2	208.3	3,447,405.1	2,139.8	2.1	1.7
11/16/2022 03:00	10.4	13.4	8.2	209.8	3,454,816.1	2,144.4	2.1	1.7
11/16/2022 04:00	10.7	13.3	8.3	219.1	3,460,991.9	2,274.6	2.2	1.8
11/16/2022 05:00	10.8	13.2	8.3	256.8	3,408,992.6	2,340.0	2.7	2.3
11/16/2022 06:00	11.1	13.2	8.5	228.3	3,418,462.0	2,346.5	2.3	2.1
11/16/2022 07:00	10.7	13.3	8.3	224.9	3,430,103.8	2,254.3	2.3	2.0
11/16/2022 08:00	5.4	13.7	4.4	154.5	3,543,926.2	1,966.8	1.5	1.2
11/16/2022 09:00	2.2	13.9	1.9	150.7	3,746,219.9	1,997.0	1.5	1.2
11/16/2022 10:00	10.3	13.6	8.3	163.3	3,494,344.2	1,964.8	1.6	1.2
11/16/2022 11:00	10.2	13.6	8.2	175.1	3,502,169.5	1,969.2	1.7	1.4
11/16/2022 12:00	10.1	13.6	8.2	174.6	3,472,719.8	1,978.0	1.7	1.4
11/16/2022 13:00	10.1	13.6	8.2	172.7	3,477,109.0	1,980.5	1.7	1.4
11/16/2022 14:00	10.1	13.6	8.2	179.5	3,478,337.9	1,981.2	1.8	1.4
11/16/2022 15:00	10.5	13.4	8.3	192.3	3,467,943.5	2,101.9	1.9	1.5
11/16/2022 16:00	10.6	13.3	8.2	204.0	3,442,032.3	2,161.6	2.1	1.7
11/16/2022 17:00	10.6	13.3	8.2	206.4	3,448,720.2	2,165.8	2.1	1.7
11/16/2022 18:00	10.6	13.3	8.2	219.8	3,418,329.5	2,221.6	2.3	2.0
11/16/2022 19:00	10.6	13.3	8.2	221.9	3,390,694.8	2,228.4	2.3	2.0
11/16/2022 20:00	10.5	13.3	8.2	219.8	3,392,672.8	2,229.7	2.3	2.0
11/16/2022 21:00	10.4	13.3	8.1	216.3	3,453,719.1	2,244.6	2.2	1.8
11/16/2022 22:00	10.3	13.3	8.0	210.2	3,488,569.3	2,216.3	2.1	1.8
11/16/2022 23:00	10.4	13.3	8.1	215.2	3,452,642.0	2,243.9	2.2	1.8
Average/Sum#:	9.9	13.4	7.8	201.2	3,464,667.7	2,142.1	2.0	1.7
Minimum:	2.2	13.2	1.9	150.7	3,390,694.8	1,964.8	1.5	1.2
Maximum:	11.1	13.9	8.5	256.8	3,746,219.9	2,346.5	2.7	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/17/2022 00:00	10.3	13.4	8.1	202.0	3,478,499.0	2,159.1	2.0	1.7
11/17/2022 01:00	10.4	13.4	8.2	203.7	3,478,982.4	2,159.4	2.0	1.7
11/17/2022 02:00	10.3	13.4	8.1	199.0	3,498,716.3	2,146.1	2.0	1.7
11/17/2022 03:00	10.2	13.4	8.0	197.1	3,504,422.2	2,149.6	2.0	1.7
11/17/2022 04:00	10.4	13.3	8.1	209.2	3,511,707.8	2,231.0	2.1	1.8
11/17/2022 05:00	10.7	13.2	8.2	231.9	3,470,680.9	2,357.0	2.3	2.1
11/17/2022 06:00	10.8	13.3	8.4	221.7	3,463,578.6	2,276.3	2.2	1.8
11/17/2022 07:00	10.4	13.4	8.2	203.7	3,484,299.0	2,162.7	2.0	1.7
11/17/2022 08:00	9.6	13.6	7.8	164.4	3,485,711.8	1,985.4	1.6	1.2
11/17/2022 09:00	10.4	13.4	8.2	196.8	3,470,838.7	2,129.0	2.0	1.7
11/17/2022 10:00	10.4	13.4	8.2	197.3	3,441,167.8	2,110.8	2.0	1.7
11/17/2022 11:00	10.5	13.4	8.3	203.3	3,397,924.1	2,133.9	2.1	1.7
11/17/2022 12:00	10.5	13.4	8.3	212.4	3,379,210.3	2,171.5	2.2	1.7
11/17/2022 13:00	10.5	13.4	8.3	211.5	3,415,375.9	2,169.8	2.2	1.7
11/17/2022 14:00	10.3	13.5	8.2	185.0	3,432,119.9	2,005.0	1.9	1.4
11/17/2022 15:00	10.6	13.4	8.3	198.9	3,413,411.1	2,118.7	2.0	1.7
11/17/2022 16:00	10.6	13.3	8.2	218.7	3,400,585.1	2,234.9	2.3	2.0
11/17/2022 17:00	10.6	13.3	8.2	226.8	3,413,327.9	2,268.2	2.3	2.0
11/17/2022 18:00	10.4	13.3	8.1	224.8	3,394,517.1	2,255.7	2.3	2.0
11/17/2022 19:00	10.5	13.3	8.2	225.8	3,399,182.2	2,258.8	2.3	2.0
11/17/2022 20:00	10.4	13.3	8.1	224.6	3,401,289.0	2,260.2	2.3	2.0
11/17/2022 21:00	10.4	13.3	8.1	223.7	3,404,599.7	2,262.4	2.3	2.0
11/17/2022 22:00	10.4	13.3	8.1	218.4	3,418,083.3	2,246.4	2.2	1.8
11/17/2022 23:00	10.2	13.3	7.9	205.4	3,473,301.0	2,206.6	2.1	1.8
Average/Sum#:	10.4	13.4	8.2	208.6	3,442,980.5	2,185.8	2.1	1.8
Minimum:	9.6	13.2	7.8	164.4	3,379,210.3	1,985.4	1.6	1.2
Maximum:	10.8	13.6	8.4	231.9	3,511,707.8	2,357.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/18/2022 00:00	10.3	13.4	8.1	199.9	3,475,276.9	2,157.1	2.0	1.7
11/18/2022 01:00	10.4	13.4	8.2	206.2	3,446,490.9	2,164.4	2.1	1.7
11/18/2022 02:00	10.4	13.4	8.2	208.0	3,410,496.3	2,166.7	2.1	1.7
11/18/2022 03:00	10.3	13.4	8.1	203.8	3,449,038.6	2,166.0	2.1	1.7
11/18/2022 04:00	10.7	13.3	8.3	226.2	3,398,675.7	2,308.1	2.3	2.1
11/18/2022 05:00	10.8	13.2	8.3	256.3	3,388,596.9	2,326.0	2.7	2.3
11/18/2022 06:00	11.3	13.2	8.7	225.2	3,398,940.5	2,333.1	2.3	2.1
11/18/2022 07:00	10.8	13.3	8.4	227.5	3,411,522.1	2,267.0	2.3	2.0
11/18/2022 08:00	10.6	13.4	8.3	209.8	3,416,713.8	2,145.7	2.1	1.7
11/18/2022 09:00	10.7	13.4	8.4	210.2	3,429,452.7	2,153.7	2.1	1.7
11/18/2022 10:00	10.8	13.4	8.5	211.7	3,404,357.5	2,162.8	2.2	1.7
11/18/2022 11:00	10.7	13.4	8.4	204.8	3,384,572.6	2,100.8	2.1	1.7
11/18/2022 12:00	10.5	13.5	8.4	188.1	3,438,308.6	1,958.4	1.9	1.4
11/18/2022 13:00	10.7	13.5	8.5	182.9	3,441,293.2	1,960.1	1.8	1.4
11/18/2022 14:00	10.7	13.5	8.5	184.5	3,405,359.7	1,964.5	1.9	1.4
11/18/2022 15:00	10.8	13.5	8.6	199.0	3,407,027.7	2,040.1	2.0	1.6
11/18/2022 16:00	10.9	13.3	8.5	220.9	3,416,636.9	2,220.5	2.3	2.0
11/18/2022 17:00	10.8	13.3	8.4	220.4	3,415,800.9	2,244.9	2.3	2.0
11/18/2022 18:00	10.7	13.3	8.3	225.6	3,413,366.4	2,243.3	2.3	2.0
11/18/2022 19:00	10.7	13.3	8.3	225.3	3,416,561.7	2,245.4	2.3	2.0
11/18/2022 20:00	10.7	13.3	8.3	229.7	3,425,517.3	2,276.3	2.4	2.0
11/18/2022 21:00	10.8	13.3	8.4	225.1	3,428,862.0	2,328.6	2.3	2.1
11/18/2022 22:00	10.9	13.2	8.4	238.5	3,447,120.9	2,341.0	2.4	2.1
11/18/2022 23:00	10.8	13.3	8.4	221.1	3,463,439.8	2,301.5	2.2	1.8
Average/Sum#:	10.7	13.4	8.4	214.6	3,422,226.2	2,190.7	2.2	1.8
Minimum:	10.3	13.2	8.1	182.9	3,384,572.6	1,958.4	1.8	1.4
Maximum:	11.3	13.5	8.7	256.3	3,475,276.9	2,341.0	2.7	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/19/2022 00:00	10.5	13.4	8.3	205.7	3,445,217.0	2,163.6	2.1	1.7
11/19/2022 01:00	10.5	13.4	8.3	205.1	3,492,521.3	2,142.3	2.0	1.7
11/19/2022 02:00	10.5	13.4	8.3	204.0	3,487,304.4	2,139.1	2.0	1.7
11/19/2022 03:00	10.5	13.4	8.3	198.6	3,495,002.0	2,118.3	2.0	1.7
11/19/2022 04:00	10.7	13.3	8.3	211.7	3,472,580.1	2,231.5	2.1	1.8
11/19/2022 05:00	10.7	13.3	8.3	242.6	3,434,668.5	2,257.3	2.5	2.3
11/19/2022 06:00	10.9	13.4	8.6	206.9	3,489,802.9	2,191.6	2.1	1.8
11/19/2022 07:00	10.5	13.4	8.3	196.7	3,461,057.1	2,123.0	2.0	1.7
11/19/2022 08:00	9.8	13.6	7.9	168.0	3,492,210.0	1,963.6	1.7	1.4
11/19/2022 09:00	10.0	13.6	8.1	168.3	3,488,830.9	1,961.7	1.7	1.4
11/19/2022 10:00	10.2	13.6	8.2	174.4	3,479,760.7	1,956.6	1.7	1.4
11/19/2022 11:00	10.4	13.6	8.4	184.6	3,429,354.7	1,953.3	1.9	1.4
11/19/2022 12:00	10.7	13.5	8.5	179.7	3,429,354.7	1,953.3	1.8	1.4
11/19/2022 13:00	10.7	13.5	8.5	192.2	3,430,759.2	1,954.1	1.9	1.4
11/19/2022 14:00	10.7	13.5	8.5	179.7	3,442,697.8	1,960.9	1.8	1.4
11/19/2022 15:00	10.8	13.5	8.6	196.2	3,417,305.6	2,021.3	2.0	1.6
11/19/2022 16:00	10.9	13.4	8.6	216.1	3,394,598.4	2,156.6	2.2	1.7
11/19/2022 17:00	10.8	13.4	8.5	214.2	3,387,302.3	2,176.7	2.2	1.7
11/19/2022 18:00	10.7	13.4	8.4	210.8	3,414,274.1	2,169.1	2.2	1.7
11/19/2022 19:00	10.8	13.3	8.4	227.1	3,420,701.7	2,273.1	2.3	2.0
11/19/2022 20:00	10.8	13.3	8.4	234.0	3,395,141.7	2,305.7	2.4	2.1
11/19/2022 21:00	10.8	13.3	8.4	229.5	3,405,596.5	2,312.8	2.4	2.1
11/19/2022 22:00	10.5	13.2	8.0	229.2	3,484,143.1	2,340.7	2.3	2.1
11/19/2022 23:00	10.7	13.2	8.2	236.9	3,472,889.7	2,358.5	2.4	2.1
Average/Sum#:	10.6	13.4	8.3	204.7	3,448,461.4	2,132.7	2.1	1.7
Minimum:	9.8	13.2	7.9	168.0	3,387,302.3	1,953.3	1.7	1.4
Maximum:	10.9	13.6	8.6	242.6	3,495,002.0	2,358.5	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/20/2022 00:00	10.5	13.3	8.2	213.9	3,469,413.6	2,254.8	2.2	1.8
11/20/2022 01:00	10.6	13.3	8.2	226.4	3,458,557.4	2,273.0	2.3	2.0
11/20/2022 02:00	10.7	13.3	8.3	234.5	3,463,138.8	2,301.3	2.4	2.1
11/20/2022 03:00	10.6	13.3	8.2	225.4	3,501,466.0	2,301.2	2.3	2.1
11/20/2022 04:00	10.4	13.3	8.1	223.5	3,509,378.2	2,306.4	2.2	1.8
11/20/2022 05:00	10.5	13.2	8.0	213.2	3,497,986.2	2,350.0	2.1	1.9
11/20/2022 06:00	10.7	13.3	8.3	212.8	3,508,371.9	2,254.5	2.1	1.8
11/20/2022 07:00	10.1	13.5	8.1	188.7	3,458,704.0	2,096.3	1.9	1.5
11/20/2022 08:00	10.3	13.9	8.7	169.6	3,321,915.0	1,722.3	1.7	1.2
11/20/2022 09:00	10.4	13.9	8.8	162.0	3,327,894.1	1,725.4	1.7	1.2
11/20/2022 10:00	10.8	13.9	9.1	149.8	3,031,056.9	1,571.5	1.7	1.1
11/20/2022 11:00	10.8	13.9	9.1	146.4	3,078,466.0	1,573.6	1.6	0.9
11/20/2022 12:00	10.8	13.9	9.1	143.5	3,024,275.9	1,545.9	1.6	0.9
11/20/2022 13:00	10.8	13.9	9.1	142.1	3,005,886.5	1,536.5	1.6	0.9
11/20/2022 14:00	9.9	13.9	8.3	143.6	3,269,259.6	1,695.0	1.5	1.0
11/20/2022 15:00	10.2	13.8	8.5	159.9	3,341,009.7	1,732.2	1.6	1.0
11/20/2022 16:00	11.0	13.4	8.7	200.6	3,419,102.4	2,147.2	2.0	1.7
11/20/2022 17:00	10.9	13.3	8.5	231.0	3,409,264.8	2,265.5	2.4	2.0
11/20/2022 18:00	10.7	13.3	8.3	228.1	3,389,250.1	2,252.2	2.4	2.0
11/20/2022 19:00	10.6	13.3	8.2	223.0	3,391,206.4	2,253.5	2.3	2.0
11/20/2022 20:00	10.5	13.3	8.2	220.7	3,397,075.4	2,257.4	2.3	2.0
11/20/2022 21:00	10.4	13.4	8.2	211.5	3,412,045.3	2,192.6	2.2	1.8
11/20/2022 22:00	10.2	13.4	8.0	200.6	3,475,760.2	2,157.4	2.0	1.7
11/20/2022 23:00	10.2	13.4	8.0	195.9	3,500,998.6	2,147.5	1.9	1.5
Average/Sum#:	10.5	13.5	8.4	194.4	3,360,895.1	2,038.1	2.0	1.6
Minimum:	9.9	13.2	8.0	142.1	3,005,886.5	1,536.5	1.5	0.9
Maximum:	11.0	13.9	9.1	234.5	3,509,378.2	2,350.0	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/21/2022 00:00	10.2	13.4	8.0	201.0	3,474,793.5	2,156.8	2.0	1.7
11/21/2022 01:00	10.1	13.4	7.9	191.5	3,515,130.9	2,130.5	1.9	1.5
11/21/2022 02:00	9.9	13.5	7.9	175.2	3,522,844.2	2,058.0	1.7	1.4
11/21/2022 03:00	10.4	13.4	8.2	196.8	3,499,604.3	2,172.2	2.0	1.7
11/21/2022 04:00	10.4	13.3	8.1	218.6	3,476,183.8	2,259.2	2.2	1.8
11/21/2022 05:00	10.4	13.3	8.1	186.4	3,488,954.8	2,267.5	1.8	1.6
11/21/2022 06:00	10.7	13.3	8.3	213.2	3,514,958.5	2,284.4	2.1	1.8
11/21/2022 07:00	10.2	13.4	8.0	196.3	3,500,346.5	2,147.1	1.9	1.5
11/21/2022 08:00	9.5	13.7	7.8	167.9	3,494,877.7	1,965.1	1.7	1.4
11/21/2022 09:00	9.6	13.7	7.9	164.0	3,495,055.6	1,965.2	1.6	1.2
11/21/2022 10:00	9.9	13.6	8.0	168.1	3,488,830.9	1,961.7	1.7	1.4
11/21/2022 11:00	10.1	13.6	8.2	181.7	3,439,186.4	1,958.9	1.8	1.4
11/21/2022 12:00	10.5	13.5	8.4	180.1	3,408,306.6	1,966.2	1.8	1.4
11/21/2022 13:00	10.6	13.5	8.5	182.0	3,428,241.3	1,977.7	1.8	1.4
11/21/2022 14:00	10.8	13.4	8.5	213.6	3,401,996.5	2,161.3	2.2	1.7
11/21/2022 15:00	10.9	13.3	8.5	224.6	3,419,046.4	2,272.0	2.3	2.0
11/21/2022 16:00	10.5	13.3	8.2	208.8	3,429,715.7	2,229.0	2.1	1.8
11/21/2022 17:00	10.6	13.3	8.2	222.0	3,394,498.7	2,230.9	2.3	2.0
11/21/2022 18:00	10.6	13.3	8.2	223.4	3,393,890.1	2,230.5	2.3	2.0
11/21/2022 19:00	10.5	13.3	8.2	222.7	3,398,881.2	2,258.6	2.3	2.0
11/21/2022 20:00	10.5	13.3	8.2	220.8	3,406,255.0	2,263.5	2.3	2.0
11/21/2022 21:00	10.5	13.3	8.2	223.7	3,407,308.5	2,264.2	2.3	2.0
11/21/2022 22:00	10.4	13.3	8.1	221.6	3,408,211.4	2,264.8	2.3	2.0
11/21/2022 23:00	10.3	13.3	8.0	214.5	3,425,099.6	2,226.0	2.2	1.8
Average/Sum#:	10.3	13.4	8.2	200.8	3,451,342.4	2,153.0	2.0	1.7
Minimum:	9.5	13.3	7.8	164.0	3,393,890.1	1,958.9	1.6	1.2
Maximum:	10.9	13.7	8.5	224.6	3,522,844.2	2,284.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/22/2022 00:00	10.2	13.4	8.0	197.3	3,454,010.5	2,143.9	2.0	1.7
11/22/2022 01:00	10.1	13.4	7.9	189.5	3,506,716.4	2,125.4	1.9	1.5
11/22/2022 02:00	10.2	13.4	8.0	189.7	3,455,569.2	2,094.4	1.9	1.5
11/22/2022 03:00	9.5	13.7	7.8	162.4	3,465,170.4	1,973.7	1.6	1.2
11/22/2022 04:00	9.7	13.6	7.8	164.6	3,471,315.2	1,977.2	1.6	1.2
11/22/2022 05:00	10.0	13.6	8.1	213.5	3,408,546.8	2,065.9	2.2	1.7
11/22/2022 06:00	10.6	13.4	8.3	190.8	3,503,444.0	2,149.0	1.9	1.5
11/22/2022 07:00	10.2	13.5	8.1	180.1	3,488,525.1	2,088.9	1.8	1.5
11/22/2022 08:00	10.1	13.5	8.1	185.5	3,510,861.8	2,051.0	1.8	1.4
11/22/2022 09:00	14.1	14.4	12.8	162.3	2,952,642.5	1,444.6	1.8	1.0
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2022 11:00	12.5	18.6	32.1	161.5	567,333.0	58.0	10.0	0.2
11/22/2022 12:00	45.0	15.9	53.1	257.1	2,031,849.9	756.7	3.9	1.1
11/22/2022 13:00	10.7	13.8	8.9	162.7	3,129,424.0	1,622.5	1.8	1.1
11/22/2022 14:00	9.5	13.9	8.0	152.9	3,453,264.0	1,790.4	1.5	1.1
11/22/2022 15:00	9.8	13.9	8.3	151.7	3,453,264.0	1,790.4	1.5	1.1
11/22/2022 16:00	10.9	13.6	8.8	185.9	3,374,830.8	1,897.6	1.9	1.3
11/22/2022 17:00	11.0	13.4	8.7	200.5	3,410,503.7	2,141.8	2.0	1.7
11/22/2022 18:00	10.6	13.5	8.5	191.1	3,399,011.5	2,035.3	1.9	1.4
11/22/2022 19:00	10.3	13.5	8.2	176.4	3,436,561.8	1,982.5	1.8	1.4
11/22/2022 20:00	10.6	13.4	8.3	200.2	3,445,632.9	2,138.7	2.0	1.7
11/22/2022 21:00	10.2	13.5	8.1	182.2	3,453,688.3	2,017.6	1.8	1.4
11/22/2022 22:00	10.2	13.5	8.1	176.1	3,429,985.4	2,028.8	1.8	1.4
11/22/2022 23:00	9.8	13.6	7.9	162.4	3,481,361.3	1,957.5	1.6	1.2
Average/Sum#:	12.0	13.9	11.4	182.5	3,229,717.9	1,840.5	2.3	1.3
Minimum:	9.5	13.4	7.8	151.7	567,333.0	58.0	1.5	0.2
Maximum:	45.0	18.6	53.1	257.1	3,510,861.8	2,149.0	10.0	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/23/2022 00:00	9.8	13.6	7.9	166.0	3,483,495.5	1,958.7	1.6	1.2
11/23/2022 01:00	9.8	13.6	7.9	165.5	3,486,874.6	1,960.6	1.6	1.2
11/23/2022 02:00	9.9	13.6	8.0	163.7	3,482,962.0	1,958.4	1.6	1.2
11/23/2022 03:00	9.6	13.7	7.9	158.7	3,490,253.7	1,962.5	1.6	1.2
11/23/2022 04:00	10.0	13.6	8.1	169.0	3,457,269.9	1,969.2	1.7	1.4
11/23/2022 05:00	10.5	13.5	8.4	168.2	3,353,622.5	2,057.1	1.7	1.4
11/23/2022 06:00	10.7	13.5	8.5	182.1	3,463,291.2	2,048.5	1.8	1.4
11/23/2022 07:00	10.8	13.4	8.5	193.0	3,471,243.3	2,103.9	1.9	1.5
11/23/2022 08:00	10.4	13.5	8.3	183.4	3,455,976.4	1,993.7	1.8	1.4
11/23/2022 09:00	10.5	13.9	8.9	157.1	3,293,755.0	1,707.7	1.6	1.0
11/23/2022 10:00	11.2	13.9	9.4	157.0	3,012,926.5	1,562.1	1.8	1.1
11/23/2022 11:00	11.2	13.9	9.4	152.7	3,044,426.0	1,556.2	1.7	1.1
11/23/2022 12:00	11.4	13.9	9.6	133.4	2,787,169.9	1,424.7	1.6	0.9
11/23/2022 13:00	10.6	14.0	9.1	146.6	3,049,316.8	1,558.7	1.6	0.9
11/23/2022 14:00	10.3	14.0	8.8	148.1	3,186,259.3	1,628.7	1.6	1.0
11/23/2022 15:00	10.8	13.9	9.1	166.4	3,181,500.7	1,649.5	1.8	1.2
11/23/2022 16:00	11.0	13.4	8.7	198.3	3,418,833.2	2,097.1	2.0	1.7
11/23/2022 17:00	10.8	13.3	8.4	208.7	3,438,847.6	2,159.6	2.1	1.7
11/23/2022 18:00	10.5	13.4	8.3	189.4	3,429,500.6	2,078.6	1.9	1.5
11/23/2022 19:00	10.5	13.4	8.3	186.4	3,457,712.0	2,045.2	1.9	1.4
11/23/2022 20:00	10.8	13.3	8.4	208.5	3,431,522.7	2,155.0	2.1	1.7
11/23/2022 21:00	10.8	13.3	8.4	207.1	3,413,487.0	2,168.6	2.1	1.7
11/23/2022 22:00	10.7	13.3	8.3	198.4	3,453,527.2	2,143.6	2.0	1.7
11/23/2022 23:00	10.6	13.3	8.2	200.4	3,448,693.9	2,140.6	2.0	1.7
Average/Sum#:	10.6	13.6	8.5	175.3	3,341,352.8	1,920.4	1.8	1.3
Minimum:	9.6	13.3	7.9	133.4	2,787,169.9	1,424.7	1.6	0.9
Maximum:	11.4	14.0	9.6	208.7	3,490,253.7	2,168.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/24/2022 00:00	10.0	13.6	8.1	174.8	3,468,155.0	1,975.4	1.7	1.4
11/24/2022 01:00	9.9	13.6	8.0	169.8	3,490,253.7	1,962.5	1.7	1.4
11/24/2022 02:00	9.9	13.6	8.0	164.7	3,492,210.0	1,963.6	1.6	1.2
11/24/2022 03:00	10.7	13.5	8.5	188.3	3,423,561.0	1,975.0	1.9	1.4
11/24/2022 04:00	10.5	13.5	8.4	186.3	3,398,740.1	1,985.5	1.9	1.4
11/24/2022 05:00	10.6	13.5	8.5	202.4	3,346,775.4	2,052.9	2.1	1.6
11/24/2022 06:00	11.1	13.4	8.7	207.0	3,408,764.9	2,165.6	2.1	1.7
11/24/2022 07:00	10.7	13.5	8.5	202.8	3,389,977.5	2,079.4	2.1	1.7
11/24/2022 08:00	10.3	13.9	8.7	163.9	3,302,048.7	1,712.0	1.7	1.2
11/24/2022 09:00	10.4	13.9	8.8	159.0	3,296,262.4	1,709.0	1.6	1.0
11/24/2022 10:00	10.3	13.9	8.7	157.3	3,310,535.2	1,716.4	1.6	1.0
11/24/2022 11:00	11.0	13.9	9.3	151.5	3,052,055.7	1,560.1	1.7	1.1
11/24/2022 12:00	11.3	14.0	9.7	125.0	2,644,749.7	1,351.9	1.6	0.8
11/24/2022 13:00	11.2	14.0	9.6	134.4	2,642,793.4	1,350.9	1.7	0.9
11/24/2022 14:00	10.9	13.9	9.2	152.4	3,056,164.0	1,562.2	1.7	1.1
11/24/2022 15:00	11.0	13.9	9.3	143.9	2,837,056.1	1,450.2	1.7	1.0
11/24/2022 16:00	9.8	13.9	8.3	151.4	3,412,952.7	1,769.5	1.5	1.1
11/24/2022 17:00	9.4	13.9	7.9	147.7	3,411,216.9	1,768.6	1.5	1.1
11/24/2022 18:00	9.6	13.9	8.1	144.0	3,366,469.5	1,745.4	1.4	0.9
11/24/2022 19:00	9.6	13.9	8.1	145.6	3,350,460.7	1,737.1	1.5	1.0
11/24/2022 20:00	10.4	13.9	8.8	167.6	3,368,591.1	1,746.5	1.7	1.2
11/24/2022 21:00	10.5	13.9	8.9	165.9	3,369,748.4	1,747.1	1.7	1.2
11/24/2022 22:00	10.5	13.9	8.9	168.2	3,377,849.2	1,751.3	1.7	1.2
11/24/2022 23:00	10.5	13.9	8.9	172.8	3,381,513.8	1,753.2	1.7	1.2
Average/Sum#:	10.4	13.8	8.7	164.4	3,274,954.4	1,774.6	1.7	1.2
Minimum:	9.4	13.4	7.9	125.0	2,642,793.4	1,350.9	1.4	0.8
Maximum:	11.3	14.0	9.7	207.0	3,492,210.0	2,165.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/25/2022 00:00	10.2	13.9	8.6	160.5	3,389,228.9	1,757.2	1.6	1.1
11/25/2022 01:00	10.1	13.9	8.5	159.6	3,391,543.4	1,758.4	1.6	1.1
11/25/2022 02:00	10.0	13.9	8.4	163.1	3,396,558.2	1,761.0	1.6	1.1
11/25/2022 03:00	10.1	13.9	8.5	157.3	3,402,923.2	1,764.3	1.6	1.1
11/25/2022 04:00	10.1	13.9	8.5	163.3	3,423,753.8	1,775.1	1.6	1.1
11/25/2022 05:00	10.2	13.8	8.5	174.6	3,416,231.6	1,771.2	1.8	1.2
11/25/2022 06:00	10.3	13.9	8.7	160.5	3,407,745.1	1,766.8	1.6	1.1
11/25/2022 07:00	10.0	13.9	8.4	155.6	3,407,745.1	1,766.8	1.5	1.1
11/25/2022 08:00	9.8	13.7	8.0	153.3	3,436,524.8	1,882.1	1.5	1.1
11/25/2022 09:00	10.4	13.6	8.4	185.1	3,370,364.1	1,919.7	1.9	1.3
11/25/2022 10:00	10.5	13.9	8.9	157.2	3,217,182.9	1,668.0	1.7	1.2
11/25/2022 11:00	10.9	13.9	9.2	146.5	2,987,659.7	1,549.0	1.7	1.1
11/25/2022 12:00	10.8	13.9	9.1	145.9	3,037,229.0	1,574.7	1.6	0.9
11/25/2022 13:00	11.2	13.9	9.4	148.1	2,976,665.7	1,543.3	1.7	1.1
11/25/2022 14:00	11.2	13.9	9.4	152.1	2,954,099.1	1,531.6	1.7	1.1
11/25/2022 15:00	10.9	13.8	9.1	163.2	3,127,422.9	1,644.3	1.8	1.2
11/25/2022 16:00	10.9	13.4	8.6	182.8	3,435,275.3	2,082.1	1.8	1.5
11/25/2022 17:00	10.7	13.4	8.4	195.2	3,418,181.1	2,096.7	2.0	1.7
11/25/2022 18:00	10.2	13.5	8.1	176.1	3,415,240.4	1,970.2	1.8	1.4
11/25/2022 19:00	10.1	13.6	8.2	170.5	3,433,392.7	1,955.6	1.7	1.4
11/25/2022 20:00	10.1	13.6	8.2	164.9	3,432,339.3	1,955.0	1.6	1.2
11/25/2022 21:00	9.9	13.6	8.0	167.3	3,452,178.4	1,966.3	1.7	1.4
11/25/2022 22:00	10.7	13.4	8.4	197.3	3,453,883.9	2,118.6	2.0	1.7
11/25/2022 23:00	10.6	13.4	8.3	190.8	3,431,810.5	2,080.0	1.9	1.5
Average/Sum#:	10.4	13.7	8.6	166.3	3,325,632.5	1,819.1	1.7	1.2
Minimum:	9.8	13.4	8.0	145.9	2,954,099.1	1,531.6	1.5	0.9
Maximum:	11.2	13.9	9.4	197.3	3,453,883.9	2,118.6	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/26/2022 00:00	10.3	13.5	8.2	179.2	3,452,318.9	2,016.8	1.8	1.4
11/26/2022 01:00	10.3	13.4	8.1	187.0	3,443,601.3	2,062.0	1.9	1.4
11/26/2022 02:00	13.4	14.3	12.0	168.6	3,038,579.1	1,575.4	1.9	1.1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.3	13.7	9.4	178.3	3,311,499.8	1,884.7	1.9	1.3
Minimum:	10.3	13.4	8.1	168.6	3,038,579.1	1,575.4	1.8	1.1
Maximum:	13.4	14.3	12.0	187.0	3,452,318.9	2,062.0	1.9	1.4
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2022 02:00	40.4	17.4	68.1	40.6	1,346,731.1	344.2	0.0	0.0
11/28/2022 03:00	35.2	15.3	37.1	229.8	2,281,413.0	949.6	3.2	1.1
11/28/2022 04:00	10.5	13.8	8.7	182.0	3,280,151.8	1,724.6	1.9	1.2
11/28/2022 05:00	10.7	13.8	8.9	156.2	3,146,823.1	1,654.5	1.7	1.2
11/28/2022 06:00	10.9	13.3	8.5	191.5	3,529,039.2	2,164.7	1.9	1.5
11/28/2022 07:00	11.1	13.2	8.5	211.2	3,478,030.2	2,260.4	2.1	1.8
11/28/2022 08:00	10.0	13.6	8.1	168.8	3,416,453.8	1,970.9	1.7	1.4
11/28/2022 09:00	10.9	13.8	9.1	155.3	3,112,643.8	1,613.8	1.7	1.1
11/28/2022 10:00	10.8	13.8	9.0	175.9	3,315,550.0	1,719.0	1.8	1.2
11/28/2022 11:00	11.3	13.9	9.5	148.2	2,944,069.5	1,526.4	1.7	1.1
11/28/2022 12:00	11.1	13.9	9.4	149.7	3,030,092.5	1,571.0	1.7	1.1
11/28/2022 13:00	10.8	13.9	9.1	159.2	3,170,892.5	1,644.0	1.7	1.2
11/28/2022 14:00	10.9	13.9	9.2	156.2	3,138,682.1	1,627.3	1.7	1.1
11/28/2022 15:00	10.7	13.8	8.9	154.7	3,088,242.2	1,623.7	1.7	1.1
11/28/2022 16:00	10.7	13.5	8.5	176.7	3,420,855.9	2,023.4	1.8	1.4
11/28/2022 17:00	10.7	13.4	8.4	188.8	3,407,258.3	2,090.0	1.9	1.5
11/28/2022 18:00	10.1	13.5	8.1	172.0	3,432,921.6	1,980.4	1.7	1.4
11/28/2022 19:00	10.0	13.6	8.1	172.2	3,438,484.2	1,958.5	1.7	1.4
11/28/2022 20:00	10.5	13.4	8.3	189.1	3,474,162.9	2,080.3	1.9	1.5
11/28/2022 21:00	10.7	13.3	8.3	208.0	3,442,857.4	2,212.4	2.1	1.8
11/28/2022 22:00	10.3	13.4	8.1	184.9	3,480,676.0	2,084.2	1.8	1.5
11/28/2022 23:00	9.9	13.6	8.0	165.6	3,479,215.8	1,981.7	1.6	1.2
Average/Sum#:	13.1	13.9	12.6	169.8	3,175,238.5	1,763.9	1.8	1.3
Minimum:	9.9	13.2	8.0	40.6	1,346,731.1	344.2	0.0	0.0
Maximum:	40.4	17.4	68.1	229.8	3,529,039.2	2,260.4	3.2	1.8
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/29/2022 00:00	10.6	13.3	8.2	197.6	3,450,627.2	2,141.8	2.0	1.7
11/29/2022 01:00	10.6	13.3	8.2	202.9	3,482,318.8	2,186.9	2.0	1.7
11/29/2022 02:00	10.4	13.3	8.1	198.6	3,464,006.7	2,175.4	2.0	1.7
11/29/2022 03:00	10.3	13.4	8.1	183.7	3,485,519.1	2,087.1	1.8	1.5
11/29/2022 04:00	10.5	13.3	8.2	193.2	3,503,444.0	2,149.0	1.9	1.5
11/29/2022 05:00	10.6	13.3	8.2	209.5	3,497,923.9	2,196.7	2.1	1.8
11/29/2022 06:00	11.0	13.2	8.4	222.9	3,471,795.1	2,281.7	2.2	1.8
11/29/2022 07:00	10.8	13.2	8.3	226.2	3,471,338.7	2,281.4	2.3	2.1
11/29/2022 08:00	10.7	13.3	8.3	222.9	3,414,583.6	2,244.1	2.3	2.0
11/29/2022 09:00	10.6	13.4	8.3	204.2	3,424,675.6	2,150.7	2.1	1.7
11/29/2022 10:00	10.6	13.4	8.3	205.9	3,415,599.2	2,145.0	2.1	1.7
11/29/2022 11:00	10.7	13.4	8.4	207.2	3,402,701.1	2,136.9	2.1	1.7
11/29/2022 12:00	10.7	13.4	8.4	211.4	3,386,299.9	2,126.6	2.2	1.7
11/29/2022 13:00	10.7	13.4	8.4	207.5	3,383,911.3	2,125.1	2.1	1.7
11/29/2022 14:00	10.7	13.4	8.4	207.6	3,389,166.1	2,128.4	2.1	1.7
11/29/2022 15:00	10.5	13.4	8.3	204.8	3,417,987.7	2,146.5	2.1	1.7
11/29/2022 16:00	10.8	13.3	8.4	224.3	3,391,657.9	2,253.8	2.3	2.0
11/29/2022 17:00	10.7	13.3	8.3	225.0	3,405,051.2	2,262.7	2.3	2.0
11/29/2022 18:00	10.6	13.3	8.2	228.0	3,415,585.2	2,269.7	2.3	2.0
11/29/2022 19:00	10.6	13.3	8.2	226.8	3,416,638.6	2,270.4	2.3	2.0
11/29/2022 20:00	10.5	13.3	8.2	224.6	3,461,600.5	2,275.0	2.3	2.0
11/29/2022 21:00	10.5	13.3	8.2	221.3	3,468,295.5	2,279.4	2.2	1.8
11/29/2022 22:00	10.4	13.3	8.1	220.1	3,470,730.0	2,281.0	2.2	1.8
11/29/2022 23:00	10.4	13.3	8.1	217.5	3,467,991.2	2,279.2	2.2	1.8
Average/Sum#:	10.6	13.3	8.3	212.2	3,439,977.0	2,203.1	2.1	1.8
Minimum:	10.3	13.2	8.1	183.7	3,383,911.3	2,087.1	1.8	1.5
Maximum:	11.0	13.4	8.4	228.0	3,503,444.0	2,281.7	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/30/2022 00:00	10.2	13.3	7.9	196.1	3,542,081.4	2,172.7	1.9	1.5
11/30/2022 01:00	10.4	13.4	8.2	195.8	3,511,921.4	2,154.2	1.9	1.5
11/30/2022 02:00	10.3	13.4	8.1	197.6	3,506,215.5	2,150.7	2.0	1.7
11/30/2022 03:00	10.2	13.4	8.0	195.6	3,507,845.8	2,151.7	1.9	1.5
11/30/2022 04:00	10.2	13.4	8.0	196.4	3,534,419.1	2,168.0	1.9	1.5
11/30/2022 05:00	10.2	13.4	8.0	192.3	3,529,691.3	2,165.1	1.9	1.5
11/30/2022 06:00	10.7	13.3	8.3	208.1	3,513,974.1	2,258.1	2.1	1.8
11/30/2022 07:00	10.2	13.4	8.0	193.5	3,498,716.3	2,146.1	1.9	1.5
11/30/2022 08:00	9.8	13.6	7.9	175.0	3,522,621.9	1,980.7	1.7	1.4
11/30/2022 09:00	9.9	13.5	7.9	171.7	3,501,688.4	1,994.5	1.7	1.4
11/30/2022 10:00	9.5	13.6	7.7	160.8	3,505,904.3	1,971.3	1.6	1.2
11/30/2022 11:00	9.8	13.6	7.9	171.2	3,451,476.1	1,965.9	1.7	1.4
11/30/2022 12:00	10.1	13.5	8.1	174.6	3,452,002.9	1,966.2	1.7	1.4
11/30/2022 13:00	10.4	13.5	8.3	172.0	3,405,186.4	1,964.4	1.7	1.4
11/30/2022 14:00	10.7	13.4	8.4	198.6	3,390,372.6	2,104.4	2.0	1.7
11/30/2022 15:00	10.7	13.3	8.3	202.7	3,364,962.3	2,113.2	2.1	1.7
11/30/2022 16:00	10.8	13.3	8.4	218.6	3,373,957.4	2,217.4	2.3	2.0
11/30/2022 17:00	10.8	13.2	8.3	223.4	3,372,505.2	2,265.7	2.3	2.0
11/30/2022 18:00	10.8	13.2	8.3	221.2	3,370,272.5	2,264.2	2.3	2.0
11/30/2022 19:00	10.7	13.2	8.2	225.1	3,369,677.1	2,263.8	2.3	2.0
11/30/2022 20:00	10.7	13.2	8.2	225.2	3,398,881.2	2,258.6	2.3	2.0
11/30/2022 21:00	10.6	13.2	8.1	220.2	3,385,217.1	2,224.8	2.3	2.0
11/30/2022 22:00	10.4	13.4	8.2	191.8	3,401,715.4	2,086.6	2.0	1.7
11/30/2022 23:00	13.5	14.1	11.7	171.8	3,014,445.4	1,584.9	1.9	1.1
Average/Sum#:	10.5	13.4	8.3	195.8	3,434,406.3	2,108.1	2.0	1.6
Minimum:	9.5	13.2	7.7	160.8	3,014,445.4	1,584.9	1.6	1.1
Maximum:	13.5	14.1	11.7	225.2	3,542,081.4	2,265.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 09:00	7.7	19.1	25.2	10.1	37,170.1	1.9	0.0	0.0
12/05/2022 10:00	44.9	16.7	63.1	84.6	1,497,449.6	470.2	0.0	0.0
12/05/2022 11:00	13.9	13.5	11.1	212.1	3,190,403.1	1,793.9	2.3	1.6
12/05/2022 12:00	11.1	13.3	8.6	221.9	3,369,571.0	2,140.7	2.3	1.9
12/05/2022 13:00	10.8	13.4	8.5	192.1	3,360,266.8	2,012.1	2.0	1.6
12/05/2022 14:00	10.9	13.4	8.6	202.1	3,394,001.4	2,032.3	2.1	1.6
12/05/2022 15:00	10.9	13.4	8.6	195.6	3,384,788.1	2,051.5	2.0	1.6
12/05/2022 16:00	11.0	13.3	8.5	214.4	3,375,246.4	2,193.6	2.2	1.8
12/05/2022 17:00	11.0	13.2	8.4	231.5	3,378,161.6	2,269.5	2.4	2.0
12/05/2022 18:00	10.9	13.2	8.4	229.6	3,381,138.6	2,271.5	2.4	2.0
12/05/2022 19:00	10.9	13.2	8.4	225.0	3,380,543.2	2,271.1	2.3	2.0
12/05/2022 20:00	10.8	13.2	8.3	220.4	3,419,196.9	2,272.1	2.3	2.0
12/05/2022 21:00	10.5	13.3	8.2	210.5	3,425,895.2	2,201.5	2.1	1.8
12/05/2022 22:00	10.3	13.4	8.1	195.0	3,451,951.5	2,067.0	2.0	1.7
12/05/2022 23:00	10.3	13.4	8.1	184.6	3,458,895.5	2,045.9	1.8	1.4
Average/Sum#:	13.1	13.9	13.3	188.6	3,033,645.3	1,873.0	1.9	1.5
Minimum:	7.7	13.2	8.1	10.1	37,170.1	1.9	0.0	0.0
Maximum:	44.9	19.1	63.1	231.5	3,458,895.5	2,272.1	2.4	2.0
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/06/2022 00:00	9.9	13.6	8.0	167.3	3,498,612.5	1,967.2	1.6	1.2
12/06/2022 01:00	9.9	13.6	8.0	172.9	3,496,656.2	1,966.1	1.7	1.4
12/06/2022 02:00	9.9	13.6	8.0	164.1	3,495,944.8	1,965.7	1.6	1.2
12/06/2022 03:00	9.8	13.6	7.9	167.3	3,498,256.8	1,967.0	1.6	1.2
12/06/2022 04:00	10.1	13.5	8.1	179.3	3,480,093.6	1,982.2	1.8	1.4
12/06/2022 05:00	10.2	13.6	8.2	180.3	3,439,480.5	2,009.3	1.8	1.4
12/06/2022 06:00	10.3	13.6	8.3	166.9	3,479,742.5	1,982.0	1.6	1.2
12/06/2022 07:00	10.7	13.4	8.4	196.6	3,481,344.0	2,084.6	2.0	1.7
12/06/2022 08:00	10.9	13.2	8.4	219.5	3,437,559.5	2,259.2	2.2	1.8
12/06/2022 09:00	10.7	13.3	8.3	215.3	3,446,795.0	2,240.1	2.2	1.8
12/06/2022 10:00	10.5	13.3	8.2	215.2	3,438,640.0	2,234.8	2.2	1.8
12/06/2022 11:00	10.6	13.3	8.2	220.4	3,432,177.6	2,230.6	2.2	1.8
12/06/2022 12:00	10.5	13.3	8.2	218.2	3,412,636.3	2,217.9	2.2	1.8
12/06/2022 13:00	9.6	13.7	7.9	161.8	3,355,652.5	1,788.8	1.7	1.3
12/06/2022 14:00	11.1	14.0	9.5	129.7	2,579,995.5	1,318.8	1.7	0.9
12/06/2022 15:00	11.2	14.0	9.6	127.2	2,579,604.3	1,318.6	1.7	0.9
12/06/2022 16:00	10.8	13.9	9.1	158.9	2,933,268.5	1,520.8	1.9	1.1
12/06/2022 17:00	9.7	13.8	8.1	158.3	3,468,257.5	1,823.5	1.6	1.1
12/06/2022 18:00	9.7	13.8	8.1	162.1	3,471,300.6	1,825.1	1.6	1.1
12/06/2022 19:00	9.9	13.7	8.1	157.5	3,479,288.9	1,829.3	1.5	1.1
12/06/2022 20:00	10.8	13.4	8.5	198.6	3,461,709.2	2,123.4	2.0	1.7
12/06/2022 21:00	10.8	13.2	8.3	219.0	3,417,252.4	2,220.9	2.2	1.8
12/06/2022 22:00	10.5	13.4	8.3	195.4	3,418,018.1	2,096.6	2.0	1.7
12/06/2022 23:00	9.9	13.6	8.0	166.7	3,501,280.2	1,968.7	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	179.9	3,362,648.6	1,955.9	1.8	1.4
Minimum:	9.6	13.2	7.9	127.2	2,579,604.3	1,318.6	1.5	0.9
Maximum:	11.2	14.0	9.6	220.4	3,501,280.2	2,259.2	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/07/2022 00:00	10.4	13.4	8.2	194.2	3,474,329.9	2,080.4	1.9	1.5
12/07/2022 01:00	9.8	13.5	7.8	175.2	3,482,376.0	1,983.5	1.7	1.4
12/07/2022 02:00	10.4	13.3	8.1	187.1	3,477,522.8	2,133.1	1.9	1.5
12/07/2022 03:00	10.4	13.3	8.1	193.6	3,489,749.8	2,140.6	1.9	1.5
12/07/2022 04:00	10.5	13.3	8.2	200.6	3,459,327.1	2,147.2	2.0	1.7
12/07/2022 05:00	10.6	13.3	8.2	186.7	3,441,395.3	2,161.2	1.9	1.5
12/07/2022 06:00	10.9	13.3	8.5	202.6	3,485,807.5	2,240.0	2.0	1.8
12/07/2022 07:00	10.5	13.3	8.2	213.7	3,447,410.5	2,240.5	2.2	1.8
12/07/2022 08:00	10.2	13.4	8.0	198.3	3,503,746.5	2,123.6	2.0	1.7
12/07/2022 09:00	10.3	13.3	8.0	200.8	3,522,192.1	2,160.5	2.0	1.7
12/07/2022 10:00	10.4	13.3	8.1	197.3	3,471,410.3	2,154.7	2.0	1.7
12/07/2022 11:00	10.4	13.3	8.1	200.9	3,467,060.3	2,152.0	2.0	1.7
12/07/2022 12:00	10.4	13.4	8.2	200.6	3,464,969.7	2,125.4	2.0	1.7
12/07/2022 13:00	10.4	13.4	8.2	202.0	3,431,875.3	2,105.1	2.0	1.7
12/07/2022 14:00	10.2	13.4	8.0	188.2	3,415,544.8	2,045.2	1.9	1.4
12/07/2022 15:00	10.3	13.4	8.1	189.4	3,420,096.2	2,072.9	1.9	1.5
12/07/2022 16:00	10.6	13.3	8.2	217.8	3,411,844.8	2,242.3	2.2	1.8
12/07/2022 17:00	10.5	13.2	8.0	223.4	3,405,653.1	2,263.1	2.3	2.0
12/07/2022 18:00	10.5	13.2	8.0	223.5	3,442,732.9	2,262.6	2.3	2.0
12/07/2022 19:00	10.4	13.2	8.0	221.9	3,438,016.0	2,259.5	2.3	2.0
12/07/2022 20:00	10.4	13.3	8.1	218.6	3,439,385.4	2,260.4	2.2	1.8
12/07/2022 21:00	10.3	13.3	8.0	213.2	3,469,567.5	2,254.9	2.1	1.8
12/07/2022 22:00	10.2	13.3	7.9	196.3	3,498,959.9	2,171.8	2.0	1.7
12/07/2022 23:00	10.3	13.3	8.0	197.8	3,497,993.2	2,171.2	2.0	1.7
Average/Sum#:	10.4	13.3	8.1	201.8	3,460,790.3	2,164.7	2.0	1.7
Minimum:	9.8	13.2	7.8	175.2	3,405,653.1	1,983.5	1.7	1.4
Maximum:	10.9	13.5	8.5	223.5	3,522,192.1	2,263.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/08/2022 00:00	10.3	13.3	8.0	198.2	3,511,501.1	2,128.3	2.0	1.7
12/08/2022 01:00	10.3	13.3	8.0	194.6	3,504,406.5	2,124.0	1.9	1.5
12/08/2022 02:00	10.3	13.3	8.0	190.1	3,506,716.4	2,125.4	1.9	1.5
12/08/2022 03:00	10.3	13.3	8.0	194.1	3,508,696.3	2,126.6	1.9	1.5
12/08/2022 04:00	10.5	13.3	8.2	201.5	3,508,008.8	2,151.8	2.0	1.7
12/08/2022 05:00	10.6	13.3	8.2	196.2	3,433,364.8	2,206.3	2.0	1.8
12/08/2022 06:00	11.0	13.2	8.4	215.3	3,503,110.7	2,276.7	2.1	1.8
12/08/2022 07:00	10.6	13.2	8.1	210.4	3,519,420.7	2,235.9	2.1	1.8
12/08/2022 08:00	10.3	13.5	8.2	195.0	3,524,621.0	2,033.3	1.9	1.4
12/08/2022 09:00	10.4	13.3	8.1	185.3	3,540,129.0	2,119.8	1.8	1.5
12/08/2022 10:00	10.5	13.3	8.2	196.8	3,506,386.4	2,125.2	1.9	1.5
12/08/2022 11:00	10.6	13.3	8.2	200.0	3,508,987.0	2,152.4	2.0	1.7
12/08/2022 12:00	10.6	13.3	8.2	195.5	3,457,877.1	2,146.3	2.0	1.7
12/08/2022 13:00	10.6	13.3	8.2	202.2	3,426,108.7	2,151.6	2.1	1.7
12/08/2022 14:00	10.7	13.3	8.3	206.0	3,430,089.6	2,154.1	2.1	1.7
12/08/2022 15:00	10.6	13.3	8.2	205.4	3,441,076.9	2,161.0	2.1	1.7
12/08/2022 16:00	10.6	13.2	8.1	217.2	3,389,701.6	2,252.5	2.2	1.8
12/08/2022 17:00	10.5	13.2	8.0	216.2	3,429,190.8	2,253.7	2.2	1.8
12/08/2022 18:00	10.6	13.2	8.1	222.0	3,402,342.4	2,260.9	2.3	2.0
12/08/2022 19:00	10.5	13.2	8.0	222.4	3,399,332.7	2,258.9	2.3	2.0
12/08/2022 20:00	10.5	13.2	8.0	222.0	3,401,740.5	2,260.5	2.3	2.0
12/08/2022 21:00	10.5	13.2	8.0	221.0	3,404,449.2	2,262.3	2.3	2.0
12/08/2022 22:00	10.5	13.3	8.2	201.7	3,424,033.2	2,175.3	2.1	1.7
12/08/2022 23:00	10.5	13.3	8.2	204.5	3,464,484.5	2,175.7	2.1	1.7
Average/Sum#:	10.5	13.3	8.1	204.7	3,464,407.3	2,179.9	2.1	1.7
Minimum:	10.3	13.2	8.0	185.3	3,389,701.6	2,033.3	1.8	1.4
Maximum:	11.0	13.5	8.4	222.4	3,540,129.0	2,276.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/09/2022 00:00	10.5	13.3	8.2	200.0	3,437,094.1	2,133.4	2.0	1.7
12/09/2022 01:00	10.3	13.4	8.1	189.3	3,507,951.7	2,049.3	1.9	1.4
12/09/2022 02:00	10.5	13.3	8.2	193.0	3,497,901.1	2,145.6	1.9	1.5
12/09/2022 03:00	10.5	13.3	8.2	194.7	3,491,706.1	2,141.8	1.9	1.5
12/09/2022 04:00	10.3	13.3	8.0	201.5	3,484,388.9	2,188.2	2.0	1.8
12/09/2022 05:00	10.5	13.2	8.0	194.5	3,467,686.9	2,279.0	2.0	1.8
12/09/2022 06:00	10.8	13.2	8.3	214.6	3,476,207.7	2,284.6	2.2	1.8
12/09/2022 07:00	10.5	13.2	8.0	211.9	3,498,340.8	2,273.6	2.1	1.8
12/09/2022 08:00	10.0	13.4	7.9	183.9	3,499,132.9	2,069.7	1.8	1.4
12/09/2022 09:00	10.0	13.5	8.0	183.6	3,508,499.9	2,024.0	1.8	1.4
12/09/2022 10:00	10.1	13.6	8.2	178.2	3,514,085.2	1,975.9	1.7	1.4
12/09/2022 11:00	10.4	13.4	8.2	193.1	3,502,007.0	2,071.4	1.9	1.4
12/09/2022 12:00	10.2	13.5	8.1	177.9	3,472,790.9	2,003.4	1.8	1.4
12/09/2022 13:00	10.6	13.3	8.2	201.2	3,459,166.0	2,147.1	2.0	1.7
12/09/2022 14:00	10.6	13.3	8.2	202.3	3,443,860.7	2,137.6	2.0	1.7
12/09/2022 15:00	10.3	13.4	8.1	178.2	3,442,158.1	2,036.0	1.8	1.4
12/09/2022 16:00	10.8	13.2	8.3	218.7	3,425,843.3	2,251.5	2.2	1.8
12/09/2022 17:00	10.7	13.2	8.2	219.8	3,425,234.7	2,251.1	2.2	1.8
12/09/2022 18:00	10.6	13.2	8.1	221.0	3,426,147.7	2,251.7	2.3	2.0
12/09/2022 19:00	10.6	13.2	8.1	222.9	3,429,038.7	2,253.6	2.3	2.0
12/09/2022 20:00	10.6	13.2	8.1	222.6	3,436,037.9	2,258.2	2.3	2.0
12/09/2022 21:00	10.6	13.2	8.1	218.6	3,434,668.5	2,257.3	2.2	1.8
12/09/2022 22:00	10.6	13.2	8.1	217.9	3,432,081.8	2,255.6	2.2	1.8
12/09/2022 23:00	10.6	13.2	8.1	217.3	3,422,191.5	2,249.1	2.2	1.8
Average/Sum#:	10.5	13.3	8.1	202.4	3,463,925.9	2,166.2	2.0	1.7
Minimum:	10.0	13.2	7.9	177.9	3,422,191.5	1,975.9	1.7	1.4
Maximum:	10.8	13.6	8.3	222.9	3,514,085.2	2,284.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/10/2022 00:00	10.0	13.5	8.0	180.5	3,434,516.4	2,006.4	1.8	1.4
12/10/2022 01:00	10.1	13.4	7.9	179.4	3,422,876.2	1,999.6	1.8	1.4
12/10/2022 02:00	10.0	13.5	8.0	165.1	3,447,087.0	1,963.4	1.6	1.2
12/10/2022 03:00	10.2	13.5	8.1	176.4	3,404,839.7	1,964.2	1.8	1.4
12/10/2022 04:00	10.2	13.5	8.1	167.7	3,395,825.8	1,959.0	1.7	1.4
12/10/2022 05:00	10.2	13.5	8.1	188.0	3,373,405.8	1,970.7	1.9	1.4
12/10/2022 06:00	10.6	13.5	8.5	166.1	3,394,612.4	1,958.3	1.7	1.4
12/10/2022 07:00	10.5	13.4	8.3	174.3	3,406,746.5	1,965.3	1.8	1.4
12/10/2022 08:00	10.6	13.4	8.3	175.7	3,390,593.3	2,005.5	1.8	1.4
12/10/2022 09:00	10.6	13.4	8.3	177.3	3,392,235.4	1,981.7	1.8	1.4
12/10/2022 10:00	10.5	13.4	8.3	170.0	3,394,439.0	1,958.2	1.7	1.4
12/10/2022 11:00	10.7	13.4	8.4	181.3	3,341,729.5	2,001.0	1.9	1.4
12/10/2022 12:00	10.7	13.3	8.3	196.3	3,340,280.8	2,097.7	2.0	1.7
12/10/2022 13:00	10.7	13.2	8.2	202.2	3,317,238.2	2,155.9	2.1	1.7
12/10/2022 14:00	10.5	13.4	8.3	183.6	3,303,777.6	2,002.4	1.9	1.4
12/10/2022 15:00	10.6	13.4	8.3	192.8	3,340,405.6	2,024.6	2.0	1.6
12/10/2022 16:00	10.6	13.3	8.2	195.2	3,334,707.6	2,094.2	2.0	1.7
12/10/2022 17:00	10.5	13.4	8.3	188.0	3,353,622.5	2,057.1	1.9	1.4
12/10/2022 18:00	10.5	13.3	8.2	193.3	3,355,252.8	2,058.1	2.0	1.6
12/10/2022 19:00	10.7	13.2	8.2	218.9	3,355,691.7	2,229.9	2.3	2.0
12/10/2022 20:00	10.5	13.3	8.2	201.9	3,351,666.2	2,153.8	2.1	1.7
12/10/2022 21:00	10.3	13.4	8.1	188.8	3,372,696.6	2,068.8	1.9	1.4
12/10/2022 22:00	10.2	13.4	8.0	186.2	3,397,017.8	2,009.3	1.9	1.4
12/10/2022 23:00	10.4	13.4	8.2	186.2	3,364,056.2	2,063.5	1.9	1.4
Average/Sum#:	10.4	13.4	8.2	184.8	3,374,388.4	2,031.2	1.9	1.5
Minimum:	10.0	13.2	7.9	165.1	3,303,777.6	1,958.2	1.6	1.2
Maximum:	10.7	13.5	8.5	218.9	3,447,087.0	2,229.9	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/11/2022 00:00	10.0	13.5	8.0	169.1	3,391,492.2	1,956.5	1.7	1.4
12/11/2022 01:00	10.0	13.5	8.0	172.5	3,431,461.5	1,954.5	1.7	1.4
12/11/2022 02:00	10.0	13.5	8.0	164.6	3,431,461.5	1,954.5	1.6	1.2
12/11/2022 03:00	10.0	13.5	8.0	170.5	3,428,828.0	1,953.0	1.7	1.4
12/11/2022 04:00	9.9	13.5	7.9	168.1	3,433,041.6	1,955.4	1.7	1.4
12/11/2022 05:00	9.9	13.5	7.9	186.3	3,434,095.0	1,956.0	1.9	1.4
12/11/2022 06:00	10.1	13.6	8.2	165.0	3,438,484.2	1,958.5	1.6	1.2
12/11/2022 07:00	9.9	13.6	8.0	160.2	3,441,995.5	1,960.5	1.6	1.2
12/11/2022 08:00	9.8	13.6	7.9	164.4	3,443,751.2	1,961.5	1.6	1.2
12/11/2022 09:00	9.8	13.5	7.8	170.9	3,449,018.2	1,964.5	1.7	1.4
12/11/2022 10:00	9.9	13.5	7.9	167.5	3,447,613.7	1,963.7	1.7	1.4
12/11/2022 11:00	10.0	13.5	8.0	174.7	3,440,766.5	1,959.8	1.7	1.4
12/11/2022 12:00	10.1	13.5	8.1	169.9	3,438,308.6	1,958.4	1.7	1.4
12/11/2022 13:00	10.2	13.5	8.1	170.3	3,398,599.3	1,960.6	1.7	1.4
12/11/2022 14:00	10.3	13.5	8.2	179.8	3,394,439.0	1,958.2	1.8	1.4
12/11/2022 15:00	10.6	13.4	8.3	185.1	3,423,728.0	2,050.1	1.9	1.4
12/11/2022 16:00	10.4	13.4	8.2	183.6	3,429,907.1	2,053.8	1.8	1.4
12/11/2022 17:00	10.5	13.3	8.2	201.2	3,421,627.7	2,123.8	2.0	1.7
12/11/2022 18:00	10.3	13.4	8.1	181.2	3,492,716.9	2,040.4	1.8	1.4
12/11/2022 19:00	10.4	13.4	8.2	185.4	3,496,935.1	2,068.4	1.8	1.4
12/11/2022 20:00	10.4	13.3	8.1	193.1	3,496,321.9	2,119.1	1.9	1.5
12/11/2022 21:00	10.2	13.5	8.1	178.6	3,516,084.9	2,002.7	1.7	1.4
12/11/2022 22:00	10.3	13.6	8.3	181.9	3,500,213.2	1,968.1	1.8	1.4
12/11/2022 23:00	10.3	13.6	8.3	185.1	3,496,300.5	1,965.9	1.8	1.4
Average/Sum#:	10.1	13.5	8.1	176.2	3,446,549.6	1,990.3	1.7	1.4
Minimum:	9.8	13.3	7.8	160.2	3,391,492.2	1,953.0	1.6	1.2
Maximum:	10.6	13.6	8.3	201.2	3,516,084.9	2,123.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/12/2022 00:00	10.2	13.6	8.2	174.6	3,511,773.2	1,974.6	1.7	1.4
12/12/2022 01:00	10.1	13.6	8.2	176.5	3,511,951.1	1,974.7	1.7	1.4
12/12/2022 02:00	10.0	13.6	8.1	169.4	3,511,773.2	1,974.6	1.7	1.4
12/12/2022 03:00	10.1	13.6	8.2	178.3	3,507,860.6	1,972.4	1.7	1.4
12/12/2022 04:00	9.8	13.6	7.9	171.9	3,513,018.2	1,975.3	1.7	1.4
12/12/2022 05:00	10.2	13.4	8.0	199.4	3,401,328.0	2,111.2	2.0	1.7
12/12/2022 06:00	10.7	13.3	8.3	204.5	3,511,777.4	2,205.4	2.0	1.8
12/12/2022 07:00	10.4	13.3	8.1	199.3	3,483,751.9	2,187.8	2.0	1.8
12/12/2022 08:00	10.1	13.4	7.9	178.0	3,506,571.7	2,074.1	1.8	1.5
12/12/2022 09:00	10.1	13.4	7.9	187.6	3,493,215.6	2,066.2	1.9	1.4
12/12/2022 10:00	9.6	13.6	7.8	162.5	3,509,639.1	1,973.4	1.6	1.2
12/12/2022 11:00	9.7	13.6	7.8	165.6	3,500,213.2	1,968.1	1.6	1.2
12/12/2022 12:00	9.8	13.6	7.9	169.4	3,492,921.4	1,964.0	1.7	1.4
12/12/2022 13:00	9.9	13.6	8.0	165.3	3,442,873.4	1,961.0	1.6	1.2
12/12/2022 14:00	9.9	13.6	8.0	167.6	3,430,056.9	1,953.7	1.7	1.4
12/12/2022 15:00	10.0	13.6	8.1	172.0	3,434,972.8	1,956.5	1.7	1.4
12/12/2022 16:00	10.5	13.4	8.3	194.4	3,434,677.5	2,131.9	2.0	1.7
12/12/2022 17:00	10.5	13.3	8.2	213.6	3,410,174.5	2,216.3	2.2	1.8
12/12/2022 18:00	10.5	13.3	8.2	224.4	3,424,012.4	2,275.3	2.3	2.0
12/12/2022 19:00	10.4	13.3	8.1	224.3	3,426,570.7	2,277.0	2.3	2.0
12/12/2022 20:00	10.4	13.3	8.1	225.6	3,432,590.1	2,281.0	2.3	2.1
12/12/2022 21:00	10.3	13.3	8.0	216.2	3,456,796.4	2,246.6	2.2	1.8
12/12/2022 22:00	10.3	13.3	8.0	201.4	3,485,344.3	2,188.8	2.0	1.8
12/12/2022 23:00	10.0	13.5	8.0	174.0	3,510,406.7	2,025.1	1.7	1.4
Average/Sum#:	10.1	13.5	8.1	188.2	3,472,677.9	2,080.6	1.9	1.6
Minimum:	9.6	13.3	7.8	162.5	3,401,328.0	1,953.7	1.6	1.2
Maximum:	10.7	13.6	8.3	225.6	3,513,018.2	2,281.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/13/2022 00:00	10.3	13.3	8.0	194.9	3,548,954.0	2,151.0	1.9	1.5
12/13/2022 01:00	10.3	13.3	8.0	199.0	3,517,138.3	2,157.4	2.0	1.7
12/13/2022 02:00	10.3	13.4	8.1	198.4	3,482,204.5	2,161.4	2.0	1.7
12/13/2022 03:00	10.4	13.4	8.2	192.2	3,499,205.4	2,146.4	1.9	1.5
12/13/2022 04:00	10.3	13.3	8.0	197.7	3,526,831.7	2,189.1	1.9	1.5
12/13/2022 05:00	10.4	13.3	8.1	219.1	3,498,648.5	2,273.8	2.2	1.8
12/13/2022 06:00	10.8	13.3	8.4	221.7	3,515,160.2	2,310.2	2.2	1.8
12/13/2022 07:00	10.5	13.3	8.2	223.6	3,481,076.8	2,287.8	2.3	2.1
12/13/2022 08:00	10.1	13.4	7.9	193.0	3,478,990.0	2,134.0	1.9	1.5
12/13/2022 09:00	9.9	13.5	7.9	176.7	3,484,751.7	2,010.3	1.8	1.4
12/13/2022 10:00	9.6	13.6	7.8	165.9	3,492,032.2	1,963.5	1.6	1.2
12/13/2022 11:00	9.8	13.6	7.9	173.3	3,496,834.1	1,966.2	1.7	1.4
12/13/2022 12:00	9.9	13.6	8.0	167.0	3,447,964.8	1,963.9	1.7	1.4
12/13/2022 13:00	9.9	13.6	8.0	166.8	3,439,010.9	1,958.8	1.7	1.4
12/13/2022 14:00	9.9	13.6	8.0	174.7	3,420,751.9	1,948.4	1.8	1.4
12/13/2022 15:00	10.3	13.5	8.2	185.1	3,433,414.1	2,055.9	1.9	1.4
12/13/2022 16:00	10.7	13.3	8.3	220.3	3,425,691.2	2,251.4	2.3	2.0
12/13/2022 17:00	10.5	13.3	8.2	224.6	3,417,842.5	2,271.2	2.3	2.0
12/13/2022 18:00	10.4	13.3	8.1	223.4	3,420,701.7	2,273.1	2.3	2.0
12/13/2022 19:00	10.3	13.3	8.0	223.6	3,455,057.7	2,270.7	2.3	2.0
12/13/2022 20:00	10.2	13.3	7.9	221.2	3,452,927.5	2,269.3	2.3	2.0
12/13/2022 21:00	10.2	13.3	7.9	219.9	3,498,956.2	2,274.0	2.2	1.8
12/13/2022 22:00	10.3	13.3	8.0	218.2	3,496,186.6	2,272.2	2.2	1.8
12/13/2022 23:00	10.3	13.3	8.0	215.6	3,450,949.4	2,268.0	2.2	1.8
Average/Sum#:	10.2	13.4	8.0	200.7	3,474,220.1	2,159.5	2.0	1.7
Minimum:	9.6	13.3	7.8	165.9	3,417,842.5	1,948.4	1.6	1.2
Maximum:	10.8	13.6	8.4	224.6	3,548,954.0	2,310.2	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/14/2022 00:00	10.1	13.3	7.8	198.1	3,482,159.6	2,186.8	2.0	1.7
12/14/2022 01:00	10.1	13.3	7.8	197.8	3,524,253.9	2,187.5	2.0	1.8
12/14/2022 02:00	10.1	13.3	7.8	200.8	3,525,703.9	2,188.4	2.0	1.8
12/14/2022 03:00	10.1	13.3	7.8	199.8	3,527,798.3	2,189.7	2.0	1.8
12/14/2022 04:00	10.1	13.3	7.8	198.9	3,522,481.7	2,186.4	2.0	1.7
12/14/2022 05:00	10.3	13.3	8.0	209.6	3,526,344.7	2,291.8	2.1	1.8
12/14/2022 06:00	10.6	13.3	8.2	207.6	3,534,499.7	2,297.1	2.0	1.8
12/14/2022 07:00	10.3	13.3	8.0	214.0	3,509,305.6	2,255.1	2.1	1.8
12/14/2022 08:00	9.9	13.4	7.8	182.7	3,542,700.9	2,069.6	1.8	1.4
12/14/2022 09:00	9.8	13.6	7.9	173.1	3,525,214.4	2,007.9	1.7	1.4
12/14/2022 10:00	9.9	13.5	7.9	175.8	3,508,326.6	2,023.9	1.7	1.4
12/14/2022 11:00	9.7	13.7	7.9	177.3	3,498,968.2	1,967.4	1.7	1.4
12/14/2022 12:00	9.6	13.7	7.9	161.3	3,499,501.8	1,967.7	1.6	1.2
12/14/2022 13:00	9.7	13.6	7.8	167.3	3,497,189.8	1,966.4	1.6	1.2
12/14/2022 14:00	9.6	13.6	7.8	168.5	3,489,186.6	1,961.9	1.7	1.4
12/14/2022 15:00	9.9	13.5	7.9	170.4	3,473,657.6	2,003.9	1.7	1.4
12/14/2022 16:00	10.4	13.3	8.1	205.3	3,457,717.9	2,196.7	2.1	1.8
12/14/2022 17:00	10.5	13.3	8.2	221.2	3,454,296.9	2,270.2	2.2	1.8
12/14/2022 18:00	10.5	13.3	8.2	222.4	3,444,406.6	2,263.7	2.3	2.0
12/14/2022 19:00	10.5	13.3	8.2	222.6	3,453,992.6	2,270.0	2.3	2.0
12/14/2022 20:00	10.4	13.3	8.1	218.7	3,453,688.3	2,269.8	2.2	1.8
12/14/2022 21:00	10.4	13.3	8.1	216.7	3,494,186.3	2,270.9	2.2	1.8
12/14/2022 22:00	10.3	13.3	8.0	211.7	3,501,524.8	2,250.1	2.1	1.8
12/14/2022 23:00	10.2	13.4	8.0	201.5	3,500,248.7	2,172.6	2.0	1.7
Average/Sum#:	10.1	13.4	8.0	196.8	3,497,806.5	2,154.8	2.0	1.7
Minimum:	9.6	13.3	7.8	161.3	3,444,406.6	1,961.9	1.6	1.2
Maximum:	10.6	13.7	8.2	222.6	3,542,700.9	2,297.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/15/2022 00:00	10.3	13.3	8.0	221.6	3,477,120.7	2,285.2	2.2	1.8
12/15/2022 01:00	10.3	13.3	8.0	222.3	3,490,814.9	2,294.2	2.2	1.8
12/15/2022 02:00	10.3	13.3	8.0	218.8	3,492,184.3	2,295.1	2.2	1.8
12/15/2022 03:00	10.3	13.3	8.0	217.7	3,494,771.0	2,296.8	2.2	1.8
12/15/2022 04:00	10.4	13.3	8.1	222.7	3,503,291.9	2,302.4	2.2	1.8
12/15/2022 05:00	10.5	13.3	8.2	240.5	3,469,609.7	2,305.6	2.4	2.1
12/15/2022 06:00	10.9	13.3	8.5	225.8	3,467,051.5	2,303.9	2.3	2.1
12/15/2022 07:00	10.6	13.3	8.2	226.8	3,496,140.5	2,297.7	2.3	2.1
12/15/2022 08:00	10.4	13.3	8.1	212.6	3,489,513.7	2,216.9	2.1	1.8
12/15/2022 09:00	10.5	13.3	8.2	211.8	3,439,900.7	2,210.5	2.2	1.8
12/15/2022 10:00	9.9	13.6	8.0	171.7	3,468,506.2	1,975.6	1.7	1.4
12/15/2022 11:00	10.1	13.5	8.1	182.9	3,439,162.0	1,984.0	1.8	1.4
12/15/2022 12:00	10.2	13.5	8.1	186.8	3,399,046.6	2,010.5	1.9	1.4
12/15/2022 13:00	10.5	13.5	8.4	186.2	3,427,449.4	2,027.3	1.9	1.4
12/15/2022 14:00	10.6	13.4	8.3	203.9	3,385,738.8	2,076.8	2.1	1.7
12/15/2022 15:00	10.6	13.3	8.2	225.9	3,384,456.3	2,224.3	2.3	2.0
12/15/2022 16:00	10.4	13.3	8.1	224.0	3,412,301.2	2,242.6	2.3	2.0
12/15/2022 17:00	10.4	13.3	8.1	222.0	3,408,953.8	2,240.4	2.3	2.0
12/15/2022 18:00	10.3	13.3	8.0	215.4	3,436,024.3	2,233.1	2.2	1.8
12/15/2022 19:00	10.4	13.3	8.1	213.6	3,431,716.0	2,230.3	2.2	1.8
12/15/2022 20:00	10.3	13.3	8.0	216.2	3,435,408.8	2,232.7	2.2	1.8
12/15/2022 21:00	10.2	13.3	7.9	216.2	3,483,317.7	2,238.4	2.2	1.8
12/15/2022 22:00	10.2	13.3	7.9	215.9	3,490,009.2	2,242.7	2.2	1.8
12/15/2022 23:00	10.2	13.3	7.9	212.1	3,510,606.0	2,230.3	2.1	1.8
Average/Sum#:	10.4	13.3	8.1	213.1	3,455,545.6	2,208.2	2.2	1.8
Minimum:	9.9	13.3	7.9	171.7	3,384,456.3	1,975.6	1.7	1.4
Maximum:	10.9	13.6	8.5	240.5	3,510,606.0	2,305.6	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/16/2022 00:00	10.0	13.6	8.1	176.3	3,500,283.8	1,993.7	1.7	1.4
12/16/2022 01:00	10.1	13.6	8.2	183.9	3,499,323.9	1,967.6	1.8	1.4
12/16/2022 02:00	10.1	13.6	8.2	175.3	3,498,079.0	1,966.9	1.7	1.4
12/16/2022 03:00	10.0	13.7	8.2	177.6	3,503,058.7	1,969.7	1.7	1.4
12/16/2022 04:00	10.0	13.7	8.2	175.0	3,501,102.4	1,968.6	1.7	1.4
12/16/2022 05:00	9.9	13.7	8.1	195.8	3,526,534.6	1,982.9	1.9	1.4
12/16/2022 06:00	10.6	13.5	8.5	193.4	3,530,609.9	2,114.1	1.9	1.5
12/16/2022 07:00	10.5	13.3	8.2	200.3	3,516,076.7	2,208.1	2.0	1.8
12/16/2022 08:00	10.3	13.4	8.1	193.6	3,535,259.8	2,142.7	1.9	1.5
12/16/2022 09:00	10.1	13.5	8.1	194.3	3,450,448.4	2,066.1	2.0	1.7
12/16/2022 10:00	10.9	13.9	9.2	154.3	2,975,894.2	1,542.9	1.8	1.1
12/16/2022 11:00	11.4	13.9	9.6	144.8	2,858,966.8	1,461.4	1.7	1.0
12/16/2022 12:00	11.1	14.0	9.5	134.0	2,590,950.9	1,324.4	1.8	0.9
12/16/2022 13:00	11.1	14.0	9.5	129.9	2,594,667.9	1,326.3	1.7	0.9
12/16/2022 14:00	11.0	13.9	9.3	160.3	3,062,688.7	1,587.9	1.8	1.1
12/16/2022 15:00	11.1	13.9	9.4	148.0	3,000,775.3	1,555.8	1.7	1.1
12/16/2022 16:00	10.7	13.4	8.4	200.3	3,459,004.9	2,147.0	2.0	1.7
12/16/2022 17:00	10.6	13.3	8.2	217.7	3,419,252.7	2,222.2	2.2	1.8
12/16/2022 18:00	10.4	13.4	8.2	200.7	3,463,838.1	2,150.0	2.0	1.7
12/16/2022 19:00	10.4	13.4	8.2	199.8	3,479,626.8	2,159.8	2.0	1.7
12/16/2022 20:00	10.6	13.3	8.2	223.4	3,413,975.0	2,243.7	2.3	2.0
12/16/2022 21:00	10.6	13.4	8.3	216.8	3,443,394.0	2,187.6	2.2	1.8
12/16/2022 22:00	9.9	13.5	7.9	185.1	3,486,020.1	2,087.4	1.8	1.5
12/16/2022 23:00	9.5	13.7	7.8	163.6	3,515,330.2	1,976.6	1.6	1.2
Average/Sum#:	10.5	13.6	8.5	181.0	3,326,048.5	1,931.4	1.9	1.4
Minimum:	9.5	13.3	7.8	129.9	2,590,950.9	1,324.4	1.6	0.9
Maximum:	11.4	14.0	9.6	223.4	3,535,259.8	2,243.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/17/2022 00:00	10.4	13.4	8.2	200.7	3,498,879.3	2,146.2	2.0	1.7
12/17/2022 01:00	10.4	13.4	8.2	200.4	3,503,118.0	2,148.8	2.0	1.7
12/17/2022 02:00	10.3	13.4	8.1	196.6	3,489,749.8	2,140.6	2.0	1.7
12/17/2022 03:00	10.3	13.4	8.1	193.2	3,510,291.2	2,153.2	1.9	1.5
12/17/2022 04:00	10.3	13.4	8.1	196.8	3,510,943.3	2,153.6	1.9	1.5
12/17/2022 05:00	10.4	13.4	8.2	202.5	3,507,356.7	2,151.4	2.0	1.7
12/17/2022 06:00	10.8	13.3	8.4	213.7	3,516,115.2	2,233.8	2.1	1.8
12/17/2022 07:00	10.2	13.4	8.0	186.0	3,505,726.4	2,099.2	1.8	1.5
12/17/2022 08:00	10.4	13.4	8.2	196.0	3,520,072.8	2,159.2	1.9	1.5
12/17/2022 09:00	10.2	13.4	8.0	192.9	3,493,187.1	2,117.2	1.9	1.5
12/17/2022 10:00	9.8	13.6	7.9	174.7	3,507,131.0	1,997.6	1.7	1.4
12/17/2022 11:00	9.6	13.6	7.8	169.4	3,493,632.8	1,964.4	1.7	1.4
12/17/2022 12:00	9.7	13.6	7.8	162.4	3,487,408.1	1,960.9	1.6	1.2
12/17/2022 13:00	9.8	13.6	7.9	169.3	3,435,148.4	1,956.6	1.7	1.4
12/17/2022 14:00	9.9	13.6	8.0	176.5	3,414,893.7	1,970.0	1.8	1.4
12/17/2022 15:00	10.3	13.4	8.1	190.6	3,424,050.0	2,100.3	1.9	1.5
12/17/2022 16:00	10.5	13.3	8.2	220.7	3,420,670.0	2,248.1	2.3	2.0
12/17/2022 17:00	10.3	13.3	8.0	214.2	3,412,482.5	2,217.8	2.2	1.8
12/17/2022 18:00	10.2	13.4	8.0	201.0	3,443,860.7	2,137.6	2.0	1.7
12/17/2022 19:00	10.3	13.3	8.0	223.1	3,400,988.0	2,260.0	2.3	2.0
12/17/2022 20:00	10.3	13.3	8.0	224.3	3,405,803.6	2,263.2	2.3	2.0
12/17/2022 21:00	10.3	13.3	8.0	222.0	3,408,060.9	2,264.7	2.3	2.0
12/17/2022 22:00	10.2	13.3	7.9	216.0	3,441,211.3	2,261.6	2.2	1.8
12/17/2022 23:00	10.0	13.4	7.9	200.4	3,471,650.0	2,180.2	2.0	1.7
Average/Sum#:	10.2	13.4	8.0	197.6	3,467,601.3	2,136.9	2.0	1.6
Minimum:	9.6	13.3	7.8	162.4	3,400,988.0	1,956.6	1.6	1.2
Maximum:	10.8	13.6	8.4	224.3	3,520,072.8	2,264.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/18/2022 00:00	10.0	13.4	7.9	193.8	3,476,544.6	2,132.5	1.9	1.5
12/18/2022 01:00	9.9	13.4	7.8	192.9	3,523,380.4	2,135.5	1.9	1.5
12/18/2022 02:00	9.7	13.5	7.7	169.2	3,504,339.7	2,021.6	1.7	1.4
12/18/2022 03:00	9.4	13.7	7.7	160.7	3,514,085.2	1,975.9	1.6	1.2
12/18/2022 04:00	10.2	13.4	8.0	193.2	3,523,380.4	2,135.5	1.9	1.5
12/18/2022 05:00	10.2	13.4	8.0	176.6	3,515,182.0	2,156.2	1.7	1.5
12/18/2022 06:00	10.5	13.3	8.2	189.4	3,497,832.1	2,171.1	1.9	1.5
12/18/2022 07:00	10.3	13.3	8.0	201.3	3,516,236.0	2,208.2	2.0	1.8
12/18/2022 08:00	10.1	13.4	7.9	196.3	3,440,390.0	2,085.2	2.0	1.7
12/18/2022 09:00	10.7	13.8	8.9	155.8	3,122,094.7	1,618.7	1.7	1.1
12/18/2022 10:00	11.0	13.8	9.1	155.6	3,011,383.5	1,561.3	1.8	1.1
12/18/2022 11:00	11.1	13.8	9.2	157.1	3,006,947.3	1,559.0	1.8	1.1
12/18/2022 12:00	11.4	13.9	9.6	137.4	2,717,439.5	1,408.9	1.7	1.0
12/18/2022 13:00	11.4	13.9	9.6	137.7	2,698,730.4	1,399.2	1.7	1.0
12/18/2022 14:00	11.0	13.8	9.1	172.2	3,169,735.3	1,643.4	1.9	1.2
12/18/2022 15:00	10.5	13.8	8.7	153.2	3,185,744.0	1,651.7	1.6	1.0
12/18/2022 16:00	10.6	13.4	8.3	198.4	3,432,421.9	2,130.5	2.0	1.7
12/18/2022 17:00	10.6	13.3	8.2	219.0	3,449,718.5	2,242.0	2.2	1.8
12/18/2022 18:00	10.5	13.3	8.2	222.7	3,453,079.7	2,269.4	2.3	2.0
12/18/2022 19:00	10.4	13.3	8.1	219.3	3,454,601.2	2,270.4	2.2	1.8
12/18/2022 20:00	10.2	13.3	7.9	207.4	3,480,049.7	2,236.3	2.1	1.8
12/18/2022 21:00	10.2	13.3	7.9	203.7	3,519,420.7	2,210.2	2.0	1.8
12/18/2022 22:00	10.2	13.3	7.9	203.1	3,541,331.5	2,198.1	2.0	1.8
12/18/2022 23:00	9.9	13.5	7.9	177.3	3,507,438.2	2,049.0	1.7	1.4
Average/Sum#:	10.4	13.5	8.3	183.1	3,344,229.4	1,977.9	1.9	1.5
Minimum:	9.4	13.3	7.7	137.4	2,698,730.4	1,399.2	1.6	1.0
Maximum:	11.4	13.9	9.6	222.7	3,541,331.5	2,270.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/19/2022 00:00	10.2	13.3	7.9	185.6	3,536,249.7	2,143.3	1.8	1.5
12/19/2022 01:00	10.2	13.3	7.9	192.8	3,510,943.3	2,153.6	1.9	1.5
12/19/2022 02:00	10.2	13.3	7.9	193.1	3,547,799.1	2,150.3	1.9	1.5
12/19/2022 03:00	10.2	13.3	7.9	186.8	3,549,779.0	2,151.5	1.8	1.5
12/19/2022 04:00	10.3	13.3	8.0	191.1	3,556,590.8	2,181.6	1.9	1.5
12/19/2022 05:00	10.4	13.2	8.0	222.3	3,533,422.6	2,296.4	2.2	1.8
12/19/2022 06:00	10.7	13.2	8.2	217.5	3,533,114.9	2,296.2	2.1	1.8
12/19/2022 07:00	10.4	13.2	8.0	216.5	3,532,037.8	2,295.5	2.1	1.8
12/19/2022 08:00	10.2	13.3	7.9	207.3	3,498,256.8	2,248.0	2.1	1.8
12/19/2022 09:00	10.2	13.3	7.9	208.4	3,512,729.2	2,257.3	2.1	1.8
12/19/2022 10:00	10.1	13.3	7.8	190.2	3,537,190.6	2,169.7	1.9	1.5
12/19/2022 11:00	10.1	13.3	7.8	188.4	3,542,244.4	2,172.8	1.8	1.5
12/19/2022 12:00	10.1	13.3	7.8	189.8	3,526,430.8	2,163.1	1.9	1.5
12/19/2022 13:00	10.1	13.3	7.8	193.6	3,512,736.6	2,154.7	1.9	1.5
12/19/2022 14:00	10.2	13.3	7.9	194.9	3,516,486.2	2,157.0	1.9	1.5
12/19/2022 15:00	10.3	13.3	8.0	200.9	3,532,955.7	2,218.7	2.0	1.8
12/19/2022 16:00	10.3	13.3	8.0	206.6	3,516,152.7	2,259.5	2.0	1.8
12/19/2022 17:00	10.2	13.3	7.9	209.0	3,524,244.8	2,264.7	2.1	1.8
12/19/2022 18:00	10.2	13.3	7.9	213.3	3,525,645.3	2,265.6	2.1	1.8
12/19/2022 19:00	10.2	13.3	7.9	214.4	3,523,466.7	2,264.2	2.1	1.8
12/19/2022 20:00	10.2	13.3	7.9	208.7	3,516,152.7	2,259.5	2.1	1.8
12/19/2022 21:00	10.2	13.3	7.9	206.1	3,516,464.0	2,259.7	2.0	1.8
12/19/2022 22:00	10.2	13.3	7.9	208.5	3,523,622.3	2,264.3	2.1	1.8
12/19/2022 23:00	10.2	13.3	7.9	212.1	3,522,533.0	2,263.6	2.1	1.8
Average/Sum#:	10.2	13.3	7.9	202.4	3,526,968.7	2,221.3	2.0	1.7
Minimum:	10.1	13.2	7.8	185.6	3,498,256.8	2,143.3	1.8	1.5
Maximum:	10.7	13.3	8.2	222.3	3,556,590.8	2,296.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/20/2022 00:00	10.1	13.3	7.8	195.8	3,541,755.3	2,172.5	1.9	1.5
12/20/2022 01:00	10.1	13.3	7.8	192.1	3,536,538.5	2,169.3	1.9	1.5
12/20/2022 02:00	10.2	13.3	7.9	189.3	3,542,896.5	2,173.2	1.9	1.5
12/20/2022 03:00	10.2	13.3	7.9	194.7	3,552,678.1	2,179.2	1.9	1.5
12/20/2022 04:00	10.2	13.3	7.9	196.7	3,561,807.6	2,184.8	1.9	1.5
12/20/2022 05:00	10.2	13.3	7.9	186.8	3,565,231.2	2,186.9	1.8	1.5
12/20/2022 06:00	10.7	13.3	8.3	204.2	3,547,898.5	2,279.9	2.0	1.8
12/20/2022 07:00	10.4	13.3	8.1	211.4	3,537,939.0	2,273.5	2.1	1.8
12/20/2022 08:00	10.2	13.3	7.9	195.2	3,527,409.0	2,163.7	1.9	1.5
12/20/2022 09:00	10.4	13.3	8.1	194.4	3,523,659.4	2,161.4	1.9	1.5
12/20/2022 10:00	10.4	13.3	8.1	189.5	3,498,631.8	2,120.5	1.9	1.5
12/20/2022 11:00	10.1	13.4	7.9	188.9	3,487,523.1	2,088.3	1.9	1.5
12/20/2022 12:00	9.3	13.7	7.6	163.0	3,487,763.8	1,961.1	1.6	1.2
12/20/2022 13:00	9.4	13.7	7.7	160.9	3,491,854.3	1,963.4	1.6	1.2
12/20/2022 14:00	9.5	13.6	7.7	161.5	3,482,250.6	1,958.0	1.6	1.2
12/20/2022 15:00	10.0	13.5	8.0	181.3	3,475,770.3	2,030.5	1.8	1.4
12/20/2022 16:00	10.4	13.3	8.1	208.4	3,477,701.0	2,184.0	2.1	1.7
12/20/2022 17:00	10.4	13.3	8.1	214.3	3,459,104.4	2,248.1	2.2	1.8
12/20/2022 18:00	10.3	13.3	8.0	214.1	3,456,796.4	2,246.6	2.2	1.8
12/20/2022 19:00	10.3	13.3	8.0	212.5	3,446,179.5	2,239.7	2.2	1.8
12/20/2022 20:00	10.3	13.3	8.0	214.3	3,449,410.8	2,241.8	2.2	1.8
12/20/2022 21:00	10.2	13.4	8.0	197.6	3,471,410.3	2,154.7	2.0	1.7
12/20/2022 22:00	10.2	13.4	8.0	198.1	3,473,988.0	2,156.3	2.0	1.7
12/20/2022 23:00	10.2	13.3	7.9	206.0	3,477,550.9	2,209.3	2.1	1.8
Average/Sum#:	10.2	13.4	7.9	194.6	3,503,072.8	2,156.1	1.9	1.6
Minimum:	9.3	13.3	7.6	160.9	3,446,179.5	1,958.0	1.6	1.2
Maximum:	10.7	13.7	8.3	214.3	3,565,231.2	2,279.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/21/2022 00:00	10.3	13.3	8.0	219.2	3,447,602.0	2,265.8	2.2	1.8
12/21/2022 01:00	10.2	13.3	7.9	218.5	3,443,645.9	2,263.2	2.2	1.8
12/21/2022 02:00	10.2	13.3	7.9	215.1	3,479,415.0	2,261.3	2.2	1.8
12/21/2022 03:00	10.2	13.3	7.9	215.5	3,488,339.3	2,267.1	2.2	1.8
12/21/2022 04:00	10.2	13.3	7.9	210.7	3,488,954.8	2,267.5	2.1	1.8
12/21/2022 05:00	10.3	13.3	8.0	236.9	3,481,876.9	2,262.9	2.4	2.0
12/21/2022 06:00	10.6	13.3	8.2	214.9	3,481,415.3	2,262.6	2.2	1.8
12/21/2022 07:00	10.4	13.3	8.1	214.7	3,478,030.2	2,260.4	2.2	1.8
12/21/2022 08:00	10.2	13.3	7.9	210.9	3,500,902.3	2,249.7	2.1	1.8
12/21/2022 09:00	10.3	13.3	8.0	208.9	3,478,804.8	2,235.5	2.1	1.8
12/21/2022 10:00	10.3	13.3	8.0	206.9	3,466,822.3	2,227.8	2.1	1.8
12/21/2022 11:00	10.3	13.3	8.0	202.6	3,455,042.0	2,195.0	2.0	1.8
12/21/2022 12:00	10.3	13.3	8.0	210.7	3,443,946.7	2,213.1	2.1	1.8
12/21/2022 13:00	10.3	13.3	8.0	212.9	3,436,632.7	2,208.4	2.2	1.8
12/21/2022 14:00	10.3	13.4	8.1	201.6	3,437,255.2	2,133.5	2.0	1.7
12/21/2022 15:00	10.4	13.3	8.1	211.5	3,431,341.8	2,205.0	2.2	1.8
12/21/2022 16:00	10.4	13.3	8.1	213.2	3,427,099.9	2,227.3	2.2	1.8
12/21/2022 17:00	10.5	13.3	8.2	214.9	3,437,562.9	2,234.1	2.2	1.8
12/21/2022 18:00	10.4	13.3	8.1	216.6	3,446,487.3	2,239.9	2.2	1.8
12/21/2022 19:00	10.4	13.3	8.1	219.6	3,448,641.4	2,241.3	2.2	1.8
12/21/2022 20:00	10.4	13.3	8.1	217.5	3,444,487.0	2,238.6	2.2	1.8
12/21/2022 21:00	10.4	13.3	8.1	215.6	3,444,487.0	2,238.6	2.2	1.8
12/21/2022 22:00	10.4	13.3	8.1	210.5	3,484,407.0	2,239.1	2.1	1.8
12/21/2022 23:00	10.4	13.3	8.1	208.8	3,485,340.7	2,239.7	2.1	1.8
Average/Sum#:	10.3	13.3	8.0	213.7	3,460,772.5	2,236.6	2.2	1.8
Minimum:	10.2	13.3	7.9	201.6	3,427,099.9	2,133.5	2.0	1.7
Maximum:	10.6	13.4	8.2	236.9	3,500,902.3	2,267.5	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/22/2022 00:00	10.3	13.3	8.0	202.7	3,470,535.4	2,179.5	2.0	1.7
12/22/2022 01:00	10.0	13.6	8.1	182.1	3,476,231.1	1,980.0	1.8	1.4
12/22/2022 02:00	10.3	13.6	8.3	178.7	3,488,297.4	1,961.4	1.8	1.4
12/22/2022 03:00	10.3	13.6	8.3	186.3	3,494,166.3	1,964.7	1.8	1.4
12/22/2022 04:00	10.4	13.4	8.2	185.1	3,541,568.1	2,094.8	1.8	1.5
12/22/2022 05:00	10.4	13.3	8.1	215.0	3,458,263.4	2,222.3	2.2	1.8
12/22/2022 06:00	10.7	13.2	8.2	209.5	3,519,109.4	2,261.4	2.1	1.8
12/22/2022 07:00	10.5	13.2	8.0	208.9	3,516,464.0	2,259.7	2.1	1.8
12/22/2022 08:00	10.3	13.3	8.0	203.4	3,483,628.9	2,238.6	2.0	1.8
12/22/2022 09:00	10.2	13.3	7.9	191.3	3,505,400.4	2,150.2	1.9	1.5
12/22/2022 10:00	10.2	13.3	7.9	193.2	3,539,219.6	2,145.1	1.9	1.5
12/22/2022 11:00	10.2	13.3	7.9	191.5	3,489,260.7	2,140.3	1.9	1.5
12/22/2022 12:00	10.3	13.3	8.0	187.6	3,484,859.0	2,137.6	1.9	1.5
12/22/2022 13:00	10.4	13.3	8.1	193.9	3,484,206.9	2,137.2	1.9	1.5
12/22/2022 14:00	10.4	13.3	8.1	196.7	3,496,433.9	2,144.7	2.0	1.7
12/22/2022 15:00	10.5	13.3	8.2	206.4	3,468,106.6	2,203.3	2.1	1.8
12/22/2022 16:00	10.5	13.3	8.2	202.1	3,460,393.8	2,198.4	2.0	1.8
12/22/2022 17:00	10.5	13.2	8.0	210.1	3,444,794.7	2,238.8	2.1	1.8
12/22/2022 18:00	10.5	13.2	8.0	213.8	3,450,026.2	2,242.2	2.2	1.8
12/22/2022 19:00	10.4	13.2	8.0	214.8	3,456,796.4	2,246.6	2.2	1.8
12/22/2022 20:00	10.3	13.3	8.0	213.1	3,452,026.5	2,243.5	2.2	1.8
12/22/2022 21:00	10.3	13.3	8.0	212.5	3,448,795.3	2,241.4	2.2	1.8
12/22/2022 22:00	10.3	13.3	8.0	203.3	3,463,227.0	2,200.2	2.0	1.8
12/22/2022 23:00	10.1	13.4	7.9	179.8	3,497,611.3	2,068.8	1.8	1.4
Average/Sum#:	10.3	13.3	8.1	199.2	3,482,892.6	2,162.5	2.0	1.7
Minimum:	10.0	13.2	7.9	178.7	3,444,794.7	1,961.4	1.8	1.4
Maximum:	10.7	13.6	8.3	215.0	3,541,568.1	2,261.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/23/2022 00:00	10.4	13.3	8.1	208.8	3,487,310.0	2,215.5	2.1	1.8
12/23/2022 01:00	10.4	13.2	8.0	216.4	3,465,413.0	2,252.2	2.2	1.8
12/23/2022 02:00	10.3	13.2	7.9	212.3	3,462,489.5	2,250.3	2.1	1.8
12/23/2022 03:00	10.3	13.2	7.9	212.0	3,455,257.7	2,245.6	2.1	1.8
12/23/2022 04:00	10.3	13.2	7.9	208.6	3,459,258.3	2,248.2	2.1	1.8
12/23/2022 05:00	10.4	13.3	8.1	228.3	3,448,487.6	2,241.2	2.3	2.0
12/23/2022 06:00	10.8	13.2	8.3	216.4	3,463,105.0	2,250.7	2.2	1.8
12/23/2022 07:00	10.6	13.2	8.1	213.8	3,474,758.8	2,232.9	2.2	1.8
12/23/2022 08:00	10.5	13.3	8.2	201.9	3,459,548.2	2,172.6	2.0	1.7
12/23/2022 09:00	10.5	13.3	8.2	202.3	3,444,898.5	2,163.4	2.0	1.7
12/23/2022 10:00	10.5	13.3	8.2	204.2	3,460,894.1	2,122.9	2.1	1.7
12/23/2022 11:00	10.6	13.3	8.2	205.3	3,422,272.1	2,124.2	2.1	1.7
12/23/2022 12:00	10.1	13.5	8.1	179.0	3,410,712.0	2,017.4	1.8	1.4
12/23/2022 13:00	9.9	13.6	8.0	174.5	3,423,561.0	1,950.0	1.8	1.4
12/23/2022 14:00	9.9	13.6	8.0	172.4	3,408,462.2	1,941.4	1.7	1.4
12/23/2022 15:00	10.5	13.4	8.3	188.0	3,423,060.0	2,049.7	1.9	1.4
12/23/2022 16:00	10.8	13.3	8.4	222.8	3,390,390.5	2,228.2	2.3	2.0
12/23/2022 17:00	10.6	13.3	8.2	222.1	3,394,346.6	2,230.8	2.3	2.0
12/23/2022 18:00	10.6	13.3	8.2	218.8	3,394,650.9	2,231.0	2.3	2.0
12/23/2022 19:00	10.6	13.3	8.2	215.7	3,430,177.3	2,229.3	2.2	1.8
12/23/2022 20:00	10.6	13.3	8.2	216.3	3,432,331.4	2,230.7	2.2	1.8
12/23/2022 21:00	10.6	13.3	8.2	220.6	3,399,672.1	2,234.3	2.3	2.0
12/23/2022 22:00	10.6	13.3	8.2	222.0	3,398,454.8	2,233.5	2.3	2.0
12/23/2022 23:00	10.5	13.3	8.2	218.2	3,424,484.2	2,225.6	2.2	1.8
Average/Sum#:	10.5	13.3	8.1	208.4	3,434,749.8	2,180.1	2.1	1.8
Minimum:	9.9	13.2	7.9	172.4	3,390,390.5	1,941.4	1.7	1.4
Maximum:	10.8	13.6	8.4	228.3	3,487,310.0	2,252.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/24/2022 00:00	10.4	13.3	8.1	197.1	3,413,894.4	2,119.0	2.0	1.7
12/24/2022 01:00	10.4	13.3	8.1	194.3	3,446,221.7	2,113.9	2.0	1.7
12/24/2022 02:00	9.9	13.6	8.0	183.6	3,443,575.6	1,961.4	1.8	1.4
12/24/2022 03:00	10.0	13.6	8.1	171.4	3,477,448.7	1,955.3	1.7	1.4
12/24/2022 04:00	10.0	13.6	8.1	178.1	3,473,358.2	1,953.0	1.8	1.4
12/24/2022 05:00	9.9	13.6	8.0	164.4	3,469,979.1	1,951.1	1.6	1.2
12/24/2022 06:00	10.2	13.5	8.1	167.3	3,467,101.6	1,974.8	1.7	1.4
12/24/2022 07:00	10.3	13.5	8.2	187.7	3,464,990.4	1,998.9	1.9	1.4
12/24/2022 08:00	10.4	13.7	8.5	168.8	3,304,457.1	1,833.9	1.7	1.3
12/24/2022 09:00	11.4	13.9	9.6	137.2	2,547,322.2	1,320.7	1.8	0.9
12/24/2022 10:00	11.3	13.8	9.4	163.6	3,008,297.5	1,559.7	1.9	1.1
12/24/2022 11:00	11.0	13.8	9.1	154.1	3,000,389.5	1,555.6	1.7	1.1
12/24/2022 12:00	10.9	13.8	9.1	156.2	2,999,039.4	1,554.9	1.8	1.1
12/24/2022 13:00	11.0	13.8	9.1	158.1	3,006,561.6	1,558.8	1.8	1.1
12/24/2022 14:00	9.9	13.8	8.2	162.4	3,338,502.3	1,730.9	1.7	1.2
12/24/2022 15:00	9.6	13.8	8.0	154.2	3,355,089.7	1,739.5	1.6	1.0
12/24/2022 16:00	10.7	13.8	8.9	160.1	3,074,647.1	1,594.1	1.8	1.1
12/24/2022 17:00	10.1	13.6	8.2	166.0	3,414,607.0	1,944.9	1.7	1.4
12/24/2022 18:00	9.9	13.6	8.0	172.4	3,412,500.2	1,943.7	1.7	1.4
12/24/2022 19:00	9.9	13.6	8.0	164.2	3,413,202.5	1,944.1	1.6	1.2
12/24/2022 20:00	9.9	13.6	8.0	172.7	3,419,522.9	1,947.7	1.7	1.4
12/24/2022 21:00	9.9	13.6	8.0	169.2	3,413,378.1	1,944.2	1.7	1.4
12/24/2022 22:00	9.6	13.6	7.8	162.4	3,462,509.5	1,946.9	1.6	1.2
12/24/2022 23:00	9.5	13.6	7.7	168.5	3,467,311.4	1,949.6	1.7	1.4
Average/Sum#:	10.3	13.6	8.3	168.1	3,303,912.8	1,837.4	1.8	1.3
Minimum:	9.5	13.3	7.7	137.2	2,547,322.2	1,320.7	1.6	0.9
Maximum:	11.4	13.9	9.6	197.1	3,477,448.7	2,119.0	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/25/2022 00:00	9.9	13.6	8.0	164.4	3,432,453.3	1,930.0	1.6	1.2
12/25/2022 01:00	25.6	16.1	31.5	196.1	1,528,070.9	591.4	4.2	0.9
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	17.8	14.9	19.8	180.3	2,480,262.1	1,260.7	2.9	1.1
Minimum:	9.9	13.6	8.0	164.4	1,528,070.9	591.4	1.6	0.9
Maximum:	25.6	16.1	31.5	196.1	3,432,453.3	1,930.0	4.2	1.2
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/26/2022 00:00	37.6	17.5	65.2	1.7	1,378,138.9	332.1	0.0	0.0
12/26/2022 01:00	37.1	15.1	37.7	217.7	2,289,772.0	969.8	3.1	1.2
12/26/2022 02:00	10.8	13.8	9.0	184.6	3,263,414.4	1,715.8	1.9	1.2
12/26/2022 03:00	11.0	13.8	9.1	179.2	3,301,834.3	1,736.0	1.9	1.2
12/26/2022 04:00	11.0	13.8	9.1	180.3	3,301,263.8	1,735.7	1.9	1.2
12/26/2022 05:00	10.9	13.8	9.1	173.5	3,329,983.6	1,750.8	1.8	1.2
12/26/2022 06:00	11.1	13.8	9.2	173.2	3,329,603.2	1,750.6	1.8	1.2
12/26/2022 07:00	11.0	13.8	9.1	174.4	3,313,816.8	1,742.3	1.8	1.2
12/26/2022 08:00	10.8	13.8	9.0	177.4	3,325,418.9	1,748.4	1.8	1.2
12/26/2022 09:00	11.5	13.8	9.6	151.6	3,016,205.4	1,563.8	1.7	1.1
12/26/2022 10:00	11.5	13.8	9.6	149.7	3,007,718.9	1,559.4	1.7	1.1
12/26/2022 11:00	11.5	13.8	9.6	149.5	2,989,974.2	1,550.2	1.7	1.1
12/26/2022 12:00	11.5	13.8	9.6	153.4	2,972,229.5	1,541.0	1.7	1.1
12/26/2022 13:00	11.3	13.8	9.4	153.2	3,012,347.9	1,561.8	1.7	1.1
12/26/2022 14:00	11.3	13.8	9.4	162.0	3,087,671.6	1,623.4	1.8	1.1
12/26/2022 15:00	10.6	13.8	8.8	173.2	3,330,554.2	1,751.1	1.8	1.2
12/26/2022 16:00	10.4	13.7	8.5	170.6	3,391,037.1	1,782.9	1.7	1.2
12/26/2022 17:00	10.6	13.4	8.3	179.1	3,429,919.0	2,103.9	1.8	1.5
12/26/2022 18:00	10.6	13.3	8.2	195.7	3,416,076.9	2,145.3	2.0	1.7
12/26/2022 19:00	9.9	13.5	7.9	174.0	3,430,579.3	2,004.1	1.8	1.4
12/26/2022 20:00	9.9	13.5	7.9	161.9	3,450,776.1	1,990.7	1.6	1.2
12/26/2022 21:00	9.8	13.6	7.9	165.3	3,441,293.2	1,960.1	1.6	1.2
12/26/2022 22:00	9.9	13.5	7.9	161.4	3,398,981.5	1,936.0	1.6	1.2
12/26/2022 23:00	23.8	16.1	29.3	179.7	1,555,717.8	602.1	3.8	0.9
Average/Sum#:	13.6	14.0	13.3	164.3	3,073,513.7	1,631.6	1.8	1.2
Minimum:	9.8	13.3	7.9	1.7	1,378,138.9	332.1	0.0	0.0
Maximum:	37.6	17.5	65.2	217.7	3,450,776.1	2,145.3	3.8	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 05:00	36.1	17.0	54.6	167.3	1,693,170.4	482.2	0.0	0.0
12/27/2022 06:00	24.0	14.3	21.5	195.0	2,459,984.2	1,185.6	2.6	1.2
12/27/2022 07:00	10.1	13.8	8.4	166.3	3,305,448.1	1,737.9	1.7	1.2
12/27/2022 08:00	10.7	13.7	8.8	166.1	3,216,459.0	1,714.6	1.8	1.2
12/27/2022 09:00	10.7	13.4	8.4	167.5	3,338,485.5	1,950.3	1.7	1.4
12/27/2022 10:00	11.0	13.4	8.7	196.7	3,334,034.8	1,947.7	2.0	1.6
12/27/2022 11:00	10.8	13.4	8.5	182.7	3,339,170.2	1,950.7	1.9	1.4
12/27/2022 12:00	10.7	13.4	8.4	172.9	3,336,260.2	1,949.0	1.8	1.4
12/27/2022 13:00	10.6	13.5	8.5	184.3	3,333,692.5	1,947.5	1.9	1.4
12/27/2022 14:00	10.5	13.5	8.4	174.5	3,334,548.4	1,948.0	1.8	1.4
12/27/2022 15:00	10.5	13.5	8.4	183.7	3,336,431.3	1,949.1	1.9	1.4
12/27/2022 16:00	10.5	13.5	8.4	176.8	3,339,512.5	1,950.9	1.8	1.4
12/27/2022 17:00	10.4	13.5	8.3	174.1	3,365,837.1	1,941.7	1.8	1.4
12/27/2022 18:00	10.3	13.5	8.2	175.3	3,403,019.6	1,938.3	1.8	1.4
12/27/2022 19:00	10.3	13.5	8.2	165.1	3,408,637.7	1,941.5	1.7	1.4
12/27/2022 20:00	10.2	13.5	8.1	175.5	3,423,912.1	1,950.2	1.8	1.4
12/27/2022 21:00	10.2	13.5	8.1	166.8	3,417,065.0	1,946.3	1.7	1.4
12/27/2022 22:00	10.0	13.6	8.1	168.8	3,383,356.1	1,927.1	1.7	1.3
12/27/2022 23:00	11.1	13.9	9.4	133.1	2,736,109.9	1,398.6	1.6	0.8
Average/Sum#:	12.6	13.8	11.5	173.3	3,184,480.8	1,776.7	1.7	1.3
Minimum:	10.0	13.4	8.1	133.1	1,693,170.4	482.2	0.0	0.0
Maximum:	36.1	17.0	54.6	196.7	3,423,912.1	1,950.9	2.6	1.6
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/28/2022 00:00	11.3	13.8	9.4	157.6	2,991,710.1	1,551.1	1.8	1.1
12/28/2022 01:00	11.5	13.8	9.6	147.6	2,842,616.4	1,473.8	1.8	1.0
12/28/2022 02:00	11.4	13.8	9.5	151.6	2,967,021.9	1,538.3	1.7	1.1
12/28/2022 03:00	11.3	13.8	9.4	147.3	2,965,478.9	1,537.5	1.7	1.1
12/28/2022 04:00	11.3	13.8	9.4	149.9	2,976,087.1	1,543.0	1.7	1.1
12/28/2022 05:00	10.8	13.8	9.0	186.3	3,301,073.6	1,735.6	1.9	1.2
12/28/2022 06:00	10.9	13.8	9.1	171.8	3,335,499.4	1,753.7	1.8	1.2
12/28/2022 07:00	10.7	13.8	8.9	173.2	3,340,824.9	1,756.5	1.8	1.2
12/28/2022 08:00	10.8	13.8	9.0	175.9	3,295,367.6	1,732.6	1.8	1.2
12/28/2022 09:00	10.8	13.8	9.0	177.1	3,278,630.2	1,723.8	1.8	1.2
12/28/2022 10:00	11.3	13.8	9.4	151.1	3,012,733.6	1,562.0	1.7	1.1
12/28/2022 11:00	11.3	13.8	9.4	153.7	3,043,401.0	1,577.9	1.7	1.1
12/28/2022 12:00	11.3	13.8	9.4	155.8	3,010,226.2	1,560.7	1.8	1.1
12/28/2022 13:00	11.2	13.8	9.3	153.4	2,961,235.6	1,535.3	1.8	1.1
12/28/2022 14:00	11.2	13.8	9.3	153.2	2,997,303.5	1,554.0	1.7	1.1
12/28/2022 15:00	10.7	13.8	8.9	153.0	3,045,637.9	1,601.3	1.7	1.1
12/28/2022 16:00	10.7	13.4	8.4	188.8	3,402,530.5	2,087.1	1.9	1.5
12/28/2022 17:00	10.0	13.5	8.0	166.6	3,423,214.3	1,974.8	1.7	1.4
12/28/2022 18:00	9.7	13.6	7.8	164.6	3,432,163.8	1,954.9	1.6	1.2
12/28/2022 19:00	9.6	13.6	7.8	164.2	3,434,621.7	1,956.3	1.6	1.2
12/28/2022 20:00	9.7	13.6	7.8	159.5	3,433,743.9	1,955.8	1.6	1.2
12/28/2022 21:00	9.8	13.5	7.8	171.5	3,411,253.5	1,967.9	1.7	1.4
12/28/2022 22:00	9.7	13.6	7.8	161.2	3,428,652.4	1,952.9	1.6	1.2
12/28/2022 23:00	9.7	13.6	7.8	159.5	3,436,904.1	1,957.6	1.6	1.2
Average/Sum#:	10.7	13.7	8.8	162.3	3,198,663.8	1,731.0	1.7	1.2
Minimum:	9.6	13.4	7.8	147.3	2,842,616.4	1,473.8	1.6	1.0
Maximum:	11.5	13.8	9.6	188.8	3,436,904.1	2,087.1	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/29/2022 00:00	9.6	13.6	7.8	165.2	3,429,003.5	1,953.1	1.7	1.4
12/29/2022 01:00	9.6	13.6	7.8	158.3	3,429,179.1	1,953.2	1.6	1.2
12/29/2022 02:00	9.6	13.6	7.8	162.2	3,430,056.9	1,953.7	1.6	1.2
12/29/2022 03:00	9.7	13.6	7.8	163.0	3,432,339.3	1,955.0	1.6	1.2
12/29/2022 04:00	9.7	13.6	7.8	159.0	3,436,728.5	1,957.5	1.6	1.2
12/29/2022 05:00	10.1	13.5	8.1	187.3	3,389,659.4	2,029.7	1.9	1.4
12/29/2022 06:00	10.5	13.4	8.3	177.6	3,447,230.0	2,039.0	1.8	1.4
12/29/2022 07:00	10.3	13.4	8.1	174.4	3,453,485.4	2,042.7	1.7	1.4
12/29/2022 08:00	10.6	13.3	8.2	201.4	3,440,088.5	2,185.5	2.0	1.7
12/29/2022 09:00	10.6	13.2	8.1	216.8	3,399,367.8	2,234.1	2.2	1.8
12/29/2022 10:00	10.4	13.3	8.1	193.3	3,411,140.6	2,142.2	2.0	1.7
12/29/2022 11:00	9.9	13.5	7.9	169.6	3,445,471.7	2,012.8	1.7	1.4
12/29/2022 12:00	9.8	13.5	7.8	171.2	3,424,601.0	1,975.6	1.7	1.4
12/29/2022 13:00	9.8	13.5	7.8	160.5	3,444,629.0	1,962.0	1.6	1.2
12/29/2022 14:00	10.0	13.5	8.0	173.1	3,416,800.5	1,971.1	1.7	1.4
12/29/2022 15:00	10.0	13.5	8.0	169.1	3,427,894.6	1,977.5	1.7	1.4
12/29/2022 16:00	10.5	13.3	8.2	187.6	3,435,605.3	2,082.3	1.9	1.5
12/29/2022 17:00	10.6	13.3	8.2	193.2	3,422,446.3	2,149.3	2.0	1.7
12/29/2022 18:00	10.2	13.4	8.0	187.2	3,403,102.1	2,062.6	1.9	1.4
12/29/2022 19:00	9.8	13.5	7.8	161.6	3,434,972.8	1,956.5	1.6	1.2
12/29/2022 20:00	10.0	13.5	8.0	168.4	3,447,262.5	1,963.5	1.7	1.4
12/29/2022 21:00	10.0	13.5	8.0	167.1	3,421,654.2	1,973.9	1.7	1.4
12/29/2022 22:00	10.1	13.5	8.1	166.4	3,394,265.7	1,958.1	1.7	1.4
12/29/2022 23:00	10.1	13.5	8.1	166.2	3,388,974.2	1,930.3	1.7	1.4
Average/Sum#:	10.1	13.5	8.0	175.0	3,425,248.3	2,017.6	1.8	1.4
Minimum:	9.6	13.2	7.8	158.3	3,388,974.2	1,930.3	1.6	1.2
Maximum:	10.6	13.6	8.3	216.8	3,453,485.4	2,234.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/30/2022 00:00	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
Minimum:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
Maximum:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/01/2022 00:00	8.6	13.0	6.4	131.1	3,371,118.2	2,166.3	1.3	1.1
10/01/2022 01:00	13.4	14.6	12.5	135.7	2,456,788.2	1,202.0	1.7	0.8
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	34.9	17.4	58.8	45.2	1,318,071.0	308.0	1.0	0.1
10/01/2022 13:00	36.8	17.1	57.1	253.8	1,393,111.7	376.4	5.6	0.8
10/01/2022 14:00	34.8	15.2	36.0	225.1	2,221,003.5	875.8	3.2	1.1
10/01/2022 15:00	7.1	13.8	5.9	87.1	2,848,604.1	1,414.5	1.0	0.6
10/01/2022 16:00	8.3	13.4	6.5	105.7	3,222,461.9	1,717.8	1.0	0.7
10/01/2022 17:00	9.4	12.8	6.8	157.8	3,324,903.5	2,258.0	1.5	1.4
10/01/2022 18:00	9.3	12.9	6.9	142.5	3,329,679.3	2,188.3	1.4	1.1
10/01/2022 19:00	8.9	13.1	6.7	120.5	3,343,870.4	2,026.7	1.2	1.0
10/01/2022 20:00	9.3	12.9	6.9	144.3	3,363,914.9	2,210.8	1.4	1.1
10/01/2022 21:00	8.9	13.1	6.7	131.0	3,150,165.2	1,932.3	1.3	1.0
10/01/2022 22:00	7.9	13.6	6.4	97.7	3,027,778.0	1,569.8	1.0	0.6
10/01/2022 23:00	19.9	15.8	23.0	152.8	1,630,131.8	630.9	2.9	0.7
Average/Sum#:	15.5	14.2	17.6	137.9	2,714,400.1	1,491.3	1.8	0.9
Minimum:	7.1	12.8	5.9	45.2	1,318,071.0	308.0	1.0	0.1
Maximum:	36.8	17.4	58.8	253.8	3,371,118.2	2,258.0	5.6	1.4
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	30.0	17.4	50.6	24.0	1,332,621.1	311.4	0.5	0.1
10/02/2022 12:00	34.7	17.1	53.9	246.1	1,496,743.8	404.4	4.9	0.8
10/02/2022 13:00	29.9	15.4	32.1	224.5	2,275,569.9	880.7	3.0	1.1
10/02/2022 14:00	8.3	13.5	6.6	108.4	3,338,116.6	1,730.7	1.0	0.7
10/02/2022 15:00	8.3	13.4	6.5	106.2	3,058,618.3	1,719.8	1.1	0.7
10/02/2022 16:00	9.3	12.9	6.9	136.3	3,360,782.9	2,184.2	1.3	1.1
10/02/2022 17:00	9.5	12.8	6.9	157.6	3,335,211.0	2,265.0	1.5	1.4
10/02/2022 18:00	9.6	12.8	7.0	154.5	3,343,457.0	2,270.6	1.5	1.4
10/02/2022 19:00	9.5	12.8	6.9	154.7	3,346,843.7	2,272.9	1.5	1.4
10/02/2022 20:00	9.4	12.8	6.8	153.4	3,348,905.2	2,274.3	1.5	1.4
10/02/2022 21:00	9.0	13.0	6.7	128.7	3,381,189.4	2,098.7	1.2	1.0
10/02/2022 22:00	8.7	13.2	6.7	123.9	3,193,096.9	1,912.0	1.2	1.0
10/02/2022 23:00	7.7	13.6	6.2	95.9	3,033,470.6	1,550.6	1.0	0.6
Average/Sum#:	14.1	13.9	15.7	139.6	2,911,125.1	1,682.7	1.6	1.0
Minimum:	7.7	12.8	6.2	24.0	1,332,621.1	311.4	0.5	0.1
Maximum:	34.7	17.4	53.9	246.1	3,381,189.4	2,274.3	4.9	1.4
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/03/2022 00:00	7.8	13.6	6.3	95.3	3,025,254.1	1,546.4	1.0	0.6
10/03/2022 01:00	7.9	13.6	6.4	95.9	3,032,883.7	1,550.3	1.0	0.6
10/03/2022 02:00	8.1	13.5	6.5	108.3	3,441,305.6	1,784.2	1.0	0.7
10/03/2022 03:00	7.8	13.6	6.3	98.6	3,096,659.8	1,582.9	1.0	0.6
10/03/2022 04:00	7.4	13.6	6.0	102.2	3,356,459.2	1,715.7	1.0	0.7
10/03/2022 05:00	7.4	13.6	6.0	102.1	3,352,350.9	1,713.6	1.0	0.7
10/03/2022 06:00	7.3	13.6	5.9	101.0	3,346,677.6	1,710.7	0.9	0.5
10/03/2022 07:00	7.7	13.6	6.2	103.1	3,347,460.1	1,711.1	1.0	0.7
10/03/2022 08:00	7.6	13.6	6.1	103.5	3,359,589.3	1,717.3	1.0	0.7
10/03/2022 09:00	7.6	13.7	6.2	103.4	3,368,979.6	1,722.1	1.0	0.7
10/03/2022 10:00	7.7	13.6	6.2	103.9	3,373,674.8	1,724.5	1.0	0.7
10/03/2022 11:00	7.7	13.6	6.2	104.1	3,374,066.0	1,724.7	1.0	0.7
10/03/2022 12:00	7.9	13.6	6.4	104.7	3,373,870.4	1,724.6	1.0	0.7
10/03/2022 13:00	8.0	13.6	6.5	105.1	3,375,239.8	1,725.3	1.0	0.7
10/03/2022 14:00	7.9	13.6	6.4	104.6	3,358,219.9	1,716.6	1.0	0.7
10/03/2022 15:00	8.1	13.5	6.5	106.9	3,384,792.7	1,754.9	1.0	0.7
10/03/2022 16:00	8.9	13.0	6.6	121.5	3,358,513.3	2,060.1	1.2	1.0
10/03/2022 17:00	8.9	12.9	6.6	131.6	3,339,087.5	2,170.1	1.3	1.1
10/03/2022 18:00	8.9	12.9	6.6	134.7	3,314,007.0	2,202.2	1.3	1.1
10/03/2022 19:00	8.8	12.9	6.5	131.7	3,348,011.8	2,175.9	1.3	1.1
10/03/2022 20:00	8.8	12.9	6.5	133.1	3,327,396.9	2,186.8	1.3	1.1
10/03/2022 21:00	8.7	12.9	6.4	131.5	3,352,474.0	2,178.8	1.3	1.1
10/03/2022 22:00	8.5	13.0	6.3	128.7	3,394,598.4	2,156.6	1.2	1.1
10/03/2022 23:00	8.5	13.0	6.3	130.4	3,383,100.7	2,174.0	1.2	1.1
Average/Sum#:	8.1	13.4	6.3	111.9	3,324,361.4	1,851.2	1.1	0.8
Minimum:	7.3	12.9	5.9	95.3	3,025,254.1	1,546.4	0.9	0.5
Maximum:	8.9	13.7	6.6	134.7	3,441,305.6	2,202.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/04/2022 00:00	8.4	13.0	6.3	128.6	3,393,968.8	2,156.2	1.2	1.1
10/04/2022 01:00	8.5	13.0	6.3	129.1	3,399,792.8	2,159.9	1.2	1.1
10/04/2022 02:00	8.5	13.0	6.3	128.9	3,397,746.5	2,158.6	1.2	1.1
10/04/2022 03:00	8.4	13.0	6.3	129.5	3,374,697.4	2,168.6	1.2	1.1
10/04/2022 04:00	8.5	13.0	6.3	130.8	3,396,639.3	2,182.7	1.2	1.1
10/04/2022 05:00	8.4	12.9	6.2	133.9	3,410,328.3	2,216.4	1.3	1.1
10/04/2022 06:00	8.4	12.9	6.2	131.3	3,471,013.1	2,179.8	1.2	1.1
10/04/2022 07:00	8.6	13.1	6.5	119.8	3,412,705.8	2,043.5	1.1	0.8
10/04/2022 08:00	7.5	13.6	6.1	97.1	3,059,409.8	1,586.2	1.0	0.6
10/04/2022 09:00	7.6	13.7	6.2	94.0	3,029,362.4	1,548.5	1.0	0.6
10/04/2022 10:00	7.9	13.6	6.4	95.2	1,018,353.8	1,554.2	3.2	1.9
10/04/2022 11:00	7.9	13.6	6.4	96.1	3,056,555.2	1,562.4	1.0	0.6
10/04/2022 12:00	7.9	13.6	6.4	104.2	3,339,439.2	1,707.0	1.0	0.7
10/04/2022 13:00	8.0	13.5	6.4	107.0	3,342,552.8	1,733.0	1.0	0.7
10/04/2022 14:00	8.8	13.1	6.7	117.9	3,372,625.1	2,019.5	1.1	0.8
10/04/2022 15:00	8.8	13.0	6.6	128.3	3,324,122.1	2,136.1	1.2	1.1
10/04/2022 16:00	8.7	12.9	6.4	127.7	3,312,295.2	2,128.5	1.2	1.1
10/04/2022 17:00	8.7	12.9	6.4	128.6	3,330,813.6	2,140.4	1.2	1.1
10/04/2022 18:00	8.7	12.9	6.4	131.1	3,338,779.7	2,169.9	1.3	1.1
10/04/2022 19:00	8.7	12.9	6.4	132.7	3,329,527.2	2,188.2	1.3	1.1
10/04/2022 20:00	8.7	12.8	6.3	139.2	3,338,418.5	2,242.8	1.4	1.1
10/04/2022 21:00	8.7	12.9	6.4	133.8	3,332,874.6	2,190.4	1.3	1.1
10/04/2022 22:00	8.6	12.9	6.3	131.1	3,352,935.6	2,179.1	1.3	1.1
10/04/2022 23:00	8.3	13.0	6.2	127.1	3,374,293.2	2,143.7	1.2	1.1
Average/Sum#:	8.4	13.1	6.4	121.8	3,325,691.1	2,020.7	1.2	1.0
Minimum:	7.5	12.8	6.1	94.0	3,029,362.4	1,548.5	1.0	0.6
Maximum:	8.8	13.7	6.7	139.2	3,471,013.1	2,242.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/05/2022 00:00	8.4	13.0	6.3	126.6	3,363,117.4	2,136.6	1.2	1.1
10/05/2022 01:00	8.2	13.1	6.2	114.8	3,373,855.9	1,995.6	1.1	0.8
10/05/2022 02:00	8.2	13.2	6.3	112.1	3,416,973.9	1,971.2	1.0	0.8
10/05/2022 03:00	8.4	13.0	6.3	121.9	3,404,812.9	2,088.5	1.1	0.8
10/05/2022 04:00	8.4	13.0	6.3	124.5	3,372,127.9	2,117.7	1.2	1.1
10/05/2022 05:00	8.5	12.9	6.3	133.1	3,392,479.6	2,204.8	1.3	1.1
10/05/2022 06:00	8.4	12.9	6.2	134.1	3,433,520.4	2,206.4	1.3	1.1
10/05/2022 07:00	8.4	13.2	6.4	115.8	3,389,838.9	1,980.3	1.1	0.8
10/05/2022 08:00	7.4	13.6	6.0	102.2	3,330,244.5	1,702.3	1.0	0.7
10/05/2022 09:00	7.4	13.7	6.1	100.4	3,262,360.1	1,667.6	1.0	0.7
10/05/2022 10:00	7.6	13.6	6.1	102.2	3,313,811.4	1,693.9	1.0	0.7
10/05/2022 11:00	7.8	13.6	6.3	103.3	3,338,069.8	1,706.3	1.0	0.7
10/05/2022 12:00	8.0	13.6	6.5	105.1	3,323,265.1	1,723.0	1.0	0.7
10/05/2022 13:00	8.8	13.0	6.6	121.7	3,365,197.4	2,064.2	1.2	1.0
10/05/2022 14:00	8.9	12.9	6.6	132.4	3,319,180.4	2,181.4	1.3	1.1
10/05/2022 15:00	8.7	12.9	6.4	128.1	3,322,410.3	2,135.0	1.2	1.1
10/05/2022 16:00	8.8	12.9	6.5	130.1	3,319,238.5	2,157.2	1.3	1.1
10/05/2022 17:00	8.8	12.8	6.4	134.5	3,304,827.4	2,196.1	1.3	1.1
10/05/2022 18:00	8.9	12.8	6.5	138.3	3,320,854.1	2,231.0	1.4	1.1
10/05/2022 19:00	8.8	12.8	6.4	140.0	3,330,678.3	2,237.6	1.4	1.1
10/05/2022 20:00	8.6	12.9	6.3	132.5	3,329,679.3	2,188.3	1.3	1.1
10/05/2022 21:00	8.7	12.8	6.3	138.6	3,326,063.9	2,234.5	1.4	1.1
10/05/2022 22:00	8.5	12.9	6.3	129.8	3,366,605.4	2,163.4	1.2	1.1
10/05/2022 23:00	8.5	12.9	6.3	130.0	3,381,233.3	2,172.8	1.2	1.1
Average/Sum#:	8.4	13.1	6.3	123.0	3,350,018.6	2,048.2	1.2	1.0
Minimum:	7.4	12.8	6.0	100.4	3,262,360.1	1,667.6	1.0	0.7
Maximum:	8.9	13.7	6.6	140.0	3,433,520.4	2,237.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/06/2022 00:00	8.4	13.0	6.3	128.8	3,403,570.5	2,162.3	1.2	1.1
10/06/2022 01:00	8.4	12.9	6.2	129.1	3,371,273.8	2,166.4	1.2	1.1
10/06/2022 02:00	8.5	12.9	6.3	129.2	3,368,161.5	2,164.4	1.2	1.1
10/06/2022 03:00	8.4	13.0	6.3	126.8	3,373,033.9	2,142.9	1.2	1.1
10/06/2022 04:00	8.3	12.9	6.1	131.5	3,361,090.6	2,184.4	1.3	1.1
10/06/2022 05:00	8.5	12.9	6.3	137.7	3,380,220.9	2,246.2	1.3	1.1
10/06/2022 06:00	8.5	12.9	6.3	140.2	3,398,150.5	2,233.3	1.3	1.1
10/06/2022 07:00	8.7	13.0	6.5	127.7	3,393,465.5	2,131.1	1.2	1.1
10/06/2022 08:00	8.4	13.0	6.3	122.1	3,395,520.4	2,082.8	1.2	1.0
10/06/2022 09:00	8.4	13.1	6.4	120.8	3,407,721.8	2,065.4	1.1	0.8
10/06/2022 10:00	8.5	13.0	6.3	122.3	3,385,575.7	2,076.7	1.2	1.0
10/06/2022 11:00	8.6	13.0	6.4	125.7	3,365,599.3	2,113.6	1.2	1.1
10/06/2022 12:00	8.7	12.9	6.4	128.4	3,334,081.5	2,142.5	1.2	1.1
10/06/2022 13:00	8.8	12.9	6.5	134.1	3,345,503.8	2,198.7	1.3	1.1
10/06/2022 14:00	8.8	12.9	6.5	135.6	3,321,230.3	2,207.0	1.3	1.1
10/06/2022 15:00	8.7	12.9	6.4	130.5	3,321,854.3	2,158.9	1.3	1.1
10/06/2022 16:00	8.8	12.9	6.5	135.2	3,343,677.9	2,197.5	1.3	1.1
10/06/2022 17:00	8.8	12.8	6.4	143.2	3,342,586.3	2,245.6	1.4	1.1
10/06/2022 18:00	8.8	12.8	6.4	141.7	3,336,930.0	2,241.8	1.4	1.1
10/06/2022 19:00	8.8	12.8	6.4	142.8	3,351,963.9	2,251.9	1.4	1.1
10/06/2022 20:00	8.8	12.8	6.4	144.5	3,354,643.2	2,253.7	1.4	1.1
10/06/2022 21:00	8.7	12.9	6.4	142.0	3,376,157.8	2,243.5	1.4	1.1
10/06/2022 22:00	8.6	12.9	6.3	133.8	3,369,091.7	2,189.6	1.3	1.1
10/06/2022 23:00	8.6	13.0	6.4	130.4	3,375,164.3	2,168.9	1.2	1.1
Average/Sum#:	8.6	12.9	6.4	132.7	3,365,677.9	2,177.9	1.3	1.1
Minimum:	8.3	12.8	6.1	120.8	3,321,230.3	2,065.4	1.1	0.8
Maximum:	8.8	13.1	6.5	144.5	3,407,721.8	2,253.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/07/2022 00:00	8.4	13.0	6.3	127.6	3,415,440.0	2,144.9	1.2	1.1
10/07/2022 01:00	8.5	13.0	6.3	128.8	3,397,589.1	2,158.5	1.2	1.1
10/07/2022 02:00	8.5	13.0	6.3	127.9	3,409,389.0	2,141.1	1.2	1.1
10/07/2022 03:00	8.5	13.0	6.3	125.3	3,407,450.1	2,115.0	1.2	1.1
10/07/2022 04:00	8.5	13.0	6.3	128.7	3,392,552.2	2,155.3	1.2	1.1
10/07/2022 05:00	8.4	13.0	6.3	131.4	3,410,333.6	2,191.5	1.2	1.1
10/07/2022 06:00	8.4	12.9	6.2	133.4	3,431,030.5	2,204.8	1.3	1.1
10/07/2022 07:00	8.8	13.1	6.7	126.1	3,401,972.4	2,111.6	1.2	1.1
10/07/2022 08:00	8.5	13.1	6.4	117.9	3,392,832.4	2,031.6	1.1	0.8
10/07/2022 09:00	8.5	13.0	6.3	126.7	3,395,694.8	2,132.5	1.2	1.1
10/07/2022 10:00	8.6	13.0	6.4	126.8	3,387,255.3	2,127.2	1.2	1.1
10/07/2022 11:00	8.6	13.0	6.4	126.2	3,371,013.3	2,117.0	1.2	1.1
10/07/2022 12:00	8.7	12.9	6.4	131.9	3,346,011.5	2,174.6	1.3	1.1
10/07/2022 13:00	8.7	13.0	6.5	130.3	3,341,395.5	2,147.2	1.3	1.1
10/07/2022 14:00	8.8	12.9	6.5	134.9	3,339,265.3	2,194.6	1.3	1.1
10/07/2022 15:00	8.8	12.9	6.5	136.7	3,316,414.8	2,203.8	1.3	1.1
10/07/2022 16:00	8.8	12.9	6.5	134.2	3,329,831.5	2,188.4	1.3	1.1
10/07/2022 17:00	8.8	12.8	6.4	142.8	3,331,869.1	2,238.4	1.4	1.1
10/07/2022 18:00	8.8	12.9	6.5	144.3	3,346,307.6	2,248.1	1.4	1.1
10/07/2022 19:00	8.8	12.9	6.5	144.6	3,355,536.3	2,254.3	1.4	1.1
10/07/2022 20:00	8.7	12.9	6.4	145.0	3,362,681.1	2,259.1	1.4	1.1
10/07/2022 21:00	8.7	12.9	6.4	144.6	3,367,146.6	2,262.1	1.4	1.1
10/07/2022 22:00	8.6	12.9	6.3	143.6	3,358,662.2	2,256.4	1.4	1.1
10/07/2022 23:00	8.5	13.0	6.3	132.3	3,371,861.3	2,191.4	1.3	1.1
Average/Sum#:	8.6	13.0	6.4	133.0	3,374,147.3	2,177.1	1.3	1.1
Minimum:	8.4	12.8	6.2	117.9	3,316,414.8	2,031.6	1.1	0.8
Maximum:	8.8	13.1	6.7	145.0	3,431,030.5	2,262.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/08/2022 00:00	8.5	13.0	6.3	130.2	3,390,881.5	2,179.0	1.2	1.1
10/08/2022 01:00	8.5	13.0	6.3	130.3	3,382,633.8	2,173.7	1.2	1.1
10/08/2022 02:00	8.5	13.0	6.3	129.9	3,409,079.7	2,165.8	1.2	1.1
10/08/2022 03:00	8.5	13.0	6.3	130.9	3,390,570.3	2,178.8	1.2	1.1
10/08/2022 04:00	8.6	13.0	6.4	131.4	3,402,397.1	2,186.4	1.2	1.1
10/08/2022 05:00	8.5	13.0	6.3	130.1	3,423,561.0	2,175.0	1.2	1.1
10/08/2022 06:00	8.4	13.0	6.3	128.9	3,487,907.4	2,114.0	1.2	1.1
10/08/2022 07:00	7.7	13.6	6.2	104.0	3,234,884.7	1,700.8	1.0	0.7
10/08/2022 08:00	7.7	13.7	6.3	86.9	2,695,384.4	1,358.1	1.0	0.5
10/08/2022 09:00	7.4	13.8	6.1	82.9	2,637,350.3	1,309.6	1.0	0.5
10/08/2022 10:00	7.2	13.8	6.0	84.1	2,636,141.9	1,309.0	1.0	0.5
10/08/2022 11:00	7.3	13.8	6.1	84.0	2,646,614.0	1,314.2	1.0	0.5
10/08/2022 12:00	7.7	13.7	6.3	95.1	3,050,099.4	1,559.1	1.0	0.6
10/08/2022 13:00	7.9	13.6	6.4	104.4	3,348,047.0	1,711.4	1.0	0.7
10/08/2022 14:00	8.0	13.5	6.4	105.6	3,333,873.3	1,728.5	1.0	0.7
10/08/2022 15:00	8.9	13.0	6.6	124.9	3,333,433.7	2,093.4	1.2	1.0
10/08/2022 16:00	8.9	12.9	6.6	135.9	3,305,278.8	2,196.4	1.3	1.1
10/08/2022 17:00	8.8	12.9	6.5	136.4	3,312,050.7	2,200.9	1.3	1.1
10/08/2022 18:00	8.7	12.9	6.4	132.8	3,337,856.5	2,169.3	1.3	1.1
10/08/2022 19:00	8.7	12.9	6.4	132.5	3,348,627.3	2,176.3	1.3	1.1
10/08/2022 20:00	8.6	12.9	6.3	132.2	3,359,551.9	2,183.4	1.3	1.1
10/08/2022 21:00	8.7	12.9	6.4	132.6	3,358,628.7	2,182.8	1.3	1.1
10/08/2022 22:00	8.6	13.0	6.4	131.8	3,390,881.5	2,179.0	1.3	1.1
10/08/2022 23:00	8.4	13.0	6.3	129.9	3,426,866.5	2,177.1	1.2	1.1
Average/Sum#:	8.3	13.2	6.3	118.7	3,235,108.4	1,946.8	1.2	0.9
Minimum:	7.2	12.9	6.0	82.9	2,636,141.9	1,309.0	1.0	0.5
Maximum:	8.9	13.8	6.6	136.4	3,487,907.4	2,200.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/09/2022 00:00	8.5	13.0	6.3	129.8	3,382,633.8	2,173.7	1.2	1.1
10/09/2022 01:00	8.5	13.0	6.3	130.0	3,425,922.0	2,176.5	1.2	1.1
10/09/2022 02:00	8.3	13.0	6.2	127.2	3,418,783.9	2,147.0	1.2	1.1
10/09/2022 03:00	8.3	13.0	6.2	127.5	3,437,255.2	2,158.6	1.2	1.1
10/09/2022 04:00	8.4	13.0	6.3	128.8	3,407,820.4	2,165.0	1.2	1.1
10/09/2022 05:00	8.4	13.0	6.3	128.2	3,393,654.0	2,156.0	1.2	1.1
10/09/2022 06:00	8.1	13.1	6.1	140.1	3,200,268.7	1,682.6	1.5	1.0
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 14:00	34.3	17.2	54.7	100.7	1,594,342.0	384.2	1.8	0.3
10/09/2022 15:00	22.4	14.2	19.7	173.8	2,801,328.8	1,309.2	2.0	1.0
10/09/2022 16:00	7.7	13.6	6.2	103.9	3,353,915.9	1,714.4	1.0	0.7
10/09/2022 17:00	8.3	13.4	6.5	107.9	3,356,611.3	1,764.8	1.0	0.7
10/09/2022 18:00	8.8	13.0	6.6	123.1	3,350,095.4	2,079.4	1.2	1.0
10/09/2022 19:00	8.9	12.9	6.6	135.0	3,322,283.7	2,207.7	1.3	1.1
10/09/2022 20:00	8.7	12.9	6.4	133.0	3,362,013.8	2,185.0	1.3	1.1
10/09/2022 21:00	8.7	13.0	6.5	131.4	3,382,167.0	2,173.4	1.3	1.1
10/09/2022 22:00	8.5	13.0	6.3	128.9	3,394,913.2	2,156.8	1.2	1.1
10/09/2022 23:00	8.5	13.0	6.3	127.9	3,381,848.6	2,148.5	1.2	1.1
Average/Sum#:	10.8	13.4	10.0	128.1	3,233,285.7	1,928.4	1.3	1.0
Minimum:	7.7	12.9	6.1	100.7	1,594,342.0	384.2	1.0	0.3
Maximum:	34.3	17.2	54.7	173.8	3,437,255.2	2,207.7	2.0	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/10/2022 00:00	8.3	13.0	6.2	125.2	3,381,204.3	2,123.4	1.2	1.1
10/10/2022 01:00	8.1	13.1	6.1	121.5	3,415,898.7	2,095.3	1.1	0.8
10/10/2022 02:00	8.0	13.2	6.1	111.8	3,434,655.0	1,981.4	1.0	0.8
10/10/2022 03:00	8.2	13.1	6.2	120.8	3,413,290.3	2,093.7	1.1	0.8
10/10/2022 04:00	8.2	13.0	6.1	124.3	3,446,438.4	2,139.2	1.2	1.1
10/10/2022 05:00	8.3	12.9	6.1	132.5	3,424,330.3	2,225.5	1.3	1.1
10/10/2022 06:00	8.2	12.9	6.0	134.4	3,447,992.7	2,215.7	1.3	1.1
10/10/2022 07:00	7.8	13.4	6.1	110.4	3,292,278.8	1,803.1	1.1	0.7
10/10/2022 08:00	7.5	13.7	6.1	93.7	3,016,646.3	1,542.0	1.0	0.6
10/10/2022 09:00	7.5	13.7	6.1	92.8	3,047,862.4	1,535.7	1.0	0.6
10/10/2022 10:00	7.1	13.8	5.9	83.1	2,799,465.9	1,390.1	0.9	0.4
10/10/2022 11:00	7.3	13.8	6.1	92.4	3,101,448.5	1,562.7	0.9	0.5
10/10/2022 12:00	7.3	13.8	6.1	93.6	3,175,453.5	1,576.8	0.9	0.5
10/10/2022 13:00	8.1	13.7	6.6	103.4	3,334,744.0	1,704.6	1.0	0.7
10/10/2022 14:00	7.7	13.6	6.2	102.9	3,349,025.1	1,711.9	1.0	0.7
10/10/2022 15:00	8.6	13.6	7.0	99.6	3,099,789.9	1,584.5	1.0	0.6
10/10/2022 16:00	8.7	13.2	6.7	117.4	3,302,341.5	1,953.3	1.1	0.8
10/10/2022 17:00	8.8	13.0	6.6	130.6	3,323,239.1	2,159.8	1.3	1.1
10/10/2022 18:00	8.8	12.9	6.5	134.2	3,339,113.1	2,194.5	1.3	1.1
10/10/2022 19:00	8.8	12.9	6.5	131.9	3,340,933.9	2,171.3	1.3	1.1
10/10/2022 20:00	8.8	12.9	6.5	131.1	3,366,294.1	2,163.2	1.3	1.1
10/10/2022 21:00	8.7	13.0	6.5	125.9	3,358,752.2	2,109.3	1.2	1.1
10/10/2022 22:00	8.5	13.1	6.4	123.7	3,410,355.8	2,091.9	1.2	1.0
10/10/2022 23:00	8.3	13.2	6.4	113.0	3,376,064.5	1,947.6	1.1	0.8
Average/Sum#:	8.2	13.3	6.3	114.6	3,291,567.4	1,919.9	1.1	0.8
Minimum:	7.1	12.9	5.9	83.1	2,799,465.9	1,390.1	0.9	0.4
Maximum:	8.8	13.8	7.0	134.4	3,447,992.7	2,225.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/11/2022 00:00	7.5	13.7	6.1	87.3	2,716,620.4	1,368.8	1.0	0.5
10/11/2022 01:00	7.5	13.8	6.2	82.4	2,568,166.9	1,294.0	1.0	0.5
10/11/2022 02:00	7.5	13.8	6.2	82.4	2,567,968.4	1,293.9	1.0	0.5
10/11/2022 03:00	7.5	13.8	6.2	84.2	2,670,973.0	1,345.8	1.0	0.5
10/11/2022 04:00	7.3	13.7	6.0	90.1	2,956,964.3	1,489.9	1.0	0.6
10/11/2022 05:00	7.5	13.8	6.2	83.3	2,608,455.8	1,314.3	1.0	0.5
10/11/2022 06:00	7.6	13.8	6.3	82.6	2,586,227.4	1,303.1	1.0	0.5
10/11/2022 07:00	7.9	13.8	6.6	83.7	2,617,585.2	1,318.9	1.0	0.5
10/11/2022 08:00	7.7	13.7	6.3	103.7	3,420,039.6	1,748.2	0.9	0.5
10/11/2022 09:00	7.5	13.7	6.1	96.5	3,159,996.4	1,592.2	1.0	0.6
10/11/2022 10:00	8.4	13.6	6.8	105.9	3,336,187.8	1,729.7	1.0	0.7
10/11/2022 11:00	8.0	13.5	6.4	105.9	3,370,327.0	1,747.4	1.0	0.7
10/11/2022 12:00	7.8	13.6	6.3	105.5	3,420,822.1	1,748.6	1.0	0.7
10/11/2022 13:00	7.9	13.6	6.4	105.4	3,404,389.0	1,740.2	1.0	0.7
10/11/2022 14:00	7.8	13.6	6.3	105.0	3,390,694.8	1,733.2	1.0	0.7
10/11/2022 15:00	7.9	13.6	6.4	105.4	3,399,498.2	1,737.7	1.0	0.7
10/11/2022 16:00	8.1	13.5	6.5	107.2	3,395,979.6	1,760.7	1.0	0.7
10/11/2022 17:00	8.4	13.4	6.6	108.8	3,368,213.4	1,770.9	1.0	0.7
10/11/2022 18:00	8.4	13.4	6.6	109.3	3,377,342.9	1,775.7	1.0	0.7
10/11/2022 19:00	8.7	13.2	6.7	122.3	3,354,274.6	2,057.5	1.2	1.0
10/11/2022 20:00	8.7	13.1	6.6	125.7	3,351,745.8	2,104.9	1.2	1.1
10/11/2022 21:00	8.8	13.0	6.6	134.8	3,360,380.7	2,159.4	1.3	1.1
10/11/2022 22:00	8.6	13.0	6.4	124.6	3,374,583.9	2,094.6	1.2	1.0
10/11/2022 23:00	8.3	13.2	6.4	112.7	3,399,812.7	1,961.3	1.1	0.8
Average/Sum#:	8.0	13.5	6.4	102.3	3,132,385.4	1,674.6	1.0	0.7
Minimum:	7.3	13.0	6.0	82.4	2,567,968.4	1,293.9	0.9	0.5
Maximum:	8.8	13.8	6.8	134.8	3,420,822.1	2,159.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/12/2022 00:00	8.3	13.2	6.4	111.3	3,421,103.0	1,948.6	1.0	0.8
10/12/2022 01:00	8.2	13.2	6.3	110.4	3,386,516.3	1,928.9	1.0	0.8
10/12/2022 02:00	7.3	13.7	6.0	92.8	2,958,347.9	1,512.2	1.0	0.6
10/12/2022 03:00	7.3	13.7	6.0	97.1	3,178,434.0	1,624.7	1.0	0.6
10/12/2022 04:00	7.9	13.5	6.3	105.7	3,368,591.1	1,746.5	1.0	0.7
10/12/2022 05:00	8.7	13.1	6.6	125.4	3,419,694.3	2,122.6	1.2	1.1
10/12/2022 06:00	8.7	12.9	6.4	138.5	3,430,103.8	2,254.3	1.3	1.1
10/12/2022 07:00	8.9	12.9	6.6	138.1	3,416,257.4	2,245.2	1.3	1.1
10/12/2022 08:00	8.6	12.9	6.3	136.6	3,413,214.2	2,243.2	1.3	1.1
10/12/2022 09:00	8.5	12.9	6.3	136.2	3,405,302.0	2,238.0	1.3	1.1
10/12/2022 10:00	8.5	12.9	6.3	135.7	3,399,367.8	2,234.1	1.3	1.1
10/12/2022 11:00	8.6	12.9	6.3	136.5	3,399,063.5	2,233.9	1.3	1.1
10/12/2022 12:00	8.6	12.9	6.3	136.0	3,395,563.8	2,231.6	1.3	1.1
10/12/2022 13:00	8.7	12.9	6.4	135.9	3,391,455.6	2,228.9	1.3	1.1
10/12/2022 14:00	8.7	12.9	6.4	135.8	3,392,672.8	2,229.7	1.3	1.1
10/12/2022 15:00	8.8	12.9	6.5	138.3	3,364,269.4	2,235.6	1.3	1.1
10/12/2022 16:00	9.0	12.8	6.6	142.9	3,314,743.3	2,251.1	1.4	1.1
10/12/2022 17:00	9.0	12.8	6.6	146.0	3,328,584.8	2,260.5	1.4	1.1
10/12/2022 18:00	8.9	12.9	6.6	139.8	3,347,114.0	2,224.2	1.4	1.1
10/12/2022 19:00	8.7	13.0	6.5	128.0	3,361,543.3	2,135.6	1.2	1.1
10/12/2022 20:00	8.7	13.0	6.5	129.0	3,385,311.5	2,150.7	1.2	1.1
10/12/2022 21:00	8.7	13.0	6.5	125.9	3,368,147.0	2,115.2	1.2	1.1
10/12/2022 22:00	8.6	13.1	6.5	123.0	3,398,943.9	2,084.9	1.2	1.0
10/12/2022 23:00	8.4	13.2	6.4	112.6	3,396,172.5	1,959.2	1.1	0.8
Average/Sum#:	8.5	13.1	6.4	127.4	3,360,021.6	2,101.6	1.2	1.0
Minimum:	7.3	12.8	6.0	92.8	2,958,347.9	1,512.2	1.0	0.6
Maximum:	9.0	13.7	6.6	146.0	3,430,103.8	2,260.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/13/2022 00:00	8.5	13.2	6.5	112.3	3,391,665.5	1,956.6	1.0	0.8
10/13/2022 01:00	8.6	13.1	6.5	115.9	3,382,816.4	2,000.9	1.1	0.8
10/13/2022 02:00	8.5	13.2	6.5	111.2	3,418,469.5	1,947.1	1.0	0.8
10/13/2022 03:00	8.5	13.2	6.5	112.0	3,439,713.1	1,959.2	1.0	0.8
10/13/2022 04:00	8.3	13.2	6.4	110.8	3,405,302.0	1,939.6	1.0	0.8
10/13/2022 05:00	7.7	13.7	6.3	84.8	2,558,671.6	1,307.9	1.0	0.5
10/13/2022 06:00	7.6	13.7	6.2	83.0	2,559,649.8	1,308.4	1.0	0.5
10/13/2022 07:00	7.9	13.7	6.5	84.0	2,597,341.6	1,308.7	1.0	0.5
10/13/2022 08:00	7.7	13.7	6.3	91.2	2,908,657.4	1,486.8	1.0	0.6
10/13/2022 09:00	7.6	13.7	6.2	93.8	3,007,255.9	1,537.2	1.0	0.6
10/13/2022 10:00	8.1	13.5	6.5	103.9	3,303,398.8	1,712.7	1.0	0.7
10/13/2022 11:00	8.4	13.4	6.6	110.0	3,413,290.3	1,794.6	1.0	0.7
10/13/2022 12:00	8.4	13.4	6.6	109.8	3,405,302.0	1,790.4	1.0	0.7
10/13/2022 13:00	8.4	13.4	6.6	110.4	3,394,270.5	1,784.6	1.0	0.7
10/13/2022 14:00	8.4	13.4	6.6	108.9	3,385,331.2	1,779.9	1.0	0.7
10/13/2022 15:00	8.4	13.4	6.6	108.9	3,380,386.1	1,777.3	1.0	0.7
10/13/2022 16:00	8.4	13.4	6.6	108.9	3,383,619.4	1,779.0	1.0	0.7
10/13/2022 17:00	8.3	13.4	6.5	108.8	3,384,950.8	1,779.7	1.0	0.7
10/13/2022 18:00	8.2	13.4	6.5	108.8	3,393,890.1	1,784.4	1.0	0.7
10/13/2022 19:00	8.2	13.4	6.5	108.9	3,400,737.2	1,788.0	1.0	0.7
10/13/2022 20:00	8.4	13.1	6.4	118.8	3,393,862.6	2,057.0	1.1	0.8
10/13/2022 21:00	8.4	13.0	6.3	128.5	3,394,283.6	2,156.4	1.2	1.1
10/13/2022 22:00	8.1	13.1	6.1	120.1	3,391,770.8	2,080.5	1.1	0.8
10/13/2022 23:00	8.0	13.1	6.1	118.9	3,415,311.4	2,070.0	1.1	0.8
Average/Sum#:	8.2	13.4	6.4	107.2	3,254,581.2	1,787.0	1.0	0.7
Minimum:	7.6	13.0	6.1	83.0	2,558,671.6	1,307.9	1.0	0.5
Maximum:	8.6	13.7	6.6	128.5	3,439,713.1	2,156.4	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/14/2022 00:00	7.9	13.1	6.0	117.4	3,442,098.3	2,061.1	1.1	0.8
10/14/2022 01:00	7.9	13.1	6.0	118.9	3,423,066.0	2,074.7	1.1	0.8
10/14/2022 02:00	8.1	13.1	6.1	121.3	3,422,901.0	2,074.6	1.1	0.8
10/14/2022 03:00	8.1	13.1	6.1	121.2	3,417,951.3	2,071.6	1.1	0.8
10/14/2022 04:00	8.2	13.0	6.1	125.0	3,403,744.6	2,112.7	1.2	1.1
10/14/2022 05:00	8.4	12.9	6.2	150.9	3,401,289.0	2,260.2	1.5	1.4
10/14/2022 06:00	8.4	12.9	6.2	155.8	3,391,206.4	2,253.5	1.5	1.4
10/14/2022 07:00	8.9	12.8	6.5	148.2	3,385,825.7	2,225.2	1.4	1.1
10/14/2022 08:00	8.2	13.1	6.2	120.5	3,382,478.2	2,025.4	1.1	0.8
10/14/2022 09:00	8.3	13.1	6.3	114.7	3,404,146.3	1,963.8	1.1	0.8
10/14/2022 10:00	8.3	13.1	6.3	115.5	3,379,397.0	1,974.2	1.1	0.8
10/14/2022 11:00	8.3	13.1	6.3	116.1	3,349,341.5	1,981.1	1.1	0.8
10/14/2022 12:00	8.3	13.1	6.3	117.7	3,363,373.9	1,989.4	1.1	0.8
10/14/2022 13:00	8.3	13.1	6.3	117.2	3,338,723.4	1,999.2	1.1	0.8
10/14/2022 14:00	8.5	13.0	6.3	130.4	3,340,758.6	2,098.0	1.3	1.0
10/14/2022 15:00	8.6	12.9	6.3	137.2	3,348,636.1	2,127.4	1.3	1.1
10/14/2022 16:00	8.5	12.9	6.3	135.0	3,335,886.3	2,119.3	1.3	1.1
10/14/2022 17:00	8.6	12.9	6.3	147.0	3,321,832.3	2,207.4	1.4	1.1
10/14/2022 18:00	8.3	13.0	6.2	134.4	3,344,974.7	2,149.5	1.3	1.1
10/14/2022 19:00	8.3	13.0	6.2	129.6	3,338,090.0	2,120.7	1.3	1.1
10/14/2022 20:00	8.2	13.0	6.1	130.0	3,352,099.0	2,129.6	1.3	1.1
10/14/2022 21:00	8.2	13.0	6.1	128.7	3,377,223.5	2,120.9	1.2	1.1
10/14/2022 22:00	8.1	13.0	6.0	124.2	3,373,133.9	2,093.7	1.2	1.0
10/14/2022 23:00	12.7	14.3	11.4	132.1	2,632,867.2	1,326.6	1.6	0.8
Average/Sum#:	8.5	13.1	6.4	128.7	3,344,626.8	2,065.0	1.2	1.0
Minimum:	7.9	12.8	6.0	114.7	2,632,867.2	1,326.6	1.1	0.8
Maximum:	12.7	14.3	11.4	155.8	3,442,098.3	2,260.2	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	28.3	17.3	46.4	0.0	1,405,799.7	328.5	0.1	0.0
10/16/2022 18:00	38.5	16.2	48.3	207.0	1,787,721.3	574.4	3.5	0.7
10/16/2022 19:00	29.4	14.8	28.4	215.2	2,280,091.6	965.7	3.0	1.2
10/16/2022 20:00	8.0	13.5	6.4	107.6	3,414,881.5	1,770.5	1.0	0.7
10/16/2022 21:00	8.0	13.5	6.4	103.0	3,251,900.7	1,686.0	1.0	0.7
10/16/2022 22:00	7.9	13.6	6.4	94.6	3,119,157.5	1,594.4	1.0	0.6
10/16/2022 23:00	8.3	13.5	6.6	109.6	3,479,109.4	1,803.8	1.0	0.7
Average/Sum#:	18.3	14.6	21.3	119.6	2,676,951.7	1,246.2	1.5	0.7
Minimum:	7.9	13.5	6.4	0.0	1,405,799.7	328.5	0.1	0.0
Maximum:	38.5	17.3	48.3	215.2	3,479,109.4	1,803.8	3.5	1.2
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/17/2022 00:00	7.8	13.6	6.3	100.9	3,214,039.0	1,642.9	1.0	0.7
10/17/2022 01:00	7.7	13.6	6.2	103.1	3,323,006.1	1,698.6	1.0	0.7
10/17/2022 02:00	7.5	13.6	6.1	103.0	3,330,635.7	1,702.5	1.0	0.7
10/17/2022 03:00	7.9	13.5	6.3	108.4	3,461,943.4	1,794.9	1.0	0.7
10/17/2022 04:00	8.8	13.1	6.7	124.8	3,437,255.2	2,058.2	1.2	1.0
10/17/2022 05:00	8.9	13.0	6.6	144.6	3,399,950.2	2,160.0	1.4	1.1
10/17/2022 06:00	8.7	13.0	6.5	139.1	3,416,076.9	2,145.3	1.3	1.1
10/17/2022 07:00	8.9	13.1	6.7	132.3	3,422,908.9	2,099.6	1.2	1.0
10/17/2022 08:00	7.4	13.6	6.0	102.7	3,246,693.0	1,683.3	1.0	0.7
10/17/2022 09:00	7.4	13.7	6.1	99.2	3,193,302.0	1,632.3	1.0	0.7
10/17/2022 10:00	7.4	13.7	6.1	92.1	3,021,863.1	1,522.6	1.0	0.6
10/17/2022 11:00	7.6	13.7	6.2	97.3	3,193,537.4	1,609.1	1.0	0.6
10/17/2022 12:00	7.5	13.7	6.1	91.6	2,990,108.4	1,506.6	1.0	0.6
10/17/2022 13:00	7.5	13.7	6.1	90.8	2,979,788.1	1,501.4	1.0	0.6
10/17/2022 14:00	7.6	13.7	6.2	100.5	3,290,389.4	1,657.9	1.0	0.7
10/17/2022 15:00	8.0	13.6	6.5	103.4	3,272,731.4	1,696.8	1.0	0.7
10/17/2022 16:00	8.9	13.1	6.7	124.9	3,390,629.6	2,079.8	1.2	1.0
10/17/2022 17:00	9.0	12.9	6.6	151.6	3,357,196.5	2,230.9	1.5	1.3
10/17/2022 18:00	8.8	12.9	6.5	154.4	3,380,521.9	2,246.4	1.5	1.3
10/17/2022 19:00	8.7	12.9	6.4	152.7	3,383,391.2	2,223.6	1.5	1.3
10/17/2022 20:00	8.7	12.9	6.4	153.2	3,392,977.1	2,229.9	1.5	1.3
10/17/2022 21:00	8.7	12.9	6.4	155.0	3,370,439.3	2,239.7	1.5	1.3
10/17/2022 22:00	8.5	13.0	6.3	140.8	3,427,023.9	2,177.2	1.3	1.1
10/17/2022 23:00	8.6	13.0	6.4	142.1	3,437,097.8	2,183.6	1.3	1.1
Average/Sum#:	8.2	13.3	6.4	121.2	3,305,562.7	1,905.1	1.2	0.9
Minimum:	7.4	12.9	6.0	90.8	2,979,788.1	1,501.4	1.0	0.6
Maximum:	9.0	13.7	6.7	155.0	3,461,943.4	2,246.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/18/2022 00:00	8.5	13.0	6.3	139.6	3,430,014.6	2,179.1	1.3	1.1
10/18/2022 01:00	8.3	13.0	6.2	136.1	3,456,841.2	2,170.9	1.3	1.1
10/18/2022 02:00	8.4	13.0	6.3	143.8	3,416,792.5	2,170.7	1.4	1.1
10/18/2022 03:00	8.5	13.0	6.3	147.6	3,387,613.6	2,176.9	1.4	1.1
10/18/2022 04:00	8.4	13.0	6.3	146.5	3,388,391.7	2,177.4	1.4	1.1
10/18/2022 05:00	8.5	13.0	6.3	143.4	3,435,523.7	2,182.6	1.4	1.1
10/18/2022 06:00	8.2	13.0	6.1	133.5	3,452,541.8	2,168.2	1.3	1.1
10/18/2022 07:00	8.8	13.1	6.7	138.3	3,450,153.3	2,166.7	1.3	1.1
10/18/2022 08:00	8.7	13.0	6.5	139.3	3,457,000.4	2,171.0	1.3	1.1
10/18/2022 09:00	8.6	13.0	6.4	138.7	3,473,182.5	2,155.8	1.3	1.1
10/18/2022 10:00	8.6	13.0	6.4	134.6	3,414,700.0	2,119.5	1.3	1.1
10/18/2022 11:00	8.6	13.1	6.5	131.8	3,420,626.5	2,098.2	1.2	1.0
10/18/2022 12:00	8.6	13.1	6.5	132.3	3,420,626.5	2,098.2	1.2	1.0
10/18/2022 13:00	8.7	13.1	6.6	133.1	3,428,125.7	2,102.8	1.3	1.1
10/18/2022 14:00	8.7	13.0	6.5	134.3	3,395,205.8	2,107.4	1.3	1.1
10/18/2022 15:00	8.8	13.0	6.6	139.0	3,399,197.9	2,134.7	1.3	1.1
10/18/2022 16:00	9.0	12.9	6.6	154.3	3,372,283.6	2,216.3	1.5	1.3
10/18/2022 17:00	8.9	13.0	6.6	150.0	3,405,509.5	2,188.4	1.4	1.1
10/18/2022 18:00	9.0	12.9	6.6	156.6	3,395,868.2	2,231.8	1.5	1.3
10/18/2022 19:00	9.0	12.9	6.6	163.5	3,391,206.4	2,253.5	1.6	1.4
10/18/2022 20:00	8.9	12.9	6.6	162.9	3,400,085.1	2,259.4	1.6	1.4
10/18/2022 21:00	8.9	12.9	6.6	164.1	3,399,934.6	2,259.3	1.6	1.4
10/18/2022 22:00	8.8	13.0	6.6	150.4	3,416,713.8	2,195.6	1.4	1.1
10/18/2022 23:00	8.8	13.0	6.6	149.8	3,412,356.6	2,192.8	1.4	1.1
Average/Sum#:	8.7	13.0	6.5	144.3	3,417,520.6	2,174.1	1.4	1.1
Minimum:	8.2	12.9	6.1	131.8	3,372,283.6	2,098.2	1.2	1.0
Maximum:	9.0	13.1	6.7	164.1	3,473,182.5	2,259.4	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/19/2022 00:00	8.8	13.0	6.6	147.7	3,434,579.3	2,182.0	1.4	1.1
10/19/2022 01:00	8.4	13.1	6.4	132.2	3,482,739.7	2,136.3	1.2	1.1
10/19/2022 02:00	8.5	13.1	6.4	131.0	3,470,913.3	2,103.7	1.2	1.1
10/19/2022 03:00	8.6	13.1	6.5	136.5	3,496,107.8	2,144.5	1.3	1.1
10/19/2022 04:00	8.7	13.0	6.5	143.5	3,484,070.4	2,188.0	1.3	1.1
10/19/2022 05:00	8.8	13.0	6.6	154.5	3,443,409.9	2,237.9	1.5	1.3
10/19/2022 06:00	8.7	13.0	6.5	151.0	3,484,004.5	2,213.4	1.4	1.1
10/19/2022 07:00	9.1	13.1	6.9	140.0	3,461,582.6	2,148.6	1.3	1.1
10/19/2022 08:00	8.7	13.1	6.6	134.9	3,485,674.1	2,138.1	1.2	1.1
10/19/2022 09:00	8.6	13.1	6.5	132.5	3,456,394.1	2,094.9	1.2	1.0
10/19/2022 10:00	8.7	13.1	6.6	131.1	3,430,985.5	2,079.5	1.2	1.0
10/19/2022 11:00	8.9	13.0	6.6	136.7	3,399,394.6	2,110.0	1.3	1.1
10/19/2022 12:00	8.9	13.0	6.6	141.8	3,392,032.4	2,130.2	1.4	1.1
10/19/2022 13:00	8.9	13.0	6.6	146.5	3,382,635.6	2,149.0	1.4	1.1
10/19/2022 14:00	8.9	13.0	6.6	141.9	3,370,672.8	2,141.4	1.4	1.1
10/19/2022 15:00	9.0	12.9	6.6	148.4	3,351,396.9	2,178.1	1.4	1.1
10/19/2022 16:00	9.1	12.9	6.7	151.8	3,376,169.6	2,194.2	1.5	1.3
10/19/2022 17:00	8.9	13.0	6.6	141.6	3,381,522.8	2,123.6	1.4	1.1
10/19/2022 18:00	8.8	13.0	6.6	134.7	3,382,156.0	2,099.3	1.3	1.0
10/19/2022 19:00	8.8	13.0	6.6	137.1	3,396,978.0	2,108.5	1.3	1.1
10/19/2022 20:00	8.8	13.0	6.6	140.4	3,418,943.1	2,147.1	1.3	1.1
10/19/2022 21:00	8.6	13.1	6.5	134.3	3,446,710.8	2,114.2	1.3	1.1
10/19/2022 22:00	8.6	13.1	6.5	131.0	3,444,184.8	2,087.5	1.2	1.0
10/19/2022 23:00	8.7	13.1	6.6	132.4	3,432,038.3	2,105.2	1.2	1.1
Average/Sum#:	8.8	13.0	6.6	139.7	3,429,387.4	2,139.8	1.3	1.1
Minimum:	8.4	12.9	6.4	131.0	3,351,396.9	2,079.5	1.2	1.0
Maximum:	9.1	13.1	6.9	154.5	3,496,107.8	2,237.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/20/2022 00:00	8.6	13.1	6.5	134.0	3,462,687.4	2,124.0	1.2	1.1
10/20/2022 01:00	8.6	13.1	6.5	130.5	3,444,844.8	2,087.9	1.2	1.0
10/20/2022 02:00	8.5	13.1	6.4	128.2	3,429,500.6	2,078.6	1.2	1.0
10/20/2022 03:00	8.5	13.1	6.4	129.3	3,447,154.7	2,089.3	1.2	1.0
10/20/2022 04:00	8.6	13.1	6.5	134.4	3,481,435.4	2,135.5	1.2	1.1
10/20/2022 05:00	8.7	13.0	6.5	148.1	3,451,416.3	2,217.9	1.4	1.1
10/20/2022 06:00	8.7	13.0	6.5	148.4	3,489,962.1	2,191.7	1.4	1.1
10/20/2022 07:00	8.7	13.2	6.7	126.1	3,498,794.8	2,069.5	1.2	1.0
10/20/2022 08:00	8.6	13.1	6.5	125.8	3,476,647.3	2,056.4	1.2	1.0
10/20/2022 09:00	8.6	13.1	6.5	128.6	3,450,448.4	2,066.1	1.2	1.0
10/20/2022 10:00	8.6	13.1	6.5	127.9	3,441,597.3	2,060.8	1.2	1.0
10/20/2022 11:00	8.6	13.1	6.5	130.7	3,389,977.5	2,079.4	1.2	1.0
10/20/2022 12:00	8.7	13.1	6.6	131.5	3,389,977.5	2,079.4	1.2	1.0
10/20/2022 13:00	8.8	13.0	6.6	135.0	3,382,800.4	2,099.7	1.3	1.0
10/20/2022 14:00	8.8	13.0	6.6	138.3	3,377,382.7	2,121.0	1.3	1.1
10/20/2022 15:00	8.9	13.0	6.6	143.7	3,379,802.3	2,147.2	1.4	1.1
10/20/2022 16:00	9.0	12.9	6.6	161.3	3,335,739.2	2,241.0	1.6	1.3
10/20/2022 17:00	8.9	13.0	6.6	149.9	3,352,166.3	2,178.6	1.5	1.3
10/20/2022 18:00	8.9	12.9	6.6	155.2	3,366,501.6	2,212.5	1.5	1.3
10/20/2022 19:00	8.7	13.0	6.5	136.2	3,356,522.9	2,107.9	1.3	1.1
10/20/2022 20:00	8.8	13.0	6.6	136.2	3,391,178.1	2,104.9	1.3	1.1
10/20/2022 21:00	8.5	13.1	6.4	129.7	3,437,255.2	2,083.3	1.2	1.0
10/20/2022 22:00	8.6	13.1	6.5	130.4	3,437,255.2	2,083.3	1.2	1.0
10/20/2022 23:00	8.5	13.0	6.3	134.9	3,442,410.7	2,136.7	1.3	1.1
Average/Sum#:	8.7	13.1	6.5	136.4	3,421,394.1	2,118.9	1.3	1.1
Minimum:	8.5	12.9	6.3	125.8	3,335,739.2	2,056.4	1.2	1.0
Maximum:	9.0	13.2	6.7	161.3	3,498,794.8	2,241.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/21/2022 00:00	8.4	13.2	6.4	120.9	3,403,019.6	1,988.0	1.1	0.8
10/21/2022 01:00	7.5	13.7	6.1	96.6	3,129,829.4	1,577.0	1.0	0.6
10/21/2022 02:00	7.7	13.7	6.3	96.8	3,104,289.4	1,586.8	1.0	0.6
10/21/2022 03:00	7.7	13.7	6.3	94.0	3,019,385.1	1,543.4	1.0	0.6
10/21/2022 04:00	7.4	13.7	6.1	101.5	3,366,203.9	1,696.1	1.0	0.7
10/21/2022 05:00	7.2	13.7	5.9	100.8	3,370,371.7	1,698.2	0.9	0.5
10/21/2022 06:00	7.1	13.7	5.8	96.5	3,172,499.8	1,598.5	1.0	0.6
10/21/2022 07:00	7.5	13.7	6.1	99.3	3,311,426.9	1,668.5	0.9	0.5
10/21/2022 08:00	7.3	13.7	6.0	101.8	3,383,669.0	1,704.9	1.0	0.7
10/21/2022 09:00	7.3	13.7	6.0	101.5	3,390,615.4	1,708.4	0.9	0.5
10/21/2022 10:00	7.4	13.7	6.1	101.7	3,387,638.4	1,706.9	0.9	0.5
10/21/2022 11:00	7.4	13.7	6.1	100.4	3,318,174.8	1,671.9	1.0	0.7
10/21/2022 12:00	8.0	13.7	6.6	101.0	3,272,328.9	1,648.8	1.0	0.7
10/21/2022 13:00	7.7	13.7	6.3	98.4	3,223,307.5	1,624.1	1.0	0.6
10/21/2022 14:00	7.8	13.6	6.3	102.6	3,288,574.8	1,681.0	1.0	0.7
10/21/2022 15:00	8.2	13.6	6.6	96.4	3,044,817.3	1,556.4	1.0	0.6
10/21/2022 16:00	8.9	13.0	6.6	125.9	3,376,517.2	2,095.8	1.2	1.0
10/21/2022 17:00	8.9	12.9	6.6	141.1	3,354,628.1	2,180.2	1.4	1.1
10/21/2022 18:00	8.8	13.0	6.6	138.7	3,362,960.0	2,136.5	1.3	1.1
10/21/2022 19:00	8.6	13.0	6.4	132.0	3,380,706.0	2,098.4	1.3	1.0
10/21/2022 20:00	8.7	13.0	6.5	133.5	3,370,535.6	2,116.7	1.3	1.1
10/21/2022 21:00	8.7	12.9	6.4	141.7	3,348,165.7	2,176.0	1.4	1.1
10/21/2022 22:00	13.3	14.5	12.3	134.2	2,493,182.3	1,201.6	1.7	0.8
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.2	13.5	6.5	111.2	3,255,341.2	1,768.0	1.1	0.7
Minimum:	7.1	12.9	5.8	94.0	2,493,182.3	1,201.6	0.9	0.5
Maximum:	13.3	14.5	12.3	141.7	3,403,019.6	2,180.2	1.7	1.1
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	33.8	17.4	57.0	0.0	1,312,880.4	297.2	0.0	0.0
10/23/2022 21:00	35.3	17.2	56.3	206.6	1,410,126.7	370.7	4.5	0.6
10/23/2022 22:00	33.3	15.7	37.8	220.0	2,155,747.9	787.1	3.1	0.9
10/23/2022 23:00	7.2	13.8	6.0	88.4	2,726,161.5	1,353.7	1.0	0.5
Average/Sum#:	27.4	16.0	39.3	128.8	1,901,229.1	702.2	2.2	0.5
Minimum:	7.2	13.8	6.0	0.0	1,312,880.4	297.2	0.0	0.0
Maximum:	35.3	17.4	57.0	220.0	2,726,161.5	1,353.7	4.5	0.9
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/24/2022 00:00	7.1	13.8	5.9	83.5	2,755,966.6	1,368.5	1.0	0.5
10/24/2022 01:00	7.3	13.8	6.1	83.9	2,738,244.6	1,359.7	1.0	0.5
10/24/2022 02:00	7.3	13.8	6.1	84.2	2,738,043.2	1,359.6	1.0	0.5
10/24/2022 03:00	7.3	13.8	6.1	84.3	2,738,043.2	1,359.6	1.0	0.5
10/24/2022 04:00	8.0	13.6	6.5	101.4	3,226,168.2	1,649.1	1.0	0.7
10/24/2022 05:00	8.3	13.6	6.7	113.5	3,511,127.0	1,820.4	1.0	0.7
10/24/2022 06:00	8.2	13.5	6.5	113.2	3,513,634.4	1,821.7	1.0	0.7
10/24/2022 07:00	8.6	13.5	6.9	115.2	3,509,005.3	1,819.3	1.0	0.7
10/24/2022 08:00	8.6	13.6	7.0	114.5	3,552,678.1	1,816.0	1.0	0.7
10/24/2022 09:00	7.9	13.6	6.4	111.5	3,509,052.2	1,793.7	1.0	0.7
10/24/2022 10:00	8.1	13.5	6.5	113.7	3,551,052.4	1,841.1	1.0	0.7
10/24/2022 11:00	8.1	13.5	6.5	113.7	3,532,536.3	1,831.5	1.0	0.7
10/24/2022 12:00	7.6	13.6	6.1	108.5	3,461,904.8	1,769.6	1.0	0.7
10/24/2022 13:00	7.6	13.6	6.1	107.5	3,416,909.5	1,746.6	1.0	0.7
10/24/2022 14:00	15.1	15.0	15.1	129.0	2,393,895.5	1,013.9	1.6	0.6
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.3	13.7	7.0	105.2	3,209,884.1	1,624.7	1.0	0.6
Minimum:	7.1	13.5	5.9	83.5	2,393,895.5	1,013.9	1.0	0.5
Maximum:	15.1	15.0	15.1	129.0	3,552,678.1	1,841.1	1.6	0.7
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	19.8	18.0	40.3	0.1	1,126,351.6	164.5	-0.2	0.0
10/30/2022 20:00	36.0	17.1	55.9	64.2	1,418,495.4	372.9	1.4	0.2
10/30/2022 21:00	39.5	16.6	54.2	238.7	1,879,451.5	562.7	3.7	0.8
10/30/2022 22:00	36.8	15.7	41.8	227.8	2,454,902.8	878.4	2.8	1.0
10/30/2022 23:00	7.9	13.5	6.3	113.3	3,420,474.9	1,773.4	1.1	0.7
Average/Sum#:	28.0	16.2	39.7	128.8	2,059,935.2	750.4	1.8	0.5
Minimum:	7.9	13.5	6.3	0.1	1,126,351.6	164.5	-0.2	0.0
Maximum:	39.5	18.0	55.9	238.7	3,420,474.9	1,773.4	3.7	1.0
%SI	79.17	79.17	79.17	79.17	79.17	79.17	79.17	79.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/31/2022 00:00	7.4	13.7	6.1	97.9	3,107,601.0	1,565.8	1.0	0.6
10/31/2022 01:00	7.9	13.6	6.4	109.7	3,495,944.8	1,787.0	1.0	0.7
10/31/2022 02:00	7.7	13.7	6.3	104.6	3,317,182.5	1,671.4	1.0	0.7
10/31/2022 03:00	7.5	13.7	6.1	104.6	3,391,409.3	1,708.8	1.0	0.7
10/31/2022 04:00	7.4	13.7	6.1	105.5	3,421,179.4	1,723.8	1.0	0.7
10/31/2022 05:00	7.4	13.7	6.1	104.8	3,390,020.0	1,708.1	1.0	0.7
10/31/2022 06:00	7.3	13.7	6.0	103.9	3,372,554.9	1,699.3	1.0	0.7
10/31/2022 07:00	7.6	13.7	6.2	104.9	3,375,333.4	1,700.7	1.0	0.7
10/31/2022 08:00	7.5	13.7	6.1	105.1	3,381,882.8	1,704.0	1.0	0.7
10/31/2022 09:00	7.5	13.7	6.1	104.9	3,384,264.4	1,705.2	1.0	0.7
10/31/2022 10:00	7.5	13.7	6.1	105.0	3,390,020.0	1,708.1	1.0	0.7
10/31/2022 11:00	7.4	13.7	6.1	103.5	3,348,341.9	1,687.1	1.0	0.7
10/31/2022 12:00	7.4	13.7	6.1	103.3	3,330,082.9	1,677.9	1.0	0.7
10/31/2022 13:00	7.4	13.7	6.1	104.0	3,357,868.3	1,691.9	1.0	0.7
10/31/2022 14:00	8.3	13.5	6.6	110.1	3,443,906.7	1,760.4	1.0	0.7
10/31/2022 15:00	9.0	13.1	6.8	125.4	3,430,655.6	2,079.3	1.2	1.0
10/31/2022 16:00	8.9	13.1	6.7	132.3	3,433,016.5	2,105.8	1.2	1.1
10/31/2022 17:00	8.8	13.1	6.7	127.5	3,429,335.6	2,078.5	1.2	1.0
10/31/2022 18:00	8.7	13.1	6.6	128.2	3,433,955.4	2,081.3	1.2	1.0
10/31/2022 19:00	8.7	13.1	6.6	130.6	3,430,082.0	2,104.0	1.2	1.1
10/31/2022 20:00	8.7	13.1	6.6	131.4	3,436,766.1	2,108.1	1.2	1.1
10/31/2022 21:00	8.7	13.0	6.5	138.0	3,444,261.6	2,163.0	1.3	1.1
10/31/2022 22:00	8.3	13.1	6.3	129.8	3,455,025.1	2,119.3	1.2	1.1
10/31/2022 23:00	8.4	13.1	6.4	137.5	3,417,669.3	2,146.3	1.3	1.1
Average/Sum#:	8.0	13.5	6.3	114.7	3,392,431.6	1,853.5	1.1	0.8
Minimum:	7.3	13.0	6.0	97.9	3,107,601.0	1,565.8	1.0	0.6
Maximum:	9.0	13.7	6.8	138.0	3,495,944.8	2,163.0	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/01/2022 00:00	8.4	13.1	6.4	136.6	3,486,071.2	2,163.8	1.3	1.1
11/01/2022 01:00	8.3	13.1	6.3	134.4	3,468,993.6	2,153.2	1.3	1.1
11/01/2022 02:00	8.3	13.1	6.3	133.3	3,483,332.3	2,162.1	1.2	1.1
11/01/2022 03:00	8.3	13.0	6.2	132.2	3,485,587.8	2,163.5	1.2	1.1
11/01/2022 04:00	8.3	13.0	6.2	134.5	3,492,676.6	2,167.9	1.2	1.1
11/01/2022 05:00	8.3	13.0	6.2	134.0	3,491,871.1	2,167.4	1.2	1.1
11/01/2022 06:00	8.4	13.0	6.3	147.8	3,474,758.8	2,232.9	1.4	1.1
11/01/2022 07:00	8.9	13.0	6.6	138.8	3,470,376.2	2,179.4	1.3	1.1
11/01/2022 08:00	8.7	12.9	6.4	148.7	3,433,716.2	2,231.6	1.4	1.1
11/01/2022 09:00	8.3	13.0	6.2	132.5	3,409,383.4	2,116.2	1.3	1.1
11/01/2022 10:00	8.3	13.1	6.3	129.2	3,458,122.6	2,121.2	1.2	1.1
11/01/2022 11:00	8.5	13.0	6.3	140.9	3,429,384.9	2,178.7	1.3	1.1
11/01/2022 12:00	8.6	13.0	6.4	147.0	3,435,838.6	2,182.8	1.4	1.1
11/01/2022 13:00	8.6	13.1	6.5	148.7	3,454,134.2	2,169.2	1.4	1.1
11/01/2022 14:00	8.6	13.2	6.6	138.9	3,436,925.2	2,083.1	1.3	1.0
11/01/2022 15:00	8.5	13.2	6.5	132.0	3,498,044.3	2,094.6	1.2	1.0
11/01/2022 16:00	8.6	13.0	6.4	147.7	3,503,522.8	2,225.8	1.4	1.1
11/01/2022 17:00	8.7	13.0	6.5	168.5	3,487,619.6	2,292.1	1.6	1.4
11/01/2022 18:00	8.3	13.1	6.3	145.6	3,490,439.8	2,192.0	1.4	1.1
11/01/2022 19:00	8.3	13.1	6.3	138.1	3,527,245.9	2,163.6	1.3	1.1
11/01/2022 20:00	8.4	13.1	6.4	145.5	3,505,885.7	2,201.7	1.3	1.1
11/01/2022 21:00	8.1	13.2	6.2	125.7	3,517,899.1	2,080.8	1.2	1.0
11/01/2022 22:00	7.8	13.2	6.0	124.0	3,544,070.3	2,070.4	1.1	0.8
11/01/2022 23:00	7.0	13.5	5.6	106.4	3,370,427.3	1,845.9	1.0	0.7
Average/Sum#:	8.4	13.1	6.3	138.0	3,473,180.3	2,151.7	1.3	1.1
Minimum:	7.0	12.9	5.6	106.4	3,370,427.3	1,845.9	1.0	0.7
Maximum:	8.9	13.5	6.6	168.5	3,544,070.3	2,292.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/02/2022 00:00	7.3	13.8	6.1	86.5	2,714,481.1	1,347.9	1.0	0.5
11/02/2022 01:00	7.2	13.7	5.9	99.4	3,236,009.4	1,630.5	1.0	0.7
11/02/2022 02:00	7.2	13.7	5.9	104.0	3,371,761.0	1,698.9	1.0	0.7
11/02/2022 03:00	7.5	13.8	6.2	87.0	2,676,927.0	1,348.8	1.0	0.5
11/02/2022 04:00	7.4	13.7	6.1	100.6	3,305,869.8	1,665.7	1.0	0.7
11/02/2022 05:00	7.7	13.4	6.1	110.7	3,530,709.2	1,907.9	1.0	0.8
11/02/2022 06:00	8.1	13.1	6.1	128.8	3,632,481.7	2,175.1	1.1	0.9
11/02/2022 07:00	8.3	13.2	6.4	121.6	3,611,053.8	2,135.9	1.1	0.9
11/02/2022 08:00	7.7	13.3	6.0	114.9	3,582,098.2	2,040.3	1.0	0.8
11/02/2022 09:00	7.0	13.6	5.7	100.7	3,393,989.3	1,710.1	0.9	0.5
11/02/2022 10:00	7.3	13.7	6.0	93.3	3,062,945.9	1,543.3	1.0	0.6
11/02/2022 11:00	7.2	13.7	5.9	98.7	3,319,167.2	1,672.4	0.9	0.5
11/02/2022 12:00	7.3	13.7	6.0	93.0	3,075,647.8	1,549.7	1.0	0.6
11/02/2022 13:00	7.3	13.7	6.0	93.0	3,081,998.7	1,552.9	1.0	0.6
11/02/2022 14:00	7.3	13.7	6.0	92.3	3,046,870.0	1,535.2	1.0	0.6
11/02/2022 15:00	7.8	13.7	6.4	96.3	3,183,415.5	1,604.0	0.9	0.5
11/02/2022 16:00	8.6	13.2	6.6	127.4	3,537,848.7	2,092.6	1.2	1.0
11/02/2022 17:00	8.4	13.1	6.4	132.8	3,558,547.1	2,182.8	1.2	1.1
11/02/2022 18:00	8.2	13.1	6.2	132.3	3,549,580.6	2,177.3	1.2	1.1
11/02/2022 19:00	8.1	13.1	6.1	131.3	3,545,831.0	2,175.0	1.2	1.1
11/02/2022 20:00	8.1	13.1	6.1	131.8	3,588,716.8	2,175.1	1.2	1.1
11/02/2022 21:00	8.0	13.1	6.1	129.2	3,559,843.4	2,157.6	1.2	1.1
11/02/2022 22:00	8.0	13.1	6.1	128.6	3,570,732.8	2,164.2	1.2	1.1
11/02/2022 23:00	8.0	13.1	6.1	130.7	3,592,676.6	2,177.5	1.2	1.1
Average/Sum#:	7.7	13.4	6.1	111.0	3,347,050.1	1,850.9	1.1	0.8
Minimum:	7.0	13.1	5.7	86.5	2,676,927.0	1,347.9	0.9	0.5
Maximum:	8.6	13.8	6.6	132.8	3,632,481.7	2,182.8	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/03/2022 00:00	8.1	13.1	6.1	130.2	3,578,652.4	2,169.0	1.2	1.1
11/03/2022 01:00	8.0	13.2	6.1	128.6	3,595,574.0	2,153.0	1.2	1.1
11/03/2022 02:00	8.1	13.1	6.1	136.6	3,577,295.1	2,194.3	1.2	1.1
11/03/2022 03:00	8.2	13.1	6.2	144.9	3,557,477.9	2,234.1	1.3	1.1
11/03/2022 04:00	8.1	13.2	6.2	131.7	3,570,237.9	2,163.9	1.2	1.1
11/03/2022 05:00	8.1	13.2	6.2	131.9	3,573,702.7	2,166.0	1.2	1.1
11/03/2022 06:00	8.2	13.1	6.2	149.6	3,594,658.5	2,231.2	1.4	1.1
11/03/2022 07:00	8.5	13.2	6.5	126.2	3,568,787.6	2,110.9	1.1	0.8
11/03/2022 08:00	7.1	13.8	5.9	88.6	2,932,582.0	1,456.2	1.0	0.6
11/03/2022 09:00	7.2	13.7	5.9	92.4	3,094,899.1	1,559.4	0.9	0.5
11/03/2022 10:00	7.3	13.7	6.0	94.0	3,124,272.3	1,574.2	0.9	0.5
11/03/2022 11:00	7.3	13.7	6.0	94.0	3,116,333.6	1,570.2	1.0	0.6
11/03/2022 12:00	7.3	13.7	6.0	94.4	3,133,798.7	1,579.0	0.9	0.5
11/03/2022 13:00	7.3	13.8	6.1	89.7	2,995,414.5	1,487.4	0.9	0.4
11/03/2022 14:00	7.2	13.8	6.0	92.3	3,128,127.8	1,553.3	0.9	0.5
11/03/2022 15:00	7.7	13.7	6.3	105.1	3,516,443.7	1,771.8	0.9	0.5
11/03/2022 16:00	8.9	13.2	6.8	131.7	3,523,478.2	2,084.1	1.2	1.0
11/03/2022 17:00	8.6	13.1	6.5	142.2	3,525,452.7	2,162.5	1.3	1.1
11/03/2022 18:00	8.5	13.1	6.4	146.9	3,546,646.1	2,175.5	1.3	1.1
11/03/2022 19:00	8.5	13.1	6.4	146.7	3,544,526.8	2,174.2	1.3	1.1
11/03/2022 20:00	8.5	13.1	6.4	147.3	3,526,919.9	2,163.4	1.4	1.1
11/03/2022 21:00	8.6	13.1	6.5	151.2	3,524,474.5	2,161.9	1.4	1.1
11/03/2022 22:00	8.6	13.1	6.5	147.4	3,523,985.4	2,161.6	1.4	1.1
11/03/2022 23:00	8.5	13.1	6.4	149.3	3,546,325.8	2,201.2	1.4	1.1
Average/Sum#:	8.0	13.3	6.2	124.7	3,413,336.1	1,969.1	1.2	0.9
Minimum:	7.1	13.1	5.9	88.6	2,932,582.0	1,456.2	0.9	0.4
Maximum:	8.9	13.8	6.8	151.2	3,595,574.0	2,234.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/04/2022 00:00	8.1	13.1	6.1	136.2	3,572,861.6	2,139.4	1.2	1.1
11/04/2022 01:00	8.2	13.1	6.2	133.0	3,540,463.0	2,120.0	1.2	1.1
11/04/2022 02:00	8.1	13.2	6.2	127.4	3,541,845.0	2,069.1	1.2	1.0
11/04/2022 03:00	8.1	13.2	6.2	128.3	3,545,268.6	2,071.1	1.2	1.0
11/04/2022 04:00	8.2	13.1	6.2	136.9	3,589,895.9	2,149.6	1.2	1.1
11/04/2022 05:00	8.4	13.0	6.3	152.7	3,570,216.8	2,242.1	1.4	1.1
11/04/2022 06:00	8.2	13.1	6.2	141.7	3,592,016.7	2,177.1	1.3	1.1
11/04/2022 07:00	8.0	13.3	6.2	125.9	3,570,730.7	2,059.9	1.1	0.8
11/04/2022 08:00	6.9	13.7	5.7	100.9	3,410,263.7	1,718.3	0.9	0.5
11/04/2022 09:00	7.1	13.7	5.8	93.1	3,080,609.5	1,552.2	1.0	0.6
11/04/2022 10:00	7.1	13.8	5.9	82.7	2,800,472.9	1,390.6	0.9	0.4
11/04/2022 11:00	7.5	13.8	6.2	83.1	2,657,086.1	1,319.4	1.0	0.5
11/04/2022 12:00	7.6	13.8	6.3	83.3	2,651,850.0	1,316.8	1.0	0.5
11/04/2022 13:00	7.6	13.8	6.3	83.3	2,653,461.1	1,317.6	1.0	0.5
11/04/2022 14:00	7.5	13.8	6.2	85.3	2,815,979.6	1,398.3	1.0	0.6
11/04/2022 15:00	8.1	13.6	6.5	99.3	3,186,846.2	1,629.0	1.0	0.7
11/04/2022 16:00	8.9	13.2	6.8	132.1	3,515,579.6	2,105.1	1.2	1.1
11/04/2022 17:00	8.7	13.1	6.6	142.7	3,497,738.1	2,145.5	1.3	1.1
11/04/2022 18:00	8.4	13.2	6.4	134.7	3,532,438.7	2,089.4	1.2	1.0
11/04/2022 19:00	8.3	13.2	6.4	130.7	3,527,873.9	2,086.7	1.2	1.0
11/04/2022 20:00	8.3	13.2	6.4	131.6	3,509,953.0	2,076.1	1.2	1.0
11/04/2022 21:00	8.3	13.2	6.4	130.0	3,507,586.1	2,074.7	1.2	1.0
11/04/2022 22:00	8.3	13.2	6.4	129.6	3,520,942.2	2,082.6	1.2	1.0
11/04/2022 23:00	7.2	13.4	5.7	108.0	3,550,052.5	1,970.2	1.0	0.8
Average/Sum#:	8.0	13.4	6.2	118.0	3,330,918.0	1,887.5	1.1	0.9
Minimum:	6.9	13.0	5.7	82.7	2,651,850.0	1,316.8	0.9	0.4
Maximum:	8.9	13.8	6.8	152.7	3,592,016.7	2,242.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/05/2022 00:00	7.2	13.4	5.7	106.4	3,540,682.8	1,965.0	1.0	0.8
11/05/2022 01:00	7.3	13.4	5.7	106.8	3,541,403.5	1,965.4	1.0	0.8
11/05/2022 02:00	7.3	13.4	5.7	112.2	3,542,304.5	1,965.9	1.0	0.8
11/05/2022 03:00	7.3	13.4	5.7	107.2	3,540,863.0	1,965.1	1.0	0.8
11/05/2022 04:00	7.3	13.4	5.7	107.1	3,556,359.1	1,973.7	1.0	0.8
11/05/2022 05:00	7.4	13.4	5.8	107.8	3,565,008.1	1,978.5	1.0	0.8
11/05/2022 06:00	7.5	13.4	5.9	107.9	3,510,050.9	1,948.0	1.0	0.8
11/05/2022 07:00	12.5	17.8	23.8	157.0	1,556,213.9	568.2	3.2	0.7
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.0	14.0	8.0	114.1	3,294,110.7	1,791.2	1.3	0.8
Minimum:	7.2	13.4	5.7	106.4	1,556,213.9	568.2	1.0	0.7
Maximum:	12.5	17.8	23.8	157.0	3,565,008.1	1,978.5	3.2	0.8
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	28.2	17.6	50.4	0.0	1,313,633.0	259.0	-0.1	0.0
11/06/2022 10:00	34.8	17.1	54.0	159.9	1,488,759.9	380.5	3.3	0.5
11/06/2022 11:00	34.8	15.4	37.3	229.0	2,182,388.4	828.7	3.2	1.0
11/06/2022 12:00	7.3	13.7	6.0	89.1	2,781,916.2	1,401.7	1.0	0.6
11/06/2022 13:00	7.5	13.7	6.1	93.5	3,042,702.2	1,533.1	1.0	0.6
11/06/2022 14:00	8.3	13.6	6.7	106.7	3,143,220.2	1,606.7	1.1	0.6
11/06/2022 15:00	9.4	13.2	7.2	140.1	3,350,810.3	1,957.5	1.3	1.0
11/06/2022 16:00	9.7	12.9	7.2	188.0	3,441,468.8	2,286.9	1.8	1.6
11/06/2022 17:00	9.6	12.9	7.1	191.9	3,428,770.7	2,303.5	1.8	1.6
11/06/2022 18:00	8.8	13.2	6.7	124.3	3,441,363.5	2,010.4	1.2	1.0
11/06/2022 19:00	8.6	13.3	6.7	118.2	3,493,455.0	1,964.3	1.1	0.8
11/06/2022 20:00	8.7	13.2	6.7	123.2	3,492,207.7	1,989.1	1.1	0.8
11/06/2022 21:00	11.9	13.8	9.9	146.0	3,022,824.1	1,677.6	1.5	1.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.4	14.1	16.3	131.5	2,894,116.9	1,553.8	1.5	0.9
Minimum:	7.3	12.9	6.0	0.0	1,313,633.0	259.0	-0.1	0.0
Maximum:	34.8	17.6	54.0	229.0	3,493,455.0	2,303.5	3.3	1.6
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/07/2022 00:00	31.0	17.6	55.4	200.0	1,539,624.3	314.8	3.5	0.4
11/07/2022 01:00	31.0	14.9	30.5	205.6	2,478,658.1	1,013.6	2.5	1.0
11/07/2022 02:00	7.4	13.7	6.1	96.6	3,109,585.7	1,566.8	1.0	0.6
11/07/2022 03:00	7.5	13.7	6.1	97.4	3,214,971.8	1,619.9	1.0	0.6
11/07/2022 04:00	7.4	13.7	6.1	101.1	3,327,304.3	1,676.5	1.0	0.7
11/07/2022 05:00	7.9	13.6	6.4	101.9	3,342,178.0	1,708.4	1.0	0.7
11/07/2022 06:00	8.3	13.3	6.4	117.9	3,437,939.9	2,008.4	1.1	0.8
11/07/2022 07:00	9.1	13.0	6.8	147.2	3,524,300.2	2,239.0	1.4	1.1
11/07/2022 08:00	8.1	13.3	6.3	113.5	3,543,430.1	1,992.4	1.0	0.8
11/07/2022 09:00	8.0	13.3	6.2	111.7	3,513,018.2	1,975.3	1.0	0.8
11/07/2022 10:00	8.4	13.3	6.5	115.3	3,494,166.3	1,964.7	1.0	0.8
11/07/2022 11:00	8.4	13.3	6.5	115.0	3,490,431.6	1,962.6	1.0	0.8
11/07/2022 12:00	8.4	13.3	6.5	115.0	3,492,565.7	1,963.8	1.0	0.8
11/07/2022 13:00	7.9	13.3	6.1	110.8	3,490,609.4	1,962.7	1.0	0.8
11/07/2022 14:00	8.3	13.1	6.3	121.1	3,483,409.9	2,060.4	1.1	0.8
11/07/2022 15:00	8.6	13.0	6.4	145.1	3,491,236.0	2,192.5	1.4	1.1
11/07/2022 16:00	8.8	12.9	6.5	156.0	3,462,181.8	2,250.1	1.5	1.4
11/07/2022 17:00	8.7	12.8	6.3	161.4	3,485,793.7	2,290.9	1.5	1.4
11/07/2022 18:00	8.7	12.8	6.3	161.3	3,495,075.3	2,297.0	1.5	1.4
11/07/2022 19:00	8.6	12.8	6.3	159.4	3,490,054.1	2,293.7	1.5	1.4
11/07/2022 20:00	8.6	12.8	6.3	154.9	3,483,663.5	2,289.5	1.5	1.4
11/07/2022 21:00	8.6	12.8	6.3	157.5	3,489,597.6	2,293.4	1.5	1.4
11/07/2022 22:00	8.4	12.9	6.2	147.6	3,513,351.6	2,257.7	1.4	1.1
11/07/2022 23:00	8.3	13.0	6.2	134.5	3,513,781.9	2,181.0	1.2	1.1
Average/Sum#:	10.2	13.4	9.4	135.3	3,329,455.4	1,932.3	1.4	1.0
Minimum:	7.4	12.8	6.1	96.6	1,539,624.3	314.8	1.0	0.4
Maximum:	31.0	17.6	55.4	205.6	3,543,430.1	2,297.0	3.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/08/2022 00:00	8.3	13.0	6.2	133.1	3,500,248.7	2,172.6	1.2	1.1
11/08/2022 01:00	8.3	13.0	6.2	131.4	3,533,604.0	2,167.5	1.2	1.1
11/08/2022 02:00	8.1	13.1	6.1	124.9	3,484,937.6	2,112.2	1.2	1.1
11/08/2022 03:00	8.3	13.0	6.2	130.0	3,522,844.2	2,160.9	1.2	1.1
11/08/2022 04:00	8.4	12.9	6.2	136.8	3,503,337.9	2,200.1	1.3	1.1
11/08/2022 05:00	8.4	12.9	6.2	140.9	3,493,921.0	2,219.7	1.3	1.1
11/08/2022 06:00	8.6	12.8	6.3	161.0	3,461,934.9	2,300.5	1.5	1.4
11/08/2022 07:00	8.8	12.9	6.5	140.5	3,484,319.3	2,213.6	1.3	1.1
11/08/2022 08:00	8.5	12.9	6.3	138.8	3,466,532.6	2,202.3	1.3	1.1
11/08/2022 09:00	8.4	12.9	6.2	139.5	3,463,541.9	2,200.4	1.3	1.1
11/08/2022 10:00	8.3	13.0	6.2	134.7	3,480,248.8	2,185.6	1.3	1.1
11/08/2022 11:00	7.7	13.2	5.9	115.0	3,523,580.9	2,032.7	1.0	0.8
11/08/2022 12:00	7.7	13.3	6.0	109.1	3,534,182.0	1,987.2	1.0	0.8
11/08/2022 13:00	7.5	13.3	5.8	108.3	3,530,447.2	1,985.1	1.0	0.8
11/08/2022 14:00	7.9	13.2	6.1	117.5	3,519,763.0	2,056.2	1.1	0.8
11/08/2022 15:00	7.9	13.2	6.1	117.3	3,519,934.2	2,056.3	1.1	0.8
11/08/2022 16:00	8.4	12.9	6.2	143.9	3,530,407.9	2,217.1	1.3	1.1
11/08/2022 17:00	8.2	13.0	6.1	136.3	3,505,726.4	2,201.6	1.3	1.1
11/08/2022 18:00	8.2	13.0	6.1	131.5	3,502,343.1	2,173.9	1.2	1.1
11/08/2022 19:00	8.3	13.0	6.2	139.3	3,513,369.7	2,206.4	1.3	1.1
11/08/2022 20:00	8.3	12.9	6.1	140.3	3,513,051.3	2,206.2	1.3	1.1
11/08/2022 21:00	8.3	12.9	6.1	140.7	3,510,344.2	2,204.5	1.3	1.1
11/08/2022 22:00	8.2	13.0	6.1	137.8	3,487,892.1	2,190.4	1.3	1.1
11/08/2022 23:00	8.1	13.0	6.0	130.0	3,499,042.3	2,146.3	1.2	1.1
Average/Sum#:	8.2	13.0	6.1	132.4	3,503,564.8	2,158.3	1.2	1.1
Minimum:	7.5	12.8	5.8	108.3	3,461,934.9	1,985.1	1.0	0.8
Maximum:	8.8	13.3	6.5	161.0	3,534,182.0	2,300.5	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/09/2022 00:00	8.1	13.0	6.0	131.2	3,513,714.7	2,155.3	1.2	1.1
11/09/2022 01:00	8.1	13.0	6.0	131.0	3,512,410.5	2,154.5	1.2	1.1
11/09/2022 02:00	8.2	13.0	6.1	136.7	3,534,726.0	2,194.0	1.3	1.1
11/09/2022 03:00	8.1	13.0	6.0	137.4	3,536,498.2	2,195.1	1.3	1.1
11/09/2022 04:00	8.1	13.0	6.0	130.4	3,524,800.5	2,162.1	1.2	1.1
11/09/2022 05:00	8.3	12.9	6.1	149.6	3,554,207.2	2,258.0	1.4	1.1
11/09/2022 06:00	8.4	12.9	6.2	167.2	3,537,115.5	2,298.8	1.6	1.4
11/09/2022 07:00	8.6	13.0	6.4	140.7	3,550,514.7	2,203.8	1.3	1.1
11/09/2022 08:00	8.2	13.1	6.2	135.3	3,525,615.7	2,162.6	1.2	1.1
11/09/2022 09:00	7.0	13.6	5.7	102.7	3,361,647.5	1,742.9	1.0	0.7
11/09/2022 10:00	7.1	13.7	5.8	101.1	3,327,701.3	1,701.0	1.0	0.7
11/09/2022 11:00	7.3	13.7	6.0	97.8	3,186,454.9	1,628.8	1.0	0.7
11/09/2022 12:00	7.2	13.7	5.9	101.7	3,334,548.4	1,704.5	1.0	0.7
11/09/2022 13:00	7.3	13.7	6.0	97.3	3,209,414.7	1,617.1	1.0	0.6
11/09/2022 14:00	7.2	13.7	5.9	100.7	3,303,247.2	1,688.5	1.0	0.7
11/09/2022 15:00	7.4	13.7	6.1	97.9	3,202,105.5	1,636.8	1.0	0.7
11/09/2022 16:00	8.4	13.2	6.4	124.7	3,522,294.8	2,083.4	1.1	0.8
11/09/2022 17:00	8.5	13.0	6.3	134.8	3,518,931.6	2,158.5	1.2	1.1
11/09/2022 18:00	7.5	13.3	5.8	114.5	3,535,397.3	2,013.7	1.0	0.8
11/09/2022 19:00	7.2	13.4	5.7	106.9	3,561,044.0	1,976.3	1.0	0.8
11/09/2022 20:00	7.3	13.4	5.7	107.4	3,567,530.7	1,979.9	1.0	0.8
11/09/2022 21:00	7.4	13.4	5.8	110.6	3,611,316.3	2,004.2	1.0	0.8
11/09/2022 22:00	7.3	13.4	5.7	107.4	3,596,721.1	1,996.1	1.0	0.8
11/09/2022 23:00	7.3	13.4	5.7	107.6	3,595,639.9	1,995.5	1.0	0.8
Average/Sum#:	7.7	13.3	6.0	119.7	3,467,649.9	1,988.0	1.1	0.9
Minimum:	7.0	12.9	5.7	97.3	3,186,454.9	1,617.1	1.0	0.6
Maximum:	8.6	13.7	6.4	167.2	3,611,316.3	2,298.8	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/10/2022 00:00	7.3	13.4	5.7	107.7	3,594,739.0	1,995.0	1.0	0.8
11/10/2022 01:00	7.3	13.4	5.7	107.7	3,591,675.8	1,993.3	1.0	0.8
11/10/2022 02:00	7.3	13.4	5.7	107.6	3,588,072.1	1,991.3	1.0	0.8
11/10/2022 03:00	7.3	13.4	5.7	107.6	3,593,297.5	1,994.2	1.0	0.8
11/10/2022 04:00	8.0	13.2	6.1	120.4	3,612,853.5	2,084.2	1.1	0.8
11/10/2022 05:00	8.3	13.1	6.3	137.7	3,591,191.7	2,176.6	1.2	1.1
11/10/2022 06:00	8.6	12.9	6.3	157.4	3,530,653.0	2,294.6	1.5	1.4
11/10/2022 07:00	8.3	13.2	6.4	134.2	3,585,017.8	2,120.5	1.2	1.1
11/10/2022 08:00	7.3	13.4	5.7	107.4	3,574,558.0	1,983.8	1.0	0.8
11/10/2022 09:00	7.3	13.4	5.7	107.0	3,542,304.5	1,965.9	1.0	0.8
11/10/2022 10:00	7.0	13.7	5.7	101.4	3,424,354.8	1,725.4	0.9	0.5
11/10/2022 11:00	7.2	13.7	5.9	101.7	3,398,752.5	1,712.5	0.9	0.5
11/10/2022 12:00	7.2	13.7	5.9	101.7	3,396,172.5	1,711.2	0.9	0.5
11/10/2022 13:00	7.2	13.7	5.9	94.1	3,101,647.0	1,562.8	1.0	0.6
11/10/2022 14:00	7.3	13.7	6.0	101.6	3,398,951.0	1,712.6	0.9	0.5
11/10/2022 15:00	7.5	13.6	6.1	102.3	3,357,241.7	1,716.1	1.0	0.7
11/10/2022 16:00	8.7	13.1	6.6	129.7	3,570,189.6	2,137.8	1.2	1.1
11/10/2022 17:00	8.8	12.9	6.5	155.4	3,576,086.5	2,271.9	1.4	1.1
11/10/2022 18:00	8.7	12.9	6.4	159.1	3,580,179.0	2,274.5	1.5	1.4
11/10/2022 19:00	8.6	12.9	6.3	160.0	3,585,530.8	2,277.9	1.5	1.4
11/10/2022 20:00	8.6	12.9	6.3	157.9	3,588,678.9	2,279.9	1.4	1.1
11/10/2022 21:00	8.6	12.9	6.3	156.9	3,590,567.8	2,281.1	1.4	1.1
11/10/2022 22:00	8.6	13.0	6.4	157.7	3,591,669.6	2,281.8	1.4	1.1
11/10/2022 23:00	8.6	13.0	6.4	155.0	3,599,516.1	2,260.5	1.4	1.1
Average/Sum#:	7.9	13.3	6.1	126.2	3,523,495.9	2,033.6	1.2	0.9
Minimum:	7.0	12.9	5.7	94.1	3,101,647.0	1,562.8	0.9	0.5
Maximum:	8.8	13.7	6.6	160.0	3,612,853.5	2,294.6	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/11/2022 00:00	8.6	13.0	6.4	158.9	3,590,410.4	2,281.0	1.4	1.1
11/11/2022 01:00	8.5	13.0	6.3	152.8	3,573,725.4	2,270.4	1.4	1.1
11/11/2022 02:00	8.2	13.1	6.2	132.1	3,597,244.1	2,154.0	1.2	1.1
11/11/2022 03:00	8.2	13.1	6.2	129.5	3,593,403.0	2,151.7	1.2	1.1
11/11/2022 04:00	8.5	13.0	6.3	152.9	3,618,465.1	2,272.4	1.4	1.1
11/11/2022 05:00	8.4	13.0	6.3	152.6	3,597,965.8	2,285.8	1.4	1.1
11/11/2022 06:00	8.3	13.0	6.2	151.7	3,644,898.2	2,289.0	1.4	1.1
11/11/2022 07:00	8.2	13.2	6.3	127.7	3,627,605.2	2,119.2	1.1	0.8
11/11/2022 08:00	7.2	13.4	5.7	106.6	3,569,267.7	1,954.8	1.0	0.8
11/11/2022 09:00	7.0	13.7	5.7	100.7	3,391,210.8	1,708.7	0.9	0.5
11/11/2022 10:00	7.1	13.7	5.8	101.5	3,398,554.1	1,712.4	0.9	0.5
11/11/2022 11:00	7.2	13.7	5.9	100.6	3,342,387.8	1,684.1	1.0	0.7
11/11/2022 12:00	7.3	13.7	6.0	100.9	3,343,380.2	1,684.6	1.0	0.7
11/11/2022 13:00	7.3	13.7	6.0	101.5	3,363,822.3	1,694.9	1.0	0.7
11/11/2022 14:00	7.3	13.7	6.0	95.2	3,122,089.1	1,573.1	1.0	0.6
11/11/2022 15:00	7.6	13.7	6.2	100.7	3,348,540.3	1,687.2	0.9	0.5
11/11/2022 16:00	8.5	13.3	6.6	119.8	3,484,658.4	1,984.8	1.1	0.8
11/11/2022 17:00	8.9	12.9	6.6	155.8	3,529,847.0	2,268.3	1.4	1.1
11/11/2022 18:00	8.7	12.9	6.4	157.5	3,522,066.1	2,263.3	1.5	1.4
11/11/2022 19:00	8.6	12.9	6.3	157.2	3,558,299.7	2,260.6	1.4	1.1
11/11/2022 20:00	8.5	13.0	6.3	157.0	3,547,438.8	2,253.7	1.4	1.1
11/11/2022 21:00	8.5	13.0	6.3	156.0	3,546,179.5	2,252.9	1.4	1.1
11/11/2022 22:00	8.5	13.0	6.3	151.4	3,576,426.9	2,246.0	1.4	1.1
11/11/2022 23:00	8.5	13.0	6.3	152.6	3,556,883.1	2,259.7	1.4	1.1
Average/Sum#:	8.1	13.2	6.2	132.2	3,501,865.4	2,054.7	1.2	0.9
Minimum:	7.0	12.9	5.7	95.2	3,122,089.1	1,573.1	0.9	0.5
Maximum:	8.9	13.7	6.6	158.9	3,644,898.2	2,289.0	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/12/2022 00:00	8.3	13.0	6.2	146.6	3,609,866.4	2,267.0	1.3	1.1
11/12/2022 01:00	8.3	12.9	6.1	147.4	3,623,560.6	2,275.6	1.3	1.1
11/12/2022 02:00	8.3	12.9	6.1	148.3	3,586,947.5	2,278.8	1.3	1.1
11/12/2022 03:00	8.3	12.9	6.1	149.1	3,589,465.9	2,280.4	1.4	1.1
11/12/2022 04:00	8.4	12.9	6.2	150.7	3,596,706.6	2,285.0	1.4	1.1
11/12/2022 05:00	8.4	12.9	6.2	149.4	3,597,178.8	2,285.3	1.4	1.1
11/12/2022 06:00	8.4	12.9	6.2	151.9	3,583,641.9	2,276.7	1.4	1.1
11/12/2022 07:00	8.6	13.2	6.6	130.8	3,556,276.8	2,103.5	1.2	1.1
11/12/2022 08:00	8.7	13.0	6.5	146.8	3,520,216.8	2,210.7	1.4	1.1
11/12/2022 09:00	6.9	13.6	5.6	102.9	3,370,905.6	1,747.7	1.0	0.7
11/12/2022 10:00	7.2	13.7	5.9	95.4	3,154,836.2	1,589.6	1.0	0.6
11/12/2022 11:00	7.3	13.7	6.0	93.5	3,084,777.3	1,554.3	1.0	0.6
11/12/2022 12:00	7.3	13.7	6.0	93.2	3,078,426.3	1,551.1	1.0	0.6
11/12/2022 13:00	7.4	13.7	6.1	94.5	3,116,333.6	1,570.2	1.0	0.6
11/12/2022 14:00	7.3	13.7	6.0	93.1	3,074,258.5	1,549.0	1.0	0.6
11/12/2022 15:00	7.7	13.6	6.2	106.3	3,504,748.3	1,791.5	1.0	0.7
11/12/2022 16:00	8.8	13.1	6.7	131.0	3,551,652.2	2,126.7	1.2	1.1
11/12/2022 17:00	8.9	12.9	6.6	152.2	3,535,161.2	2,245.9	1.4	1.1
11/12/2022 18:00	8.8	12.9	6.5	153.8	3,536,577.8	2,246.8	1.4	1.1
11/12/2022 19:00	8.7	12.9	6.4	155.5	3,543,503.6	2,251.2	1.4	1.1
11/12/2022 20:00	8.7	12.9	6.4	153.8	3,557,984.9	2,260.4	1.4	1.1
11/12/2022 21:00	8.8	12.9	6.5	156.6	3,557,040.5	2,259.8	1.4	1.1
11/12/2022 22:00	8.6	13.0	6.4	141.5	3,575,990.9	2,193.5	1.3	1.1
11/12/2022 23:00	8.6	13.0	6.4	141.8	3,571,263.2	2,190.6	1.3	1.1
Average/Sum#:	8.2	13.2	6.2	132.8	3,461,555.1	2,058.0	1.2	1.0
Minimum:	6.9	12.9	5.6	93.1	3,074,258.5	1,549.0	1.0	0.6
Maximum:	8.9	13.7	6.7	156.6	3,623,560.6	2,285.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/13/2022 00:00	8.4	13.0	6.3	136.4	3,598,121.3	2,180.8	1.2	1.1
11/13/2022 01:00	8.4	13.0	6.3	134.5	3,580,302.3	2,170.0	1.2	1.1
11/13/2022 02:00	8.4	13.0	6.3	135.3	3,615,614.4	2,165.0	1.2	1.1
11/13/2022 03:00	8.6	13.0	6.4	141.0	3,577,621.2	2,194.5	1.3	1.1
11/13/2022 04:00	8.5	13.0	6.3	139.8	3,612,805.5	2,189.7	1.3	1.1
11/13/2022 05:00	8.4	13.0	6.3	136.9	3,603,566.0	2,184.1	1.2	1.1
11/13/2022 06:00	8.6	13.0	6.4	141.4	3,578,436.3	2,195.0	1.3	1.1
11/13/2022 07:00	9.2	12.9	6.8	154.4	3,609,158.2	2,240.2	1.4	1.1
11/13/2022 08:00	8.0	13.3	6.2	125.1	3,452,354.0	1,966.4	1.2	1.0
11/13/2022 09:00	7.0	13.7	5.7	100.8	3,386,844.5	1,706.5	0.9	0.5
11/13/2022 10:00	7.1	13.7	5.8	101.3	3,389,623.1	1,707.9	0.9	0.5
11/13/2022 11:00	7.1	13.7	5.8	101.6	3,389,623.1	1,707.9	0.9	0.5
11/13/2022 12:00	7.2	13.7	5.9	101.5	3,387,439.9	1,706.8	0.9	0.5
11/13/2022 13:00	7.2	13.7	5.9	101.6	3,392,798.5	1,709.5	0.9	0.5
11/13/2022 14:00	7.2	13.7	5.9	99.9	3,329,685.9	1,677.7	0.9	0.5
11/13/2022 15:00	7.9	13.6	6.4	107.4	3,487,728.3	1,782.8	1.0	0.7
11/13/2022 16:00	9.0	13.1	6.8	140.4	3,486,815.3	2,138.8	1.3	1.1
11/13/2022 17:00	8.9	12.9	6.6	174.9	3,469,360.6	2,280.1	1.7	1.6
11/13/2022 18:00	8.8	12.9	6.5	176.0	3,469,969.2	2,280.5	1.7	1.6
11/13/2022 19:00	8.8	12.9	6.5	175.2	3,475,903.4	2,284.4	1.7	1.6
11/13/2022 20:00	8.8	12.9	6.5	177.3	3,481,685.4	2,288.2	1.7	1.6
11/13/2022 21:00	8.8	12.9	6.5	177.6	3,488,684.7	2,292.8	1.7	1.6
11/13/2022 22:00	8.8	12.9	6.5	179.1	3,492,184.3	2,295.1	1.7	1.6
11/13/2022 23:00	8.8	12.9	6.5	179.0	3,498,575.0	2,299.3	1.7	1.6
Average/Sum#:	8.2	13.2	6.3	139.1	3,493,954.2	2,068.5	1.3	1.1
Minimum:	7.0	12.9	5.7	99.9	3,329,685.9	1,677.7	0.9	0.5
Maximum:	9.2	13.7	6.8	179.1	3,615,614.4	2,299.3	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/14/2022 00:00	8.7	12.9	6.4	171.6	3,497,357.7	2,298.5	1.6	1.4
11/14/2022 01:00	8.6	12.9	6.3	162.9	3,522,805.8	2,289.5	1.5	1.4
11/14/2022 02:00	8.5	12.9	6.3	160.1	3,557,702.3	2,286.2	1.5	1.4
11/14/2022 03:00	8.2	13.1	6.2	135.5	3,574,857.6	2,166.7	1.2	1.1
11/14/2022 04:00	8.4	13.0	6.3	150.2	3,569,261.3	2,241.5	1.4	1.1
11/14/2022 05:00	8.5	12.9	6.3	161.7	3,543,885.7	2,303.2	1.5	1.4
11/14/2022 06:00	8.4	12.9	6.2	162.2	3,578,243.7	2,299.4	1.5	1.4
11/14/2022 07:00	8.6	13.1	6.5	138.7	3,577,947.3	2,194.7	1.3	1.1
11/14/2022 08:00	8.3	13.1	6.3	132.1	3,605,761.2	2,159.1	1.2	1.1
11/14/2022 09:00	8.3	13.1	6.3	136.0	3,576,507.5	2,167.7	1.2	1.1
11/14/2022 10:00	8.4	13.1	6.4	136.6	3,561,328.4	2,158.5	1.2	1.1
11/14/2022 11:00	8.4	13.1	6.4	137.0	3,514,635.9	2,130.2	1.3	1.1
11/14/2022 12:00	8.4	13.1	6.4	138.1	3,507,706.3	2,126.0	1.3	1.1
11/14/2022 13:00	8.5	13.1	6.4	145.4	3,512,084.5	2,154.3	1.3	1.1
11/14/2022 14:00	8.6	13.1	6.5	145.3	3,464,321.5	2,150.3	1.4	1.1
11/14/2022 15:00	8.3	13.2	6.4	134.2	3,516,039.4	2,079.7	1.2	1.0
11/14/2022 16:00	8.8	12.9	6.5	166.4	3,468,182.7	2,254.0	1.6	1.4
11/14/2022 17:00	8.5	13.0	6.3	152.7	3,500,153.2	2,198.1	1.4	1.1
11/14/2022 18:00	8.4	13.0	6.3	146.6	3,515,554.1	2,182.1	1.4	1.1
11/14/2022 19:00	8.6	13.0	6.4	158.8	3,487,208.1	2,240.9	1.5	1.3
11/14/2022 20:00	8.5	13.0	6.3	159.8	3,491,876.6	2,243.9	1.5	1.3
11/14/2022 21:00	8.6	12.9	6.3	171.2	3,520,497.7	2,288.0	1.6	1.4
11/14/2022 22:00	8.6	12.9	6.3	168.9	3,521,574.8	2,288.7	1.6	1.4
11/14/2022 23:00	8.5	12.9	6.3	165.9	3,534,048.6	2,271.0	1.5	1.4
Average/Sum#:	8.5	13.0	6.3	151.6	3,529,980.9	2,215.5	1.4	1.2
Minimum:	8.2	12.9	6.2	132.1	3,464,321.5	2,079.7	1.2	1.0
Maximum:	8.8	13.2	6.5	171.6	3,605,761.2	2,303.2	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/15/2022 00:00	8.7	12.9	6.4	175.6	3,540,962.2	2,301.3	1.6	1.4
11/15/2022 01:00	8.7	12.9	6.4	173.4	3,500,248.7	2,300.4	1.6	1.4
11/15/2022 02:00	8.7	12.9	6.4	170.5	3,524,806.0	2,290.8	1.6	1.4
11/15/2022 03:00	8.6	13.0	6.4	164.6	3,510,342.5	2,281.4	1.5	1.4
11/15/2022 04:00	8.6	13.0	6.4	160.0	3,523,933.5	2,264.5	1.5	1.4
11/15/2022 05:00	8.6	13.0	6.4	155.7	3,530,596.4	2,243.0	1.4	1.1
11/15/2022 06:00	8.5	13.0	6.3	162.3	3,523,879.3	2,213.0	1.5	1.3
11/15/2022 07:00	9.0	13.1	6.8	143.7	3,517,487.4	2,183.3	1.3	1.1
11/15/2022 08:00	8.6	13.1	6.5	140.9	3,519,915.6	2,133.4	1.3	1.1
11/15/2022 09:00	8.7	13.2	6.7	144.4	3,521,257.7	2,108.5	1.3	1.1
11/15/2022 10:00	8.7	13.1	6.6	143.9	3,533,774.9	2,141.8	1.3	1.1
11/15/2022 11:00	7.9	13.2	6.1	121.2	3,520,790.1	2,056.8	1.1	0.8
11/15/2022 12:00	7.5	13.4	5.9	107.8	3,563,927.0	1,977.9	1.0	0.8
11/15/2022 13:00	7.5	13.3	5.8	106.4	3,566,269.4	1,979.2	1.0	0.8
11/15/2022 14:00	7.6	13.3	5.9	109.8	3,566,269.4	1,979.2	1.0	0.8
11/15/2022 15:00	7.9	13.2	6.1	113.6	3,543,648.9	2,018.4	1.0	0.8
11/15/2022 16:00	8.5	13.0	6.3	132.5	3,546,149.2	2,149.3	1.2	1.1
11/15/2022 17:00	8.4	13.0	6.3	136.7	3,550,232.7	2,177.7	1.2	1.1
11/15/2022 18:00	8.4	13.0	6.3	137.5	3,534,242.7	2,193.7	1.3	1.1
11/15/2022 19:00	8.5	13.0	6.3	147.1	3,525,703.9	2,188.4	1.4	1.1
11/15/2022 20:00	8.9	13.1	6.7	164.3	3,497,127.7	2,196.2	1.5	1.3
11/15/2022 21:00	8.8	13.0	6.6	170.5	3,492,032.2	2,244.0	1.6	1.3
11/15/2022 22:00	8.6	13.1	6.5	156.3	3,503,632.0	2,174.7	1.5	1.3
11/15/2022 23:00	8.6	13.1	6.5	151.3	3,544,526.8	2,174.2	1.4	1.1
Average/Sum#:	8.4	13.1	6.4	145.4	3,529,239.8	2,165.5	1.3	1.1
Minimum:	7.5	12.9	5.8	106.4	3,492,032.2	1,977.9	1.0	0.8
Maximum:	9.0	13.4	6.8	175.6	3,566,269.4	2,301.3	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/16/2022 00:00	8.6	13.1	6.5	153.7	3,534,419.1	2,168.0	1.4	1.1
11/16/2022 01:00	8.5	13.1	6.4	146.8	3,532,125.0	2,140.8	1.4	1.1
11/16/2022 02:00	8.6	13.1	6.5	149.8	3,530,669.5	2,165.7	1.4	1.1
11/16/2022 03:00	8.6	13.1	6.5	149.1	3,533,604.0	2,167.5	1.4	1.1
11/16/2022 04:00	8.6	13.1	6.5	149.5	3,510,076.4	2,178.7	1.4	1.1
11/16/2022 05:00	8.5	13.1	6.4	147.4	3,545,668.0	2,174.9	1.4	1.1
11/16/2022 06:00	8.4	13.1	6.4	147.6	3,534,419.1	2,168.0	1.4	1.1
11/16/2022 07:00	9.3	13.0	6.9	169.3	3,527,448.3	2,241.0	1.6	1.3
11/16/2022 08:00	7.7	13.4	6.1	115.4	3,533,826.3	1,987.0	1.0	0.8
11/16/2022 09:00	7.9	13.3	6.1	117.4	3,590,381.7	2,018.8	1.0	0.8
11/16/2022 10:00	7.5	13.4	5.9	108.5	3,577,260.8	1,985.3	1.0	0.8
11/16/2022 11:00	7.7	13.4	6.1	110.7	1,301,805.0	1,986.8	2.9	2.2
11/16/2022 12:00	7.9	13.4	6.2	113.9	3,531,870.0	1,985.9	1.0	0.8
11/16/2022 13:00	7.6	13.4	6.0	108.5	3,533,648.5	1,986.9	1.0	0.8
11/16/2022 14:00	7.4	13.3	5.7	107.7	3,530,980.7	1,985.4	1.0	0.8
11/16/2022 15:00	8.1	13.1	6.1	122.0	3,486,752.5	2,113.3	1.1	0.8
11/16/2022 16:00	8.3	13.0	6.2	127.0	3,466,873.0	2,177.2	1.2	1.1
11/16/2022 17:00	8.2	13.0	6.1	129.3	3,491,713.7	2,192.8	1.2	1.1
11/16/2022 18:00	8.4	12.9	6.2	145.0	3,466,773.9	2,278.4	1.4	1.1
11/16/2022 19:00	8.3	12.9	6.1	144.5	3,479,098.7	2,286.5	1.4	1.1
11/16/2022 20:00	8.2	12.9	6.0	142.5	3,479,403.0	2,286.7	1.3	1.1
11/16/2022 21:00	8.2	13.0	6.1	148.0	3,488,031.6	2,266.9	1.4	1.1
11/16/2022 22:00	8.1	13.0	6.0	139.4	3,511,550.4	2,230.9	1.3	1.1
11/16/2022 23:00	8.3	13.0	6.2	149.4	3,473,414.2	2,257.4	1.4	1.1
Average/Sum#:	8.2	13.1	6.2	135.1	3,516,956.9	2,143.0	1.3	1.0
Minimum:	7.4	12.9	5.7	107.7	3,466,773.9	1,985.3	1.0	0.8
Maximum:	9.3	13.4	6.9	169.3	3,590,381.7	2,286.7	1.6	1.3
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/17/2022 00:00	8.0	13.1	6.1	131.4	3,508,626.4	2,177.8	1.2	1.1
11/17/2022 01:00	8.1	13.1	6.1	133.6	3,472,923.9	2,181.0	1.2	1.1
11/17/2022 02:00	8.0	13.1	6.1	129.6	3,489,293.3	2,165.8	1.2	1.1
11/17/2022 03:00	8.0	13.1	6.1	128.4	3,531,158.6	2,166.0	1.2	1.1
11/17/2022 04:00	8.0	13.1	6.1	131.6	3,536,212.4	2,169.1	1.2	1.1
11/17/2022 05:00	8.0	13.1	6.1	146.4	3,515,070.7	2,181.8	1.4	1.1
11/17/2022 06:00	8.3	12.9	6.1	149.7	3,486,706.6	2,291.5	1.4	1.1
11/17/2022 07:00	8.5	13.1	6.4	134.6	3,515,554.1	2,182.1	1.2	1.1
11/17/2022 08:00	7.1	13.4	5.6	107.7	3,500,986.1	1,994.1	1.0	0.8
11/17/2022 09:00	8.2	13.1	6.2	129.6	3,506,378.5	2,150.8	1.2	1.1
11/17/2022 10:00	8.1	13.1	6.1	128.3	3,493,988.5	2,143.2	1.2	1.1
11/17/2022 11:00	8.2	13.1	6.2	135.9	3,462,732.9	2,174.6	1.3	1.1
11/17/2022 12:00	8.3	13.0	6.2	146.5	3,420,915.5	2,198.3	1.4	1.1
11/17/2022 13:00	8.4	13.0	6.3	145.8	3,437,570.0	2,183.9	1.4	1.1
11/17/2022 14:00	8.0	13.2	6.1	120.2	3,450,435.9	2,015.7	1.1	0.8
11/17/2022 15:00	8.5	13.1	6.4	140.6	3,432,583.0	2,130.6	1.3	1.1
11/17/2022 16:00	8.6	13.0	6.4	161.2	3,413,214.2	2,243.2	1.5	1.3
11/17/2022 17:00	8.5	12.9	6.3	164.1	3,426,420.2	2,276.9	1.6	1.4
11/17/2022 18:00	8.3	12.9	6.1	159.1	3,424,162.9	2,275.4	1.5	1.4
11/17/2022 19:00	8.3	12.9	6.1	156.8	3,428,978.5	2,278.6	1.5	1.4
11/17/2022 20:00	8.3	12.9	6.1	158.5	3,432,289.2	2,280.8	1.5	1.4
11/17/2022 21:00	8.3	12.9	6.1	159.7	3,434,847.4	2,282.5	1.5	1.4
11/17/2022 22:00	8.3	12.9	6.1	155.7	3,453,536.1	2,269.7	1.5	1.4
11/17/2022 23:00	8.0	13.0	6.0	140.4	3,505,254.2	2,226.9	1.3	1.1
Average/Sum#:	8.2	13.0	6.1	141.5	3,469,993.3	2,193.3	1.3	1.2
Minimum:	7.1	12.9	5.6	107.7	3,413,214.2	1,994.1	1.0	0.8
Maximum:	8.6	13.4	6.4	164.1	3,536,212.4	2,291.5	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/18/2022 00:00	8.0	13.1	6.1	130.9	3,508,465.3	2,177.7	1.2	1.1
11/18/2022 01:00	8.2	13.0	6.1	138.9	3,484,388.9	2,188.2	1.3	1.1
11/18/2022 02:00	8.2	13.0	6.1	141.1	3,453,940.1	2,194.3	1.3	1.1
11/18/2022 03:00	8.1	13.0	6.0	135.1	3,484,866.6	2,188.5	1.3	1.1
11/18/2022 04:00	8.2	13.0	6.1	140.0	3,440,245.9	2,185.6	1.3	1.1
11/18/2022 05:00	8.1	13.1	6.1	138.6	3,461,299.7	2,173.7	1.3	1.1
11/18/2022 06:00	8.0	13.1	6.1	138.7	3,480,271.2	2,160.2	1.3	1.1
11/18/2022 07:00	8.9	13.0	6.6	156.3	3,470,182.9	2,255.3	1.5	1.4
11/18/2022 08:00	8.4	13.1	6.4	139.6	3,467,669.2	2,177.7	1.3	1.1
11/18/2022 09:00	8.4	13.0	6.3	142.2	3,479,293.3	2,185.0	1.3	1.1
11/18/2022 10:00	8.5	13.0	6.3	149.2	3,447,801.3	2,190.4	1.4	1.1
11/18/2022 11:00	8.4	13.1	6.4	140.7	3,456,655.4	2,120.3	1.3	1.1
11/18/2022 12:00	8.2	13.3	6.4	117.0	3,459,025.5	1,970.2	1.1	0.8
11/18/2022 13:00	8.4	13.3	6.5	119.7	3,464,117.0	1,973.1	1.1	0.8
11/18/2022 14:00	8.4	13.3	6.5	121.4	3,466,574.9	1,974.5	1.1	0.8
11/18/2022 15:00	8.6	13.2	6.6	133.9	3,480,197.6	2,058.5	1.2	1.0
11/18/2022 16:00	8.7	13.0	6.5	156.6	3,438,947.8	2,235.0	1.5	1.3
11/18/2022 17:00	8.5	13.0	6.3	159.2	3,435,581.5	2,257.9	1.5	1.4
11/18/2022 18:00	8.4	13.0	6.3	160.3	3,478,030.2	2,260.4	1.5	1.4
11/18/2022 19:00	8.4	13.0	6.3	157.0	3,482,646.2	2,263.4	1.5	1.4
11/18/2022 20:00	8.3	13.0	6.2	144.4	3,467,289.2	2,228.1	1.4	1.1
11/18/2022 21:00	8.2	13.1	6.2	138.9	3,473,560.9	2,181.4	1.3	1.1
11/18/2022 22:00	8.0	13.1	6.1	138.8	3,496,923.0	2,145.0	1.3	1.1
11/18/2022 23:00	8.3	13.0	6.2	149.8	3,484,251.4	2,239.0	1.4	1.1
Average/Sum#:	8.3	13.1	6.3	141.2	3,469,259.4	2,166.0	1.3	1.1
Minimum:	8.0	13.0	6.0	117.0	3,435,581.5	1,970.2	1.1	0.8
Maximum:	8.9	13.3	6.6	160.3	3,508,465.3	2,263.4	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/19/2022 00:00	8.2	13.1	6.2	138.3	3,493,624.5	2,194.0	1.3	1.1
11/19/2022 01:00	8.1	13.1	6.1	134.5	3,499,926.5	2,172.4	1.2	1.1
11/19/2022 02:00	8.1	13.1	6.1	131.6	3,535,560.3	2,168.7	1.2	1.1
11/19/2022 03:00	8.1	13.1	6.1	128.6	3,538,724.6	2,144.8	1.2	1.1
11/19/2022 04:00	8.3	13.0	6.2	149.2	3,523,041.0	2,238.2	1.4	1.1
11/19/2022 05:00	8.3	13.0	6.2	152.3	3,534,982.3	2,271.6	1.4	1.1
11/19/2022 06:00	8.2	13.0	6.1	140.8	3,532,159.5	2,218.2	1.3	1.1
11/19/2022 07:00	8.2	13.2	6.3	129.7	3,517,605.8	2,132.0	1.2	1.1
11/19/2022 08:00	7.2	13.4	5.7	106.0	3,519,242.8	1,978.8	1.0	0.8
11/19/2022 09:00	7.5	13.4	5.9	107.7	3,519,242.8	1,978.8	1.0	0.8
11/19/2022 10:00	7.8	13.4	6.1	108.8	3,512,662.5	1,975.1	1.0	0.8
11/19/2022 11:00	8.0	13.4	6.3	110.9	3,504,659.3	1,970.6	1.0	0.8
11/19/2022 12:00	8.3	13.3	6.4	117.0	3,460,430.1	1,971.0	1.1	0.8
11/19/2022 13:00	8.4	13.3	6.5	120.9	3,462,010.2	1,971.9	1.1	0.8
11/19/2022 14:00	8.4	13.3	6.5	121.8	3,459,025.5	1,970.2	1.1	0.8
11/19/2022 15:00	8.7	13.2	6.7	136.7	3,467,348.7	2,050.9	1.3	1.0
11/19/2022 16:00	8.7	13.1	6.6	150.8	3,437,884.8	2,184.1	1.4	1.1
11/19/2022 17:00	8.6	13.0	6.4	152.5	3,426,362.1	2,201.8	1.5	1.3
11/19/2022 18:00	8.5	13.1	6.4	149.8	3,458,819.7	2,197.4	1.4	1.1
11/19/2022 19:00	8.6	13.0	6.4	163.2	3,439,841.9	2,260.7	1.6	1.4
11/19/2022 20:00	8.4	13.0	6.3	150.0	3,453,750.5	2,219.4	1.4	1.1
11/19/2022 21:00	8.1	13.1	6.1	138.9	3,467,350.7	2,177.5	1.3	1.1
11/19/2022 22:00	7.8	13.1	5.9	137.4	3,546,809.2	2,175.6	1.3	1.1
11/19/2022 23:00	7.8	13.1	5.9	137.9	3,537,074.7	2,143.8	1.3	1.1
Average/Sum#:	8.2	13.2	6.2	134.0	3,493,672.5	2,123.6	1.3	1.0
Minimum:	7.2	13.0	5.7	106.0	3,426,362.1	1,970.2	1.0	0.8
Maximum:	8.7	13.4	6.7	163.2	3,546,809.2	2,271.6	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/20/2022 00:00	7.7	13.2	5.9	131.0	3,518,585.7	2,106.9	1.2	1.1
11/20/2022 01:00	7.7	13.2	5.9	132.1	3,514,686.9	2,078.9	1.2	1.0
11/20/2022 02:00	7.7	13.2	5.9	135.3	3,530,204.9	2,062.3	1.2	1.0
11/20/2022 03:00	7.6	13.3	5.9	134.1	3,532,259.0	2,063.5	1.2	1.0
11/20/2022 04:00	7.6	13.3	5.9	134.2	3,544,241.5	2,070.5	1.2	1.0
11/20/2022 05:00	7.9	13.1	6.0	145.7	3,559,688.3	2,183.5	1.3	1.1
11/20/2022 06:00	8.1	13.0	6.0	142.1	3,543,230.0	2,276.9	1.3	1.1
11/20/2022 07:00	8.0	13.2	6.1	131.2	3,486,257.5	2,113.0	1.2	1.1
11/20/2022 08:00	6.5	13.7	5.3	97.9	3,333,179.0	1,703.8	0.9	0.5
11/20/2022 09:00	6.8	13.7	5.6	99.3	3,342,569.3	1,708.6	0.9	0.5
11/20/2022 10:00	6.8	13.8	5.7	92.3	3,062,619.8	1,565.5	0.9	0.5
11/20/2022 11:00	6.9	13.8	5.7	92.0	3,058,902.8	1,563.6	0.9	0.5
11/20/2022 12:00	6.9	13.8	5.7	90.2	3,043,297.6	1,533.4	0.9	0.5
11/20/2022 13:00	6.9	13.8	5.7	89.4	3,024,443.2	1,523.9	0.9	0.5
11/20/2022 14:00	6.9	13.7	5.7	98.7	3,281,218.0	1,701.2	0.9	0.5
11/20/2022 15:00	7.6	13.7	6.2	102.1	3,323,843.7	1,723.3	1.0	0.7
11/20/2022 16:00	9.0	13.1	6.8	143.0	3,483,654.5	2,162.3	1.3	1.1
11/20/2022 17:00	8.8	13.0	6.6	165.8	3,463,730.7	2,276.4	1.6	1.4
11/20/2022 18:00	8.5	13.0	6.3	158.4	3,447,602.0	2,265.8	1.5	1.4
11/20/2022 19:00	8.4	13.0	6.3	159.9	3,433,907.7	2,256.8	1.5	1.4
11/20/2022 20:00	8.3	13.0	6.2	156.2	3,440,298.4	2,261.0	1.5	1.4
11/20/2022 21:00	8.1	13.0	6.0	144.9	3,469,995.5	2,204.5	1.4	1.1
11/20/2022 22:00	8.0	13.1	6.1	132.3	3,493,321.0	2,168.3	1.2	1.1
11/20/2022 23:00	7.9	13.1	6.0	128.8	3,510,454.2	2,153.3	1.2	1.1
Average/Sum#:	7.7	13.3	6.0	126.5	3,393,424.6	1,988.6	1.2	0.9
Minimum:	6.5	13.0	5.3	89.4	3,024,443.2	1,523.9	0.9	0.5
Maximum:	9.0	13.8	6.8	165.8	3,559,688.3	2,276.9	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/21/2022 00:00	7.8	13.1	5.9	128.4	3,521,866.1	2,160.3	1.2	1.1
11/21/2022 01:00	7.7	13.1	5.8	120.3	3,526,680.3	2,137.5	1.1	0.9
11/21/2022 02:00	7.4	13.3	5.7	113.6	3,529,691.3	2,062.0	1.0	0.8
11/21/2022 03:00	8.1	13.1	6.1	132.9	3,503,148.7	2,174.4	1.2	1.1
11/21/2022 04:00	8.2	13.0	6.1	145.3	3,511,017.4	2,256.2	1.4	1.1
11/21/2022 05:00	8.0	13.0	6.0	143.8	3,527,979.6	2,267.1	1.3	1.1
11/21/2022 06:00	8.0	13.0	6.0	145.0	3,514,496.9	2,284.1	1.3	1.1
11/21/2022 07:00	8.1	13.2	6.2	131.8	3,505,726.4	2,150.4	1.2	1.1
11/21/2022 08:00	6.8	13.4	5.3	104.4	3,546,809.2	1,968.4	0.9	0.6
11/21/2022 09:00	6.9	13.4	5.4	104.9	3,547,349.7	1,968.7	0.9	0.6
11/21/2022 10:00	7.5	13.4	5.9	107.5	3,501,991.6	1,969.1	1.0	0.8
11/21/2022 11:00	7.8	13.4	6.1	109.4	3,519,598.5	1,979.0	1.0	0.8
11/21/2022 12:00	8.2	13.3	6.4	117.7	3,477,109.0	1,980.5	1.1	0.8
11/21/2022 13:00	8.3	13.3	6.4	118.6	3,476,757.8	1,980.3	1.1	0.8
11/21/2022 14:00	8.8	13.1	6.7	149.7	3,440,917.6	2,160.9	1.4	1.1
11/21/2022 15:00	8.9	12.9	6.6	170.7	3,425,691.2	2,251.4	1.6	1.4
11/21/2022 16:00	8.1	12.9	6.0	135.2	3,465,110.5	2,226.7	1.3	1.1
11/21/2022 17:00	8.2	12.9	6.0	141.2	3,459,013.8	2,273.3	1.3	1.1
11/21/2022 18:00	8.2	12.9	6.0	142.3	3,513,419.8	2,283.4	1.3	1.1
11/21/2022 19:00	8.4	13.0	6.3	154.3	3,446,536.9	2,265.1	1.5	1.4
11/21/2022 20:00	8.3	13.0	6.2	154.9	3,446,993.3	2,265.4	1.5	1.4
11/21/2022 21:00	8.3	13.0	6.2	153.9	3,450,645.1	2,267.8	1.5	1.4
11/21/2022 22:00	8.3	13.0	6.2	154.2	3,445,623.9	2,264.5	1.5	1.4
11/21/2022 23:00	8.1	13.0	6.0	144.5	3,468,378.5	2,228.8	1.4	1.1
Average/Sum#:	8.0	13.1	6.1	134.4	3,490,523.0	2,159.4	1.3	1.1
Minimum:	6.8	12.9	5.3	104.4	3,425,691.2	1,968.4	0.9	0.6
Maximum:	8.9	13.4	6.7	170.7	3,547,349.7	2,284.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/22/2022 00:00	7.9	13.1	6.0	127.7	3,471,732.5	2,154.9	1.2	1.1
11/22/2022 01:00	7.8	13.1	5.9	122.0	3,514,635.9	2,130.2	1.1	0.9
11/22/2022 02:00	7.9	13.2	6.1	120.9	3,509,233.5	2,101.3	1.1	0.8
11/22/2022 03:00	6.9	13.4	5.4	106.3	3,476,406.7	1,980.1	1.0	0.8
11/22/2022 04:00	7.0	13.4	5.5	106.1	3,530,980.7	1,985.4	1.0	0.8
11/22/2022 05:00	7.6	13.2	5.8	116.5	3,501,499.8	2,071.1	1.1	0.8
11/22/2022 06:00	7.9	13.1	6.0	121.8	3,515,182.0	2,156.2	1.1	0.9
11/22/2022 07:00	7.7	13.2	5.9	125.7	3,545,625.7	2,097.2	1.1	0.8
11/22/2022 08:00	7.6	13.3	5.9	112.8	3,519,249.5	2,055.9	1.0	0.8
11/22/2022 09:00	6.7	13.7	5.5	96.6	3,178,607.6	1,648.0	1.0	0.7
11/22/2022 10:00	7.3	13.6	5.9	98.2	3,229,719.9	1,674.5	1.0	0.7
11/22/2022 11:00	6.8	13.7	5.6	103.6	3,511,595.4	1,795.0	0.9	0.5
11/22/2022 12:00	6.8	13.7	5.6	92.6	3,044,817.3	1,556.4	1.0	0.6
11/22/2022 13:00	7.3	13.7	6.0	95.4	3,163,566.0	1,617.1	0.9	0.5
11/22/2022 14:00	7.1	13.6	5.7	103.9	3,432,240.4	1,779.5	1.0	0.7
11/22/2022 15:00	7.1	13.6	5.7	103.8	3,436,290.8	1,781.6	1.0	0.7
11/22/2022 16:00	7.7	13.4	6.1	111.3	3,413,779.4	1,919.5	1.0	0.8
11/22/2022 17:00	8.2	13.0	6.1	126.3	3,489,643.6	2,191.5	1.2	1.1
11/22/2022 18:00	7.9	13.2	6.1	118.0	3,475,802.0	2,055.9	1.1	0.8
11/22/2022 19:00	7.5	13.3	5.8	109.1	3,509,588.9	1,999.0	1.0	0.8
11/22/2022 20:00	8.1	13.1	6.1	128.1	3,514,692.9	2,155.9	1.2	1.1
11/22/2022 21:00	7.5	13.3	5.8	113.4	3,481,761.5	2,034.0	1.0	0.8
11/22/2022 22:00	7.5	13.3	5.8	115.1	3,501,104.6	2,045.3	1.1	0.8
11/22/2022 23:00	6.9	13.4	5.4	104.9	3,508,927.7	1,973.0	1.0	0.8
Average/Sum#:	7.4	13.4	5.8	111.7	3,436,528.5	1,956.6	1.0	0.8
Minimum:	6.7	13.0	5.4	92.6	3,044,817.3	1,556.4	0.9	0.5
Maximum:	8.2	13.7	6.1	128.1	3,545,625.7	2,191.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/23/2022 00:00	7.0	13.4	5.5	105.2	3,511,239.7	1,974.3	1.0	0.8
11/23/2022 01:00	6.9	13.4	5.4	105.1	3,512,662.5	1,975.1	1.0	0.8
11/23/2022 02:00	7.1	13.4	5.6	105.9	3,510,350.5	1,973.8	1.0	0.8
11/23/2022 03:00	6.8	13.4	5.3	104.6	3,514,974.5	1,976.4	1.0	0.8
11/23/2022 04:00	7.4	13.4	5.8	107.5	3,525,645.3	1,982.4	1.0	0.8
11/23/2022 05:00	8.1	13.2	6.2	118.9	3,464,476.7	2,074.5	1.1	0.8
11/23/2022 06:00	7.5	13.3	5.8	116.2	3,434,917.2	2,056.8	1.1	0.8
11/23/2022 07:00	8.2	13.2	6.3	119.0	3,525,432.8	2,111.0	1.1	0.8
11/23/2022 08:00	7.6	13.3	5.9	111.4	3,475,217.7	2,004.8	1.0	0.8
11/23/2022 09:00	6.8	13.7	5.6	99.4	3,331,613.9	1,703.0	0.9	0.5
11/23/2022 10:00	6.9	13.8	5.7	91.9	3,040,709.0	1,554.3	1.0	0.6
11/23/2022 11:00	6.9	13.8	5.7	91.6	3,033,470.6	1,550.6	1.0	0.6
11/23/2022 12:00	6.9	13.8	5.7	84.4	2,823,792.8	1,422.8	0.9	0.4
11/23/2022 13:00	6.9	13.8	5.7	91.2	3,094,303.7	1,559.1	0.9	0.5
11/23/2022 14:00	7.0	13.8	5.8	95.1	3,235,414.0	1,630.2	0.9	0.5
11/23/2022 15:00	8.1	13.7	6.6	99.8	3,201,518.6	1,636.5	1.0	0.7
11/23/2022 16:00	8.5	13.2	6.5	120.9	3,482,297.7	2,110.6	1.1	0.8
11/23/2022 17:00	8.1	13.1	6.1	124.9	3,479,771.1	2,185.3	1.2	1.1
11/23/2022 18:00	7.7	13.2	5.9	117.8	3,507,730.5	2,100.4	1.1	0.8
11/23/2022 19:00	7.7	13.3	6.0	113.7	3,532,259.0	2,063.5	1.0	0.8
11/23/2022 20:00	8.1	13.1	6.1	125.1	3,475,949.4	2,182.9	1.2	1.1
11/23/2022 21:00	8.1	13.1	6.1	127.4	3,506,204.1	2,201.9	1.2	1.1
11/23/2022 22:00	8.0	13.1	6.1	124.3	3,506,209.7	2,176.3	1.1	0.9
11/23/2022 23:00	7.9	13.1	6.0	123.4	3,498,476.5	2,171.5	1.1	0.9
Average/Sum#:	7.5	13.4	5.9	109.4	3,384,359.9	1,932.4	1.0	0.8
Minimum:	6.8	13.1	5.3	84.4	2,823,792.8	1,422.8	0.9	0.4
Maximum:	8.5	13.8	6.6	127.4	3,532,259.0	2,201.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/24/2022 00:00	7.2	13.4	5.7	107.8	3,494,841.3	1,990.6	1.0	0.8
11/24/2022 01:00	7.1	13.4	5.6	105.9	3,515,863.7	1,976.9	1.0	0.8
11/24/2022 02:00	7.1	13.4	5.6	106.3	3,515,508.0	1,976.7	1.0	0.8
11/24/2022 03:00	7.9	13.3	6.1	112.9	3,545,580.2	2,019.5	1.0	0.8
11/24/2022 04:00	7.5	13.3	5.8	111.8	3,513,353.6	2,026.8	1.0	0.8
11/24/2022 05:00	7.8	13.2	6.0	117.2	3,553,740.8	2,102.0	1.1	0.8
11/24/2022 06:00	8.5	13.1	6.4	161.3	3,448,745.8	2,191.0	1.5	1.3
11/24/2022 07:00	8.5	13.2	6.5	135.9	3,419,159.2	2,097.3	1.3	1.0
11/24/2022 08:00	6.5	13.7	5.3	98.8	3,350,785.8	1,712.8	0.9	0.5
11/24/2022 09:00	6.7	13.7	5.5	98.7	3,318,897.8	1,696.5	0.9	0.5
11/24/2022 10:00	6.8	13.7	5.6	99.4	3,332,983.3	1,703.7	0.9	0.5
11/24/2022 11:00	6.8	13.8	5.7	91.7	3,074,258.5	1,549.0	0.9	0.5
11/24/2022 12:00	7.0	13.8	5.8	82.5	2,678,911.6	1,349.8	1.0	0.5
11/24/2022 13:00	7.1	13.8	5.9	81.8	2,669,782.1	1,345.2	1.0	0.5
11/24/2022 14:00	6.9	13.8	5.7	91.0	3,078,823.3	1,551.3	0.9	0.5
11/24/2022 15:00	7.3	13.8	6.1	87.6	2,859,516.9	1,440.8	1.0	0.6
11/24/2022 16:00	7.2	13.7	5.9	103.2	3,436,863.9	1,756.8	0.9	0.5
11/24/2022 17:00	6.9	13.7	5.7	101.7	3,433,929.5	1,755.3	0.9	0.5
11/24/2022 18:00	6.9	13.7	5.7	101.2	3,400,280.7	1,738.1	0.9	0.5
11/24/2022 19:00	6.9	13.7	5.7	101.1	3,395,585.6	1,735.7	0.9	0.5
11/24/2022 20:00	6.9	13.7	5.7	101.3	3,396,563.7	1,736.2	0.9	0.5
11/24/2022 21:00	6.9	13.7	5.7	101.5	3,402,824.0	1,739.4	0.9	0.5
11/24/2022 22:00	6.9	13.7	5.7	101.6	3,409,475.5	1,742.8	0.9	0.5
11/24/2022 23:00	6.9	13.7	5.7	101.7	3,412,801.2	1,744.5	0.9	0.5
Average/Sum#:	7.2	13.6	5.8	104.3	3,319,128.2	1,778.3	1.0	0.6
Minimum:	6.5	13.1	5.3	81.8	2,669,782.1	1,345.2	0.9	0.5
Maximum:	8.5	13.8	6.5	161.3	3,553,740.8	2,191.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/25/2022 00:00	6.9	13.7	5.7	101.8	3,416,713.8	1,746.5	0.9	0.5
11/25/2022 01:00	6.9	13.7	5.7	101.9	3,417,300.7	1,746.8	0.9	0.5
11/25/2022 02:00	6.8	13.7	5.6	101.9	3,422,778.4	1,749.6	0.9	0.5
11/25/2022 03:00	6.8	13.7	5.6	102.1	3,430,212.4	1,753.4	0.9	0.5
11/25/2022 04:00	6.8	13.7	5.6	102.4	3,450,753.8	1,763.9	0.9	0.5
11/25/2022 05:00	6.9	13.7	5.7	102.5	3,445,471.7	1,761.2	0.9	0.5
11/25/2022 06:00	6.9	13.7	5.7	102.4	3,433,929.5	1,755.3	0.9	0.5
11/25/2022 07:00	7.1	13.7	5.8	103.4	3,435,103.3	1,755.9	0.9	0.5
11/25/2022 08:00	7.3	13.5	5.8	107.2	3,475,562.1	1,878.1	1.0	0.8
11/25/2022 09:00	7.6	13.4	6.0	108.6	3,427,117.9	1,927.0	1.0	0.8
11/25/2022 10:00	6.8	13.7	5.6	96.9	3,249,839.7	1,661.2	0.9	0.5
11/25/2022 11:00	6.9	13.7	5.7	90.7	3,010,386.1	1,538.8	0.9	0.5
11/25/2022 12:00	6.9	13.7	5.7	91.9	3,062,424.2	1,565.4	0.9	0.5
11/25/2022 13:00	6.9	13.7	5.7	90.4	3,001,582.6	1,534.3	0.9	0.5
11/25/2022 14:00	7.0	13.7	5.7	89.5	2,976,933.0	1,521.7	0.9	0.5
11/25/2022 15:00	7.8	13.6	6.3	98.0	3,144,468.4	1,630.3	1.0	0.7
11/25/2022 16:00	8.5	13.2	6.5	123.2	3,462,333.8	2,098.5	1.1	0.8
11/25/2022 17:00	8.0	13.2	6.1	121.8	3,448,178.0	2,115.1	1.1	0.8
11/25/2022 18:00	7.5	13.4	5.9	108.8	3,469,910.7	1,976.4	1.0	0.8
11/25/2022 19:00	7.4	13.4	5.8	106.9	3,496,656.2	1,966.1	1.0	0.8
11/25/2022 20:00	7.5	13.4	5.9	107.3	3,510,706.1	1,974.0	1.0	0.8
11/25/2022 21:00	7.1	13.4	5.6	105.9	3,516,397.3	1,977.2	1.0	0.8
11/25/2022 22:00	8.0	13.2	6.1	121.0	3,517,110.8	2,131.7	1.1	0.9
11/25/2022 23:00	7.9	13.2	6.1	118.9	3,492,199.2	2,091.1	1.1	0.8
Average/Sum#:	7.3	13.5	5.8	104.4	3,363,086.2	1,817.5	1.0	0.6
Minimum:	6.8	13.2	5.6	89.5	2,976,933.0	1,521.7	0.9	0.5
Maximum:	8.5	13.7	6.5	123.2	3,517,110.8	2,131.7	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/26/2022 00:00	7.5	13.3	5.8	111.9	3,524,621.0	2,033.3	1.0	0.8
11/26/2022 01:00	7.6	13.2	5.8	117.4	3,516,715.6	2,080.1	1.1	0.8
11/26/2022 02:00	10.1	14.1	8.8	114.8	3,080,813.6	1,574.8	1.2	0.8
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.4	13.5	6.8	114.7	3,374,050.1	1,896.1	1.1	0.8
Minimum:	7.5	13.2	5.8	111.9	3,080,813.6	1,574.8	1.0	0.8
Maximum:	10.1	14.1	8.8	117.4	3,524,621.0	2,080.1	1.2	0.8
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	33.3	17.5	57.8	0.0	1,413,074.8	330.2	0.0	0.0
11/27/2022 22:00	33.7	17.2	53.7	202.1	1,509,790.4	396.9	4.1	0.6
11/27/2022 23:00	33.8	15.3	35.6	217.8	2,286,431.5	901.6	2.9	1.0
Average/Sum#:	33.6	16.7	49.0	140.0	1,736,432.2	542.9	2.3	0.5
Minimum:	33.3	15.3	35.6	0.0	1,413,074.8	330.2	0.0	0.0
Maximum:	33.8	17.5	57.8	217.8	2,286,431.5	901.6	4.1	1.0
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/28/2022 00:00	6.9	13.7	5.7	96.1	3,081,009.2	1,574.9	1.0	0.6
11/28/2022 01:00	7.1	13.7	5.8	88.2	2,910,613.7	1,487.8	1.0	0.6
11/28/2022 02:00	7.1	13.7	5.8	98.0	3,366,662.3	1,745.5	0.9	0.5
11/28/2022 03:00	7.2	13.7	5.9	92.9	2,994,735.5	1,530.8	1.0	0.6
11/28/2022 04:00	7.0	13.7	5.7	100.0	3,346,286.3	1,710.5	0.9	0.5
11/28/2022 05:00	7.3	13.7	6.0	97.2	3,167,420.7	1,642.2	1.0	0.7
11/28/2022 06:00	8.2	13.1	6.2	127.8	3,460,503.6	2,173.2	1.2	1.1
11/28/2022 07:00	8.6	13.0	6.4	141.4	3,493,109.3	2,270.2	1.3	1.1
11/28/2022 08:00	7.3	13.4	5.7	109.7	3,462,361.3	1,972.1	1.0	0.8
11/28/2022 09:00	6.9	13.7	5.7	95.2	3,133,438.6	1,601.7	1.0	0.6
11/28/2022 10:00	7.0	13.7	5.7	100.2	3,323,788.6	1,699.0	1.0	0.7
11/28/2022 11:00	7.1	13.7	5.8	91.1	2,973,020.3	1,519.7	1.0	0.6
11/28/2022 12:00	7.1	13.7	5.8	93.9	3,064,380.5	1,566.4	1.0	0.6
11/28/2022 13:00	7.0	13.7	5.7	96.8	3,196,627.8	1,634.0	1.0	0.7
11/28/2022 14:00	7.1	13.7	5.8	96.0	3,163,174.7	1,616.9	1.0	0.6
11/28/2022 15:00	7.6	13.7	6.2	97.7	3,124,602.1	1,620.0	1.0	0.6
11/28/2022 16:00	8.2	13.3	6.4	115.0	3,450,780.4	2,041.1	1.1	0.8
11/28/2022 17:00	8.2	13.2	6.3	122.4	3,465,303.7	2,100.3	1.1	0.8
11/28/2022 18:00	7.6	13.3	5.9	110.3	3,491,154.3	1,988.5	1.0	0.8
11/28/2022 19:00	7.5	13.4	5.9	107.5	3,499,679.6	1,967.8	1.0	0.8
11/28/2022 20:00	8.0	13.2	6.1	119.7	3,497,042.3	2,094.0	1.1	0.8
11/28/2022 21:00	8.2	13.0	6.1	138.2	3,483,317.7	2,238.4	1.3	1.1
11/28/2022 22:00	7.7	13.2	5.9	119.3	3,499,380.3	2,095.4	1.1	0.8
11/28/2022 23:00	7.2	13.4	5.7	107.0	3,504,497.5	1,996.1	1.0	0.8
Average/Sum#:	7.5	13.5	5.9	106.7	3,298,037.1	1,828.6	1.0	0.7
Minimum:	6.9	13.0	5.7	88.2	2,910,613.7	1,487.8	0.9	0.5
Maximum:	8.6	13.7	6.4	141.4	3,504,497.5	2,270.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/29/2022 00:00	8.0	13.1	6.1	124.4	3,529,854.4	2,165.2	1.1	0.9
11/29/2022 01:00	8.1	13.1	6.1	132.0	3,523,560.8	2,212.8	1.2	1.1
11/29/2022 02:00	7.9	13.1	6.0	129.2	3,531,826.0	2,192.2	1.2	1.1
11/29/2022 03:00	7.7	13.2	5.9	117.5	3,530,071.7	2,088.0	1.1	0.8
11/29/2022 04:00	8.0	13.2	6.1	126.4	3,509,639.1	2,152.8	1.2	1.1
11/29/2022 05:00	8.0	13.1	6.1	131.4	3,553,414.6	2,205.6	1.2	1.1
11/29/2022 06:00	8.3	13.0	6.2	146.9	3,494,923.2	2,296.9	1.4	1.1
11/29/2022 07:00	8.7	13.0	6.5	154.5	3,506,030.7	2,304.2	1.4	1.2
11/29/2022 08:00	8.4	13.0	6.3	151.9	3,500,341.0	2,274.9	1.4	1.1
11/29/2022 09:00	8.1	13.1	6.1	132.7	3,503,309.8	2,174.5	1.2	1.1
11/29/2022 10:00	8.2	13.1	6.2	135.5	3,491,387.7	2,167.1	1.3	1.1
11/29/2022 11:00	8.2	13.1	6.2	134.3	3,476,565.7	2,157.9	1.3	1.1
11/29/2022 12:00	8.2	13.1	6.2	135.1	3,465,771.5	2,151.2	1.3	1.1
11/29/2022 13:00	8.2	13.1	6.2	135.1	3,466,093.7	2,151.4	1.3	1.1
11/29/2022 14:00	8.3	13.1	6.3	135.4	3,473,504.7	2,156.0	1.3	1.1
11/29/2022 15:00	8.3	13.1	6.3	138.1	3,456,363.5	2,170.6	1.3	1.1
11/29/2022 16:00	8.5	13.0	6.3	160.2	3,471,490.8	2,281.5	1.5	1.4
11/29/2022 17:00	8.3	13.0	6.2	157.5	3,483,815.6	2,289.6	1.5	1.4
11/29/2022 18:00	8.3	13.0	6.2	157.6	3,488,684.7	2,292.8	1.5	1.4
11/29/2022 19:00	8.3	13.0	6.2	154.3	3,485,185.1	2,290.5	1.4	1.1
11/29/2022 20:00	8.1	13.0	6.0	150.2	3,522,498.0	2,289.3	1.4	1.1
11/29/2022 21:00	8.1	13.0	6.0	150.7	3,487,771.7	2,292.2	1.4	1.1
11/29/2022 22:00	8.1	13.0	6.0	146.4	3,535,576.8	2,297.8	1.4	1.1
11/29/2022 23:00	8.1	13.0	6.0	150.5	3,533,884.3	2,296.7	1.4	1.1
Average/Sum#:	8.2	13.1	6.2	141.2	3,500,898.5	2,223.0	1.3	1.1
Minimum:	7.7	13.0	5.9	117.5	3,456,363.5	2,088.0	1.1	0.8
Maximum:	8.7	13.2	6.5	160.2	3,553,414.6	2,304.2	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/30/2022 00:00	7.6	13.2	5.8	121.6	3,581,457.2	2,170.7	1.1	0.9
11/30/2022 01:00	7.7	13.2	5.9	120.3	3,552,583.8	2,153.2	1.1	0.9
11/30/2022 02:00	7.8	13.2	6.0	120.4	3,553,573.8	2,153.8	1.1	0.9
11/30/2022 03:00	7.7	13.2	5.9	119.4	3,548,954.0	2,151.0	1.1	0.9
11/30/2022 04:00	7.7	13.2	5.9	121.3	3,579,642.3	2,169.6	1.1	0.9
11/30/2022 05:00	7.7	13.2	5.9	121.9	3,579,147.4	2,169.3	1.1	0.9
11/30/2022 06:00	7.9	13.1	6.0	142.7	3,529,380.1	2,268.0	1.3	1.1
11/30/2022 07:00	7.9	13.2	6.1	124.1	3,560,503.4	2,158.0	1.1	0.9
11/30/2022 08:00	7.0	13.4	5.5	105.9	3,575,459.0	1,984.3	0.9	0.6
11/30/2022 09:00	7.3	13.3	5.7	108.0	3,554,634.4	1,998.7	1.0	0.8
11/30/2022 10:00	7.0	13.4	5.5	105.5	3,521,910.5	1,980.3	1.0	0.8
11/30/2022 11:00	7.2	13.4	5.7	106.7	3,528,668.7	1,984.1	1.0	0.8
11/30/2022 12:00	7.7	13.3	6.0	108.9	3,528,135.2	1,983.8	1.0	0.8
11/30/2022 13:00	7.8	13.3	6.1	109.5	3,474,124.3	1,978.8	1.0	0.8
11/30/2022 14:00	8.2	13.1	6.2	127.0	3,476,544.6	2,132.5	1.2	1.1
11/30/2022 15:00	8.2	13.1	6.2	129.7	3,449,016.1	2,140.8	1.2	1.1
11/30/2022 16:00	8.4	13.0	6.3	148.9	3,426,299.8	2,251.8	1.4	1.1
11/30/2022 17:00	8.4	12.9	6.2	158.7	3,419,542.0	2,297.3	1.5	1.4
11/30/2022 18:00	8.3	12.9	6.1	156.8	3,445,231.0	2,289.4	1.5	1.4
11/30/2022 19:00	8.3	12.9	6.1	154.5	3,445,531.9	2,289.6	1.5	1.4
11/30/2022 20:00	8.2	12.9	6.0	150.2	3,444,478.5	2,288.9	1.4	1.1
11/30/2022 21:00	8.1	12.9	6.0	143.1	3,472,183.2	2,256.6	1.3	1.1
11/30/2022 22:00	7.7	13.1	5.8	121.8	3,476,193.1	2,106.9	1.1	0.8
11/30/2022 23:00	10.4	13.9	8.8	117.0	3,067,703.5	1,590.5	1.2	0.8
Average/Sum#:	7.9	13.2	6.1	126.8	3,491,287.4	2,122.8	1.2	1.0
Minimum:	7.0	12.9	5.5	105.5	3,067,703.5	1,590.5	0.9	0.6
Maximum:	10.4	13.9	8.8	158.7	3,581,457.2	2,297.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	30.2	17.5	52.4	206.6	1,378,097.4	301.9	4.3	0.5
12/01/2022 03:00	22.5	14.6	21.1	183.9	2,568,232.0	1,144.0	2.2	0.9
12/01/2022 04:00	7.1	13.6	5.7	101.8	3,285,847.0	1,703.6	1.0	0.7
12/01/2022 05:00	7.5	13.5	6.0	106.7	3,313,451.8	1,790.5	1.0	0.7
12/01/2022 06:00	8.9	12.9	6.6	162.2	3,410,164.4	2,291.0	1.6	1.4
12/01/2022 07:00	9.2	12.9	6.8	179.8	3,426,358.7	2,326.9	1.7	1.6
12/01/2022 08:00	8.6	13.0	6.4	135.0	3,429,163.2	2,203.6	1.3	1.1
12/01/2022 09:00	8.5	13.0	6.3	132.6	3,447,801.3	2,190.4	1.2	1.1
12/01/2022 10:00	8.5	13.0	6.3	133.8	3,455,514.2	2,195.3	1.3	1.1
12/01/2022 11:00	8.5	13.0	6.3	132.3	3,461,140.5	2,173.6	1.2	1.1
12/01/2022 12:00	8.6	13.0	6.4	135.0	3,426,394.3	2,176.8	1.3	1.1
12/01/2022 13:00	8.5	13.0	6.3	135.7	3,428,125.7	2,177.9	1.3	1.1
12/01/2022 14:00	8.6	13.0	6.4	140.5	3,411,578.5	2,192.3	1.3	1.1
12/01/2022 15:00	8.9	12.9	6.6	172.8	3,403,535.0	2,311.4	1.7	1.6
12/01/2022 16:00	9.0	12.9	6.6	176.2	3,443,587.0	2,338.6	1.7	1.6
12/01/2022 17:00	9.0	12.9	6.6	182.0	3,456,250.4	2,347.2	1.7	1.6
12/01/2022 18:00	8.9	12.9	6.6	171.5	3,439,169.5	2,335.6	1.6	1.4
12/01/2022 19:00	8.9	12.9	6.6	173.7	3,490,841.4	2,345.2	1.6	1.4
12/01/2022 20:00	8.9	12.9	6.6	171.9	3,496,646.5	2,349.1	1.6	1.4
12/01/2022 21:00	8.8	13.0	6.6	162.2	3,497,750.7	2,324.3	1.5	1.4
12/01/2022 22:00	8.4	13.1	6.4	132.0	3,519,742.9	2,184.7	1.2	1.1
12/01/2022 23:00	8.4	13.1	6.4	134.4	3,515,070.7	2,181.8	1.2	1.1
Average/Sum#:	10.2	13.3	9.2	152.8	3,304,748.3	2,072.1	1.6	1.2
Minimum:	7.1	12.9	5.7	101.8	1,378,097.4	301.9	1.0	0.5
Maximum:	30.2	17.5	52.4	206.6	3,519,742.9	2,349.1	4.3	1.6
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/02/2022 00:00	8.4	13.1	6.4	132.8	3,514,909.6	2,181.7	1.2	1.1
12/02/2022 01:00	8.4	13.1	6.4	133.7	3,520,226.2	2,185.0	1.2	1.1
12/02/2022 02:00	8.3	13.1	6.3	136.7	3,527,637.2	2,189.6	1.3	1.1
12/02/2022 03:00	8.3	13.1	6.3	128.6	3,534,419.1	2,168.0	1.2	1.1
12/02/2022 04:00	8.3	13.1	6.3	130.9	3,549,906.7	2,177.5	1.2	1.1
12/02/2022 05:00	8.2	13.1	6.2	130.2	3,544,526.8	2,174.2	1.2	1.1
12/02/2022 06:00	8.5	13.0	6.3	159.9	3,557,426.0	2,312.0	1.5	1.4
12/02/2022 07:00	8.9	13.0	6.6	159.8	3,535,397.3	2,323.5	1.5	1.4
12/02/2022 08:00	8.6	13.0	6.4	151.0	3,571,735.8	2,321.3	1.4	1.2
12/02/2022 09:00	8.3	13.1	6.3	131.8	3,538,592.6	2,196.4	1.2	1.1
12/02/2022 10:00	8.4	13.1	6.4	134.0	3,538,753.7	2,196.5	1.2	1.1
12/02/2022 11:00	8.5	13.1	6.4	138.5	3,525,790.1	2,214.2	1.3	1.1
12/02/2022 12:00	8.5	13.1	6.4	138.1	3,531,044.9	2,217.5	1.3	1.1
12/02/2022 13:00	8.5	13.1	6.4	138.6	3,516,713.7	2,208.5	1.3	1.1
12/02/2022 14:00	8.4	13.1	6.4	135.7	3,480,885.7	2,186.0	1.3	1.1
12/02/2022 15:00	8.8	13.0	6.6	162.1	3,509,378.2	2,306.4	1.5	1.4
12/02/2022 16:00	8.8	12.9	6.5	167.6	3,479,528.7	2,337.6	1.6	1.4
12/02/2022 17:00	8.6	13.0	6.4	162.7	3,504,221.6	2,328.6	1.5	1.4
12/02/2022 18:00	8.6	13.0	6.4	158.4	3,528,245.8	2,318.8	1.5	1.4
12/02/2022 19:00	8.6	13.0	6.4	158.8	3,536,462.4	2,324.2	1.5	1.4
12/02/2022 20:00	8.6	13.0	6.4	158.4	3,532,658.4	2,321.7	1.5	1.4
12/02/2022 21:00	8.6	13.0	6.4	158.5	3,523,833.3	2,315.9	1.5	1.4
12/02/2022 22:00	8.6	13.0	6.4	154.6	3,519,877.1	2,313.3	1.4	1.2
12/02/2022 23:00	8.6	13.0	6.4	157.3	3,526,572.1	2,317.7	1.5	1.4
Average/Sum#:	8.5	13.0	6.4	146.6	3,527,031.0	2,255.7	1.4	1.2
Minimum:	8.2	12.9	6.2	128.6	3,479,528.7	2,168.0	1.2	1.1
Maximum:	8.9	13.1	6.6	167.6	3,571,735.8	2,337.6	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/03/2022 00:00	8.5	13.0	6.3	152.6	3,554,810.3	2,310.3	1.4	1.2
12/03/2022 01:00	8.5	13.0	6.3	153.5	3,567,581.3	2,318.6	1.4	1.2
12/03/2022 02:00	8.4	13.0	6.3	150.5	3,533,875.7	2,322.5	1.4	1.2
12/03/2022 03:00	8.4	13.0	6.3	153.3	3,533,571.4	2,322.3	1.4	1.2
12/03/2022 04:00	8.5	13.0	6.3	154.7	3,526,876.4	2,317.9	1.4	1.2
12/03/2022 05:00	8.5	13.0	6.3	154.1	3,532,506.3	2,321.6	1.4	1.2
12/03/2022 06:00	8.5	13.0	6.3	157.5	3,538,440.4	2,325.5	1.5	1.4
12/03/2022 07:00	8.8	13.0	6.6	158.2	3,512,949.8	2,334.4	1.5	1.4
12/03/2022 08:00	8.6	13.0	6.4	158.9	3,543,157.4	2,328.6	1.5	1.4
12/03/2022 09:00	8.6	13.0	6.4	153.6	3,507,381.8	2,330.7	1.4	1.2
12/03/2022 10:00	8.4	13.0	6.3	149.8	3,516,681.8	2,311.2	1.4	1.2
12/03/2022 11:00	8.4	13.0	6.3	143.3	3,507,726.7	2,279.7	1.3	1.1
12/03/2022 12:00	8.4	12.9	6.2	150.2	3,512,725.7	2,308.6	1.4	1.2
12/03/2022 13:00	8.1	13.1	6.1	128.0	3,498,720.1	2,197.2	1.2	1.1
12/03/2022 14:00	8.1	13.1	6.1	127.0	3,520,870.6	2,185.4	1.2	1.1
12/03/2022 15:00	8.5	12.9	6.3	152.9	3,519,420.7	2,313.0	1.4	1.2
12/03/2022 16:00	8.5	12.9	6.3	158.2	3,475,509.8	2,334.9	1.5	1.4
12/03/2022 17:00	8.5	12.9	6.3	156.3	3,498,954.5	2,325.1	1.5	1.4
12/03/2022 18:00	8.5	12.9	6.3	153.9	3,480,444.7	2,312.8	1.4	1.2
12/03/2022 19:00	8.5	12.9	6.3	153.0	3,485,410.8	2,316.1	1.4	1.2
12/03/2022 20:00	8.6	12.9	6.3	158.2	3,466,876.4	2,329.1	1.5	1.4
12/03/2022 21:00	8.6	12.9	6.3	161.5	3,489,055.2	2,344.0	1.5	1.4
12/03/2022 22:00	8.6	12.9	6.3	162.2	3,499,325.9	2,350.9	1.5	1.4
12/03/2022 23:00	8.5	12.9	6.3	158.4	3,486,227.0	2,342.1	1.5	1.4
Average/Sum#:	8.5	13.0	6.3	152.5	3,512,879.2	2,311.8	1.4	1.3
Minimum:	8.1	12.9	6.1	127.0	3,466,876.4	2,185.4	1.2	1.1
Maximum:	8.8	13.1	6.6	162.2	3,567,581.3	2,350.9	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/04/2022 00:00	8.2	13.1	6.2	129.5	3,503,656.4	2,200.3	1.2	1.1
12/04/2022 01:00	8.2	13.1	6.2	129.9	3,509,388.8	2,203.9	1.2	1.1
12/04/2022 02:00	8.2	13.0	6.1	130.4	3,517,032.1	2,208.7	1.2	1.1
12/04/2022 03:00	8.2	13.1	6.2	129.4	3,503,815.6	2,200.4	1.2	1.1
12/04/2022 04:00	8.2	13.0	6.1	131.1	3,521,490.7	2,211.5	1.2	1.1
12/04/2022 05:00	8.2	13.0	6.1	128.4	3,506,681.8	2,202.2	1.2	1.1
12/04/2022 06:00	8.5	12.9	6.3	164.1	3,501,512.8	2,326.8	1.5	1.4
12/04/2022 07:00	8.8	12.9	6.5	155.8	3,481,761.5	2,339.1	1.5	1.4
12/04/2022 08:00	8.3	13.0	6.2	130.3	3,526,745.5	2,214.8	1.2	1.1
12/04/2022 09:00	8.3	13.0	6.2	128.1	3,489,325.2	2,191.3	1.2	1.1
12/04/2022 10:00	8.3	13.0	6.2	130.6	3,472,513.9	2,206.1	1.2	1.1
12/04/2022 11:00	8.4	13.0	6.3	133.5	3,472,986.2	2,206.4	1.2	1.1
12/04/2022 12:00	8.6	13.0	6.4	138.4	3,419,981.8	2,197.7	1.3	1.1
12/04/2022 13:00	8.7	13.0	6.5	143.4	3,412,979.0	2,193.2	1.4	1.1
12/04/2022 14:00	8.6	13.0	6.4	138.3	3,435,076.6	2,207.4	1.3	1.1
12/04/2022 15:00	8.5	13.0	6.3	136.0	3,415,468.9	2,194.8	1.3	1.1
12/04/2022 16:00	8.8	12.9	6.5	165.3	3,420,174.2	2,322.7	1.6	1.4
12/04/2022 17:00	8.8	12.9	6.5	166.6	3,443,734.2	2,338.7	1.6	1.4
12/04/2022 18:00	8.8	12.9	6.5	162.6	3,421,205.0	2,323.4	1.6	1.4
12/04/2022 19:00	8.7	12.9	6.4	161.7	3,454,670.7	2,320.9	1.5	1.4
12/04/2022 20:00	8.7	12.9	6.4	156.0	3,456,159.2	2,321.9	1.5	1.4
12/04/2022 21:00	8.6	12.9	6.3	157.2	3,457,647.7	2,322.9	1.5	1.4
12/04/2022 22:00	8.6	12.9	6.3	155.5	3,478,789.4	2,311.7	1.5	1.4
12/04/2022 23:00	8.3	13.0	6.2	129.9	3,491,554.5	2,192.7	1.2	1.1
Average/Sum#:	8.5	13.0	6.3	143.0	3,471,431.3	2,248.3	1.3	1.2
Minimum:	8.2	12.9	6.1	128.1	3,412,979.0	2,191.3	1.2	1.1
Maximum:	8.8	13.1	6.5	166.6	3,526,745.5	2,339.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/05/2022 00:00	8.3	13.0	6.2	130.7	3,494,102.2	2,194.3	1.2	1.1
12/05/2022 01:00	8.3	13.0	6.2	129.3	3,489,484.4	2,191.4	1.2	1.1
12/05/2022 02:00	8.3	13.0	6.2	131.5	3,497,446.2	2,196.4	1.2	1.1
12/05/2022 03:00	8.4	13.0	6.3	131.0	3,487,255.1	2,190.0	1.2	1.1
12/05/2022 04:00	8.4	13.0	6.3	135.5	3,487,939.6	2,215.9	1.3	1.1
12/05/2022 05:00	8.7	12.9	6.4	160.6	3,492,483.6	2,320.8	1.5	1.4
12/05/2022 06:00	8.7	12.9	6.4	175.6	3,451,685.7	2,344.1	1.7	1.6
12/05/2022 07:00	9.0	12.9	6.6	161.7	3,483,994.3	2,340.6	1.5	1.4
12/05/2022 08:00	8.8	12.9	6.5	161.8	3,462,876.7	2,351.7	1.5	1.4
12/05/2022 09:00	8.8	12.8	6.4	170.4	3,446,870.3	2,366.0	1.6	1.4
12/05/2022 10:00	8.6	13.0	6.4	154.7	3,258,925.7	2,141.8	1.6	1.3
12/05/2022 11:00	7.6	13.5	6.1	106.0	3,248,914.9	1,826.8	1.0	0.7
12/05/2022 12:00	8.3	13.0	6.2	127.3	3,402,783.5	2,161.8	1.2	1.1
12/05/2022 13:00	8.1	13.2	6.2	117.3	3,426,942.3	2,027.0	1.1	0.8
12/05/2022 14:00	8.2	13.2	6.3	120.5	3,434,416.2	2,056.5	1.1	0.8
12/05/2022 15:00	8.2	13.2	6.3	121.8	3,422,571.0	2,074.4	1.1	0.8
12/05/2022 16:00	8.4	13.0	6.3	144.4	3,420,022.0	2,222.7	1.4	1.1
12/05/2022 17:00	8.4	12.9	6.2	154.3	3,420,584.0	2,298.0	1.5	1.4
12/05/2022 18:00	8.3	12.9	6.1	151.3	3,421,625.9	2,298.7	1.5	1.4
12/05/2022 19:00	8.3	12.9	6.1	151.2	3,464,643.7	2,302.3	1.4	1.2
12/05/2022 20:00	8.2	12.9	6.0	146.4	3,460,129.1	2,299.3	1.4	1.1
12/05/2022 21:00	8.0	13.0	6.0	133.7	3,456,396.0	2,221.1	1.3	1.1
12/05/2022 22:00	7.6	13.2	5.8	116.1	3,464,142.7	2,074.3	1.1	0.8
12/05/2022 23:00	7.6	13.2	5.8	113.6	3,465,658.1	2,049.9	1.1	0.8
Average/Sum#:	8.3	13.0	6.2	139.4	3,440,078.9	2,198.6	1.3	1.1
Minimum:	7.6	12.8	5.8	106.0	3,248,914.9	1,826.8	1.0	0.7
Maximum:	9.0	13.5	6.6	175.6	3,497,446.2	2,366.0	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/06/2022 00:00	7.1	13.4	5.6	106.0	3,500,746.7	1,968.4	1.0	0.8
12/06/2022 01:00	7.1	13.4	5.6	106.0	3,500,035.3	1,968.0	1.0	0.8
12/06/2022 02:00	7.1	13.4	5.6	106.1	3,500,035.3	1,968.0	1.0	0.8
12/06/2022 03:00	7.1	13.4	5.6	106.2	3,502,525.2	1,969.4	1.0	0.8
12/06/2022 04:00	7.4	13.4	5.8	108.0	3,483,429.4	1,984.1	1.0	0.8
12/06/2022 05:00	7.5	13.3	5.8	110.3	3,488,565.3	2,012.5	1.0	0.8
12/06/2022 06:00	7.2	13.4	5.7	106.5	3,485,887.3	1,985.5	1.0	0.8
12/06/2022 07:00	8.1	13.2	6.2	120.6	3,491,197.2	2,090.5	1.1	0.8
12/06/2022 08:00	8.4	13.0	6.3	142.7	3,474,077.5	2,283.2	1.3	1.1
12/06/2022 09:00	8.1	13.0	6.0	140.8	3,493,878.6	2,270.7	1.3	1.1
12/06/2022 10:00	8.1	13.0	6.0	139.9	3,484,031.0	2,264.3	1.3	1.1
12/06/2022 11:00	8.1	13.0	6.0	141.6	3,478,030.2	2,260.4	1.3	1.1
12/06/2022 12:00	8.2	13.0	6.1	147.0	3,448,179.8	2,241.0	1.4	1.1
12/06/2022 13:00	6.8	13.6	5.5	104.5	3,385,141.0	1,779.8	1.0	0.7
12/06/2022 14:00	7.1	13.8	5.9	82.6	2,608,852.7	1,314.5	1.0	0.5
12/06/2022 15:00	7.2	13.8	6.0	81.7	2,608,058.8	1,314.1	1.0	0.5
12/06/2022 16:00	7.3	13.7	6.0	91.2	2,958,739.2	1,512.4	1.0	0.6
12/06/2022 17:00	7.1	13.6	5.7	105.9	3,487,210.3	1,808.0	1.0	0.7
12/06/2022 18:00	7.0	13.6	5.7	105.4	3,486,824.5	1,807.8	1.0	0.7
12/06/2022 19:00	7.2	13.6	5.8	106.6	3,505,726.4	1,817.6	1.0	0.7
12/06/2022 20:00	8.2	13.1	6.2	122.8	3,484,369.9	2,137.3	1.1	0.9
12/06/2022 21:00	8.3	13.0	6.2	139.1	3,479,427.3	2,235.9	1.3	1.1
12/06/2022 22:00	7.8	13.2	6.0	125.5	3,474,213.2	2,105.7	1.2	1.1
12/06/2022 23:00	7.2	13.4	5.7	106.3	3,509,283.4	1,973.2	1.0	0.8
Average/Sum#:	7.5	13.3	5.9	114.7	3,388,269.4	1,961.3	1.1	0.8
Minimum:	6.8	13.0	5.5	81.7	2,608,058.8	1,314.1	1.0	0.5
Maximum:	8.4	13.8	6.3	147.0	3,509,283.4	2,283.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/07/2022 00:00	7.9	13.2	6.1	117.4	3,480,509.0	2,084.1	1.1	0.8
12/07/2022 01:00	7.3	13.4	5.7	108.0	3,495,368.0	1,990.9	1.0	0.8
12/07/2022 02:00	7.9	13.1	6.0	119.7	3,529,155.1	2,139.0	1.1	0.9
12/07/2022 03:00	7.8	13.1	5.9	120.5	3,500,509.6	2,147.2	1.1	0.9
12/07/2022 04:00	7.9	13.1	6.0	123.4	3,528,876.2	2,164.6	1.1	0.9
12/07/2022 05:00	7.9	13.1	6.0	123.8	3,501,054.3	2,173.1	1.1	0.9
12/07/2022 06:00	8.0	13.0	6.0	141.7	3,506,971.4	2,253.6	1.3	1.1
12/07/2022 07:00	8.5	13.0	6.3	139.3	3,525,334.1	2,265.4	1.3	1.1
12/07/2022 08:00	7.9	13.1	6.0	120.8	3,527,175.2	2,137.8	1.1	0.9
12/07/2022 09:00	7.8	13.1	5.9	121.0	3,541,266.2	2,172.2	1.1	0.9
12/07/2022 10:00	7.9	13.1	6.0	123.0	3,540,125.1	2,171.5	1.1	0.9
12/07/2022 11:00	7.9	13.1	6.0	125.2	3,536,049.4	2,169.0	1.1	0.9
12/07/2022 12:00	7.9	13.1	6.0	122.2	3,496,596.9	2,144.8	1.1	0.9
12/07/2022 13:00	7.9	13.1	6.0	121.9	3,457,144.5	2,120.6	1.1	0.8
12/07/2022 14:00	7.7	13.2	5.9	116.9	3,491,863.1	2,065.4	1.1	0.8
12/07/2022 15:00	7.8	13.2	6.0	119.0	3,488,525.1	2,088.9	1.1	0.8
12/07/2022 16:00	8.2	13.0	6.1	146.1	3,480,646.0	2,262.1	1.4	1.1
12/07/2022 17:00	8.2	13.0	6.1	145.9	3,463,122.1	2,276.0	1.4	1.1
12/07/2022 18:00	8.1	13.0	6.0	146.5	3,467,991.2	2,279.2	1.4	1.1
12/07/2022 19:00	8.1	13.0	6.0	145.9	3,465,861.0	2,277.8	1.4	1.1
12/07/2022 20:00	8.1	13.0	6.0	144.1	3,466,317.4	2,278.1	1.4	1.1
12/07/2022 21:00	8.0	13.0	6.0	139.3	3,497,109.8	2,272.8	1.3	1.1
12/07/2022 22:00	7.7	13.1	5.8	123.7	3,520,870.6	2,185.4	1.1	0.9
12/07/2022 23:00	7.8	13.1	5.9	123.2	3,515,070.7	2,181.8	1.1	0.9
Average/Sum#:	7.9	13.1	6.0	128.3	3,500,979.7	2,179.2	1.2	0.9
Minimum:	7.3	13.0	5.7	108.0	3,457,144.5	1,990.9	1.0	0.8
Maximum:	8.5	13.4	6.3	146.5	3,541,266.2	2,279.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/08/2022 00:00	7.7	13.2	5.9	119.2	3,531,300.0	2,140.3	1.1	0.9
12/08/2022 01:00	7.7	13.2	5.9	118.7	3,521,730.5	2,134.5	1.1	0.9
12/08/2022 02:00	7.8	13.2	6.0	118.7	3,516,285.8	2,131.2	1.1	0.9
12/08/2022 03:00	7.8	13.2	6.0	118.2	3,554,992.3	2,128.7	1.1	0.9
12/08/2022 04:00	7.8	13.1	5.9	120.9	3,553,243.8	2,153.6	1.1	0.9
12/08/2022 05:00	7.9	13.1	6.0	128.8	3,562,758.9	2,211.4	1.2	1.1
12/08/2022 06:00	8.0	13.0	6.0	140.2	3,517,882.0	2,286.3	1.3	1.1
12/08/2022 07:00	8.3	13.0	6.2	134.7	3,527,605.7	2,241.1	1.2	1.1
12/08/2022 08:00	7.3	13.3	5.7	110.6	3,525,314.4	2,033.7	1.0	0.8
12/08/2022 09:00	7.7	13.2	5.9	115.7	3,569,294.8	2,111.2	1.0	0.8
12/08/2022 10:00	7.7	13.2	5.9	116.8	3,538,793.0	2,119.0	1.1	0.8
12/08/2022 11:00	7.8	13.1	5.9	120.1	3,505,889.4	2,150.5	1.1	0.9
12/08/2022 12:00	7.8	13.1	5.9	121.1	3,509,639.1	2,152.8	1.1	0.9
12/08/2022 13:00	7.9	13.1	6.0	123.3	3,491,065.5	2,166.9	1.1	0.9
12/08/2022 14:00	7.9	13.1	6.0	124.5	3,467,191.5	2,177.4	1.2	1.1
12/08/2022 15:00	7.9	13.1	6.0	126.1	3,477,541.8	2,183.9	1.2	1.1
12/08/2022 16:00	8.2	12.9	6.0	144.4	3,474,838.3	2,283.7	1.4	1.1
12/08/2022 17:00	8.1	12.9	6.0	142.8	3,476,359.9	2,284.7	1.3	1.1
12/08/2022 18:00	8.2	12.9	6.0	144.4	3,480,620.3	2,287.5	1.4	1.1
12/08/2022 19:00	8.1	12.9	6.0	145.1	3,478,033.6	2,285.8	1.4	1.1
12/08/2022 20:00	8.1	12.9	6.0	141.5	3,480,468.2	2,287.4	1.3	1.1
12/08/2022 21:00	8.1	12.9	6.0	142.3	3,476,816.4	2,285.0	1.3	1.1
12/08/2022 22:00	7.9	13.0	5.9	126.2	3,494,102.2	2,194.3	1.2	1.1
12/08/2022 23:00	7.9	13.1	6.0	126.0	3,496,331.5	2,195.7	1.2	1.1
Average/Sum#:	7.9	13.1	6.0	127.9	3,509,504.1	2,192.8	1.2	1.0
Minimum:	7.3	12.9	5.7	110.6	3,467,191.5	2,033.7	1.0	0.8
Maximum:	8.3	13.3	6.2	145.1	3,569,294.8	2,287.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/09/2022 00:00	7.7	13.1	5.8	120.7	3,495,781.8	2,144.3	1.1	0.9
12/09/2022 01:00	7.4	13.2	5.7	112.0	3,502,645.2	2,046.2	1.0	0.8
12/09/2022 02:00	7.8	13.1	5.9	120.1	3,534,599.8	2,142.3	1.1	0.9
12/09/2022 03:00	7.8	13.1	5.9	120.2	3,537,734.7	2,144.2	1.1	0.9
12/09/2022 04:00	7.8	13.1	5.9	123.7	3,536,176.0	2,194.9	1.1	0.9
12/09/2022 05:00	8.0	13.0	6.0	140.1	3,533,114.9	2,296.2	1.3	1.1
12/09/2022 06:00	7.9	13.0	5.9	138.3	3,536,807.7	2,298.6	1.3	1.1
12/09/2022 07:00	8.3	13.0	6.2	138.5	3,518,651.3	2,286.8	1.3	1.1
12/09/2022 08:00	7.4	13.2	5.7	113.4	3,547,665.0	2,072.5	1.0	0.8
12/09/2022 09:00	7.3	13.3	5.7	110.2	3,523,927.6	2,032.9	1.0	0.8
12/09/2022 10:00	7.0	13.4	5.5	106.0	3,529,024.4	1,984.3	1.0	0.8
12/09/2022 11:00	7.7	13.2	5.9	115.2	3,506,740.8	2,074.2	1.1	0.8
12/09/2022 12:00	7.3	13.3	5.7	109.4	3,480,418.1	2,007.8	1.0	0.8
12/09/2022 13:00	7.9	13.1	6.0	122.8	3,480,271.2	2,160.2	1.1	0.9
12/09/2022 14:00	7.9	13.1	6.0	123.2	3,484,943.4	2,163.1	1.1	0.9
12/09/2022 15:00	7.5	13.2	5.7	112.9	3,518,736.0	2,055.6	1.0	0.8
12/09/2022 16:00	8.2	12.9	6.0	142.0	3,478,337.9	2,286.0	1.3	1.1
12/09/2022 17:00	8.1	13.0	6.0	140.9	3,477,577.1	2,285.5	1.3	1.1
12/09/2022 18:00	8.0	12.9	5.9	141.9	3,478,185.8	2,285.9	1.3	1.1
12/09/2022 19:00	8.0	12.9	5.9	141.2	3,480,163.8	2,287.2	1.3	1.1
12/09/2022 20:00	8.0	12.9	5.9	142.2	3,483,207.0	2,289.2	1.3	1.1
12/09/2022 21:00	8.0	13.0	6.0	143.6	3,481,228.9	2,287.9	1.3	1.1
12/09/2022 22:00	8.0	12.9	5.9	140.8	3,479,250.9	2,286.6	1.3	1.1
12/09/2022 23:00	8.0	13.0	6.0	141.0	3,469,817.1	2,280.4	1.3	1.1
Average/Sum#:	7.8	13.1	5.9	127.5	3,503,958.6	2,183.0	1.2	1.0
Minimum:	7.0	12.9	5.5	106.0	3,469,817.1	1,984.3	1.0	0.8
Maximum:	8.3	13.4	6.2	143.6	3,547,665.0	2,298.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/10/2022 00:00	7.3	13.3	5.7	110.5	3,502,259.5	2,020.4	1.0	0.8
12/10/2022 01:00	7.3	13.3	5.7	109.6	3,495,325.7	2,016.4	1.0	0.8
12/10/2022 02:00	7.2	13.3	5.6	106.4	3,477,109.0	1,980.5	1.0	0.8
12/10/2022 03:00	7.5	13.3	5.8	108.4	3,478,337.9	1,981.2	1.0	0.8
12/10/2022 04:00	7.3	13.3	5.7	107.2	3,469,735.1	1,976.3	1.0	0.8
12/10/2022 05:00	7.4	13.3	5.7	108.2	3,443,842.3	1,986.7	1.0	0.8
12/10/2022 06:00	7.4	13.3	5.7	107.2	3,464,994.8	1,973.6	1.0	0.8
12/10/2022 07:00	7.8	13.3	6.1	109.3	3,477,986.8	1,981.0	1.0	0.8
12/10/2022 08:00	7.8	13.2	6.0	112.6	3,459,850.7	2,021.2	1.0	0.8
12/10/2022 09:00	7.7	13.2	5.9	110.7	3,420,479.8	1,998.2	1.0	0.8
12/10/2022 10:00	7.7	13.2	5.9	108.9	3,422,694.2	1,974.5	1.0	0.8
12/10/2022 11:00	7.8	13.2	6.0	112.3	3,407,330.7	2,015.4	1.1	0.8
12/10/2022 12:00	8.0	13.0	6.0	121.1	3,417,277.7	2,121.1	1.1	0.8
12/10/2022 13:00	8.1	13.0	6.0	129.0	3,358,321.0	2,182.6	1.2	1.1
12/10/2022 14:00	7.8	13.1	5.9	114.5	3,370,120.0	2,018.0	1.1	0.8
12/10/2022 15:00	8.0	13.1	6.1	117.9	3,372,083.8	2,043.8	1.1	0.8
12/10/2022 16:00	8.1	13.1	6.1	125.5	3,403,583.5	2,112.6	1.2	1.1
12/10/2022 17:00	7.9	13.1	6.0	119.8	3,377,750.5	2,071.9	1.1	0.8
12/10/2022 18:00	8.0	13.1	6.1	118.1	3,419,931.2	2,072.8	1.1	0.8
12/10/2022 19:00	8.3	12.9	6.1	146.0	3,390,153.0	2,252.8	1.4	1.1
12/10/2022 20:00	8.1	13.0	6.0	130.3	3,423,718.4	2,175.1	1.2	1.1
12/10/2022 21:00	7.8	13.1	5.9	119.7	3,391,933.8	2,080.6	1.1	0.8
12/10/2022 22:00	7.8	13.2	6.0	112.5	3,450,949.4	2,016.0	1.0	0.8
12/10/2022 23:00	7.9	13.1	6.0	119.3	3,427,520.7	2,077.4	1.1	0.8
Average/Sum#:	7.8	13.2	5.9	116.0	3,430,137.1	2,047.9	1.1	0.9
Minimum:	7.2	12.9	5.6	106.4	3,358,321.0	1,973.6	1.0	0.8
Maximum:	8.3	13.3	6.1	146.0	3,502,259.5	2,252.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/11/2022 00:00	7.5	13.3	5.8	108.1	3,454,285.2	1,967.5	1.0	0.8
12/11/2022 01:00	7.4	13.3	5.7	107.6	3,449,896.0	1,965.0	1.0	0.8
12/11/2022 02:00	7.5	13.3	5.8	107.7	3,449,720.5	1,964.9	1.0	0.8
12/11/2022 03:00	7.4	13.3	5.7	107.3	3,450,598.3	1,965.4	1.0	0.8
12/11/2022 04:00	7.2	13.3	5.6	106.6	3,456,918.7	1,969.0	1.0	0.8
12/11/2022 05:00	7.1	13.3	5.5	106.1	3,454,811.9	1,967.8	1.0	0.8
12/11/2022 06:00	7.1	13.3	5.5	106.2	3,457,621.0	1,969.4	1.0	0.8
12/11/2022 07:00	7.4	13.4	5.8	107.3	3,507,149.2	1,972.0	1.0	0.8
12/11/2022 08:00	7.2	13.4	5.7	106.6	3,510,172.6	1,973.7	1.0	0.8
12/11/2022 09:00	7.2	13.3	5.6	107.0	3,460,430.1	1,971.0	1.0	0.8
12/11/2022 10:00	7.5	13.3	5.8	108.3	3,457,269.9	1,969.2	1.0	0.8
12/11/2022 11:00	7.6	13.3	5.9	108.6	3,453,231.8	1,966.9	1.0	0.8
12/11/2022 12:00	7.7	13.3	6.0	108.6	3,453,056.3	1,966.8	1.0	0.8
12/11/2022 13:00	7.8	13.3	6.1	109.3	3,455,689.8	1,968.3	1.0	0.8
12/11/2022 14:00	7.8	13.3	6.1	109.0	3,447,262.5	1,963.5	1.0	0.8
12/11/2022 15:00	8.0	13.2	6.1	117.7	3,441,430.3	2,060.7	1.1	0.8
12/11/2022 16:00	7.7	13.2	5.9	115.6	3,497,273.2	2,068.6	1.1	0.8
12/11/2022 17:00	7.8	13.1	5.9	121.3	3,491,054.0	2,141.4	1.1	0.9
12/11/2022 18:00	7.4	13.2	5.7	112.2	3,505,897.6	2,048.1	1.0	0.8
12/11/2022 19:00	7.6	13.2	5.8	113.9	3,494,061.0	2,066.7	1.0	0.8
12/11/2022 20:00	7.7	13.1	5.8	118.4	3,498,136.8	2,120.2	1.1	0.8
12/11/2022 21:00	7.1	13.3	5.5	108.2	3,516,611.6	2,003.0	1.0	0.8
12/11/2022 22:00	7.0	13.4	5.5	105.8	3,508,394.1	1,972.7	1.0	0.8
12/11/2022 23:00	7.1	13.4	5.6	106.1	3,511,239.7	1,974.3	1.0	0.8
Average/Sum#:	7.5	13.3	5.8	109.7	3,474,258.8	1,999.0	1.0	0.8
Minimum:	7.0	13.1	5.5	105.8	3,441,430.3	1,963.5	1.0	0.8
Maximum:	8.0	13.4	6.1	121.3	3,516,611.6	2,141.4	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/12/2022 00:00	7.0	13.4	5.5	106.2	3,524,222.5	1,981.6	1.0	0.8
12/12/2022 01:00	7.0	13.4	5.5	106.1	3,525,467.5	1,982.3	1.0	0.8
12/12/2022 02:00	7.0	13.4	5.5	106.1	3,523,866.8	1,981.4	1.0	0.8
12/12/2022 03:00	6.9	13.4	5.4	105.8	3,518,531.4	1,978.4	1.0	0.8
12/12/2022 04:00	6.9	13.4	5.4	105.7	3,517,642.2	1,977.9	1.0	0.8
12/12/2022 05:00	7.6	13.2	5.8	117.4	3,539,127.0	2,119.2	1.1	0.8
12/12/2022 06:00	7.8	13.1	5.9	129.3	3,491,402.6	2,218.1	1.2	1.1
12/12/2022 07:00	8.1	13.1	6.1	126.9	3,501,427.1	2,198.9	1.2	1.1
12/12/2022 08:00	7.4	13.2	5.7	114.6	3,510,967.4	2,076.7	1.0	0.8
12/12/2022 09:00	7.5	13.2	5.7	114.0	3,541,331.5	2,068.8	1.0	0.8
12/12/2022 10:00	6.9	13.4	5.4	105.1	3,555,097.8	1,973.0	0.9	0.6
12/12/2022 11:00	6.9	13.4	5.4	105.1	3,503,947.9	1,970.2	1.0	0.8
12/12/2022 12:00	7.1	13.4	5.6	105.7	3,504,659.3	1,970.6	1.0	0.8
12/12/2022 13:00	7.1	13.4	5.6	105.8	3,502,880.9	1,969.6	1.0	0.8
12/12/2022 14:00	7.2	13.4	5.7	106.3	3,500,035.3	1,968.0	1.0	0.8
12/12/2022 15:00	7.4	13.4	5.8	106.9	3,499,501.8	1,967.7	1.0	0.8
12/12/2022 16:00	8.1	13.1	6.1	130.7	3,511,432.4	2,153.9	1.2	1.1
12/12/2022 17:00	8.2	13.0	6.1	143.6	3,501,680.4	2,250.2	1.3	1.1
12/12/2022 18:00	8.2	13.0	6.1	152.5	3,483,003.0	2,314.5	1.4	1.2
12/12/2022 19:00	8.2	13.0	6.1	154.7	3,485,862.2	2,316.4	1.5	1.4
12/12/2022 20:00	8.2	13.0	6.1	156.3	3,491,731.2	2,320.3	1.5	1.4
12/12/2022 21:00	8.0	13.0	6.0	140.8	3,492,647.7	2,269.9	1.3	1.1
12/12/2022 22:00	7.9	13.1	6.0	131.1	3,506,204.1	2,201.9	1.2	1.1
12/12/2022 23:00	7.3	13.3	5.7	110.7	3,527,741.2	2,035.1	1.0	0.8
Average/Sum#:	7.5	13.2	5.8	120.3	3,510,850.5	2,094.4	1.1	0.9
Minimum:	6.9	13.0	5.4	105.1	3,483,003.0	1,967.7	0.9	0.6
Maximum:	8.2	13.4	6.1	156.3	3,555,097.8	2,320.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/13/2022 00:00	7.7	13.1	5.8	119.3	3,556,048.6	2,155.3	1.1	0.9
12/13/2022 01:00	7.8	13.1	5.9	122.0	3,525,289.6	2,162.4	1.1	0.9
12/13/2022 02:00	7.9	13.1	6.0	125.9	3,539,309.9	2,171.0	1.1	0.9
12/13/2022 03:00	7.8	13.1	5.9	125.0	3,523,659.4	2,161.4	1.1	0.9
12/13/2022 04:00	7.8	13.1	5.9	126.2	3,547,131.4	2,201.7	1.2	1.1
12/13/2022 05:00	7.8	13.0	5.8	138.3	3,558,324.8	2,286.6	1.3	1.1
12/13/2022 06:00	8.0	13.0	6.0	146.8	3,535,397.3	2,323.5	1.4	1.2
12/13/2022 07:00	8.5	13.0	6.3	148.9	3,521,703.0	2,314.5	1.4	1.2
12/13/2022 08:00	7.7	13.2	5.9	128.5	3,504,585.2	2,149.7	1.2	1.1
12/13/2022 09:00	7.3	13.3	5.7	108.9	3,534,870.6	2,013.4	1.0	0.8
12/13/2022 10:00	6.9	13.4	5.4	104.9	3,564,467.5	1,978.2	0.9	0.6
12/13/2022 11:00	7.3	13.4	5.7	106.7	3,508,572.0	1,972.8	1.0	0.8
12/13/2022 12:00	7.5	13.4	5.9	107.6	3,506,437.8	1,971.6	1.0	0.8
12/13/2022 13:00	7.5	13.4	5.9	107.7	3,503,414.4	1,969.9	1.0	0.8
12/13/2022 14:00	7.5	13.4	5.9	107.6	3,501,102.4	1,968.6	1.0	0.8
12/13/2022 15:00	7.9	13.2	6.1	121.1	3,510,122.1	2,076.2	1.1	0.8
12/13/2022 16:00	8.4	13.0	6.3	152.5	3,472,708.1	2,282.3	1.4	1.1
12/13/2022 17:00	8.2	13.0	6.1	154.0	3,459,978.6	2,299.2	1.5	1.4
12/13/2022 18:00	8.2	13.0	6.1	153.9	3,495,531.8	2,297.3	1.4	1.1
12/13/2022 19:00	8.1	13.0	6.0	152.2	3,494,618.9	2,296.7	1.4	1.1
12/13/2022 20:00	8.0	13.0	6.0	146.3	3,489,445.5	2,293.3	1.4	1.1
12/13/2022 21:00	8.0	13.0	6.0	143.5	3,528,652.7	2,293.3	1.3	1.1
12/13/2022 22:00	8.0	13.0	6.0	148.1	3,534,961.3	2,297.4	1.4	1.1
12/13/2022 23:00	8.0	13.0	6.0	147.0	3,489,749.8	2,293.5	1.4	1.1
Average/Sum#:	7.8	13.1	5.9	131.0	3,516,920.1	2,176.2	1.2	1.0
Minimum:	6.9	13.0	5.4	104.9	3,459,978.6	1,968.6	0.9	0.6
Maximum:	8.5	13.4	6.3	154.0	3,564,467.5	2,323.5	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/14/2022 00:00	7.8	13.1	5.9	127.7	3,546,003.6	2,201.0	1.2	1.1
12/14/2022 01:00	7.7	13.1	5.8	125.9	3,553,736.8	2,205.8	1.1	0.9
12/14/2022 02:00	7.8	13.1	5.9	127.9	3,556,475.7	2,207.5	1.2	1.1
12/14/2022 03:00	7.7	13.1	5.8	124.7	3,589,848.2	2,202.0	1.1	0.9
12/14/2022 04:00	7.7	13.1	5.8	123.7	3,579,740.6	2,195.8	1.1	0.9
12/14/2022 05:00	7.9	13.0	5.9	144.8	3,550,194.2	2,307.3	1.3	1.2
12/14/2022 06:00	7.9	13.0	5.9	143.9	3,556,041.2	2,311.1	1.3	1.2
12/14/2022 07:00	8.3	13.0	6.2	142.3	3,544,630.5	2,277.8	1.3	1.1
12/14/2022 08:00	7.5	13.3	5.8	113.4	3,562,215.2	2,081.0	1.0	0.8
12/14/2022 09:00	7.2	13.3	5.6	108.4	3,530,832.5	2,011.1	1.0	0.8
12/14/2022 10:00	7.4	13.3	5.7	110.2	3,516,127.1	2,028.4	1.0	0.8
12/14/2022 11:00	6.9	13.4	5.4	105.2	3,512,306.8	1,974.9	1.0	0.8
12/14/2022 12:00	6.9	13.4	5.4	105.3	3,515,152.3	1,976.5	1.0	0.8
12/14/2022 13:00	6.9	13.4	5.4	105.3	3,518,353.6	1,978.3	1.0	0.8
12/14/2022 14:00	6.9	13.4	5.4	105.1	3,512,840.3	1,975.2	1.0	0.8
12/14/2022 15:00	7.3	13.3	5.7	109.2	3,543,648.9	2,018.4	1.0	0.8
12/14/2022 16:00	8.2	13.1	6.2	135.8	3,493,448.8	2,219.4	1.3	1.1
12/14/2022 17:00	8.1	13.0	6.0	146.5	3,486,250.2	2,291.2	1.4	1.1
12/14/2022 18:00	8.1	13.0	6.0	148.1	3,481,533.3	2,288.1	1.4	1.1
12/14/2022 19:00	8.1	13.0	6.0	147.4	3,488,380.4	2,292.6	1.4	1.1
12/14/2022 20:00	8.1	13.0	6.0	146.0	3,528,037.3	2,292.9	1.4	1.1
12/14/2022 21:00	8.0	13.0	6.0	146.3	3,525,575.4	2,291.3	1.4	1.1
12/14/2022 22:00	7.9	13.0	5.9	140.1	3,525,022.9	2,265.2	1.3	1.1
12/14/2022 23:00	7.8	13.1	5.9	126.6	3,551,700.0	2,178.6	1.2	1.1
Average/Sum#:	7.7	13.1	5.8	127.5	3,532,004.0	2,169.6	1.2	1.0
Minimum:	6.9	13.0	5.4	105.1	3,481,533.3	1,974.9	1.0	0.8
Maximum:	8.3	13.4	6.2	148.1	3,589,848.2	2,311.1	1.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/15/2022 00:00	8.1	13.0	6.0	147.1	3,538,961.9	2,300.0	1.4	1.2
12/15/2022 01:00	8.1	13.0	6.0	148.2	3,515,921.0	2,310.7	1.4	1.2
12/15/2022 02:00	8.1	13.0	6.0	150.4	3,515,921.0	2,310.7	1.4	1.2
12/15/2022 03:00	8.1	13.0	6.0	151.6	3,518,659.9	2,312.5	1.4	1.2
12/15/2022 04:00	8.1	13.0	6.0	151.2	3,526,267.8	2,317.5	1.4	1.2
12/15/2022 05:00	8.1	13.0	6.0	154.3	3,530,376.1	2,320.2	1.4	1.2
12/15/2022 06:00	8.1	13.0	6.0	176.5	3,529,463.1	2,319.6	1.7	1.6
12/15/2022 07:00	8.7	13.0	6.5	154.4	3,522,159.5	2,314.8	1.4	1.2
12/15/2022 08:00	8.1	13.1	6.1	138.6	3,514,698.5	2,232.9	1.3	1.1
12/15/2022 09:00	8.2	13.1	6.2	143.1	3,472,113.3	2,231.2	1.3	1.1
12/15/2022 10:00	7.4	13.4	5.8	108.7	3,473,948.8	1,978.7	1.0	0.8
12/15/2022 11:00	7.7	13.3	6.0	110.8	3,494,314.6	1,990.3	1.0	0.8
12/15/2022 12:00	7.9	13.3	6.1	116.4	3,463,103.1	2,023.1	1.1	0.8
12/15/2022 13:00	8.2	13.2	6.3	125.2	3,457,543.0	2,045.1	1.2	1.0
12/15/2022 14:00	8.3	13.2	6.4	135.0	3,469,098.4	2,102.6	1.3	1.1
12/15/2022 15:00	8.6	13.0	6.4	160.1	3,435,733.6	2,258.0	1.5	1.4
12/15/2022 16:00	8.3	13.0	6.2	154.6	3,453,992.6	2,270.0	1.5	1.4
12/15/2022 17:00	8.3	13.0	6.2	156.1	3,451,101.6	2,268.1	1.5	1.4
12/15/2022 18:00	8.1	13.0	6.0	145.5	3,474,645.1	2,258.2	1.4	1.1
12/15/2022 19:00	8.1	13.0	6.0	141.7	3,464,028.2	2,251.3	1.3	1.1
12/15/2022 20:00	8.2	13.0	6.1	148.1	3,466,644.0	2,253.0	1.4	1.1
12/15/2022 21:00	8.1	13.0	6.0	144.7	3,508,527.5	2,254.6	1.3	1.1
12/15/2022 22:00	8.1	13.0	6.0	143.0	3,517,086.4	2,260.1	1.3	1.1
12/15/2022 23:00	7.9	13.1	6.0	135.0	3,529,809.4	2,242.5	1.2	1.1
Average/Sum#:	8.1	13.1	6.1	143.3	3,493,504.9	2,226.1	1.3	1.1
Minimum:	7.4	13.0	5.8	108.7	3,435,733.6	1,978.7	1.0	0.8
Maximum:	8.7	13.4	6.5	176.5	3,538,961.9	2,320.2	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/16/2022 00:00	6.9	13.4	5.4	107.0	3,507,306.5	1,997.7	1.0	0.8
12/16/2022 01:00	6.9	13.4	5.4	105.2	3,512,484.6	1,975.0	1.0	0.8
12/16/2022 02:00	6.9	13.4	5.4	105.5	3,512,662.5	1,975.1	1.0	0.8
12/16/2022 03:00	6.9	13.4	5.4	105.4	3,517,642.2	1,977.9	1.0	0.8
12/16/2022 04:00	6.8	13.4	5.3	105.1	3,514,263.1	1,976.0	1.0	0.8
12/16/2022 05:00	7.0	13.4	5.5	106.1	3,532,581.4	1,986.3	1.0	0.8
12/16/2022 06:00	7.7	13.3	6.0	125.9	3,531,611.9	2,114.7	1.1	0.8
12/16/2022 07:00	8.4	13.1	6.4	135.2	3,565,981.1	2,213.4	1.2	1.1
12/16/2022 08:00	7.9	13.2	6.1	122.3	3,545,159.2	2,148.7	1.1	0.9
12/16/2022 09:00	7.5	13.3	5.8	120.3	3,504,881.1	2,073.1	1.1	0.8
12/16/2022 10:00	6.7	13.7	5.5	90.9	3,000,800.1	1,533.9	1.0	0.6
12/16/2022 11:00	6.9	13.8	5.7	86.0	2,887,699.2	1,455.0	0.9	0.4
12/16/2022 12:00	7.3	13.8	6.1	82.3	2,619,569.9	1,319.9	1.0	0.5
12/16/2022 13:00	7.3	13.8	6.1	82.4	2,624,134.7	1,322.2	1.0	0.5
12/16/2022 14:00	7.1	13.7	5.8	93.7	3,085,508.8	1,577.2	1.0	0.6
12/16/2022 15:00	7.2	13.8	6.0	91.8	3,032,296.9	1,550.0	1.0	0.6
12/16/2022 16:00	8.4	13.1	6.4	129.7	3,490,904.4	2,166.8	1.2	1.1
12/16/2022 17:00	8.3	13.0	6.2	143.2	3,480,672.2	2,236.7	1.3	1.1
12/16/2022 18:00	8.0	13.1	6.1	129.3	3,483,815.6	2,162.4	1.2	1.1
12/16/2022 19:00	8.1	13.1	6.1	133.6	3,493,965.5	2,168.7	1.2	1.1
12/16/2022 20:00	8.3	13.0	6.2	151.6	3,471,875.5	2,256.4	1.4	1.1
12/16/2022 21:00	8.1	13.1	6.1	140.1	3,461,180.8	2,198.9	1.3	1.1
12/16/2022 22:00	7.4	13.3	5.7	124.4	3,489,527.1	2,089.5	1.2	1.0
12/16/2022 23:00	6.9	13.4	5.4	105.1	3,512,662.5	1,975.1	1.0	0.8
Average/Sum#:	7.5	13.4	5.8	113.4	3,349,132.8	1,935.4	1.1	0.8
Minimum:	6.7	13.0	5.3	82.3	2,619,569.9	1,319.9	0.9	0.4
Maximum:	8.4	13.8	6.4	151.6	3,565,981.1	2,256.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/17/2022 00:00	8.0	13.2	6.1	124.8	3,502,302.9	2,148.3	1.1	0.9
12/17/2022 01:00	7.9	13.2	6.1	125.0	3,507,030.6	2,151.2	1.1	0.9
12/17/2022 02:00	7.8	13.2	6.0	123.1	3,535,094.8	2,142.6	1.1	0.9
12/17/2022 03:00	7.8	13.2	6.0	125.4	3,552,913.8	2,153.4	1.1	0.9
12/17/2022 04:00	7.8	13.2	6.0	124.7	3,512,247.5	2,154.4	1.1	0.9
12/17/2022 05:00	7.8	13.2	6.0	124.1	3,549,449.0	2,151.3	1.1	0.9
12/17/2022 06:00	8.0	13.1	6.1	140.8	3,489,231.1	2,242.2	1.3	1.1
12/17/2022 07:00	8.0	13.3	6.2	121.6	3,505,893.4	2,099.3	1.1	0.8
12/17/2022 08:00	8.0	13.2	6.1	125.4	3,530,995.6	2,165.9	1.1	0.9
12/17/2022 09:00	7.7	13.2	5.9	119.0	3,548,479.2	2,124.8	1.1	0.8
12/17/2022 10:00	7.1	13.4	5.6	108.0	3,528,023.5	2,009.5	1.0	0.8
12/17/2022 11:00	6.9	13.4	5.4	105.1	3,516,575.1	1,977.3	1.0	0.8
12/17/2022 12:00	7.1	13.4	5.6	106.1	3,503,592.3	1,970.0	1.0	0.8
12/17/2022 13:00	7.4	13.4	5.8	107.2	3,503,947.9	1,970.2	1.0	0.8
12/17/2022 14:00	7.6	13.4	6.0	109.5	3,495,719.1	1,991.1	1.0	0.8
12/17/2022 15:00	8.0	13.2	6.1	126.2	3,505,066.5	2,124.4	1.2	1.1
12/17/2022 16:00	8.3	13.0	6.2	155.1	3,467,839.0	2,279.1	1.5	1.4
12/17/2022 17:00	8.1	13.0	6.0	144.2	3,458,027.4	2,247.4	1.4	1.1
12/17/2022 18:00	7.8	13.1	5.9	127.9	3,479,465.7	2,159.7	1.2	1.1
12/17/2022 19:00	8.1	13.0	6.0	154.2	3,481,381.1	2,288.0	1.5	1.4
12/17/2022 20:00	8.0	13.0	6.0	151.1	3,486,554.5	2,291.4	1.4	1.1
12/17/2022 21:00	8.0	13.0	6.0	153.5	3,487,923.9	2,292.3	1.4	1.1
12/17/2022 22:00	8.0	13.0	6.0	151.5	3,475,599.1	2,284.2	1.4	1.1
12/17/2022 23:00	7.7	13.1	5.8	133.2	3,491,236.0	2,192.5	1.2	1.1
Average/Sum#:	7.8	13.2	6.0	128.6	3,504,774.5	2,150.4	1.2	1.0
Minimum:	6.9	13.0	5.4	105.1	3,458,027.4	1,970.0	1.0	0.8
Maximum:	8.3	13.4	6.2	155.1	3,552,913.8	2,292.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/18/2022 00:00	7.7	13.2	5.9	122.0	3,491,054.0	2,141.4	1.1	0.9
12/18/2022 01:00	7.6	13.2	5.8	118.2	3,532,125.0	2,140.8	1.1	0.9
12/18/2022 02:00	7.2	13.3	5.6	108.9	3,552,954.0	2,023.7	1.0	0.8
12/18/2022 03:00	6.9	13.4	5.4	105.2	3,577,080.6	1,985.2	0.9	0.6
12/18/2022 04:00	7.7	13.2	5.9	117.8	3,574,364.6	2,140.3	1.1	0.9
12/18/2022 05:00	7.7	13.2	5.9	121.5	3,567,103.0	2,162.0	1.1	0.9
12/18/2022 06:00	7.7	13.2	5.9	126.6	3,515,554.1	2,182.1	1.2	1.1
12/18/2022 07:00	8.2	13.1	6.2	128.8	3,533,911.1	2,219.3	1.2	1.1
12/18/2022 08:00	7.5	13.2	5.7	121.7	3,493,201.2	2,091.7	1.1	0.8
12/18/2022 09:00	6.7	13.7	5.5	94.8	3,145,567.8	1,607.9	1.0	0.6
12/18/2022 10:00	6.9	13.7	5.7	92.3	3,036,600.8	1,552.2	1.0	0.6
12/18/2022 11:00	6.9	13.7	5.7	92.2	3,021,341.5	1,544.4	1.0	0.6
12/18/2022 12:00	6.9	13.7	5.7	83.4	2,787,076.3	1,404.3	0.9	0.4
12/18/2022 13:00	7.0	13.8	5.8	82.4	2,770,206.6	1,395.8	0.9	0.4
12/18/2022 14:00	7.0	13.7	5.7	96.8	3,198,192.8	1,634.8	1.0	0.7
12/18/2022 15:00	7.4	13.7	6.1	98.3	3,219,908.0	1,645.9	1.0	0.7
12/18/2022 16:00	8.2	13.2	6.3	127.3	3,494,151.5	2,143.3	1.2	1.1
12/18/2022 17:00	8.2	13.0	6.1	145.0	3,468,182.7	2,254.0	1.4	1.1
12/18/2022 18:00	8.1	13.0	6.0	147.6	3,475,142.6	2,283.9	1.4	1.1
12/18/2022 19:00	8.0	13.0	6.0	147.3	3,482,446.2	2,288.7	1.4	1.1
12/18/2022 20:00	7.8	13.0	5.8	133.4	3,533,744.5	2,245.0	1.2	1.1
12/18/2022 21:00	7.7	13.1	5.8	126.0	3,558,731.2	2,208.9	1.1	0.9
12/18/2022 22:00	7.6	13.1	5.7	126.0	3,553,575.7	2,205.7	1.2	1.1
12/18/2022 23:00	7.1	13.3	5.5	109.7	3,552,529.5	2,049.4	1.0	0.8
Average/Sum#:	7.5	13.3	5.8	115.6	3,380,614.4	1,981.3	1.1	0.8
Minimum:	6.7	13.0	5.4	82.4	2,770,206.6	1,395.8	0.9	0.4
Maximum:	8.2	13.8	6.3	147.6	3,577,080.6	2,288.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/19/2022 00:00	7.6	13.1	5.7	116.6	3,577,036.7	2,141.9	1.1	0.9
12/19/2022 01:00	7.6	13.1	5.7	117.9	3,553,078.8	2,153.5	1.1	0.9
12/19/2022 02:00	7.6	13.1	5.7	117.3	3,546,809.2	2,149.7	1.1	0.9
12/19/2022 03:00	7.5	13.1	5.7	117.4	3,550,768.9	2,152.1	1.1	0.9
12/19/2022 04:00	7.6	13.1	5.7	120.0	3,562,948.8	2,185.5	1.1	0.9
12/19/2022 05:00	7.8	13.0	5.8	139.8	3,553,733.2	2,309.6	1.3	1.2
12/19/2022 06:00	7.8	13.0	5.8	142.0	3,554,502.5	2,310.1	1.3	1.2
12/19/2022 07:00	8.2	13.0	6.1	138.6	3,554,502.5	2,310.1	1.3	1.2
12/19/2022 08:00	7.7	13.0	5.8	132.2	3,560,503.4	2,262.0	1.2	1.1
12/19/2022 09:00	7.8	13.0	5.8	133.8	3,539,184.0	2,274.3	1.2	1.1
12/19/2022 10:00	7.5	13.1	5.7	119.6	3,556,427.7	2,181.5	1.1	0.9
12/19/2022 11:00	7.5	13.1	5.7	119.5	3,556,916.8	2,181.8	1.1	0.9
12/19/2022 12:00	7.5	13.1	5.7	118.9	3,587,066.9	2,174.1	1.1	0.9
12/19/2022 13:00	7.6	13.1	5.7	118.3	3,571,557.8	2,164.7	1.1	0.9
12/19/2022 14:00	7.6	13.1	5.7	119.0	3,575,022.6	2,166.8	1.1	0.9
12/19/2022 15:00	7.8	13.1	5.9	129.5	3,552,541.6	2,231.0	1.2	1.1
12/19/2022 16:00	7.8	13.0	5.8	135.3	3,539,495.2	2,274.5	1.2	1.1
12/19/2022 17:00	7.8	13.0	5.8	134.6	3,540,273.3	2,275.0	1.2	1.1
12/19/2022 18:00	7.8	13.0	5.8	133.6	3,543,541.2	2,277.1	1.2	1.1
12/19/2022 19:00	7.8	13.0	5.8	135.5	3,548,520.9	2,280.3	1.2	1.1
12/19/2022 20:00	7.8	13.0	5.8	133.8	3,584,429.0	2,277.2	1.2	1.1
12/19/2022 21:00	7.8	13.0	5.8	134.0	3,584,743.8	2,277.4	1.2	1.1
12/19/2022 22:00	7.8	13.0	5.8	134.6	3,553,189.4	2,283.3	1.2	1.1
12/19/2022 23:00	7.8	13.0	5.8	134.0	3,546,186.7	2,278.8	1.2	1.1
Average/Sum#:	7.7	13.0	5.8	128.2	3,558,040.9	2,232.2	1.2	1.0
Minimum:	7.5	13.0	5.7	116.6	3,539,184.0	2,141.9	1.1	0.9
Maximum:	8.2	13.1	6.1	142.0	3,587,066.9	2,310.1	1.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/20/2022 00:00	7.6	13.1	5.7	119.5	3,597,791.3	2,180.6	1.1	0.9
12/20/2022 01:00	7.6	13.1	5.7	119.1	3,594,986.5	2,178.9	1.1	0.9
12/20/2022 02:00	7.6	13.1	5.7	119.8	3,560,829.5	2,184.2	1.1	0.9
12/20/2022 03:00	7.6	13.1	5.7	120.1	3,569,632.9	2,189.6	1.1	0.9
12/20/2022 04:00	7.6	13.1	5.7	120.3	3,571,426.2	2,190.7	1.1	0.9
12/20/2022 05:00	7.6	13.1	5.7	120.2	3,571,589.2	2,190.8	1.1	0.9
12/20/2022 06:00	7.8	13.0	5.8	139.0	3,566,105.6	2,291.6	1.3	1.1
12/20/2022 07:00	8.2	13.0	6.1	134.5	3,555,523.7	2,284.8	1.2	1.1
12/20/2022 08:00	7.7	13.1	5.8	119.9	3,580,962.3	2,170.4	1.1	0.9
12/20/2022 09:00	7.7	13.1	5.8	120.2	3,537,679.7	2,170.0	1.1	0.9
12/20/2022 10:00	7.7	13.1	5.8	118.1	3,554,157.3	2,128.2	1.1	0.9
12/20/2022 11:00	7.6	13.2	5.8	115.9	3,542,075.3	2,095.1	1.1	0.8
12/20/2022 12:00	6.8	13.4	5.3	104.3	3,534,196.0	1,961.4	0.9	0.6
12/20/2022 13:00	6.9	13.4	5.4	104.5	3,541,583.7	1,965.5	0.9	0.6
12/20/2022 14:00	6.9	13.4	5.4	104.7	3,538,880.9	1,964.0	0.9	0.6
12/20/2022 15:00	7.5	13.3	5.8	112.3	3,533,808.3	2,038.6	1.0	0.8
12/20/2022 16:00	8.1	13.1	6.1	133.3	3,502,860.2	2,199.8	1.2	1.1
12/20/2022 17:00	8.1	13.0	6.0	142.2	3,486,646.8	2,266.0	1.3	1.1
12/20/2022 18:00	8.1	13.0	6.0	143.9	3,486,492.9	2,265.9	1.3	1.1
12/20/2022 19:00	8.1	13.0	6.0	145.9	3,476,491.5	2,259.4	1.4	1.1
12/20/2022 20:00	8.1	13.0	6.0	142.3	3,477,260.9	2,259.9	1.3	1.1
12/20/2022 21:00	7.9	13.1	6.0	127.3	3,493,482.2	2,168.4	1.2	1.1
12/20/2022 22:00	7.9	13.1	6.0	126.2	3,492,676.6	2,167.9	1.2	1.1
12/20/2022 23:00	8.0	13.0	6.0	138.5	3,504,782.0	2,226.6	1.3	1.1
Average/Sum#:	7.7	13.1	5.8	124.7	3,536,330.1	2,166.6	1.1	0.9
Minimum:	6.8	13.0	5.3	104.3	3,476,491.5	1,961.4	0.9	0.6
Maximum:	8.2	13.4	6.1	145.9	3,597,791.3	2,291.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/21/2022 00:00	8.1	13.0	6.0	147.3	3,517,574.3	2,286.1	1.4	1.1
12/21/2022 01:00	8.0	13.0	6.0	145.5	3,515,727.8	2,284.9	1.4	1.1
12/21/2022 02:00	8.0	13.0	6.0	144.8	3,510,188.6	2,281.3	1.3	1.1
12/21/2022 03:00	8.0	13.0	6.0	144.1	3,522,036.4	2,289.0	1.3	1.1
12/21/2022 04:00	7.9	13.0	5.9	140.7	3,511,881.1	2,282.4	1.3	1.1
12/21/2022 05:00	7.9	13.0	5.9	141.0	3,515,420.1	2,284.7	1.3	1.1
12/21/2022 06:00	7.9	13.0	5.9	145.8	3,515,112.4	2,284.5	1.4	1.1
12/21/2022 07:00	8.4	13.0	6.3	139.5	3,513,266.0	2,283.3	1.3	1.1
12/21/2022 08:00	7.9	13.0	5.9	130.8	1,486,579.0	2,268.8	3.0	2.7
12/21/2022 09:00	7.9	13.0	5.9	132.0	3,557,197.9	2,259.9	1.2	1.1
12/21/2022 10:00	7.9	13.0	5.9	134.4	3,547,753.6	2,253.9	1.2	1.1
12/21/2022 11:00	7.8	13.0	5.8	130.5	3,533,433.4	2,219.0	1.2	1.1
12/21/2022 12:00	8.0	13.0	6.0	136.8	3,520,994.7	2,236.9	1.3	1.1
12/21/2022 13:00	8.0	13.0	6.0	136.8	3,469,934.6	2,229.8	1.3	1.1
12/21/2022 14:00	7.9	13.1	6.0	125.4	3,521,866.1	2,160.3	1.2	1.1
12/21/2022 15:00	8.1	13.0	6.0	140.3	3,476,937.4	2,234.3	1.3	1.1
12/21/2022 16:00	8.1	13.0	6.0	143.7	3,473,414.2	2,257.4	1.4	1.1
12/21/2022 17:00	8.1	13.0	6.0	144.5	3,470,029.1	2,255.2	1.4	1.1
12/21/2022 18:00	8.1	13.0	6.0	143.3	3,475,106.7	2,258.5	1.3	1.1
12/21/2022 19:00	8.1	13.0	6.0	141.6	3,471,875.5	2,256.4	1.3	1.1
12/21/2022 20:00	8.0	13.0	6.0	139.8	3,505,726.4	2,252.8	1.3	1.1
12/21/2022 21:00	8.0	13.0	6.0	137.9	3,507,127.0	2,253.7	1.3	1.1
12/21/2022 22:00	7.9	13.0	5.9	136.8	3,502,769.7	2,250.9	1.3	1.1
12/21/2022 23:00	7.8	13.0	5.8	132.6	3,499,657.4	2,248.9	1.2	1.1
Average/Sum#:	8.0	13.0	6.0	139.0	3,506,740.5	2,257.2	1.3	1.1
Minimum:	7.8	13.0	5.8	125.4	3,469,934.6	2,160.3	1.2	1.1
Maximum:	8.4	13.1	6.3	147.3	3,557,197.9	2,289.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/22/2022 00:00	7.7	13.1	5.8	122.7	3,520,709.5	2,185.3	1.1	0.9
12/22/2022 01:00	6.9	13.4	5.4	105.6	3,523,689.0	1,981.3	1.0	0.8
12/22/2022 02:00	6.9	13.4	5.4	104.9	3,501,458.1	1,968.8	1.0	0.8
12/22/2022 03:00	7.0	13.4	5.5	105.5	3,500,035.3	1,968.0	1.0	0.8
12/22/2022 04:00	7.6	13.2	5.8	114.2	3,536,496.2	2,091.8	1.0	0.8
12/22/2022 05:00	7.8	13.1	5.9	127.4	3,579,514.2	2,221.8	1.2	1.1
12/22/2022 06:00	7.9	13.0	5.9	134.9	3,530,158.2	2,268.5	1.2	1.1
12/22/2022 07:00	8.2	13.0	6.1	131.7	3,526,579.0	2,266.2	1.2	1.1
12/22/2022 08:00	7.9	13.0	5.9	130.3	3,539,883.3	2,248.9	1.2	1.1
12/22/2022 09:00	7.6	13.1	5.7	118.6	3,546,314.2	2,149.4	1.1	0.9
12/22/2022 10:00	7.6	13.1	5.7	117.8	3,541,034.5	2,146.2	1.1	0.9
12/22/2022 11:00	7.6	13.1	5.7	118.0	3,537,074.7	2,143.8	1.1	0.9
12/22/2022 12:00	7.6	13.1	5.7	118.2	3,533,279.9	2,141.5	1.1	0.9
12/22/2022 13:00	7.6	13.1	5.7	118.9	3,536,249.7	2,143.3	1.1	0.9
12/22/2022 14:00	7.6	13.1	5.7	119.4	3,546,644.2	2,149.6	1.1	0.9
12/22/2022 15:00	7.8	13.0	5.8	127.2	3,526,427.0	2,214.6	1.2	1.1
12/22/2022 16:00	7.7	13.0	5.8	127.6	3,518,624.5	2,209.7	1.2	1.1
12/22/2022 17:00	7.8	13.0	5.8	134.1	3,511,484.2	2,256.5	1.2	1.1
12/22/2022 18:00	7.9	13.0	5.9	134.1	3,518,642.6	2,261.1	1.2	1.1
12/22/2022 19:00	7.9	13.0	5.9	136.0	3,528,446.4	2,267.4	1.3	1.1
12/22/2022 20:00	7.9	13.0	5.9	134.5	3,521,132.4	2,262.7	1.2	1.1
12/22/2022 21:00	7.8	13.0	5.8	133.7	3,517,708.9	2,260.5	1.2	1.1
12/22/2022 22:00	7.7	13.0	5.8	126.7	3,527,541.7	2,215.3	1.2	1.1
12/22/2022 23:00	7.4	13.2	5.7	113.8	3,511,981.8	2,077.3	1.0	0.8
Average/Sum#:	7.6	13.1	5.8	123.2	3,528,379.6	2,170.8	1.1	1.0
Minimum:	6.9	13.0	5.4	104.9	3,500,035.3	1,968.0	1.0	0.8
Maximum:	8.2	13.4	6.1	136.0	3,579,514.2	2,268.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/23/2022 00:00	7.8	13.0	5.8	129.2	3,548,083.0	2,228.2	1.2	1.1
12/23/2022 01:00	7.8	13.0	5.8	134.9	3,525,178.5	2,265.3	1.2	1.1
12/23/2022 02:00	7.8	13.0	5.8	134.2	3,519,265.1	2,261.5	1.2	1.1
12/23/2022 03:00	7.8	13.0	5.8	134.3	3,519,420.7	2,261.6	1.2	1.1
12/23/2022 04:00	7.8	13.0	5.8	135.2	3,520,198.7	2,262.1	1.3	1.1
12/23/2022 05:00	7.8	13.0	5.8	134.0	3,516,775.2	2,259.9	1.2	1.1
12/23/2022 06:00	7.9	13.0	5.9	139.8	3,516,464.0	2,259.7	1.3	1.1
12/23/2022 07:00	8.3	13.0	6.2	132.7	3,526,031.7	2,240.1	1.2	1.1
12/23/2022 08:00	7.9	13.1	6.0	127.3	3,524,898.4	2,187.9	1.2	1.1
12/23/2022 09:00	7.9	13.1	6.0	128.2	3,516,037.4	2,182.4	1.2	1.1
12/23/2022 10:00	7.8	13.1	5.9	121.6	3,484,859.0	2,137.6	1.1	0.9
12/23/2022 11:00	7.9	13.1	6.0	122.9	3,491,543.1	2,141.7	1.1	0.9
12/23/2022 12:00	7.4	13.3	5.7	112.9	3,470,463.7	2,027.4	1.0	0.8
12/23/2022 13:00	7.1	13.4	5.6	105.8	3,485,807.5	1,960.0	1.0	0.8
12/23/2022 14:00	7.1	13.4	5.6	105.8	3,474,781.0	1,953.8	1.0	0.8
12/23/2022 15:00	7.8	13.2	6.0	117.4	3,490,679.7	2,064.7	1.1	0.8
12/23/2022 16:00	8.3	13.0	6.2	145.6	3,466,797.8	2,253.1	1.4	1.1
12/23/2022 17:00	8.2	13.0	6.1	143.2	3,468,490.4	2,254.2	1.3	1.1
12/23/2022 18:00	8.2	13.0	6.1	143.4	3,477,568.6	2,260.1	1.3	1.1
12/23/2022 19:00	8.1	13.0	6.0	141.6	3,465,720.8	2,252.4	1.3	1.1
12/23/2022 20:00	8.1	13.0	6.0	143.9	3,460,181.5	2,248.8	1.4	1.1
12/23/2022 21:00	8.1	13.0	6.0	143.9	3,466,951.7	2,253.2	1.4	1.1
12/23/2022 22:00	8.1	13.0	6.0	145.0	3,465,413.0	2,252.2	1.4	1.1
12/23/2022 23:00	8.1	13.0	6.0	142.7	3,451,103.3	2,242.9	1.4	1.1
Average/Sum#:	7.9	13.1	5.9	131.9	3,493,863.1	2,196.3	1.2	1.0
Minimum:	7.1	13.0	5.6	105.8	3,451,103.3	1,953.8	1.0	0.8
Maximum:	8.3	13.4	6.2	145.6	3,548,083.0	2,265.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/24/2022 00:00	7.8	13.1	5.9	123.3	3,473,936.2	2,130.9	1.1	0.9
12/24/2022 01:00	7.8	13.1	5.9	122.2	3,504,571.5	2,124.1	1.1	0.8
12/24/2022 02:00	6.9	13.4	5.4	105.9	3,491,498.6	1,963.2	1.0	0.8
12/24/2022 03:00	6.9	13.4	5.4	105.2	3,477,982.2	1,955.6	1.0	0.8
12/24/2022 04:00	7.0	13.4	5.5	105.6	3,476,915.2	1,955.0	1.0	0.8
12/24/2022 05:00	7.0	13.4	5.5	105.5	3,473,358.2	1,953.0	1.0	0.8
12/24/2022 06:00	7.1	13.4	5.6	107.7	3,476,055.6	1,979.9	1.0	0.8
12/24/2022 07:00	7.5	13.4	5.9	112.9	3,484,405.0	2,010.1	1.0	0.8
12/24/2022 08:00	7.0	13.5	5.6	103.7	3,354,724.6	1,837.3	1.0	0.7
12/24/2022 09:00	7.3	13.8	6.1	82.9	2,575,104.7	1,316.3	1.0	0.5
12/24/2022 10:00	7.3	13.7	6.0	93.4	3,028,971.1	1,548.3	1.0	0.6
12/24/2022 11:00	7.3	13.7	6.0	93.6	3,028,188.6	1,547.9	1.0	0.6
12/24/2022 12:00	7.2	13.7	5.9	93.8	3,036,209.5	1,552.0	1.0	0.6
12/24/2022 13:00	7.2	13.7	5.9	93.9	3,040,904.7	1,554.4	1.0	0.6
12/24/2022 14:00	7.2	13.7	5.9	102.1	3,385,021.4	1,730.3	1.0	0.7
12/24/2022 15:00	7.1	13.7	5.8	102.7	3,392,846.7	1,734.3	1.0	0.7
12/24/2022 16:00	7.3	13.7	6.0	95.3	3,110,940.9	1,590.2	1.0	0.6
12/24/2022 17:00	7.5	13.3	5.8	107.2	3,457,621.0	1,969.4	1.0	0.8
12/24/2022 18:00	7.2	13.4	5.7	105.8	3,451,300.6	1,965.8	1.0	0.8
12/24/2022 19:00	7.1	13.4	5.6	105.5	3,451,476.1	1,965.9	1.0	0.8
12/24/2022 20:00	7.1	13.4	5.6	105.5	3,453,934.1	1,967.3	1.0	0.8
12/24/2022 21:00	7.1	13.4	5.6	105.4	3,445,506.9	1,962.5	1.0	0.8
12/24/2022 22:00	7.0	13.4	5.5	105.1	3,495,233.4	1,965.3	1.0	0.8
12/24/2022 23:00	7.0	13.4	5.5	105.0	3,453,758.5	1,967.2	1.0	0.8
Average/Sum#:	7.2	13.5	5.7	103.7	3,334,186.1	1,843.6	1.0	0.7
Minimum:	6.9	13.1	5.4	82.9	2,575,104.7	1,316.3	1.0	0.5
Maximum:	7.8	13.8	6.1	123.3	3,504,571.5	2,130.9	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/25/2022 00:00	7.0	13.4	5.5	104.7	3,417,942.8	1,946.8	1.0	0.8
12/25/2022 01:00	22.0	15.9	26.0	160.3	1,530,138.0	592.2	3.3	0.8
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	32.1	17.4	54.1	19.4	1,477,694.5	345.3	0.4	0.1
12/25/2022 19:00	32.3	17.2	51.5	227.4	1,563,806.6	411.1	4.4	0.7
12/25/2022 20:00	30.3	15.7	34.4	221.5	2,137,397.6	780.4	3.2	0.9
12/25/2022 21:00	6.9	13.7	5.7	88.3	2,773,084.4	1,417.5	1.0	0.6
12/25/2022 22:00	7.1	13.7	5.8	86.8	2,847,815.8	1,455.7	1.0	0.6
12/25/2022 23:00	7.2	13.7	5.9	88.6	2,890,268.0	1,477.4	1.0	0.6
Average/Sum#:	18.1	15.1	23.6	124.6	2,329,768.5	1,053.3	1.9	0.6
Minimum:	6.9	13.4	5.5	19.4	1,477,694.5	345.3	0.4	0.1
Maximum:	32.3	17.4	54.1	227.4	3,417,942.8	1,946.8	4.4	0.9
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/26/2022 00:00	7.4	13.6	6.0	104.5	3,402,151.6	1,763.9	1.0	0.7
12/26/2022 01:00	7.2	13.7	5.9	94.7	2,976,087.1	1,543.0	1.0	0.6
12/26/2022 02:00	7.1	13.6	5.7	101.0	3,280,060.7	1,700.6	1.0	0.7
12/26/2022 03:00	7.1	13.6	5.7	102.3	3,321,143.4	1,721.9	1.0	0.7
12/26/2022 04:00	7.1	13.6	5.7	102.2	3,320,757.7	1,721.7	1.0	0.7
12/26/2022 05:00	7.0	13.6	5.7	103.0	3,351,232.2	1,737.5	1.0	0.7
12/26/2022 06:00	7.0	13.6	5.7	102.7	3,349,882.1	1,736.8	1.0	0.7
12/26/2022 07:00	7.2	13.6	5.8	103.2	3,332,908.9	1,728.0	1.0	0.7
12/26/2022 08:00	7.1	13.6	5.7	102.9	3,346,024.5	1,734.8	1.0	0.7
12/26/2022 09:00	7.1	13.7	5.8	93.9	3,029,949.3	1,548.8	1.0	0.6
12/26/2022 10:00	7.2	13.7	5.9	93.2	3,020,558.9	1,544.0	1.0	0.6
12/26/2022 11:00	7.1	13.6	5.7	92.6	3,004,125.8	1,535.6	1.0	0.6
12/26/2022 12:00	7.2	13.7	5.9	91.8	2,986,518.9	1,526.6	1.0	0.6
12/26/2022 13:00	7.2	13.6	5.8	93.4	3,026,623.5	1,547.1	1.0	0.6
12/26/2022 14:00	7.2	13.6	5.8	97.1	3,106,278.8	1,610.5	1.0	0.6
12/26/2022 15:00	7.0	13.6	5.7	102.4	3,356,054.1	1,740.0	1.0	0.7
12/26/2022 16:00	7.1	13.6	5.7	104.3	3,422,210.8	1,774.3	1.0	0.7
12/26/2022 17:00	8.0	13.1	6.1	119.0	3,502,096.6	2,122.6	1.1	0.8
12/26/2022 18:00	7.9	13.1	6.0	122.8	3,486,232.3	2,163.9	1.1	0.9
12/26/2022 19:00	7.4	13.3	5.7	110.6	3,494,285.7	2,015.8	1.0	0.8
12/26/2022 20:00	7.4	13.3	5.7	109.0	3,512,046.8	2,000.4	1.0	0.8
12/26/2022 21:00	7.2	13.4	5.7	106.6	3,503,236.6	1,969.8	1.0	0.8
12/26/2022 22:00	7.3	13.4	5.7	106.3	3,463,754.5	1,947.6	1.0	0.8
12/26/2022 23:00	19.9	15.9	23.5	147.5	1,574,062.9	609.2	2.9	0.7
Average/Sum#:	7.8	13.6	6.5	104.5	3,215,345.2	1,710.2	1.1	0.7
Minimum:	7.0	13.1	5.7	91.8	1,574,062.9	609.2	1.0	0.6
Maximum:	19.9	15.9	23.5	147.5	3,512,046.8	2,163.9	2.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	18.7	18.0	38.0	165.6	1,292,475.8	198.2	3.7	0.3
12/27/2022 02:00	30.5	15.8	35.3	212.8	2,115,062.0	756.8	3.0	0.9
12/27/2022 03:00	7.1	13.6	5.7	95.9	2,967,214.7	1,538.4	1.0	0.6
12/27/2022 04:00	7.2	13.6	5.8	93.4	3,011,364.2	1,539.3	1.0	0.6
12/27/2022 05:00	7.4	13.5	5.9	101.0	3,250,743.5	1,685.4	1.0	0.7
12/27/2022 06:00	7.3	13.7	6.0	88.3	2,733,566.7	1,397.3	1.0	0.6
12/27/2022 07:00	7.5	13.6	6.1	99.9	3,339,081.0	1,731.2	0.9	0.5
12/27/2022 08:00	7.5	13.6	6.1	103.1	3,281,989.5	1,701.6	1.0	0.7
12/27/2022 09:00	8.1	13.2	6.2	110.2	3,377,000.5	1,972.8	1.0	0.8
12/27/2022 10:00	8.0	13.2	6.1	110.0	3,368,612.8	1,967.9	1.0	0.8
12/27/2022 11:00	8.1	13.2	6.2	111.0	3,372,892.3	1,970.4	1.0	0.8
12/27/2022 12:00	8.1	13.2	6.2	111.3	3,371,522.8	1,969.6	1.1	0.8
12/27/2022 13:00	8.1	13.2	6.2	111.2	3,370,838.1	1,969.2	1.1	0.8
12/27/2022 14:00	8.1	13.3	6.3	111.1	3,373,234.6	1,970.6	1.1	0.8
12/27/2022 15:00	8.0	13.3	6.2	111.2	3,373,577.0	1,970.8	1.1	0.8
12/27/2022 16:00	8.0	13.3	6.2	110.8	3,415,760.4	1,970.5	1.0	0.8
12/27/2022 17:00	7.9	13.3	6.1	109.5	3,401,892.9	1,962.5	1.0	0.8
12/27/2022 18:00	7.9	13.3	6.1	109.0	3,441,293.2	1,960.1	1.0	0.8
12/27/2022 19:00	7.7	13.3	6.0	108.4	3,440,239.8	1,959.5	1.0	0.8
12/27/2022 20:00	7.8	13.3	6.1	108.8	3,461,483.5	1,971.6	1.0	0.8
12/27/2022 21:00	7.8	13.3	6.1	109.1	3,463,239.2	1,972.6	1.0	0.8
12/27/2022 22:00	7.2	13.4	5.7	106.1	3,460,553.2	1,945.8	1.0	0.8
12/27/2022 23:00	7.1	13.8	5.9	86.7	2,763,260.2	1,392.3	1.0	0.6
Average/Sum#:	9.2	13.7	8.7	112.4	3,149,865.1	1,716.3	1.2	0.7
Minimum:	7.1	13.2	5.7	86.7	1,292,475.8	198.2	0.9	0.3
Maximum:	30.5	18.0	38.0	212.8	3,463,239.2	1,972.8	3.7	0.9
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/28/2022 00:00	7.1	13.7	5.8	92.6	3,012,146.7	1,539.7	1.0	0.6
12/28/2022 01:00	7.1	13.7	5.8	88.1	2,866,400.9	1,465.2	1.0	0.6
12/28/2022 02:00	7.1	13.7	5.8	92.0	2,975,367.9	1,520.9	1.0	0.6
12/28/2022 03:00	7.1	13.7	5.8	91.9	2,969,890.2	1,518.1	1.0	0.6
12/28/2022 04:00	7.1	13.7	5.8	91.9	2,989,649.1	1,528.2	1.0	0.6
12/28/2022 05:00	7.1	13.6	5.7	102.0	3,315,357.1	1,718.9	1.0	0.7
12/28/2022 06:00	6.9	13.6	5.6	102.4	3,348,146.2	1,735.9	1.0	0.7
12/28/2022 07:00	7.2	13.6	5.8	103.5	3,352,968.1	1,738.4	1.0	0.7
12/28/2022 08:00	7.1	13.6	5.7	102.5	3,310,342.4	1,716.3	1.0	0.7
12/28/2022 09:00	7.1	13.6	5.7	101.9	3,293,947.8	1,707.8	1.0	0.7
12/28/2022 10:00	7.1	13.7	5.8	93.8	3,027,797.3	1,547.7	1.0	0.6
12/28/2022 11:00	7.2	13.7	5.9	94.5	3,057,729.0	1,563.0	1.0	0.6
12/28/2022 12:00	7.2	13.7	5.9	93.6	3,023,297.8	1,545.4	1.0	0.6
12/28/2022 13:00	7.1	13.7	5.8	92.1	2,983,975.7	1,525.3	1.0	0.6
12/28/2022 14:00	7.1	13.7	5.8	93.6	3,030,536.2	1,549.1	1.0	0.6
12/28/2022 15:00	7.3	13.6	5.9	95.3	3,115,244.8	1,592.4	1.0	0.6
12/28/2022 16:00	8.2	13.1	6.2	118.9	3,457,219.1	2,095.4	1.1	0.8
12/28/2022 17:00	7.3	13.3	5.7	108.5	3,469,208.4	1,976.0	1.0	0.8
12/28/2022 18:00	7.1	13.4	5.6	105.6	3,478,871.5	1,956.1	1.0	0.8
12/28/2022 19:00	7.1	13.4	5.6	105.9	3,481,361.3	1,957.5	1.0	0.8
12/28/2022 20:00	7.1	13.4	5.6	106.1	3,484,029.0	1,959.0	1.0	0.8
12/28/2022 21:00	7.3	13.3	5.7	107.6	3,459,376.7	1,970.4	1.0	0.8
12/28/2022 22:00	7.1	13.4	5.6	105.8	3,478,693.6	1,956.0	1.0	0.8
12/28/2022 23:00	7.1	13.4	5.6	105.9	3,487,408.1	1,960.9	1.0	0.8
Average/Sum#:	7.2	13.6	5.8	99.8	3,227,873.5	1,722.7	1.0	0.7
Minimum:	6.9	13.1	5.6	88.1	2,866,400.9	1,465.2	1.0	0.6
Maximum:	8.2	13.7	6.2	118.9	3,487,408.1	2,095.4	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/29/2022 00:00	7.1	13.4	5.6	105.7	3,480,294.3	1,956.9	1.0	0.8
12/29/2022 01:00	7.1	13.4	5.6	105.8	3,487,586.0	1,961.0	1.0	0.8
12/29/2022 02:00	7.1	13.4	5.6	105.8	3,494,699.9	1,965.0	1.0	0.8
12/29/2022 03:00	7.1	13.4	5.6	105.8	3,494,344.2	1,964.8	1.0	0.8
12/29/2022 04:00	7.1	13.4	5.6	106.0	3,501,991.6	1,969.1	1.0	0.8
12/29/2022 05:00	7.5	13.3	5.8	111.8	3,488,608.6	2,038.0	1.0	0.8
12/29/2022 06:00	7.5	13.2	5.7	112.8	3,378,188.5	2,047.5	1.1	0.8
12/29/2022 07:00	7.9	13.2	6.1	115.3	3,468,025.0	2,051.3	1.1	0.8
12/29/2022 08:00	8.1	13.0	6.0	131.5	3,472,986.2	2,206.4	1.2	1.1
12/29/2022 09:00	8.1	12.9	6.0	139.2	3,438,016.0	2,259.5	1.3	1.1
12/29/2022 10:00	7.8	13.1	5.9	122.7	3,483,010.1	2,161.9	1.1	0.9
12/29/2022 11:00	7.3	13.3	5.7	111.0	3,465,157.2	2,024.3	1.0	0.8
12/29/2022 12:00	7.3	13.3	5.7	107.7	3,487,116.3	1,986.2	1.0	0.8
12/29/2022 13:00	7.2	13.3	5.6	106.4	3,513,373.9	1,975.5	1.0	0.8
12/29/2022 14:00	7.4	13.3	5.7	107.8	3,485,185.1	1,985.1	1.0	0.8
12/29/2022 15:00	7.3	13.3	5.7	107.9	3,492,910.0	1,989.5	1.0	0.8
12/29/2022 16:00	7.7	13.1	5.8	118.0	3,507,563.5	2,100.3	1.1	0.8
12/29/2022 17:00	7.9	13.0	5.9	124.3	3,466,236.0	2,176.8	1.2	1.1
12/29/2022 18:00	7.5	13.1	5.7	116.4	3,440,885.0	2,085.5	1.1	0.8
12/29/2022 19:00	7.0	13.3	5.4	105.5	3,500,746.7	1,968.4	1.0	0.8
12/29/2022 20:00	7.2	13.3	5.6	106.6	3,517,464.3	1,977.8	1.0	0.8
12/29/2022 21:00	7.3	13.3	5.7	108.0	3,492,558.9	1,989.3	1.0	0.8
12/29/2022 22:00	7.1	13.3	5.5	106.1	3,462,361.3	1,972.1	1.0	0.8
12/29/2022 23:00	7.1	13.3	5.5	105.6	3,411,798.0	1,943.3	1.0	0.8
Average/Sum#:	7.4	13.2	5.7	112.2	3,476,296.1	2,031.5	1.1	0.8
Minimum:	7.0	12.9	5.4	105.5	3,378,188.5	1,943.3	1.0	0.8
Maximum:	8.1	13.4	6.1	139.2	3,517,464.3	2,259.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/30/2022 00:00	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
Minimum:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
Maximum:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:28 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:28 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:32 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:33 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:34 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	4.0	2.5	0.5	2.7	0.0
February	2.6	2.0	0.3	1.4	0.0
March	0.0	0.0	0.0	0.0	0.0
April	2.7	1.9	0.3	1.5	0.0
May	1.7	1.3	0.1	0.5	0.0
June	2.9	2.0	0.3	1.5	0.0
July	3.3	2.1	0.4	2.0	0.4
August	5.0	1.9	0.6	3.5	0.8
September	3.8	1.2	0.5	2.8	0.6
October	3.7	1.7	0.5	2.5	0.6
November	4.8	1.4	0.7	3.6	0.8
December	4.6	1.2	0.6	3.5	0.8
Quarter 1	6.6	4.5	0.8	4.1	0.0
Quarter 2	7.3	5.2	0.7	3.5	0.0
Quarter 3	12.1	5.2	1.5	8.3	1.8
Quarter 4	13.1	4.3	1.8	9.6	2.2
YTD	39.1	19.2	4.8	25.5	4.0

Cumulative Emissions Report

CT1

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:34 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
October	7,919,842	951,375	8,871,217.7	481	180.3
November	10,950,023	1,401,925	12,351,946.6	643	190.2
December	9,790,518	1,220,911	11,011,423.9	565	190.1
Quarter 4	28,660,383	3,574,211	32,234,588.2	1,689	186.9
YTD	28,660,383	3,574,211	32,234,588.2	1,689	186.9

Cumulative Emissions Report

CT2

From: 01/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:52 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	8,823,028	399,749	9,222,775.5	568	58,712.9
February	4,322,812	308,326	4,631,136.4	280	31,470.0
March	0	0	0.0	0	0.0
April	4,450,499	355,813	4,806,312.4	304	34,611.8
May	1,677,243	100,892	1,778,134.5	130	14,773.6
June	4,174,988	509,777	4,684,764.3	280	33,418.7
July	6,134,263	839,845	6,974,107.4	405	48,218.3
August	10,360,506	1,860,538	12,221,042.8	638	82,239.5
September	8,373,899	1,461,631	9,835,527.9	520	64,542.0
October	7,800,797	1,040,185	8,840,976.9	482	59,513.8
November	11,038,432	1,481,743	12,520,172.1	651	83,151.6
December	11,660,812	1,771,525	13,432,333.9	678	85,152.5
Quarter 1	13,145,840	708,075	13,853,911.9	848	90,182.9
Quarter 2	10,302,730	966,482	11,269,211.2	714	82,804.1
Quarter 3	24,868,668	4,162,014	29,030,678.1	1,563	194,999.8
Quarter 4	30,500,041	4,293,453	34,793,482.9	1,811	227,817.9
YTD	78,817,279	10,130,024	88,947,284.1	4,936	595,804.7

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
10/01/2022	1.9	6.8	6.1	59.0
10/02/2022	0.0	0.0	6.7	65.3
10/03/2022	27.1	97.8	13.4	133.3
10/04/2022	33.7	121.4	14.7	145.4
10/05/2022	34.5	123.1	14.8	147.5
10/06/2022	36.6	130.6	15.7	156.7
10/07/2022	36.5	130.6	15.7	156.8
10/08/2022	32.3	116.6	14.5	139.9
10/09/2022	26.5	95.0	9.7	97.9
10/10/2022	32.4	115.2	13.8	138.2
10/11/2022	27.8	99.1	11.7	120.5
10/12/2022	35.9	126.5	15.4	151.4
10/13/2022	30.7	108.1	12.5	128.6
10/14/2022	34.4	122.6	14.4	147.0
10/15/2022	0.0	0.0	0.0	0.0
10/16/2022	0.1	0.4	2.6	25.9
10/17/2022	32.0	113.1	13.9	137.1
10/18/2022	36.5	130.9	16.1	156.5
10/19/2022	36.0	128.5	15.0	153.7
10/20/2022	35.9	127.3	14.9	152.4
10/21/2022	28.2	100.6	12.1	120.2
10/22/2022	0.0	0.0	0.0	0.0
10/23/2022	0.0	0.0	0.8	8.2
10/24/2022	12.8	45.3	6.8	71.4
10/25/2022	31.0	108.4	0.0	0.0
10/26/2022	16.1	57.6	0.0	0.0
10/27/2022	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0
10/30/2022	0.0	0.0	1.1	10.8
10/31/2022	28.6	101.0	12.9	133.3
Monthly Avg/Sum*:	647.5 *	2,306.5 *	275.3 *	2,757.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	36.6	130.9	16.1	156.8
Oct 2022 - Oct 2022	647.5	2,306.5	275.3	2,757.0
QTD:	647.5 *	2,306.5 *	275.3 *	2,757.0 *
YTD 2022:	4,942.8 *	17,615.6 *	1,942.4 *	19,513.8 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
11/01/2022	36.1	129.2	15.6	154.8
11/02/2022	30.9	111.1	13.6	132.9
11/03/2022	33.1	118.4	14.1	141.9
11/04/2022	31.4	113.0	13.3	136.0
11/05/2022	21.5	75.7	4.2	41.6
11/06/2022	2.2	7.8	6.0	60.0
11/07/2022	28.6	101.7	14.1	138.7
11/08/2022	35.6	128.7	16.0	155.5
11/09/2022	33.3	119.1	14.2	143.3
11/10/2022	34.3	121.5	14.7	146.3
11/11/2022	34.8	123.4	14.9	148.3
11/12/2022	34.7	124.3	15.2	148.2
11/13/2022	34.7	124.3	15.1	148.8
11/14/2022	37.1	132.2	16.1	159.7
11/15/2022	36.4	129.6	15.9	155.6
11/16/2022	36.3	128.7	15.8	154.5
11/17/2022	36.8	131.2	16.1	157.6
11/18/2022	36.8	131.6	16.1	156.1
11/19/2022	36.0	128.1	15.7	152.8
11/20/2022	34.3	122.2	14.4	143.2
11/21/2022	36.5	129.2	15.7	155.6
11/22/2022	29.5	105.2	13.8	141.0
11/23/2022	32.4	115.3	14.1	139.0
11/24/2022	29.6	106.5	12.6	127.9
11/25/2022	30.6	109.0	13.0	130.8
11/26/2022	3.9	14.1	1.7	17.0
11/27/2022	0.0	0.0	0.5	4.6
11/28/2022	27.3	97.1	13.3	131.7
11/29/2022	37.1	132.3	16.1	160.3
11/30/2022	35.7	126.6	15.3	153.2
Monthly Avg/Sum*:	907.5 *	3,237.1 *	397.2 *	3,936.9 *
Daily Min:	0.0	0.0	0.5	4.6
Daily Max:	37.1	132.3	16.1	160.3
Oct 2022 - Nov 2022	1,555.0	5,543.6	672.5	6,693.9
QTD:	1,555.0 *	5,543.6 *	672.5 *	6,693.9 *
YTD 2022:	5,850.3 *	20,852.7 *	2,339.6 *	23,450.7 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
12/01/2022	0.0	0.0	13.9	136.1
12/02/2022	0.0	0.0	16.8	162.5
12/03/2022	0.0	0.0	16.8	166.5
12/04/2022	0.0	0.0	16.8	161.9
12/05/2022	19.5	70.4	15.9	158.4
12/06/2022	33.4	117.4	14.1	141.0
12/07/2022	36.6	130.0	15.8	156.8
12/08/2022	36.7	130.8	15.8	158.3
12/09/2022	36.4	129.8	15.6	157.4
12/10/2022	34.2	121.8	14.7	147.1
12/11/2022	33.8	119.4	14.4	143.8
12/12/2022	35.2	124.7	15.2	150.6
12/13/2022	36.4	129.7	15.7	156.6
12/14/2022	36.1	129.4	16.0	156.1
12/15/2022	37.4	132.5	16.3	160.4
12/16/2022	32.5	116.1	14.1	139.3
12/17/2022	36.2	128.5	15.2	155.0
12/18/2022	33.3	118.4	14.3	142.6
12/19/2022	37.4	133.2	16.3	160.3
12/20/2022	36.2	129.3	16.2	156.2
12/21/2022	37.9	134.5	16.7	162.9
12/22/2022	36.5	129.8	15.7	156.0
12/23/2022	37.2	130.8	16.2	158.4
12/24/2022	31.3	110.5	13.5	132.8
12/25/2022	1.5	5.1	2.2	23.5
12/26/2022	26.9	96.6	12.1	121.5
12/27/2022	23.8	84.0	11.9	117.9
12/28/2022	29.3	103.7	12.7	124.1
12/29/2022	34.2	121.1	14.7	146.4
12/30/2022	0.1	0.4	0.0	0.4
12/31/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	810.0 *	2,877.9 *	425.6 *	4,210.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	37.9	134.5	16.8	166.5
Oct 2022 - Dec 2022	2,365.0	8,421.5	1,098.1	10,904.7
QTD:	2,365.0 *	8,421.5 *	1,098.1 *	10,904.7 *
YTD 2022:	6,660.3 *	23,730.6 *	2,765.2 *	27,661.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
10/01/2022	16.6	11.16	1.6	100.6	180.10	11.6
10/02/2022	0.0	0.00	0.0	125.9	161.74	13.0
10/03/2022	160.6	200.30	23.1	22.5	121.10	26.2
10/04/2022	66.5	146.10	28.9	23.2	169.20	28.9
10/05/2022	70.3	146.10	29.3	23.2	169.40	29.3
10/06/2022	71.3	154.40	31.2	21.1	205.00	31.1
10/07/2022	72.8	156.50	31.5	20.9	207.00	31.5
10/08/2022	62.5	142.80	27.8	22.1	153.30	27.9
10/09/2022	139.2	158.89	22.6	92.8	201.10	19.6
10/10/2022	65.2	149.50	27.7	23.0	146.00	27.7
10/11/2022	45.9	133.30	24.0	21.5	93.00	24.1
10/12/2022	71.6	164.30	30.6	23.6	183.80	30.2
10/13/2022	62.6	156.50	26.3	30.1	135.10	26.0
10/14/2022	83.5	155.90	29.6	34.0	199.55	29.5
10/15/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/16/2022	63.7	27.50	0.1	218.2	159.59	5.2
10/17/2022	127.4	221.40	27.1	18.4	163.10	27.2
10/18/2022	74.0	163.20	31.5	23.7	208.70	31.5
10/19/2022	79.6	162.60	31.1	29.4	205.60	31.1
10/20/2022	83.0	163.50	30.9	30.5	203.40	30.5
10/21/2022	60.3	130.90	24.2	30.2	138.72	24.1
10/22/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/23/2022	0.0	0.00	0.0	125.6	123.53	1.6
10/24/2022	117.0	185.40	11.1	14.7	75.30	14.3
10/25/2022	35.5	159.00	26.3	0.0	0.00	0.0
10/26/2022	197.5	208.44	13.8	0.0	0.00	0.0
10/27/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/28/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/29/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/30/2022	0.0	0.00	0.0	218.6	174.42	2.1
10/31/2022	204.3	229.42	24.1	23.3	152.40	26.5
Monthly Avg/Sum*:	2,030.9 *	3,527.11 *	554.4 *	1,317.1 *	3,930.15 *	550.7 *
Daily Min:	16.6	11.16	0.1	14.7	75.30	1.6
Daily Max:	204.3	229.42	31.5	218.6	208.70	31.5
Oct 2022 - Oct 2022	2,030.9	3,527.11	554.4	1,317.1	3,930.15	550.7
QTD:	2,030.9 *	3,527.11 *	554.4 *	1,317.1 *	3,930.15 *	550.7 *
YTD 2022:	21,694.1 *	29,604.49 *	4,226.5 *	11,661.3 *	29,690.13 *	3,906.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
11/01/2022	72.6	159.80	31.1	20.0	204.80	30.8
11/02/2022	60.8	141.70	26.5	18.3	154.10	26.5
11/03/2022	62.1	151.00	28.2	17.1	174.30	28.2
11/04/2022	63.8	136.00	26.8	19.3	164.30	27.0
11/05/2022	147.2	192.20	18.4	14.9	57.39	8.5
11/06/2022	8.9	9.98	1.8	161.9	175.21	12.1
11/07/2022	165.6	217.78	24.5	105.4	217.24	27.9
11/08/2022	66.2	168.90	30.8	21.6	207.00	30.8
11/09/2022	61.1	153.20	28.6	18.0	179.10	28.7
11/10/2022	60.7	151.80	29.4	14.9	185.00	29.5
11/11/2022	51.9	149.90	29.8	10.8	183.60	29.9
11/12/2022	52.0	151.40	30.1	9.4	186.10	29.8
11/13/2022	47.0	157.60	29.9	10.6	186.60	29.8
11/14/2022	57.0	160.70	32.0	17.2	212.80	32.0
11/15/2022	56.5	152.40	31.4	18.7	208.00	31.2
11/16/2022	71.5	156.80	30.9	8.6	192.00	31.0
11/17/2022	59.0	167.70	31.7	0.0	206.40	31.7
11/18/2022	56.9	170.20	31.6	0.0	205.70	31.2
11/19/2022	65.4	164.00	31.0	0.0	197.60	30.6
11/20/2022	47.2	158.20	29.5	0.0	147.90	28.5
11/21/2022	67.5	165.60	31.3	0.0	201.30	31.5
11/22/2022	156.1	184.70	25.4	0.0	152.00	28.3
11/23/2022	64.1	150.40	27.7	0.6	151.80	27.8
11/24/2022	44.2	148.20	25.4	2.0	105.40	25.4
11/25/2022	48.7	144.00	26.5	0.3	115.90	26.4
11/26/2022	23.0	23.80	3.3	9.8	27.40	3.3
11/27/2022	0.0	0.00	0.0	145.6	128.98	0.8
11/28/2022	174.9	232.86	23.4	0.0	124.20	26.4
11/29/2022	64.6	175.50	32.2	0.0	213.70	32.3
11/30/2022	89.6	169.80	30.8	11.9	196.80	31.0
Monthly Avg/Sum*:	2,066.1 *	4,466.12 *	780.0 *	656.9 *	5,062.62 *	788.9 *
Daily Min:	8.9	9.98	1.8	0.0	27.40	0.8
Daily Max:	174.9	232.86	32.2	161.9	217.24	32.3
Oct 2022 - Nov 2022	4,097.0	7,993.23	1,334.4	1,974.0	8,992.77	1,339.6
QTD:	4,097.0 *	7,993.23 *	1,334.4 *	1,974.0 *	8,992.77 *	1,339.6 *
YTD 2022:	23,760.2 *	34,070.61 *	5,006.5 *	12,318.2 *	34,752.75 *	4,695.4 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
12/01/2022	0.0	0.00	0.0	65.5	200.60	27.2
12/02/2022	0.0	0.00	0.0	1.8	216.70	32.4
12/03/2022	0.0	0.00	0.0	0.3	221.90	33.4
12/04/2022	0.0	0.00	0.0	0.6	215.90	32.1
12/05/2022	129.4	171.10	16.9	0.0	207.40	31.4
12/06/2022	65.5	152.30	28.3	0.6	144.90	28.6
12/07/2022	69.8	164.20	31.3	0.0	205.20	31.8
12/08/2022	71.1	172.10	31.8	0.0	208.20	31.8
12/09/2022	73.9	164.60	31.5	0.3	203.50	31.6
12/10/2022	81.4	168.30	29.3	0.0	172.60	29.4
12/11/2022	94.5	161.40	29.0	0.0	160.40	29.0
12/12/2022	84.9	166.10	30.1	1.5	177.10	30.3
12/13/2022	73.7	161.60	31.6	0.0	198.90	31.6
12/14/2022	74.5	168.00	31.3	0.0	194.30	31.3
12/15/2022	61.8	160.90	31.5	0.0	213.70	32.4
12/16/2022	64.8	153.70	27.9	0.0	147.50	27.9
12/17/2022	69.6	162.40	31.1	0.0	198.60	31.2
12/18/2022	61.8	158.40	28.4	0.0	162.70	28.5
12/19/2022	74.6	166.60	32.4	0.0	214.00	32.5
12/20/2022	74.3	167.90	31.0	0.0	202.30	31.4
12/21/2022	65.2	163.00	32.0	3.9	207.10	33.0
12/22/2022	78.5	159.50	31.0	12.5	200.50	31.5
12/23/2022	69.6	165.60	31.1	6.4	206.90	32.0
12/24/2022	67.5	143.80	26.7	9.5	123.20	26.7
12/25/2022	11.2	8.02	1.3	131.4	123.34	4.8
12/26/2022	190.6	230.94	23.1	15.7	98.11	24.1
12/27/2022	159.1	153.60	20.4	54.1	152.64	23.7
12/28/2022	53.0	139.00	24.9	9.5	100.70	24.7
12/29/2022	95.9	161.30	29.2	22.7	165.40	29.5
12/30/2022	7.7	1.88	0.1	5.5	2.85	0.1
12/31/2022	0.0	0.00	0.0	0.0	0.00	0.0
Monthly Avg/Sum*:	2,023.9 *	3,946.24 *	693.2 *	341.8 *	5,247.14 *	845.9 *
Daily Min:	7.7	1.88	0.1	0.0	2.85	0.1
Daily Max:	190.6	230.94	32.4	131.4	221.90	33.4
Oct 2022 - Dec 2022	6,120.9	11,939.47	2,027.6	2,315.8	14,239.91	2,185.5
QTD:	6,120.9 *	11,939.47 *	2,027.6 *	2,315.8 *	14,239.91 *	2,185.5 *
YTD 2022:	25,784.1 *	38,016.85 *	5,699.7 *	12,660.0 *	39,999.89 *	5,541.3 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	1.48	22,748.8	1.18	3,659.4	26,408.2	366.1	2,746.428
10/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/03/2022	21.82	348,310.3	8.03	27,830.9	376,141.2	3,751.6	39,118.620
10/04/2022	24.00	406,146.3	18.02	60,342.2	466,488.5	4,218.2	48,514.800
10/05/2022	24.00	411,799.5	19.00	61,957.4	473,756.9	3,773.3	49,270.800
10/06/2022	24.00	417,033.0	24.00	85,505.6	502,538.6	3,947.9	52,264.200
10/07/2022	24.00	417,192.6	24.00	84,546.2	501,738.8	3,955.1	52,180.600
10/08/2022	24.00	394,261.8	16.17	55,148.8	449,410.6	4,291.1	46,739.000
10/09/2022	20.22	324,309.5	12.75	41,014.1	365,323.6	4,179.5	37,993.712
10/10/2022	24.00	399,851.7	15.30	43,629.1	443,480.8	4,510.5	46,121.800
10/11/2022	24.00	368,718.0	4.78	11,536.4	380,254.4	3,921.6	39,546.500
10/12/2022	24.00	413,581.9	20.93	73,730.4	487,312.3	4,996.0	50,680.600
10/13/2022	24.00	398,608.6	9.05	17,488.3	416,096.9	4,243.3	43,274.000
10/14/2022	23.55	404,321.1	23.27	67,363.2	471,684.4	4,735.0	49,055.115
10/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2022	0.50	1,470.4	0.00	0.0	1,470.4	8.5	152.900
10/17/2022	24.00	392,382.2	12.34	41,812.2	434,194.4	4,573.5	45,156.100
10/18/2022	24.00	419,814.3	24.00	83,523.0	503,337.3	5,120.5	52,347.000
10/19/2022	24.00	418,290.0	24.00	75,008.9	493,298.9	5,064.9	51,303.000
10/20/2022	24.00	419,015.1	24.00	70,795.0	489,810.1	4,997.7	50,940.100
10/21/2022	22.48	364,897.3	7.22	21,412.9	386,310.2	3,940.2	40,176.388
10/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/24/2022	11.08	174,700.9	0.00	0.0	174,700.9	1,794.6	18,168.876
10/25/2022	24.00	417,490.1	0.00	0.0	417,490.1	3,805.9	43,418.800
10/26/2022	14.99	221,295.1	0.00	0.0	221,295.1	2,529.4	23,014.664
10/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/31/2022	22.97	363,602.6	9.05	25,072.5	388,675.1	3,986.0	40,422.221
Monthly Avg/Sum*:	475.09 *	7,919,841.1 *	297.09 *	951,376.5 *	8,871,217.7 *	86,710.4 *	922,606.224 *
Daily Min:	0.50	1,470.4	0.00	0.0	1,470.4	8.5	152.900
Daily Max:	24.00	419,814.3	24.00	85,505.6	503,337.3	5,120.5	52,347.000
Oct 2022 - Oct 2022	475.09	7,919,841.1	297.09	951,376.5	8,871,217.7	86,710.4	922,606.224
QTD:	475.09 *	7,919,841.1 *	297.09 *	951,376.5 *	8,871,217.7 *	86,710.4 *	922,606.224 *
YTD 2022:	3,804.18 *	60,808,971.0 *	2,267.96 *	6,868,954.1 *	67,677,925.2 *	662,306.6 *	7,045,504.614 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	24.00	417,976.8	23.70	75,414.7	493,391.5	4,817.2	51,707.400
11/02/2022	24.00	395,648.6	11.55	28,535.3	424,183.9	4,032.3	44,454.400
11/03/2022	24.00	405,138.5	16.02	47,213.2	452,351.7	4,391.6	47,406.500
11/04/2022	24.00	394,996.2	16.03	36,431.5	431,427.7	4,129.0	45,213.800
11/05/2022	17.43	274,407.2	12.00	14,497.3	288,904.5	2,952.4	30,277.179
11/06/2022	2.18	29,538.7	0.00	0.0	29,538.7	484.2	3,095.668
11/07/2022	20.40	340,508.8	17.80	47,214.4	387,723.2	3,933.6	40,633.200
11/08/2022	24.00	425,520.2	24.00	65,001.5	490,521.7	4,701.7	51,406.600
11/09/2022	24.00	415,419.0	17.25	39,037.5	454,456.5	4,391.5	47,627.100
11/10/2022	24.00	416,466.8	17.98	48,474.2	464,941.0	4,472.3	48,725.600
11/11/2022	24.00	414,482.5	16.73	55,960.4	470,442.9	4,656.6	49,302.300
11/12/2022	24.00	412,508.6	17.23	61,307.3	473,815.9	4,716.5	49,655.900
11/13/2022	24.00	417,232.0	16.74	56,907.6	474,139.6	4,708.2	49,689.900
11/14/2022	24.00	427,475.3	24.00	76,687.2	504,162.5	4,917.0	52,836.200
11/15/2022	24.00	423,461.7	24.00	72,037.0	495,498.7	5,025.7	51,928.400
11/16/2022	24.00	424,352.0	24.00	66,193.3	490,545.3	4,828.1	51,409.300
11/17/2022	24.00	424,594.3	24.00	75,959.8	500,554.1	5,006.1	52,458.500
11/18/2022	24.00	421,990.9	24.00	79,686.9	501,677.8	5,150.7	52,576.000
11/19/2022	24.00	423,286.6	24.00	65,114.9	488,401.5	4,912.2	51,184.700
11/20/2022	24.00	409,466.1	16.03	57,261.9	466,728.0	4,666.7	48,913.200
11/21/2022	24.00	424,747.2	24.00	68,299.4	493,046.6	4,818.5	51,671.300
11/22/2022	21.97	368,689.3	16.80	32,684.1	401,373.4	4,196.4	42,064.070
11/23/2022	24.00	405,865.9	17.04	33,910.9	439,776.8	4,208.1	46,088.500
11/24/2022	24.00	391,815.6	7.95	14,588.7	406,404.3	3,946.7	42,591.300
11/25/2022	24.00	400,436.2	9.48	16,148.1	416,584.3	3,990.8	43,658.000
11/26/2022	3.00	49,653.7	2.68	4,299.1	53,952.8	534.8	5,654.200
11/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/28/2022	21.95	346,183.8	11.10	23,929.2	370,113.0	3,736.6	38,787.790
11/29/2022	24.00	425,556.0	24.00	78,971.3	504,527.3	5,093.7	52,874.500
11/30/2022	24.00	422,602.1	23.67	60,159.3	482,761.4	4,699.3	50,593.200
Monthly Avg/Sum*:	638.93 *	10,950,020.6 *	503.78 *	1,401,926.0 *	12,351,946.6 *	122,118.5 *	1,294,484.707 *
Daily Min:	2.18	29,538.7	0.00	0.0	29,538.7	484.2	3,095.668
Daily Max:	24.00	427,475.3	24.00	79,686.9	504,527.3	5,150.7	52,874.500
Oct 2022 - Nov 2022	1,114.02	18,869,861.7	800.87	2,353,302.5	21,223,164.3	208,828.9	2,217,090.931
QTD:	1,114.02 *	18,869,861.7 *	800.87 *	2,353,302.5 *	21,223,164.3 *	208,828.9 *	2,217,090.931 *
YTD 2022:	4,443.11 *	71,758,991.6 *	2,771.74 *	8,270,880.1 *	80,029,871.8 *	784,425.1 *	8,339,989.321 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/03/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/04/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/05/2022	14.12	231,636.4	12.70	37,199.1	268,835.5	2,829.5	28,093.128
12/06/2022	24.00	410,467.1	17.25	38,729.9	449,197.0	4,318.5	46,941.200
12/07/2022	24.00	430,228.1	24.00	66,917.8	497,145.9	4,843.7	51,951.700
12/08/2022	24.00	432,960.2	24.00	67,696.6	500,656.8	4,913.6	52,318.500
12/09/2022	24.00	430,617.6	24.00	66,881.3	497,498.9	4,856.7	51,988.700
12/10/2022	24.00	418,274.6	24.00	48,218.6	466,493.2	4,435.2	48,748.600
12/11/2022	24.00	421,857.1	24.00	35,250.4	457,107.5	4,229.0	47,767.900
12/12/2022	24.00	426,529.8	24.00	51,319.3	477,849.1	4,515.8	49,935.000
12/13/2022	24.00	429,858.5	24.00	66,103.8	495,962.3	4,815.9	51,828.000
12/14/2022	24.00	432,234.2	24.00	62,651.5	494,885.7	4,723.1	51,715.500
12/15/2022	24.00	428,227.0	24.00	78,923.3	507,150.3	5,113.4	52,997.300
12/16/2022	24.00	403,808.6	18.03	39,763.5	443,572.1	4,344.2	46,353.400
12/17/2022	24.00	427,475.5	24.00	63,298.9	490,774.4	4,743.4	51,286.200
12/18/2022	24.00	410,501.5	17.02	43,755.6	454,257.1	4,393.3	47,469.800
12/19/2022	24.00	440,899.6	24.00	69,250.9	510,150.5	4,857.9	53,310.800
12/20/2022	24.00	434,137.8	23.98	61,046.1	495,183.9	4,671.0	51,746.700
12/21/2022	24.00	432,099.5	24.00	81,559.9	513,659.4	5,128.2	53,677.400
12/22/2022	24.00	434,643.9	24.00	62,010.8	496,654.7	4,781.8	51,900.700
12/23/2022	24.00	428,687.1	24.00	71,996.7	500,683.8	5,000.7	52,321.600
12/24/2022	24.00	399,176.3	15.77	22,801.7	421,978.0	4,034.0	44,096.600
12/25/2022	1.22	18,463.7	0.98	1,249.9	19,713.6	360.5	2,060.108
12/26/2022	22.86	358,447.3	6.00	10,653.9	369,101.2	3,942.3	38,570.806
12/27/2022	18.45	300,661.4	14.02	19,836.0	320,497.4	3,292.5	33,491.990
12/28/2022	24.00	385,671.0	8.03	11,882.7	397,553.7	3,894.4	41,544.400
12/29/2022	24.00	421,451.4	23.95	41,910.0	463,361.4	4,199.7	48,421.200
12/30/2022	0.25	1,500.5	0.00	0.0	1,500.5	172.4	156.800
12/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	560.90 *	9,790,515.7 *	493.73 *	1,220,908.2 *	11,011,423.9 *	107,410.7 *	1,150,694.032 *
Daily Min:	0.25	1,500.5	0.00	0.0	1,500.5	172.4	156.800
Daily Max:	24.00	440,899.6	24.00	81,559.9	513,659.4	5,128.2	53,677.400
Oct 2022 - Dec 2022	1,674.92	28,660,377.4	1,294.60	3,574,210.7	32,234,588.2	316,239.6	3,367,784.963
QTD:	1,674.92 *	28,660,377.4 *	1,294.60 *	3,574,210.7 *	32,234,588.2 *	316,239.6 *	3,367,784.963 *
YTD 2022:	5,004.01 *	81,549,507.3 *	3,265.47 *	9,491,788.3 *	91,041,295.7 *	891,835.8 *	9,490,683.353 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	12.45	167,393.3	6.42	21,965.5	189,358.8	1,930.3	19,693.145
10/02/2022	12.67	181,518.7	7.23	27,832.8	209,351.5	1,814.2	21,772.538
10/03/2022	24.00	397,876.6	8.07	29,330.8	427,207.4	2,685.9	44,429.400
10/04/2022	24.00	403,065.7	18.07	63,237.8	466,303.5	2,923.0	48,495.600
10/05/2022	24.00	407,485.9	18.98	65,164.4	472,650.3	2,952.1	49,155.700
10/06/2022	24.00	412,343.6	24.00	90,243.8	502,587.4	3,184.1	52,269.100
10/07/2022	24.00	413,011.3	24.00	89,386.7	502,398.0	3,192.0	52,249.400
10/08/2022	24.00	390,331.2	16.24	58,920.2	449,251.4	2,847.7	46,722.000
10/09/2022	16.72	270,289.8	12.77	43,895.3	314,185.1	2,177.2	32,675.224
10/10/2022	24.00	396,466.2	15.29	46,577.2	443,043.4	2,750.2	46,076.500
10/11/2022	24.00	372,504.0	5.05	13,945.5	386,449.5	2,454.7	40,190.900
10/12/2022	24.00	409,594.7	20.93	75,399.5	484,994.2	3,057.5	50,439.400
10/13/2022	24.00	393,689.1	9.05	18,684.1	412,373.2	2,572.6	42,886.900
10/14/2022	23.55	402,242.6	23.27	68,552.6	470,795.2	3,089.0	48,962.830
10/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2022	6.73	83,025.6	0.00	0.0	83,025.6	837.0	8,634.605
10/17/2022	24.00	397,009.5	12.31	42,634.7	439,644.2	2,908.5	45,723.100
10/18/2022	24.00	416,451.3	24.00	85,251.5	501,702.8	3,463.5	52,177.200
10/19/2022	24.00	416,648.1	24.00	77,152.6	493,800.7	3,353.5	51,355.200
10/20/2022	24.00	415,714.1	24.00	73,252.6	488,966.7	3,274.3	50,852.600
10/21/2022	22.52	363,089.1	7.18	22,364.0	385,453.1	2,557.3	40,087.332
10/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2022	3.72	26,207.7	0.00	0.0	26,207.7	515.0	2,725.484
10/24/2022	14.42	228,675.9	0.00	0.0	228,675.9	1,577.6	23,782.238
10/25/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/26/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2022	4.20	34,810.2	0.00	0.0	34,810.2	644.1	3,620.300
10/31/2022	24.00	401,351.0	9.05	26,390.1	427,741.1	2,752.5	44,485.100
Monthly Avg/Sum*:	476.98 *	7,800,795.2 *	309.91 *	1,040,181.7 *	8,840,976.9 *	59,513.8 *	919,461.796 *
Daily Min:	3.72	26,207.7	0.00	0.0	26,207.7	515.0	2,725.484
Daily Max:	24.00	416,648.1	24.00	90,243.8	502,587.4	3,463.5	52,269.100
Oct 2022 - Oct 2022	476.98	7,800,795.2	309.91	1,040,181.7	8,840,976.9	59,513.8	919,461.796
QTD:	476.98 *	7,800,795.2 *	309.91 *	1,040,181.7 *	8,840,976.9 *	59,513.8 *	919,461.796 *
YTD 2022:	3,519.78 *	56,118,030.9 *	2,211.67 *	6,876,742.3 *	62,994,778.1 *	427,500.6 *	6,504,334.621 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	24.00	415,783.9	23.70	76,961.4	492,745.3	3,311.0	51,639.900
11/02/2022	24.00	393,465.5	11.57	30,395.6	423,861.1	2,664.9	44,420.700
11/03/2022	24.00	403,027.7	16.02	47,911.9	450,939.6	2,992.9	47,258.300
11/04/2022	24.00	393,284.9	16.10	38,972.1	432,257.0	2,832.5	45,300.800
11/05/2022	7.23	122,390.0	6.95	10,168.9	132,558.9	912.4	13,892.286
11/06/2022	12.32	172,667.3	6.42	17,984.0	190,651.4	1,709.9	19,980.322
11/07/2022	23.45	389,545.0	17.80	51,313.8	440,858.8	3,247.8	46,201.960
11/08/2022	24.00	423,190.1	24.00	71,080.1	494,270.2	3,178.6	51,799.300
11/09/2022	24.00	412,161.3	17.25	43,101.9	455,263.2	2,872.6	47,711.400
11/10/2022	24.00	414,371.0	17.98	51,330.0	465,701.0	3,029.2	48,805.400
11/11/2022	24.00	411,878.3	16.73	58,662.8	470,541.1	3,173.2	49,312.600
11/12/2022	24.00	409,886.3	17.18	61,404.6	471,290.9	3,186.1	49,391.300
11/13/2022	24.00	413,852.6	16.80	59,848.6	473,701.2	3,338.4	49,644.000
11/14/2022	24.00	424,604.2	24.00	82,763.8	507,368.0	3,637.9	53,172.200
11/15/2022	24.00	422,662.5	24.00	73,246.0	495,908.5	3,490.0	51,971.100
11/16/2022	24.00	423,060.9	24.00	67,691.3	490,752.2	3,242.4	51,430.800
11/17/2022	24.00	421,345.4	24.00	80,945.3	502,290.7	3,395.4	52,640.300
11/18/2022	24.00	419,234.0	24.00	76,790.3	496,024.3	3,388.3	51,983.400
11/19/2022	24.00	420,953.1	24.00	65,379.5	486,332.6	3,215.3	50,967.500
11/20/2022	24.00	406,843.8	16.18	48,569.2	455,413.0	3,036.9	47,727.200
11/21/2022	24.00	422,291.5	24.00	72,225.7	494,517.2	3,224.5	51,825.300
11/22/2022	24.00	411,686.6	16.82	36,389.2	448,075.8	2,680.1	46,958.500
11/23/2022	24.00	404,523.0	17.02	38,015.3	442,538.3	2,624.7	46,378.000
11/24/2022	24.00	390,951.5	7.95	16,286.8	407,238.3	2,503.9	42,678.700
11/25/2022	24.00	397,991.5	9.48	18,223.2	416,214.7	2,505.4	43,619.500
11/26/2022	3.00	49,390.6	2.68	4,886.5	54,277.1	344.1	5,688.200
11/27/2022	2.70	14,595.3	0.00	0.0	14,595.3	419.9	1,529.640
11/28/2022	24.00	392,072.4	11.10	26,689.4	418,761.8	2,561.6	43,886.500
11/29/2022	24.00	421,604.2	24.00	87,477.9	509,082.1	3,387.8	53,351.700
11/30/2022	24.00	419,115.5	23.67	67,027.0	486,142.5	3,043.9	50,947.900
Monthly Avg/Sum*:	648.70 *	11,038,429.9 *	505.40 *	1,481,742.1 *	12,520,172.1 *	83,151.6 *	1,312,114.708 *
Daily Min:	2.70	14,595.3	0.00	0.0	14,595.3	344.1	1,529.640
Daily Max:	24.00	424,604.2	24.00	87,477.9	509,082.1	3,637.9	53,351.700
Oct 2022 - Nov 2022	1,125.68	18,839,225.1	815.31	2,521,923.8	21,361,149.0	142,665.4	2,231,576.504
QTD:	1,125.68 *	18,839,225.1 *	815.31 *	2,521,923.8 *	21,361,149.0 *	142,665.4 *	2,231,576.504 *
YTD 2022:	4,168.48 *	67,156,460.8 *	2,717.07 *	8,358,484.4 *	75,514,950.2 *	510,652.2 *	7,816,449.329 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	21.47	361,587.3	18.32	73,110.2	434,697.5	3,362.6	45,425.693
12/02/2022	24.00	428,734.6	24.00	89,313.0	518,047.6	3,518.7	54,136.100
12/03/2022	24.00	429,512.6	24.00	101,421.5	530,934.1	3,659.8	55,482.500
12/04/2022	24.00	424,925.0	24.00	91,432.3	516,357.3	3,432.0	53,959.500
12/05/2022	24.00	420,268.3	23.55	84,668.6	504,936.9	3,346.7	52,765.800
12/06/2022	24.00	406,717.7	17.23	43,735.3	450,453.0	2,753.3	47,072.300
12/07/2022	24.00	425,632.9	24.00	74,857.1	500,490.0	3,078.5	52,301.300
12/08/2022	24.00	428,427.0	24.00	75,177.1	503,604.1	3,070.3	52,626.600
12/09/2022	24.00	426,489.1	24.00	74,877.8	501,366.9	3,060.3	52,392.800
12/10/2022	24.00	415,952.1	24.00	54,384.2	470,336.3	2,785.0	49,150.100
12/11/2022	24.00	418,227.9	24.00	40,873.4	459,101.3	2,633.5	47,976.100
12/12/2022	24.00	422,439.5	24.00	58,562.1	481,001.6	2,887.4	50,264.600
12/13/2022	24.00	425,404.8	24.00	74,401.6	499,806.4	3,142.9	52,229.800
12/14/2022	24.00	427,460.2	24.00	70,831.8	498,292.0	3,059.8	52,071.400
12/15/2022	24.00	423,300.8	24.00	87,949.6	511,250.4	3,440.3	53,425.700
12/16/2022	24.00	399,846.5	18.03	44,655.7	444,502.2	2,722.1	46,450.600
12/17/2022	24.00	422,958.0	24.00	70,922.3	493,880.3	3,086.7	51,610.500
12/18/2022	24.00	406,113.3	17.00	48,916.8	455,030.1	2,773.2	47,550.700
12/19/2022	24.00	434,804.2	24.00	77,849.3	512,653.5	3,075.8	53,572.300
12/20/2022	24.00	428,805.5	23.98	68,783.9	497,589.4	2,992.0	51,998.300
12/21/2022	24.00	427,368.8	24.00	91,033.3	518,402.1	3,335.9	54,172.900
12/22/2022	24.00	429,729.4	24.00	68,827.4	498,556.8	2,955.8	52,099.500
12/23/2022	24.00	424,715.6	24.00	79,695.8	504,411.4	3,165.5	52,710.800
12/24/2022	24.00	396,546.3	15.77	26,863.0	423,409.3	2,489.2	44,246.200
12/25/2022	6.94	73,742.1	0.98	1,546.7	75,288.8	997.0	7,867.800
12/26/2022	23.23	376,374.0	6.04	11,907.9	388,281.9	2,507.0	40,575.316
12/27/2022	22.20	352,314.5	14.02	23,913.1	376,227.6	2,584.4	39,315.840
12/28/2022	24.00	382,192.5	8.03	13,439.8	395,632.3	2,396.0	41,343.600
12/29/2022	24.00	418,982.7	23.95	47,573.8	466,556.5	2,693.7	48,755.500
12/30/2022	0.23	1,236.3	0.00	0.0	1,236.3	147.1	129.191
12/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	674.07 *	11,660,809.5 *	594.90 *	1,771,524.4 *	13,432,333.9 *	85,152.5 *	1,403,679.340 *
Daily Min:	0.23	1,236.3	0.00	0.0	1,236.3	147.1	129.191
Daily Max:	24.00	434,804.2	24.00	101,421.5	530,934.1	3,659.8	55,482.500
Oct 2022 - Dec 2022	1,799.75	30,500,034.6	1,410.21	4,293,448.2	34,793,482.9	227,817.9	3,635,255.844
QTD:	1,799.75 *	30,500,034.6 *	1,410.21 *	4,293,448.2 *	34,793,482.9 *	227,817.9 *	3,635,255.844 *
YTD 2022:	4,842.55 *	78,817,270.3 *	3,311.97 *	10,130,008.8 *	88,947,284.1 *	595,804.7 *	9,220,128.669 *

ATTACHMENT 10
Maximum Emissions

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
10/01/2022	191.3	117.2	8.0	65.8	13.2
10/02/2022	161.7	125.9	6.7	65.3	13.0
10/03/2022	321.4	183.1	40.5	231.1	49.3
10/04/2022	315.3	89.7	48.4	266.8	57.8
10/05/2022	315.5	93.5	49.3	270.6	58.6
10/06/2022	359.4	92.4	52.3	287.3	62.3
10/07/2022	363.5	93.7	52.2	287.4	63.0
10/08/2022	296.1	84.6	46.8	256.5	55.7
10/09/2022	360.0	232.0	36.2	192.9	42.2
10/10/2022	295.5	88.2	46.2	253.4	55.4
10/11/2022	226.3	67.4	39.5	219.6	48.1
10/12/2022	348.1	95.2	51.3	277.9	60.8
10/13/2022	291.6	92.7	43.2	236.7	52.3
10/14/2022	355.5	117.5	48.8	269.6	59.1
10/15/2022	0.0	0.0	0.0	0.0	0.0
10/16/2022	187.1	281.9	2.7	26.3	5.3
10/17/2022	384.5	145.8	45.9	250.2	54.3
10/18/2022	371.9	97.7	52.6	287.4	63.0
10/19/2022	368.2	109.0	51.0	282.2	62.2
10/20/2022	366.9	113.5	50.8	279.7	61.4
10/21/2022	269.6	90.5	40.3	220.8	48.3
10/22/2022	0.0	0.0	0.0	0.0	0.0
10/23/2022	123.5	125.6	0.8	8.2	1.6
10/24/2022	260.7	131.7	19.6	116.7	25.4
10/25/2022	159.0	35.5	31.0	108.4	26.3
10/26/2022	208.4	197.5	16.1	57.6	13.8
10/27/2022	0.0	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0	0.0
10/30/2022	174.4	218.6	1.1	10.8	2.1
10/31/2022	381.8	227.6	41.5	234.3	50.6
Monthly Avg/Sum*:	7,457.2 *	3,348.0 *	922.8 *	5,063.5 *	1,105.1 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	384.5	281.9	52.6	287.4	63.0
Oct 2022 - Oct 2022	7,457.2	3,348.0	922.8	5,063.5	1,105.1
QTD:	7,457.2 *	3,348.0 *	922.8 *	5,063.5 *	1,105.1 *
YTD 2022:	59,296.1 *	33,355.4 *	6,885.2 *	37,129.4 *	4,756.6 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
11/01/2022	364.6	92.6	51.7	284.0	61.9
11/02/2022	295.8	79.1	44.5	244.0	53.0
11/03/2022	325.3	79.2	47.2	260.3	56.4
11/04/2022	300.3	83.1	44.7	249.0	53.8
11/05/2022	249.6	162.1	25.7	117.3	26.9
11/06/2022	185.2	170.8	8.2	67.8	13.9
11/07/2022	435.0	271.0	42.7	240.4	52.4
11/08/2022	375.9	87.8	51.6	284.2	61.6
11/09/2022	332.3	79.1	47.5	262.4	57.3
11/10/2022	336.8	75.6	49.0	267.8	58.9
11/11/2022	333.5	62.7	49.7	271.7	59.7
11/12/2022	337.5	61.4	49.9	272.5	59.9
11/13/2022	344.2	57.6	49.8	273.1	59.7
11/14/2022	373.5	74.2	53.2	291.9	64.0
11/15/2022	360.4	75.2	52.3	285.2	62.6
11/16/2022	348.8	80.1	52.1	283.2	61.9
11/17/2022	374.1	59.0	52.9	288.8	63.4
11/18/2022	375.9	56.9	52.9	287.7	62.8
11/19/2022	361.6	65.4	51.7	280.9	61.6
11/20/2022	306.1	47.2	48.7	265.4	58.0
11/21/2022	366.9	67.5	52.2	284.8	62.8
11/22/2022	336.7	156.1	43.3	246.2	53.7
11/23/2022	302.2	64.7	46.5	254.3	55.5
11/24/2022	253.6	46.2	42.2	234.4	50.8
11/25/2022	259.9	49.0	43.6	239.8	52.9
11/26/2022	51.2	32.8	5.6	31.1	6.6
11/27/2022	129.0	145.6	0.5	4.6	0.8
11/28/2022	357.1	174.9	40.6	228.8	49.8
11/29/2022	389.2	64.6	53.2	292.6	64.5
11/30/2022	366.6	101.5	51.0	279.8	61.8
Monthly Avg/Sum*:	9,528.8 *	2,723.0 *	1,304.7 *	7,174.0 *	1,568.9 *
Daily Min:	51.2	32.8	0.5	4.6	0.8
Daily Max:	435.0	271.0	53.2	292.6	64.5
Oct 2022 - Nov 2022	16,986.0	6,071.0	2,227.5	12,237.5	2,674.0
QTD:	16,986.0 *	6,071.0 *	2,227.5 *	12,237.5 *	2,674.0 *
YTD 2022:	68,824.9 *	36,078.4 *	8,189.9 *	44,303.4 *	6,325.5 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
12/01/2022	200.6	65.5	13.9	136.1	27.2
12/02/2022	216.7	1.8	16.8	162.5	32.4
12/03/2022	221.9	0.3	16.8	166.5	33.4
12/04/2022	215.9	0.6	16.8	161.9	32.1
12/05/2022	378.5	129.4	35.4	228.8	48.3
12/06/2022	297.2	66.1	47.5	258.4	56.9
12/07/2022	369.4	69.8	52.4	286.8	63.1
12/08/2022	380.3	71.1	52.5	289.1	63.6
12/09/2022	368.1	74.2	52.0	287.2	63.1
12/10/2022	340.9	81.4	48.9	268.9	58.7
12/11/2022	321.8	94.5	48.2	263.2	58.0
12/12/2022	343.2	86.4	50.4	275.3	60.4
12/13/2022	360.5	73.7	52.1	286.3	63.2
12/14/2022	362.3	74.5	52.1	285.5	62.6
12/15/2022	374.6	61.8	53.7	292.9	63.9
12/16/2022	301.2	64.8	46.6	255.4	55.8
12/17/2022	361.0	69.6	51.4	283.5	62.3
12/18/2022	321.1	61.8	47.6	261.0	56.9
12/19/2022	380.6	74.6	53.7	293.5	64.9
12/20/2022	370.2	74.3	52.4	285.5	62.4
12/21/2022	370.1	69.1	54.6	297.4	65.0
12/22/2022	360.0	91.0	52.2	285.8	62.5
12/23/2022	372.5	76.0	53.4	289.2	63.1
12/24/2022	267.0	77.0	44.8	243.3	53.4
12/25/2022	131.3	142.6	3.7	28.6	6.1
12/26/2022	329.0	206.3	39.0	218.1	47.2
12/27/2022	306.2	213.2	35.7	201.9	44.1
12/28/2022	239.7	62.5	42.0	227.8	49.6
12/29/2022	326.7	118.6	48.9	267.5	58.7
12/30/2022	4.8	13.2	0.1	0.8	0.2
12/31/2022	0.0	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	9,193.3 *	2,365.7 *	1,235.6 *	7,088.7 *	1,539.1 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	380.6	213.2	54.6	297.4	65.0
Oct 2022 - Dec 2022	26,179.3	8,436.7	3,463.1	19,326.2	4,213.1
QTD:	26,179.3 *	8,436.7 *	3,463.1 *	19,326.2 *	4,213.1 *
YTD 2022:	78,018.2 *	38,444.1 *	9,425.5 *	51,392.1 *	7,864.6 *

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/01/2022 00:00	15.2	3.5	2.1	11.9	2.6
10/01/2022 01:00	10.4	23.7	0.6	3.1	0.6
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	38.8	20.0	0.1	0.6	0.1
10/01/2022 13:00	22.6	16.4	0.1	1.1	0.2
10/01/2022 14:00	52.5	37.1	0.3	2.6	0.5
10/01/2022 15:00	1.4	0.5	0.4	4.2	0.8
10/01/2022 16:00	3.4	1.2	0.5	5.2	1.0
10/01/2022 17:00	9.0	1.3	0.7	6.8	1.4
10/01/2022 18:00	8.8	1.3	0.7	6.6	1.3
10/01/2022 19:00	8.1	1.9	0.6	6.1	1.2
10/01/2022 20:00	8.8	1.3	0.7	6.6	1.3
10/01/2022 21:00	7.7	1.2	0.6	5.8	1.2
10/01/2022 22:00	3.1	0.9	0.5	4.7	0.9
10/01/2022 23:00	1.4	6.9	0.1	0.5	0.1
Average/Sum#:	191.2 #	117.2 #	8.0 #	65.8 #	13.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.5	37.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	34.8	39.8	0.1	0.6	0.1
10/02/2022 12:00	19.8	23.7	0.1	1.2	0.2
10/02/2022 13:00	36.1	49.4	0.3	2.6	0.5
10/02/2022 14:00	3.5	1.0	0.5	5.2	1.0
10/02/2022 15:00	5.2	1.8	0.5	5.2	1.0
10/02/2022 16:00	8.7	1.9	0.7	6.6	1.3
10/02/2022 17:00	9.1	1.3	0.7	6.8	1.4
10/02/2022 18:00	9.1	1.3	0.7	6.8	1.4
10/02/2022 19:00	9.1	1.0	0.7	6.8	1.4
10/02/2022 20:00	9.1	1.0	0.7	6.8	1.4
10/02/2022 21:00	8.4	1.6	0.6	6.3	1.3
10/02/2022 22:00	5.7	1.2	0.6	5.7	1.1
10/02/2022 23:00	3.1	0.9	0.5	4.7	0.9
Average/Sum#:	161.7 #	125.9 #	6.7 #	65.3 #	13.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	36.1	49.4	0.7	6.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/03/2022 00:00	3.1	0.9	0.5	4.6	0.9
10/03/2022 01:00	3.1	0.9	0.5	4.7	0.9
10/03/2022 02:00	55.1	65.9	0.7	6.1	1.3
10/03/2022 03:00	35.3	53.5	1.1	6.9	1.4
10/03/2022 04:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 05:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 06:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 07:00	10.2	1.9	1.7	9.4	2.0
10/03/2022 08:00	8.6	1.6	1.7	9.5	2.0
10/03/2022 09:00	8.6	1.6	1.7	9.5	2.0
10/03/2022 10:00	3.4	2.6	1.7	9.5	2.0
10/03/2022 11:00	8.6	2.6	1.7	9.5	2.0
10/03/2022 12:00	8.6	2.6	1.7	9.5	2.0
10/03/2022 13:00	8.7	2.6	1.7	9.5	2.0
10/03/2022 14:00	8.6	2.6	1.7	9.4	2.0
10/03/2022 15:00	10.6	2.6	1.7	9.7	2.2
10/03/2022 16:00	12.4	5.7	2.0	11.4	2.4
10/03/2022 17:00	17.4	4.8	2.2	11.9	2.6
10/03/2022 18:00	17.6	4.1	2.2	12.1	2.6
10/03/2022 19:00	15.2	4.2	2.2	11.9	2.6
10/03/2022 20:00	15.3	4.1	2.2	12.1	2.6
10/03/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/03/2022 22:00	15.1	4.2	2.1	11.9	2.6
10/03/2022 23:00	15.2	4.2	2.2	11.9	2.6
Average/Sum#:	321.4 #	183.1 #	40.5 #	231.1 #	49.3 #
Minimum:	3.1	0.9	0.5	4.6	0.9
Maximum:	55.1	65.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/04/2022 00:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 01:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 02:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 03:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 04:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 05:00	15.5	3.6	2.2	12.1	2.6
10/04/2022 06:00	15.2	3.9	2.2	11.9	2.6
10/04/2022 07:00	12.2	3.9	2.0	11.2	2.4
10/04/2022 08:00	8.0	1.8	1.6	8.8	2.0
10/04/2022 09:00	9.3	2.0	1.6	8.5	1.8
10/04/2022 10:00	6.2	1.7	1.6	8.6	1.8
10/04/2022 11:00	9.4	2.6	1.6	8.6	1.8
10/04/2022 12:00	12.0	2.6	1.7	9.4	2.0
10/04/2022 13:00	6.9	3.2	1.7	9.6	2.0
10/04/2022 14:00	8.1	6.3	2.0	11.2	2.4
10/04/2022 15:00	15.0	4.8	2.1	11.8	2.6
10/04/2022 16:00	14.9	4.5	2.1	11.7	2.6
10/04/2022 17:00	15.0	4.2	2.1	11.8	2.6
10/04/2022 18:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 19:00	15.4	4.2	2.2	12.1	2.6
10/04/2022 20:00	15.7	3.5	2.3	12.3	2.6
10/04/2022 21:00	15.4	3.5	2.2	12.1	2.6
10/04/2022 22:00	15.2	3.9	2.2	11.9	2.6
10/04/2022 23:00	15.0	4.3	2.1	11.8	2.6
Average/Sum#:	309.1 #	88.0 #	48.4 #	266.8 #	57.8 #
Minimum:	6.9	1.8	1.6	8.5	1.8
Maximum:	15.7	6.3	2.3	12.3	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/05/2022 00:00	14.9	4.2	2.1	11.7	2.6
10/05/2022 01:00	12.0	4.6	2.0	11.0	2.4
10/05/2022 02:00	11.8	5.2	2.0	10.8	2.4
10/05/2022 03:00	12.6	4.9	2.1	11.5	2.6
10/05/2022 04:00	14.8	4.6	2.1	11.7	2.6
10/05/2022 05:00	15.4	3.9	2.2	12.1	2.6
10/05/2022 06:00	15.4	3.6	2.2	12.1	2.6
10/05/2022 07:00	11.9	4.9	2.0	10.9	2.4
10/05/2022 08:00	8.6	1.6	1.7	9.4	2.0
10/05/2022 09:00	8.3	1.9	1.7	9.2	2.0
10/05/2022 10:00	8.5	2.6	1.7	9.4	2.0
10/05/2022 11:00	8.6	2.6	1.7	9.4	2.0
10/05/2022 12:00	6.9	3.3	1.7	9.5	2.0
10/05/2022 13:00	12.4	5.8	2.1	11.4	2.4
10/05/2022 14:00	15.3	4.5	2.2	12.0	2.6
10/05/2022 15:00	14.9	4.5	2.1	11.7	2.6
10/05/2022 16:00	15.1	4.2	2.1	11.9	2.6
10/05/2022 17:00	15.4	3.8	2.2	12.1	2.6
10/05/2022 18:00	15.6	3.5	2.3	12.3	2.6
10/05/2022 19:00	15.7	3.5	2.3	12.3	2.6
10/05/2022 20:00	15.4	3.9	2.2	12.1	2.6
10/05/2022 21:00	15.6	3.5	2.3	12.3	2.6
10/05/2022 22:00	15.2	4.2	2.1	11.9	2.6
10/05/2022 23:00	15.2	4.2	2.2	11.9	2.6
Average/Sum#:	315.5 #	93.5 #	49.3 #	270.6 #	58.6 #
Minimum:	6.9	1.6	1.7	9.2	2.0
Maximum:	15.7	5.8	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/06/2022 00:00	15.1	4.3	2.1	11.9	2.6
10/06/2022 01:00	15.2	4.3	2.1	11.9	2.6
10/06/2022 02:00	15.2	4.2	2.1	11.9	2.6
10/06/2022 03:00	15.0	4.3	2.1	11.8	2.6
10/06/2022 04:00	15.2	3.2	2.2	12.1	2.6
10/06/2022 05:00	13.5	3.6	2.3	12.3	2.7
10/06/2022 06:00	15.6	3.3	2.3	12.3	2.6
10/06/2022 07:00	14.9	4.2	2.1	11.7	2.6
10/06/2022 08:00	12.4	4.5	2.1	11.4	2.4
10/06/2022 09:00	12.4	4.6	2.0	11.4	2.4
10/06/2022 10:00	14.5	4.6	2.1	11.4	2.4
10/06/2022 11:00	14.8	4.5	2.1	11.6	2.6
10/06/2022 12:00	15.0	4.2	2.1	11.7	2.6
10/06/2022 13:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 14:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 15:00	15.1	3.9	2.1	11.9	2.6
10/06/2022 16:00	15.4	3.9	2.2	12.1	2.6
10/06/2022 17:00	15.7	3.1	2.3	12.3	2.6
10/06/2022 18:00	15.7	3.2	2.3	12.3	2.6
10/06/2022 19:00	15.8	3.2	2.3	12.4	2.8
10/06/2022 20:00	15.8	3.2	2.3	12.4	2.8
10/06/2022 21:00	15.7	3.3	2.3	12.3	2.6
10/06/2022 22:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 23:00	15.2	4.3	2.2	11.9	2.6
Average/Sum#:	359.4 #	92.4 #	52.3 #	287.3 #	62.3 #
Minimum:	12.4	3.1	2.0	11.4	2.4
Maximum:	15.8	4.6	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/07/2022 00:00	15.0	4.3	2.1	11.8	2.6
10/07/2022 01:00	15.1	4.3	2.1	11.9	2.6
10/07/2022 02:00	15.0	4.3	2.1	11.8	2.6
10/07/2022 03:00	14.8	4.2	2.1	11.6	2.6
10/07/2022 04:00	15.1	4.3	2.1	11.9	2.6
10/07/2022 05:00	15.4	4.3	2.2	12.1	2.6
10/07/2022 06:00	15.4	3.6	2.2	12.1	2.6
10/07/2022 07:00	14.7	4.3	2.1	11.6	2.6
10/07/2022 08:00	12.2	4.6	2.0	11.2	2.4
10/07/2022 09:00	14.9	4.3	2.1	11.7	2.6
10/07/2022 10:00	14.9	4.3	2.1	11.7	2.6
10/07/2022 11:00	14.8	4.2	2.1	11.7	2.6
10/07/2022 12:00	15.2	4.2	2.2	11.9	2.6
10/07/2022 13:00	15.0	4.2	2.1	11.7	2.6
10/07/2022 14:00	15.3	3.9	2.2	12.1	2.6
10/07/2022 15:00	15.4	3.5	2.2	12.1	2.6
10/07/2022 16:00	15.3	3.9	2.2	12.0	2.6
10/07/2022 17:00	15.7	3.5	2.3	12.3	2.6
10/07/2022 18:00	15.7	3.1	2.3	12.3	2.6
10/07/2022 19:00	15.8	3.2	2.3	12.4	2.8
10/07/2022 20:00	15.8	3.2	2.3	12.5	2.8
10/07/2022 21:00	15.8	3.2	2.3	12.5	2.8
10/07/2022 22:00	15.8	3.2	2.3	12.4	2.8
10/07/2022 23:00	15.4	3.6	2.2	12.1	2.6
Average/Sum#:	363.5 #	93.7 #	52.2 #	287.4 #	63.0 #
Minimum:	12.2	3.1	2.0	11.2	2.4
Maximum:	15.8	4.6	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/08/2022 00:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 01:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 02:00	15.2	4.3	2.1	11.9	2.6
10/08/2022 03:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 04:00	15.2	4.2	2.2	12.0	2.6
10/08/2022 05:00	13.0	4.3	2.2	11.9	2.6
10/08/2022 06:00	12.6	4.5	2.1	11.6	2.6
10/08/2022 07:00	10.2	2.5	1.7	9.4	2.0
10/08/2022 08:00	5.5	2.0	1.4	7.5	1.6
10/08/2022 09:00	5.2	1.3	1.3	7.2	1.6
10/08/2022 10:00	5.2	1.3	1.3	7.2	1.6
10/08/2022 11:00	5.3	1.3	1.3	7.2	1.6
10/08/2022 12:00	7.8	2.4	1.6	8.6	1.8
10/08/2022 13:00	10.3	2.6	1.7	9.4	2.0
10/08/2022 14:00	10.5	2.6	1.7	9.6	2.0
10/08/2022 15:00	12.5	5.1	2.0	11.5	2.5
10/08/2022 16:00	15.4	4.2	2.2	12.1	2.6
10/08/2022 17:00	15.4	3.8	2.2	12.1	2.6
10/08/2022 18:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 19:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 20:00	15.2	4.2	2.2	12.1	2.6
10/08/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 22:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 23:00	15.2	4.3	2.2	11.9	2.6
Average/Sum#:	296.1 #	84.6 #	46.8 #	256.5 #	55.7 #
Minimum:	5.2	1.3	1.3	7.2	1.6
Maximum:	15.4	5.1	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/09/2022 00:00	15.2	4.2	2.2	11.9	2.6
10/09/2022 01:00	15.2	4.3	2.2	11.9	2.6
10/09/2022 02:00	15.0	4.2	2.1	11.7	2.6
10/09/2022 03:00	15.0	4.6	2.1	11.9	2.6
10/09/2022 04:00	15.2	4.2	2.1	11.9	2.6
10/09/2022 05:00	15.0	4.2	2.1	11.9	2.6
10/09/2022 06:00	21.9	39.0	1.7	9.2	2.0
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	0.3	3.9	0.0	0.1	0.0
10/09/2022 11:00	34.4	69.0	0.6	2.0	0.5
10/09/2022 12:00	4.2	1.0	1.0	3.5	0.8
10/09/2022 13:00	4.2	1.1	1.0	3.5	0.8
10/09/2022 14:00	39.8	24.7	1.3	5.2	1.2
10/09/2022 15:00	49.2	36.4	1.5	7.8	1.7
10/09/2022 16:00	10.3	2.6	1.7	9.4	2.0
10/09/2022 17:00	12.4	2.6	1.7	9.8	2.2
10/09/2022 18:00	14.5	5.8	2.1	11.4	2.4
10/09/2022 19:00	17.6	3.8	2.2	12.1	2.6
10/09/2022 20:00	15.3	3.8	2.2	12.1	2.6
10/09/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/09/2022 22:00	15.1	4.2	2.1	11.9	2.6
10/09/2022 23:00	15.0	4.2	2.1	11.8	2.6
Average/Sum#:	360.0 #	232.0 #	36.2 #	192.9 #	42.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.2	69.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/10/2022 00:00	14.9	4.2	2.1	11.7	2.6
10/10/2022 01:00	12.6	4.3	2.1	11.5	2.6
10/10/2022 02:00	13.8	5.6	2.0	10.9	2.4
10/10/2022 03:00	12.6	4.9	2.1	11.5	2.6
10/10/2022 04:00	17.1	4.3	2.1	11.7	2.6
10/10/2022 05:00	15.5	3.6	2.2	12.2	2.6
10/10/2022 06:00	15.5	3.6	2.2	12.1	2.6
10/10/2022 07:00	10.8	3.2	1.8	9.9	2.2
10/10/2022 08:00	7.8	2.3	1.6	8.5	1.8
10/10/2022 09:00	7.7	1.8	1.6	8.5	1.8
10/10/2022 10:00	5.6	1.4	1.4	7.7	1.6
10/10/2022 11:00	7.8	1.8	1.6	8.6	1.8
10/10/2022 12:00	7.9	1.8	1.6	8.6	1.8
10/10/2022 13:00	10.3	1.9	1.7	9.4	2.0
10/10/2022 14:00	10.3	2.2	1.7	9.4	2.0
10/10/2022 15:00	9.6	2.4	1.6	8.8	2.0
10/10/2022 16:00	11.8	5.4	2.0	10.8	2.4
10/10/2022 17:00	15.1	4.5	2.1	11.9	2.6
10/10/2022 18:00	15.4	4.2	2.2	12.1	2.6
10/10/2022 19:00	15.2	4.5	2.2	11.9	2.6
10/10/2022 20:00	15.2	4.5	2.1	11.9	2.6
10/10/2022 21:00	14.7	5.1	2.1	11.6	2.6
10/10/2022 22:00	14.7	5.2	2.1	11.5	2.6
10/10/2022 23:00	13.6	5.5	2.0	10.7	2.4
Average/Sum#:	295.5 #	88.2 #	46.2 #	253.4 #	55.4 #
Minimum:	5.6	1.4	1.4	7.7	1.6
Maximum:	17.1	5.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/11/2022 00:00	6.8	2.3	1.4	7.5	1.6
10/11/2022 01:00	5.2	1.7	1.3	7.2	1.6
10/11/2022 02:00	5.2	1.4	1.3	7.2	1.6
10/11/2022 03:00	5.4	2.0	1.3	7.4	1.6
10/11/2022 04:00	6.0	2.0	1.4	8.2	1.8
10/11/2022 05:00	5.3	2.2	1.3	7.2	1.6
10/11/2022 06:00	5.2	2.5	1.3	7.2	1.6
10/11/2022 07:00	5.2	2.2	1.3	7.3	1.6
10/11/2022 08:00	7.5	2.2	1.4	8.5	1.8
10/11/2022 09:00	7.6	2.0	1.5	8.5	1.9
10/11/2022 10:00	9.8	2.5	1.6	9.1	1.9
10/11/2022 11:00	8.4	2.2	1.6	9.3	2.0
10/11/2022 12:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 13:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 14:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 15:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 16:00	10.7	2.6	1.8	9.8	2.2
10/11/2022 17:00	12.5	2.6	1.8	9.8	2.2
10/11/2022 18:00	12.5	2.6	1.8	9.8	2.2
10/11/2022 19:00	12.2	5.7	2.0	11.2	2.4
10/11/2022 20:00	14.8	4.8	2.1	11.6	2.6
10/11/2022 21:00	16.7	4.5	2.0	11.6	2.5
10/11/2022 22:00	14.7	4.5	2.1	11.6	2.6
10/11/2022 23:00	11.8	4.5	2.0	10.8	2.4
Average/Sum#:	226.3 #	67.4 #	39.5 #	219.6 #	48.1 #
Minimum:	5.2	1.4	1.3	7.2	1.6
Maximum:	16.7	5.7	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/12/2022 00:00	13.6	5.9	2.0	10.7	2.4
10/12/2022 01:00	11.6	5.9	2.0	10.6	2.4
10/12/2022 02:00	7.6	2.3	1.6	8.3	1.8
10/12/2022 03:00	8.1	2.1	1.6	9.0	2.0
10/12/2022 04:00	10.6	2.2	1.7	9.6	2.1
10/12/2022 05:00	12.8	5.4	2.1	11.7	2.6
10/12/2022 06:00	15.8	4.2	2.3	12.5	2.8
10/12/2022 07:00	15.8	3.6	2.3	12.3	2.7
10/12/2022 08:00	15.7	3.6	2.3	12.3	2.6
10/12/2022 09:00	15.7	3.6	2.3	12.3	2.6
10/12/2022 10:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 11:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 12:00	17.9	3.3	2.3	12.3	2.7
10/12/2022 13:00	15.6	3.3	2.3	12.3	2.6
10/12/2022 14:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 15:00	17.9	3.5	2.3	12.3	2.7
10/12/2022 16:00	15.8	3.4	2.3	12.5	2.8
10/12/2022 17:00	15.8	3.4	2.3	12.5	2.8
10/12/2022 18:00	17.8	3.5	2.3	12.3	2.6
10/12/2022 19:00	14.9	4.5	2.1	11.7	2.6
10/12/2022 20:00	15.0	4.5	2.1	11.9	2.6
10/12/2022 21:00	14.9	4.8	2.1	11.6	2.6
10/12/2022 22:00	14.6	5.2	2.1	11.5	2.6
10/12/2022 23:00	13.8	6.2	2.0	10.8	2.4
Average/Sum#:	348.1 #	95.2 #	51.3 #	277.9 #	60.8 #
Minimum:	7.6	2.1	1.6	8.3	1.8
Maximum:	17.9	6.2	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/13/2022 00:00	13.7	6.5	2.0	10.8	2.4
10/13/2022 01:00	12.0	6.2	2.0	11.0	2.4
10/13/2022 02:00	11.7	7.5	2.0	10.7	2.4
10/13/2022 03:00	13.7	6.9	2.0	10.8	2.4
10/13/2022 04:00	11.6	6.8	1.9	10.6	2.4
10/13/2022 05:00	6.5	2.5	1.3	7.2	1.6
10/13/2022 06:00	5.2	2.5	1.3	7.2	1.6
10/13/2022 07:00	5.3	2.3	1.3	7.2	1.6
10/13/2022 08:00	9.3	2.1	1.5	8.5	1.9
10/13/2022 09:00	7.7	2.0	1.6	8.4	1.8
10/13/2022 10:00	10.6	2.6	1.8	9.6	2.1
10/13/2022 11:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 12:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 13:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 14:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 15:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 16:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 17:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 18:00	14.3	2.6	1.8	9.9	2.2
10/13/2022 19:00	14.4	2.9	1.8	9.9	2.2
10/13/2022 20:00	14.4	6.2	2.0	11.3	2.4
10/13/2022 21:00	15.1	5.1	2.1	11.9	2.6
10/13/2022 22:00	16.6	4.9	2.1	11.4	2.5
10/13/2022 23:00	14.5	4.9	2.1	11.4	2.4
Average/Sum#:	291.6 #	92.7 #	43.2 #	236.7 #	52.3 #
Minimum:	5.2	2.0	1.3	7.2	1.6
Maximum:	16.6	7.5	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/14/2022 00:00	14.4	4.6	2.0	11.4	2.4
10/14/2022 01:00	14.5	4.5	2.0	11.3	2.4
10/14/2022 02:00	14.5	4.5	2.0	11.3	2.4
10/14/2022 03:00	14.5	4.2	2.0	11.3	2.4
10/14/2022 04:00	16.9	3.9	2.1	11.5	2.6
10/14/2022 05:00	18.0	3.2	2.3	12.4	2.8
10/14/2022 06:00	15.8	2.9	2.3	12.5	2.8
10/14/2022 07:00	15.7	2.9	2.3	12.4	2.7
10/14/2022 08:00	14.2	3.9	2.0	11.2	2.4
10/14/2022 09:00	15.8	4.5	2.0	10.8	2.4
10/14/2022 10:00	13.8	4.5	2.0	10.8	2.4
10/14/2022 11:00	13.9	4.5	2.0	10.9	2.4
10/14/2022 12:00	14.0	4.8	2.0	11.0	2.4
10/14/2022 13:00	14.0	4.5	2.0	11.0	2.4
10/14/2022 14:00	14.7	4.5	2.1	11.6	2.6
10/14/2022 15:00	14.9	4.2	2.1	11.8	2.6
10/14/2022 16:00	14.9	3.9	2.1	11.8	2.6
10/14/2022 17:00	15.5	3.4	2.3	12.2	2.6
10/14/2022 18:00	15.1	4.2	2.1	11.8	2.6
10/14/2022 19:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 20:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 21:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 22:00	14.7	4.2	2.1	11.5	2.6
10/14/2022 23:00	11.0	23.1	0.7	4.0	0.8
Average/Sum#:	355.5 #	117.5 #	48.8 #	269.6 #	59.1 #
Minimum:	11.0	2.9	0.7	4.0	0.8
Maximum:	18.0	23.1	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	44.1	74.6	0.1	0.7	0.1
10/16/2022 18:00	47.1	60.3	0.2	1.7	0.3
10/16/2022 19:00	44.4	80.7	0.3	2.9	0.6
10/16/2022 20:00	5.3	0.7	0.5	5.3	1.1
10/16/2022 21:00	6.7	0.6	0.5	5.1	1.0
10/16/2022 22:00	4.8	0.6	0.5	4.8	1.0
10/16/2022 23:00	34.7	64.4	0.6	5.8	1.2
Average/Sum#:	187.1 #	281.9 #	2.7 #	26.3 #	5.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	47.1	80.7	0.6	5.8	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/17/2022 00:00	70.9	74.0	1.1	7.0	1.5
10/17/2022 01:00	11.9	2.2	1.7	9.4	2.0
10/17/2022 02:00	12.0	2.2	1.7	9.4	2.0
10/17/2022 03:00	12.6	2.4	1.8	9.9	2.2
10/17/2022 04:00	16.5	4.8	2.1	11.4	2.5
10/17/2022 05:00	17.3	3.9	2.1	12.0	2.6
10/17/2022 06:00	15.1	4.0	2.1	11.8	2.6
10/17/2022 07:00	14.7	4.3	2.1	11.6	2.6
10/17/2022 08:00	11.8	2.4	1.7	9.2	2.0
10/17/2022 09:00	11.5	1.5	1.7	9.0	2.0
10/17/2022 10:00	9.2	2.0	1.6	8.4	1.8
10/17/2022 11:00	9.6	1.8	1.6	8.8	2.0
10/17/2022 12:00	9.0	2.0	1.6	8.3	1.8
10/17/2022 13:00	10.6	2.0	1.6	8.3	1.8
10/17/2022 14:00	10.0	1.9	1.7	9.2	2.0
10/17/2022 15:00	12.0	2.5	1.7	9.4	2.0
10/17/2022 16:00	16.6	5.2	2.1	11.4	2.5
10/17/2022 17:00	15.6	3.9	2.3	12.3	2.6
10/17/2022 18:00	18.0	3.6	2.3	12.4	2.7
10/17/2022 19:00	15.6	3.6	2.3	12.3	2.6
10/17/2022 20:00	15.6	3.6	2.3	12.3	2.6
10/17/2022 21:00	18.0	3.6	2.3	12.3	2.7
10/17/2022 22:00	15.2	4.2	2.2	12.0	2.6
10/17/2022 23:00	15.2	4.2	2.2	12.1	2.6
Average/Sum#:	384.5 #	145.8 #	45.9 #	250.2 #	54.3 #
Minimum:	9.0	1.5	1.1	7.0	1.5
Maximum:	70.9	74.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/18/2022 00:00	15.2	4.2	2.2	11.9	2.6
10/18/2022 01:00	15.2	3.6	2.2	11.9	2.6
10/18/2022 02:00	15.2	3.3	2.2	11.9	2.6
10/18/2022 03:00	15.3	3.3	2.2	12.0	2.6
10/18/2022 04:00	15.3	3.3	2.2	12.0	2.6
10/18/2022 05:00	15.2	3.6	2.2	11.9	2.6
10/18/2022 06:00	15.1	3.9	2.2	11.9	2.6
10/18/2022 07:00	15.1	3.9	2.2	11.9	2.6
10/18/2022 08:00	15.2	4.3	2.2	11.9	2.6
10/18/2022 09:00	15.1	4.3	2.1	11.9	2.6
10/18/2022 10:00	14.9	4.9	2.1	11.7	2.6
10/18/2022 11:00	16.8	4.9	2.1	11.6	2.6
10/18/2022 12:00	14.7	4.5	2.1	11.6	2.6
10/18/2022 13:00	16.8	4.9	2.1	11.6	2.6
10/18/2022 14:00	14.8	4.8	2.1	11.6	2.6
10/18/2022 15:00	14.9	4.8	2.1	11.8	2.6
10/18/2022 16:00	15.6	3.9	2.3	12.2	2.6
10/18/2022 17:00	15.4	4.2	2.2	12.1	2.6
10/18/2022 18:00	17.9	3.9	2.3	12.3	2.6
10/18/2022 19:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 20:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 21:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 22:00	15.4	4.2	2.2	12.1	2.6
10/18/2022 23:00	15.4	4.2	2.2	12.1	2.6
Average/Sum#:	371.9 #	97.7 #	52.6 #	287.4 #	63.0 #
Minimum:	14.7	3.3	2.1	11.6	2.6
Maximum:	17.9	4.9	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/19/2022 00:00	15.3	4.6	2.2	12.0	2.6
10/19/2022 01:00	14.9	4.6	2.1	11.7	2.6
10/19/2022 02:00	14.6	4.2	2.0	11.5	2.5
10/19/2022 03:00	14.9	3.9	2.1	11.7	2.6
10/19/2022 04:00	15.2	3.6	2.2	11.9	2.6
10/19/2022 05:00	15.6	3.2	2.2	12.2	2.6
10/19/2022 06:00	15.6	4.3	2.3	12.2	2.6
10/19/2022 07:00	15.1	4.9	2.1	11.8	2.6
10/19/2022 08:00	17.2	4.9	2.1	11.8	2.6
10/19/2022 09:00	14.7	4.9	2.1	11.6	2.6
10/19/2022 10:00	16.7	4.9	2.1	11.4	2.5
10/19/2022 11:00	14.8	4.8	2.1	11.6	2.6
10/19/2022 12:00	14.9	4.8	2.1	11.7	2.6
10/19/2022 13:00	15.1	4.5	2.1	11.8	2.6
10/19/2022 14:00	15.0	4.5	2.1	11.8	2.6
10/19/2022 15:00	15.3	4.2	2.2	12.0	2.6
10/19/2022 16:00	15.4	4.2	2.2	12.1	2.6
10/19/2022 17:00	14.9	4.8	2.1	11.7	2.6
10/19/2022 18:00	14.7	4.8	2.1	11.6	2.6
10/19/2022 19:00	14.7	4.8	2.1	11.6	2.6
10/19/2022 20:00	15.1	4.9	2.1	11.8	2.6
10/19/2022 21:00	14.9	4.9	2.1	11.6	2.6
10/19/2022 22:00	16.8	4.9	2.1	11.5	2.6
10/19/2022 23:00	16.8	4.9	2.1	11.6	2.6
Average/Sum#:	368.2 #	109.0 #	51.0 #	282.2 #	62.2 #
Minimum:	14.6	3.2	2.0	11.4	2.5
Maximum:	17.2	4.9	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/20/2022 00:00	14.9	4.9	2.1	11.7	2.6
10/20/2022 01:00	16.8	4.9	2.1	11.5	2.6
10/20/2022 02:00	14.6	4.9	2.1	11.4	2.5
10/20/2022 03:00	14.7	5.6	2.1	11.5	2.6
10/20/2022 04:00	17.0	4.9	2.1	11.7	2.6
10/20/2022 05:00	15.5	3.9	2.2	12.2	2.6
10/20/2022 06:00	15.4	4.3	2.2	12.1	2.6
10/20/2022 07:00	14.5	4.9	2.0	11.4	2.4
10/20/2022 08:00	14.4	4.9	2.0	11.3	2.4
10/20/2022 09:00	14.5	5.3	2.1	11.4	2.4
10/20/2022 10:00	14.4	4.9	2.0	11.4	2.4
10/20/2022 11:00	16.7	4.9	2.1	11.4	2.5
10/20/2022 12:00	16.7	4.8	2.1	11.4	2.5
10/20/2022 13:00	14.7	4.9	2.1	11.6	2.6
10/20/2022 14:00	14.9	4.8	2.1	11.7	2.6
10/20/2022 15:00	15.0	4.5	2.1	11.8	2.6
10/20/2022 16:00	15.8	3.9	2.3	12.3	2.7
10/20/2022 17:00	15.3	4.2	2.2	12.0	2.6
10/20/2022 18:00	15.6	4.2	2.3	12.2	2.6
10/20/2022 19:00	14.7	4.8	2.1	11.6	2.6
10/20/2022 20:00	14.7	4.8	2.1	11.6	2.6
10/20/2022 21:00	16.6	4.9	2.1	11.4	2.6
10/20/2022 22:00	14.6	4.9	2.1	11.4	2.6
10/20/2022 23:00	14.9	4.5	2.1	11.7	2.6
Average/Sum#:	366.9 #	113.5 #	50.8 #	279.7 #	61.4 #
Minimum:	14.4	3.9	2.0	11.3	2.4
Maximum:	17.0	5.6	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/21/2022 00:00	13.8	4.1	2.0	10.9	2.4
10/21/2022 01:00	9.4	1.8	1.6	8.7	1.9
10/21/2022 02:00	9.6	2.1	1.6	8.8	2.0
10/21/2022 03:00	9.2	2.4	1.6	8.5	1.8
10/21/2022 04:00	10.2	1.9	1.7	9.4	2.0
10/21/2022 05:00	10.2	2.3	1.7	9.4	2.0
10/21/2022 06:00	9.6	2.1	1.6	8.8	2.0
10/21/2022 07:00	10.0	2.2	1.7	9.2	2.0
10/21/2022 08:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 09:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 10:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 11:00	10.1	1.9	1.7	9.2	2.0
10/21/2022 12:00	9.9	2.4	1.7	9.1	2.0
10/21/2022 13:00	11.4	2.4	1.6	9.0	2.0
10/21/2022 14:00	11.8	2.9	1.7	9.2	2.0
10/21/2022 15:00	9.4	2.9	1.6	8.6	1.8
10/21/2022 16:00	14.7	5.4	2.1	11.5	2.6
10/21/2022 17:00	17.4	4.5	2.2	12.0	2.6
10/21/2022 18:00	14.9	4.8	2.1	11.8	2.6
10/21/2022 19:00	16.8	5.2	2.1	11.5	2.6
10/21/2022 20:00	14.8	4.8	2.1	11.7	2.6
10/21/2022 21:00	15.2	4.5	2.2	11.9	2.6
10/21/2022 22:00	10.3	23.9	0.6	3.4	0.8
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	269.6 #	90.5 #	40.3 #	220.8 #	48.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	17.4	23.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	44.9	62.4	0.1	0.6	0.1
10/23/2022 21:00	32.6	20.7	0.1	1.1	0.2
10/23/2022 22:00	43.3	42.2	0.2	2.4	0.5
10/23/2022 23:00	2.7	0.3	0.4	4.1	0.8
Average/Sum#:	123.5 #	125.6 #	0.8 #	8.2 #	1.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	44.9	62.4	0.4	4.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/24/2022 00:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 01:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 02:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 03:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 04:00	4.9	0.3	0.5	4.9	1.0
10/24/2022 05:00	5.5	0.3	0.5	5.5	1.1
10/24/2022 06:00	7.3	0.3	0.5	5.5	1.1
10/24/2022 07:00	5.5	0.3	0.5	5.5	1.1
10/24/2022 08:00	7.3	0.3	0.5	5.4	1.1
10/24/2022 09:00	5.4	0.7	0.5	5.4	1.1
10/24/2022 10:00	7.4	0.7	0.6	5.5	1.1
10/24/2022 11:00	7.3	0.7	0.5	5.5	1.1
10/24/2022 12:00	5.3	0.7	0.5	5.3	1.1
10/24/2022 13:00	90.7	75.2	0.8	6.3	1.3
10/24/2022 14:00	45.9	39.3	1.2	5.2	1.2
10/24/2022 15:00	5.3	1.3	1.2	4.4	1.1
10/24/2022 16:00	7.1	1.3	1.2	4.4	1.1
10/24/2022 17:00	7.1	1.3	1.2	4.4	1.1
10/24/2022 18:00	5.4	1.3	1.3	4.5	1.1
10/24/2022 19:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 20:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 21:00	5.4	1.3	1.3	4.5	1.1
10/24/2022 22:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 23:00	5.5	1.3	1.3	4.6	1.1
Average/Sum#:	260.7 #	131.7 #	19.6 #	116.7 #	25.4 #
Minimum:	2.7	0.3	0.4	4.1	0.8
Maximum:	90.7	75.2	1.3	6.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/25/2022 00:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 01:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 02:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 03:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 04:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 05:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 06:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 07:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 08:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 09:00	7.3	1.3	1.3	4.5	1.1
10/25/2022 10:00	7.3	1.3	1.3	4.5	1.1
10/25/2022 11:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 12:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 13:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 14:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 15:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 16:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 17:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 18:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 19:00	7.3	1.7	1.3	4.5	1.1
10/25/2022 20:00	7.2	1.7	1.3	4.5	1.1
10/25/2022 21:00	7.2	1.7	1.3	4.5	1.1
10/25/2022 22:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 23:00	4.9	1.2	1.1	4.1	1.0
Average/Sum#:	159.0 #	35.5 #	31.0 #	108.4 #	26.3 #
Minimum:	4.9	1.2	1.1	4.1	1.0
Maximum:	7.3	1.7	1.3	4.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/26/2022 00:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 01:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 02:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 03:00	4.8	1.2	1.1	4.0	1.0
10/26/2022 04:00	5.4	1.3	1.3	4.5	1.1
10/26/2022 05:00	5.2	1.3	1.2	4.3	1.0
10/26/2022 06:00	5.1	1.3	1.2	4.2	1.0
10/26/2022 07:00	5.2	1.3	1.2	4.4	1.0
10/26/2022 08:00	2.6	6.7	0.1	0.5	0.1
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	13.2	14.4	0.1	0.2	0.0
10/26/2022 17:00	44.8	25.5	0.2	0.5	0.1
10/26/2022 18:00	77.8	121.7	0.6	2.1	0.5
10/26/2022 19:00	5.5	1.7	1.3	4.6	1.1
10/26/2022 20:00	7.3	1.7	1.3	4.6	1.1
10/26/2022 21:00	5.4	1.7	1.3	4.5	1.1
10/26/2022 22:00	5.3	1.6	1.2	4.4	1.1
10/26/2022 23:00	6.1	12.5	0.7	2.5	0.6
Average/Sum#:	208.4 #	197.5 #	16.1 #	57.6 #	13.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	77.8	121.7	1.3	4.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	3.8	25.9	0.0	0.1	0.0
10/30/2022 20:00	65.6	49.9	0.1	1.1	0.2
10/30/2022 21:00	40.0	53.1	0.2	1.7	0.3
10/30/2022 22:00	59.7	89.0	0.3	2.6	0.5
10/30/2022 23:00	5.3	0.7	0.5	5.3	1.1
Average/Sum#:	174.4 #	218.6 #	1.1 #	10.8 #	2.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	65.6	89.0	0.5	5.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/31/2022 00:00	4.7	0.6	0.5	4.7	0.9
10/31/2022 01:00	62.9	77.4	0.7	6.1	1.3
10/31/2022 02:00	50.7	76.2	1.0	6.8	1.4
10/31/2022 03:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 04:00	10.4	2.3	1.7	9.5	2.0
10/31/2022 05:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 06:00	10.2	2.3	1.7	9.3	2.0
10/31/2022 07:00	10.2	2.3	1.7	9.3	2.0
10/31/2022 08:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 09:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 10:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 11:00	10.2	2.2	1.7	9.3	2.0
10/31/2022 12:00	10.1	1.9	1.7	9.2	2.0
10/31/2022 13:00	10.2	1.9	1.7	9.4	2.0
10/31/2022 14:00	12.4	2.9	1.7	9.7	2.2
10/31/2022 15:00	16.6	6.3	2.1	11.4	2.4
10/31/2022 16:00	14.7	5.6	2.1	11.6	2.6
10/31/2022 17:00	16.6	5.6	2.1	11.4	2.4
10/31/2022 18:00	14.5	5.6	2.1	11.4	2.4
10/31/2022 19:00	16.8	5.2	2.1	11.6	2.6
10/31/2022 20:00	14.7	4.9	2.1	11.5	2.6
10/31/2022 21:00	15.1	4.5	2.1	11.8	2.6
10/31/2022 22:00	14.8	4.2	2.1	11.6	2.6
10/31/2022 23:00	15.0	4.2	2.1	11.7	2.6
Average/Sum#:	381.8 #	227.6 #	41.5 #	234.3 #	50.6 #
Minimum:	4.7	0.6	0.5	4.7	0.9
Maximum:	62.9	77.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/01/2022 00:00	15.2	4.3	2.1	11.9	2.6
11/01/2022 01:00	15.1	4.3	2.1	11.9	2.6
11/01/2022 02:00	15.1	4.3	2.1	11.9	2.6
11/01/2022 03:00	15.2	4.3	2.1	11.9	2.6
11/01/2022 04:00	15.2	4.3	2.2	11.9	2.6
11/01/2022 05:00	17.4	4.3	2.2	11.9	2.6
11/01/2022 06:00	15.7	3.6	2.3	12.3	2.7
11/01/2022 07:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 08:00	15.6	3.3	2.3	12.3	2.6
11/01/2022 09:00	14.9	3.6	2.1	11.6	2.6
11/01/2022 10:00	14.9	4.3	2.1	11.7	2.6
11/01/2022 11:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 12:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 13:00	15.2	3.3	2.2	12.0	2.6
11/01/2022 14:00	14.6	3.6	2.1	11.4	2.5
11/01/2022 15:00	14.7	5.0	2.1	11.5	2.6
11/01/2022 16:00	15.5	4.0	2.2	12.2	2.6
11/01/2022 17:00	16.1	2.9	2.3	12.6	2.8
11/01/2022 18:00	15.4	3.7	2.2	12.1	2.6
11/01/2022 19:00	17.4	3.7	2.1	11.9	2.6
11/01/2022 20:00	15.4	3.7	2.2	12.1	2.6
11/01/2022 21:00	14.6	4.0	2.1	11.4	2.5
11/01/2022 22:00	14.5	4.0	2.1	11.4	2.4
11/01/2022 23:00	11.0	3.3	1.9	10.1	2.2
Average/Sum#:	364.6 #	92.6 #	51.7 #	284.0 #	61.9 #
Minimum:	11.0	2.9	1.9	10.1	2.2
Maximum:	17.4	5.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/02/2022 00:00	6.8	2.1	1.3	7.4	1.6
11/02/2022 01:00	9.8	1.8	1.6	9.0	2.0
11/02/2022 02:00	10.2	2.3	1.7	9.4	2.0
11/02/2022 03:00	6.8	3.1	1.3	7.4	1.6
11/02/2022 04:00	10.1	2.2	1.7	9.2	2.0
11/02/2022 05:00	13.4	4.2	1.9	10.5	2.3
11/02/2022 06:00	15.2	5.2	2.2	11.9	2.6
11/02/2022 07:00	14.9	4.4	2.1	11.7	2.6
11/02/2022 08:00	16.3	4.7	2.0	11.2	2.4
11/02/2022 09:00	10.3	1.9	1.7	9.4	2.0
11/02/2022 10:00	9.2	1.8	1.6	8.5	1.8
11/02/2022 11:00	10.0	1.9	1.7	9.2	2.0
11/02/2022 12:00	9.3	1.8	1.6	8.5	1.8
11/02/2022 13:00	9.4	1.8	1.6	8.6	1.8
11/02/2022 14:00	9.2	2.1	1.6	8.5	1.8
11/02/2022 15:00	9.6	2.1	1.6	8.8	2.0
11/02/2022 16:00	14.6	5.0	2.1	11.5	2.5
11/02/2022 17:00	17.4	4.3	2.2	11.9	2.6
11/02/2022 18:00	17.4	4.4	2.2	11.9	2.6
11/02/2022 19:00	15.2	4.4	2.2	11.9	2.6
11/02/2022 20:00	15.2	4.4	2.2	11.9	2.6
11/02/2022 21:00	15.1	4.4	2.1	11.9	2.6
11/02/2022 22:00	15.2	4.4	2.1	11.9	2.6
11/02/2022 23:00	15.2	4.4	2.2	11.9	2.6
Average/Sum#:	295.8 #	79.1 #	44.5 #	244.0 #	53.0 #
Minimum:	6.8	1.8	1.3	7.4	1.6
Maximum:	17.4	5.2	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/03/2022 00:00	17.4	4.4	2.2	11.9	2.6
11/03/2022 01:00	15.1	4.4	2.1	11.9	2.6
11/03/2022 02:00	15.4	4.4	2.2	12.1	2.6
11/03/2022 03:00	15.6	3.7	2.3	12.3	2.6
11/03/2022 04:00	17.4	4.4	2.1	11.9	2.6
11/03/2022 05:00	15.2	4.4	2.1	11.9	2.6
11/03/2022 06:00	13.4	3.7	2.3	12.3	2.6
11/03/2022 07:00	14.8	4.0	2.1	11.6	2.6
11/03/2022 08:00	8.8	1.7	1.4	8.1	1.8
11/03/2022 09:00	9.4	1.8	1.6	8.6	1.8
11/03/2022 10:00	9.4	1.8	1.6	8.7	1.8
11/03/2022 11:00	9.4	1.5	1.6	8.6	1.8
11/03/2022 12:00	9.5	1.5	1.6	8.7	1.9
11/03/2022 13:00	9.0	1.7	1.4	8.2	1.8
11/03/2022 14:00	9.4	1.8	1.6	8.6	1.8
11/03/2022 15:00	10.7	2.0	1.8	9.8	2.2
11/03/2022 16:00	14.5	5.1	2.1	11.5	2.5
11/03/2022 17:00	15.2	4.4	2.1	11.9	2.6
11/03/2022 18:00	15.2	4.0	2.2	11.9	2.6
11/03/2022 19:00	17.4	3.7	2.2	11.9	2.6
11/03/2022 20:00	15.2	3.7	2.1	11.9	2.6
11/03/2022 21:00	15.1	3.7	2.1	11.9	2.6
11/03/2022 22:00	17.3	3.7	2.1	11.9	2.6
11/03/2022 23:00	15.5	3.7	2.3	12.2	2.6
Average/Sum#:	325.3 #	79.2 #	47.2 #	260.3 #	56.4 #
Minimum:	8.8	1.5	1.4	8.1	1.8
Maximum:	17.4	5.1	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/04/2022 00:00	15.0	4.4	2.1	11.8	2.6
11/04/2022 01:00	14.9	4.4	2.1	11.7	2.6
11/04/2022 02:00	14.5	4.0	2.0	11.4	2.4
11/04/2022 03:00	14.5	4.4	2.1	11.4	2.4
11/04/2022 04:00	15.1	4.4	2.1	11.8	2.6
11/04/2022 05:00	15.8	3.7	2.3	12.4	2.7
11/04/2022 06:00	15.3	4.4	2.2	12.0	2.6
11/04/2022 07:00	14.4	4.4	2.0	11.4	2.4
11/04/2022 08:00	10.4	1.6	1.7	9.5	2.0
11/04/2022 09:00	9.4	1.8	1.6	8.6	1.8
11/04/2022 10:00	7.0	1.6	1.4	7.7	1.6
11/04/2022 11:00	6.6	1.8	1.3	7.3	1.6
11/04/2022 12:00	6.6	1.8	1.3	7.3	1.6
11/04/2022 13:00	6.6	1.6	1.3	7.3	1.6
11/04/2022 14:00	8.4	2.1	1.4	7.7	1.6
11/04/2022 15:00	9.8	2.7	1.6	9.0	2.0
11/04/2022 16:00	14.6	5.0	2.1	11.5	2.5
11/04/2022 17:00	15.0	4.3	2.1	11.7	2.6
11/04/2022 18:00	14.6	4.0	2.0	11.4	2.5
11/04/2022 19:00	14.5	4.0	2.0	11.4	2.5
11/04/2022 20:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 21:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 22:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 23:00	13.8	4.7	2.0	10.8	2.4
Average/Sum#:	300.3 #	83.1 #	44.7 #	249.0 #	53.8 #
Minimum:	6.6	1.6	1.3	7.3	1.6
Maximum:	15.8	5.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/05/2022 00:00	13.8	5.5	2.0	10.8	2.4
11/05/2022 01:00	13.8	5.1	2.0	10.8	2.4
11/05/2022 02:00	11.8	5.5	2.0	10.8	2.4
11/05/2022 03:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 04:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 05:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 06:00	13.6	5.8	1.9	10.6	2.4
11/05/2022 07:00	6.0	12.7	0.1	0.7	0.2
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	2.8	4.7	0.0	0.1	0.0
11/05/2022 14:00	89.6	76.2	0.5	1.8	0.4
11/05/2022 15:00	4.3	1.4	1.0	3.6	0.9
11/05/2022 16:00	5.1	3.3	1.2	4.3	1.0
11/05/2022 17:00	7.9	4.0	1.4	5.0	1.2
11/05/2022 18:00	7.9	4.3	1.4	4.9	1.2
11/05/2022 19:00	7.9	4.6	1.4	4.9	1.2
11/05/2022 20:00	7.9	5.0	1.4	4.9	1.2
11/05/2022 21:00	6.6	3.2	1.2	4.1	1.0
11/05/2022 22:00	4.2	1.9	1.0	3.5	0.8
11/05/2022 23:00	5.0	1.5	1.2	4.1	1.0
Average/Sum#:	249.6 #	162.1 #	25.7 #	117.3 #	26.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	89.6	76.2	2.0	10.8	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/06/2022 00:00	4.7	1.5	1.1	3.9	0.9
11/06/2022 01:00	4.4	1.6	1.0	3.7	0.9
11/06/2022 02:00	0.9	5.8	0.1	0.2	0.0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	15.5	40.9	0.0	0.3	0.1
11/06/2022 10:00	43.8	26.8	0.1	1.1	0.2
11/06/2022 11:00	43.9	72.4	0.2	2.5	0.5
11/06/2022 12:00	2.8	0.5	0.4	4.2	0.8
11/06/2022 13:00	4.6	0.6	0.5	4.6	0.9
11/06/2022 14:00	4.8	0.6	0.5	4.8	1.0
11/06/2022 15:00	7.8	1.3	0.6	5.9	1.2
11/06/2022 16:00	9.1	1.0	0.7	6.9	1.4
11/06/2022 17:00	9.2	0.7	0.7	6.9	1.4
11/06/2022 18:00	8.0	1.3	0.6	6.0	1.2
11/06/2022 19:00	7.9	1.7	0.6	5.9	1.2
11/06/2022 20:00	8.0	1.7	0.6	6.0	1.2
11/06/2022 21:00	9.8	12.4	0.5	4.9	1.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	185.2 #	170.8 #	8.2 #	67.8 #	13.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	43.9	72.4	1.1	6.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/07/2022 00:00	2.8	9.5	0.0	0.4	0.1
11/07/2022 01:00	40.5	77.0	0.3	3.0	0.6
11/07/2022 02:00	4.7	0.6	0.5	4.7	0.9
11/07/2022 03:00	24.6	45.7	0.6	5.2	1.1
11/07/2022 04:00	71.4	69.2	0.9	6.4	1.3
11/07/2022 05:00	13.7	2.5	1.7	9.4	2.0
11/07/2022 06:00	16.0	4.6	2.0	11.0	2.4
11/07/2022 07:00	15.6	4.3	2.2	12.2	2.6
11/07/2022 08:00	15.9	4.7	2.0	11.0	2.4
11/07/2022 09:00	13.8	5.0	2.0	10.8	2.4
11/07/2022 10:00	13.8	4.6	2.0	10.8	2.4
11/07/2022 11:00	13.8	4.0	2.0	10.8	2.4
11/07/2022 12:00	13.8	3.6	2.0	10.8	2.4
11/07/2022 13:00	13.8	4.0	2.0	10.8	2.4
11/07/2022 14:00	14.4	4.3	2.0	11.3	2.4
11/07/2022 15:00	15.4	4.0	2.2	12.1	2.6
11/07/2022 16:00	15.7	3.3	2.3	12.4	2.7
11/07/2022 17:00	18.3	2.6	2.3	12.6	2.8
11/07/2022 18:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 19:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 20:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 21:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 22:00	15.7	3.4	2.3	12.4	2.7
11/07/2022 23:00	17.3	3.7	2.2	11.9	2.6
Average/Sum#:	435.0 #	271.0 #	42.7 #	240.4 #	52.4 #
Minimum:	2.8	0.6	0.0	0.4	0.1
Maximum:	71.4	77.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/08/2022 00:00	17.3	4.0	2.2	11.9	2.6
11/08/2022 01:00	15.1	4.0	2.2	11.9	2.6
11/08/2022 02:00	14.7	3.7	2.1	11.5	2.6
11/08/2022 03:00	15.0	4.0	2.1	11.9	2.6
11/08/2022 04:00	15.3	3.7	2.2	12.1	2.6
11/08/2022 05:00	17.7	3.3	2.2	12.2	2.6
11/08/2022 06:00	16.0	2.6	2.3	12.6	2.8
11/08/2022 07:00	15.5	3.3	2.2	12.1	2.6
11/08/2022 08:00	15.4	3.3	2.2	12.1	2.6
11/08/2022 09:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 10:00	17.4	3.7	2.2	12.0	2.6
11/08/2022 11:00	16.2	3.7	2.0	11.1	2.4
11/08/2022 12:00	13.8	4.1	2.0	10.9	2.4
11/08/2022 13:00	13.8	4.1	2.0	10.9	2.4
11/08/2022 14:00	16.4	4.4	2.0	11.3	2.4
11/08/2022 15:00	16.4	4.1	2.0	11.3	2.4
11/08/2022 16:00	15.5	3.7	2.2	12.2	2.6
11/08/2022 17:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 18:00	15.2	4.0	2.2	11.9	2.6
11/08/2022 19:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 20:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 21:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 22:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 23:00	17.1	4.0	2.1	11.7	2.6
Average/Sum#:	375.9 #	87.8 #	51.6 #	284.2 #	61.6 #
Minimum:	13.8	2.6	2.0	10.9	2.4
Maximum:	17.7	4.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/09/2022 00:00	15.0	4.0	2.1	11.9	2.6
11/09/2022 01:00	15.0	4.0	2.1	11.9	2.6
11/09/2022 02:00	17.5	3.7	2.2	12.1	2.6
11/09/2022 03:00	15.4	3.7	2.2	12.1	2.6
11/09/2022 04:00	15.1	4.0	2.1	11.9	2.6
11/09/2022 05:00	18.0	3.3	2.3	12.4	2.7
11/09/2022 06:00	16.1	3.0	2.3	12.6	2.8
11/09/2022 07:00	17.5	3.4	2.2	12.1	2.6
11/09/2022 08:00	17.3	3.4	2.1	11.9	2.6
11/09/2022 09:00	12.2	1.9	1.7	9.6	2.1
11/09/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/09/2022 11:00	9.8	1.2	1.6	9.0	2.0
11/09/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/09/2022 13:00	9.8	1.2	1.6	9.0	2.0
11/09/2022 14:00	10.2	1.3	1.7	9.3	2.0
11/09/2022 15:00	9.8	1.5	1.7	9.0	2.0
11/09/2022 16:00	14.5	4.8	2.1	11.5	2.5
11/09/2022 17:00	15.1	4.0	2.1	11.9	2.6
11/09/2022 18:00	14.1	4.1	2.0	11.0	2.4
11/09/2022 19:00	13.8	4.8	2.0	10.8	2.4
11/09/2022 20:00	13.8	4.8	2.0	10.8	2.4
11/09/2022 21:00	14.0	4.8	2.0	11.0	2.4
11/09/2022 22:00	13.9	4.8	2.0	10.9	2.4
11/09/2022 23:00	13.9	4.8	2.0	10.9	2.4
Average/Sum#:	332.3 #	79.1 #	47.5 #	262.4 #	57.3 #
Minimum:	9.8	1.2	1.6	9.0	2.0
Maximum:	18.0	4.8	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/10/2022 00:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 01:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 02:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 03:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 04:00	16.6	4.4	2.1	11.5	2.5
11/10/2022 05:00	17.4	3.7	2.2	11.9	2.6
11/10/2022 06:00	16.1	3.4	2.3	12.6	2.8
11/10/2022 07:00	14.8	4.1	2.1	11.7	2.6
11/10/2022 08:00	13.8	4.8	2.0	10.9	2.4
11/10/2022 09:00	13.7	4.7	2.0	10.8	2.4
11/10/2022 10:00	10.4	1.3	1.7	9.5	2.0
11/10/2022 11:00	12.0	1.3	1.7	9.4	2.0
11/10/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/10/2022 13:00	9.4	1.2	1.6	8.6	1.8
11/10/2022 14:00	10.3	1.3	1.7	9.4	2.0
11/10/2022 15:00	10.3	1.6	1.7	9.4	2.0
11/10/2022 16:00	15.0	5.1	2.1	11.7	2.6
11/10/2022 17:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 18:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 19:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 20:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 21:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 22:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 23:00	15.8	2.6	2.3	12.4	2.8
Average/Sum#:	336.8 #	75.6 #	49.0 #	267.8 #	58.9 #
Minimum:	9.4	1.2	1.6	8.6	1.8
Maximum:	17.4	5.1	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/11/2022 00:00	15.9	2.7	2.3	12.5	2.8
11/11/2022 01:00	15.9	2.7	2.3	12.5	2.8
11/11/2022 02:00	15.0	3.4	2.1	11.9	2.6
11/11/2022 03:00	15.0	3.4	2.1	11.9	2.6
11/11/2022 04:00	15.9	3.0	2.3	12.5	2.8
11/11/2022 05:00	16.0	3.0	2.3	12.6	2.8
11/11/2022 06:00	16.1	2.8	2.3	12.6	2.8
11/11/2022 07:00	14.8	3.8	2.1	11.7	2.6
11/11/2022 08:00	11.7	4.7	2.0	10.8	2.4
11/11/2022 09:00	10.3	1.3	1.7	9.4	2.0
11/11/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/11/2022 11:00	10.2	1.3	1.7	9.3	2.0
11/11/2022 12:00	10.2	1.3	1.7	9.3	2.0
11/11/2022 13:00	10.2	1.6	1.7	9.4	2.0
11/11/2022 14:00	9.4	1.5	1.6	8.7	1.8
11/11/2022 15:00	10.2	1.6	1.7	9.3	2.0
11/11/2022 16:00	15.8	4.3	2.0	10.9	2.4
11/11/2022 17:00	15.9	2.6	2.3	12.5	2.8
11/11/2022 18:00	15.9	2.6	2.3	12.5	2.8
11/11/2022 19:00	15.8	2.6	2.3	12.4	2.8
11/11/2022 20:00	15.8	2.6	2.3	12.4	2.8
11/11/2022 21:00	15.7	2.6	2.3	12.4	2.7
11/11/2022 22:00	15.7	3.0	2.3	12.3	2.6
11/11/2022 23:00	15.8	3.0	2.3	12.5	2.8
Average/Sum#:	333.5 #	62.7 #	49.7 #	271.7 #	59.7 #
Minimum:	9.4	1.3	1.6	8.7	1.8
Maximum:	16.1	4.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/12/2022 00:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 01:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 02:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 03:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 04:00	16.0	3.0	2.3	12.6	2.8
11/12/2022 05:00	16.0	3.0	2.3	12.6	2.8
11/12/2022 06:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 07:00	14.8	3.7	2.1	11.6	2.6
11/12/2022 08:00	15.4	3.4	2.2	12.1	2.6
11/12/2022 09:00	10.5	1.6	1.7	9.6	2.1
11/12/2022 10:00	9.6	1.2	1.6	8.8	2.0
11/12/2022 11:00	9.4	1.2	1.6	8.6	1.8
11/12/2022 12:00	9.4	1.2	1.6	8.6	1.8
11/12/2022 13:00	9.4	1.2	1.6	8.7	1.8
11/12/2022 14:00	9.3	1.2	1.6	8.5	1.8
11/12/2022 15:00	10.8	1.7	1.8	9.9	2.2
11/12/2022 16:00	14.9	5.0	2.1	11.7	2.6
11/12/2022 17:00	15.9	2.6	2.3	12.4	2.7
11/12/2022 18:00	15.9	2.6	2.3	12.4	2.7
11/12/2022 19:00	15.9	2.6	2.3	12.5	2.8
11/12/2022 20:00	15.9	2.6	2.3	12.6	2.8
11/12/2022 21:00	15.9	2.6	2.3	12.6	2.8
11/12/2022 22:00	17.6	3.0	2.2	12.1	2.6
11/12/2022 23:00	15.4	3.0	2.2	12.1	2.6
Average/Sum#:	337.5 #	61.4 #	49.9 #	272.5 #	59.9 #
Minimum:	9.3	1.2	1.6	8.5	1.8
Maximum:	17.6	5.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/13/2022 00:00	15.2	3.4	2.2	12.0	2.6
11/13/2022 01:00	17.4	3.4	2.2	11.9	2.6
11/13/2022 02:00	15.2	3.4	2.1	11.9	2.6
11/13/2022 03:00	15.4	3.0	2.2	12.1	2.6
11/13/2022 04:00	17.6	3.0	2.2	12.1	2.6
11/13/2022 05:00	15.3	3.4	2.2	12.1	2.6
11/13/2022 06:00	17.6	3.0	2.2	12.1	2.6
11/13/2022 07:00	15.8	2.7	2.3	12.4	2.7
11/13/2022 08:00	13.8	2.3	2.0	10.8	2.4
11/13/2022 09:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 10:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 11:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 13:00	10.2	1.7	1.7	9.4	2.0
11/13/2022 14:00	10.1	1.6	1.7	9.2	2.0
11/13/2022 15:00	10.7	1.7	1.8	9.8	2.2
11/13/2022 16:00	17.1	3.7	2.1	11.7	2.6
11/13/2022 17:00	15.9	2.3	2.3	12.5	2.8
11/13/2022 18:00	15.9	2.3	2.3	12.5	2.8
11/13/2022 19:00	15.9	2.3	2.3	12.6	2.8
11/13/2022 20:00	16.0	2.3	2.3	12.6	2.8
11/13/2022 21:00	16.1	2.3	2.3	12.6	2.8
11/13/2022 22:00	16.1	2.3	2.3	12.6	2.8
11/13/2022 23:00	16.1	2.3	2.3	12.6	2.8
Average/Sum#:	344.2 #	57.6 #	49.8 #	273.1 #	59.7 #
Minimum:	10.1	1.3	1.7	9.2	2.0
Maximum:	17.6	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/14/2022 00:00	16.1	2.4	2.3	12.6	2.8
11/14/2022 01:00	16.0	2.7	2.3	12.6	2.8
11/14/2022 02:00	15.9	3.1	2.3	12.6	2.8
11/14/2022 03:00	15.1	3.8	2.2	11.9	2.6
11/14/2022 04:00	17.9	3.5	2.3	12.3	2.6
11/14/2022 05:00	16.1	3.1	2.3	12.6	2.8
11/14/2022 06:00	16.1	3.1	2.3	12.6	2.8
11/14/2022 07:00	15.4	3.8	2.2	12.1	2.6
11/14/2022 08:00	15.0	3.8	2.1	11.9	2.6
11/14/2022 09:00	15.1	3.7	2.2	11.9	2.6
11/14/2022 10:00	15.0	3.7	2.1	11.9	2.6
11/14/2022 11:00	14.9	3.4	2.1	11.7	2.6
11/14/2022 12:00	14.8	3.4	2.1	11.7	2.6
11/14/2022 13:00	15.0	3.1	2.1	11.8	2.6
11/14/2022 14:00	15.0	3.1	2.1	11.8	2.6
11/14/2022 15:00	14.5	3.4	2.0	11.4	2.4
11/14/2022 16:00	15.7	2.7	2.3	12.4	2.7
11/14/2022 17:00	15.3	3.0	2.2	12.0	2.6
11/14/2022 18:00	15.2	3.1	2.2	11.9	2.6
11/14/2022 19:00	15.8	2.7	2.3	12.4	2.7
11/14/2022 20:00	15.8	2.7	2.3	12.4	2.7
11/14/2022 21:00	16.0	2.3	2.3	12.5	2.8
11/14/2022 22:00	16.0	2.3	2.3	12.5	2.8
11/14/2022 23:00	15.8	2.3	2.3	12.4	2.7
Average/Sum#:	373.5 #	74.2 #	53.2 #	291.9 #	64.0 #
Minimum:	14.5	2.3	2.0	11.4	2.4
Maximum:	17.9	3.8	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/15/2022 00:00	16.0	2.3	2.3	12.6	2.8
11/15/2022 01:00	16.0	2.3	2.3	12.6	2.8
11/15/2022 02:00	16.1	2.3	2.3	12.6	2.8
11/15/2022 03:00	16.0	2.3	2.3	12.5	2.8
11/15/2022 04:00	16.0	2.3	2.3	12.5	2.8
11/15/2022 05:00	16.0	2.7	2.3	12.5	2.7
11/15/2022 06:00	15.5	3.0	2.2	12.1	2.6
11/15/2022 07:00	15.7	2.7	2.3	12.3	2.7
11/15/2022 08:00	15.2	2.7	2.2	12.0	2.6
11/15/2022 09:00	14.7	3.1	2.1	11.6	2.6
11/15/2022 10:00	15.0	3.7	2.1	11.7	2.6
11/15/2022 11:00	14.3	4.0	2.0	11.3	2.4
11/15/2022 12:00	13.8	5.8	2.0	10.8	2.4
11/15/2022 13:00	13.8	5.8	2.0	10.8	2.4
11/15/2022 14:00	7.9	1.4	2.0	10.8	2.4
11/15/2022 15:00	8.1	1.4	2.0	11.1	2.4
11/15/2022 16:00	15.0	4.0	2.1	11.7	2.6
11/15/2022 17:00	17.2	4.0	2.2	11.8	2.6
11/15/2022 18:00	17.3	3.6	2.2	11.9	2.6
11/15/2022 19:00	15.2	3.3	2.2	11.9	2.6
11/15/2022 20:00	15.3	3.3	2.2	12.0	2.6
11/15/2022 21:00	15.7	2.6	2.3	12.3	2.6
11/15/2022 22:00	17.3	3.3	2.2	11.9	2.6
11/15/2022 23:00	17.3	3.3	2.2	11.9	2.6
Average/Sum#:	344.4 #	72.4 #	52.3 #	285.2 #	62.6 #
Minimum:	13.8	2.3	2.0	10.8	2.4
Maximum:	17.3	5.8	2.3	12.6	2.8
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/16/2022 00:00	17.3	3.3	2.2	11.9	2.6
11/16/2022 01:00	14.9	3.4	2.1	11.7	2.6
11/16/2022 02:00	17.3	3.4	2.1	11.8	2.6
11/16/2022 03:00	17.3	3.4	2.2	11.9	2.6
11/16/2022 04:00	15.5	3.4	2.3	12.2	2.7
11/16/2022 05:00	15.7	3.0	2.3	12.4	2.7
11/16/2022 06:00	15.7	2.7	2.3	12.4	2.7
11/16/2022 07:00	15.8	2.6	2.3	12.3	2.7
11/16/2022 08:00	9.9	4.4	2.0	10.9	2.4
11/16/2022 09:00	8.1	5.3	2.0	11.1	2.4
11/16/2022 10:00	13.8	5.4	2.0	10.9	2.4
11/16/2022 11:00	5.9	4.1	2.0	10.9	2.4
11/16/2022 12:00	13.9	4.0	2.0	10.9	2.4
11/16/2022 13:00	11.9	4.0	2.0	11.0	2.4
11/16/2022 14:00	13.9	4.0	2.0	11.0	2.4
11/16/2022 15:00	14.8	3.3	2.1	11.6	2.6
11/16/2022 16:00	15.2	2.7	2.2	11.9	2.6
11/16/2022 17:00	17.5	2.7	2.2	12.0	2.6
11/16/2022 18:00	15.8	2.3	2.3	12.4	2.7
11/16/2022 19:00	15.8	2.3	2.3	12.5	2.7
11/16/2022 20:00	15.8	2.3	2.3	12.5	2.7
11/16/2022 21:00	15.8	2.7	2.3	12.4	2.7
11/16/2022 22:00	15.5	2.7	2.3	12.2	2.6
11/16/2022 23:00	15.7	2.7	2.3	12.4	2.7
Average/Sum#:	342.9 #	76.0 #	52.1 #	283.2 #	61.9 #
Minimum:	8.1	2.3	2.0	10.9	2.4
Maximum:	17.5	5.4	2.3	12.5	2.7
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/17/2022 00:00	15.2	2.7	2.2	11.9	2.6
11/17/2022 01:00	17.3	2.7	2.2	11.9	2.6
11/17/2022 02:00	15.1	2.7	2.1	11.9	2.6
11/17/2022 03:00	15.1	2.7	2.1	11.9	2.6
11/17/2022 04:00	15.4	2.7	2.3	12.1	2.6
11/17/2022 05:00	13.6	2.3	2.3	12.4	2.7
11/17/2022 06:00	16.0	2.3	2.3	12.6	2.8
11/17/2022 07:00	17.4	2.7	2.2	11.9	2.6
11/17/2022 08:00	13.9	3.4	2.0	11.0	2.4
11/17/2022 09:00	17.1	2.7	2.1	11.8	2.6
11/17/2022 10:00	14.9	2.7	2.1	11.7	2.6
11/17/2022 11:00	15.1	2.6	2.2	11.8	2.6
11/17/2022 12:00	15.3	2.3	2.2	12.0	2.6
11/17/2022 13:00	15.2	2.3	2.2	12.0	2.6
11/17/2022 14:00	16.1	2.3	2.0	11.0	2.4
11/17/2022 15:00	14.9	2.3	2.1	11.7	2.6
11/17/2022 16:00	15.7	2.3	2.3	12.3	2.6
11/17/2022 17:00	15.9	2.0	2.3	12.5	2.8
11/17/2022 18:00	15.9	2.0	2.3	12.4	2.8
11/17/2022 19:00	15.9	2.0	2.3	12.4	2.8
11/17/2022 20:00	15.9	2.3	2.3	12.5	2.8
11/17/2022 21:00	15.9	2.0	2.3	12.5	2.8
11/17/2022 22:00	15.8	2.3	2.3	12.4	2.7
11/17/2022 23:00	15.5	2.7	2.2	12.2	2.6
Average/Sum#:	374.1 #	59.0 #	52.9 #	288.8 #	63.4 #
Minimum:	13.6	2.0	2.0	11.0	2.4
Maximum:	17.4	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/18/2022 00:00	15.2	2.7	2.2	11.9	2.6
11/18/2022 01:00	17.5	2.7	2.2	12.0	2.6
11/18/2022 02:00	15.3	2.6	2.2	12.0	2.6
11/18/2022 03:00	17.5	2.7	2.2	12.0	2.6
11/18/2022 04:00	15.6	2.0	2.3	12.4	2.7
11/18/2022 05:00	15.7	2.0	2.3	12.3	2.7
11/18/2022 06:00	15.6	2.0	2.2	12.3	2.7
11/18/2022 07:00	15.8	2.3	2.3	12.5	2.8
11/18/2022 08:00	17.3	2.6	2.2	11.9	2.6
11/18/2022 09:00	17.3	2.6	2.2	12.0	2.6
11/18/2022 10:00	15.3	2.3	2.2	12.0	2.6
11/18/2022 11:00	14.8	2.3	2.1	11.7	2.6
11/18/2022 12:00	15.7	2.7	2.0	10.8	2.4
11/18/2022 13:00	15.7	2.7	2.0	10.8	2.4
11/18/2022 14:00	13.8	2.6	2.0	10.8	2.4
11/18/2022 15:00	14.3	2.6	2.0	11.3	2.4
11/18/2022 16:00	15.6	2.3	2.3	12.3	2.6
11/18/2022 17:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 18:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 19:00	15.8	2.3	2.3	12.4	2.7
11/18/2022 20:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 21:00	15.7	2.0	2.3	12.3	2.7
11/18/2022 22:00	13.4	2.0	2.2	12.3	2.7
11/18/2022 23:00	15.9	2.0	2.3	12.5	2.7
Average/Sum#:	375.9 #	56.9 #	52.9 #	287.7 #	62.8 #
Minimum:	13.4	2.0	2.0	10.8	2.4
Maximum:	17.5	2.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/19/2022 00:00	15.3	2.7	2.2	12.0	2.6
11/19/2022 01:00	15.1	2.7	2.2	11.9	2.6
11/19/2022 02:00	15.1	2.7	2.2	11.8	2.6
11/19/2022 03:00	15.0	2.7	2.1	11.7	2.6
11/19/2022 04:00	15.7	2.7	2.3	12.3	2.6
11/19/2022 05:00	15.9	2.3	2.3	12.4	2.8
11/19/2022 06:00	17.7	2.7	2.2	12.2	2.6
11/19/2022 07:00	14.9	2.7	2.1	11.7	2.6
11/19/2022 08:00	11.8	3.7	2.0	10.8	2.4
11/19/2022 09:00	13.8	3.7	2.0	10.8	2.4
11/19/2022 10:00	13.8	3.7	2.0	10.8	2.4
11/19/2022 11:00	15.7	3.6	2.0	10.8	2.4
11/19/2022 12:00	13.8	3.3	2.0	10.8	2.4
11/19/2022 13:00	15.7	3.0	2.0	10.8	2.4
11/19/2022 14:00	15.7	3.0	2.0	10.8	2.4
11/19/2022 15:00	14.3	2.6	2.0	11.3	2.4
11/19/2022 16:00	15.2	2.3	2.2	12.0	2.6
11/19/2022 17:00	15.3	2.3	2.2	12.0	2.6
11/19/2022 18:00	15.3	2.3	2.2	12.0	2.6
11/19/2022 19:00	15.8	2.0	2.3	12.5	2.8
11/19/2022 20:00	15.8	2.0	2.3	12.5	2.7
11/19/2022 21:00	15.6	2.0	2.3	12.3	2.7
11/19/2022 22:00	13.5	2.4	2.3	12.4	2.7
11/19/2022 23:00	15.8	2.3	2.3	12.3	2.7
Average/Sum#:	361.6 #	65.4 #	51.7 #	280.9 #	61.6 #
Minimum:	11.8	2.0	2.0	10.8	2.4
Maximum:	17.7	3.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/20/2022 00:00	13.1	2.7	2.2	11.9	2.7
11/20/2022 01:00	13.0	2.3	2.2	11.9	2.6
11/20/2022 02:00	13.1	2.3	2.2	12.0	2.6
11/20/2022 03:00	13.3	2.4	2.2	12.0	2.6
11/20/2022 04:00	11.0	2.4	2.2	12.0	2.6
11/20/2022 05:00	16.0	2.4	2.3	12.5	2.7
11/20/2022 06:00	15.9	2.7	2.3	12.4	2.8
11/20/2022 07:00	14.8	2.7	2.1	11.5	2.6
11/20/2022 08:00	10.3	1.0	1.7	9.4	2.0
11/20/2022 09:00	8.6	1.0	1.7	9.4	2.0
11/20/2022 10:00	9.4	0.9	1.6	8.6	1.8
11/20/2022 11:00	7.8	0.9	1.6	8.6	1.8
11/20/2022 12:00	7.7	0.9	1.6	8.5	1.8
11/20/2022 13:00	7.6	0.9	1.6	8.4	1.8
11/20/2022 14:00	10.2	0.9	1.7	9.3	2.0
11/20/2022 15:00	10.3	1.0	1.7	9.5	2.0
11/20/2022 16:00	15.0	2.6	2.1	11.9	2.6
11/20/2022 17:00	15.9	2.3	2.3	12.5	2.8
11/20/2022 18:00	15.9	2.3	2.3	12.4	2.8
11/20/2022 19:00	15.8	2.3	2.3	12.4	2.8
11/20/2022 20:00	15.8	2.3	2.3	12.4	2.8
11/20/2022 21:00	15.4	2.3	2.2	12.1	2.6
11/20/2022 22:00	15.2	2.7	2.2	11.9	2.6
11/20/2022 23:00	15.0	3.0	2.1	11.9	2.6
Average/Sum#:	306.1 #	47.2 #	48.7 #	265.4 #	58.0 #
Minimum:	7.6	0.9	1.6	8.4	1.8
Maximum:	16.0	3.0	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/21/2022 00:00	15.1	2.7	2.1	11.9	2.6
11/21/2022 01:00	15.0	2.7	2.1	11.7	2.6
11/21/2022 02:00	16.4	3.4	2.0	11.3	2.4
11/21/2022 03:00	17.4	3.0	2.2	11.9	2.6
11/21/2022 04:00	15.8	2.7	2.3	12.4	2.8
11/21/2022 05:00	18.2	2.7	2.3	12.5	2.8
11/21/2022 06:00	16.0	2.7	2.3	12.6	2.8
11/21/2022 07:00	15.0	3.0	2.1	11.9	2.6
11/21/2022 08:00	11.8	4.0	2.0	10.8	2.4
11/21/2022 09:00	11.8	4.4	2.0	10.8	2.4
11/21/2022 10:00	11.8	4.0	2.0	10.8	2.4
11/21/2022 11:00	15.7	3.3	2.0	10.8	2.4
11/21/2022 12:00	15.8	3.0	2.0	10.8	2.4
11/21/2022 13:00	13.8	2.6	2.0	10.8	2.4
11/21/2022 14:00	15.1	2.6	2.1	11.9	2.6
11/21/2022 15:00	15.8	2.0	2.3	12.5	2.8
11/21/2022 16:00	15.6	2.6	2.3	12.3	2.6
11/21/2022 17:00	15.8	2.3	2.3	12.4	2.7
11/21/2022 18:00	15.8	2.3	2.3	12.5	2.7
11/21/2022 19:00	15.9	2.3	2.3	12.4	2.8
11/21/2022 20:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 21:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 22:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 23:00	15.6	2.3	2.3	12.3	2.6
Average/Sum#:	366.9 #	67.5 #	52.2 #	284.8 #	62.8 #
Minimum:	11.8	2.0	2.0	10.8	2.4
Maximum:	18.2	4.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/22/2022 00:00	15.0	2.7	2.1	11.9	2.6
11/22/2022 01:00	14.9	3.0	2.1	11.7	2.6
11/22/2022 02:00	14.7	3.0	2.1	11.5	2.6
11/22/2022 03:00	11.8	3.3	2.0	10.8	2.4
11/22/2022 04:00	13.9	3.7	2.0	10.9	2.4
11/22/2022 05:00	12.4	3.3	2.0	11.4	2.4
11/22/2022 06:00	15.0	3.0	2.1	11.9	2.6
11/22/2022 07:00	12.6	3.4	2.1	11.5	2.6
11/22/2022 08:00	16.4	3.7	2.0	11.3	2.4
11/22/2022 09:00	10.7	15.0	1.4	8.0	1.7
11/22/2022 10:00	3.3	0.0	0.5	5.0	1.0
11/22/2022 11:00	3.6	0.1	0.5	5.4	1.1
11/22/2022 12:00	44.0	83.5	1.0	6.6	1.4
11/22/2022 13:00	8.1	1.2	1.6	9.0	2.0
11/22/2022 14:00	9.0	1.0	1.8	9.8	2.2
11/22/2022 15:00	10.8	1.0	1.8	9.8	2.2
11/22/2022 16:00	13.4	2.3	1.9	10.5	2.3
11/22/2022 17:00	17.4	3.0	2.2	12.0	2.6
11/22/2022 18:00	14.3	3.0	2.0	11.3	2.4
11/22/2022 19:00	15.9	3.3	2.0	11.0	2.4
11/22/2022 20:00	17.2	3.0	2.1	11.8	2.6
11/22/2022 21:00	16.2	3.3	2.0	11.1	2.4
11/22/2022 22:00	14.3	3.3	2.0	11.2	2.4
11/22/2022 23:00	11.8	4.0	2.0	10.8	2.4
Average/Sum#:	336.7 #	156.1 #	43.3 #	246.2 #	53.7 #
Minimum:	3.3	0.0	0.5	5.0	1.0
Maximum:	44.0	83.5	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/23/2022 00:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 01:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 02:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 03:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 04:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 05:00	16.5	2.9	2.0	11.3	2.4
11/23/2022 06:00	14.3	3.3	2.0	11.3	2.4
11/23/2022 07:00	14.7	3.0	2.1	11.6	2.6
11/23/2022 08:00	16.0	3.3	2.0	11.0	2.4
11/23/2022 09:00	8.5	1.0	1.7	9.4	2.0
11/23/2022 10:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 11:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 12:00	5.7	0.8	1.4	7.9	1.8
11/23/2022 13:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 14:00	8.2	0.9	1.6	9.0	2.0
11/23/2022 15:00	9.9	0.9	1.7	9.0	2.0
11/23/2022 16:00	14.7	3.6	2.1	11.5	2.6
11/23/2022 17:00	17.3	3.0	2.2	12.0	2.6
11/23/2022 18:00	14.6	3.3	2.1	11.5	2.5
11/23/2022 19:00	14.4	4.0	2.0	11.3	2.4
11/23/2022 20:00	17.3	3.0	2.2	11.9	2.6
11/23/2022 21:00	15.3	3.0	2.2	12.0	2.6
11/23/2022 22:00	17.3	3.0	2.2	11.9	2.6
11/23/2022 23:00	15.1	3.0	2.2	11.9	2.6
Average/Sum#:	302.2 #	64.7 #	46.5 #	254.3 #	55.5 #
Minimum:	5.7	0.8	1.4	7.9	1.8
Maximum:	17.3	4.0	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/24/2022 00:00	13.9	4.3	2.0	10.9	2.4
11/24/2022 01:00	13.8	5.4	2.0	10.8	2.4
11/24/2022 02:00	11.8	5.4	2.0	10.8	2.4
11/24/2022 03:00	16.0	3.3	2.0	11.0	2.4
11/24/2022 04:00	14.0	3.3	2.0	11.1	2.4
11/24/2022 05:00	14.5	2.9	2.0	11.4	2.5
11/24/2022 06:00	15.3	2.6	2.2	12.0	2.6
11/24/2022 07:00	14.6	2.6	2.1	11.5	2.5
11/24/2022 08:00	8.5	1.0	1.7	9.4	2.0
11/24/2022 09:00	8.5	1.0	1.7	9.4	2.0
11/24/2022 10:00	10.3	1.0	1.7	9.4	2.0
11/24/2022 11:00	7.8	0.9	1.6	8.5	1.8
11/24/2022 12:00	5.4	0.8	1.3	7.4	1.6
11/24/2022 13:00	5.4	0.8	1.3	7.4	1.6
11/24/2022 14:00	7.8	0.9	1.6	8.6	1.8
11/24/2022 15:00	7.3	0.8	1.4	7.9	1.8
11/24/2022 16:00	10.6	1.0	1.7	9.7	2.2
11/24/2022 17:00	10.6	1.0	1.7	9.7	2.2
11/24/2022 18:00	8.7	1.0	1.7	9.6	2.0
11/24/2022 19:00	10.4	1.0	1.7	9.5	2.0
11/24/2022 20:00	8.7	1.3	1.7	9.6	2.0
11/24/2022 21:00	8.7	1.3	1.7	9.6	2.0
11/24/2022 22:00	10.5	1.3	1.7	9.6	2.1
11/24/2022 23:00	10.5	1.3	1.7	9.6	2.1
Average/Sum#:	253.6 #	46.2 #	42.2 #	234.4 #	50.8 #
Minimum:	5.4	0.8	1.3	7.4	1.6
Maximum:	16.0	5.4	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/25/2022 00:00	8.8	1.3	1.7	9.6	2.1
11/25/2022 01:00	10.5	1.3	1.7	9.6	2.1
11/25/2022 02:00	8.8	1.3	1.7	9.6	2.1
11/25/2022 03:00	10.6	1.3	1.7	9.7	2.2
11/25/2022 04:00	10.6	1.0	1.7	9.7	2.2
11/25/2022 05:00	8.8	1.3	1.7	9.7	2.2
11/25/2022 06:00	10.6	1.3	1.7	9.7	2.2
11/25/2022 07:00	8.8	1.3	1.7	9.7	2.2
11/25/2022 08:00	9.4	2.7	1.9	10.3	2.2
11/25/2022 09:00	11.6	2.9	1.9	10.6	2.4
11/25/2022 10:00	8.3	0.9	1.7	9.2	2.0
11/25/2022 11:00	7.7	1.2	1.6	8.5	1.8
11/25/2022 12:00	7.8	0.9	1.6	8.6	1.8
11/25/2022 13:00	7.7	0.9	1.6	8.5	1.8
11/25/2022 14:00	7.6	1.1	1.6	8.4	1.8
11/25/2022 15:00	8.2	1.2	1.7	9.0	2.0
11/25/2022 16:00	16.7	3.6	2.1	11.5	2.5
11/25/2022 17:00	14.8	3.0	2.1	11.5	2.6
11/25/2022 18:00	15.8	3.3	2.0	10.8	2.4
11/25/2022 19:00	13.7	3.6	2.0	10.8	2.4
11/25/2022 20:00	11.8	3.6	2.0	10.8	2.4
11/25/2022 21:00	11.8	4.0	2.0	10.8	2.4
11/25/2022 22:00	14.9	3.0	2.1	11.7	2.6
11/25/2022 23:00	14.6	3.0	2.1	11.5	2.5
Average/Sum#:	259.9 #	49.0 #	43.6 #	239.8 #	52.9 #
Minimum:	7.6	0.9	1.6	8.4	1.8
Maximum:	16.7	4.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/26/2022 00:00	16.2	3.3	2.0	11.1	2.4
11/26/2022 01:00	14.5	3.3	2.0	11.4	2.4
11/26/2022 02:00	20.5	26.2	1.6	8.6	1.8
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	51.2 #	32.8 #	5.6 #	31.1 #	6.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	20.5	26.2	2.0	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	47.2	56.5	0.1	0.7	0.1
11/27/2022 22:00	34.9	21.0	0.1	1.2	0.2
11/27/2022 23:00	46.9	68.1	0.3	2.7	0.5
Average/Sum#:	129.0 #	145.6 #	0.5 #	4.6 #	0.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	47.2	68.1	0.3	2.7	0.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/28/2022 00:00	1.6	0.0	0.5	4.7	0.9
11/28/2022 01:00	3.0	0.0	0.4	4.5	0.9
11/28/2022 02:00	67.0	67.6	0.7	6.1	1.2
11/28/2022 03:00	43.9	61.6	1.2	7.0	1.5
11/28/2022 04:00	10.3	1.3	1.7	9.4	2.0
11/28/2022 05:00	9.9	1.5	1.7	9.0	2.0
11/28/2022 06:00	15.2	3.7	2.2	11.9	2.6
11/28/2022 07:00	15.9	3.0	2.3	12.5	2.8
11/28/2022 08:00	13.8	3.3	2.0	10.8	2.4
11/28/2022 09:00	9.7	1.2	1.6	8.8	2.0
11/28/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/28/2022 11:00	7.6	1.1	1.6	8.4	1.8
11/28/2022 12:00	7.8	0.9	1.6	8.6	1.8
11/28/2022 13:00	9.9	0.9	1.7	9.0	2.0
11/28/2022 14:00	8.1	0.9	1.6	9.0	2.0
11/28/2022 15:00	9.7	1.2	1.6	9.0	2.0
11/28/2022 16:00	12.2	3.3	2.0	11.2	2.4
11/28/2022 17:00	14.7	3.0	2.1	11.5	2.6
11/28/2022 18:00	15.9	3.0	2.0	11.0	2.4
11/28/2022 19:00	11.8	3.6	2.0	10.8	2.4
11/28/2022 20:00	14.6	3.4	2.1	11.5	2.5
11/28/2022 21:00	15.6	2.7	2.2	12.2	2.6
11/28/2022 22:00	14.7	3.0	2.1	11.5	2.6
11/28/2022 23:00	13.9	3.4	2.0	11.0	2.4
Average/Sum#:	357.1 #	174.9 #	40.6 #	228.8 #	49.8 #
Minimum:	1.6	0.0	0.4	4.5	0.9
Maximum:	67.0	67.6	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/29/2022 00:00	15.1	3.0	2.1	11.9	2.6
11/29/2022 01:00	17.6	3.0	2.2	12.1	2.6
11/29/2022 02:00	17.5	3.0	2.2	12.0	2.6
11/29/2022 03:00	14.7	3.4	2.1	11.5	2.6
11/29/2022 04:00	15.0	3.0	2.1	11.9	2.6
11/29/2022 05:00	15.4	3.0	2.2	12.1	2.6
11/29/2022 06:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 07:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 08:00	15.8	2.6	2.3	12.4	2.7
11/29/2022 09:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 10:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 11:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 12:00	15.0	2.6	2.1	11.8	2.6
11/29/2022 13:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 14:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 15:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 16:00	15.9	2.3	2.3	12.4	2.8
11/29/2022 17:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 18:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 19:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 20:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 21:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 22:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 23:00	16.0	2.7	2.3	12.6	2.8
Average/Sum#:	389.2 #	64.6 #	53.2 #	292.6 #	64.5 #
Minimum:	14.7	2.3	2.1	11.5	2.6
Maximum:	17.6	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/30/2022 00:00	15.2	3.1	2.2	11.9	2.6
11/30/2022 01:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 02:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 03:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 04:00	17.4	3.1	2.2	11.9	2.6
11/30/2022 05:00	17.4	3.4	2.2	11.9	2.6
11/30/2022 06:00	13.6	3.1	2.3	12.4	2.8
11/30/2022 07:00	15.0	3.0	2.1	11.9	2.6
11/30/2022 08:00	11.9	4.7	2.0	11.0	2.4
11/30/2022 09:00	14.0	4.7	2.0	11.0	2.4
11/30/2022 10:00	11.8	4.4	2.0	10.8	2.4
11/30/2022 11:00	11.9	4.3	2.0	10.9	2.4
11/30/2022 12:00	15.8	4.3	2.0	10.9	2.4
11/30/2022 13:00	15.8	3.6	2.0	10.8	2.4
11/30/2022 14:00	16.9	2.9	2.1	11.7	2.6
11/30/2022 15:00	17.1	2.9	2.1	11.7	2.6
11/30/2022 16:00	15.7	2.6	2.3	12.3	2.7
11/30/2022 17:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 18:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 19:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 20:00	16.0	2.3	2.3	12.5	2.8
11/30/2022 21:00	15.7	2.6	2.3	12.4	2.7
11/30/2022 22:00	14.7	3.0	2.1	11.5	2.6
11/30/2022 23:00	17.4	27.6	1.6	8.8	2.0
Average/Sum#:	366.6 #	101.5 #	51.0 #	279.8 #	61.8 #
Minimum:	11.8	2.3	1.6	8.8	2.0
Maximum:	17.4	27.6	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	2.4	8.0	0.0	0.4	0.1
12/01/2022 03:00	28.6	57.5	0.3	3.4	0.7
12/01/2022 04:00	3.4	0.0	0.5	5.1	1.0
12/01/2022 05:00	3.6	0.0	0.5	5.4	1.1
12/01/2022 06:00	9.2	0.0	0.7	6.9	1.4
12/01/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 08:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 09:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 10:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 11:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 12:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 13:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 14:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 15:00	9.2	0.0	0.7	6.9	1.4
12/01/2022 16:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 17:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 19:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 20:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 21:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 22:00	8.7	0.0	0.7	6.6	1.3
12/01/2022 23:00	8.7	0.0	0.7	6.5	1.3
Average/Sum#:	200.6 #	65.5 #	13.9 #	136.1 #	27.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	28.6	57.5	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/02/2022 00:00	8.7	0.0	0.7	6.5	1.3
12/02/2022 01:00	8.7	0.0	0.7	6.6	1.3
12/02/2022 02:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 03:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 04:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 05:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 06:00	9.2	0.0	0.7	6.9	1.4
12/02/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 08:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 09:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 10:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 11:00	8.9	0.0	0.7	6.6	1.3
12/02/2022 12:00	8.9	0.0	0.7	6.7	1.3
12/02/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/02/2022 14:00	8.7	0.0	0.7	6.6	1.3
12/02/2022 15:00	9.2	0.0	0.7	6.9	1.4
12/02/2022 16:00	9.4	0.0	0.7	7.0	1.4
12/02/2022 17:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 19:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 21:00	9.3	0.0	0.7	6.9	1.4
12/02/2022 22:00	9.3	0.0	0.7	6.9	1.4
12/02/2022 23:00	9.3	0.0	0.7	7.0	1.4
Average/Sum#:	216.7 #	1.8 #	16.8 #	162.5 #	32.4 #
Minimum:	8.7	0.0	0.7	6.5	1.3
Maximum:	9.4	0.3	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/03/2022 00:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 01:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 02:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 03:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 04:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 05:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 06:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 08:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 09:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 10:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 11:00	9.1	0.0	0.7	6.8	1.4
12/03/2022 12:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/03/2022 14:00	8.7	0.3	0.7	6.6	1.3
12/03/2022 15:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 16:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 17:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 18:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 19:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 21:00	9.4	0.0	0.7	7.0	1.4
12/03/2022 22:00	9.4	0.0	0.7	7.1	1.4
12/03/2022 23:00	9.4	0.0	0.7	7.0	1.4
Average/Sum#:	221.9 #	0.3 #	16.8 #	166.5 #	33.4 #
Minimum:	8.7	0.0	0.7	6.6	1.3
Maximum:	9.4	0.3	0.7	7.1	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/04/2022 00:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 01:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 02:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 03:00	8.8	0.3	0.7	6.6	1.3
12/04/2022 04:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 05:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 06:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 07:00	9.4	0.0	0.7	7.0	1.4
12/04/2022 08:00	8.9	0.0	0.7	6.6	1.3
12/04/2022 09:00	8.8	0.3	0.7	6.6	1.3
12/04/2022 10:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 11:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 12:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 14:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 15:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 16:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 17:00	9.4	0.0	0.7	7.0	1.4
12/04/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 19:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 21:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 22:00	9.2	0.0	0.7	6.9	1.4
12/04/2022 23:00	8.8	0.0	0.7	6.6	1.3
Average/Sum#:	215.9 #	0.6 #	16.8 #	161.9 #	32.1 #
Minimum:	8.8	0.0	0.7	6.6	1.3
Maximum:	9.4	0.3	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/05/2022 00:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 01:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 02:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 03:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 04:00	8.9	0.0	0.7	6.6	1.3
12/05/2022 05:00	9.3	0.0	0.7	7.0	1.4
12/05/2022 06:00	9.4	0.0	0.7	7.0	1.4
12/05/2022 07:00	9.4	0.0	0.7	7.0	1.4
12/05/2022 08:00	9.4	0.0	0.7	7.1	1.4
12/05/2022 09:00	9.5	0.5	0.7	7.1	1.4
12/05/2022 10:00	82.4	89.5	0.9	7.6	1.6
12/05/2022 11:00	23.4	6.8	1.8	10.0	2.2
12/05/2022 12:00	15.0	2.9	2.1	11.9	2.6
12/05/2022 13:00	14.1	2.9	2.0	11.1	2.4
12/05/2022 14:00	14.3	2.9	2.0	11.3	2.4
12/05/2022 15:00	16.5	2.6	2.0	11.3	2.4
12/05/2022 16:00	15.5	2.6	2.2	12.2	2.6
12/05/2022 17:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 18:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 19:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 20:00	16.0	2.6	2.3	12.6	2.8
12/05/2022 21:00	15.5	2.6	2.2	12.2	2.6
12/05/2022 22:00	14.5	3.3	2.0	11.4	2.4
12/05/2022 23:00	12.2	3.3	2.0	11.2	2.4
Average/Sum#:	378.5 #	129.4 #	35.4 #	228.8 #	48.3 #
Minimum:	8.8	0.0	0.7	6.6	1.3
Maximum:	82.4	89.5	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/06/2022 00:00	11.8	4.0	2.0	10.8	2.4
12/06/2022 01:00	11.8	4.4	2.0	10.8	2.4
12/06/2022 02:00	11.8	4.7	2.0	10.8	2.4
12/06/2022 03:00	11.8	4.7	2.0	10.8	2.4
12/06/2022 04:00	13.9	4.0	2.0	11.0	2.4
12/06/2022 05:00	14.0	3.3	2.0	11.0	2.4
12/06/2022 06:00	11.9	4.0	2.0	11.0	2.4
12/06/2022 07:00	12.6	3.4	2.1	11.5	2.6
12/06/2022 08:00	15.9	3.0	2.3	12.4	2.8
12/06/2022 09:00	15.8	2.7	2.3	12.4	2.7
12/06/2022 10:00	15.8	2.7	2.3	12.4	2.7
12/06/2022 11:00	15.7	2.6	2.3	12.4	2.7
12/06/2022 12:00	15.7	2.6	2.3	12.2	2.6
12/06/2022 13:00	10.8	1.3	1.8	9.8	2.2
12/06/2022 14:00	5.3	1.0	1.3	7.2	1.6
12/06/2022 15:00	5.3	1.0	1.3	7.2	1.6
12/06/2022 16:00	7.6	1.1	1.6	8.3	1.8
12/06/2022 17:00	10.9	1.0	1.8	10.0	2.2
12/06/2022 18:00	10.9	1.0	1.8	10.0	2.2
12/06/2022 19:00	10.9	1.3	1.8	10.1	2.2
12/06/2022 20:00	14.9	3.3	2.1	11.7	2.6
12/06/2022 21:00	15.6	2.6	2.3	12.3	2.6
12/06/2022 22:00	14.7	3.0	2.1	11.5	2.6
12/06/2022 23:00	11.8	3.4	2.0	10.8	2.4
Average/Sum#:	297.2 #	66.1 #	47.5 #	258.4 #	56.9 #
Minimum:	5.3	1.0	1.3	7.2	1.6
Maximum:	15.9	4.7	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/07/2022 00:00	14.5	3.0	2.1	11.5	2.5
12/07/2022 01:00	13.9	3.4	2.0	11.0	2.4
12/07/2022 02:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 03:00	15.0	3.0	2.1	11.8	2.6
12/07/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/07/2022 05:00	17.3	3.0	2.2	11.9	2.6
12/07/2022 06:00	13.5	3.0	2.3	12.4	2.7
12/07/2022 07:00	15.8	2.7	2.3	12.4	2.7
12/07/2022 08:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 09:00	17.3	3.1	2.2	11.9	2.6
12/07/2022 10:00	15.2	3.0	2.2	11.9	2.6
12/07/2022 11:00	15.2	3.0	2.2	11.9	2.6
12/07/2022 12:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 13:00	14.8	2.6	2.1	11.7	2.6
12/07/2022 14:00	14.4	3.0	2.0	11.3	2.4
12/07/2022 15:00	14.6	3.0	2.1	11.5	2.5
12/07/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/07/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/07/2022 18:00	15.9	2.7	2.3	12.5	2.8
12/07/2022 19:00	15.9	2.7	2.3	12.4	2.8
12/07/2022 20:00	15.9	2.7	2.3	12.5	2.8
12/07/2022 21:00	15.9	2.7	2.3	12.4	2.8
12/07/2022 22:00	17.4	3.0	2.2	12.0	2.6
12/07/2022 23:00	15.2	3.0	2.2	11.9	2.6
Average/Sum#:	369.4 #	69.8 #	52.4 #	286.8 #	63.1 #
Minimum:	13.5	2.6	2.0	11.0	2.4
Maximum:	17.4	3.4	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/08/2022 00:00	15.0	3.0	2.1	11.7	2.6
12/08/2022 01:00	17.0	3.0	2.1	11.7	2.6
12/08/2022 02:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 03:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/08/2022 05:00	17.6	3.3	2.2	12.1	2.6
12/08/2022 06:00	15.9	3.0	2.3	12.6	2.8
12/08/2022 07:00	15.7	3.1	2.3	12.3	2.6
12/08/2022 08:00	14.2	3.7	2.0	11.2	2.4
12/08/2022 09:00	14.8	3.4	2.1	11.6	2.6
12/08/2022 10:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 11:00	17.2	3.0	2.1	11.9	2.6
12/08/2022 12:00	15.0	3.0	2.1	11.9	2.6
12/08/2022 13:00	15.2	3.0	2.2	11.9	2.6
12/08/2022 14:00	17.3	3.0	2.2	11.9	2.6
12/08/2022 15:00	17.3	3.0	2.2	12.0	2.6
12/08/2022 16:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 18:00	16.0	2.6	2.3	12.6	2.8
12/08/2022 19:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 20:00	15.9	2.6	2.3	12.6	2.8
12/08/2022 21:00	15.9	2.6	2.3	12.6	2.8
12/08/2022 22:00	15.3	3.0	2.2	12.0	2.6
12/08/2022 23:00	17.5	3.0	2.2	12.0	2.6
Average/Sum#:	380.3 #	71.1 #	52.5 #	289.1 #	63.6 #
Minimum:	14.2	2.6	2.0	11.2	2.4
Maximum:	17.6	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/09/2022 00:00	15.0	3.0	2.1	11.7	2.6
12/09/2022 01:00	16.4	3.4	2.0	11.2	2.4
12/09/2022 02:00	15.0	3.0	2.1	11.8	2.6
12/09/2022 03:00	15.0	3.0	2.1	11.8	2.6
12/09/2022 04:00	15.4	3.0	2.2	12.1	2.6
12/09/2022 05:00	18.3	3.0	2.3	12.6	2.8
12/09/2022 06:00	16.1	3.0	2.3	12.6	2.8
12/09/2022 07:00	15.9	3.0	2.3	12.6	2.8
12/09/2022 08:00	14.5	3.7	2.0	11.4	2.4
12/09/2022 09:00	14.2	3.7	2.0	11.2	2.4
12/09/2022 10:00	11.9	4.7	2.0	10.9	2.4
12/09/2022 11:00	14.5	3.4	2.0	11.4	2.4
12/09/2022 12:00	12.0	3.7	2.0	11.0	2.4
12/09/2022 13:00	15.0	3.0	2.1	11.9	2.6
12/09/2022 14:00	17.3	3.0	2.1	11.8	2.6
12/09/2022 15:00	14.3	3.7	2.0	11.3	2.4
12/09/2022 16:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 18:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 19:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 20:00	16.0	2.7	2.3	12.5	2.8
12/09/2022 21:00	16.0	2.6	2.3	12.5	2.8
12/09/2022 22:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 23:00	15.8	2.6	2.3	12.4	2.7
Average/Sum#:	368.1 #	74.2 #	52.0 #	287.2 #	63.1 #
Minimum:	11.9	2.6	2.0	10.9	2.4
Maximum:	18.3	4.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/10/2022 00:00	14.1	3.6	2.0	11.1	2.4
12/10/2022 01:00	14.0	3.6	2.0	11.0	2.4
12/10/2022 02:00	11.8	4.0	2.0	10.8	2.4
12/10/2022 03:00	13.8	3.9	2.0	10.8	2.4
12/10/2022 04:00	13.7	3.9	2.0	10.8	2.4
12/10/2022 05:00	13.9	3.9	2.0	10.9	2.4
12/10/2022 06:00	13.7	4.3	2.0	10.8	2.4
12/10/2022 07:00	13.8	4.3	2.0	10.8	2.4
12/10/2022 08:00	12.1	3.6	2.0	11.1	2.4
12/10/2022 09:00	13.9	3.9	2.0	11.0	2.4
12/10/2022 10:00	13.7	4.3	2.0	10.8	2.4
12/10/2022 11:00	12.0	3.5	2.0	11.0	2.4
12/10/2022 12:00	16.9	2.9	2.1	11.6	2.6
12/10/2022 13:00	15.2	2.6	2.2	11.9	2.6
12/10/2022 14:00	14.1	2.9	2.0	11.1	2.4
12/10/2022 15:00	14.3	2.9	2.0	11.2	2.4
12/10/2022 16:00	16.9	2.9	2.1	11.5	2.6
12/10/2022 17:00	14.5	2.9	2.0	11.3	2.4
12/10/2022 18:00	14.5	3.2	2.0	11.3	2.4
12/10/2022 19:00	15.7	2.6	2.3	12.4	2.7
12/10/2022 20:00	15.2	2.6	2.2	11.9	2.6
12/10/2022 21:00	14.5	2.9	2.0	11.4	2.4
12/10/2022 22:00	14.1	3.3	2.0	11.0	2.4
12/10/2022 23:00	14.5	2.9	2.0	11.4	2.4
Average/Sum#:	340.9 #	81.4 #	48.9 #	268.9 #	58.7 #
Minimum:	11.8	2.6	2.0	10.8	2.4
Maximum:	16.9	4.3	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/11/2022 00:00	11.8	3.6	2.0	10.8	2.4
12/11/2022 01:00	13.7	4.0	2.0	10.8	2.4
12/11/2022 02:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 03:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 04:00	13.7	4.3	2.0	10.8	2.4
12/11/2022 05:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 06:00	13.7	4.3	2.0	10.8	2.4
12/11/2022 07:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 08:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 09:00	13.8	4.3	2.0	10.8	2.4
12/11/2022 10:00	13.8	4.3	2.0	10.8	2.4
12/11/2022 11:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 12:00	13.7	4.0	2.0	10.8	2.4
12/11/2022 13:00	13.8	3.9	2.0	10.8	2.4
12/11/2022 14:00	15.7	3.9	2.0	10.8	2.4
12/11/2022 15:00	14.4	3.3	2.0	11.3	2.4
12/11/2022 16:00	14.5	3.3	2.0	11.3	2.4
12/11/2022 17:00	15.0	3.0	2.1	11.7	2.6
12/11/2022 18:00	16.4	3.7	2.0	11.2	2.4
12/11/2022 19:00	14.5	3.4	2.0	11.4	2.4
12/11/2022 20:00	14.9	3.4	2.1	11.7	2.6
12/11/2022 21:00	12.0	4.1	2.0	11.0	2.4
12/11/2022 22:00	13.8	4.4	2.0	10.8	2.4
12/11/2022 23:00	11.8	4.4	2.0	10.8	2.4
Average/Sum#:	321.8 #	94.5 #	48.2 #	263.2 #	58.0 #
Minimum:	11.8	3.0	2.0	10.8	2.4
Maximum:	16.4	4.4	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/12/2022 00:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 01:00	11.8	4.4	2.0	10.8	2.4
12/12/2022 02:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 03:00	11.8	4.4	2.0	10.8	2.4
12/12/2022 04:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 05:00	14.8	3.3	2.1	11.7	2.6
12/12/2022 06:00	17.7	3.0	2.2	12.2	2.6
12/12/2022 07:00	17.6	3.0	2.2	12.1	2.6
12/12/2022 08:00	12.4	3.7	2.1	11.4	2.4
12/12/2022 09:00	14.5	3.4	2.0	11.4	2.4
12/12/2022 10:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 11:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 12:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 13:00	11.8	4.3	2.0	10.8	2.4
12/12/2022 14:00	11.8	4.3	2.0	10.8	2.4
12/12/2022 15:00	13.7	4.0	2.0	10.8	2.4
12/12/2022 16:00	15.0	3.0	2.1	11.8	2.6
12/12/2022 17:00	15.6	2.6	2.3	12.3	2.7
12/12/2022 18:00	16.1	2.3	2.3	12.6	2.8
12/12/2022 19:00	16.1	2.3	2.3	12.6	2.8
12/12/2022 20:00	16.1	2.3	2.3	12.7	2.8
12/12/2022 21:00	15.8	2.7	2.3	12.4	2.7
12/12/2022 22:00	17.6	2.7	2.2	12.1	2.6
12/12/2022 23:00	16.2	3.4	2.0	11.2	2.4
Average/Sum#:	343.2 #	86.4 #	50.4 #	275.3 #	60.4 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.7	4.7	2.3	12.7	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/13/2022 00:00	15.1	3.1	2.1	11.9	2.6
12/13/2022 01:00	15.1	3.1	2.1	11.9	2.6
12/13/2022 02:00	17.3	3.0	2.2	11.9	2.6
12/13/2022 03:00	15.0	3.0	2.1	11.9	2.6
12/13/2022 04:00	15.4	3.1	2.2	12.1	2.6
12/13/2022 05:00	15.9	3.0	2.3	12.6	2.8
12/13/2022 06:00	16.2	2.7	2.3	12.8	2.8
12/13/2022 07:00	16.2	2.7	2.3	12.6	2.8
12/13/2022 08:00	15.0	3.0	2.1	11.7	2.6
12/13/2022 09:00	14.0	3.7	2.0	11.0	2.4
12/13/2022 10:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 11:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 12:00	13.8	4.0	2.0	10.8	2.4
12/13/2022 13:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 14:00	13.7	4.0	2.0	10.8	2.4
12/13/2022 15:00	14.5	3.3	2.0	11.3	2.4
12/13/2022 16:00	15.9	2.3	2.3	12.4	2.8
12/13/2022 17:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 18:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 19:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 20:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 21:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 22:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 23:00	16.0	2.7	2.3	12.6	2.8
Average/Sum#:	360.5 #	73.7 #	52.1 #	286.3 #	63.2 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.3	4.0	2.3	12.8	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/14/2022 00:00	17.5	2.7	2.2	12.1	2.6
12/14/2022 01:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 02:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 03:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 04:00	17.5	3.1	2.2	12.1	2.6
12/14/2022 05:00	18.4	3.1	2.3	12.6	2.8
12/14/2022 06:00	16.1	2.7	2.3	12.6	2.8
12/14/2022 07:00	15.9	2.7	2.3	12.4	2.8
12/14/2022 08:00	16.6	3.4	2.0	11.4	2.4
12/14/2022 09:00	14.0	3.7	2.0	11.0	2.4
12/14/2022 10:00	12.2	3.4	2.0	11.2	2.4
12/14/2022 11:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 12:00	11.8	4.0	2.0	10.8	2.4
12/14/2022 13:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 14:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 15:00	14.1	3.7	2.0	11.1	2.4
12/14/2022 16:00	15.5	2.7	2.2	12.2	2.6
12/14/2022 17:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 18:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 19:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 20:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 21:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 22:00	15.9	2.7	2.3	12.4	2.8
12/14/2022 23:00	15.2	2.7	2.2	11.9	2.6
Average/Sum#:	362.3 #	74.5 #	52.1 #	285.5 #	62.6 #
Minimum:	11.8	2.7	2.0	10.8	2.4
Maximum:	18.4	4.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/15/2022 00:00	16.1	2.7	2.3	12.6	2.8
12/15/2022 01:00	16.1	2.7	2.3	12.6	2.8
12/15/2022 02:00	16.1	2.4	2.3	12.6	2.8
12/15/2022 03:00	16.2	2.7	2.3	12.6	2.8
12/15/2022 04:00	16.2	2.4	2.3	12.8	2.8
12/15/2022 05:00	16.2	2.3	2.3	12.8	2.8
12/15/2022 06:00	16.2	2.3	2.3	12.8	2.8
12/15/2022 07:00	16.2	2.4	2.3	12.6	2.8
12/15/2022 08:00	15.6	2.4	2.3	12.2	2.6
12/15/2022 09:00	15.5	2.7	2.2	12.2	2.6
12/15/2022 10:00	13.8	3.3	2.0	10.8	2.4
12/15/2022 11:00	15.9	3.3	2.0	11.0	2.4
12/15/2022 12:00	14.1	3.0	2.0	11.1	2.4
12/15/2022 13:00	14.3	3.0	2.0	11.2	2.4
12/15/2022 14:00	14.6	2.3	2.1	11.5	2.5
12/15/2022 15:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 16:00	15.8	2.0	2.3	12.4	2.7
12/15/2022 17:00	15.8	2.3	2.3	12.4	2.7
12/15/2022 18:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 19:00	15.7	2.6	2.3	12.4	2.7
12/15/2022 20:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 21:00	15.7	2.7	2.3	12.4	2.7
12/15/2022 22:00	15.7	2.7	2.3	12.4	2.7
12/15/2022 23:00	15.7	2.7	2.3	12.3	2.6
Average/Sum#:	374.6 #	61.8 #	53.7 #	292.9 #	63.9 #
Minimum:	13.8	2.0	2.0	10.8	2.4
Maximum:	16.2	3.3	2.3	12.8	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/16/2022 00:00	14.0	3.7	2.0	11.0	2.4
12/16/2022 01:00	11.8	4.0	2.0	10.8	2.4
12/16/2022 02:00	13.8	4.0	2.0	10.8	2.4
12/16/2022 03:00	11.8	4.1	2.0	10.8	2.4
12/16/2022 04:00	13.8	4.1	2.0	10.8	2.4
12/16/2022 05:00	11.9	4.1	2.0	11.0	2.4
12/16/2022 06:00	12.6	3.4	2.1	11.6	2.6
12/16/2022 07:00	17.7	2.7	2.2	12.1	2.6
12/16/2022 08:00	15.0	2.7	2.1	11.8	2.6
12/16/2022 09:00	14.5	3.0	2.0	11.4	2.4
12/16/2022 10:00	7.7	0.9	1.6	8.5	1.8
12/16/2022 11:00	7.3	1.1	1.4	8.1	1.8
12/16/2022 12:00	5.3	1.2	1.3	7.3	1.6
12/16/2022 13:00	5.3	1.0	1.3	7.3	1.6
12/16/2022 14:00	8.0	0.9	1.6	8.7	1.9
12/16/2022 15:00	7.8	1.2	1.6	8.6	1.8
12/16/2022 16:00	17.3	3.0	2.2	11.9	2.6
12/16/2022 17:00	15.6	2.6	2.3	12.3	2.6
12/16/2022 18:00	17.2	2.7	2.1	11.9	2.6
12/16/2022 19:00	17.3	2.7	2.2	11.9	2.6
12/16/2022 20:00	15.7	2.3	2.3	12.4	2.7
12/16/2022 21:00	15.4	2.7	2.2	12.1	2.6
12/16/2022 22:00	12.6	3.0	2.1	11.5	2.6
12/16/2022 23:00	11.8	3.7	2.0	10.8	2.4
Average/Sum#:	301.2 #	64.8 #	46.6 #	255.4 #	55.8 #
Minimum:	5.3	0.9	1.3	7.3	1.6
Maximum:	17.7	4.1	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/17/2022 00:00	15.0	3.0	2.1	11.8	2.6
12/17/2022 01:00	15.0	3.0	2.1	11.9	2.6
12/17/2022 02:00	15.0	3.0	2.1	11.8	2.6
12/17/2022 03:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 05:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 06:00	15.7	2.7	2.3	12.3	2.6
12/17/2022 07:00	14.7	3.0	2.1	11.5	2.6
12/17/2022 08:00	15.2	3.1	2.1	11.9	2.6
12/17/2022 09:00	14.9	3.0	2.1	11.7	2.6
12/17/2022 10:00	14.0	3.4	2.0	11.0	2.4
12/17/2022 11:00	11.8	3.7	2.0	10.8	2.4
12/17/2022 12:00	11.8	3.7	2.0	10.8	2.4
12/17/2022 13:00	11.8	3.3	2.0	10.8	2.4
12/17/2022 14:00	15.9	3.3	2.0	10.9	2.4
12/17/2022 15:00	14.8	2.6	2.1	11.7	2.6
12/17/2022 16:00	15.8	2.3	2.3	12.4	2.7
12/17/2022 17:00	15.7	2.6	2.3	12.2	2.6
12/17/2022 18:00	17.2	2.7	2.1	11.8	2.6
12/17/2022 19:00	16.0	2.6	2.3	12.6	2.8
12/17/2022 20:00	16.0	2.3	2.3	12.6	2.8
12/17/2022 21:00	16.0	2.3	2.3	12.6	2.8
12/17/2022 22:00	15.9	2.3	2.3	12.6	2.8
12/17/2022 23:00	17.5	2.7	2.2	12.1	2.6
Average/Sum#:	361.0 #	69.6 #	51.4 #	283.5 #	62.3 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.5	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/18/2022 00:00	15.0	2.7	2.1	11.7	2.6
12/18/2022 01:00	15.0	3.1	2.1	11.7	2.6
12/18/2022 02:00	14.2	3.7	2.0	11.2	2.4
12/18/2022 03:00	11.9	4.1	2.0	10.9	2.4
12/18/2022 04:00	15.0	3.1	2.1	11.7	2.6
12/18/2022 05:00	17.2	3.1	2.1	11.9	2.6
12/18/2022 06:00	15.2	3.0	2.2	11.9	2.6
12/18/2022 07:00	17.7	3.1	2.2	12.2	2.6
12/18/2022 08:00	14.7	3.0	2.1	11.5	2.6
12/18/2022 09:00	8.1	1.2	1.6	8.8	2.0
12/18/2022 10:00	9.3	1.2	1.6	8.6	1.8
12/18/2022 11:00	7.8	1.2	1.6	8.5	1.8
12/18/2022 12:00	7.0	1.3	1.4	7.7	1.6
12/18/2022 13:00	7.0	1.3	1.4	7.7	1.6
12/18/2022 14:00	9.9	1.2	1.7	9.0	2.0
12/18/2022 15:00	8.3	1.2	1.7	9.0	2.0
12/18/2022 16:00	15.0	3.3	2.1	11.7	2.6
12/18/2022 17:00	15.7	2.7	2.3	12.4	2.7
12/18/2022 18:00	15.9	2.7	2.3	12.6	2.8
12/18/2022 19:00	16.0	2.7	2.3	12.6	2.8
12/18/2022 20:00	15.7	3.0	2.3	12.3	2.6
12/18/2022 21:00	17.6	3.1	2.2	12.1	2.6
12/18/2022 22:00	17.6	3.1	2.2	12.1	2.6
12/18/2022 23:00	14.3	3.7	2.0	11.2	2.4
Average/Sum#:	321.1 #	61.8 #	47.6 #	261.0 #	56.9 #
Minimum:	7.0	1.2	1.4	7.7	1.6
Maximum:	17.7	4.1	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/19/2022 00:00	15.0	3.4	2.1	11.8	2.6
12/19/2022 01:00	15.1	3.0	2.1	11.9	2.6
12/19/2022 02:00	17.2	3.1	2.1	11.8	2.6
12/19/2022 03:00	17.2	3.1	2.1	11.9	2.6
12/19/2022 04:00	15.2	3.4	2.2	12.1	2.6
12/19/2022 05:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 06:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 07:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 08:00	15.7	3.0	2.3	12.4	2.7
12/19/2022 09:00	15.9	3.0	2.3	12.4	2.8
12/19/2022 10:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 11:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 12:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 13:00	15.2	3.0	2.1	11.9	2.6
12/19/2022 14:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 15:00	17.8	3.1	2.3	12.2	2.6
12/19/2022 16:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 17:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 18:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 19:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 20:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 21:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 22:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 23:00	15.9	3.1	2.3	12.5	2.8
Average/Sum#:	380.6 #	74.6 #	53.7 #	293.5 #	64.9 #
Minimum:	15.0	3.0	2.1	11.8	2.6
Maximum:	17.8	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/20/2022 00:00	15.2	3.1	2.2	11.9	2.6
12/20/2022 01:00	17.4	3.1	2.2	11.9	2.6
12/20/2022 02:00	15.2	3.1	2.2	12.0	2.6
12/20/2022 03:00	15.3	3.1	2.2	12.0	2.6
12/20/2022 04:00	17.5	3.1	2.2	12.1	2.6
12/20/2022 05:00	17.5	3.1	2.2	12.1	2.6
12/20/2022 06:00	16.0	3.1	2.3	12.6	2.8
12/20/2022 07:00	15.9	3.1	2.3	12.6	2.8
12/20/2022 08:00	15.2	3.1	2.2	11.9	2.6
12/20/2022 09:00	17.3	3.1	2.2	11.9	2.6
12/20/2022 10:00	14.9	3.0	2.1	11.7	2.6
12/20/2022 11:00	14.7	3.0	2.1	11.5	2.6
12/20/2022 12:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 13:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 14:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 15:00	16.3	3.7	2.0	11.2	2.4
12/20/2022 16:00	17.5	2.7	2.2	12.1	2.6
12/20/2022 17:00	15.8	2.7	2.3	12.4	2.7
12/20/2022 18:00	15.8	2.7	2.3	12.4	2.7
12/20/2022 19:00	15.7	2.7	2.3	12.4	2.7
12/20/2022 20:00	15.7	2.7	2.3	12.4	2.7
12/20/2022 21:00	15.2	2.7	2.2	11.9	2.6
12/20/2022 22:00	15.2	2.7	2.2	11.9	2.6
12/20/2022 23:00	15.5	2.7	2.2	12.2	2.6
Average/Sum#:	370.2 #	74.3 #	52.4 #	285.5 #	62.4 #
Minimum:	11.8	2.7	2.0	10.8	2.4
Maximum:	17.5	4.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/21/2022 00:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 01:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 02:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 03:00	16.0	2.7	2.3	12.6	2.8
12/21/2022 04:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 05:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 06:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 07:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 08:00	6.7	2.7	2.3	12.4	2.7
12/21/2022 09:00	15.7	3.3	2.3	12.4	2.7
12/21/2022 10:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 11:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 12:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 13:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 14:00	17.1	3.0	2.1	11.8	2.6
12/21/2022 15:00	15.5	2.9	2.2	12.2	2.6
12/21/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/21/2022 17:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 18:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 19:00	15.7	2.7	2.3	12.4	2.7
12/21/2022 20:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 21:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 22:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 23:00	15.7	3.3	2.3	12.3	2.6
Average/Sum#:	363.4 #	66.4 #	54.6 #	297.4 #	65.0 #
Minimum:	15.5	2.6	2.1	11.8	2.6
Maximum:	17.1	3.3	2.3	12.6	2.8
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/22/2022 00:00	15.2	3.7	2.2	12.0	2.6
12/22/2022 01:00	13.8	5.0	2.0	10.9	2.4
12/22/2022 02:00	11.8	5.7	2.0	10.8	2.4
12/22/2022 03:00	13.8	5.7	2.0	10.8	2.4
12/22/2022 04:00	12.6	5.1	2.1	11.5	2.6
12/22/2022 05:00	15.6	3.6	2.3	12.3	2.6
12/22/2022 06:00	15.9	3.4	2.3	12.5	2.8
12/22/2022 07:00	15.9	3.4	2.3	12.4	2.8
12/22/2022 08:00	15.7	3.3	2.3	12.3	2.6
12/22/2022 09:00	15.1	3.7	2.1	11.8	2.6
12/22/2022 10:00	15.0	3.8	2.1	11.8	2.6
12/22/2022 11:00	15.0	3.7	2.1	11.8	2.6
12/22/2022 12:00	15.0	3.7	2.1	11.7	2.6
12/22/2022 13:00	15.0	3.3	2.1	11.7	2.6
12/22/2022 14:00	15.0	3.7	2.1	11.8	2.6
12/22/2022 15:00	15.5	3.3	2.2	12.1	2.6
12/22/2022 16:00	15.4	3.3	2.2	12.1	2.6
12/22/2022 17:00	15.7	3.3	2.3	12.4	2.7
12/22/2022 18:00	15.7	3.3	2.3	12.4	2.7
12/22/2022 19:00	15.8	3.3	2.3	12.4	2.7
12/22/2022 20:00	15.8	3.3	2.3	12.4	2.7
12/22/2022 21:00	15.7	3.0	2.3	12.4	2.7
12/22/2022 22:00	15.5	3.3	2.2	12.1	2.6
12/22/2022 23:00	14.5	4.1	2.0	11.4	2.4
Average/Sum#:	360.0 #	91.0 #	52.2 #	285.8 #	62.5 #
Minimum:	11.8	3.0	2.0	10.8	2.4
Maximum:	15.9	5.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/23/2022 00:00	15.5	3.3	2.3	12.2	2.6
12/23/2022 01:00	15.9	3.3	2.3	12.4	2.8
12/23/2022 02:00	15.8	3.3	2.3	12.4	2.8
12/23/2022 03:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 04:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 05:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 06:00	15.8	3.3	2.3	12.4	2.8
12/23/2022 07:00	15.7	3.3	2.3	12.3	2.6
12/23/2022 08:00	17.5	3.3	2.2	12.0	2.6
12/23/2022 09:00	17.4	3.3	2.2	11.9	2.6
12/23/2022 10:00	15.0	3.3	2.1	11.7	2.6
12/23/2022 11:00	17.1	2.9	2.1	11.7	2.6
12/23/2022 12:00	14.2	4.0	2.0	11.1	2.4
12/23/2022 13:00	11.8	4.3	2.0	10.8	2.4
12/23/2022 14:00	13.7	4.6	2.0	10.8	2.4
12/23/2022 15:00	14.4	4.0	2.0	11.3	2.4
12/23/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 17:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 18:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 19:00	15.7	2.3	2.3	12.4	2.7
12/23/2022 20:00	15.7	2.3	2.3	12.3	2.6
12/23/2022 21:00	15.7	2.3	2.3	12.4	2.7
12/23/2022 22:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 23:00	15.7	2.6	2.3	12.3	2.6
Average/Sum#:	372.5 #	76.0 #	53.4 #	289.2 #	63.1 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.5	4.6	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/24/2022 00:00	17.0	2.9	2.1	11.7	2.6
12/24/2022 01:00	14.8	3.0	2.1	11.7	2.6
12/24/2022 02:00	11.8	4.4	2.0	10.8	2.4
12/24/2022 03:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 04:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 05:00	13.7	4.7	2.0	10.8	2.4
12/24/2022 06:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 07:00	14.0	4.4	2.0	11.0	2.4
12/24/2022 08:00	11.0	3.8	1.9	10.1	2.2
12/24/2022 09:00	5.3	1.5	1.3	7.2	1.6
12/24/2022 10:00	7.8	1.5	1.6	8.5	1.8
12/24/2022 11:00	7.8	1.5	1.6	8.5	1.8
12/24/2022 12:00	7.8	1.5	1.6	8.6	1.8
12/24/2022 13:00	9.3	0.9	1.6	8.6	1.8
12/24/2022 14:00	8.7	1.0	1.7	9.5	2.0
12/24/2022 15:00	8.7	1.0	1.7	9.5	2.0
12/24/2022 16:00	8.0	1.2	1.6	8.8	2.0
12/24/2022 17:00	11.7	5.0	2.0	10.8	2.4
12/24/2022 18:00	13.7	4.3	2.0	10.8	2.4
12/24/2022 19:00	11.7	3.9	2.0	10.8	2.4
12/24/2022 20:00	11.7	3.9	2.0	10.8	2.4
12/24/2022 21:00	13.7	3.9	2.0	10.8	2.4
12/24/2022 22:00	11.7	4.3	2.0	10.8	2.4
12/24/2022 23:00	11.7	4.3	2.0	10.8	2.4
Average/Sum#:	267.0 #	77.0 #	44.8 #	243.3 #	53.4 #
Minimum:	5.3	0.9	1.3	7.2	1.6
Maximum:	17.0	5.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/25/2022 00:00	11.6	4.3	2.0	10.6	2.4
12/25/2022 01:00	5.6	12.5	0.1	0.7	0.2
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	48.0	43.8	0.1	0.7	0.1
12/25/2022 19:00	23.8	25.3	0.1	1.2	0.2
12/25/2022 20:00	35.1	56.1	0.2	2.3	0.5
12/25/2022 21:00	1.4	0.3	0.4	4.3	0.9
12/25/2022 22:00	2.9	0.0	0.4	4.4	0.9
12/25/2022 23:00	3.0	0.3	0.4	4.4	0.9
Average/Sum#:	131.4 #	142.6 #	3.7 #	28.6 #	6.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	48.0	56.1	2.0	10.6	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/26/2022 00:00	45.0	50.6	0.6	5.8	1.2
12/26/2022 01:00	57.4	85.1	1.2	7.0	1.5
12/26/2022 02:00	10.3	1.9	1.7	9.4	2.0
12/26/2022 03:00	10.3	1.9	1.7	9.5	2.0
12/26/2022 04:00	10.3	1.9	1.7	9.5	2.0
12/26/2022 05:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 06:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 07:00	10.5	1.9	1.7	9.6	2.0
12/26/2022 08:00	10.5	1.9	1.7	9.6	2.0
12/26/2022 09:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 10:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 11:00	7.8	1.7	1.6	8.5	1.8
12/26/2022 12:00	7.7	2.0	1.6	8.5	1.8
12/26/2022 13:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 14:00	8.1	1.8	1.6	8.9	2.0
12/26/2022 15:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 16:00	10.6	1.9	1.7	9.8	2.2
12/26/2022 17:00	12.7	5.3	2.1	11.7	2.6
12/26/2022 18:00	15.1	4.0	2.1	11.9	2.6
12/26/2022 19:00	14.0	5.0	2.0	11.0	2.4
12/26/2022 20:00	14.0	5.0	2.0	11.0	2.4
12/26/2022 21:00	11.8	5.6	2.0	10.8	2.4
12/26/2022 22:00	13.5	5.6	2.0	10.6	2.4
12/26/2022 23:00	4.6	12.1	0.1	0.7	0.2
Average/Sum#:	329.1 #	206.3 #	39.0 #	218.1 #	47.2 #
Minimum:	4.6	1.7	0.1	0.7	0.2
Maximum:	57.4	85.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	0.0	1.6	0.0	0.1	0.0
12/27/2022 02:00	24.2	41.8	0.2	2.3	0.5
12/27/2022 03:00	3.1	0.0	0.5	4.6	0.9
12/27/2022 04:00	3.1	0.0	0.5	4.6	0.9
12/27/2022 05:00	14.7	43.9	0.6	5.6	1.1
12/27/2022 06:00	27.7	60.7	1.2	7.2	1.5
12/27/2022 07:00	10.5	1.3	1.7	9.5	2.0
12/27/2022 08:00	10.3	1.9	1.7	9.4	2.0
12/27/2022 09:00	13.7	5.5	2.0	10.8	2.4
12/27/2022 10:00	13.7	4.9	2.0	10.8	2.4
12/27/2022 11:00	15.7	3.9	2.0	10.8	2.4
12/27/2022 12:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 13:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 14:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 15:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 16:00	15.7	3.9	2.0	10.8	2.4
12/27/2022 17:00	13.7	4.6	2.0	10.8	2.4
12/27/2022 18:00	15.6	4.6	2.0	10.7	2.4
12/27/2022 19:00	13.6	4.6	2.0	10.8	2.4
12/27/2022 20:00	13.8	5.0	2.0	10.8	2.4
12/27/2022 21:00	15.7	4.7	2.0	10.8	2.4
12/27/2022 22:00	11.6	4.6	1.9	10.6	2.4
12/27/2022 23:00	7.0	1.3	1.4	7.7	1.6
Average/Sum#:	306.2 #	213.2 #	35.7 #	201.9 #	44.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	27.7	60.7	2.0	10.8	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/28/2022 00:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 01:00	7.3	1.4	1.4	8.1	1.8
12/28/2022 02:00	7.6	1.4	1.6	8.4	1.8
12/28/2022 03:00	7.6	1.4	1.6	8.4	1.8
12/28/2022 04:00	9.3	1.4	1.6	8.5	1.8
12/28/2022 05:00	8.6	1.6	1.7	9.5	2.0
12/28/2022 06:00	10.5	1.3	1.7	9.6	2.1
12/28/2022 07:00	10.5	1.6	1.7	9.6	2.1
12/28/2022 08:00	10.3	1.3	1.7	9.4	2.0
12/28/2022 09:00	8.6	1.6	1.7	9.4	2.0
12/28/2022 10:00	7.8	1.5	1.6	8.5	1.8
12/28/2022 11:00	7.8	1.2	1.6	8.6	1.8
12/28/2022 12:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 13:00	7.7	1.1	1.6	8.4	1.8
12/28/2022 14:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 15:00	9.6	1.8	1.6	8.8	2.0
12/28/2022 16:00	14.7	4.9	2.1	11.5	2.6
12/28/2022 17:00	13.8	4.6	2.0	10.8	2.4
12/28/2022 18:00	11.8	5.0	2.0	10.8	2.4
12/28/2022 19:00	13.7	5.0	2.0	10.8	2.4
12/28/2022 20:00	11.8	5.3	2.0	10.8	2.4
12/28/2022 21:00	11.8	4.9	2.0	10.8	2.4
12/28/2022 22:00	13.7	5.3	2.0	10.8	2.4
12/28/2022 23:00	11.8	5.3	2.0	10.8	2.4
Average/Sum#:	239.7 #	62.5 #	42.0 #	227.8 #	49.6 #
Minimum:	7.3	1.1	1.4	8.1	1.8
Maximum:	14.7	5.3	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/29/2022 00:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 01:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 02:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 03:00	13.7	5.3	2.0	10.8	2.4
12/29/2022 04:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 05:00	14.3	4.6	2.0	11.2	2.4
12/29/2022 06:00	14.3	4.7	2.0	11.2	2.4
12/29/2022 07:00	12.3	4.7	2.0	11.3	2.4
12/29/2022 08:00	15.4	4.0	2.2	12.1	2.6
12/29/2022 09:00	15.7	3.3	2.3	12.4	2.7
12/29/2022 10:00	17.2	3.3	2.1	11.9	2.6
12/29/2022 11:00	16.2	4.7	2.0	11.1	2.4
12/29/2022 12:00	13.9	5.0	2.0	10.9	2.4
12/29/2022 13:00	11.8	5.7	2.0	10.8	2.4
12/29/2022 14:00	13.9	5.3	2.0	10.9	2.4
12/29/2022 15:00	11.9	5.3	2.0	10.9	2.4
12/29/2022 16:00	14.6	5.0	2.1	11.5	2.5
12/29/2022 17:00	15.1	3.3	2.2	11.9	2.6
12/29/2022 18:00	14.5	4.0	2.0	11.5	2.5
12/29/2022 19:00	13.7	6.0	2.0	10.8	2.4
12/29/2022 20:00	11.8	6.1	2.0	10.8	2.4
12/29/2022 21:00	13.9	5.3	2.0	10.9	2.4
12/29/2022 22:00	11.8	5.9	2.0	10.8	2.4
12/29/2022 23:00	13.5	5.9	2.0	10.6	2.4
Average/Sum#:	326.7 #	118.6 #	48.9 #	267.5 #	58.7 #
Minimum:	11.8	3.3	2.0	10.6	2.4
Maximum:	17.2	6.1	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/30/2022 00:00	4.7	13.2	0.1	0.8	0.2
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	4.7 #	13.2 #	0.1 #	0.8 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	4.7	13.2	0.1	0.8	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:00 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:01 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:01 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:02 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:02 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:03 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:03 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:04 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:04 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:06 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
Linearity

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/05/2022	Scale:	High
Performance Spec:	5 %	Test No.:	116	Highest Error:	0.9
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/05/2022	1129	L	200.0	50.2	50.3		25.1 %
10/05/2022	1135	M	200.0	111.1	110.8		55.6 %
10/05/2022	1141	H	200.0	184.3	187.1		92.2 %
10/05/2022	1150	L	200.0	50.2	50.1		25.1 %
10/05/2022	1156	M	200.0	111.1	112.7		55.6 %
10/05/2022	1202	H	200.0	184.3	184.3		92.2 %
10/05/2022	1210	L	200.0	50.2	50.3		25.1 %
10/05/2022	1216	M	200.0	111.1	111.1		55.6 %
10/05/2022	1222	H	200.0	184.3	186.5		92.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.200	50.233	No	**0.1**
M	111.100	111.533	No	**0.4**
H	184.300	185.967	No	**0.9**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT1
Component ID: A12
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument
Test End Date/Time: 10/05/2022
Scale: High
Performance Spec: 5 %
Test No.: 117
Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/05/2022	0926	L	25.0	5.5	5.4		22.0 %
10/05/2022	0932	M	25.0	13.0	13.0		52.0 %
10/05/2022	0938	H	25.0	21.0	21.0		84.0 %
10/05/2022	0947	L	25.0	5.5	5.4		22.0 %
10/05/2022	0953	M	25.0	13.0	13.0		52.0 %
10/05/2022	0959	H	25.0	21.0	21.0		84.0 %
10/05/2022	1007	L	25.0	5.5	5.4		22.0 %
10/05/2022	1013	M	25.0	13.0	13.0		52.0 %
10/05/2022	1019	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	**1.8**
M	13.000	13.000	No	**0.0**
H	21.000	21.000	No	**0.0**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT2
Component ID: A21
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrume
Test End Date/Time: 10/04/2022
Scale: High
Performance Spec: 5 %
Test No.: 118
Highest Error: 3.2
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1235	L	200.0	50.3	48.6		25.2 %
10/04/2022	1241	M	200.0	111.2	111.3		55.6 %
10/04/2022	1247	H	200.0	184.2	183.6		92.1 %
10/04/2022	1256	L	200.0	50.3	48.7		25.2 %
10/04/2022	1302	M	200.0	111.2	111.4		55.6 %
10/04/2022	1308	H	200.0	184.2	183.5		92.1 %
10/04/2022	1316	L	200.0	50.3	48.8		25.2 %
10/04/2022	1322	M	200.0	111.2	111.1		55.6 %
10/04/2022	1328	H	200.0	184.2	183.8		92.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.300	48.700	No	**3.2**
M	111.200	111.267	No	**0.1**
H	184.200	183.633	No	**0.3**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Facility Name: COLUSA GENERATION
Component ID: A22
Component Type: O2D
ReasonForTest: QA
Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument
Performance Spec: 5 %
Test End Date/Time: 10/04/2022
Test No.: 119
Status (Pass/Fail): **Passed**
Scale: High
Highest Error: 1.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0951	L	25.0	5.5	5.6		22.0 %
10/04/2022	0957	M	25.0	13.0	13.1		52.0 %
10/04/2022	1003	H	25.0	21.1	21.1		84.4 %
10/04/2022	1012	L	25.0	5.5	5.6		22.0 %
10/04/2022	1018	M	25.0	13.0	13.1		52.0 %
10/04/2022	1024	H	25.0	21.1	21.1		84.4 %
10/04/2022	1032	L	25.0	5.5	5.6		22.0 %
10/04/2022	1038	M	25.0	13.0	13.1		52.0 %
10/04/2022	1044	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.600	No	**1.8**
M	13.000	13.100	No	**0.8**
H	21.100	21.100	No	**0.0**

ATTACHMENT 12
Startup/Shutdown Emissions

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.6		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	132.8		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	107.0		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	118.6		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	0.7		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	125.2		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.2		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	10.0		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	2.2		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	161.9		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.5		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	158.4		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.6		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	101.1		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.6		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	127.1		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	0.8		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	110.4		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	142.4		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.3		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	132.2		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.4		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	133.8		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.0		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	100.1		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.7		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:07 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,674.85 Hours
Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	2.9	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.9 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	64.9	0	1	0	0	0
10/03/2022 03:00	41.0	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	105.9 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.4	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	3.9	0	0	1	0	0
10/09/2022 11:00	60.0	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.3 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	2.6	0	0	0	1	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	63.7	0	1	0	0	0
Average/Sum#:	63.7 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.7	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	60.9	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.9 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	2.9	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	0.0	0	1	0	0	0
10/24/2022 13:00	74.5	0	1	0	0	0
10/24/2022 14:00	10.2	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.7 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	2.0	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	2.2	0	1	0	1	0
10/26/2022 17:00	25.5	0	1	0	0	0
10/26/2022 18:00	121.7	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	1.4	0	0	0	1	0
Average/Sum#:	152.8 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	121.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	76.7	1	0	0	0	0
10/31/2022 02:00	75.6	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	152.3 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	3.1	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	4.7	0	0	1	0	0
11/05/2022 14:00	70.1	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.9 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	3.2	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.2 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	45.1	0	1	0	0	0
11/07/2022 04:00	68.6	0	1	0	0	0
11/07/2022 05:00	0.2	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	113.9 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	1.8	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	0.1	0	0	1	0	0
11/22/2022 12:00	79.3	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	81.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	79.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.6	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	67.6	0	1	0	0	0
11/28/2022 03:00	45.0	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	112.6 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	0.5	1	0	0	0	0
12/05/2022 10:00	89.5	1	0	0	0	0
12/05/2022 11:00	1.8	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.8 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	89.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	2.6	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	50.3	0	1	0	0	0
12/26/2022 01:00	65.3	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	3.2	0	0	0	1	0
Average/Sum#:	118.8 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	43.9	0	0	1	0	0
12/27/2022 06:00	26.1	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	3.1	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	36.5	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.5 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	2,638.8	0	1	0	0	0
10/03/2022 03:00	5,327.7	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,966.5 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,327.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	23.5	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	436.6	0	0	1	0	0
10/09/2022 11:00	5,985.6	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,445.7 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,985.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	60.0	0	0	0	1	0
Average/Sum#:	60.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	1,470.4	0	1	0	0	0
Average/Sum#:	1,470.4 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,470.4	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	5,643.6	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,643.6 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,643.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	41.4	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	41.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	1.8	0	1	0	0	0
10/24/2022 13:00	4,132.2	0	1	0	0	0
10/24/2022 14:00	3,375.0	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,509.0 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,132.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	14.0	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	731.0	0	1	0	1	0
10/26/2022 17:00	2,008.0	0	1	0	0	0
10/26/2022 18:00	7,703.1	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	32.1	0	0	0	1	0
Average/Sum#:	10,488.2 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,703.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	2,781.8	1	0	0	0	0
10/31/2022 02:00	6,723.1	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,504.9 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,723.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	34.3	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	373.1	0	0	1	0	0
11/05/2022 14:00	5,690.1	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,097.5 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,690.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	37.3	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	37.3 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	1,072.5	0	1	0	0	0
11/07/2022 04:00	5,239.8	0	1	0	0	0
11/07/2022 05:00	1,312.3	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,624.6 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,239.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	49.0	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	64.5	0	0	1	0	0
11/22/2022 12:00	6,557.8	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,671.3 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,557.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	36.3	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.3 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	3,120.1	0	1	0	0	0
11/28/2022 03:00	5,426.8	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,546.9 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,426.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	16.7	0	0	0	1	0
Average/Sum#:	16.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	2.1	1	0	0	0	0
12/05/2022 10:00	4,500.1	1	0	0	0	0
12/05/2022 11:00	3,428.2	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,930.4 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,500.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	23.3	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	23.3 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	2,012.2	0	1	0	0	0
12/26/2022 01:00	6,013.2	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	58.9	0	0	0	1	0
Average/Sum#:	8,084.3 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,013.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	2,076.7	0	0	1	0	0
12/27/2022 06:00	3,928.5	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,005.2 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,928.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	42.7	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	42.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	1.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	51.5	0	1	0	0	0
10/03/2022 03:00	25.0	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.5 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	0.7	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.3	0	0	1	0	0
10/09/2022 11:00	29.9	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	27.5	0	1	0	0	0
Average/Sum#:	27.5 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.5	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	54.8	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.8 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.0	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	0.0	0	1	0	0	0
10/24/2022 13:00	85.5	0	1	0	0	0
10/24/2022 14:00	14.0	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	99.5 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	85.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	0.8	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	2.1	0	1	0	1	0
10/26/2022 17:00	44.8	0	1	0	0	0
10/26/2022 18:00	77.8	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	0.7	0	0	0	1	0
Average/Sum#:	126.2 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	57.5	1	0	0	0	0
10/31/2022 02:00	45.7	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.2 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	0.8	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	2.8	0	0	1	0	0
11/05/2022 14:00	82.4	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	86.0 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	82.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	0.5	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	19.7	0	1	0	0	0
11/07/2022 04:00	66.4	0	1	0	0	0
11/07/2022 05:00	0.9	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.0 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.9	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	0.0	0	0	1	0	0
11/22/2022 12:00	38.9	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.8 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.0	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	63.5	0	1	0	0	0
11/28/2022 03:00	29.8	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.3 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.6	0	0	0	1	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	0.0	1	0	0	0	0
12/05/2022 10:00	73.8	1	0	0	0	0
12/05/2022 11:00	4.8	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.6 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	0.8	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	41.5	0	1	0	0	0
12/26/2022 01:00	41.8	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	84.1 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	11.3	0	0	1	0	0
12/27/2022 06:00	10.7	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	22.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	0.8	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.9	483.5		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	94.1	790.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.6	483.5		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	65.7	679.6		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.3	483.5		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	109.4	790.5		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	1.2	483.5		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	77.8	790.5		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.2	483.5		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	9.9	790.5		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	1.4	483.5		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	140.4	790.5		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.7	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	128.4	1,355.6		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7	483.5		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	72.6	679.6		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.8	483.5		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	103.4	790.5		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	1.1	483.5		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	76.4	679.6		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6	483.5		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	104.2	790.5		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4	483.5		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	89.2	1,355.6		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5	483.5		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	110.1	790.5		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	94.4	679.6		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.9	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:14 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours
Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.12	115.00		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	80.91	456.20		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.06	115.00		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	33.46	259.90		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	0.18	115.00		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	80.84	456.20		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	0.17	115.00		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	109.07	456.20		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.05	115.00		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	11.10	456.20		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	3.41	115.00		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	119.34	456.20		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.15	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	101.63	779.10		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.15	115.00		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	78.75	259.90		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.07	115.00		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	85.84	456.20		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	0.21	115.00		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	39.78	259.90		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.14	115.00		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	98.73	456.20		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.06	115.00		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	77.86	779.10		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.08	115.00		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	87.99	456.20		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.19	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	30.69	259.90		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.12	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.6		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	193.9		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.8		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	189.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	113.1		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	233.5		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.5		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	188.2		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.6		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	273.2		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:17 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	188.4		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.3		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	119.1		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	208.2		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	105.2		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	203.1		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.2		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	97.2		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.6		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	2.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	20.0	0	1	0	0	0
10/01/2022 13:00	16.4	0	1	0	0	0
10/01/2022 14:00	30.4	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	71.5 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	39.8	0	1	0	0	0
10/02/2022 12:00	23.7	0	1	0	0	0
10/02/2022 13:00	39.5	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.0 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.7	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	23.1	0	0	1	0	0
10/09/2022 15:00	16.4	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.2 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	74.6	0	1	0	0	0
10/16/2022 18:00	60.3	0	1	0	0	0
10/16/2022 19:00	62.1	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	197.0 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.9	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	62.4	0	1	0	0	0
10/23/2022 21:00	20.7	0	1	0	0	0
10/23/2022 22:00	35.9	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	119.0 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	2.0	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	25.9	1	0	0	0	0
10/30/2022 20:00	49.9	1	0	0	0	0
10/30/2022 21:00	53.1	1	0	0	0	0
10/30/2022 22:00	80.1	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	209.0 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	2.4	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	40.9	0	1	0	0	0
11/06/2022 10:00	26.8	0	1	0	0	0
11/06/2022 11:00	66.6	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	1.0	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	135.3 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	9.5	0	0	1	0	0
11/07/2022 01:00	56.2	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.7 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.2	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.0	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	56.5	0	1	0	0	0
11/27/2022 22:00	21.0	0	1	0	0	0
11/27/2022 23:00	57.9	0	1	0	0	0
Average/Sum#:	135.4 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.9	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	8.0	0	0	1	0	0
12/01/2022 03:00	34.5	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.5 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	1.9	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	43.8	0	1	0	0	0
12/25/2022 19:00	25.3	0	1	0	0	0
12/25/2022 20:00	49.4	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	120.4 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	2.1	0	0	0	1	0
Average/Sum#:	2.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	1.6	0	0	1	0	0
12/27/2022 02:00	36.4	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.0 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	2.4	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	33.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	2,122.5	0	1	0	0	0
10/01/2022 13:00	3,619.2	0	1	0	0	0
10/01/2022 14:00	5,890.9	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	48.7	0	0	0	1	0
Average/Sum#:	11,714.3 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,890.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	1,996.4	0	1	0	0	0
10/02/2022 12:00	3,888.4	0	1	0	0	0
10/02/2022 13:00	5,484.2	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,369.0 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,484.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	24.2	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	2,647.3	0	0	1	0	0
10/09/2022 15:00	4,141.6	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,813.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,141.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	61.3	0	0	0	1	0
Average/Sum#:	61.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	2,316.6	0	1	0	0	0
10/16/2022 18:00	5,522.9	0	1	0	0	0
10/16/2022 19:00	6,173.3	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,012.8 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,173.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	31.4	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	31.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	2,048.4	0	1	0	0	0
10/23/2022 21:00	3,564.8	0	1	0	0	0
10/23/2022 22:00	5,679.3	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,292.5 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,679.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	37.4	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	37.4 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	316.2	1	0	0	0	0
10/30/2022 20:00	3,585.6	1	0	0	0	0
10/30/2022 21:00	5,409.9	1	0	0	0	0
10/30/2022 22:00	7,082.4	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,394.1 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,082.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	41.2	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	41.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	864.9	0	1	0	0	0
11/06/2022 10:00	3,630.7	0	1	0	0	0
11/06/2022 11:00	6,809.7	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	18.5	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,323.8 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,809.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	1,351.8	0	0	1	0	0
11/07/2022 01:00	5,792.9	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,144.7 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,792.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	33.4	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	33.4 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	2,205.7	0	1	0	0	0
11/27/2022 22:00	3,787.1	0	1	0	0	0
11/27/2022 23:00	6,500.0	0	1	0	0	0
Average/Sum#:	12,492.8 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,500.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	25.2	0	0	0	1	0
Average/Sum#:	25.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	1,348.3	0	0	1	0	0
12/01/2022 03:00	4,961.0	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,309.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,961.0	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	30.5	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	2,368.1	0	1	0	0	0
12/25/2022 19:00	3,933.6	0	1	0	0	0
12/25/2022 20:00	5,883.9	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,216.1 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,883.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	69.9	0	0	0	1	0
Average/Sum#:	69.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	379.4	0	0	1	0	0
12/27/2022 02:00	5,452.8	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,832.2 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,452.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	38.8	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	38.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	1.2	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	38.8	0	1	0	0	0
10/01/2022 13:00	22.6	0	1	0	0	0
10/01/2022 14:00	43.1	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	0.6	0	0	0	1	0
Average/Sum#:	106.3 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	34.8	0	1	0	0	0
10/02/2022 12:00	19.8	0	1	0	0	0
10/02/2022 13:00	28.9	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	83.5 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.1	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	32.9	0	0	1	0	0
10/09/2022 15:00	20.9	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.9 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	44.1	0	1	0	0	0
10/16/2022 18:00	47.1	0	1	0	0	0
10/16/2022 19:00	34.2	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.4 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.1	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	44.9	0	1	0	0	0
10/23/2022 21:00	32.6	0	1	0	0	0
10/23/2022 22:00	36.8	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.3 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	0.8	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	3.8	1	0	0	0	0
10/30/2022 20:00	65.6	1	0	0	0	0
10/30/2022 21:00	40.0	1	0	0	0	0
10/30/2022 22:00	53.7	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	163.1 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	1.8	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	15.5	0	1	0	0	0
11/06/2022 10:00	43.8	0	1	0	0	0
11/06/2022 11:00	40.4	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	0.8	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	100.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	2.8	0	0	1	0	0
11/07/2022 01:00	29.6	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.4 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.1	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	47.2	0	1	0	0	0
11/27/2022 22:00	34.9	0	1	0	0	0
11/27/2022 23:00	39.9	0	1	0	0	0
Average/Sum#:	122.0 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.2	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	2.4	0	0	1	0	0
12/01/2022 03:00	17.2	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	19.6 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.2	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	1.2	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	48.0	0	1	0	0	0
12/25/2022 19:00	23.8	0	1	0	0	0
12/25/2022 20:00	30.9	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.9 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	1	0	0
12/27/2022 02:00	21.1	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	21.1 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.1	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	1.2	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.7	483.5		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	66.7	790.5		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.9	483.5		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	97.2	790.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4	483.5		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	46.5	679.6		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0	483.5		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	189.3	790.5		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.6	483.5		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	109.4	790.5		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.6	483.5		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	199.7	1,355.6		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	120.1	790.5		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.3	483.5		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	71.8	679.6		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.4	483.5		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	123.1	790.5		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4	483.5		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	52.1	679.6		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5	483.5		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	108.3	790.5		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.9	483.5		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	38.3	679.6		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.7	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.18	115.00		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	108.24	456.20		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.13	115.00		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	86.43	456.20		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.13	115.00		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	64.82	259.90		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	0.32	115.00		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	129.10	456.20		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.16	115.00		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	117.64	456.20		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.17	115.00		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	169.89	779.10		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.22	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	96.58	456.20		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.05	115.00		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	37.00	259.90		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.21	115.00		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	124.17	456.20		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.16	115.00		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	25.11	259.90		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.18	115.00		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	104.88	456.20		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.41	115.00		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	22.34	259.90		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.22	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/01/2022 02:00	10/03/2022 01:00	48
10/09/2022 07:00	10/09/2022 09:00	3
10/15/2022 00:00	10/16/2022 22:00	47
10/21/2022 23:00	10/24/2022 11:00	61
10/26/2022 09:00	10/26/2022 15:00	7
10/27/2022 00:00	10/31/2022 00:00	97
11/05/2022 08:00	11/05/2022 12:00	5
11/06/2022 03:00	11/07/2022 02:00	24
11/22/2022 10:00	11/22/2022 10:00	1
11/26/2022 03:00	11/28/2022 01:00	47
12/01/2022 00:00	12/05/2022 08:00	105
12/25/2022 02:00	12/25/2022 23:00	22
12/27/2022 00:00	12/27/2022 04:00	5
12/30/2022 01:00	12/31/2022 23:00	47

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	519.00 Hour(s)
Offline Percentage:	23.51 %
Total Online:	1,689.00 Hour(s)
Online Percentage:	76.49 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/03/2022 02:00	10/03/2022 03:00	Warm Startup	2
2	10/09/2022 10:00	10/09/2022 11:00	Hot Startup	2
3	10/16/2022 23:00	10/17/2022 00:00	Warm Startup	2
4	10/24/2022 12:00	10/24/2022 14:00	Warm Startup	3
5	10/26/2022 16:00	10/26/2022 18:00	Warm Startup	3
6	10/31/2022 01:00	10/31/2022 02:00	Cold Startup	2
7	11/05/2022 13:00	11/05/2022 14:00	Hot Startup	2
8	11/07/2022 03:00	11/07/2022 05:00	Warm Startup	3
9	11/22/2022 11:00	11/22/2022 12:00	Hot Startup	2
10	11/28/2022 02:00	11/28/2022 03:00	Warm Startup	2
11	12/05/2022 09:00	12/05/2022 11:00	Cold Startup	3
12	12/26/2022 00:00	12/26/2022 01:00	Warm Startup	2
13	12/27/2022 05:00	12/27/2022 06:00	Hot Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	5	0.30
Hot Startup/Startup Shutdown Event Text 02 Add	4	8	0.47
Warm Startup	7	17	1.01
Total Process Events:	13	30	1.78

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,689 Hour(s)
Total Startup Time:	30 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	30 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.78 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/01/2022 02:00	10/01/2022 11:00	10
10/02/2022 00:00	10/02/2022 10:00	11
10/09/2022 07:00	10/09/2022 13:00	7
10/15/2022 00:00	10/16/2022 16:00	41
10/21/2022 23:00	10/23/2022 19:00	45
10/24/2022 15:00	10/30/2022 18:00	148
11/05/2022 08:00	11/06/2022 08:00	25
11/06/2022 22:00	11/06/2022 23:00	2
11/26/2022 03:00	11/27/2022 20:00	42
12/01/2022 00:00	12/01/2022 01:00	2
12/25/2022 02:00	12/25/2022 17:00	16
12/27/2022 00:00	12/27/2022 00:00	1
12/30/2022 01:00	12/31/2022 23:00	47

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	397.00 Hour(s)
Offline Percentage:	17.98 %
Total Online:	1,811.00 Hour(s)
Online Percentage:	82.02 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2022 12:00	10/01/2022 14:00	Warm startup	3
2	10/02/2022 11:00	10/02/2022 13:00	Warm startup	3
3	10/09/2022 14:00	10/09/2022 15:00	Hot Startup	2
4	10/16/2022 17:00	10/16/2022 19:00	Warm startup	3
5	10/23/2022 20:00	10/23/2022 22:00	Warm startup	3
6	10/30/2022 19:00	10/30/2022 22:00	Cold Startup	4
7	11/06/2022 09:00	11/06/2022 11:00	Warm startup	3
8	11/07/2022 00:00	11/07/2022 01:00	Hot Startup	2
9	11/27/2022 21:00	11/27/2022 23:00	Warm startup	3
10	12/01/2022 02:00	12/01/2022 03:00	Hot Startup	2
11	12/25/2022 18:00	12/25/2022 20:00	Warm startup	3
12	12/27/2022 01:00	12/27/2022 02:00	Hot Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	4	0.22
Hot Startup	4	8	0.44
Warm startup	7	21	1.16
Total Process Events:	12	33	1.82

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,811 Hour(s)
Total Startup Time:	33 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	33 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.82 %

ATTACHMENT 13
Water Bath Heater Operations

The Natural Gas Fired Water Bath Heater did not operate in the 4th Quarter of 2022.

ATTACHMENT 14
Toxics GHG Tracking

TOXICS TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2022

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test*	11.1	11.1	55544.40	27.772
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test*	0.022	0.022	110.09	0.055
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test*	2.6	2.6	12589.20	6.295
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test*	0.023	0.023	111.37	0.056
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	2.04	0.001
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.580	2196.93	1.098
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.080	303.08	0.152
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.056	213.28	0.107
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.076	287.04	0.144
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.097	4153.32	2.077
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.264	12363.76	6.182
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.202	766.52	0.383
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.301	1138.56	0.569
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.111	418.54	0.209
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.007	26.62	0.013
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	2.10	0.001

Total Turbines/HRSGs

Fuel Use Rate Data

NG HHV	1040	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.2338	mmscf	(for both units)
Annual Fuel Use	16036.00	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4403.15	mmbtu	(for both units)
Annual Heat Rate	16677440.0	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	5004	Hrs/Yr	
Unit #2 Annual Ops Hrs	4842	Hrs/Yr	
Total Hrs, All Units	9846	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	8155	mmscf	
CT2 Annual Fuel Use	7881	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0000	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0000	0.000	0.0000

Total FG Heater

Fuel Use Rate Data

NG HHV	1040	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00000	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	0.00	mmbtu
Annual Heat Rate	0.00	mmbtu

*Testing conducted Oct 11-14

Reporting Quarter 4

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Toxics Plan:

1. perform annual testing for ammonia per CCAPCD Permit Condition #9 (3-2-09)
2. perform annual testing for formaldehyde per CCAPCD Permit Condition #9 (3-2-09)
3. comply with all other provisions of CCAPCD Permit Condition #9 (3-2-09)
4. quantify other identified toxic pollutants via the emissions factors delineated in the AFC Appendix L (Public Health)
5. report toxic emissions to the CCAPCD annually and show compliance with CCAPCD Permit Condition #28 (3-2-09)

Data and Source References:

1. CGS plant and operational data (CEMS, DAHS, purchase records, and ops logs)
2. CCAR General Protocol, Version 3.1, January 2009.
3. CCAR Power Sector Protocol, Version 1.1, May 2009.
4. Other references as noted on the calculation tab.

Public

ATTACHMENT 15
Title V Certification Forms

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): October 1 - December 31, 2022
2. Due date for submittal of report: January 30, 2023

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)

ATTACHMENT 1
Complaints

During the fourth quarter of 2022, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

2022 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22	Avg
Gr/100SCF	0.202	0.149	OUTAGE	0.285	0.486	0.118	0.180	0.110	0.145	0.183	0.229	0.164	0.205

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V #17)

Atmospheric Analysis & Consulting, Inc

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 222151
REPORT DATE : 10/26/2022

On October 13, 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Oct-A	222151-37208	680.9

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Environmental Services
PROJECT NO. : 222151

SAMPLING DATE : 10/12/2022
ANALYSIS DATE : 10/19-24/2022

	Client ID:	CPP-GS-Oct-A			
	AAC ID:	222151-37208			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 2.25	2.25	< 0.002	0.002
	O_2	2.98	0.225	5.12	0.004
	N_2	12.4	0.225	18.7	0.003
	CO	< 0.225	0.225	< 0.003	0.003
	CO_2	0.603	0.225	1.42	0.005
	CH_4	80.8	0.00011	69.5	0.009
	He	NM	NM	NM	NM
	Ar	< 0.225	0.225	< 0.004	0.004
HYDROCARBONS	C_2 (as Ethane)	3.14	0.00056	5.07	0.0008
	C_3 (as Propane)	0.0510	0.00011	0.121	0.0002
	C_4 (as Butane)	0.00942	0.00011	0.0294	0.0003
	C_5 (as Pentane)	0.00274	0.00011	0.0106	0.0004
	C_6 (as Hexane)	0.00082	0.00011	0.0038	0.0005
	C_{6+} (as Hexane)	0.00303	0.00011	0.0140	0.0005
TRS	Total Reduced Sulfur	0.000288	0.0000022	0.000526	0.000004
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	17780
Carbon (C)	56.6	*LHV Btu/lb*	16025
Hydrogen (H)	18.5	*HHV Btu/dscf*	873
Oxygen (O)	6.2	*LHV Btu/dscf*	787
Nitrogen (N)	18.7	*F-Factor*	8653
Helium (He)	0.00	*Relative Density*	0.6436
Argon (Ar)	0.00	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	18.639
Motor Octane Number	131.79	*Methane Number*	94.93
		Wobbe Number	1088.531

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 222151
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 10/12/2022
ANALYSIS DATE : 10/14/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Oct-A
AAC ID	222151-37208
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.822**
COS / SO2	**1.01**
Methyl Mercaptan	< 0.112
Ethyl Mercaptan	< 0.112
Dimethyl Sulfide	< 0.112
Carbon Disulfide	< 0.112
Isopropyl Mercaptan	< 0.112
tert-Butyl Mercaptan	< 0.112
n-Propyl Mercaptan	< 0.112
Methylethylsulfide	< 0.112
sec-Butyl Mercaptan / Thiophene	< 0.112
iso-Butyl Mercaptan	< 0.112
Diethyl Sulfide	< 0.112
n-Butyl Mercaptan	< 0.112
Dimethyl Disulfide	< 0.112
2-Methylthiophene	< 0.112
3-Methylthiophene	< 0.112
Tetrahydrothiophene	**0.813**
Bromothiophene	< 0.112
Thiophenol	< 0.112
Diethyl Disulfide	< 0.112
Total Unidentified Sulfur	**1.37**
Total Reduced Sulfurs	**3.01**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 222151
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 10/12/2022
RECEIVING DATE : 10/13/2022
ANALYSIS DATE : 10/14/2022
REPORT DATE : 10/26/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Oct-A
AAC ID	222151-37208
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.0501**
COS / SO2	**0.0616**
Methyl Mercaptan	< 0.00685
Ethyl Mercaptan	< 0.00685
Dimethyl Sulfide	< 0.00685
Carbon Disulfide	< 0.00685
Isopropyl Mercaptan	< 0.00685
tert-Butyl Mercaptan	< 0.00685
n-Propyl Mercaptan	< 0.00685
Methylethylsulfide	< 0.00685
sec-Butyl Mercaptan / Thiophene	< 0.00685
iso-Butyl Mercaptan	< 0.00685
Diethyl Sulfide	< 0.00685
n-Butyl Mercaptan	< 0.00685
Dimethyl Disulfide	< 0.00685
2-Methylthiophene	< 0.00685
3-Methylthiophene	< 0.00685
Tetrahydrothiophene	**0.0495**
Bromothiophene	< 0.00685
Thiophenol	< 0.00685
Diethyl Disulfide	< 0.00685
Total Unidentified Sulfur	**0.0837**
Total Reduced Sulfurs	**0.183**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 10/19/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	9.9	10.1	23.0	10.7	9.6	10.2
	% Rec *	99.7	98.2	111.9	106.8	95.6	102.7

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	9.8	10.1	22.7	10.8	9.8	10.3
	LCSD Result	9.9	10.3	22.8	10.6	9.6	10.3
	LCS % Rec *	99.1	97.6	110.7	107.7	97.6	103.3
	LCSD % Rec *	99.6	99.7	111.0	106.6	95.9	103.4
	% RPD ***	0.5	2.2	0.3	1.0	1.7	0.1

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
222142-37178	Sample	0.0	0.4	4.6	31.4	0.0	21.4
	Sample Dup	0.0	0.4	4.5	31.1	0.0	21.3
	Mean	0.0	0.4	4.5	31.3	0.0	21.3
	% RPD ***	0.0	0.0	1.6	0.9	0.0	0.5

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
222142-37178	Sample Conc	0.0	2.3	15.6	0.0	10.7
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.2	13.1	26.4	9.7	21.2
	MSD Result	10.3	13.6	26.0	9.9	21.0
	MS % Rec **	102.5	107.4	107.3	97.4	105.2
	MSD % Rec **	104.4	111.9	104.1	99.3	103.9
	% RPD ***	1.8	4.2	3.0	1.9	1.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.1	9.9	22.0	10.9	9.7	10.5
	% Rec *	102.3	95.8	107.1	108.7	96.7	105.7

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 10/24/2022
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	94.8	94.9	93.4	95.4	97.2	99.6
	% Rec *	95.9	95.7	94.7	97.3	99.0	99.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	97.3	97.5	95.3	97.3	101.3	102.5
	LCSD Result	97.1	96.7	95.6	97.7	99.6	101.8
	LCS % Rec *	98.4	98.4	96.6	99.2	103.3	102.7
	LCSD % Rec *	98.2	97.5	96.8	99.6	101.5	102.1
	% RPD ***	0.2	0.8	0.2	0.4	1.8	0.6

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	49.6	49.2	47.9	49.1	50.8	51.5
	MSD Result	56.1	55.0	54.4	55.3	56.8	58.2
	MS % Rec **	100.4	99.2	97.1	100.1	103.4	103.2
	MSD % Rec **	113.5	111.0	110.3	112.7	115.8	116.8
	% RPD ***	12.2	11.2	12.8	11.8	11.3	12.3

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	96.3	96.3	94.7	97.4	101.6	105.2
	% Rec *	97.4	97.2	95.9	99.3	103.5	105.5

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 10/14/2022
Analyst: ZD
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

499.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1844	500	100.1	0.8
Duplicate	1860	505	101.0	0.1
Triplicate	1872	508	101.6	0.7

547.5 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2332	541	98.8	2.3
Duplicate	2410	559	102.1	0.9
Triplicate	2421	561	102.5	1.4

479.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2480	469	97.9	1.1
Duplicate	2559	484	101.0	2.0
Triplicate	2484	470	98.0	0.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 220521-28941

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 220521-28941

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	249.9	252.8	258.7	101.2	103.5	2.3
MeSH	<PQL	273.8	287.2	281.6	104.9	102.9	2.0
DMS	<PQL	239.5	240.0	242.9	100.2	101.4	1.2

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	499.8	537.0	107.5
MeSH	547.5	570.1	104.1
DMS	479.0	506.0	105.6

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

222151

Fuel Gas Sampling

Client: PG&E Colusa Generating Station		Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd		Telephone Number: 53-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA / Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling		Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504	Preparation and Analysis: BTU
CPP-GS-Oct-A	37208	12-Oct-2022	0930	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other _____	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	12-Oct-2022	1500 hrs	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	10/13/22	0857

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS

Internal

1x 1.4L can

Atmospheric Analysis & Consulting, Inc

CLIENT	: PG&E Colusa Generating Sampling
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 222338
REPORT DATE	: 11/21/2022

On November 8th 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canisters for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned unique Laboratory ID numbers as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Nov-A	222338-38028	752.3

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of these samples. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/18/2022

	Client ID:	CPP-GS-Nov-A			
	AAC ID:	222338-38028			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 1.47	1.47	< 0.002	0.002
	O_2	0.394	0.147	0.723	0.002
	N_2	2.23	0.147	3.58	0.002
	CO	< 0.147	0.147	< 0.002	0.002
	CO_2	0.779	0.147	1.97	0.003
	CH_4	91.0	0.00007	83.8	0.006
	He	NM	NM	NM	NM
	Ar	< 0.147	0.147	< 0.003	0.003
HYDROCARBONS	C_2 (as Ethane)	5.20	0.00037	8.96	0.0006
	C_3 (as Propane)	0.273	0.00007	0.690	0.0002
	C_4 (as Butane)	0.0655	0.00007	0.218	0.0002
	C_5 (as Pentane)	0.0133	0.00007	0.0551	0.0003
	C_6 (as Hexane)	0.00197	0.00007	0.0098	0.0003
	C_{6+} (as Hexane)	0.00350	0.00007	0.0173	0.0003
TRS	Total Reduced Sulfur	0.000375	0.0000015	0.000732	0.000003

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	22231
Carbon (C)	71.2	*LHV Btu/lb*	20043
Hydrogen (H)	23.0	*HHV Btu/dscf*	1021
Oxygen (O)	2.2	*LHV Btu/dscf*	921
Nitrogen (N)	3.6	*F-Factor*	8652
Helium (He)	0.00	*Relative Density*	0.6020
Argon (Ar)	0.00	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	17.435
Motor Octane Number	128.64	*Methane Number*	89.81
		Wobbe Number	1316.318

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/10/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Nov-A
AAC ID	222338-38028
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	**1.36**
COS / SO2	**0.463**
Methyl Mercaptan	**0.358**
Ethyl Mercaptan	**0.256**
Dimethyl Sulfide	< 0.074
Carbon Disulfide	< 0.074
Isopropyl Mercaptan	< 0.074
tert-Butyl Mercaptan	**1.08**
n-Propyl Mercaptan	< 0.074
Methylethylsulfide	< 0.074
sec-Butyl Mercaptan / Thiophene	< 0.074
iso-Butyl Mercaptan	< 0.074
Diethyl Sulfide	< 0.074
n-Butyl Mercaptan	< 0.074
Dimethyl Disulfide	< 0.074
2-Methylthiophene	< 0.074
3-Methylthiophene	< 0.074
Tetrahydrothiophene	**0.713**
Bromothiophene	< 0.074
Thiophenol	< 0.074
Diethyl Disulfide	< 0.074
Total Unidentified Sulfur	< 0.074
Total Reduced Sulfurs	**3.77**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 222338
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 11/07/2022
ANALYSIS DATE : 11/10/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Nov-A
AAC ID	222338-38028
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	**0.08267**
COS / SO2	**0.02819**
Methyl Mercaptan	**0.02181**
Ethyl Mercaptan	**0.01562**
Dimethyl Sulfide	< 0.00449
Carbon Disulfide	< 0.00449
Isopropyl Mercaptan	< 0.00449
tert-Butyl Mercaptan	**0.06607**
n-Propyl Mercaptan	< 0.00449
Methylethylsulfide	< 0.00449
sec-Butyl Mercaptan / Thiophene	< 0.00449
iso-Butyl Mercaptan	< 0.00449
Diethyl Sulfide	< 0.00449
n-Butyl Mercaptan	< 0.00449
Dimethyl Disulfide	< 0.00449
2-Methylthiophene	< 0.00449
3-Methylthiophene	< 0.00449
Tetrahydrothiophene	**0.04345**
Bromothiophene	< 0.00449
Thiophenol	< 0.00449
Diethyl Disulfide	< 0.00449
Total Unidentified Sulfur	< 0.00449
Total Reduced Sulfurs	**0.2296**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 11/18/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.1	10.7	23.0	10.7	9.5	10.0
	% Rec *	102.1	103.6	112.3	106.7	95.2	99.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	10.1	10.3	22.7	10.9	9.7	10.5
	LCSD Result	10.3	10.2	22.3	11.1	9.9	10.6
	LCS % Rec *	102.2	99.9	110.8	109.2	97.4	105.0
	LCSD % Rec *	104.4	98.7	108.8	111.3	99.1	106.4
	% RPD ***	2.2	1.2	1.8	1.9	1.8	1.3

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
222334-38014	Sample	0.0	13.5	53.8	0.0	0.0	0.0
	Sample Dup	0.0	13.3	53.3	0.0	0.0	0.0
	Mean	0.0	13.4	53.5	0.0	0.0	0.0
	% RPD ***	0.0	0.9	0.8	0.0	0.0	0.0

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
222334-38014	Sample Conc	0.0	26.8	0.0	0.0	0.0
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.5	38.6	11.0	9.8	10.6
	MSD Result	10.6	37.7	11.3	10.1	10.8
	MS % Rec **	105.7	116.8	110.2	98.0	106.0
	MSD % Rec **	107.2	107.6	112.7	100.5	108.3
	% RPD ***	1.4	8.2	2.3	2.5	2.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	9.9	10.6	23.6	10.3	9.2	9.9
	% Rec *	99.5	102.6	115.0	103.1	92.1	99.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 11/18/2022
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	106.2	105.4	104.3	107.2	109.2	110.6
	% Rec *	107.4	106.3	105.6	109.3	111.3	110.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	88.2	87.9	87.0	88.6	92.2	93.5
	LCSD Result	93.1	93.5	92.0	94.6	97.1	98.1
	LCS % Rec *	89.2	88.7	88.2	90.3	93.9	93.7
	LCSD % Rec *	94.1	94.3	93.3	96.5	98.9	98.3
	% RPD ***	5.4	6.1	5.6	6.6	5.2	4.8

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29439	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	48.7	48.0	47.2	47.8	49.1	49.5
	MSD Result	47.5	46.8	46.2	46.9	48.0	48.7
	MS % Rec **	98.6	96.9	95.6	97.5	100.2	99.2
	MSD % Rec **	96.2	94.5	93.5	95.6	97.8	97.7
	% RPD ***	2.5	2.5	2.2	1.9	2.4	1.5

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	95.2	93.8	92.1	94.9	97.8	101.1
	% Rec *	96.3	94.7	93.3	96.7	99.7	101.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 11/10/2022
Analyst: ZD
Units: ppmV

Instrument ID: SCD-BTU
Calb. Date: 10/21/2021

Opening Calibration Verification Standard

0.500 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1115	0.508	101.6	1.6
Duplicate	1075	0.489	97.9	2.1
Triplicate	1103	0.502	100.5	0.5

0.548 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1235	0.560	102.3	0.9
Duplicate	1218	0.553	100.9	0.5
Triplicate	1220	0.553	101.1	0.4

0.479 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1186	0.489	102.1	0.7
Duplicate	1135	0.468	97.7	3.6
Triplicate	1213	0.500	104.4	2.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 220521-28939

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.000	0.0
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate Sample ID x2

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	0.250	0.231	0.251	92.4	100.5	8.3
MeSH	<PQL	0.274	0.262	0.267	95.7	97.5	1.9
DMS	<PQL	0.240	0.238	0.251	99.4	104.8	5.3

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.500	0.502	102.9
MeSH	0.548	0.561	96.4
DMS	0.479	0.491	102.9

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

PQL = 50.0 ppbV
MDL = 1.1 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

222338

Fuel Gas Sampling

Client: PG&E Colusa Generating Station		Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd		Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA	Zip: 95955	Site Contacat:	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling		Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504	Preparation and Analysis: BTU
CPP-GS-Nov-A	38028	7-Nov-2022	1000	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other _____	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	7-Nov-2022	1500 hrs	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	11/8/22	1015

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1 x 1.4L can

Atmospheric Analysis & Consulting, Inc

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 230002
REPORT DATE	: 01/12/2023

On January 2nd, 2023, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-Dec-A	230002-39621	737.7

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. Sample was received past the recommended hold time of seven days for sulfur analysis. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 230002

SAMPLING DATE : 12/21/2023
ANALYSIS DATE : 01/09/2023

	Client ID:	CPP-GS-Dec-A			
	AAC ID:	230002-39621			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 1.52	1.52	< 0.001	0.001
	O_2	2.99	0.152	4.99	0.002
	N_2	13.3	0.152	19.4	0.002
	CO	< 0.152	0.152	< 0.002	0.002
	CO_2	0.698	0.152	1.60	0.003
	CH_4	77.4	0.00008	64.7	0.006
	He	NM	NM	NM	NM
	Ar	0.160	0.152	0.332	0.003
HYDROCARBONS	C_2 (as Ethane)	4.93	0.00038	7.72	0.0006
	C_3 (as Propane)	0.352	0.00008	0.809	0.0002
	C_4 (as Butane)	0.0870	0.00008	0.263	0.0002
	C_5 (as Pentane)	0.0206	0.00008	0.0775	0.0003
	C_6 (as Hexane)	0.00530	0.00008	0.0238	0.0003
	C_{6+} (as Hexane)	0.00711	0.00008	0.0319	0.0003
TRS	Total Reduced Sulfur	0.000177	0.0000015	0.000314	0.000002
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	17442
Carbon (C)	56.0	*LHV Btu/lb*	15726
Hydrogen (H)	18.0	*HHV Btu/dscf*	882
Oxygen (O)	6.2	*LHV Btu/dscf*	796
Nitrogen (N)	19.4	*F-Factor*	8672
Helium (He)	0.00	*Relative Density*	0.6629
Argon (Ar)	0.33	*C2-C6+ Weight %*	0.0000
Sulfur (S)	0.00	*MW lb/lb-mole*	19.197
Motor Octane Number	127.31	*Methane Number*	87.66
		Wobbe Number	1083.682

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : **PG&E**
PROJECT NO. : **230002**
MATRIX : **AIR**
UNITS : **ppmV**

SAMPLING DATE : **12/21/2023**
ANALYSIS DATE : **01/03/2023**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Dec-A
AAC ID	230002-39621
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	< 0.076
COS / SO2	**0.719**
Methyl Mercaptan	< 0.076
Ethyl Mercaptan	< 0.076
Dimethyl Sulfide	< 0.076
Carbon Disulfide	< 0.076
Isopropyl Mercaptan	< 0.076
tert-Butyl Mercaptan	**0.471**
n-Propyl Mercaptan	< 0.076
Methylethylsulfide	< 0.076
sec-Butyl Mercaptan / Thiophene	< 0.076
iso-Butyl Mercaptan	< 0.076
Diethyl Sulfide	< 0.076
n-Butyl Mercaptan	< 0.076
Dimethyl Disulfide	< 0.076
2-Methylthiophene	< 0.076
3-Methylthiophene	< 0.076
Tetrahydrothiophene	**1.15**
Bromothiophene	< 0.076
Thiophenol	< 0.076
Diethyl Disulfide	< 0.076
Total Unidentified Sulfur	**0.231**
Total Reduced Sulfurs	**1.86**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT : **PG&E**
PROJECT NO. : **230002**
MATRIX : **AIR**
UNITS : **grains/100 dscf**

SAMPLING DATE : **12/21/2023**
ANALYSIS DATE : **01/03/2023**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-Dec-A
AAC ID	230002-39621
Canister Dil. Fac.	1.5
Analyte	Result
Hydrogen Sulfide	< 0.00463
COS / SO2	**0.04381**
Methyl Mercaptan	< 0.00463
Ethyl Mercaptan	< 0.00463
Dimethyl Sulfide	< 0.00463
Carbon Disulfide	< 0.00463
Isopropyl Mercaptan	< 0.00463
tert-Butyl Mercaptan	**0.02869**
n-Propyl Mercaptan	< 0.00463
Methylethylsulfide	< 0.00463
sec-Butyl Mercaptan / Thiophene	< 0.00463
iso-Butyl Mercaptan	< 0.00463
Diethyl Sulfide	< 0.00463
n-Butyl Mercaptan	< 0.00463
Dimethyl Disulfide	< 0.00463
2-Methylthiophene	< 0.00463
3-Methylthiophene	< 0.00463
Tetrahydrothiophene	**0.07032**
Bromothiophene	< 0.00463
Thiophenol	< 0.00463
Diethyl Disulfide	< 0.00463
Total Unidentified Sulfur	**0.01405**
Total Reduced Sulfurs	**0.11305**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 01/09/2022
Analyst : CM/KM
Units : %

Instrument ID : TCD #1
Calb Date : 02/01/22
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.0	10.3	23.0	10.8	9.7	10.4
	% Rec *	101.3	100.2	112.4	107.8	96.5	104.2

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	LCS Result	9.9	10.2	23.3	11.0	9.7	10.7
	LCSD Result	10.2	10.4	23.2	10.9	9.7	10.5
	LCS % Rec *	100.1	98.7	113.8	110.0	97.0	107.4
	LCSD % Rec *	103.1	100.5	113.3	108.9	97.2	105.6
	% RPD ***	2.9	1.8	0.5	1.0	0.2	1.7

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
230001-39603	Sample	0.0	7.3	45.8	0.0	0.0	2.6
	Sample Dup	0.0	7.3	45.4	0.0	0.0	2.5
	Mean	0.0	7.3	45.6	0.0	0.0	2.5
	% RPD ***	0.0	0.7	0.9	0.0	0.0	1.8

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
230001-39603	Sample Conc	0.0	22.8	0.0	0.0	1.3
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.0	34.9	10.6	9.6	11.5
	MSD Result	10.3	34.0	10.8	9.8	11.8
	MS % Rec **	101.3	119.6	105.7	95.9	102.9
	MSD % Rec **	103.8	110.6	108.6	97.5	105.9
	% RPD ***	2.4	7.8	2.7	1.7	2.9

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.3	20.5	10.0	10.0	10.0
	Result	10.4	10.0	22.1	11.0	9.9	10.6
	% Rec *	104.8	97.1	107.6	110.3	98.6	106.3

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 01/09/2023
Analyst : CM/KM
Units : ppmv

Instrument ID : FID #3
Calb Date : 02/01/22
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	91.3	91.0	89.8	90.9	91.3	91.3
	% Rec *	92.4	91.9	91.0	92.7	93.1	91.5

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	92.1	90.9	89.8	92.1	94.0	93.8
	LCSD Result	97.9	96.5	95.3	98.0	99.0	98.6
	LCS % Rec *	93.1	91.7	90.9	93.9	95.8	94.0
	LCSD % Rec *	99.0	97.3	96.6	99.9	100.9	98.9
	% RPD ***	6.1	5.9	6.0	6.1	5.2	5.1

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29436	Sample	0.0	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.0	0.0	0.0	0.0	0.0	0.0
	Mean	0.0	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.0	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
220629-29436	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	50.2	48.6	48.2	49.3	50.6	51.9
	MSD Result	49.2	47.3	47.3	48.2	50.5	51.7
	MS % Rec **	101.5	98.1	97.6	100.6	103.1	104.0
	MSD % Rec **	99.5	95.3	95.9	98.2	102.9	103.7
	% RPD ***	2.0	2.8	1.7	2.4	0.2	0.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	102.5	100.3	99.2	102.1	105.5	109.1
	% Rec *	103.7	101.2	100.5	104.1	107.5	109.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 1/3/2023
Analyst: ZD
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

499.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	1779	483	96.6	2.9
Duplicate	1849	502	100.4	1.0
Triplicate	1866	506	101.3	1.9

547.5 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2347	544	99.4	1.2
Duplicate	2330	540	98.7	0.4
Triplicate	2283	529	96.7	1.6

479.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2640	499	104.2	2.3
Duplicate	2553	483	100.8	1.1
Triplicate	2549	482	100.6	1.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 220521-28941

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 220521-28941

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	249.9	242.1	242.4	96.9	97.0	0.1
MeSH	<PQL	273.8	270.6	265.3	98.8	96.9	2.0
DMS	<PQL	239.5	245.7	246.7	102.6	103.0	0.4

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	499.8	501.8	100.4
MeSH	547.5	558.7	102.0
DMS	479.0	478.9	100.0

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

230002

Fuel Gas Sampling

Client: PG&E Colusa Generating Station		Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd		Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA / Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling		Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504	Preparation and Analysis: BTU
CPP-GS-Dec-A	39621	21-Dec-2022	1000	Gas	1 liter	cyl	1	None		X	X

Special Instruction:
Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	21-Dec-2022	1500 hrs	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	12/23	0954

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

1x 1.4L can

Internal

ATTACHMENT 3
40 CFR 60 Section KKKK

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/01/2022 00:00	1	1
10/01/2022 01:00	1	1
10/01/2022 02:00	1	1
10/01/2022 03:00	1	1
10/01/2022 04:00	1	1
10/01/2022 05:00	1	1
10/01/2022 06:00	1	1
10/01/2022 07:00	1	1
10/01/2022 08:00	1	1
10/01/2022 09:00	1	1
10/01/2022 10:00	1	1
10/01/2022 11:00	1	1
10/01/2022 12:00	1	13
10/01/2022 13:00	1	17
10/01/2022 14:00	1	21
10/01/2022 15:00	1	20
10/01/2022 16:00	1	8
10/01/2022 17:00	1	5
10/01/2022 18:00	1	1
10/01/2022 19:00	1	1
10/01/2022 20:00	1	1
10/01/2022 21:00	1	1
10/01/2022 22:00	1	1
10/01/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	21
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/02/2022 00:00	1	1
10/02/2022 01:00	1	1
10/02/2022 02:00	1	1
10/02/2022 03:00	1	1
10/02/2022 04:00	1	1
10/02/2022 05:00	1	1
10/02/2022 06:00	1	1
10/02/2022 07:00	1	1
10/02/2022 08:00	1	1
10/02/2022 09:00	1	1
10/02/2022 10:00	1	1
10/02/2022 11:00	1	12
10/02/2022 12:00	1	15
10/02/2022 13:00	1	18
10/02/2022 14:00	1	18
10/02/2022 15:00	1	6
10/02/2022 16:00	1	3
10/02/2022 17:00	1	1
10/02/2022 18:00	1	1
10/02/2022 19:00	1	1
10/02/2022 20:00	1	1
10/02/2022 21:00	1	1
10/02/2022 22:00	1	1
10/02/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/03/2022 00:00	1	1
10/03/2022 01:00	1	1
10/03/2022 02:00	14	1
10/03/2022 03:00	16	1
10/03/2022 04:00	16	1
10/03/2022 05:00	16	1
10/03/2022 06:00	3	0
10/03/2022 07:00	1	0
10/03/2022 08:00	1	0
10/03/2022 09:00	1	0
10/03/2022 10:00	1	0
10/03/2022 11:00	1	0
10/03/2022 12:00	1	1
10/03/2022 13:00	1	1
10/03/2022 14:00	1	1
10/03/2022 15:00	1	1
10/03/2022 16:00	1	1
10/03/2022 17:00	1	1
10/03/2022 18:00	1	1
10/03/2022 19:00	1	1
10/03/2022 20:00	1	1
10/03/2022 21:00	1	1
10/03/2022 22:00	1	1
10/03/2022 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	16	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/04/2022 00:00	1	1
10/04/2022 01:00	1	1
10/04/2022 02:00	1	1
10/04/2022 03:00	1	1
10/04/2022 04:00	1	1
10/04/2022 05:00	1	1
10/04/2022 06:00	1	1
10/04/2022 07:00	1	1
10/04/2022 08:00	1	1
10/04/2022 09:00	1	1
10/04/2022 10:00	1	1
10/04/2022 11:00	1	0
10/04/2022 12:00	1	1
10/04/2022 13:00	1	1
10/04/2022 14:00	1	1
10/04/2022 15:00	1	1
10/04/2022 16:00	1	1
10/04/2022 17:00	1	1
10/04/2022 18:00	1	1
10/04/2022 19:00	1	1
10/04/2022 20:00	1	1
10/04/2022 21:00	1	1
10/04/2022 22:00	1	1
10/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/05/2022 00:00	1	1
10/05/2022 01:00	1	1
10/05/2022 02:00	1	1
10/05/2022 03:00	1	1
10/05/2022 04:00	1	1
10/05/2022 05:00	1	1
10/05/2022 06:00	1	1
10/05/2022 07:00	1	1
10/05/2022 08:00	1	1
10/05/2022 09:00	1	1
10/05/2022 10:00	1	1
10/05/2022 11:00	1	1
10/05/2022 12:00	1	1
10/05/2022 13:00	1	1
10/05/2022 14:00	1	1
10/05/2022 15:00	1	1
10/05/2022 16:00	1	1
10/05/2022 17:00	1	1
10/05/2022 18:00	1	1
10/05/2022 19:00	1	1
10/05/2022 20:00	1	1
10/05/2022 21:00	1	1
10/05/2022 22:00	1	1
10/05/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/06/2022 00:00	1	1
10/06/2022 01:00	1	1
10/06/2022 02:00	1	1
10/06/2022 03:00	1	1
10/06/2022 04:00	1	1
10/06/2022 05:00	1	1
10/06/2022 06:00	1	1
10/06/2022 07:00	1	1
10/06/2022 08:00	1	1
10/06/2022 09:00	1	1
10/06/2022 10:00	1	1
10/06/2022 11:00	1	1
10/06/2022 12:00	1	1
10/06/2022 13:00	1	1
10/06/2022 14:00	1	1
10/06/2022 15:00	1	1
10/06/2022 16:00	1	1
10/06/2022 17:00	1	1
10/06/2022 18:00	1	1
10/06/2022 19:00	1	1
10/06/2022 20:00	1	1
10/06/2022 21:00	1	1
10/06/2022 22:00	1	1
10/06/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/07/2022 00:00	1	1
10/07/2022 01:00	1	1
10/07/2022 02:00	1	1
10/07/2022 03:00	1	1
10/07/2022 04:00	1	1
10/07/2022 05:00	1	1
10/07/2022 06:00	1	1
10/07/2022 07:00	1	1
10/07/2022 08:00	1	1
10/07/2022 09:00	1	1
10/07/2022 10:00	1	1
10/07/2022 11:00	1	1
10/07/2022 12:00	1	1
10/07/2022 13:00	1	1
10/07/2022 14:00	1	1
10/07/2022 15:00	1	1
10/07/2022 16:00	1	1
10/07/2022 17:00	1	1
10/07/2022 18:00	1	1
10/07/2022 19:00	1	1
10/07/2022 20:00	1	1
10/07/2022 21:00	1	1
10/07/2022 22:00	1	1
10/07/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/08/2022 00:00	1	1
10/08/2022 01:00	1	1
10/08/2022 02:00	1	1
10/08/2022 03:00	1	1
10/08/2022 04:00	1	1
10/08/2022 05:00	1	1
10/08/2022 06:00	1	1
10/08/2022 07:00	1	1
10/08/2022 08:00	1	1
10/08/2022 09:00	1	1
10/08/2022 10:00	1	0
10/08/2022 11:00	1	0
10/08/2022 12:00	1	0
10/08/2022 13:00	1	0
10/08/2022 14:00	1	1
10/08/2022 15:00	1	1
10/08/2022 16:00	1	1
10/08/2022 17:00	1	1
10/08/2022 18:00	1	1
10/08/2022 19:00	1	1
10/08/2022 20:00	1	1
10/08/2022 21:00	1	1
10/08/2022 22:00	1	1
10/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/09/2022 00:00	1	1
10/09/2022 01:00	1	1
10/09/2022 02:00	1	1
10/09/2022 03:00	1	1
10/09/2022 04:00	1	1
10/09/2022 05:00	1	1
10/09/2022 06:00	1	1
10/09/2022 07:00	1	1
10/09/2022 08:00	1	1
10/09/2022 09:00	1	1
10/09/2022 10:00	1	1
10/09/2022 11:00	4	1
10/09/2022 12:00	4	1
10/09/2022 13:00	4	1
10/09/2022 14:00	4	9
10/09/2022 15:00	1	11
10/09/2022 16:00	1	11
10/09/2022 17:00	1	11
10/09/2022 18:00	1	3
10/09/2022 19:00	1	1
10/09/2022 20:00	1	1
10/09/2022 21:00	1	1
10/09/2022 22:00	1	1
10/09/2022 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/10/2022 00:00	1	1
10/10/2022 01:00	1	1
10/10/2022 02:00	1	1
10/10/2022 03:00	1	1
10/10/2022 04:00	1	1
10/10/2022 05:00	1	1
10/10/2022 06:00	1	1
10/10/2022 07:00	1	1
10/10/2022 08:00	1	1
10/10/2022 09:00	1	1
10/10/2022 10:00	1	0
10/10/2022 11:00	1	0
10/10/2022 12:00	1	0
10/10/2022 13:00	1	0
10/10/2022 14:00	1	1
10/10/2022 15:00	1	1
10/10/2022 16:00	1	1
10/10/2022 17:00	1	1
10/10/2022 18:00	1	1
10/10/2022 19:00	1	1
10/10/2022 20:00	1	1
10/10/2022 21:00	1	1
10/10/2022 22:00	1	1
10/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/11/2022 00:00	1	1
10/11/2022 01:00	1	1
10/11/2022 02:00	1	0
10/11/2022 03:00	1	0
10/11/2022 04:00	1	0
10/11/2022 05:00	1	0
10/11/2022 06:00	1	0
10/11/2022 07:00	1	0
10/11/2022 08:00	1	0
10/11/2022 09:00	1	0
10/11/2022 10:00	1	0
10/11/2022 11:00	1	1
10/11/2022 12:00	1	1
10/11/2022 13:00	1	1
10/11/2022 14:00	1	1
10/11/2022 15:00	1	1
10/11/2022 16:00	1	1
10/11/2022 17:00	1	1
10/11/2022 18:00	1	1
10/11/2022 19:00	1	1
10/11/2022 20:00	1	1
10/11/2022 21:00	1	1
10/11/2022 22:00	1	1
10/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/12/2022 00:00	1	1
10/12/2022 01:00	1	1
10/12/2022 02:00	1	1
10/12/2022 03:00	1	1
10/12/2022 04:00	1	1
10/12/2022 05:00	1	1
10/12/2022 06:00	1	1
10/12/2022 07:00	1	1
10/12/2022 08:00	1	1
10/12/2022 09:00	1	1
10/12/2022 10:00	1	1
10/12/2022 11:00	1	1
10/12/2022 12:00	1	1
10/12/2022 13:00	1	1
10/12/2022 14:00	1	1
10/12/2022 15:00	1	1
10/12/2022 16:00	1	1
10/12/2022 17:00	1	1
10/12/2022 18:00	1	1
10/12/2022 19:00	1	1
10/12/2022 20:00	1	1
10/12/2022 21:00	1	1
10/12/2022 22:00	1	1
10/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/13/2022 00:00	1	1
10/13/2022 01:00	1	1
10/13/2022 02:00	1	1
10/13/2022 03:00	1	1
10/13/2022 04:00	1	1
10/13/2022 05:00	1	1
10/13/2022 06:00	1	1
10/13/2022 07:00	1	0
10/13/2022 08:00	1	0
10/13/2022 09:00	1	0
10/13/2022 10:00	1	0
10/13/2022 11:00	1	1
10/13/2022 12:00	1	1
10/13/2022 13:00	1	1
10/13/2022 14:00	1	1
10/13/2022 15:00	1	1
10/13/2022 16:00	1	1
10/13/2022 17:00	1	1
10/13/2022 18:00	1	1
10/13/2022 19:00	1	1
10/13/2022 20:00	1	1
10/13/2022 21:00	1	1
10/13/2022 22:00	1	1
10/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/14/2022 00:00	1	1
10/14/2022 01:00	1	1
10/14/2022 02:00	1	1
10/14/2022 03:00	1	1
10/14/2022 04:00	1	1
10/14/2022 05:00	1	1
10/14/2022 06:00	1	1
10/14/2022 07:00	1	1
10/14/2022 08:00	1	1
10/14/2022 09:00	1	1
10/14/2022 10:00	1	1
10/14/2022 11:00	1	1
10/14/2022 12:00	1	1
10/14/2022 13:00	1	1
10/14/2022 14:00	1	1
10/14/2022 15:00	1	1
10/14/2022 16:00	1	1
10/14/2022 17:00	1	1
10/14/2022 18:00	1	1
10/14/2022 19:00	1	1
10/14/2022 20:00	1	1
10/14/2022 21:00	1	1
10/14/2022 22:00	1	1
10/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/15/2022 00:00	1	1
10/15/2022 01:00	1	1
10/15/2022 02:00	1	1
10/15/2022 03:00	1	1
10/15/2022 04:00	1	1
10/15/2022 05:00	1	1
10/15/2022 06:00	1	1
10/15/2022 07:00	1	1
10/15/2022 08:00	1	1
10/15/2022 09:00	1	1
10/15/2022 10:00	1	1
10/15/2022 11:00	1	1
10/15/2022 12:00	1	1
10/15/2022 13:00	1	1
10/15/2022 14:00	1	1
10/15/2022 15:00	1	1
10/15/2022 16:00	1	1
10/15/2022 17:00	1	1
10/15/2022 18:00	1	1
10/15/2022 19:00	1	1
10/15/2022 20:00	1	1
10/15/2022 21:00	1	1
10/15/2022 22:00	1	1
10/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/16/2022 00:00	1	1
10/16/2022 01:00	1	1
10/16/2022 02:00	1	1
10/16/2022 03:00	1	1
10/16/2022 04:00	1	1
10/16/2022 05:00	1	1
10/16/2022 06:00	1	1
10/16/2022 07:00	1	1
10/16/2022 08:00	1	1
10/16/2022 09:00	1	1
10/16/2022 10:00	1	1
10/16/2022 11:00	1	1
10/16/2022 12:00	1	1
10/16/2022 13:00	1	1
10/16/2022 14:00	1	1
10/16/2022 15:00	1	1
10/16/2022 16:00	1	1
10/16/2022 17:00	1	14
10/16/2022 18:00	1	19
10/16/2022 19:00	1	22
10/16/2022 20:00	1	21
10/16/2022 21:00	1	9
10/16/2022 22:00	1	4
10/16/2022 23:00	13	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	13	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/17/2022 00:00	18	1
10/17/2022 01:00	18	1
10/17/2022 02:00	18	1
10/17/2022 03:00	6	1
10/17/2022 04:00	1	1
10/17/2022 05:00	1	1
10/17/2022 06:00	1	1
10/17/2022 07:00	1	1
10/17/2022 08:00	1	1
10/17/2022 09:00	1	1
10/17/2022 10:00	1	1
10/17/2022 11:00	1	1
10/17/2022 12:00	1	1
10/17/2022 13:00	1	1
10/17/2022 14:00	1	1
10/17/2022 15:00	1	1
10/17/2022 16:00	1	1
10/17/2022 17:00	1	1
10/17/2022 18:00	1	1
10/17/2022 19:00	1	1
10/17/2022 20:00	1	1
10/17/2022 21:00	1	1
10/17/2022 22:00	1	1
10/17/2022 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	18	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/18/2022 00:00	1	1
10/18/2022 01:00	1	1
10/18/2022 02:00	1	1
10/18/2022 03:00	1	1
10/18/2022 04:00	1	1
10/18/2022 05:00	1	1
10/18/2022 06:00	1	1
10/18/2022 07:00	1	1
10/18/2022 08:00	1	1
10/18/2022 09:00	1	1
10/18/2022 10:00	1	1
10/18/2022 11:00	1	1
10/18/2022 12:00	1	1
10/18/2022 13:00	1	1
10/18/2022 14:00	1	1
10/18/2022 15:00	1	1
10/18/2022 16:00	1	1
10/18/2022 17:00	1	1
10/18/2022 18:00	1	1
10/18/2022 19:00	1	1
10/18/2022 20:00	1	1
10/18/2022 21:00	1	1
10/18/2022 22:00	1	1
10/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/19/2022 00:00	1	1
10/19/2022 01:00	1	1
10/19/2022 02:00	1	1
10/19/2022 03:00	1	1
10/19/2022 04:00	1	1
10/19/2022 05:00	1	1
10/19/2022 06:00	1	1
10/19/2022 07:00	1	1
10/19/2022 08:00	1	1
10/19/2022 09:00	1	1
10/19/2022 10:00	1	1
10/19/2022 11:00	1	1
10/19/2022 12:00	1	1
10/19/2022 13:00	1	1
10/19/2022 14:00	1	1
10/19/2022 15:00	1	1
10/19/2022 16:00	1	1
10/19/2022 17:00	1	1
10/19/2022 18:00	1	1
10/19/2022 19:00	1	1
10/19/2022 20:00	1	1
10/19/2022 21:00	1	1
10/19/2022 22:00	1	1
10/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/20/2022 00:00	1	1
10/20/2022 01:00	1	1
10/20/2022 02:00	1	1
10/20/2022 03:00	1	1
10/20/2022 04:00	1	1
10/20/2022 05:00	1	1
10/20/2022 06:00	1	1
10/20/2022 07:00	1	1
10/20/2022 08:00	1	1
10/20/2022 09:00	1	1
10/20/2022 10:00	1	1
10/20/2022 11:00	1	1
10/20/2022 12:00	1	1
10/20/2022 13:00	1	1
10/20/2022 14:00	1	1
10/20/2022 15:00	1	1
10/20/2022 16:00	1	1
10/20/2022 17:00	1	1
10/20/2022 18:00	1	1
10/20/2022 19:00	1	1
10/20/2022 20:00	1	1
10/20/2022 21:00	1	1
10/20/2022 22:00	1	1
10/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/21/2022 00:00	1	1
10/21/2022 01:00	1	1
10/21/2022 02:00	1	1
10/21/2022 03:00	1	1
10/21/2022 04:00	1	1
10/21/2022 05:00	1	1
10/21/2022 06:00	1	1
10/21/2022 07:00	1	1
10/21/2022 08:00	1	1
10/21/2022 09:00	1	1
10/21/2022 10:00	1	1
10/21/2022 11:00	1	1
10/21/2022 12:00	1	1
10/21/2022 13:00	1	1
10/21/2022 14:00	1	1
10/21/2022 15:00	1	1
10/21/2022 16:00	1	1
10/21/2022 17:00	1	1
10/21/2022 18:00	1	1
10/21/2022 19:00	1	1
10/21/2022 20:00	1	1
10/21/2022 21:00	1	1
10/21/2022 22:00	1	1
10/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/22/2022 00:00	1	1
10/22/2022 01:00	1	1
10/22/2022 02:00	1	1
10/22/2022 03:00	1	1
10/22/2022 04:00	1	1
10/22/2022 05:00	1	1
10/22/2022 06:00	1	1
10/22/2022 07:00	1	1
10/22/2022 08:00	1	1
10/22/2022 09:00	1	1
10/22/2022 10:00	1	1
10/22/2022 11:00	1	1
10/22/2022 12:00	1	1
10/22/2022 13:00	1	1
10/22/2022 14:00	1	1
10/22/2022 15:00	1	1
10/22/2022 16:00	1	1
10/22/2022 17:00	1	1
10/22/2022 18:00	1	1
10/22/2022 19:00	1	1
10/22/2022 20:00	1	1
10/22/2022 21:00	1	1
10/22/2022 22:00	1	1
10/22/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/23/2022 00:00	1	1
10/23/2022 01:00	1	1
10/23/2022 02:00	1	1
10/23/2022 03:00	1	1
10/23/2022 04:00	1	1
10/23/2022 05:00	1	1
10/23/2022 06:00	1	1
10/23/2022 07:00	1	1
10/23/2022 08:00	1	1
10/23/2022 09:00	1	1
10/23/2022 10:00	1	1
10/23/2022 11:00	1	1
10/23/2022 12:00	1	1
10/23/2022 13:00	1	1
10/23/2022 14:00	1	1
10/23/2022 15:00	1	1
10/23/2022 16:00	1	1
10/23/2022 17:00	1	1
10/23/2022 18:00	1	1
10/23/2022 19:00	1	1
10/23/2022 20:00	1	15
10/23/2022 21:00	1	21
10/23/2022 22:00	1	25
10/23/2022 23:00	1	24
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/24/2022 00:00	1	10
10/24/2022 01:00	1	4
10/24/2022 02:00	1	1
10/24/2022 03:00	1	1
10/24/2022 04:00	1	1
10/24/2022 05:00	1	1
10/24/2022 06:00	1	1
10/24/2022 07:00	1	1
10/24/2022 08:00	1	1
10/24/2022 09:00	1	1
10/24/2022 10:00	1	1
10/24/2022 11:00	1	1
10/24/2022 12:00	1	1
10/24/2022 13:00	14	1
10/24/2022 14:00	16	1
10/24/2022 15:00	16	1
10/24/2022 16:00	16	1
10/24/2022 17:00	3	1
10/24/2022 18:00	1	1
10/24/2022 19:00	1	1
10/24/2022 20:00	1	1
10/24/2022 21:00	1	1
10/24/2022 22:00	1	1
10/24/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	16	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/25/2022 00:00	1	1
10/25/2022 01:00	1	1
10/25/2022 02:00	1	1
10/25/2022 03:00	1	1
10/25/2022 04:00	1	1
10/25/2022 05:00	1	1
10/25/2022 06:00	1	1
10/25/2022 07:00	1	1
10/25/2022 08:00	1	1
10/25/2022 09:00	1	1
10/25/2022 10:00	1	1
10/25/2022 11:00	1	1
10/25/2022 12:00	1	1
10/25/2022 13:00	1	1
10/25/2022 14:00	1	1
10/25/2022 15:00	1	1
10/25/2022 16:00	1	1
10/25/2022 17:00	1	1
10/25/2022 18:00	1	1
10/25/2022 19:00	1	1
10/25/2022 20:00	1	1
10/25/2022 21:00	1	1
10/25/2022 22:00	1	1
10/25/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/26/2022 00:00	1	1
10/26/2022 01:00	1	1
10/26/2022 02:00	1	1
10/26/2022 03:00	1	1
10/26/2022 04:00	1	1
10/26/2022 05:00	1	1
10/26/2022 06:00	1	1
10/26/2022 07:00	1	1
10/26/2022 08:00	2	1
10/26/2022 09:00	2	1
10/26/2022 10:00	2	1
10/26/2022 11:00	2	1
10/26/2022 12:00	2	1
10/26/2022 13:00	2	1
10/26/2022 14:00	2	1
10/26/2022 15:00	2	1
10/26/2022 16:00	13	1
10/26/2022 17:00	27	1
10/26/2022 18:00	34	1
10/26/2022 19:00	33	1
10/26/2022 20:00	21	1
10/26/2022 21:00	7	1
10/26/2022 22:00	1	1
10/26/2022 23:00	1	1
Average/Sum#:	7	1
Minimum:	1	1
Maximum:	34	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/27/2022 00:00	1	1
10/27/2022 01:00	1	1
10/27/2022 02:00	1	1
10/27/2022 03:00	1	1
10/27/2022 04:00	1	1
10/27/2022 05:00	1	1
10/27/2022 06:00	1	1
10/27/2022 07:00	1	1
10/27/2022 08:00	1	1
10/27/2022 09:00	1	1
10/27/2022 10:00	1	1
10/27/2022 11:00	1	1
10/27/2022 12:00	1	1
10/27/2022 13:00	1	1
10/27/2022 14:00	1	1
10/27/2022 15:00	1	1
10/27/2022 16:00	1	1
10/27/2022 17:00	1	1
10/27/2022 18:00	1	1
10/27/2022 19:00	1	1
10/27/2022 20:00	1	1
10/27/2022 21:00	1	1
10/27/2022 22:00	1	1
10/27/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/28/2022 00:00	1	1
10/28/2022 01:00	1	1
10/28/2022 02:00	1	1
10/28/2022 03:00	1	1
10/28/2022 04:00	1	1
10/28/2022 05:00	1	1
10/28/2022 06:00	1	1
10/28/2022 07:00	1	1
10/28/2022 08:00	1	1
10/28/2022 09:00	1	1
10/28/2022 10:00	1	1
10/28/2022 11:00	1	1
10/28/2022 12:00	1	1
10/28/2022 13:00	1	1
10/28/2022 14:00	1	1
10/28/2022 15:00	1	1
10/28/2022 16:00	1	1
10/28/2022 17:00	1	1
10/28/2022 18:00	1	1
10/28/2022 19:00	1	1
10/28/2022 20:00	1	1
10/28/2022 21:00	1	1
10/28/2022 22:00	1	1
10/28/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/29/2022 00:00	1	1
10/29/2022 01:00	1	1
10/29/2022 02:00	1	1
10/29/2022 03:00	1	1
10/29/2022 04:00	1	1
10/29/2022 05:00	1	1
10/29/2022 06:00	1	1
10/29/2022 07:00	1	1
10/29/2022 08:00	1	1
10/29/2022 09:00	1	1
10/29/2022 10:00	1	1
10/29/2022 11:00	1	1
10/29/2022 12:00	1	1
10/29/2022 13:00	1	1
10/29/2022 14:00	1	1
10/29/2022 15:00	1	1
10/29/2022 16:00	1	1
10/29/2022 17:00	1	1
10/29/2022 18:00	1	1
10/29/2022 19:00	1	1
10/29/2022 20:00	1	1
10/29/2022 21:00	1	1
10/29/2022 22:00	1	1
10/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/30/2022 00:00	1	1
10/30/2022 01:00	1	1
10/30/2022 02:00	1	1
10/30/2022 03:00	1	1
10/30/2022 04:00	1	1
10/30/2022 05:00	1	1
10/30/2022 06:00	1	1
10/30/2022 07:00	1	1
10/30/2022 08:00	1	1
10/30/2022 09:00	1	1
10/30/2022 10:00	1	1
10/30/2022 11:00	1	1
10/30/2022 12:00	1	1
10/30/2022 13:00	1	1
10/30/2022 14:00	1	1
10/30/2022 15:00	1	1
10/30/2022 16:00	1	1
10/30/2022 17:00	1	1
10/30/2022 18:00	1	1
10/30/2022 19:00	1	9
10/30/2022 20:00	1	21
10/30/2022 21:00	1	25
10/30/2022 22:00	1	29
10/30/2022 23:00	1	22
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	29
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/31/2022 00:00	1	10
10/31/2022 01:00	14	5
10/31/2022 02:00	18	1
10/31/2022 03:00	18	1
10/31/2022 04:00	18	1
10/31/2022 05:00	5	1
10/31/2022 06:00	1	1
10/31/2022 07:00	1	1
10/31/2022 08:00	1	1
10/31/2022 09:00	1	1
10/31/2022 10:00	1	1
10/31/2022 11:00	1	1
10/31/2022 12:00	1	1
10/31/2022 13:00	1	1
10/31/2022 14:00	1	1
10/31/2022 15:00	1	1
10/31/2022 16:00	1	1
10/31/2022 17:00	1	1
10/31/2022 18:00	1	1
10/31/2022 19:00	1	1
10/31/2022 20:00	1	1
10/31/2022 21:00	1	1
10/31/2022 22:00	1	1
10/31/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	18	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/01/2022 00:00	1	1
11/01/2022 01:00	1	1
11/01/2022 02:00	1	1
11/01/2022 03:00	1	1
11/01/2022 04:00	1	1
11/01/2022 05:00	1	1
11/01/2022 06:00	1	1
11/01/2022 07:00	1	1
11/01/2022 08:00	1	1
11/01/2022 09:00	1	1
11/01/2022 10:00	1	1
11/01/2022 11:00	1	1
11/01/2022 12:00	1	1
11/01/2022 13:00	1	1
11/01/2022 14:00	1	1
11/01/2022 15:00	1	1
11/01/2022 16:00	1	1
11/01/2022 17:00	1	1
11/01/2022 18:00	1	1
11/01/2022 19:00	1	1
11/01/2022 20:00	1	1
11/01/2022 21:00	1	1
11/01/2022 22:00	1	1
11/01/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/02/2022 00:00	1	1
11/02/2022 01:00	1	1
11/02/2022 02:00	1	1
11/02/2022 03:00	1	1
11/02/2022 04:00	1	1
11/02/2022 05:00	1	1
11/02/2022 06:00	1	1
11/02/2022 07:00	1	1
11/02/2022 08:00	1	1
11/02/2022 09:00	1	1
11/02/2022 10:00	1	1
11/02/2022 11:00	1	1
11/02/2022 12:00	1	1
11/02/2022 13:00	1	1
11/02/2022 14:00	1	1
11/02/2022 15:00	1	1
11/02/2022 16:00	1	1
11/02/2022 17:00	1	1
11/02/2022 18:00	1	1
11/02/2022 19:00	1	1
11/02/2022 20:00	1	1
11/02/2022 21:00	1	1
11/02/2022 22:00	1	1
11/02/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/03/2022 00:00	1	1
11/03/2022 01:00	1	1
11/03/2022 02:00	1	1
11/03/2022 03:00	1	1
11/03/2022 04:00	1	1
11/03/2022 05:00	1	1
11/03/2022 06:00	1	1
11/03/2022 07:00	1	1
11/03/2022 08:00	1	1
11/03/2022 09:00	1	1
11/03/2022 10:00	1	1
11/03/2022 11:00	1	1
11/03/2022 12:00	1	1
11/03/2022 13:00	1	1
11/03/2022 14:00	1	1
11/03/2022 15:00	1	1
11/03/2022 16:00	1	1
11/03/2022 17:00	1	1
11/03/2022 18:00	1	1
11/03/2022 19:00	1	1
11/03/2022 20:00	1	1
11/03/2022 21:00	1	1
11/03/2022 22:00	1	1
11/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/04/2022 00:00	1	1
11/04/2022 01:00	1	1
11/04/2022 02:00	1	1
11/04/2022 03:00	1	1
11/04/2022 04:00	1	1
11/04/2022 05:00	1	1
11/04/2022 06:00	1	1
11/04/2022 07:00	1	1
11/04/2022 08:00	1	1
11/04/2022 09:00	1	1
11/04/2022 10:00	1	1
11/04/2022 11:00	1	1
11/04/2022 12:00	1	1
11/04/2022 13:00	1	1
11/04/2022 14:00	1	1
11/04/2022 15:00	1	1
11/04/2022 16:00	1	1
11/04/2022 17:00	1	1
11/04/2022 18:00	1	1
11/04/2022 19:00	1	1
11/04/2022 20:00	1	1
11/04/2022 21:00	1	1
11/04/2022 22:00	1	1
11/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/05/2022 00:00	1	1
11/05/2022 01:00	1	1
11/05/2022 02:00	1	1
11/05/2022 03:00	1	1
11/05/2022 04:00	1	1
11/05/2022 05:00	1	1
11/05/2022 06:00	1	1
11/05/2022 07:00	2	3
11/05/2022 08:00	2	3
11/05/2022 09:00	2	3
11/05/2022 10:00	2	3
11/05/2022 11:00	2	3
11/05/2022 12:00	2	3
11/05/2022 13:00	6	3
11/05/2022 14:00	15	3
11/05/2022 15:00	15	3
11/05/2022 16:00	14	3
11/05/2022 17:00	9	3
11/05/2022 18:00	1	3
11/05/2022 19:00	1	3
11/05/2022 20:00	1	3
11/05/2022 21:00	1	3
11/05/2022 22:00	1	3
11/05/2022 23:00	1	3
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	15	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/06/2022 00:00	1	3
11/06/2022 01:00	1	3
11/06/2022 02:00	2	3
11/06/2022 03:00	2	3
11/06/2022 04:00	2	3
11/06/2022 05:00	2	3
11/06/2022 06:00	2	3
11/06/2022 07:00	2	3
11/06/2022 08:00	2	3
11/06/2022 09:00	2	14
11/06/2022 10:00	2	22
11/06/2022 11:00	2	25
11/06/2022 12:00	2	23
11/06/2022 13:00	2	12
11/06/2022 14:00	2	4
11/06/2022 15:00	2	1
11/06/2022 16:00	2	1
11/06/2022 17:00	2	1
11/06/2022 18:00	2	1
11/06/2022 19:00	2	1
11/06/2022 20:00	2	1
11/06/2022 21:00	2	1
11/06/2022 22:00	2	1
11/06/2022 23:00	2	1
Average/Sum#:	2	6
Minimum:	1	1
Maximum:	2	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/07/2022 00:00	2	2
11/07/2022 01:00	2	5
11/07/2022 02:00	2	5
11/07/2022 03:00	13	5
11/07/2022 04:00	21	3
11/07/2022 05:00	21	1
11/07/2022 06:00	21	1
11/07/2022 07:00	9	1
11/07/2022 08:00	1	1
11/07/2022 09:00	1	1
11/07/2022 10:00	1	1
11/07/2022 11:00	1	1
11/07/2022 12:00	1	1
11/07/2022 13:00	1	1
11/07/2022 14:00	1	1
11/07/2022 15:00	1	1
11/07/2022 16:00	1	1
11/07/2022 17:00	1	1
11/07/2022 18:00	1	1
11/07/2022 19:00	1	1
11/07/2022 20:00	1	1
11/07/2022 21:00	1	1
11/07/2022 22:00	1	1
11/07/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	21	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/08/2022 00:00	1	1
11/08/2022 01:00	1	1
11/08/2022 02:00	1	1
11/08/2022 03:00	1	1
11/08/2022 04:00	1	1
11/08/2022 05:00	1	1
11/08/2022 06:00	1	1
11/08/2022 07:00	1	1
11/08/2022 08:00	1	1
11/08/2022 09:00	1	1
11/08/2022 10:00	1	1
11/08/2022 11:00	1	1
11/08/2022 12:00	1	1
11/08/2022 13:00	1	1
11/08/2022 14:00	1	1
11/08/2022 15:00	1	1
11/08/2022 16:00	1	1
11/08/2022 17:00	1	1
11/08/2022 18:00	1	1
11/08/2022 19:00	1	1
11/08/2022 20:00	1	1
11/08/2022 21:00	1	1
11/08/2022 22:00	1	1
11/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/09/2022 00:00	1	1
11/09/2022 01:00	1	1
11/09/2022 02:00	1	1
11/09/2022 03:00	1	1
11/09/2022 04:00	1	1
11/09/2022 05:00	1	1
11/09/2022 06:00	1	1
11/09/2022 07:00	1	1
11/09/2022 08:00	1	1
11/09/2022 09:00	1	1
11/09/2022 10:00	1	1
11/09/2022 11:00	1	1
11/09/2022 12:00	1	1
11/09/2022 13:00	1	1
11/09/2022 14:00	1	1
11/09/2022 15:00	1	1
11/09/2022 16:00	1	1
11/09/2022 17:00	1	1
11/09/2022 18:00	1	1
11/09/2022 19:00	1	1
11/09/2022 20:00	1	1
11/09/2022 21:00	1	1
11/09/2022 22:00	1	1
11/09/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/10/2022 00:00	1	1
11/10/2022 01:00	1	1
11/10/2022 02:00	1	1
11/10/2022 03:00	1	1
11/10/2022 04:00	1	1
11/10/2022 05:00	1	1
11/10/2022 06:00	1	1
11/10/2022 07:00	1	1
11/10/2022 08:00	1	1
11/10/2022 09:00	1	1
11/10/2022 10:00	1	1
11/10/2022 11:00	1	1
11/10/2022 12:00	1	1
11/10/2022 13:00	1	1
11/10/2022 14:00	1	1
11/10/2022 15:00	1	1
11/10/2022 16:00	1	1
11/10/2022 17:00	1	1
11/10/2022 18:00	1	1
11/10/2022 19:00	1	1
11/10/2022 20:00	1	1
11/10/2022 21:00	1	1
11/10/2022 22:00	1	1
11/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/11/2022 00:00	1	1
11/11/2022 01:00	1	1
11/11/2022 02:00	1	1
11/11/2022 03:00	1	1
11/11/2022 04:00	1	1
11/11/2022 05:00	1	1
11/11/2022 06:00	1	1
11/11/2022 07:00	1	1
11/11/2022 08:00	1	1
11/11/2022 09:00	1	1
11/11/2022 10:00	1	1
11/11/2022 11:00	1	1
11/11/2022 12:00	1	1
11/11/2022 13:00	1	1
11/11/2022 14:00	1	1
11/11/2022 15:00	1	1
11/11/2022 16:00	1	1
11/11/2022 17:00	1	1
11/11/2022 18:00	1	1
11/11/2022 19:00	1	1
11/11/2022 20:00	1	1
11/11/2022 21:00	1	1
11/11/2022 22:00	1	1
11/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/12/2022 00:00	1	1
11/12/2022 01:00	1	1
11/12/2022 02:00	1	1
11/12/2022 03:00	1	1
11/12/2022 04:00	1	1
11/12/2022 05:00	1	1
11/12/2022 06:00	1	1
11/12/2022 07:00	1	1
11/12/2022 08:00	1	1
11/12/2022 09:00	1	1
11/12/2022 10:00	1	1
11/12/2022 11:00	1	1
11/12/2022 12:00	1	1
11/12/2022 13:00	1	1
11/12/2022 14:00	1	1
11/12/2022 15:00	1	1
11/12/2022 16:00	1	1
11/12/2022 17:00	1	1
11/12/2022 18:00	1	1
11/12/2022 19:00	1	1
11/12/2022 20:00	1	1
11/12/2022 21:00	1	1
11/12/2022 22:00	1	1
11/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/13/2022 00:00	1	1
11/13/2022 01:00	1	1
11/13/2022 02:00	1	1
11/13/2022 03:00	1	1
11/13/2022 04:00	1	1
11/13/2022 05:00	1	1
11/13/2022 06:00	1	1
11/13/2022 07:00	1	1
11/13/2022 08:00	1	1
11/13/2022 09:00	1	1
11/13/2022 10:00	1	1
11/13/2022 11:00	1	1
11/13/2022 12:00	1	1
11/13/2022 13:00	1	1
11/13/2022 14:00	1	1
11/13/2022 15:00	1	1
11/13/2022 16:00	1	1
11/13/2022 17:00	1	1
11/13/2022 18:00	1	1
11/13/2022 19:00	1	1
11/13/2022 20:00	1	1
11/13/2022 21:00	1	1
11/13/2022 22:00	1	1
11/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/14/2022 00:00	1	1
11/14/2022 01:00	1	1
11/14/2022 02:00	1	1
11/14/2022 03:00	1	1
11/14/2022 04:00	1	1
11/14/2022 05:00	1	1
11/14/2022 06:00	1	1
11/14/2022 07:00	1	1
11/14/2022 08:00	1	1
11/14/2022 09:00	1	1
11/14/2022 10:00	1	1
11/14/2022 11:00	1	1
11/14/2022 12:00	1	1
11/14/2022 13:00	1	1
11/14/2022 14:00	1	1
11/14/2022 15:00	1	1
11/14/2022 16:00	1	1
11/14/2022 17:00	1	1
11/14/2022 18:00	1	1
11/14/2022 19:00	1	1
11/14/2022 20:00	1	1
11/14/2022 21:00	1	1
11/14/2022 22:00	1	1
11/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/15/2022 00:00	1	1
11/15/2022 01:00	1	1
11/15/2022 02:00	1	1
11/15/2022 03:00	1	1
11/15/2022 04:00	1	1
11/15/2022 05:00	1	1
11/15/2022 06:00	1	1
11/15/2022 07:00	1	1
11/15/2022 08:00	1	1
11/15/2022 09:00	1	1
11/15/2022 10:00	1	1
11/15/2022 11:00	1	1
11/15/2022 12:00	1	1
11/15/2022 13:00	1	1
11/15/2022 14:00	1	1
11/15/2022 15:00	0	1
11/15/2022 16:00	0	1
11/15/2022 17:00	0	1
11/15/2022 18:00	1	1
11/15/2022 19:00	1	1
11/15/2022 20:00	1	1
11/15/2022 21:00	1	1
11/15/2022 22:00	1	1
11/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	12.50	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/16/2022 00:00	1	1
11/16/2022 01:00	1	1
11/16/2022 02:00	1	1
11/16/2022 03:00	1	1
11/16/2022 04:00	1	1
11/16/2022 05:00	1	1
11/16/2022 06:00	1	1
11/16/2022 07:00	1	1
11/16/2022 08:00	1	1
11/16/2022 09:00	1	1
11/16/2022 10:00	1	1
11/16/2022 11:00	1	1
11/16/2022 12:00	1	1
11/16/2022 13:00	1	1
11/16/2022 14:00	1	1
11/16/2022 15:00	1	1
11/16/2022 16:00	1	1
11/16/2022 17:00	1	1
11/16/2022 18:00	1	1
11/16/2022 19:00	1	1
11/16/2022 20:00	1	1
11/16/2022 21:00	1	1
11/16/2022 22:00	1	1
11/16/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/17/2022 00:00	1	1
11/17/2022 01:00	1	1
11/17/2022 02:00	1	1
11/17/2022 03:00	1	1
11/17/2022 04:00	1	1
11/17/2022 05:00	1	1
11/17/2022 06:00	1	1
11/17/2022 07:00	1	1
11/17/2022 08:00	1	1
11/17/2022 09:00	1	1
11/17/2022 10:00	1	1
11/17/2022 11:00	1	1
11/17/2022 12:00	1	1
11/17/2022 13:00	1	1
11/17/2022 14:00	1	1
11/17/2022 15:00	1	1
11/17/2022 16:00	1	1
11/17/2022 17:00	1	1
11/17/2022 18:00	1	1
11/17/2022 19:00	1	1
11/17/2022 20:00	1	1
11/17/2022 21:00	1	1
11/17/2022 22:00	1	1
11/17/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/18/2022 00:00	1	1
11/18/2022 01:00	1	1
11/18/2022 02:00	1	1
11/18/2022 03:00	1	1
11/18/2022 04:00	1	1
11/18/2022 05:00	1	1
11/18/2022 06:00	1	1
11/18/2022 07:00	1	1
11/18/2022 08:00	1	1
11/18/2022 09:00	1	1
11/18/2022 10:00	1	1
11/18/2022 11:00	1	1
11/18/2022 12:00	1	1
11/18/2022 13:00	1	1
11/18/2022 14:00	1	1
11/18/2022 15:00	1	1
11/18/2022 16:00	1	1
11/18/2022 17:00	1	1
11/18/2022 18:00	1	1
11/18/2022 19:00	1	1
11/18/2022 20:00	1	1
11/18/2022 21:00	1	1
11/18/2022 22:00	1	1
11/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/19/2022 00:00	1	1
11/19/2022 01:00	1	1
11/19/2022 02:00	1	1
11/19/2022 03:00	1	1
11/19/2022 04:00	1	1
11/19/2022 05:00	1	1
11/19/2022 06:00	1	1
11/19/2022 07:00	1	1
11/19/2022 08:00	1	1
11/19/2022 09:00	1	1
11/19/2022 10:00	1	1
11/19/2022 11:00	1	1
11/19/2022 12:00	1	1
11/19/2022 13:00	1	1
11/19/2022 14:00	1	1
11/19/2022 15:00	1	1
11/19/2022 16:00	1	1
11/19/2022 17:00	1	1
11/19/2022 18:00	1	1
11/19/2022 19:00	1	1
11/19/2022 20:00	1	1
11/19/2022 21:00	1	1
11/19/2022 22:00	1	1
11/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/20/2022 00:00	1	1
11/20/2022 01:00	1	1
11/20/2022 02:00	1	1
11/20/2022 03:00	1	1
11/20/2022 04:00	1	1
11/20/2022 05:00	1	1
11/20/2022 06:00	1	1
11/20/2022 07:00	1	1
11/20/2022 08:00	1	1
11/20/2022 09:00	1	1
11/20/2022 10:00	1	1
11/20/2022 11:00	1	0
11/20/2022 12:00	1	0
11/20/2022 13:00	1	0
11/20/2022 14:00	1	0
11/20/2022 15:00	1	0
11/20/2022 16:00	1	1
11/20/2022 17:00	1	1
11/20/2022 18:00	1	1
11/20/2022 19:00	1	1
11/20/2022 20:00	1	1
11/20/2022 21:00	1	1
11/20/2022 22:00	1	1
11/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/21/2022 00:00	1	1
11/21/2022 01:00	1	1
11/21/2022 02:00	1	1
11/21/2022 03:00	1	1
11/21/2022 04:00	1	1
11/21/2022 05:00	1	1
11/21/2022 06:00	1	1
11/21/2022 07:00	1	1
11/21/2022 08:00	1	1
11/21/2022 09:00	1	1
11/21/2022 10:00	1	1
11/21/2022 11:00	1	1
11/21/2022 12:00	1	1
11/21/2022 13:00	1	1
11/21/2022 14:00	1	1
11/21/2022 15:00	1	1
11/21/2022 16:00	1	1
11/21/2022 17:00	1	1
11/21/2022 18:00	1	1
11/21/2022 19:00	1	1
11/21/2022 20:00	1	1
11/21/2022 21:00	1	1
11/21/2022 22:00	1	1
11/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/22/2022 00:00	1	1
11/22/2022 01:00	1	1
11/22/2022 02:00	1	1
11/22/2022 03:00	1	1
11/22/2022 04:00	1	1
11/22/2022 05:00	1	1
11/22/2022 06:00	1	1
11/22/2022 07:00	1	1
11/22/2022 08:00	1	1
11/22/2022 09:00	1	1
11/22/2022 10:00	1	1
11/22/2022 11:00	1	1
11/22/2022 12:00	4	1
11/22/2022 13:00	4	1
11/22/2022 14:00	4	1
11/22/2022 15:00	4	1
11/22/2022 16:00	1	1
11/22/2022 17:00	1	1
11/22/2022 18:00	1	1
11/22/2022 19:00	1	1
11/22/2022 20:00	1	1
11/22/2022 21:00	1	1
11/22/2022 22:00	1	1
11/22/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	4	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/23/2022 00:00	1	1
11/23/2022 01:00	1	1
11/23/2022 02:00	1	1
11/23/2022 03:00	1	1
11/23/2022 04:00	1	1
11/23/2022 05:00	1	1
11/23/2022 06:00	1	1
11/23/2022 07:00	1	1
11/23/2022 08:00	1	1
11/23/2022 09:00	1	1
11/23/2022 10:00	1	1
11/23/2022 11:00	1	1
11/23/2022 12:00	1	0
11/23/2022 13:00	1	0
11/23/2022 14:00	1	0
11/23/2022 15:00	1	0
11/23/2022 16:00	1	1
11/23/2022 17:00	1	1
11/23/2022 18:00	1	1
11/23/2022 19:00	1	1
11/23/2022 20:00	1	1
11/23/2022 21:00	1	1
11/23/2022 22:00	1	1
11/23/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/24/2022 00:00	1	1
11/24/2022 01:00	1	1
11/24/2022 02:00	1	1
11/24/2022 03:00	1	1
11/24/2022 04:00	1	1
11/24/2022 05:00	1	1
11/24/2022 06:00	1	1
11/24/2022 07:00	1	1
11/24/2022 08:00	1	1
11/24/2022 09:00	1	1
11/24/2022 10:00	1	1
11/24/2022 11:00	1	0
11/24/2022 12:00	1	0
11/24/2022 13:00	1	0
11/24/2022 14:00	1	0
11/24/2022 15:00	1	0
11/24/2022 16:00	1	0
11/24/2022 17:00	1	0
11/24/2022 18:00	1	1
11/24/2022 19:00	1	1
11/24/2022 20:00	1	1
11/24/2022 21:00	1	1
11/24/2022 22:00	1	1
11/24/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/25/2022 00:00	1	1
11/25/2022 01:00	1	1
11/25/2022 02:00	1	1
11/25/2022 03:00	1	1
11/25/2022 04:00	1	1
11/25/2022 05:00	1	1
11/25/2022 06:00	1	1
11/25/2022 07:00	1	1
11/25/2022 08:00	1	1
11/25/2022 09:00	1	1
11/25/2022 10:00	1	1
11/25/2022 11:00	1	1
11/25/2022 12:00	1	1
11/25/2022 13:00	1	0
11/25/2022 14:00	1	0
11/25/2022 15:00	1	0
11/25/2022 16:00	1	1
11/25/2022 17:00	1	1
11/25/2022 18:00	1	1
11/25/2022 19:00	1	1
11/25/2022 20:00	1	1
11/25/2022 21:00	1	1
11/25/2022 22:00	1	1
11/25/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/26/2022 00:00	1	1
11/26/2022 01:00	1	1
11/26/2022 02:00	1	1
11/26/2022 03:00	1	1
11/26/2022 04:00	1	1
11/26/2022 05:00	1	1
11/26/2022 06:00	1	1
11/26/2022 07:00	1	1
11/26/2022 08:00	1	1
11/26/2022 09:00	1	1
11/26/2022 10:00	1	1
11/26/2022 11:00	1	1
11/26/2022 12:00	1	1
11/26/2022 13:00	1	1
11/26/2022 14:00	1	1
11/26/2022 15:00	1	1
11/26/2022 16:00	1	1
11/26/2022 17:00	1	1
11/26/2022 18:00	1	1
11/26/2022 19:00	1	1
11/26/2022 20:00	1	1
11/26/2022 21:00	1	1
11/26/2022 22:00	1	1
11/26/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/27/2022 00:00	1	1
11/27/2022 01:00	1	1
11/27/2022 02:00	1	1
11/27/2022 03:00	1	1
11/27/2022 04:00	1	1
11/27/2022 05:00	1	1
11/27/2022 06:00	1	1
11/27/2022 07:00	1	1
11/27/2022 08:00	1	1
11/27/2022 09:00	1	1
11/27/2022 10:00	1	1
11/27/2022 11:00	1	1
11/27/2022 12:00	1	1
11/27/2022 13:00	1	1
11/27/2022 14:00	1	1
11/27/2022 15:00	1	1
11/27/2022 16:00	1	1
11/27/2022 17:00	1	1
11/27/2022 18:00	1	1
11/27/2022 19:00	1	1
11/27/2022 20:00	1	1
11/27/2022 21:00	1	15
11/27/2022 22:00	1	21
11/27/2022 23:00	1	24
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	24
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/28/2022 00:00	1	23
11/28/2022 01:00	1	10
11/28/2022 02:00	14	4
11/28/2022 03:00	17	0
11/28/2022 04:00	17	0
11/28/2022 05:00	17	1
11/28/2022 06:00	4	1
11/28/2022 07:00	1	1
11/28/2022 08:00	1	1
11/28/2022 09:00	1	1
11/28/2022 10:00	1	1
11/28/2022 11:00	1	1
11/28/2022 12:00	1	0
11/28/2022 13:00	1	0
11/28/2022 14:00	1	0
11/28/2022 15:00	1	1
11/28/2022 16:00	1	1
11/28/2022 17:00	1	1
11/28/2022 18:00	1	1
11/28/2022 19:00	1	1
11/28/2022 20:00	1	1
11/28/2022 21:00	1	1
11/28/2022 22:00	1	1
11/28/2022 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	0
Maximum:	17	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/29/2022 00:00	1	1
11/29/2022 01:00	1	1
11/29/2022 02:00	1	1
11/29/2022 03:00	1	1
11/29/2022 04:00	1	1
11/29/2022 05:00	1	1
11/29/2022 06:00	1	1
11/29/2022 07:00	1	1
11/29/2022 08:00	1	1
11/29/2022 09:00	1	1
11/29/2022 10:00	1	1
11/29/2022 11:00	1	1
11/29/2022 12:00	1	1
11/29/2022 13:00	1	1
11/29/2022 14:00	1	1
11/29/2022 15:00	1	1
11/29/2022 16:00	1	1
11/29/2022 17:00	1	1
11/29/2022 18:00	1	1
11/29/2022 19:00	1	1
11/29/2022 20:00	1	1
11/29/2022 21:00	1	1
11/29/2022 22:00	1	1
11/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/30/2022 00:00	1	1
11/30/2022 01:00	1	1
11/30/2022 02:00	1	1
11/30/2022 03:00	1	1
11/30/2022 04:00	1	1
11/30/2022 05:00	1	1
11/30/2022 06:00	1	1
11/30/2022 07:00	1	1
11/30/2022 08:00	1	1
11/30/2022 09:00	1	1
11/30/2022 10:00	1	1
11/30/2022 11:00	1	1
11/30/2022 12:00	1	1
11/30/2022 13:00	1	1
11/30/2022 14:00	1	1
11/30/2022 15:00	1	1
11/30/2022 16:00	1	1
11/30/2022 17:00	1	1
11/30/2022 18:00	1	1
11/30/2022 19:00	1	1
11/30/2022 20:00	1	1
11/30/2022 21:00	1	1
11/30/2022 22:00	1	1
11/30/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/01/2022 00:00	1	1
12/01/2022 01:00	1	1
12/01/2022 02:00	1	2
12/01/2022 03:00	1	4
12/01/2022 04:00	1	3
12/01/2022 05:00	1	3
12/01/2022 06:00	1	2
12/01/2022 07:00	1	1
12/01/2022 08:00	1	1
12/01/2022 09:00	1	1
12/01/2022 10:00	1	1
12/01/2022 11:00	1	1
12/01/2022 12:00	1	1
12/01/2022 13:00	1	1
12/01/2022 14:00	1	1
12/01/2022 15:00	1	1
12/01/2022 16:00	1	1
12/01/2022 17:00	1	1
12/01/2022 18:00	1	1
12/01/2022 19:00	1	1
12/01/2022 20:00	1	1
12/01/2022 21:00	1	1
12/01/2022 22:00	1	1
12/01/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/02/2022 00:00	1	1
12/02/2022 01:00	1	1
12/02/2022 02:00	1	1
12/02/2022 03:00	1	1
12/02/2022 04:00	1	1
12/02/2022 05:00	1	1
12/02/2022 06:00	1	1
12/02/2022 07:00	1	1
12/02/2022 08:00	1	1
12/02/2022 09:00	1	1
12/02/2022 10:00	1	1
12/02/2022 11:00	1	1
12/02/2022 12:00	1	1
12/02/2022 13:00	1	1
12/02/2022 14:00	1	1
12/02/2022 15:00	1	1
12/02/2022 16:00	1	1
12/02/2022 17:00	1	1
12/02/2022 18:00	1	1
12/02/2022 19:00	1	1
12/02/2022 20:00	1	1
12/02/2022 21:00	1	1
12/02/2022 22:00	1	1
12/02/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/03/2022 00:00	1	1
12/03/2022 01:00	1	1
12/03/2022 02:00	1	1
12/03/2022 03:00	1	1
12/03/2022 04:00	1	1
12/03/2022 05:00	1	1
12/03/2022 06:00	1	1
12/03/2022 07:00	1	1
12/03/2022 08:00	1	1
12/03/2022 09:00	1	1
12/03/2022 10:00	1	1
12/03/2022 11:00	1	1
12/03/2022 12:00	1	1
12/03/2022 13:00	1	1
12/03/2022 14:00	1	1
12/03/2022 15:00	1	1
12/03/2022 16:00	1	1
12/03/2022 17:00	1	1
12/03/2022 18:00	1	1
12/03/2022 19:00	1	1
12/03/2022 20:00	1	1
12/03/2022 21:00	1	1
12/03/2022 22:00	1	1
12/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/04/2022 00:00	1	1
12/04/2022 01:00	1	1
12/04/2022 02:00	1	1
12/04/2022 03:00	1	1
12/04/2022 04:00	1	1
12/04/2022 05:00	1	1
12/04/2022 06:00	1	1
12/04/2022 07:00	1	1
12/04/2022 08:00	1	1
12/04/2022 09:00	1	1
12/04/2022 10:00	1	1
12/04/2022 11:00	1	1
12/04/2022 12:00	1	1
12/04/2022 13:00	1	1
12/04/2022 14:00	1	1
12/04/2022 15:00	1	1
12/04/2022 16:00	1	1
12/04/2022 17:00	1	1
12/04/2022 18:00	1	1
12/04/2022 19:00	1	1
12/04/2022 20:00	1	1
12/04/2022 21:00	1	1
12/04/2022 22:00	1	1
12/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/05/2022 00:00	1	1
12/05/2022 01:00	1	1
12/05/2022 02:00	1	1
12/05/2022 03:00	1	1
12/05/2022 04:00	1	1
12/05/2022 05:00	1	1
12/05/2022 06:00	1	1
12/05/2022 07:00	1	1
12/05/2022 08:00	1	1
12/05/2022 09:00	4	1
12/05/2022 10:00	15	1
12/05/2022 11:00	15	1
12/05/2022 12:00	15	1
12/05/2022 13:00	12	1
12/05/2022 14:00	1	1
12/05/2022 15:00	1	1
12/05/2022 16:00	1	1
12/05/2022 17:00	1	1
12/05/2022 18:00	1	1
12/05/2022 19:00	1	1
12/05/2022 20:00	1	1
12/05/2022 21:00	1	1
12/05/2022 22:00	1	1
12/05/2022 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	15	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/06/2022 00:00	1	1
12/06/2022 01:00	1	1
12/06/2022 02:00	1	1
12/06/2022 03:00	1	1
12/06/2022 04:00	1	1
12/06/2022 05:00	1	1
12/06/2022 06:00	1	1
12/06/2022 07:00	1	1
12/06/2022 08:00	1	1
12/06/2022 09:00	1	1
12/06/2022 10:00	1	1
12/06/2022 11:00	1	1
12/06/2022 12:00	1	1
12/06/2022 13:00	1	1
12/06/2022 14:00	1	1
12/06/2022 15:00	1	1
12/06/2022 16:00	1	0
12/06/2022 17:00	1	0
12/06/2022 18:00	1	0
12/06/2022 19:00	1	1
12/06/2022 20:00	1	1
12/06/2022 21:00	1	1
12/06/2022 22:00	1	1
12/06/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/07/2022 00:00	1	1
12/07/2022 01:00	1	1
12/07/2022 02:00	1	1
12/07/2022 03:00	1	1
12/07/2022 04:00	1	1
12/07/2022 05:00	1	1
12/07/2022 06:00	1	1
12/07/2022 07:00	1	1
12/07/2022 08:00	1	1
12/07/2022 09:00	1	1
12/07/2022 10:00	1	1
12/07/2022 11:00	1	1
12/07/2022 12:00	1	1
12/07/2022 13:00	1	1
12/07/2022 14:00	1	1
12/07/2022 15:00	1	1
12/07/2022 16:00	1	1
12/07/2022 17:00	1	1
12/07/2022 18:00	1	1
12/07/2022 19:00	1	1
12/07/2022 20:00	1	1
12/07/2022 21:00	1	1
12/07/2022 22:00	1	1
12/07/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/08/2022 00:00	1	1
12/08/2022 01:00	1	1
12/08/2022 02:00	1	1
12/08/2022 03:00	1	1
12/08/2022 04:00	1	1
12/08/2022 05:00	1	1
12/08/2022 06:00	1	1
12/08/2022 07:00	1	1
12/08/2022 08:00	1	1
12/08/2022 09:00	1	1
12/08/2022 10:00	1	1
12/08/2022 11:00	1	1
12/08/2022 12:00	1	1
12/08/2022 13:00	1	1
12/08/2022 14:00	1	1
12/08/2022 15:00	1	1
12/08/2022 16:00	1	1
12/08/2022 17:00	1	1
12/08/2022 18:00	1	1
12/08/2022 19:00	1	1
12/08/2022 20:00	1	1
12/08/2022 21:00	1	1
12/08/2022 22:00	1	1
12/08/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/09/2022 00:00	1	1
12/09/2022 01:00	1	1
12/09/2022 02:00	1	1
12/09/2022 03:00	1	1
12/09/2022 04:00	1	1
12/09/2022 05:00	1	1
12/09/2022 06:00	1	1
12/09/2022 07:00	1	1
12/09/2022 08:00	1	1
12/09/2022 09:00	1	1
12/09/2022 10:00	1	1
12/09/2022 11:00	1	1
12/09/2022 12:00	1	1
12/09/2022 13:00	1	1
12/09/2022 14:00	1	1
12/09/2022 15:00	1	1
12/09/2022 16:00	1	1
12/09/2022 17:00	1	1
12/09/2022 18:00	1	1
12/09/2022 19:00	1	1
12/09/2022 20:00	1	1
12/09/2022 21:00	1	1
12/09/2022 22:00	1	1
12/09/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/10/2022 00:00	1	1
12/10/2022 01:00	1	1
12/10/2022 02:00	1	1
12/10/2022 03:00	1	1
12/10/2022 04:00	1	1
12/10/2022 05:00	1	1
12/10/2022 06:00	1	1
12/10/2022 07:00	1	1
12/10/2022 08:00	1	1
12/10/2022 09:00	1	1
12/10/2022 10:00	1	1
12/10/2022 11:00	1	1
12/10/2022 12:00	1	1
12/10/2022 13:00	1	1
12/10/2022 14:00	1	1
12/10/2022 15:00	1	1
12/10/2022 16:00	1	1
12/10/2022 17:00	1	1
12/10/2022 18:00	1	1
12/10/2022 19:00	1	1
12/10/2022 20:00	1	1
12/10/2022 21:00	1	1
12/10/2022 22:00	1	1
12/10/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/11/2022 00:00	1	1
12/11/2022 01:00	1	1
12/11/2022 02:00	1	1
12/11/2022 03:00	1	1
12/11/2022 04:00	1	1
12/11/2022 05:00	1	1
12/11/2022 06:00	1	1
12/11/2022 07:00	1	1
12/11/2022 08:00	1	1
12/11/2022 09:00	1	1
12/11/2022 10:00	1	1
12/11/2022 11:00	1	1
12/11/2022 12:00	1	1
12/11/2022 13:00	1	1
12/11/2022 14:00	1	1
12/11/2022 15:00	1	1
12/11/2022 16:00	1	1
12/11/2022 17:00	1	1
12/11/2022 18:00	1	1
12/11/2022 19:00	1	1
12/11/2022 20:00	1	1
12/11/2022 21:00	1	1
12/11/2022 22:00	1	1
12/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/12/2022 00:00	1	1
12/12/2022 01:00	1	1
12/12/2022 02:00	1	1
12/12/2022 03:00	1	1
12/12/2022 04:00	1	1
12/12/2022 05:00	1	1
12/12/2022 06:00	1	1
12/12/2022 07:00	1	1
12/12/2022 08:00	1	1
12/12/2022 09:00	1	1
12/12/2022 10:00	1	1
12/12/2022 11:00	1	1
12/12/2022 12:00	1	1
12/12/2022 13:00	1	1
12/12/2022 14:00	1	1
12/12/2022 15:00	1	1
12/12/2022 16:00	1	1
12/12/2022 17:00	1	1
12/12/2022 18:00	1	1
12/12/2022 19:00	1	1
12/12/2022 20:00	1	1
12/12/2022 21:00	1	1
12/12/2022 22:00	1	1
12/12/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/13/2022 00:00	1	1
12/13/2022 01:00	1	1
12/13/2022 02:00	1	1
12/13/2022 03:00	1	1
12/13/2022 04:00	1	1
12/13/2022 05:00	1	1
12/13/2022 06:00	1	1
12/13/2022 07:00	1	1
12/13/2022 08:00	1	1
12/13/2022 09:00	1	1
12/13/2022 10:00	1	1
12/13/2022 11:00	1	1
12/13/2022 12:00	1	1
12/13/2022 13:00	1	1
12/13/2022 14:00	1	1
12/13/2022 15:00	1	1
12/13/2022 16:00	1	1
12/13/2022 17:00	1	1
12/13/2022 18:00	1	1
12/13/2022 19:00	1	1
12/13/2022 20:00	1	1
12/13/2022 21:00	1	1
12/13/2022 22:00	1	1
12/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/14/2022 00:00	1	1
12/14/2022 01:00	1	1
12/14/2022 02:00	1	1
12/14/2022 03:00	1	1
12/14/2022 04:00	1	1
12/14/2022 05:00	1	1
12/14/2022 06:00	1	1
12/14/2022 07:00	1	1
12/14/2022 08:00	1	1
12/14/2022 09:00	1	1
12/14/2022 10:00	1	1
12/14/2022 11:00	1	1
12/14/2022 12:00	1	1
12/14/2022 13:00	1	1
12/14/2022 14:00	1	1
12/14/2022 15:00	1	1
12/14/2022 16:00	1	1
12/14/2022 17:00	1	1
12/14/2022 18:00	1	1
12/14/2022 19:00	1	1
12/14/2022 20:00	1	1
12/14/2022 21:00	1	1
12/14/2022 22:00	1	1
12/14/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/15/2022 00:00	1	1
12/15/2022 01:00	1	1
12/15/2022 02:00	1	1
12/15/2022 03:00	1	1
12/15/2022 04:00	1	1
12/15/2022 05:00	1	1
12/15/2022 06:00	1	1
12/15/2022 07:00	1	1
12/15/2022 08:00	1	1
12/15/2022 09:00	1	1
12/15/2022 10:00	1	1
12/15/2022 11:00	1	1
12/15/2022 12:00	1	1
12/15/2022 13:00	1	1
12/15/2022 14:00	1	1
12/15/2022 15:00	1	1
12/15/2022 16:00	1	1
12/15/2022 17:00	1	1
12/15/2022 18:00	1	1
12/15/2022 19:00	1	1
12/15/2022 20:00	1	1
12/15/2022 21:00	1	1
12/15/2022 22:00	1	1
12/15/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/16/2022 00:00	1	1
12/16/2022 01:00	1	1
12/16/2022 02:00	1	1
12/16/2022 03:00	1	1
12/16/2022 04:00	1	1
12/16/2022 05:00	1	1
12/16/2022 06:00	1	1
12/16/2022 07:00	1	1
12/16/2022 08:00	1	1
12/16/2022 09:00	1	1
12/16/2022 10:00	1	1
12/16/2022 11:00	1	1
12/16/2022 12:00	1	1
12/16/2022 13:00	1	0
12/16/2022 14:00	1	0
12/16/2022 15:00	1	0
12/16/2022 16:00	1	1
12/16/2022 17:00	1	1
12/16/2022 18:00	1	1
12/16/2022 19:00	1	1
12/16/2022 20:00	1	1
12/16/2022 21:00	1	1
12/16/2022 22:00	1	1
12/16/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/17/2022 00:00	1	1
12/17/2022 01:00	1	1
12/17/2022 02:00	1	1
12/17/2022 03:00	1	1
12/17/2022 04:00	1	1
12/17/2022 05:00	1	1
12/17/2022 06:00	1	1
12/17/2022 07:00	1	1
12/17/2022 08:00	1	1
12/17/2022 09:00	1	1
12/17/2022 10:00	1	1
12/17/2022 11:00	1	1
12/17/2022 12:00	1	1
12/17/2022 13:00	1	1
12/17/2022 14:00	1	1
12/17/2022 15:00	1	1
12/17/2022 16:00	1	1
12/17/2022 17:00	1	1
12/17/2022 18:00	1	1
12/17/2022 19:00	1	1
12/17/2022 20:00	1	1
12/17/2022 21:00	1	1
12/17/2022 22:00	1	1
12/17/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/18/2022 00:00	1	1
12/18/2022 01:00	1	1
12/18/2022 02:00	1	1
12/18/2022 03:00	1	1
12/18/2022 04:00	1	1
12/18/2022 05:00	1	1
12/18/2022 06:00	1	1
12/18/2022 07:00	1	1
12/18/2022 08:00	1	1
12/18/2022 09:00	1	1
12/18/2022 10:00	1	1
12/18/2022 11:00	1	1
12/18/2022 12:00	1	0
12/18/2022 13:00	1	0
12/18/2022 14:00	1	0
12/18/2022 15:00	1	0
12/18/2022 16:00	1	1
12/18/2022 17:00	1	1
12/18/2022 18:00	1	1
12/18/2022 19:00	1	1
12/18/2022 20:00	1	1
12/18/2022 21:00	1	1
12/18/2022 22:00	1	1
12/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/19/2022 00:00	1	1
12/19/2022 01:00	1	1
12/19/2022 02:00	1	1
12/19/2022 03:00	1	1
12/19/2022 04:00	1	1
12/19/2022 05:00	1	1
12/19/2022 06:00	1	1
12/19/2022 07:00	1	1
12/19/2022 08:00	1	1
12/19/2022 09:00	1	1
12/19/2022 10:00	1	1
12/19/2022 11:00	1	1
12/19/2022 12:00	1	1
12/19/2022 13:00	1	1
12/19/2022 14:00	1	1
12/19/2022 15:00	1	1
12/19/2022 16:00	1	1
12/19/2022 17:00	1	1
12/19/2022 18:00	1	1
12/19/2022 19:00	1	1
12/19/2022 20:00	1	1
12/19/2022 21:00	1	1
12/19/2022 22:00	1	1
12/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/20/2022 00:00	1	1
12/20/2022 01:00	1	1
12/20/2022 02:00	1	1
12/20/2022 03:00	1	1
12/20/2022 04:00	1	1
12/20/2022 05:00	1	1
12/20/2022 06:00	1	1
12/20/2022 07:00	1	1
12/20/2022 08:00	1	1
12/20/2022 09:00	1	1
12/20/2022 10:00	1	1
12/20/2022 11:00	1	1
12/20/2022 12:00	1	1
12/20/2022 13:00	1	1
12/20/2022 14:00	1	1
12/20/2022 15:00	1	1
12/20/2022 16:00	1	1
12/20/2022 17:00	1	1
12/20/2022 18:00	1	1
12/20/2022 19:00	1	1
12/20/2022 20:00	1	1
12/20/2022 21:00	1	1
12/20/2022 22:00	1	1
12/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/21/2022 00:00	1	1
12/21/2022 01:00	1	1
12/21/2022 02:00	1	1
12/21/2022 03:00	1	1
12/21/2022 04:00	1	1
12/21/2022 05:00	1	1
12/21/2022 06:00	1	1
12/21/2022 07:00	1	1
12/21/2022 08:00	1	1
12/21/2022 09:00	1	1
12/21/2022 10:00	1	1
12/21/2022 11:00	1	1
12/21/2022 12:00	1	1
12/21/2022 13:00	1	1
12/21/2022 14:00	1	1
12/21/2022 15:00	1	1
12/21/2022 16:00	1	1
12/21/2022 17:00	1	1
12/21/2022 18:00	1	1
12/21/2022 19:00	1	1
12/21/2022 20:00	1	1
12/21/2022 21:00	1	1
12/21/2022 22:00	1	1
12/21/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/22/2022 00:00	1	1
12/22/2022 01:00	1	1
12/22/2022 02:00	1	1
12/22/2022 03:00	1	1
12/22/2022 04:00	1	1
12/22/2022 05:00	1	1
12/22/2022 06:00	1	1
12/22/2022 07:00	1	1
12/22/2022 08:00	1	1
12/22/2022 09:00	1	1
12/22/2022 10:00	1	1
12/22/2022 11:00	1	1
12/22/2022 12:00	1	1
12/22/2022 13:00	1	1
12/22/2022 14:00	1	1
12/22/2022 15:00	1	1
12/22/2022 16:00	1	1
12/22/2022 17:00	1	1
12/22/2022 18:00	1	1
12/22/2022 19:00	1	1
12/22/2022 20:00	1	1
12/22/2022 21:00	1	1
12/22/2022 22:00	1	1
12/22/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/23/2022 00:00	1	1
12/23/2022 01:00	1	1
12/23/2022 02:00	1	1
12/23/2022 03:00	1	1
12/23/2022 04:00	1	1
12/23/2022 05:00	1	1
12/23/2022 06:00	1	1
12/23/2022 07:00	1	1
12/23/2022 08:00	1	1
12/23/2022 09:00	1	1
12/23/2022 10:00	1	1
12/23/2022 11:00	1	1
12/23/2022 12:00	1	1
12/23/2022 13:00	1	1
12/23/2022 14:00	1	1
12/23/2022 15:00	1	1
12/23/2022 16:00	1	1
12/23/2022 17:00	1	1
12/23/2022 18:00	1	1
12/23/2022 19:00	1	1
12/23/2022 20:00	1	1
12/23/2022 21:00	1	1
12/23/2022 22:00	1	1
12/23/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/24/2022 00:00	1	1
12/24/2022 01:00	1	1
12/24/2022 02:00	1	1
12/24/2022 03:00	1	1
12/24/2022 04:00	1	1
12/24/2022 05:00	1	1
12/24/2022 06:00	1	1
12/24/2022 07:00	1	1
12/24/2022 08:00	1	1
12/24/2022 09:00	1	1
12/24/2022 10:00	1	1
12/24/2022 11:00	1	1
12/24/2022 12:00	1	0
12/24/2022 13:00	1	1
12/24/2022 14:00	1	1
12/24/2022 15:00	1	1
12/24/2022 16:00	1	1
12/24/2022 17:00	1	1
12/24/2022 18:00	1	1
12/24/2022 19:00	1	1
12/24/2022 20:00	1	1
12/24/2022 21:00	1	1
12/24/2022 22:00	1	1
12/24/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/25/2022 00:00	1	1
12/25/2022 01:00	2	2
12/25/2022 02:00	2	2
12/25/2022 03:00	2	2
12/25/2022 04:00	2	2
12/25/2022 05:00	2	2
12/25/2022 06:00	2	2
12/25/2022 07:00	2	2
12/25/2022 08:00	2	2
12/25/2022 09:00	2	2
12/25/2022 10:00	2	2
12/25/2022 11:00	2	2
12/25/2022 12:00	2	2
12/25/2022 13:00	2	2
12/25/2022 14:00	2	2
12/25/2022 15:00	2	2
12/25/2022 16:00	2	2
12/25/2022 17:00	2	2
12/25/2022 18:00	2	15
12/25/2022 19:00	2	19
12/25/2022 20:00	2	22
12/25/2022 21:00	2	20
12/25/2022 22:00	2	7
12/25/2022 23:00	2	3
Average/Sum#:	2	5
Minimum:	1	1
Maximum:	2	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/26/2022 00:00	15	1
12/26/2022 01:00	19	1
12/26/2022 02:00	19	1
12/26/2022 03:00	18	1
12/26/2022 04:00	5	0
12/26/2022 05:00	1	1
12/26/2022 06:00	1	1
12/26/2022 07:00	1	1
12/26/2022 08:00	1	1
12/26/2022 09:00	1	0
12/26/2022 10:00	1	0
12/26/2022 11:00	1	0
12/26/2022 12:00	1	0
12/26/2022 13:00	1	0
12/26/2022 14:00	1	0
12/26/2022 15:00	1	0
12/26/2022 16:00	1	1
12/26/2022 17:00	1	1
12/26/2022 18:00	1	1
12/26/2022 19:00	1	1
12/26/2022 20:00	1	1
12/26/2022 21:00	1	1
12/26/2022 22:00	1	1
12/26/2022 23:00	2	2
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	19	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/27/2022 00:00	2	2
12/27/2022 01:00	2	2
12/27/2022 02:00	2	4
12/27/2022 03:00	2	4
12/27/2022 04:00	2	2
12/27/2022 05:00	5	3
12/27/2022 06:00	6	0
12/27/2022 07:00	6	1
12/27/2022 08:00	5	1
12/27/2022 09:00	2	1
12/27/2022 10:00	1	1
12/27/2022 11:00	1	1
12/27/2022 12:00	1	1
12/27/2022 13:00	1	1
12/27/2022 14:00	1	1
12/27/2022 15:00	1	1
12/27/2022 16:00	1	1
12/27/2022 17:00	1	1
12/27/2022 18:00	1	1
12/27/2022 19:00	1	1
12/27/2022 20:00	1	1
12/27/2022 21:00	1	1
12/27/2022 22:00	1	1
12/27/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	0
Maximum:	6	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/28/2022 00:00	1	1
12/28/2022 01:00	1	1
12/28/2022 02:00	1	0
12/28/2022 03:00	1	0
12/28/2022 04:00	1	0
12/28/2022 05:00	1	0
12/28/2022 06:00	1	0
12/28/2022 07:00	1	0
12/28/2022 08:00	1	1
12/28/2022 09:00	1	1
12/28/2022 10:00	1	0
12/28/2022 11:00	1	0
12/28/2022 12:00	1	0
12/28/2022 13:00	1	0
12/28/2022 14:00	1	0
12/28/2022 15:00	1	0
12/28/2022 16:00	1	1
12/28/2022 17:00	1	1
12/28/2022 18:00	1	1
12/28/2022 19:00	1	1
12/28/2022 20:00	1	1
12/28/2022 21:00	1	1
12/28/2022 22:00	1	1
12/28/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/29/2022 00:00	1	1
12/29/2022 01:00	1	1
12/29/2022 02:00	1	1
12/29/2022 03:00	1	1
12/29/2022 04:00	1	1
12/29/2022 05:00	1	1
12/29/2022 06:00	1	1
12/29/2022 07:00	1	1
12/29/2022 08:00	1	1
12/29/2022 09:00	1	1
12/29/2022 10:00	1	1
12/29/2022 11:00	1	1
12/29/2022 12:00	1	1
12/29/2022 13:00	1	1
12/29/2022 14:00	1	1
12/29/2022 15:00	1	1
12/29/2022 16:00	1	1
12/29/2022 17:00	1	1
12/29/2022 18:00	1	1
12/29/2022 19:00	1	1
12/29/2022 20:00	1	1
12/29/2022 21:00	1	1
12/29/2022 22:00	1	1
12/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/30/2022 00:00	2	2
12/30/2022 01:00	2	2
12/30/2022 02:00	2	2
12/30/2022 03:00	2	2
12/30/2022 04:00	2	2
12/30/2022 05:00	2	2
12/30/2022 06:00	2	2
12/30/2022 07:00	2	2
12/30/2022 08:00	2	2
12/30/2022 09:00	2	2
12/30/2022 10:00	2	2
12/30/2022 11:00	2	2
12/30/2022 12:00	2	2
12/30/2022 13:00	2	2
12/30/2022 14:00	2	2
12/30/2022 15:00	2	2
12/30/2022 16:00	2	2
12/30/2022 17:00	2	2
12/30/2022 18:00	2	2
12/30/2022 19:00	2	2
12/30/2022 20:00	2	2
12/30/2022 21:00	2	2
12/30/2022 22:00	2	2
12/30/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/31/2022 00:00	2	2
12/31/2022 01:00	2	2
12/31/2022 02:00	2	2
12/31/2022 03:00	2	2
12/31/2022 04:00	2	2
12/31/2022 05:00	2	2
12/31/2022 06:00	2	2
12/31/2022 07:00	2	2
12/31/2022 08:00	2	2
12/31/2022 09:00	2	2
12/31/2022 10:00	2	2
12/31/2022 11:00	2	2
12/31/2022 12:00	2	2
12/31/2022 13:00	2	2
12/31/2022 14:00	2	2
12/31/2022 15:00	2	2
12/31/2022 16:00	2	2
12/31/2022 17:00	2	2
12/31/2022 18:00	2	2
12/31/2022 19:00	2	2
12/31/2022 20:00	2	2
12/31/2022 21:00	2	2
12/31/2022 22:00	2	2
12/31/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:30 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 78.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**78.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:30 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 8.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**84.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:31 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:31 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:32 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:32 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,689.00 Hour(s)
Operating time for CMS: 1,689.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:36 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:37 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:39 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:39 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	1
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.17
4. Total Availability as a percentage of operating time	99.83

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:44 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:45 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:46 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:47 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:47 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:48 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:49 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:50 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:51 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s)
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/15/2022 14:00	11/15/2022 15:59	2	13 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	**1,689.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.88 %**
Percent Monitor Downtime:	**0.12 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Other known causes	2	100.00
8	Action	Quarterly Maintenance	2	100.00

Invalid Data Report

CT1 - Stack NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:51 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s)
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/15/2022 14:00	11/15/2022 15:59	2	13 - Maintenance	8 - Quarterly Maintenance

Total Operating Time:	**1,689.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.88 %**
Percent Monitor Downtime:	**0.12 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	2	100.00
8	Action	Quarterly Maintenance	2	100.00

Invalid Data Report

CT2 - Stack CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:52 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/04/2022 10:00	10/04/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	11/16/2022 11:00	11/16/2022 11:59	1	4 - Other known causes	3 - Performed manual calibration
3	12/21/2022 08:00	12/21/2022 08:59	1	5 - Unknown causes	3 - Performed manual calibration

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**3.00 Hour(s)**
Percent Monitor Availability:	**99.83 %**
Percent Monitor Downtime:	**0.17 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
3	Reason	Quality assurance calibration	1	33.33
5	Reason	Unknown causes	1	33.33
3	Action	Performed manual calibration	2	66.67
4	Action	Quarterly linearity/cga	1	33.33

Invalid Data Report

CT2 - Stack NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 09:52 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/04/2022 10:00	10/04/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	11/16/2022 11:00	11/16/2022 11:59	1	4 - Other known causes	3 - Performed manual calibration
3	12/21/2022 08:00	12/21/2022 08:59	1	5 - Unknown causes	3 - Performed manual calibration

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**3.00 Hour(s)**
Percent Monitor Availability:	**99.83 %**
Percent Monitor Downtime:	**0.17 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
3	Reason	Quality assurance calibration	1	33.33
5	Reason	Unknown causes	1	33.33
3	Action	Performed manual calibration	2	66.67
4	Action	Quarterly linearity/cga	1	33.33

ATTACHMENT 5
Hourly Emissions – VOC

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2022 00:00	-0.5	11.9	2,165.1	-0.1	1.5	1	1	1
10/01/2022 01:00	0.0	14.1	1,211.1	0.0	0.8	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.3	13.0	1,688.1	-0.1	1.2	2 #	1 #	2 #
Minimum:	-0.5	11.9	1,211.1	-0.1	0.8	0	0	0
Maximum:	0.0	14.1	2,165.1	0.0	1.5	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2022 02:00	0.0	17.5	336.0	0.0	0.2	1	0	0
10/03/2022 03:00	0.0	15.5	867.5	0.0	0.6	1	0	0
10/03/2022 04:00	0.3	13.8	1,711.7	0.4	1.2	1	1	0
10/03/2022 05:00	0.3	13.8	1,704.2	0.4	1.2	1	1	0
10/03/2022 06:00	0.3	13.8	1,701.6	0.4	1.2	1	1	0
10/03/2022 07:00	0.3	13.8	1,708.6	0.4	1.2	1	1	0
10/03/2022 08:00	0.4	13.8	1,718.8	0.4	1.2	1	1	0
10/03/2022 09:00	0.4	13.8	1,725.0	0.4	1.2	1	1	0
10/03/2022 10:00	0.2	13.9	1,728.2	0.3	1.2	1	1	0
10/03/2022 11:00	0.2	13.9	1,728.3	0.3	1.2	1	1	0
10/03/2022 12:00	0.2	13.9	1,728.4	0.3	1.2	1	1	0
10/03/2022 13:00	0.2	13.9	1,730.3	0.3	1.2	1	1	0
10/03/2022 14:00	0.2	13.9	1,724.6	0.3	1.2	1	1	0
10/03/2022 15:00	-0.1	13.6	1,766.0	0.1	1.2	1	1	1
10/03/2022 16:00	-1.1	12.3	2,061.1	-0.5	1.4	1	1	1
10/03/2022 17:00	-0.9	11.8	2,172.2	-0.4	1.5	1	1	1
10/03/2022 18:00	-0.8	11.6	2,206.8	-0.2	1.5	1	1	1
10/03/2022 19:00	-0.8	11.8	2,173.9	-0.2	1.5	1	1	1
10/03/2022 20:00	-0.8	11.7	2,187.2	-0.2	1.5	1	1	1
10/03/2022 21:00	-0.8	11.8	2,174.5	-0.2	1.5	1	1	1
10/03/2022 22:00	-0.8	12.0	2,152.4	-0.4	1.5	1	1	1
10/03/2022 23:00	-0.8	11.9	2,171.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.2	13.4	1,780.9	0.1	1.2	22 #	20 #	9 #
Minimum:	-1.1	11.6	336.0	-0.5	0.2	0	0	0
Maximum:	0.4	17.5	2,206.8	0.4	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2022 00:00	-0.8	12.0	2,154.5	-0.4	1.5	1	1	1
10/04/2022 01:00	-0.8	12.0	2,158.5	-0.4	1.5	1	1	1
10/04/2022 02:00	-0.8	12.0	2,156.3	-0.4	1.5	1	1	1
10/04/2022 03:00	-0.8	12.0	2,166.2	-0.4	1.5	1	1	1
10/04/2022 04:00	-0.8	12.0	2,173.6	-0.4	1.5	1	1	1
10/04/2022 05:00	-0.7	11.8	2,201.6	-0.2	1.5	1	1	1
10/04/2022 06:00	-0.7	12.0	2,166.7	-0.2	1.5	1	1	1
10/04/2022 07:00	-0.7	12.6	2,035.8	-0.2	1.4	1	1	1
10/04/2022 08:00	0.3	13.7	1,595.1	0.4	1.1	1	1	0
10/04/2022 09:00	0.2	13.8	1,547.9	0.3	1.1	1	1	0
10/04/2022 10:00	0.1	13.7	1,555.2	0.2	1.1	1	1	0
10/04/2022 11:00	0.1	13.7	1,564.0	0.2	1.1	1	1	0
10/04/2022 12:00	0.2	13.7	1,722.8	0.3	1.2	1	1	0
10/04/2022 13:00	-0.1	13.8	1,747.1	0.1	1.2	1	1	1
10/04/2022 14:00	-1.2	12.8	2,032.9	-0.7	1.4	1	1	1
10/04/2022 15:00	-0.9	12.0	2,150.2	-0.4	1.5	1	1	1
10/04/2022 16:00	-0.8	12.1	2,131.5	-0.4	1.5	1	1	1
10/04/2022 17:00	-0.8	12.0	2,143.7	-0.4	1.5	1	1	1
10/04/2022 18:00	-0.8	11.9	2,169.2	-0.4	1.5	1	1	1
10/04/2022 19:00	-0.8	11.9	2,185.2	-0.4	1.5	1	1	1
10/04/2022 20:00	-0.7	11.6	2,243.7	-0.2	1.6	1	1	1
10/04/2022 21:00	-0.7	11.9	2,190.4	-0.2	1.5	1	1	1
10/04/2022 22:00	-0.7	11.9	2,177.9	-0.2	1.5	1	1	1
10/04/2022 23:00	-0.8	12.2	2,144.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,021.5	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.6	1,547.9	-0.7	1.1	1	1	0
Maximum:	0.3	13.8	2,243.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	-0.8	12.2	2,136.7	-0.4	1.5	1	1	1
10/05/2022 01:00	-0.8	12.8	1,998.7	-0.4	1.4	1	1	1
10/05/2022 02:00	-0.9	13.0	1,971.1	-0.5	1.4	1	1	1
10/05/2022 03:00	-0.9	12.5	2,085.4	-0.5	1.5	1	1	1
10/05/2022 04:00	-0.9	12.3	2,111.1	-0.5	1.5	1	1	1
10/05/2022 05:00	-0.8	11.9	2,200.3	-0.4	1.5	1	1	1
10/05/2022 06:00	-0.7	11.9	2,201.4	-0.2	1.5	1	1	1
10/05/2022 07:00	-0.9	12.9	1,985.2	-0.5	1.4	1	1	1
10/05/2022 08:00	0.3	13.9	1,718.1	0.4	1.2	1	1	0
10/05/2022 09:00	0.3	13.9	1,682.9	0.4	1.2	1	1	0
10/05/2022 10:00	0.2	13.9	1,710.7	0.3	1.2	1	1	0
10/05/2022 11:00	0.2	13.9	1,722.4	0.3	1.2	1	1	0
10/05/2022 12:00	-0.4	13.8	1,738.9	-0.2	1.2	1	1	1
10/05/2022 13:00	-1.2	12.4	2,080.5	-0.7	1.5	1	1	1
10/05/2022 14:00	-0.9	11.8	2,190.4	-0.4	1.5	1	1	1
10/05/2022 15:00	-0.9	12.1	2,137.1	-0.4	1.5	1	1	1
10/05/2022 16:00	-0.8	11.9	2,159.1	-0.4	1.5	1	1	1
10/05/2022 17:00	-0.7	11.7	2,198.2	-0.2	1.5	1	1	1
10/05/2022 18:00	-0.7	11.6	2,230.9	-0.2	1.6	1	1	1
10/05/2022 19:00	-0.7	11.6	2,240.8	-0.2	1.6	1	1	1
10/05/2022 20:00	-0.7	11.9	2,190.7	-0.2	1.5	1	1	1
10/05/2022 21:00	-0.7	11.6	2,237.8	-0.2	1.6	1	1	1
10/05/2022 22:00	-0.8	12.0	2,166.4	-0.4	1.5	1	1	1
10/05/2022 23:00	-0.8	12.0	2,176.0	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,053.0	-0.2	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.6	1,682.9	-0.7	1.2	1	1	0
Maximum:	0.3	13.9	2,240.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	-0.8	12.1	2,165.7	-0.4	1.5	1	1	1
10/06/2022 01:00	-0.8	12.1	2,167.7	-0.4	1.5	1	1	1
10/06/2022 02:00	-0.8	12.1	2,165.0	-0.4	1.5	1	1	1
10/06/2022 03:00	-0.8	12.2	2,141.6	-0.4	1.5	1	1	1
10/06/2022 04:00	-0.5	12.0	2,181.3	-0.1	1.5	1	1	1
10/06/2022 05:00	-0.7	11.6	2,250.8	-0.2	1.6	1	1	1
10/06/2022 06:00	-0.5	11.8	2,238.5	-0.1	1.6	1	1	1
10/06/2022 07:00	-0.8	12.2	2,135.9	-0.4	1.5	1	1	1
10/06/2022 08:00	-0.8	12.4	2,082.9	-0.4	1.5	1	1	1
10/06/2022 09:00	-0.8	12.5	2,071.3	-0.4	1.4	1	1	1
10/06/2022 10:00	-0.8	12.5	2,082.0	-0.4	1.5	1	1	1
10/06/2022 11:00	-0.8	12.3	2,114.5	-0.4	1.5	1	1	1
10/06/2022 12:00	-0.8	12.1	2,136.7	-0.4	1.5	1	1	1
10/06/2022 13:00	-0.7	11.8	2,192.4	-0.2	1.5	1	1	1
10/06/2022 14:00	-0.7	11.8	2,197.6	-0.2	1.5	1	1	1
10/06/2022 15:00	-0.7	12.0	2,150.8	-0.2	1.5	1	1	1
10/06/2022 16:00	-0.7	11.8	2,191.5	-0.2	1.5	1	1	1
10/06/2022 17:00	-0.5	11.6	2,240.1	-0.1	1.6	1	1	1
10/06/2022 18:00	-0.5	11.7	2,239.0	-0.1	1.6	1	1	1
10/06/2022 19:00	-0.5	11.6	2,255.1	-0.1	1.6	1	1	1
10/06/2022 20:00	-0.5	11.6	2,259.5	-0.1	1.6	1	1	1
10/06/2022 21:00	-0.5	11.7	2,245.4	-0.1	1.6	1	1	1
10/06/2022 22:00	-0.7	12.0	2,190.1	-0.2	1.5	1	1	1
10/06/2022 23:00	-0.8	12.1	2,168.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,177.7	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	2,071.3	-0.4	1.4	1	1	1
Maximum:	-0.5	12.5	2,259.5	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	-0.8	12.2	2,143.9	-0.4	1.5	1	1	1
10/07/2022 01:00	-0.8	12.2	2,159.9	-0.4	1.5	1	1	1
10/07/2022 02:00	-0.8	12.2	2,141.6	-0.4	1.5	1	1	1
10/07/2022 03:00	-0.8	12.3	2,114.7	-0.4	1.5	1	1	1
10/07/2022 04:00	-0.8	12.2	2,155.6	-0.4	1.5	1	1	1
10/07/2022 05:00	-0.8	12.0	2,191.6	-0.4	1.5	1	1	1
10/07/2022 06:00	-0.7	12.0	2,204.6	-0.2	1.5	1	1	1
10/07/2022 07:00	-0.8	12.4	2,110.8	-0.4	1.5	1	1	1
10/07/2022 08:00	-0.8	12.7	2,030.0	-0.4	1.4	1	1	1
10/07/2022 09:00	-0.8	12.3	2,127.6	-0.4	1.5	1	1	1
10/07/2022 10:00	-0.8	12.3	2,127.5	-0.4	1.5	1	1	1
10/07/2022 11:00	-0.8	12.3	2,111.0	-0.4	1.5	1	1	1
10/07/2022 12:00	-0.8	12.0	2,168.6	-0.4	1.5	1	1	1
10/07/2022 13:00	-0.8	12.1	2,136.9	-0.4	1.5	1	1	1
10/07/2022 14:00	-0.7	11.9	2,182.3	-0.2	1.5	1	1	1
10/07/2022 15:00	-0.7	11.8	2,193.0	-0.2	1.5	1	1	1
10/07/2022 16:00	-0.7	11.9	2,179.2	-0.2	1.5	1	1	1
10/07/2022 17:00	-0.7	11.6	2,229.9	-0.2	1.6	1	1	1
10/07/2022 18:00	-0.5	11.6	2,243.3	-0.1	1.6	1	1	1
10/07/2022 19:00	-0.5	11.6	2,258.3	-0.1	1.6	1	1	1
10/07/2022 20:00	-0.5	11.6	2,262.5	-0.1	1.6	1	1	1
10/07/2022 21:00	-0.5	11.6	2,265.6	-0.1	1.6	1	1	1
10/07/2022 22:00	-0.5	11.7	2,257.3	-0.1	1.6	1	1	1
10/07/2022 23:00	-0.7	12.0	2,184.9	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,174.2	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	2,030.0	-0.4	1.4	1	1	1
Maximum:	-0.5	12.7	2,265.6	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	-0.8	12.1	2,173.3	-0.4	1.5	1	1	1
10/08/2022 01:00	-0.8	12.1	2,176.2	-0.4	1.5	1	1	1
10/08/2022 02:00	-0.8	12.1	2,167.4	-0.4	1.5	1	1	1
10/08/2022 03:00	-0.8	12.1	2,178.3	-0.4	1.5	1	1	1
10/08/2022 04:00	-0.8	12.0	2,176.1	-0.4	1.5	1	1	1
10/08/2022 05:00	-0.8	12.1	2,170.4	-0.4	1.5	1	1	1
10/08/2022 06:00	-0.8	12.3	2,110.4	-0.4	1.5	1	1	1
10/08/2022 07:00	-0.1	13.8	1,711.8	0.1	1.2	1	1	1
10/08/2022 08:00	0.1	13.9	1,365.6	0.2	1.0	1	1	0
10/08/2022 09:00	0.3	13.9	1,315.8	0.4	0.9	1	1	0
10/08/2022 10:00	0.3	14.0	1,312.6	0.4	0.9	1	1	0
10/08/2022 11:00	0.3	14.0	1,318.8	0.4	0.9	1	1	0
10/08/2022 12:00	0.2	13.8	1,569.8	0.3	1.1	1	1	0
10/08/2022 13:00	0.2	13.8	1,728.0	0.3	1.2	1	1	0
10/08/2022 14:00	-0.1	13.7	1,745.1	0.1	1.2	1	1	1
10/08/2022 15:00	-0.9	12.2	2,069.6	-0.4	1.4	1	1	1
10/08/2022 16:00	-0.8	11.7	2,201.9	-0.2	1.5	1	1	1
10/08/2022 17:00	-0.7	11.7	2,201.4	-0.2	1.5	1	1	1
10/08/2022 18:00	-0.8	11.9	2,167.0	-0.4	1.5	1	1	1
10/08/2022 19:00	-0.8	11.9	2,177.6	-0.4	1.5	1	1	1
10/08/2022 20:00	-0.8	11.9	2,180.4	-0.4	1.5	1	1	1
10/08/2022 21:00	-0.8	11.9	2,177.9	-0.4	1.5	1	1	1
10/08/2022 22:00	-0.8	12.0	2,173.3	-0.4	1.5	1	1	1
10/08/2022 23:00	-0.8	12.1	2,170.3	-0.4	1.5	1	1	1
Average/Sum#:	-0.5	12.6	1,947.5	-0.2	1.3	24 #	24 #	18 #
Minimum:	-0.9	11.7	1,312.6	-0.4	0.9	1	1	0
Maximum:	0.3	14.0	2,201.9	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	-0.8	12.0	2,166.8	-0.4	1.5	1	1	1
10/09/2022 01:00	-0.8	12.1	2,167.0	-0.4	1.5	1	1	1
10/09/2022 02:00	-0.8	12.2	2,138.4	-0.4	1.5	1	1	1
10/09/2022 03:00	-0.9	12.2	2,147.8	-0.4	1.5	1	1	1
10/09/2022 04:00	-0.8	12.1	2,158.6	-0.4	1.5	1	1	1
10/09/2022 05:00	-0.8	12.1	2,149.2	-0.4	1.5	1	1	1
10/09/2022 06:00	0.0	13.0	1,685.1	0.0	1.2	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	18.7	209.6	0.0	0.1	1	0	0
10/09/2022 11:00	0.0	15.6	799.9	0.0	0.6	1	0	0
10/09/2022 12:00	0.3	13.9	1,387.0	0.4	1.0	1	1	0
10/09/2022 13:00	0.3	14.0	1,390.9	0.4	1.0	1	1	0
10/09/2022 14:00	0.2	13.7	1,726.4	0.3	1.2	1	1	0
10/09/2022 15:00	0.2	13.8	1,562.3	0.3	1.1	1	1	0
10/09/2022 16:00	0.2	13.8	1,729.7	0.3	1.2	1	1	0
10/09/2022 17:00	-0.1	13.6	1,781.5	0.1	1.2	1	1	1
10/09/2022 18:00	-1.2	12.3	2,081.7	-0.7	1.5	1	1	1
10/09/2022 19:00	-0.8	11.7	2,209.0	-0.2	1.5	1	1	1
10/09/2022 20:00	-0.8	11.8	2,188.3	-0.2	1.5	1	1	1
10/09/2022 21:00	-0.8	11.9	2,174.8	-0.4	1.5	1	1	1
10/09/2022 22:00	-0.8	12.0	2,156.1	-0.4	1.5	1	1	1
10/09/2022 23:00	-0.8	12.1	2,147.1	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	13.1	1,817.0	-0.1	1.3	21 #	18 #	14 #
Minimum:	-1.2	11.7	209.6	-0.7	0.1	0	0	0
Maximum:	0.3	18.7	2,209.0	0.4	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	-0.8	12.2	2,121.9	-0.4	1.5	1	1	1
10/10/2022 01:00	-0.8	12.4	2,092.6	-0.4	1.5	1	1	1
10/10/2022 02:00	-1.1	12.9	1,980.8	-0.7	1.4	1	1	1
10/10/2022 03:00	-0.9	12.4	2,083.6	-0.5	1.5	1	1	1
10/10/2022 04:00	-0.8	12.3	2,127.1	-0.4	1.5	1	1	1
10/10/2022 05:00	-0.7	11.8	2,214.2	-0.2	1.5	1	1	1
10/10/2022 06:00	-0.7	11.9	2,205.4	-0.2	1.5	1	1	1
10/10/2022 07:00	-0.4	13.3	1,816.6	-0.1	1.3	1	1	1
10/10/2022 08:00	0.1	13.8	1,551.8	0.2	1.1	1	1	0
10/10/2022 09:00	0.3	13.9	1,545.1	0.4	1.1	1	1	0
10/10/2022 10:00	0.3	14.0	1,390.8	0.4	1.0	1	1	0
10/10/2022 11:00	0.3	13.9	1,560.6	0.4	1.1	1	1	0
10/10/2022 12:00	0.3	13.9	1,574.2	0.4	1.1	1	1	0
10/10/2022 13:00	0.3	13.8	1,729.9	0.4	1.2	1	1	0
10/10/2022 14:00	0.2	13.8	1,718.4	0.3	1.2	1	1	0
10/10/2022 15:00	0.2	13.8	1,602.6	0.3	1.1	1	1	0
10/10/2022 16:00	-1.1	12.6	1,973.3	-0.7	1.4	1	1	1
10/10/2022 17:00	-0.9	11.9	2,163.0	-0.4	1.5	1	1	1
10/10/2022 18:00	-0.8	11.7	2,198.7	-0.2	1.5	1	1	1
10/10/2022 19:00	-0.9	11.8	2,169.1	-0.4	1.5	1	1	1
10/10/2022 20:00	-0.9	11.9	2,160.6	-0.4	1.5	1	1	1
10/10/2022 21:00	-1.1	12.2	2,102.8	-0.5	1.5	1	1	1
10/10/2022 22:00	-1.1	12.4	2,085.4	-0.5	1.5	1	1	1
10/10/2022 23:00	-1.1	12.9	1,953.3	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	12.8	1,921.7	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.1	11.7	1,390.8	-0.7	1.0	1	1	0
Maximum:	0.3	14.0	2,214.2	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.1	13.9	1,376.2	0.1	1.0	1	1	0
10/11/2022 01:00	0.2	13.9	1,300.5	0.3	0.9	1	1	0
10/11/2022 02:00	0.2	13.9	1,300.2	0.3	0.9	1	1	0
10/11/2022 03:00	0.1	13.9	1,352.3	0.2	0.9	1	1	0
10/11/2022 04:00	0.2	13.9	1,495.7	0.3	1.0	1	1	0
10/11/2022 05:00	0.1	13.9	1,319.9	0.1	0.9	1	1	0
10/11/2022 06:00	0.0	13.9	1,313.8	0.1	0.9	1	1	0
10/11/2022 07:00	0.1	13.9	1,315.9	0.1	0.9	1	1	0
10/11/2022 08:00	0.1	13.9	1,317.2	0.2	0.9	1	1	0
10/11/2022 09:00	0.2	13.9	1,480.0	0.3	1.0	1	1	0
10/11/2022 10:00	0.2	13.9	1,548.1	0.3	1.1	1	1	0
10/11/2022 11:00	0.3	13.8	1,635.9	0.4	1.1	1	1	0
10/11/2022 12:00	0.2	13.6	1,802.5	0.3	1.3	1	1	0
10/11/2022 13:00	0.2	13.6	1,793.7	0.3	1.3	1	1	0
10/11/2022 14:00	0.2	13.6	1,789.9	0.3	1.3	1	1	0
10/11/2022 15:00	0.2	13.6	1,787.5	0.3	1.3	1	1	0
10/11/2022 16:00	0.2	13.6	1,788.3	0.3	1.3	1	1	0
10/11/2022 17:00	0.2	13.6	1,789.6	0.3	1.3	1	1	0
10/11/2022 18:00	-0.1	13.6	1,794.2	0.1	1.3	1	1	1
10/11/2022 19:00	-1.1	12.6	2,005.4	-0.7	1.4	1	1	1
10/11/2022 20:00	-0.9	12.1	2,131.3	-0.4	1.5	1	1	1
10/11/2022 21:00	-0.8	12.4	2,034.7	-0.4	1.4	1	1	1
10/11/2022 22:00	-0.8	12.2	2,102.6	-0.4	1.5	1	1	1
10/11/2022 23:00	-0.7	12.8	1,971.1	-0.4	1.4	1	1	1
Average/Sum#:	-0.1	13.5	1,647.8	0.1	1.2	24 #	24 #	6 #
Minimum:	-1.1	12.1	1,300.2	-0.7	0.9	1	1	0
Maximum:	0.3	13.9	2,131.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2022 00:00	-0.9	13.0	1,958.1	-0.5	1.4	1	1	1
10/12/2022 01:00	-0.9	13.0	1,935.0	-0.5	1.4	1	1	1
10/12/2022 02:00	0.1	13.8	1,519.8	0.2	1.1	1	1	0
10/12/2022 03:00	0.2	13.9	1,637.4	0.3	1.1	1	1	0
10/12/2022 04:00	0.2	13.7	1,768.9	0.3	1.2	1	1	0
10/12/2022 05:00	-1.1	12.0	2,131.1	-0.5	1.5	1	1	1
10/12/2022 06:00	-0.8	11.7	2,260.0	-0.2	1.6	1	1	1
10/12/2022 07:00	-0.7	11.7	2,255.1	-0.2	1.6	1	1	1
10/12/2022 08:00	-0.7	11.7	2,247.7	-0.2	1.6	1	1	1
10/12/2022 09:00	-0.7	11.7	2,246.9	-0.2	1.6	1	1	1
10/12/2022 10:00	-0.7	11.7	2,242.0	-0.2	1.6	1	1	1
10/12/2022 11:00	-0.7	11.7	2,245.9	-0.2	1.6	1	1	1
10/12/2022 12:00	-0.5	11.6	2,250.7	-0.1	1.6	1	1	1
10/12/2022 13:00	-0.5	11.6	2,248.0	-0.1	1.6	1	1	1
10/12/2022 14:00	-0.7	11.6	2,249.4	-0.2	1.6	1	1	1
10/12/2022 15:00	-0.7	11.6	2,250.4	-0.2	1.6	1	1	1
10/12/2022 16:00	-0.7	11.4	2,266.7	-0.2	1.6	1	1	1
10/12/2022 17:00	-0.7	11.4	2,274.9	-0.2	1.6	1	1	1
10/12/2022 18:00	-0.7	11.6	2,233.1	-0.2	1.6	1	1	1
10/12/2022 19:00	-0.9	12.1	2,138.2	-0.4	1.5	1	1	1
10/12/2022 20:00	-0.9	12.0	2,147.6	-0.4	1.5	1	1	1
10/12/2022 21:00	-0.9	12.2	2,119.1	-0.4	1.5	1	1	1
10/12/2022 22:00	-1.1	12.4	2,086.8	-0.5	1.5	1	1	1
10/12/2022 23:00	-1.2	12.9	1,967.8	-0.8	1.4	1	1	1
Average/Sum#:	-0.7	12.2	2,111.7	-0.2	1.5	24 #	24 #	21 #
Minimum:	-1.2	11.4	1,519.8	-0.8	1.1	1	1	0
Maximum:	0.2	13.9	2,274.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	-1.4	12.9	1,961.3	-0.8	1.4	1	1	1
10/13/2022 01:00	-1.2	12.7	2,005.0	-0.7	1.4	1	1	1
10/13/2022 02:00	-1.5	13.0	1,953.3	-0.9	1.4	1	1	1
10/13/2022 03:00	-1.4	13.0	1,959.2	-0.8	1.4	1	1	1
10/13/2022 04:00	-1.2	13.0	1,926.0	-0.8	1.3	1	1	1
10/13/2022 05:00	0.0	13.9	1,311.2	0.1	0.9	1	1	0
10/13/2022 06:00	0.0	13.9	1,311.4	0.1	0.9	1	1	0
10/13/2022 07:00	0.1	13.9	1,339.8	0.1	0.9	1	1	0
10/13/2022 08:00	0.2	13.8	1,587.0	0.3	1.1	1	1	0
10/13/2022 09:00	0.2	13.8	1,535.6	0.3	1.1	1	1	0
10/13/2022 10:00	0.2	13.6	1,804.0	0.3	1.3	1	1	0
10/13/2022 11:00	0.2	13.5	1,810.3	0.3	1.3	1	1	0
10/13/2022 12:00	0.2	13.6	1,808.3	0.3	1.3	1	1	0
10/13/2022 13:00	0.2	13.6	1,802.3	0.3	1.3	1	1	0
10/13/2022 14:00	0.2	13.6	1,793.3	0.3	1.3	1	1	0
10/13/2022 15:00	0.2	13.6	1,792.5	0.3	1.3	1	1	0
10/13/2022 16:00	0.2	13.6	1,790.7	0.3	1.3	1	1	0
10/13/2022 17:00	0.2	13.6	1,796.8	0.3	1.3	1	1	0
10/13/2022 18:00	0.2	13.5	1,804.3	0.3	1.3	1	1	0
10/13/2022 19:00	-0.2	13.5	1,807.0	-0.1	1.3	1	1	1
10/13/2022 20:00	-1.2	12.4	2,059.6	-0.7	1.4	1	1	1
10/13/2022 21:00	-1.1	12.0	2,159.9	-0.5	1.5	1	1	1
10/13/2022 22:00	-0.9	12.4	2,083.7	-0.5	1.5	1	1	1
10/13/2022 23:00	-0.9	12.5	2,071.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.4	13.3	1,803.1	-0.1	1.3	24 #	24 #	10 #
Minimum:	-1.5	12.0	1,311.2	-0.9	0.9	1	1	0
Maximum:	0.2	13.9	2,159.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	-0.8	12.6	2,061.0	-0.4	1.4	1	1	1
10/14/2022 01:00	-0.8	12.5	2,055.5	-0.4	1.4	1	1	1
10/14/2022 02:00	-0.8	12.5	2,056.0	-0.4	1.4	1	1	1
10/14/2022 03:00	-0.7	12.5	2,053.2	-0.2	1.4	1	1	1
10/14/2022 04:00	-0.7	12.3	2,098.1	-0.2	1.5	1	1	1
10/14/2022 05:00	-0.5	11.5	2,254.4	-0.1	1.6	1	1	1
10/14/2022 06:00	-0.4	11.5	2,261.5	0.1	1.6	1	1	1
10/14/2022 07:00	-0.4	11.5	2,266.0	0.1	1.6	1	1	1
10/14/2022 08:00	-0.7	12.5	2,033.0	-0.2	1.4	1	1	1
10/14/2022 09:00	-0.8	12.9	1,968.5	-0.4	1.4	1	1	1
10/14/2022 10:00	-0.8	12.7	1,978.5	-0.4	1.4	1	1	1
10/14/2022 11:00	-0.8	12.7	1,988.2	-0.4	1.4	1	1	1
10/14/2022 12:00	-0.8	12.7	1,992.9	-0.4	1.4	1	1	1
10/14/2022 13:00	-0.8	12.6	1,998.9	-0.4	1.4	1	1	1
10/14/2022 14:00	-0.8	12.2	2,104.1	-0.4	1.5	1	1	1
10/14/2022 15:00	-0.8	12.0	2,146.5	-0.4	1.5	1	1	1
10/14/2022 16:00	-0.7	12.0	2,145.1	-0.2	1.5	1	1	1
10/14/2022 17:00	-0.7	11.5	2,227.8	-0.2	1.6	1	1	1
10/14/2022 18:00	-0.8	11.9	2,153.4	-0.4	1.5	1	1	1
10/14/2022 19:00	-0.8	12.1	2,127.2	-0.4	1.5	1	1	1
10/14/2022 20:00	-0.8	12.0	2,134.2	-0.4	1.5	1	1	1
10/14/2022 21:00	-0.8	12.1	2,122.5	-0.4	1.5	1	1	1
10/14/2022 22:00	-0.8	12.3	2,095.3	-0.4	1.5	1	1	1
10/14/2022 23:00	0.0	13.9	1,333.3	0.0	0.9	1	0	1
Average/Sum#:	-0.7	12.3	2,069.0	-0.3	1.5	24 #	23 #	24 #
Minimum:	-0.8	11.5	1,333.3	-0.4	0.9	1	0	1
Maximum:	0.0	13.9	2,266.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 23:00	0.0	17.8	305.8	0.0	0.2	1	0	0
Average/Sum#:	0.0	17.8	305.8	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	17.8	305.8	0.0	0.2	0	0	0
Maximum:	0.0	17.8	305.8	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.0	15.6	846.3	0.0	0.6	1	0	0
10/17/2022 01:00	0.2	13.8	1,704.0	0.3	1.2	1	1	0
10/17/2022 02:00	0.2	13.8	1,714.0	0.3	1.2	1	1	0
10/17/2022 03:00	-0.1	13.7	1,810.2	0.1	1.3	1	1	1
10/17/2022 04:00	-0.9	12.3	2,087.2	-0.5	1.5	1	1	1
10/17/2022 05:00	-0.8	11.9	2,182.2	-0.4	1.5	1	1	1
10/17/2022 06:00	-0.8	12.2	2,151.6	-0.4	1.5	1	1	1
10/17/2022 07:00	-0.8	12.4	2,100.6	-0.4	1.5	1	1	1
10/17/2022 08:00	-0.2	13.6	1,691.4	-0.1	1.2	1	1	1
10/17/2022 09:00	0.3	13.8	1,644.4	0.4	1.2	1	1	0
10/17/2022 10:00	0.2	13.9	1,523.9	0.3	1.1	1	1	0
10/17/2022 11:00	0.3	13.8	1,608.2	0.4	1.1	1	1	0
10/17/2022 12:00	0.2	13.9	1,506.8	0.3	1.1	1	1	0
10/17/2022 13:00	0.2	13.9	1,513.1	0.3	1.1	1	1	0
10/17/2022 14:00	0.3	13.9	1,670.2	0.4	1.2	1	1	0
10/17/2022 15:00	-0.1	13.7	1,713.7	0.1	1.2	1	1	1
10/17/2022 16:00	-0.9	12.4	2,086.6	-0.5	1.5	1	1	1
10/17/2022 17:00	-0.7	11.6	2,242.9	-0.2	1.6	1	1	1
10/17/2022 18:00	-0.7	11.6	2,260.4	-0.2	1.6	1	1	1
10/17/2022 19:00	-0.7	11.7	2,236.0	-0.2	1.6	1	1	1
10/17/2022 20:00	-0.7	11.7	2,243.1	-0.2	1.6	1	1	1
10/17/2022 21:00	-0.7	11.6	2,256.3	-0.2	1.6	1	1	1
10/17/2022 22:00	-0.8	12.0	2,182.4	-0.4	1.5	1	1	1
10/17/2022 23:00	-0.8	12.0	2,180.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.0	1,881.5	-0.1	1.3	24 #	23 #	15 #
Minimum:	-0.9	11.6	846.3	-0.5	0.6	1	0	0
Maximum:	0.3	15.6	2,260.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	-0.8	12.0	2,175.4	-0.4	1.5	1	1	1
10/18/2022 01:00	-0.7	12.1	2,166.0	-0.2	1.5	1	1	1
10/18/2022 02:00	-0.5	12.0	2,168.9	-0.1	1.5	1	1	1
10/18/2022 03:00	-0.5	11.9	2,193.4	-0.1	1.5	1	1	1
10/18/2022 04:00	-0.5	11.9	2,192.8	-0.1	1.5	1	1	1
10/18/2022 05:00	-0.5	12.0	2,173.8	-0.1	1.5	1	1	1
10/18/2022 06:00	-0.7	12.2	2,149.9	-0.2	1.5	1	1	1
10/18/2022 07:00	-0.7	12.1	2,148.0	-0.2	1.5	1	1	1
10/18/2022 08:00	-0.8	12.1	2,167.9	-0.4	1.5	1	1	1
10/18/2022 09:00	-0.8	12.1	2,165.6	-0.4	1.5	1	1	1
10/18/2022 10:00	-0.9	12.2	2,133.5	-0.4	1.5	1	1	1
10/18/2022 11:00	-0.9	12.3	2,107.8	-0.5	1.5	1	1	1
10/18/2022 12:00	-0.8	12.3	2,105.5	-0.4	1.5	1	1	1
10/18/2022 13:00	-0.9	12.3	2,109.2	-0.5	1.5	1	1	1
10/18/2022 14:00	-0.9	12.2	2,117.2	-0.4	1.5	1	1	1
10/18/2022 15:00	-0.9	12.1	2,149.3	-0.4	1.5	1	1	1
10/18/2022 16:00	-0.7	11.7	2,239.2	-0.2	1.6	1	1	1
10/18/2022 17:00	-0.8	11.9	2,202.8	-0.4	1.5	1	1	1
10/18/2022 18:00	-0.7	11.7	2,249.3	-0.2	1.6	1	1	1
10/18/2022 19:00	-0.7	11.6	2,271.7	-0.2	1.6	1	1	1
10/18/2022 20:00	-0.7	11.6	2,277.4	-0.2	1.6	1	1	1
10/18/2022 21:00	-0.7	11.6	2,277.9	-0.2	1.6	1	1	1
10/18/2022 22:00	-0.8	11.9	2,202.9	-0.4	1.5	1	1	1
10/18/2022 23:00	-0.8	11.9	2,201.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.7	12.0	2,181.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	2,105.5	-0.5	1.5	1	1	1
Maximum:	-0.5	12.3	2,277.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2022 00:00	-0.9	12.0	2,189.4	-0.4	1.5	1	1	1
10/19/2022 01:00	-0.8	12.4	2,117.8	-0.4	1.5	1	1	1
10/19/2022 02:00	-0.7	12.5	2,070.1	-0.2	1.4	1	1	1
10/19/2022 03:00	-0.5	12.3	2,105.5	-0.1	1.5	1	1	1
10/19/2022 04:00	-0.5	12.1	2,139.4	-0.1	1.5	1	1	1
10/19/2022 05:00	-0.4	11.7	2,201.4	0.1	1.5	1	1	1
10/19/2022 06:00	-0.8	11.9	2,222.6	-0.4	1.6	1	1	1
10/19/2022 07:00	-0.9	12.2	2,151.9	-0.4	1.5	1	1	1
10/19/2022 08:00	-0.9	12.3	2,140.6	-0.5	1.5	1	1	1
10/19/2022 09:00	-0.9	12.4	2,101.5	-0.5	1.5	1	1	1
10/19/2022 10:00	-0.9	12.4	2,092.4	-0.5	1.5	1	1	1
10/19/2022 11:00	-0.9	12.2	2,121.8	-0.4	1.5	1	1	1
10/19/2022 12:00	-0.9	12.1	2,136.5	-0.4	1.5	1	1	1
10/19/2022 13:00	-0.8	12.0	2,154.1	-0.4	1.5	1	1	1
10/19/2022 14:00	-0.8	12.1	2,145.1	-0.4	1.5	1	1	1
10/19/2022 15:00	-0.8	11.8	2,185.0	-0.2	1.5	1	1	1
10/19/2022 16:00	-0.8	11.7	2,199.7	-0.2	1.5	1	1	1
10/19/2022 17:00	-0.9	12.1	2,124.9	-0.4	1.5	1	1	1
10/19/2022 18:00	-0.9	12.2	2,109.1	-0.4	1.5	1	1	1
10/19/2022 19:00	-0.9	12.2	2,115.7	-0.4	1.5	1	1	1
10/19/2022 20:00	-0.9	12.1	2,154.7	-0.4	1.5	1	1	1
10/19/2022 21:00	-0.9	12.3	2,120.2	-0.5	1.5	1	1	1
10/19/2022 22:00	-0.9	12.4	2,092.4	-0.5	1.5	1	1	1
10/19/2022 23:00	-0.9	12.3	2,111.2	-0.5	1.5	1	1	1
Average/Sum#:	-0.8	12.2	2,137.6	-0.4	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.7	2,070.1	-0.5	1.4	1	1	1
Maximum:	-0.4	12.5	2,222.6	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	-0.9	12.3	2,129.2	-0.5	1.5	1	1	1
10/20/2022 01:00	-0.9	12.4	2,089.4	-0.5	1.5	1	1	1
10/20/2022 02:00	-0.9	12.5	2,083.4	-0.5	1.5	1	1	1
10/20/2022 03:00	-1.1	12.4	2,093.7	-0.5	1.5	1	1	1
10/20/2022 04:00	-0.9	12.3	2,133.0	-0.5	1.5	1	1	1
10/20/2022 05:00	-0.7	11.8	2,202.7	-0.2	1.5	1	1	1
10/20/2022 06:00	-0.8	12.0	2,196.1	-0.4	1.5	1	1	1
10/20/2022 07:00	-0.9	12.6	2,066.6	-0.5	1.4	1	1	1
10/20/2022 08:00	-0.9	12.6	2,058.0	-0.5	1.4	1	1	1
10/20/2022 09:00	-0.9	12.5	2,072.7	-0.5	1.5	1	1	1
10/20/2022 10:00	-0.9	12.5	2,068.4	-0.5	1.4	1	1	1
10/20/2022 11:00	-0.9	12.4	2,087.7	-0.5	1.5	1	1	1
10/20/2022 12:00	-0.9	12.3	2,089.8	-0.5	1.5	1	1	1
10/20/2022 13:00	-0.9	12.3	2,104.8	-0.5	1.5	1	1	1
10/20/2022 14:00	-0.9	12.2	2,117.9	-0.4	1.5	1	1	1
10/20/2022 15:00	-0.8	12.1	2,149.5	-0.4	1.5	1	1	1
10/20/2022 16:00	-0.7	11.5	2,255.7	-0.2	1.6	1	1	1
10/20/2022 17:00	-0.8	11.8	2,184.0	-0.2	1.5	1	1	1
10/20/2022 18:00	-0.8	11.7	2,231.4	-0.2	1.6	1	1	1
10/20/2022 19:00	-0.9	12.2	2,115.3	-0.4	1.5	1	1	1
10/20/2022 20:00	-0.9	12.2	2,110.7	-0.4	1.5	1	1	1
10/20/2022 21:00	-0.9	12.4	2,086.7	-0.5	1.5	1	1	1
10/20/2022 22:00	-0.9	12.4	2,088.4	-0.5	1.5	1	1	1
10/20/2022 23:00	-0.8	12.2	2,125.0	-0.4	1.5	1	1	1
Average/Sum#:	-0.9	12.2	2,122.5	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.5	2,058.0	-0.5	1.4	1	1	1
Maximum:	-0.7	12.6	2,255.7	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	-0.5	12.8	1,944.1	-0.2	1.4	1	1	1
10/21/2022 01:00	0.3	13.9	1,583.3	0.4	1.1	1	1	0
10/21/2022 02:00	0.3	13.9	1,597.9	0.4	1.1	1	1	0
10/21/2022 03:00	0.2	13.9	1,547.4	0.3	1.1	1	1	0
10/21/2022 04:00	0.3	13.9	1,708.6	0.4	1.2	1	1	0
10/21/2022 05:00	0.2	13.9	1,710.6	0.3	1.2	1	1	0
10/21/2022 06:00	0.2	13.9	1,608.8	0.3	1.1	1	1	0
10/21/2022 07:00	0.2	13.9	1,676.8	0.3	1.2	1	1	0
10/21/2022 08:00	0.3	13.9	1,716.7	0.4	1.2	1	1	0
10/21/2022 09:00	0.3	13.9	1,720.8	0.4	1.2	1	1	0
10/21/2022 10:00	0.3	13.9	1,719.5	0.4	1.2	1	1	0
10/21/2022 11:00	0.3	13.9	1,683.4	0.4	1.2	1	1	0
10/21/2022 12:00	0.2	13.8	1,661.0	0.3	1.2	1	1	0
10/21/2022 13:00	0.2	13.8	1,633.6	0.3	1.1	1	1	0
10/21/2022 14:00	0.1	13.8	1,692.1	0.2	1.2	1	1	0
10/21/2022 15:00	-0.4	13.8	1,568.6	-0.2	1.1	1	1	1
10/21/2022 16:00	-1.1	12.2	2,099.1	-0.5	1.5	1	1	1
10/21/2022 17:00	-0.9	11.8	2,183.0	-0.4	1.5	1	1	1
10/21/2022 18:00	-0.9	12.0	2,142.7	-0.4	1.5	1	1	1
10/21/2022 19:00	-1.1	12.3	2,098.0	-0.5	1.5	1	1	1
10/21/2022 20:00	-0.9	12.2	2,114.4	-0.4	1.5	1	1	1
10/21/2022 21:00	-0.9	11.9	2,175.3	-0.4	1.5	1	1	1
10/21/2022 22:00	0.0	14.0	1,230.6	0.0	0.9	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	13.4	1,774.6	0.1	1.2	23 #	22 #	9 #
Minimum:	-1.1	11.8	1,230.6	-0.5	0.9	0	0	0
Maximum:	0.3	14.0	2,183.0	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 12:00	0.0	21.0	2.2	0.0	0.0	1	0	0
10/24/2022 13:00	0.0	17.0	429.7	0.0	0.3	1	0	0
10/24/2022 14:00	0.0	14.1	1,572.3	0.0	1.1	1	0	0
10/24/2022 15:00	0.3	13.7	1,771.7	0.4	1.2	1	1	0
10/24/2022 16:00	0.3	13.7	1,770.8	0.4	1.2	1	1	0
10/24/2022 17:00	0.3	13.7	1,779.7	0.4	1.2	1	1	0
10/24/2022 18:00	0.3	13.7	1,791.6	0.4	1.3	1	1	0
10/24/2022 19:00	0.3	13.7	1,799.7	0.4	1.3	1	1	0
10/24/2022 20:00	0.3	13.7	1,806.0	0.4	1.3	1	1	0
10/24/2022 21:00	0.3	13.7	1,813.9	0.4	1.3	1	1	0
10/24/2022 22:00	0.3	13.7	1,810.6	0.4	1.3	1	1	0
10/24/2022 23:00	0.3	13.7	1,822.7	0.4	1.3	1	1	0
Average/Sum#:	0.2	14.6	1,514.2	0.3	1.1	12 #	9 #	0 #
Minimum:	0.0	13.7	2.2	0.0	0.0	0	0	0
Maximum:	0.3	21.0	1,822.7	0.4	1.3	1	1	0
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.3	13.7	1,809.3	0.4	1.3	1	1	0
10/25/2022 01:00	0.3	13.7	1,804.8	0.4	1.3	1	1	0
10/25/2022 02:00	0.3	13.8	1,804.4	0.4	1.3	1	1	0
10/25/2022 03:00	0.3	13.8	1,802.4	0.4	1.3	1	1	0
10/25/2022 04:00	0.3	13.8	1,805.0	0.4	1.3	1	1	0
10/25/2022 05:00	0.3	13.8	1,808.1	0.4	1.3	1	1	0
10/25/2022 06:00	0.3	13.8	1,808.2	0.4	1.3	1	1	0
10/25/2022 07:00	0.3	13.8	1,807.7	0.4	1.3	1	1	0
10/25/2022 08:00	0.3	13.7	1,812.1	0.4	1.3	1	1	0
10/25/2022 09:00	0.3	13.7	1,815.9	0.4	1.3	1	1	0
10/25/2022 10:00	0.3	13.7	1,814.8	0.4	1.3	1	1	0
10/25/2022 11:00	0.2	13.7	1,829.7	0.3	1.3	1	1	0
10/25/2022 12:00	0.2	13.7	1,832.3	0.3	1.3	1	1	0
10/25/2022 13:00	0.2	13.6	1,836.6	0.3	1.3	1	1	0
10/25/2022 14:00	0.2	13.6	1,831.6	0.3	1.3	1	1	0
10/25/2022 15:00	0.2	13.6	1,832.4	0.3	1.3	1	1	0
10/25/2022 16:00	0.2	13.6	1,831.0	0.3	1.3	1	1	0
10/25/2022 17:00	0.2	13.6	1,834.2	0.3	1.3	1	1	0
10/25/2022 18:00	0.2	13.7	1,826.1	0.3	1.3	1	1	0
10/25/2022 19:00	0.2	13.7	1,814.8	0.3	1.3	1	1	0
10/25/2022 20:00	0.2	13.7	1,807.6	0.3	1.3	1	1	0
10/25/2022 21:00	0.2	13.7	1,809.8	0.3	1.3	1	1	0
10/25/2022 22:00	0.3	13.7	1,804.5	0.4	1.3	1	1	0
10/25/2022 23:00	0.3	13.9	1,635.5	0.4	1.1	1	1	0
Average/Sum#:	0.3	13.7	1,809.1	0.4	1.3	24 #	24 #	0 #
Minimum:	0.2	13.6	1,635.5	0.3	1.1	1	1	0
Maximum:	0.3	13.9	1,836.6	0.4	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.3	13.8	1,630.9	0.4	1.1	1	1	0
10/26/2022 01:00	0.3	13.9	1,631.9	0.4	1.1	1	1	0
10/26/2022 02:00	0.3	13.9	1,628.9	0.4	1.1	1	1	0
10/26/2022 03:00	0.3	13.9	1,616.4	0.4	1.1	1	1	0
10/26/2022 04:00	0.3	13.8	1,794.6	0.4	1.3	1	1	0
10/26/2022 05:00	0.3	13.9	1,733.8	0.4	1.2	1	1	0
10/26/2022 06:00	0.3	13.9	1,691.8	0.4	1.2	1	1	0
10/26/2022 07:00	0.3	13.8	1,742.7	0.4	1.2	1	1	0
10/26/2022 08:00	0.0	15.4	735.2	0.0	0.5	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	18.3	240.1	0.0	0.2	1	0	0
10/26/2022 17:00	0.0	17.6	391.6	0.0	0.3	1	0	0
10/26/2022 18:00	0.0	15.4	828.0	0.0	0.6	1	0	0
10/26/2022 19:00	0.2	13.7	1,825.1	0.3	1.3	1	1	0
10/26/2022 20:00	0.2	13.7	1,820.3	0.3	1.3	1	1	0
10/26/2022 21:00	0.2	13.7	1,810.2	0.3	1.3	1	1	0
10/26/2022 22:00	0.2	13.7	1,764.5	0.3	1.2	1	1	0
10/26/2022 23:00	0.0	14.5	1,164.0	0.0	0.8	1	0	0
Average/Sum#:	0.2	14.5	1,414.7	0.3	1.0	17 #	12 #	0 #
Minimum:	0.0	13.7	240.1	0.0	0.2	0	0	0
Maximum:	0.3	18.3	1,825.1	0.4	1.3	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/31/2022 01:00	0.0	17.7	299.3	0.0	0.2	1	0	0
10/31/2022 02:00	0.0	16.0	725.0	0.0	0.5	1	0	0
10/31/2022 03:00	0.2	13.8	1,712.6	0.3	1.2	1	1	0
10/31/2022 04:00	0.2	13.8	1,726.3	0.3	1.2	1	1	0
10/31/2022 05:00	0.2	13.8	1,711.3	0.3	1.2	1	1	0
10/31/2022 06:00	0.2	13.8	1,692.8	0.3	1.2	1	1	0
10/31/2022 07:00	0.2	13.8	1,693.6	0.3	1.2	1	1	0
10/31/2022 08:00	0.2	13.8	1,704.5	0.3	1.2	1	1	0
10/31/2022 09:00	0.2	13.9	1,706.8	0.3	1.2	1	1	0
10/31/2022 10:00	0.2	13.9	1,708.4	0.3	1.2	1	1	0
10/31/2022 11:00	0.2	13.9	1,689.0	0.3	1.2	1	1	0
10/31/2022 12:00	0.3	13.9	1,687.9	0.4	1.2	1	1	0
10/31/2022 13:00	0.3	13.9	1,702.8	0.4	1.2	1	1	0
10/31/2022 14:00	-0.2	13.7	1,767.7	-0.1	1.2	1	1	1
10/31/2022 15:00	-1.2	12.5	2,082.4	-0.7	1.5	1	1	1
10/31/2022 16:00	-1.1	12.3	2,105.6	-0.5	1.5	1	1	1
10/31/2022 17:00	-1.1	12.4	2,076.3	-0.5	1.5	1	1	1
10/31/2022 18:00	-1.1	12.4	2,082.4	-0.5	1.5	1	1	1
10/31/2022 19:00	-1.1	12.4	2,103.6	-0.5	1.5	1	1	1
10/31/2022 20:00	-0.9	12.4	2,089.0	-0.5	1.5	1	1	1
10/31/2022 21:00	-0.8	12.2	2,130.3	-0.4	1.5	1	1	1
10/31/2022 22:00	-0.8	12.3	2,096.7	-0.4	1.5	1	1	1
10/31/2022 23:00	-0.8	12.2	2,136.9	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.5	1,757.9	0.0	1.2	23 #	21 #	10 #
Minimum:	-1.2	12.2	299.3	-0.7	0.2	0	0	0
Maximum:	0.3	17.7	2,136.9	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	-0.8	12.2	2,154.2	-0.4	1.5	1	1	1
11/01/2022 01:00	-0.8	12.2	2,150.3	-0.4	1.5	1	1	1
11/01/2022 02:00	-0.8	12.2	2,158.5	-0.4	1.5	1	1	1
11/01/2022 03:00	-0.8	12.2	2,167.8	-0.4	1.5	1	1	1
11/01/2022 04:00	-0.8	12.2	2,175.8	-0.4	1.5	1	1	1
11/01/2022 05:00	-0.8	12.1	2,176.4	-0.4	1.5	1	1	1
11/01/2022 06:00	-0.7	11.8	2,250.2	-0.2	1.6	1	1	1
11/01/2022 07:00	-0.7	12.0	2,187.2	-0.2	1.5	1	1	1
11/01/2022 08:00	-0.5	11.7	2,240.2	-0.1	1.6	1	1	1
11/01/2022 09:00	-0.7	12.2	2,118.9	-0.2	1.5	1	1	1
11/01/2022 10:00	-0.8	12.3	2,123.0	-0.4	1.5	1	1	1
11/01/2022 11:00	-0.7	12.0	2,183.5	-0.2	1.5	1	1	1
11/01/2022 12:00	-0.7	11.9	2,189.4	-0.2	1.5	1	1	1
11/01/2022 13:00	-0.5	12.0	2,180.9	-0.1	1.5	1	1	1
11/01/2022 14:00	-0.7	12.4	2,089.8	-0.2	1.5	1	1	1
11/01/2022 15:00	-0.9	12.6	2,087.1	-0.5	1.5	1	1	1
11/01/2022 16:00	-0.7	12.1	2,204.2	-0.2	1.5	1	1	1
11/01/2022 17:00	-0.5	11.6	2,294.1	-0.1	1.6	1	1	1
11/01/2022 18:00	-0.7	12.1	2,186.6	-0.2	1.5	1	1	1
11/01/2022 19:00	-0.7	12.3	2,168.2	-0.2	1.5	1	1	1
11/01/2022 20:00	-0.7	12.1	2,209.2	-0.2	1.5	1	1	1
11/01/2022 21:00	-0.7	12.6	2,087.6	-0.2	1.5	1	1	1
11/01/2022 22:00	-0.7	12.7	2,075.1	-0.2	1.5	1	1	1
11/01/2022 23:00	-0.5	13.3	1,849.2	-0.2	1.3	1	1	1
Average/Sum#:	-0.7	12.2	2,154.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	1,849.2	-0.5	1.3	1	1	1
Maximum:	-0.5	13.3	2,294.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.1	13.9	1,353.8	0.1	0.9	1	1	0
11/02/2022 01:00	0.2	13.9	1,639.5	0.3	1.1	1	1	0
11/02/2022 02:00	0.2	13.8	1,709.9	0.3	1.2	1	1	0
11/02/2022 03:00	-0.2	13.9	1,353.8	0.0	0.9	1	1	0
11/02/2022 04:00	0.2	13.8	1,683.4	0.3	1.2	1	1	0
11/02/2022 05:00	-0.8	13.1	1,917.9	-0.5	1.3	1	1	1
11/02/2022 06:00	-0.9	12.5	2,169.6	-0.5	1.5	1	1	1
11/02/2022 07:00	-0.8	12.7	2,129.3	-0.4	1.5	1	1	1
11/02/2022 08:00	-0.8	12.9	2,028.9	-0.4	1.4	1	1	1
11/02/2022 09:00	0.2	13.8	1,719.4	0.3	1.2	1	1	0
11/02/2022 10:00	0.2	13.9	1,549.8	0.3	1.1	1	1	0
11/02/2022 11:00	0.2	13.9	1,678.6	0.3	1.2	1	1	0
11/02/2022 12:00	0.2	13.9	1,558.6	0.3	1.1	1	1	0
11/02/2022 13:00	0.2	13.9	1,562.4	0.3	1.1	1	1	0
11/02/2022 14:00	0.2	13.9	1,544.2	0.3	1.1	1	1	0
11/02/2022 15:00	-0.1	13.9	1,612.7	0.1	1.1	1	1	1
11/02/2022 16:00	-0.9	12.6	2,080.8	-0.5	1.5	1	1	1
11/02/2022 17:00	-0.8	12.3	2,172.4	-0.4	1.5	1	1	1
11/02/2022 18:00	-0.8	12.4	2,164.8	-0.4	1.5	1	1	1
11/02/2022 19:00	-0.8	12.4	2,165.2	-0.4	1.5	1	1	1
11/02/2022 20:00	-0.8	12.4	2,166.8	-0.4	1.5	1	1	1
11/02/2022 21:00	-0.8	12.5	2,152.9	-0.4	1.5	1	1	1
11/02/2022 22:00	-0.8	12.4	2,163.4	-0.4	1.5	1	1	1
11/02/2022 23:00	-0.8	12.4	2,176.3	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.2	1,852.3	-0.1	1.3	24 #	24 #	13 #
Minimum:	-0.9	12.3	1,353.8	-0.5	0.9	1	1	0
Maximum:	0.2	13.9	2,176.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	-0.8	12.4	2,167.7	-0.4	1.5	1	1	1
11/03/2022 01:00	-0.8	12.5	2,153.5	-0.4	1.5	1	1	1
11/03/2022 02:00	-0.8	12.3	2,199.7	-0.4	1.5	1	1	1
11/03/2022 03:00	-0.7	12.1	2,243.0	-0.2	1.6	1	1	1
11/03/2022 04:00	-0.8	12.4	2,170.3	-0.4	1.5	1	1	1
11/03/2022 05:00	-0.8	12.4	2,175.5	-0.4	1.5	1	1	1
11/03/2022 06:00	-0.7	12.1	2,246.8	-0.2	1.6	1	1	1
11/03/2022 07:00	-0.7	12.6	2,117.7	-0.2	1.5	1	1	1
11/03/2022 08:00	0.2	13.9	1,461.2	0.3	1.0	1	1	0
11/03/2022 09:00	0.2	13.9	1,567.5	0.3	1.1	1	1	0
11/03/2022 10:00	0.2	13.9	1,581.7	0.3	1.1	1	1	0
11/03/2022 11:00	0.3	13.9	1,575.7	0.4	1.1	1	1	0
11/03/2022 12:00	0.3	13.9	1,587.6	0.4	1.1	1	1	0
11/03/2022 13:00	0.2	13.9	1,496.8	0.3	1.0	1	1	0
11/03/2022 14:00	0.3	13.9	1,564.2	0.4	1.1	1	1	0
11/03/2022 15:00	0.1	13.8	1,787.2	0.2	1.3	1	1	1
11/03/2022 16:00	-0.9	12.7	2,081.8	-0.5	1.5	1	1	1
11/03/2022 17:00	-0.8	12.4	2,162.4	-0.4	1.5	1	1	1
11/03/2022 18:00	-0.8	12.3	2,178.2	-0.4	1.5	1	1	1
11/03/2022 19:00	-0.7	12.3	2,176.0	-0.2	1.5	1	1	1
11/03/2022 20:00	-0.7	12.3	2,164.2	-0.2	1.5	1	1	1
11/03/2022 21:00	-0.7	12.3	2,163.9	-0.2	1.5	1	1	1
11/03/2022 22:00	-0.7	12.3	2,163.3	-0.2	1.5	1	1	1
11/03/2022 23:00	-0.7	12.1	2,220.6	-0.2	1.6	1	1	1
Average/Sum#:	-0.4	12.9	1,975.3	-0.1	1.4	24 #	24 #	17 #
Minimum:	-0.9	12.1	1,461.2	-0.5	1.0	1	1	0
Maximum:	0.3	13.9	2,246.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	-0.8	12.5	2,148.4	-0.4	1.5	1	1	1
11/04/2022 01:00	-0.8	12.6	2,120.9	-0.4	1.5	1	1	1
11/04/2022 02:00	-0.7	12.8	2,070.3	-0.4	1.4	1	1	1
11/04/2022 03:00	-0.8	12.8	2,074.1	-0.4	1.5	1	1	1
11/04/2022 04:00	-0.8	12.5	2,153.1	-0.4	1.5	1	1	1
11/04/2022 05:00	-0.7	12.0	2,266.7	-0.2	1.6	1	1	1
11/04/2022 06:00	-0.8	12.4	2,187.8	-0.4	1.5	1	1	1
11/04/2022 07:00	-0.8	12.8	2,062.9	-0.4	1.4	1	1	1
11/04/2022 08:00	0.3	13.8	1,733.8	0.4	1.2	1	1	0
11/04/2022 09:00	0.2	13.9	1,557.3	0.3	1.1	1	1	0
11/04/2022 10:00	0.2	13.9	1,396.0	0.3	1.0	1	1	0
11/04/2022 11:00	0.1	14.0	1,324.8	0.2	0.9	1	1	0
11/04/2022 12:00	0.1	14.0	1,322.8	0.2	0.9	1	1	0
11/04/2022 13:00	0.2	14.0	1,324.0	0.3	0.9	1	1	0
11/04/2022 14:00	0.1	13.9	1,404.7	0.2	1.0	1	1	0
11/04/2022 15:00	-0.2	13.8	1,636.8	-0.1	1.1	1	1	1
11/04/2022 16:00	-0.9	12.6	2,081.0	-0.5	1.5	1	1	1
11/04/2022 17:00	-0.8	12.4	2,119.5	-0.4	1.5	1	1	1
11/04/2022 18:00	-0.7	12.7	2,057.5	-0.2	1.4	1	1	1
11/04/2022 19:00	-0.7	12.7	2,056.8	-0.2	1.4	1	1	1
11/04/2022 20:00	-0.7	12.8	2,052.8	-0.4	1.4	1	1	1
11/04/2022 21:00	-0.7	12.8	2,054.4	-0.4	1.4	1	1	1
11/04/2022 22:00	-0.7	12.8	2,054.9	-0.4	1.4	1	1	1
11/04/2022 23:00	-0.9	13.3	1,952.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.1	1,883.9	-0.2	1.3	24 #	24 #	17 #
Minimum:	-0.9	12.0	1,322.8	-0.7	0.9	1	1	0
Maximum:	0.3	14.0	2,266.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2022 00:00	-1.1	13.3	1,950.5	-0.7	1.4	1	1	1
11/05/2022 01:00	-1.1	13.3	1,950.4	-0.7	1.4	1	1	1
11/05/2022 02:00	-1.1	13.3	1,950.1	-0.7	1.4	1	1	1
11/05/2022 03:00	-1.2	13.3	1,950.9	-0.8	1.4	1	1	1
11/05/2022 04:00	-1.2	13.3	1,954.3	-0.8	1.4	1	1	1
11/05/2022 05:00	-1.2	13.3	1,956.6	-0.8	1.4	1	1	1
11/05/2022 06:00	-1.2	13.3	1,927.6	-0.8	1.3	1	1	1
11/05/2022 07:00	0.0	15.8	567.3	0.0	0.4	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	18.8	195.5	0.0	0.1	1	0	0
11/05/2022 14:00	0.0	16.1	711.5	0.0	0.5	1	0	0
11/05/2022 15:00	0.2	13.9	1,436.7	0.3	1.0	1	1	0
11/05/2022 16:00	-0.9	13.4	1,707.2	-0.7	1.2	1	1	1
11/05/2022 17:00	-1.1	13.0	1,981.9	-0.7	1.4	1	1	1
11/05/2022 18:00	-1.2	13.0	1,971.9	-0.8	1.4	1	1	1
11/05/2022 19:00	-1.4	13.0	1,972.1	-0.8	1.4	1	1	1
11/05/2022 20:00	-1.5	13.0	1,975.2	-0.9	1.4	1	1	1
11/05/2022 21:00	-0.9	13.5	1,647.5	-0.7	1.2	1	1	1
11/05/2022 22:00	0.1	13.9	1,409.8	0.1	1.0	1	1	0
11/05/2022 23:00	0.2	13.8	1,653.4	0.3	1.2	1	1	0
Average/Sum#:	-0.8	13.9	1,624.8	-0.5	1.2	19 #	16 #	13 #
Minimum:	-1.5	13.0	195.5	-0.9	0.1	0	0	0
Maximum:	0.2	18.8	1,981.9	0.3	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.2	13.8	1,564.1	0.3	1.1	1	1	0
11/06/2022 01:00	0.1	13.8	1,463.6	0.2	1.0	1	1	0
11/06/2022 02:00	0.0	16.3	377.6	0.0	0.3	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.6	1,135.1	0.2	0.8	3 #	2 #	0 #
Minimum:	0.0	13.8	377.6	0.0	0.3	0	0	0
Maximum:	0.2	16.3	1,564.1	0.3	1.1	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 03:00	0.0	18.1	281.0	0.0	0.2	1	0	0
11/07/2022 04:00	0.0	16.6	549.1	0.0	0.4	1	0	0
11/07/2022 05:00	0.0	13.7	1,723.5	0.0	1.2	1	0	0
11/07/2022 06:00	-0.8	12.9	2,000.6	-0.4	1.4	1	1	1
11/07/2022 07:00	-0.8	12.1	2,210.3	-0.4	1.5	1	1	1
11/07/2022 08:00	-0.8	13.0	1,980.7	-0.4	1.4	1	1	1
11/07/2022 09:00	-0.9	13.0	1,964.2	-0.5	1.4	1	1	1
11/07/2022 10:00	-0.8	13.0	1,956.5	-0.4	1.4	1	1	1
11/07/2022 11:00	-0.5	13.1	1,957.6	-0.2	1.4	1	1	1
11/07/2022 12:00	-0.4	13.1	1,957.2	-0.1	1.4	1	1	1
11/07/2022 13:00	-0.5	13.1	1,960.7	-0.2	1.4	1	1	1
11/07/2022 14:00	-0.7	12.8	2,055.3	-0.4	1.4	1	1	1
11/07/2022 15:00	-0.7	12.2	2,186.1	-0.2	1.5	1	1	1
11/07/2022 16:00	-0.5	11.9	2,241.6	-0.1	1.6	1	1	1
11/07/2022 17:00	-0.4	11.8	2,276.8	-0.1	1.6	1	1	1
11/07/2022 18:00	-0.4	11.8	2,279.9	-0.1	1.6	1	1	1
11/07/2022 19:00	-0.4	11.8	2,279.4	-0.1	1.6	1	1	1
11/07/2022 20:00	-0.4	11.8	2,276.6	-0.1	1.6	1	1	1
11/07/2022 21:00	-0.4	11.8	2,272.9	-0.1	1.6	1	1	1
11/07/2022 22:00	-0.5	12.0	2,232.3	-0.1	1.6	1	1	1
11/07/2022 23:00	-0.5	12.4	2,159.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.5	13.0	1,942.9	-0.2	1.4	21 #	18 #	18 #
Minimum:	-0.9	11.8	281.0	-0.5	0.2	0	0	0
Maximum:	0.0	18.1	2,279.9	0.0	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	-0.7	12.4	2,151.8	-0.2	1.5	1	1	1
11/08/2022 01:00	-0.7	12.4	2,149.8	-0.2	1.5	1	1	1
11/08/2022 02:00	-0.5	12.6	2,096.5	-0.2	1.5	1	1	1
11/08/2022 03:00	-0.7	12.4	2,143.2	-0.2	1.5	1	1	1
11/08/2022 04:00	-0.7	12.2	2,180.4	-0.2	1.5	1	1	1
11/08/2022 05:00	-0.5	12.1	2,197.5	-0.1	1.5	1	1	1
11/08/2022 06:00	-0.4	11.7	2,281.0	0.1	1.6	1	1	1
11/08/2022 07:00	-0.5	12.1	2,193.7	-0.1	1.5	1	1	1
11/08/2022 08:00	-0.5	12.1	2,185.1	-0.1	1.5	1	1	1
11/08/2022 09:00	-0.5	12.2	2,181.7	-0.1	1.5	1	1	1
11/08/2022 10:00	-0.7	12.3	2,165.2	-0.2	1.5	1	1	1
11/08/2022 11:00	-0.5	12.9	2,016.4	-0.2	1.4	1	1	1
11/08/2022 12:00	-0.5	13.1	1,972.3	-0.2	1.4	1	1	1
11/08/2022 13:00	-0.5	13.2	1,972.1	-0.2	1.4	1	1	1
11/08/2022 14:00	-0.7	12.9	2,046.8	-0.4	1.4	1	1	1
11/08/2022 15:00	-0.5	12.9	2,043.8	-0.2	1.4	1	1	1
11/08/2022 16:00	-0.5	12.2	2,202.3	-0.1	1.5	1	1	1
11/08/2022 17:00	-0.5	12.2	2,181.5	-0.1	1.5	1	1	1
11/08/2022 18:00	-0.7	12.4	2,151.7	-0.2	1.5	1	1	1
11/08/2022 19:00	-0.5	12.2	2,186.1	-0.1	1.5	1	1	1
11/08/2022 20:00	-0.5	12.2	2,194.5	-0.1	1.5	1	1	1
11/08/2022 21:00	-0.5	12.2	2,195.9	-0.1	1.5	1	1	1
11/08/2022 22:00	-0.5	12.2	2,180.1	-0.1	1.5	1	1	1
11/08/2022 23:00	-0.7	12.4	2,137.2	-0.2	1.5	1	1	1
Average/Sum#:	-0.6	12.4	2,141.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.7	11.7	1,972.1	-0.4	1.4	1	1	1
Maximum:	-0.4	13.2	2,281.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	-0.7	12.4	2,147.1	-0.2	1.5	1	1	1
11/09/2022 01:00	-0.7	12.4	2,147.0	-0.2	1.5	1	1	1
11/09/2022 02:00	-0.7	12.3	2,184.9	-0.2	1.5	1	1	1
11/09/2022 03:00	-0.7	12.3	2,187.0	-0.2	1.5	1	1	1
11/09/2022 04:00	-0.7	12.5	2,154.3	-0.2	1.5	1	1	1
11/09/2022 05:00	-0.5	11.9	2,246.2	-0.1	1.6	1	1	1
11/09/2022 06:00	-0.4	11.9	2,284.3	-0.1	1.6	1	1	1
11/09/2022 07:00	-0.5	12.4	2,184.8	-0.2	1.5	1	1	1
11/09/2022 08:00	-0.5	12.5	2,147.6	-0.2	1.5	1	1	1
11/09/2022 09:00	0.1	13.7	1,760.8	0.2	1.2	1	1	1
11/09/2022 10:00	0.4	13.9	1,725.2	0.4	1.2	1	1	0
11/09/2022 11:00	0.4	13.9	1,641.0	0.4	1.1	1	1	0
11/09/2022 12:00	0.4	13.9	1,716.3	0.4	1.2	1	1	0
11/09/2022 13:00	0.4	13.9	1,625.0	0.4	1.1	1	1	0
11/09/2022 14:00	0.4	13.9	1,698.0	0.4	1.2	1	1	0
11/09/2022 15:00	0.1	13.9	1,645.4	0.2	1.2	1	1	1
11/09/2022 16:00	-0.8	12.8	2,074.2	-0.4	1.5	1	1	1
11/09/2022 17:00	-0.7	12.5	2,153.5	-0.2	1.5	1	1	1
11/09/2022 18:00	-0.7	13.1	2,009.9	-0.4	1.4	1	1	1
11/09/2022 19:00	-0.9	13.3	1,973.0	-0.7	1.4	1	1	1
11/09/2022 20:00	-0.9	13.3	1,976.7	-0.7	1.4	1	1	1
11/09/2022 21:00	-0.9	13.3	1,988.3	-0.7	1.4	1	1	1
11/09/2022 22:00	-0.9	13.3	1,979.1	-0.7	1.4	1	1	1
11/09/2022 23:00	-0.9	13.3	1,977.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.0	1,984.5	-0.2	1.4	24 #	24 #	19 #
Minimum:	-0.9	11.9	1,625.0	-0.7	1.1	1	1	0
Maximum:	0.4	13.9	2,284.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	-0.9	13.3	1,977.3	-0.7	1.4	1	1	1
11/10/2022 01:00	-0.9	13.3	1,975.5	-0.7	1.4	1	1	1
11/10/2022 02:00	-0.9	13.3	1,974.4	-0.7	1.4	1	1	1
11/10/2022 03:00	-0.9	13.3	1,977.4	-0.7	1.4	1	1	1
11/10/2022 04:00	-0.8	12.9	2,073.4	-0.4	1.5	1	1	1
11/10/2022 05:00	-0.5	12.3	2,174.8	-0.1	1.5	1	1	1
11/10/2022 06:00	-0.5	12.0	2,299.8	-0.1	1.6	1	1	1
11/10/2022 07:00	-0.7	12.7	2,110.5	-0.2	1.5	1	1	1
11/10/2022 08:00	-0.9	13.3	1,967.3	-0.7	1.4	1	1	1
11/10/2022 09:00	-0.9	13.3	1,948.5	-0.7	1.4	1	1	1
11/10/2022 10:00	0.4	13.9	1,736.2	0.4	1.2	1	1	0
11/10/2022 11:00	0.4	13.9	1,728.1	0.4	1.2	1	1	0
11/10/2022 12:00	0.4	13.9	1,714.9	0.4	1.2	1	1	0
11/10/2022 13:00	0.4	14.0	1,570.6	0.4	1.1	1	1	0
11/10/2022 14:00	0.4	13.9	1,724.2	0.4	1.2	1	1	0
11/10/2022 15:00	0.2	13.9	1,723.1	0.2	1.2	1	1	1
11/10/2022 16:00	-1.1	12.6	2,126.5	-0.7	1.5	1	1	1
11/10/2022 17:00	-0.4	11.9	2,271.9	-0.1	1.6	1	1	1
11/10/2022 18:00	-0.4	11.9	2,274.6	-0.1	1.6	1	1	1
11/10/2022 19:00	-0.4	11.9	2,278.5	-0.1	1.6	1	1	1
11/10/2022 20:00	-0.4	11.9	2,278.8	-0.1	1.6	1	1	1
11/10/2022 21:00	-0.4	11.9	2,281.7	-0.1	1.6	1	1	1
11/10/2022 22:00	-0.4	11.9	2,281.2	-0.1	1.6	1	1	1
11/10/2022 23:00	-0.4	12.0	2,256.4	-0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.9	2,030.2	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.9	1,570.6	-0.7	1.1	1	1	0
Maximum:	0.4	14.0	2,299.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	-0.4	12.0	2,281.8	-0.1	1.6	1	1	1
11/11/2022 01:00	-0.4	12.0	2,275.8	-0.1	1.6	1	1	1
11/11/2022 02:00	-0.5	12.6	2,145.1	-0.2	1.5	1	1	1
11/11/2022 03:00	-0.5	12.6	2,142.7	-0.2	1.5	1	1	1
11/11/2022 04:00	-0.5	12.1	2,271.6	-0.1	1.6	1	1	1
11/11/2022 05:00	-0.5	12.0	2,285.2	-0.1	1.6	1	1	1
11/11/2022 06:00	-0.4	12.0	2,284.1	-0.1	1.6	1	1	1
11/11/2022 07:00	-0.7	12.7	2,108.2	-0.2	1.5	1	1	1
11/11/2022 08:00	-0.9	13.3	1,940.2	-0.7	1.4	1	1	1
11/11/2022 09:00	0.4	13.9	1,718.1	0.4	1.2	1	1	0
11/11/2022 10:00	0.4	13.9	1,724.0	0.4	1.2	1	1	0
11/11/2022 11:00	0.4	13.9	1,688.9	0.4	1.2	1	1	0
11/11/2022 12:00	0.4	13.9	1,687.5	0.4	1.2	1	1	0
11/11/2022 13:00	0.4	13.9	1,700.7	0.4	1.2	1	1	0
11/11/2022 14:00	0.4	13.9	1,582.3	0.4	1.1	1	1	0
11/11/2022 15:00	0.4	13.9	1,688.6	0.4	1.2	1	1	0
11/11/2022 16:00	-0.8	13.0	1,979.8	-0.4	1.4	1	1	1
11/11/2022 17:00	-0.4	11.8	2,273.3	-0.1	1.6	1	1	1
11/11/2022 18:00	-0.4	11.9	2,266.1	-0.1	1.6	1	1	1
11/11/2022 19:00	-0.4	11.9	2,254.1	-0.1	1.6	1	1	1
11/11/2022 20:00	-0.4	11.9	2,250.8	-0.1	1.6	1	1	1
11/11/2022 21:00	-0.4	11.9	2,249.2	-0.1	1.6	1	1	1
11/11/2022 22:00	-0.5	12.1	2,243.3	-0.1	1.6	1	1	1
11/11/2022 23:00	-0.5	12.0	2,260.9	-0.1	1.6	1	1	1
Average/Sum#:	-0.2	12.7	2,054.3	0.0	1.5	24 #	24 #	17 #
Minimum:	-0.9	11.8	1,582.3	-0.7	1.1	1	1	0
Maximum:	0.4	13.9	2,285.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	-0.5	12.0	2,265.2	-0.1	1.6	1	1	1
11/12/2022 01:00	-0.5	12.0	2,268.8	-0.1	1.6	1	1	1
11/12/2022 02:00	-0.5	12.0	2,275.3	-0.1	1.6	1	1	1
11/12/2022 03:00	-0.5	12.0	2,278.8	-0.1	1.6	1	1	1
11/12/2022 04:00	-0.5	12.0	2,285.3	-0.1	1.6	1	1	1
11/12/2022 05:00	-0.5	12.0	2,286.6	-0.1	1.6	1	1	1
11/12/2022 06:00	-0.5	12.0	2,277.1	-0.1	1.6	1	1	1
11/12/2022 07:00	-0.5	12.7	2,119.5	-0.2	1.5	1	1	1
11/12/2022 08:00	-0.5	12.2	2,196.2	-0.1	1.5	1	1	1
11/12/2022 09:00	0.1	13.7	1,755.8	0.2	1.2	1	1	1
11/12/2022 10:00	0.4	13.9	1,596.8	0.4	1.1	1	1	0
11/12/2022 11:00	0.4	13.9	1,557.9	0.4	1.1	1	1	0
11/12/2022 12:00	0.4	13.9	1,557.2	0.4	1.1	1	1	0
11/12/2022 13:00	0.4	13.9	1,580.9	0.4	1.1	1	1	0
11/12/2022 14:00	0.4	13.9	1,557.8	0.4	1.1	1	1	0
11/12/2022 15:00	0.2	13.8	1,793.1	0.4	1.3	1	1	1
11/12/2022 16:00	-1.1	12.5	2,136.2	-0.5	1.5	1	1	1
11/12/2022 17:00	-0.4	11.8	2,289.6	-0.1	1.6	1	1	1
11/12/2022 18:00	-0.4	11.8	2,288.4	-0.1	1.6	1	1	1
11/12/2022 19:00	-0.4	11.8	2,294.2	-0.1	1.6	1	1	1
11/12/2022 20:00	-0.4	11.8	2,304.8	-0.1	1.6	1	1	1
11/12/2022 21:00	-0.4	11.8	2,300.6	-0.1	1.6	1	1	1
11/12/2022 22:00	-0.5	12.3	2,197.1	-0.1	1.5	1	1	1
11/12/2022 23:00	-0.5	12.3	2,192.7	-0.1	1.5	1	1	1
Average/Sum#:	-0.3	12.6	2,069.0	0.0	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.8	1,557.2	-0.5	1.1	1	1	0
Maximum:	0.4	13.9	2,304.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	-0.5	12.4	2,183.0	-0.2	1.5	1	1	1
11/13/2022 01:00	-0.5	12.4	2,169.4	-0.2	1.5	1	1	1
11/13/2022 02:00	-0.5	12.5	2,162.2	-0.2	1.5	1	1	1
11/13/2022 03:00	-0.5	12.3	2,198.3	-0.1	1.5	1	1	1
11/13/2022 04:00	-0.5	12.4	2,192.5	-0.2	1.5	1	1	1
11/13/2022 05:00	-0.5	12.4	2,185.1	-0.2	1.5	1	1	1
11/13/2022 06:00	-0.5	12.3	2,201.5	-0.1	1.5	1	1	1
11/13/2022 07:00	-0.4	12.0	2,269.1	-0.1	1.6	1	1	1
11/13/2022 08:00	-0.2	12.9	1,972.8	0.1	1.4	1	1	1
11/13/2022 09:00	0.4	13.9	1,713.6	0.4	1.2	1	1	0
11/13/2022 10:00	0.4	13.9	1,714.5	0.4	1.2	1	1	0
11/13/2022 11:00	0.4	13.9	1,714.3	0.4	1.2	1	1	0
11/13/2022 12:00	0.4	13.9	1,712.3	0.4	1.2	1	1	0
11/13/2022 13:00	0.4	14.0	1,713.9	0.4	1.2	1	1	0
11/13/2022 14:00	0.4	14.0	1,686.9	0.4	1.2	1	1	0
11/13/2022 15:00	0.2	13.8	1,797.5	0.4	1.3	1	1	1
11/13/2022 16:00	-0.5	12.6	2,132.3	-0.2	1.5	1	1	1
11/13/2022 17:00	-0.2	12.0	2,273.8	0.1	1.6	1	1	1
11/13/2022 18:00	-0.2	12.0	2,273.5	0.1	1.6	1	1	1
11/13/2022 19:00	-0.2	12.0	2,277.3	0.1	1.6	1	1	1
11/13/2022 20:00	-0.2	12.0	2,280.0	0.1	1.6	1	1	1
11/13/2022 21:00	-0.2	12.0	2,284.9	0.1	1.6	1	1	1
11/13/2022 22:00	-0.2	12.0	2,287.2	0.1	1.6	1	1	1
11/13/2022 23:00	-0.2	12.0	2,294.0	0.1	1.6	1	1	1
Average/Sum#:	-0.1	12.7	2,070.4	0.1	1.4	24 #	24 #	18 #
Minimum:	-0.5	12.0	1,686.9	-0.2	1.2	1	1	0
Maximum:	0.4	14.0	2,294.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	-0.2	12.1	2,288.4	0.1	1.6	1	1	1
11/14/2022 01:00	-0.4	12.1	2,277.6	-0.1	1.6	1	1	1
11/14/2022 02:00	-0.4	12.2	2,265.6	-0.1	1.6	1	1	1
11/14/2022 03:00	-0.5	12.7	2,149.5	-0.2	1.5	1	1	1
11/14/2022 04:00	-0.5	12.4	2,230.6	-0.2	1.6	1	1	1
11/14/2022 05:00	-0.4	12.2	2,291.8	-0.1	1.6	1	1	1
11/14/2022 06:00	-0.4	12.2	2,286.5	-0.1	1.6	1	1	1
11/14/2022 07:00	-0.5	12.6	2,184.1	-0.2	1.5	1	1	1
11/14/2022 08:00	-0.5	12.7	2,143.2	-0.2	1.5	1	1	1
11/14/2022 09:00	-0.5	12.6	2,149.5	-0.2	1.5	1	1	1
11/14/2022 10:00	-0.5	12.6	2,141.4	-0.2	1.5	1	1	1
11/14/2022 11:00	-0.4	12.7	2,116.8	-0.1	1.5	1	1	1
11/14/2022 12:00	-0.4	12.7	2,106.1	-0.1	1.5	1	1	1
11/14/2022 13:00	-0.4	12.5	2,137.1	-0.1	1.5	1	1	1
11/14/2022 14:00	-0.4	12.5	2,137.4	-0.1	1.5	1	1	1
11/14/2022 15:00	-0.4	12.8	2,062.7	-0.1	1.4	1	1	1
11/14/2022 16:00	-0.2	12.1	2,229.8	0.1	1.6	1	1	1
11/14/2022 17:00	-0.4	12.3	2,177.1	-0.1	1.5	1	1	1
11/14/2022 18:00	-0.4	12.5	2,159.1	-0.1	1.5	1	1	1
11/14/2022 19:00	-0.2	12.1	2,265.3	0.1	1.6	1	1	1
11/14/2022 20:00	-0.2	12.0	2,281.3	0.1	1.6	1	1	1
11/14/2022 21:00	-0.2	12.1	2,256.1	0.1	1.6	1	1	1
11/14/2022 22:00	-0.2	12.1	2,259.7	0.1	1.6	1	1	1
11/14/2022 23:00	-0.2	12.2	2,239.5	0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.4	2,201.5	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.5	12.0	2,062.7	-0.2	1.4	1	1	1
Maximum:	-0.2	12.8	2,291.8	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2022 00:00	-0.2	12.1	2,265.0	0.1	1.6	1	1	1
11/15/2022 01:00	-0.2	12.1	2,268.0	0.1	1.6	1	1	1
11/15/2022 02:00	-0.2	12.0	2,286.6	0.1	1.6	1	1	1
11/15/2022 03:00	-0.2	12.0	2,296.0	0.1	1.6	1	1	1
11/15/2022 04:00	-0.2	12.0	2,299.8	0.1	1.6	1	1	1
11/15/2022 05:00	-0.2	11.7	2,332.5	0.1	1.6	1	1	1
11/15/2022 06:00	-0.4	12.2	2,202.6	-0.1	1.5	1	1	1
11/15/2022 07:00	-0.2	11.8	2,323.2	0.1	1.6	1	1	1
11/15/2022 08:00	-0.2	12.0	2,234.7	0.1	1.6	1	1	1
11/15/2022 09:00	-0.4	12.6	2,114.0	-0.1	1.5	1	1	1
11/15/2022 10:00	-0.5	12.5	2,135.7	-0.2	1.5	1	1	1
11/15/2022 11:00	-0.7	12.9	2,037.3	-0.4	1.4	1	1	1
11/15/2022 12:00	-1.2	13.3	1,961.1	-0.8	1.4	1	1	1
11/15/2022 13:00	-1.2	13.3	1,967.3	-0.8	1.4	1	1	1
11/15/2022 14:00	0.7	0.0	1,973.8	0.7	1.4	1	1	1
11/15/2022 15:00	0.7	0.0	2,007.0	0.7	1.4	1	1	1
11/15/2022 16:00	-0.7	12.5	2,120.1	-0.2	1.5	1	1	1
11/15/2022 17:00	-0.7	12.4	2,133.8	-0.2	1.5	1	1	1
11/15/2022 18:00	-0.5	12.4	2,123.0	-0.2	1.5	1	1	1
11/15/2022 19:00	-0.5	12.3	2,137.1	-0.1	1.5	1	1	1
11/15/2022 20:00	-0.5	12.2	2,175.2	-0.1	1.5	1	1	1
11/15/2022 21:00	-0.4	11.9	2,237.4	-0.1	1.6	1	1	1
11/15/2022 22:00	-0.5	12.3	2,149.1	-0.1	1.5	1	1	1
11/15/2022 23:00	-0.5	12.3	2,148.1	-0.1	1.5	1	1	1
Average/Sum#:	-0.5	12.3	2,163.7	-0.1	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.7	1,961.1	-0.8	1.4	1	1	1
Maximum:	-0.2	13.3	2,332.5	0.1	1.6	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	-0.5	12.3	2,142.4	-0.1	1.5	1	1	1
11/16/2022 01:00	-0.5	12.5	2,116.0	-0.2	1.5	1	1	1
11/16/2022 02:00	-0.5	12.4	2,139.8	-0.2	1.5	1	1	1
11/16/2022 03:00	-0.5	12.4	2,144.4	-0.2	1.5	1	1	1
11/16/2022 04:00	-0.5	11.9	2,274.6	-0.1	1.6	1	1	1
11/16/2022 05:00	-0.4	11.5	2,340.0	0.1	1.6	1	1	1
11/16/2022 06:00	-0.2	11.5	2,346.5	0.1	1.6	1	1	1
11/16/2022 07:00	-0.4	11.9	2,254.3	-0.1	1.6	1	1	1
11/16/2022 08:00	-0.8	13.3	1,966.8	-0.5	1.4	1	1	1
11/16/2022 09:00	-1.1	13.6	1,997.0	-0.8	1.4	1	1	1
11/16/2022 10:00	-1.1	13.2	1,964.8	-0.7	1.4	1	1	1
11/16/2022 11:00	-1.1	13.2	1,969.2	-0.7	1.4	1	1	1
11/16/2022 12:00	-1.1	13.1	1,978.0	-0.7	1.4	1	1	1
11/16/2022 13:00	-1.1	13.1	1,980.5	-0.7	1.4	1	1	1
11/16/2022 14:00	-1.1	13.1	1,981.2	-0.7	1.4	1	1	1
11/16/2022 15:00	-0.8	12.6	2,101.9	-0.4	1.5	1	1	1
11/16/2022 16:00	-0.5	12.3	2,161.6	-0.1	1.5	1	1	1
11/16/2022 17:00	-0.5	12.3	2,165.8	-0.1	1.5	1	1	1
11/16/2022 18:00	-0.4	12.0	2,221.6	-0.1	1.6	1	1	1
11/16/2022 19:00	-0.4	11.9	2,228.4	-0.1	1.6	1	1	1
11/16/2022 20:00	-0.4	11.9	2,229.7	-0.1	1.6	1	1	1
11/16/2022 21:00	-0.5	12.0	2,244.6	-0.1	1.6	1	1	1
11/16/2022 22:00	-0.5	12.2	2,216.3	-0.1	1.6	1	1	1
11/16/2022 23:00	-0.5	12.0	2,243.9	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.4	2,142.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.5	1,964.8	-0.8	1.4	1	1	1
Maximum:	-0.2	13.6	2,346.5	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	-0.5	12.4	2,159.1	-0.2	1.5	1	1	1
11/17/2022 01:00	-0.5	12.4	2,159.4	-0.2	1.5	1	1	1
11/17/2022 02:00	-0.5	12.5	2,146.1	-0.2	1.5	1	1	1
11/17/2022 03:00	-0.5	12.5	2,149.6	-0.2	1.5	1	1	1
11/17/2022 04:00	-0.5	12.2	2,231.0	-0.1	1.6	1	1	1
11/17/2022 05:00	-0.4	11.6	2,357.0	0.1	1.6	1	1	1
11/17/2022 06:00	-0.4	11.9	2,276.3	-0.1	1.6	1	1	1
11/17/2022 07:00	-0.5	12.4	2,162.7	-0.2	1.5	1	1	1
11/17/2022 08:00	-0.8	13.1	1,985.4	-0.5	1.4	1	1	1
11/17/2022 09:00	-0.5	12.5	2,129.0	-0.2	1.5	1	1	1
11/17/2022 10:00	-0.5	12.5	2,110.8	-0.2	1.5	1	1	1
11/17/2022 11:00	-0.5	12.3	2,133.9	-0.1	1.5	1	1	1
11/17/2022 12:00	-0.4	12.1	2,171.5	-0.1	1.5	1	1	1
11/17/2022 13:00	-0.4	12.2	2,169.8	-0.1	1.5	1	1	1
11/17/2022 14:00	-0.4	12.9	2,005.0	-0.1	1.4	1	1	1
11/17/2022 15:00	-0.4	12.4	2,118.7	-0.1	1.5	1	1	1
11/17/2022 16:00	-0.4	11.9	2,234.9	-0.1	1.6	1	1	1
11/17/2022 17:00	-0.2	11.8	2,268.2	0.1	1.6	1	1	1
11/17/2022 18:00	-0.2	11.8	2,255.7	0.1	1.6	1	1	1
11/17/2022 19:00	-0.2	11.8	2,258.8	0.1	1.6	1	1	1
11/17/2022 20:00	-0.4	11.8	2,260.2	-0.1	1.6	1	1	1
11/17/2022 21:00	-0.2	11.8	2,262.4	0.1	1.6	1	1	1
11/17/2022 22:00	-0.4	11.9	2,246.4	-0.1	1.6	1	1	1
11/17/2022 23:00	-0.5	12.2	2,206.6	-0.1	1.5	1	1	1
Average/Sum#:	-0.4	12.2	2,185.8	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.6	1,985.4	-0.5	1.4	1	1	1
Maximum:	-0.2	13.1	2,357.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	-0.5	12.4	2,157.1	-0.2	1.5	1	1	1
11/18/2022 01:00	-0.5	12.3	2,164.4	-0.1	1.5	1	1	1
11/18/2022 02:00	-0.5	12.2	2,166.7	-0.1	1.5	1	1	1
11/18/2022 03:00	-0.5	12.3	2,166.0	-0.1	1.5	1	1	1
11/18/2022 04:00	-0.2	11.6	2,308.1	0.1	1.6	1	1	1
11/18/2022 05:00	-0.2	11.5	2,326.0	0.1	1.6	1	1	1
11/18/2022 06:00	-0.2	11.5	2,333.1	0.1	1.6	1	1	1
11/18/2022 07:00	-0.4	11.8	2,267.0	-0.1	1.6	1	1	1
11/18/2022 08:00	-0.5	12.3	2,145.7	-0.1	1.5	1	1	1
11/18/2022 09:00	-0.5	12.3	2,153.7	-0.1	1.5	1	1	1
11/18/2022 10:00	-0.4	12.2	2,162.8	-0.1	1.5	1	1	1
11/18/2022 11:00	-0.4	12.4	2,100.8	-0.1	1.5	1	1	1
11/18/2022 12:00	-0.5	13.1	1,958.4	-0.2	1.4	1	1	1
11/18/2022 13:00	-0.5	13.1	1,960.1	-0.2	1.4	1	1	1
11/18/2022 14:00	-0.5	13.0	1,964.5	-0.2	1.4	1	1	1
11/18/2022 15:00	-0.5	12.7	2,040.1	-0.2	1.4	1	1	1
11/18/2022 16:00	-0.4	12.0	2,220.5	-0.1	1.6	1	1	1
11/18/2022 17:00	-0.4	11.9	2,244.9	-0.1	1.6	1	1	1
11/18/2022 18:00	-0.4	11.9	2,243.3	-0.1	1.6	1	1	1
11/18/2022 19:00	-0.4	11.9	2,245.4	-0.1	1.6	1	1	1
11/18/2022 20:00	-0.4	11.8	2,276.3	-0.1	1.6	1	1	1
11/18/2022 21:00	-0.2	11.6	2,328.6	0.1	1.6	1	1	1
11/18/2022 22:00	-0.2	11.6	2,341.0	0.1	1.6	1	1	1
11/18/2022 23:00	-0.2	11.8	2,301.5	0.1	1.6	1	1	1
Average/Sum#:	-0.4	12.1	2,190.7	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.5	11.5	1,958.4	-0.2	1.4	1	1	1
Maximum:	-0.2	13.1	2,341.0	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	-0.5	12.3	2,163.6	-0.1	1.5	1	1	1
11/19/2022 01:00	-0.5	12.5	2,142.3	-0.2	1.5	1	1	1
11/19/2022 02:00	-0.5	12.5	2,139.1	-0.2	1.5	1	1	1
11/19/2022 03:00	-0.5	12.6	2,118.3	-0.2	1.5	1	1	1
11/19/2022 04:00	-0.5	12.1	2,231.5	-0.1	1.6	1	1	1
11/19/2022 05:00	-0.4	11.9	2,257.3	-0.1	1.6	1	1	1
11/19/2022 06:00	-0.5	12.3	2,191.6	-0.1	1.5	1	1	1
11/19/2022 07:00	-0.5	12.5	2,123.0	-0.2	1.5	1	1	1
11/19/2022 08:00	-0.9	13.2	1,963.6	-0.5	1.4	1	1	1
11/19/2022 09:00	-0.9	13.2	1,961.7	-0.5	1.4	1	1	1
11/19/2022 10:00	-0.9	13.2	1,956.6	-0.5	1.4	1	1	1
11/19/2022 11:00	-0.9	13.1	1,953.3	-0.5	1.4	1	1	1
11/19/2022 12:00	-0.8	13.1	1,953.3	-0.5	1.4	1	1	1
11/19/2022 13:00	-0.7	13.1	1,954.1	-0.4	1.4	1	1	1
11/19/2022 14:00	-0.7	13.1	1,960.9	-0.4	1.4	1	1	1
11/19/2022 15:00	-0.5	12.8	2,021.3	-0.2	1.4	1	1	1
11/19/2022 16:00	-0.4	12.2	2,156.6	-0.1	1.5	1	1	1
11/19/2022 17:00	-0.4	12.1	2,176.7	-0.1	1.5	1	1	1
11/19/2022 18:00	-0.4	12.2	2,169.1	-0.1	1.5	1	1	1
11/19/2022 19:00	-0.2	11.8	2,273.1	0.1	1.6	1	1	1
11/19/2022 20:00	-0.2	11.6	2,305.7	0.1	1.6	1	1	1
11/19/2022 21:00	-0.2	11.6	2,312.8	0.1	1.6	1	1	1
11/19/2022 22:00	-0.4	11.7	2,340.7	0.1	1.6	1	1	1
11/19/2022 23:00	-0.4	11.6	2,358.5	0.1	1.7	1	1	1
Average/Sum#:	-0.5	12.4	2,132.7	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.6	1,953.3	-0.5	1.4	1	1	1
Maximum:	-0.2	13.2	2,358.5	0.1	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	-0.5	12.0	2,254.8	-0.1	1.6	1	1	1
11/20/2022 01:00	-0.4	11.9	2,273.0	-0.1	1.6	1	1	1
11/20/2022 02:00	-0.4	11.8	2,301.3	-0.1	1.6	1	1	1
11/20/2022 03:00	-0.4	11.9	2,301.2	-0.1	1.6	1	1	1
11/20/2022 04:00	-0.4	11.9	2,306.4	-0.1	1.6	1	1	1
11/20/2022 05:00	-0.4	11.7	2,350.0	0.1	1.6	1	1	1
11/20/2022 06:00	-0.5	12.1	2,254.5	-0.1	1.6	1	1	1
11/20/2022 07:00	-0.5	12.6	2,096.3	-0.2	1.5	1	1	1
11/20/2022 08:00	0.4	13.8	1,722.3	0.4	1.2	1	1	0
11/20/2022 09:00	0.4	13.8	1,725.4	0.4	1.2	1	1	0
11/20/2022 10:00	0.4	13.8	1,571.5	0.4	1.1	1	1	0
11/20/2022 11:00	0.4	13.9	1,573.6	0.4	1.1	1	1	0
11/20/2022 12:00	0.4	13.9	1,545.9	0.4	1.1	1	1	0
11/20/2022 13:00	0.4	13.9	1,536.5	0.4	1.1	1	1	0
11/20/2022 14:00	0.4	13.8	1,695.0	0.4	1.2	1	1	0
11/20/2022 15:00	0.2	13.8	1,732.2	0.4	1.2	1	1	1
11/20/2022 16:00	-0.5	12.3	2,147.2	-0.1	1.5	1	1	1
11/20/2022 17:00	-0.4	11.8	2,265.5	-0.1	1.6	1	1	1
11/20/2022 18:00	-0.4	11.8	2,252.2	-0.1	1.6	1	1	1
11/20/2022 19:00	-0.4	11.8	2,253.5	-0.1	1.6	1	1	1
11/20/2022 20:00	-0.4	11.8	2,257.4	-0.1	1.6	1	1	1
11/20/2022 21:00	-0.4	12.1	2,192.6	-0.1	1.5	1	1	1
11/20/2022 22:00	-0.5	12.4	2,157.4	-0.2	1.5	1	1	1
11/20/2022 23:00	-0.7	12.5	2,147.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.2	12.6	2,038.1	0.1	1.4	24 #	24 #	17 #
Minimum:	-0.7	11.7	1,536.5	-0.2	1.1	1	1	0
Maximum:	0.4	13.9	2,350.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2022 00:00	-0.5	12.4	2,156.8	-0.2	1.5	1	1	1
11/21/2022 01:00	-0.5	12.6	2,130.5	-0.2	1.5	1	1	1
11/21/2022 02:00	-0.8	12.9	2,058.0	-0.4	1.4	1	1	1
11/21/2022 03:00	-0.7	12.4	2,172.2	-0.2	1.5	1	1	1
11/21/2022 04:00	-0.5	12.0	2,259.2	-0.1	1.6	1	1	1
11/21/2022 05:00	-0.5	12.0	2,267.5	-0.1	1.6	1	1	1
11/21/2022 06:00	-0.5	12.0	2,284.4	-0.1	1.6	1	1	1
11/21/2022 07:00	-0.7	12.5	2,147.1	-0.2	1.5	1	1	1
11/21/2022 08:00	-1.1	13.2	1,965.1	-0.7	1.4	1	1	1
11/21/2022 09:00	-1.2	13.2	1,965.2	-0.8	1.4	1	1	1
11/21/2022 10:00	-1.1	13.2	1,961.7	-0.7	1.4	1	1	1
11/21/2022 11:00	-0.8	13.1	1,958.9	-0.5	1.4	1	1	1
11/21/2022 12:00	-0.7	13.0	1,966.2	-0.4	1.4	1	1	1
11/21/2022 13:00	-0.5	13.0	1,977.7	-0.2	1.4	1	1	1
11/21/2022 14:00	-0.5	12.2	2,161.3	-0.1	1.5	1	1	1
11/21/2022 15:00	-0.2	11.8	2,272.0	0.1	1.6	1	1	1
11/21/2022 16:00	-0.5	12.0	2,229.0	-0.1	1.6	1	1	1
11/21/2022 17:00	-0.4	11.9	2,230.9	-0.1	1.6	1	1	1
11/21/2022 18:00	-0.4	11.9	2,230.5	-0.1	1.6	1	1	1
11/21/2022 19:00	-0.4	11.8	2,258.6	-0.1	1.6	1	1	1
11/21/2022 20:00	-0.4	11.8	2,263.5	-0.1	1.6	1	1	1
11/21/2022 21:00	-0.4	11.8	2,264.2	-0.1	1.6	1	1	1
11/21/2022 22:00	-0.4	11.8	2,264.8	-0.1	1.6	1	1	1
11/21/2022 23:00	-0.4	12.0	2,226.0	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.4	2,153.0	-0.2	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,958.9	-0.8	1.4	1	1	1
Maximum:	-0.2	13.2	2,284.4	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2022 00:00	-0.5	12.4	2,143.9	-0.2	1.5	1	1	1
11/22/2022 01:00	-0.7	12.6	2,125.4	-0.2	1.5	1	1	1
11/22/2022 02:00	-0.7	12.6	2,094.4	-0.2	1.5	1	1	1
11/22/2022 03:00	-0.8	13.1	1,973.7	-0.5	1.4	1	1	1
11/22/2022 04:00	-0.9	13.1	1,977.2	-0.5	1.4	1	1	1
11/22/2022 05:00	-0.8	12.6	2,065.9	-0.4	1.4	1	1	1
11/22/2022 06:00	-0.7	12.5	2,149.0	-0.2	1.5	1	1	1
11/22/2022 07:00	-0.8	12.7	2,088.9	-0.4	1.5	1	1	1
11/22/2022 08:00	-0.9	12.9	2,051.0	-0.5	1.4	1	1	1
11/22/2022 09:00	0.0	14.2	1,444.6	0.0	1.0	1	0	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2022 11:00	0.0	19.5	58.0	0.0	0.0	1	0	0
11/22/2022 12:00	0.0	15.8	756.7	0.0	0.5	1	0	0
11/22/2022 13:00	0.3	13.8	1,622.5	0.4	1.1	1	1	0
11/22/2022 14:00	0.4	13.8	1,790.4	0.4	1.3	1	1	0
11/22/2022 15:00	0.4	13.8	1,790.4	0.4	1.3	1	1	0
11/22/2022 16:00	-0.4	13.2	1,897.6	-0.1	1.3	1	1	1
11/22/2022 17:00	-0.7	12.3	2,141.8	-0.2	1.5	1	1	1
11/22/2022 18:00	-0.7	12.7	2,035.3	-0.2	1.4	1	1	1
11/22/2022 19:00	-0.8	13.0	1,982.5	-0.4	1.4	1	1	1
11/22/2022 20:00	-0.7	12.4	2,138.7	-0.2	1.5	1	1	1
11/22/2022 21:00	-0.8	12.9	2,017.6	-0.4	1.4	1	1	1
11/22/2022 22:00	-0.8	12.8	2,028.8	-0.4	1.4	1	1	1
11/22/2022 23:00	-1.1	13.2	1,957.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.4	1,840.5	-0.2	1.3	23 #	20 #	18 #
Minimum:	-1.1	12.3	58.0	-0.7	0.0	0	0	0
Maximum:	0.4	19.5	2,149.0	0.4	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	-1.1	13.2	1,958.7	-0.7	1.4	1	1	1
11/23/2022 01:00	-1.1	13.2	1,960.6	-0.7	1.4	1	1	1
11/23/2022 02:00	-1.1	13.2	1,958.4	-0.7	1.4	1	1	1
11/23/2022 03:00	-1.1	13.2	1,962.5	-0.7	1.4	1	1	1
11/23/2022 04:00	-1.1	13.1	1,969.2	-0.7	1.4	1	1	1
11/23/2022 05:00	-0.7	12.5	2,057.1	-0.2	1.4	1	1	1
11/23/2022 06:00	-0.8	12.8	2,048.5	-0.4	1.4	1	1	1
11/23/2022 07:00	-0.7	12.6	2,103.9	-0.2	1.5	1	1	1
11/23/2022 08:00	-0.8	13.0	1,993.7	-0.4	1.4	1	1	1
11/23/2022 09:00	0.4	13.8	1,707.7	0.4	1.2	1	1	0
11/23/2022 10:00	0.4	13.8	1,562.1	0.4	1.1	1	1	0
11/23/2022 11:00	0.4	13.9	1,556.2	0.4	1.1	1	1	0
11/23/2022 12:00	0.4	13.9	1,424.7	0.4	1.0	1	1	0
11/23/2022 13:00	0.4	13.9	1,558.7	0.4	1.1	1	1	0
11/23/2022 14:00	0.4	13.9	1,628.7	0.4	1.1	1	1	0
11/23/2022 15:00	0.2	13.8	1,649.5	0.4	1.2	1	1	1
11/23/2022 16:00	-0.8	12.5	2,097.1	-0.4	1.5	1	1	1
11/23/2022 17:00	-0.7	12.3	2,159.6	-0.2	1.5	1	1	1
11/23/2022 18:00	-0.8	12.6	2,078.6	-0.4	1.5	1	1	1
11/23/2022 19:00	-0.9	12.8	2,045.2	-0.5	1.4	1	1	1
11/23/2022 20:00	-0.7	12.3	2,155.0	-0.2	1.5	1	1	1
11/23/2022 21:00	-0.7	12.2	2,168.6	-0.2	1.5	1	1	1
11/23/2022 22:00	-0.7	12.4	2,143.6	-0.2	1.5	1	1	1
11/23/2022 23:00	-0.7	12.4	2,140.6	-0.2	1.5	1	1	1
Average/Sum#:	-0.5	13.1	1,920.4	-0.2	1.4	24 #	24 #	18 #
Minimum:	-1.1	12.2	1,424.7	-0.7	1.0	1	1	0
Maximum:	0.4	13.9	2,168.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	-1.1	13.1	1,975.4	-0.7	1.4	1	1	1
11/24/2022 01:00	-1.4	13.2	1,962.5	-0.9	1.4	1	1	1
11/24/2022 02:00	-1.4	13.2	1,963.6	-0.9	1.4	1	1	1
11/24/2022 03:00	-0.8	13.0	1,975.0	-0.4	1.4	1	1	1
11/24/2022 04:00	-0.7	12.9	1,985.5	-0.4	1.4	1	1	1
11/24/2022 05:00	-0.7	12.5	2,052.9	-0.2	1.4	1	1	1
11/24/2022 06:00	-0.5	12.2	2,165.6	-0.1	1.5	1	1	1
11/24/2022 07:00	-0.5	12.5	2,079.4	-0.2	1.5	1	1	1
11/24/2022 08:00	0.4	13.8	1,712.0	0.4	1.2	1	1	0
11/24/2022 09:00	0.4	13.8	1,709.0	0.4	1.2	1	1	0
11/24/2022 10:00	0.4	13.8	1,716.4	0.4	1.2	1	1	0
11/24/2022 11:00	0.4	13.9	1,560.1	0.4	1.1	1	1	0
11/24/2022 12:00	0.4	13.9	1,351.9	0.4	0.9	1	1	0
11/24/2022 13:00	0.4	13.9	1,350.9	0.4	0.9	1	1	0
11/24/2022 14:00	0.4	13.9	1,562.2	0.4	1.1	1	1	0
11/24/2022 15:00	0.4	13.9	1,450.2	0.4	1.0	1	1	0
11/24/2022 16:00	0.4	13.8	1,769.5	0.4	1.2	1	1	0
11/24/2022 17:00	0.4	13.8	1,768.6	0.4	1.2	1	1	0
11/24/2022 18:00	0.4	13.8	1,745.4	0.4	1.2	1	1	0
11/24/2022 19:00	0.4	13.8	1,737.1	0.4	1.2	1	1	0
11/24/2022 20:00	0.3	13.8	1,746.5	0.4	1.2	1	1	0
11/24/2022 21:00	0.3	13.8	1,747.1	0.4	1.2	1	1	0
11/24/2022 22:00	0.3	13.8	1,751.3	0.4	1.2	1	1	0
11/24/2022 23:00	0.3	13.8	1,753.2	0.4	1.2	1	1	0
Average/Sum#:	0.0	13.5	1,774.6	0.1	1.2	24 #	24 #	8 #
Minimum:	-1.4	12.2	1,350.9	-0.9	0.9	1	1	0
Maximum:	0.4	13.9	2,165.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.3	13.8	1,757.2	0.4	1.2	1	1	0
11/25/2022 01:00	0.3	13.8	1,758.4	0.4	1.2	1	1	0
11/25/2022 02:00	0.3	13.8	1,761.0	0.4	1.2	1	1	0
11/25/2022 03:00	0.3	13.8	1,764.3	0.4	1.2	1	1	0
11/25/2022 04:00	0.4	13.8	1,775.1	0.4	1.2	1	1	0
11/25/2022 05:00	0.3	13.8	1,771.2	0.4	1.2	1	1	0
11/25/2022 06:00	0.3	13.8	1,766.8	0.4	1.2	1	1	0
11/25/2022 07:00	0.3	13.8	1,766.8	0.4	1.2	1	1	0
11/25/2022 08:00	-0.5	13.4	1,882.1	-0.2	1.3	1	1	1
11/25/2022 09:00	-0.7	13.1	1,919.7	-0.4	1.3	1	1	1
11/25/2022 10:00	0.4	13.8	1,668.0	0.4	1.2	1	1	0
11/25/2022 11:00	0.3	13.8	1,549.0	0.4	1.1	1	1	0
11/25/2022 12:00	0.4	13.8	1,574.7	0.4	1.1	1	1	0
11/25/2022 13:00	0.4	13.8	1,543.3	0.4	1.1	1	1	0
11/25/2022 14:00	0.3	13.8	1,531.6	0.4	1.1	1	1	0
11/25/2022 15:00	0.1	13.7	1,644.3	0.2	1.2	1	1	1
11/25/2022 16:00	-0.8	12.6	2,082.1	-0.4	1.5	1	1	1
11/25/2022 17:00	-0.7	12.5	2,096.7	-0.2	1.5	1	1	1
11/25/2022 18:00	-0.8	13.0	1,970.2	-0.4	1.4	1	1	1
11/25/2022 19:00	-0.9	13.1	1,955.6	-0.5	1.4	1	1	1
11/25/2022 20:00	-0.9	13.1	1,955.0	-0.5	1.4	1	1	1
11/25/2022 21:00	-1.1	13.1	1,966.3	-0.7	1.4	1	1	1
11/25/2022 22:00	-0.7	12.5	2,118.6	-0.2	1.5	1	1	1
11/25/2022 23:00	-0.7	12.6	2,080.0	-0.2	1.5	1	1	1
Average/Sum#:	-0.1	13.4	1,819.1	0.1	1.3	24 #	24 #	11 #
Minimum:	-1.1	12.5	1,531.6	-0.7	1.1	1	1	0
Maximum:	0.4	13.8	2,118.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	-0.8	12.9	2,016.8	-0.4	1.4	1	1	1
11/26/2022 01:00	-0.8	12.7	2,062.0	-0.4	1.4	1	1	1
11/26/2022 02:00	0.0	13.8	1,575.4	0.0	1.1	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.5	13.1	1,884.7	-0.3	1.3	3 #	2 #	3 #
Minimum:	-0.8	12.7	1,575.4	-0.4	1.1	0	0	0
Maximum:	0.0	13.8	2,062.0	0.0	1.4	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2022 02:00	0.0	17.4	344.2	0.0	0.2	1	0	0
11/28/2022 03:00	0.0	15.2	949.6	0.0	0.7	1	0	0
11/28/2022 04:00	0.3	13.7	1,724.6	0.4	1.2	1	1	0
11/28/2022 05:00	-0.1	13.7	1,654.5	0.1	1.2	1	1	1
11/28/2022 06:00	-0.9	12.5	2,164.7	-0.5	1.5	1	1	1
11/28/2022 07:00	-0.7	12.0	2,260.4	-0.2	1.6	1	1	1
11/28/2022 08:00	-0.8	13.0	1,970.9	-0.4	1.4	1	1	1
11/28/2022 09:00	0.3	13.8	1,613.8	0.4	1.1	1	1	0
11/28/2022 10:00	0.3	13.8	1,719.0	0.4	1.2	1	1	0
11/28/2022 11:00	0.3	13.8	1,526.4	0.4	1.1	1	1	0
11/28/2022 12:00	0.4	13.8	1,571.0	0.4	1.1	1	1	0
11/28/2022 13:00	0.4	13.8	1,644.0	0.4	1.2	1	1	0
11/28/2022 14:00	0.4	13.8	1,627.3	0.4	1.1	1	1	0
11/28/2022 15:00	0.1	13.7	1,623.7	0.2	1.1	1	1	1
11/28/2022 16:00	-0.8	12.8	2,023.4	-0.4	1.4	1	1	1
11/28/2022 17:00	-0.7	12.5	2,090.0	-0.2	1.5	1	1	1
11/28/2022 18:00	-0.7	13.0	1,980.4	-0.4	1.4	1	1	1
11/28/2022 19:00	-0.9	13.1	1,958.5	-0.5	1.4	1	1	1
11/28/2022 20:00	-0.8	12.7	2,080.3	-0.4	1.5	1	1	1
11/28/2022 21:00	-0.5	12.1	2,212.4	-0.1	1.5	1	1	1
11/28/2022 22:00	-0.7	12.7	2,084.2	-0.2	1.5	1	1	1
11/28/2022 23:00	-0.8	13.1	1,981.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.5	1,763.9	0.0	1.2	22 #	20 #	13 #
Minimum:	-0.9	12.0	344.2	-0.5	0.2	0	0	0
Maximum:	0.4	17.4	2,260.4	0.4	1.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	-0.7	12.4	2,141.8	-0.2	1.5	1	1	1
11/29/2022 01:00	-0.7	12.3	2,186.9	-0.2	1.5	1	1	1
11/29/2022 02:00	-0.7	12.3	2,175.4	-0.2	1.5	1	1	1
11/29/2022 03:00	-0.8	12.7	2,087.1	-0.4	1.5	1	1	1
11/29/2022 04:00	-0.7	12.5	2,149.0	-0.2	1.5	1	1	1
11/29/2022 05:00	-0.7	12.3	2,196.7	-0.2	1.5	1	1	1
11/29/2022 06:00	-0.5	11.9	2,281.7	-0.1	1.6	1	1	1
11/29/2022 07:00	-0.5	11.9	2,281.4	-0.1	1.6	1	1	1
11/29/2022 08:00	-0.5	11.9	2,244.1	-0.1	1.6	1	1	1
11/29/2022 09:00	-0.5	12.3	2,150.7	-0.1	1.5	1	1	1
11/29/2022 10:00	-0.5	12.3	2,145.0	-0.1	1.5	1	1	1
11/29/2022 11:00	-0.5	12.3	2,136.9	-0.1	1.5	1	1	1
11/29/2022 12:00	-0.5	12.3	2,126.6	-0.1	1.5	1	1	1
11/29/2022 13:00	-0.5	12.3	2,125.1	-0.1	1.5	1	1	1
11/29/2022 14:00	-0.5	12.3	2,128.4	-0.1	1.5	1	1	1
11/29/2022 15:00	-0.5	12.3	2,146.5	-0.1	1.5	1	1	1
11/29/2022 16:00	-0.4	11.8	2,253.8	-0.1	1.6	1	1	1
11/29/2022 17:00	-0.4	11.8	2,262.7	-0.1	1.6	1	1	1
11/29/2022 18:00	-0.4	11.8	2,269.7	-0.1	1.6	1	1	1
11/29/2022 19:00	-0.4	11.8	2,270.4	-0.1	1.6	1	1	1
11/29/2022 20:00	-0.5	11.9	2,275.0	-0.1	1.6	1	1	1
11/29/2022 21:00	-0.5	11.9	2,279.4	-0.1	1.6	1	1	1
11/29/2022 22:00	-0.5	11.9	2,281.0	-0.1	1.6	1	1	1
11/29/2022 23:00	-0.5	11.9	2,279.2	-0.1	1.6	1	1	1
Average/Sum#:	-0.5	12.1	2,203.1	-0.1	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.8	2,087.1	-0.4	1.5	1	1	1
Maximum:	-0.4	12.7	2,281.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2022 00:00	-0.7	12.5	2,172.7	-0.2	1.5	1	1	1
11/30/2022 01:00	-0.7	12.5	2,154.2	-0.2	1.5	1	1	1
11/30/2022 02:00	-0.7	12.5	2,150.7	-0.2	1.5	1	1	1
11/30/2022 03:00	-0.7	12.5	2,151.7	-0.2	1.5	1	1	1
11/30/2022 04:00	-0.7	12.5	2,168.0	-0.2	1.5	1	1	1
11/30/2022 05:00	-0.8	12.5	2,165.1	-0.4	1.5	1	1	1
11/30/2022 06:00	-0.7	12.1	2,258.1	-0.2	1.6	1	1	1
11/30/2022 07:00	-0.7	12.5	2,146.1	-0.2	1.5	1	1	1
11/30/2022 08:00	-1.2	13.2	1,980.7	-0.8	1.4	1	1	1
11/30/2022 09:00	-1.2	13.1	1,994.5	-0.8	1.4	1	1	1
11/30/2022 10:00	-1.1	13.2	1,971.3	-0.7	1.4	1	1	1
11/30/2022 11:00	-1.1	13.1	1,965.9	-0.7	1.4	1	1	1
11/30/2022 12:00	-1.1	13.1	1,966.2	-0.7	1.4	1	1	1
11/30/2022 13:00	-0.9	13.0	1,964.4	-0.5	1.4	1	1	1
11/30/2022 14:00	-0.7	12.4	2,104.4	-0.2	1.5	1	1	1
11/30/2022 15:00	-0.7	12.3	2,113.2	-0.2	1.5	1	1	1
11/30/2022 16:00	-0.5	11.9	2,217.4	-0.1	1.6	1	1	1
11/30/2022 17:00	-0.4	11.7	2,265.7	0.1	1.6	1	1	1
11/30/2022 18:00	-0.4	11.7	2,264.2	0.1	1.6	1	1	1
11/30/2022 19:00	-0.4	11.7	2,263.8	0.1	1.6	1	1	1
11/30/2022 20:00	-0.4	11.8	2,258.6	-0.1	1.6	1	1	1
11/30/2022 21:00	-0.5	11.9	2,224.8	-0.1	1.6	1	1	1
11/30/2022 22:00	-0.7	12.5	2,086.6	-0.2	1.5	1	1	1
11/30/2022 23:00	0.0	13.7	1,584.9	0.0	1.1	1	0	1
Average/Sum#:	-0.7	12.5	2,108.1	-0.3	1.5	24 #	23 #	24 #
Minimum:	-1.2	11.7	1,584.9	-0.8	1.1	1	0	1
Maximum:	0.0	13.7	2,265.7	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2022 09:00	0.0	20.2	1.9	0.0	0.0	1	0	0
12/05/2022 10:00	0.0	16.6	470.2	0.0	0.3	1	0	0
12/05/2022 11:00	0.0	13.2	1,793.9	0.0	1.3	1	0	1
12/05/2022 12:00	-0.7	12.2	2,140.7	-0.2	1.5	1	1	1
12/05/2022 13:00	-0.7	12.7	2,012.1	-0.2	1.4	1	1	1
12/05/2022 14:00	-0.7	12.7	2,032.3	-0.2	1.4	1	1	1
12/05/2022 15:00	-0.5	12.6	2,051.5	-0.2	1.4	1	1	1
12/05/2022 16:00	-0.5	12.0	2,193.6	-0.1	1.5	1	1	1
12/05/2022 17:00	-0.4	11.7	2,269.5	0.1	1.6	1	1	1
12/05/2022 18:00	-0.4	11.7	2,271.5	0.1	1.6	1	1	1
12/05/2022 19:00	-0.4	11.7	2,271.1	0.1	1.6	1	1	1
12/05/2022 20:00	-0.5	11.8	2,272.1	-0.1	1.6	1	1	1
12/05/2022 21:00	-0.5	12.1	2,201.5	-0.1	1.5	1	1	1
12/05/2022 22:00	-0.8	12.7	2,067.0	-0.4	1.4	1	1	1
12/05/2022 23:00	-0.8	12.8	2,045.9	-0.4	1.4	1	1	1
Average/Sum#:	-0.5	13.1	1,873.0	-0.1	1.3	15 #	12 #	13 #
Minimum:	-0.8	11.7	1.9	-0.4	0.0	0	0	0
Maximum:	0.0	20.2	2,272.1	0.1	1.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2022 00:00	-1.1	13.2	1,967.2	-0.7	1.4	1	1	1
12/06/2022 01:00	-1.2	13.2	1,966.1	-0.8	1.4	1	1	1
12/06/2022 02:00	-1.2	13.2	1,965.7	-0.8	1.4	1	1	1
12/06/2022 03:00	-1.2	13.2	1,967.0	-0.8	1.4	1	1	1
12/06/2022 04:00	-1.1	13.1	1,982.2	-0.7	1.4	1	1	1
12/06/2022 05:00	-0.8	12.9	2,009.3	-0.4	1.4	1	1	1
12/06/2022 06:00	-1.1	13.1	1,982.0	-0.7	1.4	1	1	1
12/06/2022 07:00	-0.8	12.7	2,084.6	-0.4	1.5	1	1	1
12/06/2022 08:00	-0.7	11.9	2,259.2	-0.2	1.6	1	1	1
12/06/2022 09:00	-0.5	12.0	2,240.1	-0.1	1.6	1	1	1
12/06/2022 10:00	-0.5	12.0	2,234.8	-0.1	1.6	1	1	1
12/06/2022 11:00	-0.5	12.0	2,230.6	-0.1	1.6	1	1	1
12/06/2022 12:00	-0.5	12.0	2,217.9	-0.1	1.6	1	1	1
12/06/2022 13:00	0.1	13.6	1,788.8	0.2	1.3	1	1	1
12/06/2022 14:00	0.3	13.9	1,318.8	0.4	0.9	1	1	0
12/06/2022 15:00	0.3	13.9	1,318.6	0.4	0.9	1	1	0
12/06/2022 16:00	0.3	13.8	1,520.8	0.4	1.1	1	1	0
12/06/2022 17:00	0.4	13.7	1,823.5	0.4	1.3	1	1	0
12/06/2022 18:00	0.4	13.7	1,825.1	0.4	1.3	1	1	0
12/06/2022 19:00	0.1	13.7	1,829.3	0.2	1.3	1	1	1
12/06/2022 20:00	-0.8	12.5	2,123.4	-0.4	1.5	1	1	1
12/06/2022 21:00	-0.5	12.0	2,220.9	-0.1	1.6	1	1	1
12/06/2022 22:00	-0.7	12.5	2,096.6	-0.2	1.5	1	1	1
12/06/2022 23:00	-0.8	13.2	1,968.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.0	1,955.9	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.9	1,318.6	-0.8	0.9	1	1	0
Maximum:	0.4	13.9	2,259.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	-0.7	12.7	2,080.4	-0.2	1.5	1	1	1
12/07/2022 01:00	-0.8	13.1	1,983.5	-0.5	1.4	1	1	1
12/07/2022 02:00	-0.7	12.5	2,133.1	-0.2	1.5	1	1	1
12/07/2022 03:00	-0.7	12.5	2,140.6	-0.2	1.5	1	1	1
12/07/2022 04:00	-0.7	12.4	2,147.2	-0.2	1.5	1	1	1
12/07/2022 05:00	-0.7	12.3	2,161.2	-0.2	1.5	1	1	1
12/07/2022 06:00	-0.7	12.1	2,240.0	-0.2	1.6	1	1	1
12/07/2022 07:00	-0.5	12.0	2,240.5	-0.1	1.6	1	1	1
12/07/2022 08:00	-0.7	12.6	2,123.6	-0.2	1.5	1	1	1
12/07/2022 09:00	-0.7	12.5	2,160.5	-0.2	1.5	1	1	1
12/07/2022 10:00	-0.7	12.4	2,154.7	-0.2	1.5	1	1	1
12/07/2022 11:00	-0.7	12.4	2,152.0	-0.2	1.5	1	1	1
12/07/2022 12:00	-0.7	12.5	2,125.4	-0.2	1.5	1	1	1
12/07/2022 13:00	-0.5	12.5	2,105.1	-0.2	1.5	1	1	1
12/07/2022 14:00	-0.7	12.7	2,045.2	-0.2	1.4	1	1	1
12/07/2022 15:00	-0.7	12.6	2,072.9	-0.2	1.5	1	1	1
12/07/2022 16:00	-0.5	11.9	2,242.3	-0.1	1.6	1	1	1
12/07/2022 17:00	-0.5	11.8	2,263.1	-0.1	1.6	1	1	1
12/07/2022 18:00	-0.5	11.9	2,262.6	-0.1	1.6	1	1	1
12/07/2022 19:00	-0.5	11.9	2,259.5	-0.1	1.6	1	1	1
12/07/2022 20:00	-0.5	11.9	2,260.4	-0.1	1.6	1	1	1
12/07/2022 21:00	-0.5	12.0	2,254.9	-0.1	1.6	1	1	1
12/07/2022 22:00	-0.7	12.4	2,171.8	-0.2	1.5	1	1	1
12/07/2022 23:00	-0.7	12.4	2,171.2	-0.2	1.5	1	1	1
Average/Sum#:	-0.6	12.3	2,164.7	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.8	11.8	1,983.5	-0.5	1.4	1	1	1
Maximum:	-0.5	13.1	2,263.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	-0.7	12.6	2,128.3	-0.2	1.5	1	1	1
12/08/2022 01:00	-0.7	12.6	2,124.0	-0.2	1.5	1	1	1
12/08/2022 02:00	-0.7	12.6	2,125.4	-0.2	1.5	1	1	1
12/08/2022 03:00	-0.7	12.6	2,126.6	-0.2	1.5	1	1	1
12/08/2022 04:00	-0.7	12.5	2,151.8	-0.2	1.5	1	1	1
12/08/2022 05:00	-0.8	12.1	2,206.3	-0.4	1.5	1	1	1
12/08/2022 06:00	-0.7	12.0	2,276.7	-0.2	1.6	1	1	1
12/08/2022 07:00	-0.7	12.2	2,235.9	-0.2	1.6	1	1	1
12/08/2022 08:00	-0.9	13.0	2,033.3	-0.5	1.4	1	1	1
12/08/2022 09:00	-0.8	12.7	2,119.8	-0.4	1.5	1	1	1
12/08/2022 10:00	-0.7	12.6	2,125.2	-0.2	1.5	1	1	1
12/08/2022 11:00	-0.7	12.5	2,152.4	-0.2	1.5	1	1	1
12/08/2022 12:00	-0.7	12.4	2,146.3	-0.2	1.5	1	1	1
12/08/2022 13:00	-0.7	12.3	2,151.6	-0.2	1.5	1	1	1
12/08/2022 14:00	-0.7	12.3	2,154.1	-0.2	1.5	1	1	1
12/08/2022 15:00	-0.7	12.3	2,161.0	-0.2	1.5	1	1	1
12/08/2022 16:00	-0.5	11.8	2,252.5	-0.1	1.6	1	1	1
12/08/2022 17:00	-0.5	11.9	2,253.7	-0.1	1.6	1	1	1
12/08/2022 18:00	-0.5	11.8	2,260.9	-0.1	1.6	1	1	1
12/08/2022 19:00	-0.5	11.8	2,258.9	-0.1	1.6	1	1	1
12/08/2022 20:00	-0.5	11.8	2,260.5	-0.1	1.6	1	1	1
12/08/2022 21:00	-0.5	11.8	2,262.3	-0.1	1.6	1	1	1
12/08/2022 22:00	-0.7	12.2	2,175.3	-0.2	1.5	1	1	1
12/08/2022 23:00	-0.7	12.3	2,175.7	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.3	2,179.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.8	2,033.3	-0.5	1.4	1	1	1
Maximum:	-0.5	13.0	2,276.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2022 00:00	-0.7	12.4	2,133.4	-0.2	1.5	1	1	1
12/09/2022 01:00	-0.8	12.9	2,049.3	-0.4	1.4	1	1	1
12/09/2022 02:00	-0.7	12.5	2,145.6	-0.2	1.5	1	1	1
12/09/2022 03:00	-0.7	12.5	2,141.8	-0.2	1.5	1	1	1
12/09/2022 04:00	-0.7	12.3	2,188.2	-0.2	1.5	1	1	1
12/09/2022 05:00	-0.7	11.9	2,279.0	-0.2	1.6	1	1	1
12/09/2022 06:00	-0.7	11.9	2,284.6	-0.2	1.6	1	1	1
12/09/2022 07:00	-0.7	12.0	2,273.6	-0.2	1.6	1	1	1
12/09/2022 08:00	-0.9	12.8	2,069.7	-0.5	1.4	1	1	1
12/09/2022 09:00	-0.9	13.0	2,024.0	-0.5	1.4	1	1	1
12/09/2022 10:00	-1.2	13.2	1,975.9	-0.8	1.4	1	1	1
12/09/2022 11:00	-0.8	12.8	2,071.4	-0.4	1.4	1	1	1
12/09/2022 12:00	-0.9	13.0	2,003.4	-0.5	1.4	1	1	1
12/09/2022 13:00	-0.7	12.4	2,147.1	-0.2	1.5	1	1	1
12/09/2022 14:00	-0.7	12.4	2,137.6	-0.2	1.5	1	1	1
12/09/2022 15:00	-0.9	12.8	2,036.0	-0.5	1.4	1	1	1
12/09/2022 16:00	-0.5	11.9	2,251.5	-0.1	1.6	1	1	1
12/09/2022 17:00	-0.5	11.9	2,251.1	-0.1	1.6	1	1	1
12/09/2022 18:00	-0.5	11.9	2,251.7	-0.1	1.6	1	1	1
12/09/2022 19:00	-0.5	11.9	2,253.6	-0.1	1.6	1	1	1
12/09/2022 20:00	-0.5	11.9	2,258.2	-0.1	1.6	1	1	1
12/09/2022 21:00	-0.5	11.9	2,257.3	-0.1	1.6	1	1	1
12/09/2022 22:00	-0.5	11.9	2,255.6	-0.1	1.6	1	1	1
12/09/2022 23:00	-0.5	11.9	2,249.1	-0.1	1.6	1	1	1
Average/Sum#:	-0.7	12.3	2,166.2	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.9	1,975.9	-0.8	1.4	1	1	1
Maximum:	-0.5	13.2	2,284.6	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	-0.9	12.9	2,006.4	-0.5	1.4	1	1	1
12/10/2022 01:00	-0.9	12.9	1,999.6	-0.5	1.4	1	1	1
12/10/2022 02:00	-1.1	13.1	1,963.4	-0.7	1.4	1	1	1
12/10/2022 03:00	-1.1	13.0	1,964.2	-0.7	1.4	1	1	1
12/10/2022 04:00	-1.1	13.0	1,959.0	-0.7	1.4	1	1	1
12/10/2022 05:00	-1.1	12.9	1,970.7	-0.7	1.4	1	1	1
12/10/2022 06:00	-1.2	13.0	1,958.3	-0.8	1.4	1	1	1
12/10/2022 07:00	-1.2	13.0	1,965.3	-0.8	1.4	1	1	1
12/10/2022 08:00	-0.9	12.8	2,005.5	-0.5	1.4	1	1	1
12/10/2022 09:00	-1.1	12.9	1,981.7	-0.7	1.4	1	1	1
12/10/2022 10:00	-1.2	13.0	1,958.2	-0.8	1.4	1	1	1
12/10/2022 11:00	-0.9	12.7	2,001.0	-0.5	1.4	1	1	1
12/10/2022 12:00	-0.7	12.3	2,097.7	-0.2	1.5	1	1	1
12/10/2022 13:00	-0.5	12.0	2,155.9	-0.1	1.5	1	1	1
12/10/2022 14:00	-0.7	12.6	2,002.4	-0.2	1.4	1	1	1
12/10/2022 15:00	-0.7	12.6	2,024.6	-0.2	1.4	1	1	1
12/10/2022 16:00	-0.7	12.3	2,094.2	-0.2	1.5	1	1	1
12/10/2022 17:00	-0.7	12.5	2,057.1	-0.2	1.4	1	1	1
12/10/2022 18:00	-0.8	12.5	2,058.1	-0.4	1.4	1	1	1
12/10/2022 19:00	-0.5	11.8	2,229.9	-0.1	1.6	1	1	1
12/10/2022 20:00	-0.5	12.1	2,153.8	-0.1	1.5	1	1	1
12/10/2022 21:00	-0.7	12.5	2,068.8	-0.2	1.4	1	1	1
12/10/2022 22:00	-0.8	12.8	2,009.3	-0.4	1.4	1	1	1
12/10/2022 23:00	-0.7	12.5	2,063.5	-0.2	1.4	1	1	1
Average/Sum#:	-0.9	12.7	2,031.2	-0.4	1.4	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,958.2	-0.8	1.4	1	1	1
Maximum:	-0.5	13.1	2,229.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	-0.9	13.0	1,956.5	-0.5	1.4	1	1	1
12/11/2022 01:00	-1.1	13.1	1,954.5	-0.7	1.4	1	1	1
12/11/2022 02:00	-1.1	13.1	1,954.5	-0.7	1.4	1	1	1
12/11/2022 03:00	-1.1	13.1	1,953.0	-0.7	1.4	1	1	1
12/11/2022 04:00	-1.2	13.1	1,955.4	-0.8	1.4	1	1	1
12/11/2022 05:00	-1.2	13.1	1,956.0	-0.8	1.4	1	1	1
12/11/2022 06:00	-1.2	13.1	1,958.5	-0.8	1.4	1	1	1
12/11/2022 07:00	-1.2	13.1	1,960.5	-0.8	1.4	1	1	1
12/11/2022 08:00	-1.2	13.1	1,961.5	-0.8	1.4	1	1	1
12/11/2022 09:00	-1.2	13.1	1,964.5	-0.8	1.4	1	1	1
12/11/2022 10:00	-1.2	13.1	1,963.7	-0.8	1.4	1	1	1
12/11/2022 11:00	-1.1	13.1	1,959.8	-0.7	1.4	1	1	1
12/11/2022 12:00	-1.1	13.1	1,958.4	-0.7	1.4	1	1	1
12/11/2022 13:00	-1.1	13.0	1,960.6	-0.7	1.4	1	1	1
12/11/2022 14:00	-1.1	13.0	1,958.2	-0.7	1.4	1	1	1
12/11/2022 15:00	-0.8	12.7	2,050.1	-0.4	1.4	1	1	1
12/11/2022 16:00	-0.8	12.7	2,053.8	-0.4	1.4	1	1	1
12/11/2022 17:00	-0.7	12.4	2,123.8	-0.2	1.5	1	1	1
12/11/2022 18:00	-0.9	12.9	2,040.4	-0.5	1.4	1	1	1
12/11/2022 19:00	-0.8	12.8	2,068.4	-0.4	1.4	1	1	1
12/11/2022 20:00	-0.8	12.6	2,119.1	-0.4	1.5	1	1	1
12/11/2022 21:00	-1.1	13.1	2,002.7	-0.7	1.4	1	1	1
12/11/2022 22:00	-1.2	13.2	1,968.1	-0.8	1.4	1	1	1
12/11/2022 23:00	-1.2	13.2	1,965.9	-0.8	1.4	1	1	1
Average/Sum#:	-1.1	13.0	1,990.3	-0.7	1.4	24 #	24 #	24 #
Minimum:	-1.2	12.4	1,953.0	-0.8	1.4	1	1	1
Maximum:	-0.7	13.2	2,123.8	-0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	-1.2	13.2	1,974.6	-0.8	1.4	1	1	1
12/12/2022 01:00	-1.2	13.2	1,974.7	-0.8	1.4	1	1	1
12/12/2022 02:00	-1.2	13.2	1,974.6	-0.8	1.4	1	1	1
12/12/2022 03:00	-1.2	13.2	1,972.4	-0.8	1.4	1	1	1
12/12/2022 04:00	-1.2	13.2	1,975.3	-0.8	1.4	1	1	1
12/12/2022 05:00	-0.8	12.4	2,111.2	-0.4	1.5	1	1	1
12/12/2022 06:00	-0.7	12.3	2,205.4	-0.2	1.5	1	1	1
12/12/2022 07:00	-0.7	12.3	2,187.8	-0.2	1.5	1	1	1
12/12/2022 08:00	-0.9	12.8	2,074.1	-0.5	1.5	1	1	1
12/12/2022 09:00	-0.8	12.8	2,066.2	-0.4	1.4	1	1	1
12/12/2022 10:00	-1.2	13.2	1,973.4	-0.8	1.4	1	1	1
12/12/2022 11:00	-1.2	13.2	1,968.1	-0.8	1.4	1	1	1
12/12/2022 12:00	-1.2	13.2	1,964.0	-0.8	1.4	1	1	1
12/12/2022 13:00	-1.1	13.1	1,961.0	-0.7	1.4	1	1	1
12/12/2022 14:00	-1.1	13.1	1,953.7	-0.7	1.4	1	1	1
12/12/2022 15:00	-1.1	13.1	1,956.5	-0.7	1.4	1	1	1
12/12/2022 16:00	-0.7	12.4	2,131.9	-0.2	1.5	1	1	1
12/12/2022 17:00	-0.5	12.0	2,216.3	-0.1	1.6	1	1	1
12/12/2022 18:00	-0.4	11.8	2,275.3	-0.1	1.6	1	1	1
12/12/2022 19:00	-0.4	11.8	2,277.0	-0.1	1.6	1	1	1
12/12/2022 20:00	-0.4	11.8	2,281.0	-0.1	1.6	1	1	1
12/12/2022 21:00	-0.5	12.0	2,246.6	-0.1	1.6	1	1	1
12/12/2022 22:00	-0.5	12.3	2,188.8	-0.1	1.5	1	1	1
12/12/2022 23:00	-0.8	13.0	2,025.1	-0.4	1.4	1	1	1
Average/Sum#:	-0.9	12.7	2,080.6	-0.5	1.5	24 #	24 #	24 #
Minimum:	-1.2	11.8	1,953.7	-0.8	1.4	1	1	1
Maximum:	-0.4	13.2	2,281.0	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	-0.7	12.6	2,151.0	-0.2	1.5	1	1	1
12/13/2022 01:00	-0.7	12.5	2,157.4	-0.2	1.5	1	1	1
12/13/2022 02:00	-0.7	12.4	2,161.4	-0.2	1.5	1	1	1
12/13/2022 03:00	-0.7	12.5	2,146.4	-0.2	1.5	1	1	1
12/13/2022 04:00	-0.7	12.4	2,189.1	-0.2	1.5	1	1	1
12/13/2022 05:00	-0.7	12.0	2,273.8	-0.2	1.6	1	1	1
12/13/2022 06:00	-0.5	11.9	2,310.2	-0.1	1.6	1	1	1
12/13/2022 07:00	-0.5	11.9	2,287.8	-0.1	1.6	1	1	1
12/13/2022 08:00	-0.7	12.5	2,134.0	-0.2	1.5	1	1	1
12/13/2022 09:00	-0.9	13.0	2,010.3	-0.5	1.4	1	1	1
12/13/2022 10:00	-1.1	13.2	1,963.5	-0.7	1.4	1	1	1
12/13/2022 11:00	-1.1	13.2	1,966.2	-0.7	1.4	1	1	1
12/13/2022 12:00	-1.1	13.1	1,963.9	-0.7	1.4	1	1	1
12/13/2022 13:00	-1.1	13.1	1,958.8	-0.7	1.4	1	1	1
12/13/2022 14:00	-1.1	13.1	1,948.4	-0.7	1.4	1	1	1
12/13/2022 15:00	-0.8	12.7	2,055.9	-0.4	1.4	1	1	1
12/13/2022 16:00	-0.4	11.9	2,251.4	-0.1	1.6	1	1	1
12/13/2022 17:00	-0.4	11.8	2,271.2	-0.1	1.6	1	1	1
12/13/2022 18:00	-0.4	11.8	2,273.1	-0.1	1.6	1	1	1
12/13/2022 19:00	-0.4	11.9	2,270.7	-0.1	1.6	1	1	1
12/13/2022 20:00	-0.5	11.9	2,269.3	-0.1	1.6	1	1	1
12/13/2022 21:00	-0.5	12.0	2,274.0	-0.1	1.6	1	1	1
12/13/2022 22:00	-0.5	12.0	2,272.2	-0.1	1.6	1	1	1
12/13/2022 23:00	-0.5	11.9	2,268.0	-0.1	1.6	1	1	1
Average/Sum#:	-0.7	12.4	2,159.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.8	1,948.4	-0.7	1.4	1	1	1
Maximum:	-0.4	13.2	2,310.2	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	-0.5	12.3	2,186.8	-0.1	1.5	1	1	1
12/14/2022 01:00	-0.7	12.4	2,187.5	-0.2	1.5	1	1	1
12/14/2022 02:00	-0.7	12.4	2,188.4	-0.2	1.5	1	1	1
12/14/2022 03:00	-0.7	12.4	2,189.7	-0.2	1.5	1	1	1
12/14/2022 04:00	-0.7	12.4	2,186.4	-0.2	1.5	1	1	1
12/14/2022 05:00	-0.7	12.0	2,291.8	-0.2	1.6	1	1	1
12/14/2022 06:00	-0.5	12.0	2,297.1	-0.1	1.6	1	1	1
12/14/2022 07:00	-0.5	12.1	2,255.1	-0.1	1.6	1	1	1
12/14/2022 08:00	-0.8	12.9	2,069.6	-0.4	1.4	1	1	1
12/14/2022 09:00	-0.9	13.1	2,007.9	-0.5	1.4	1	1	1
12/14/2022 10:00	-0.8	13.0	2,023.9	-0.4	1.4	1	1	1
12/14/2022 11:00	-0.9	13.2	1,967.4	-0.5	1.4	1	1	1
12/14/2022 12:00	-1.1	13.2	1,967.7	-0.7	1.4	1	1	1
12/14/2022 13:00	-0.9	13.2	1,966.4	-0.5	1.4	1	1	1
12/14/2022 14:00	-0.9	13.2	1,961.9	-0.5	1.4	1	1	1
12/14/2022 15:00	-0.9	13.0	2,003.9	-0.5	1.4	1	1	1
12/14/2022 16:00	-0.5	12.2	2,196.7	-0.1	1.5	1	1	1
12/14/2022 17:00	-0.5	11.9	2,270.2	-0.1	1.6	1	1	1
12/14/2022 18:00	-0.5	11.9	2,263.7	-0.1	1.6	1	1	1
12/14/2022 19:00	-0.5	11.9	2,270.0	-0.1	1.6	1	1	1
12/14/2022 20:00	-0.5	11.9	2,269.8	-0.1	1.6	1	1	1
12/14/2022 21:00	-0.5	12.0	2,270.9	-0.1	1.6	1	1	1
12/14/2022 22:00	-0.5	12.1	2,250.1	-0.1	1.6	1	1	1
12/14/2022 23:00	-0.5	12.4	2,172.6	-0.2	1.5	1	1	1
Average/Sum#:	-0.7	12.5	2,154.8	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.9	1,961.9	-0.7	1.4	1	1	1
Maximum:	-0.5	13.2	2,297.1	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2022 00:00	-0.5	11.9	2,285.2	-0.1	1.6	1	1	1
12/15/2022 01:00	-0.5	11.9	2,294.2	-0.1	1.6	1	1	1
12/15/2022 02:00	-0.4	11.9	2,295.1	-0.1	1.6	1	1	1
12/15/2022 03:00	-0.5	11.9	2,296.8	-0.1	1.6	1	1	1
12/15/2022 04:00	-0.4	11.9	2,302.4	-0.1	1.6	1	1	1
12/15/2022 05:00	-0.4	11.8	2,305.6	-0.1	1.6	1	1	1
12/15/2022 06:00	-0.4	11.8	2,303.9	-0.1	1.6	1	1	1
12/15/2022 07:00	-0.4	11.9	2,297.7	-0.1	1.6	1	1	1
12/15/2022 08:00	-0.4	12.2	2,216.9	-0.1	1.6	1	1	1
12/15/2022 09:00	-0.5	12.1	2,210.5	-0.1	1.5	1	1	1
12/15/2022 10:00	-0.8	13.1	1,975.6	-0.5	1.4	1	1	1
12/15/2022 11:00	-0.8	13.0	1,984.0	-0.4	1.4	1	1	1
12/15/2022 12:00	-0.7	12.8	2,010.5	-0.4	1.4	1	1	1
12/15/2022 13:00	-0.7	12.8	2,027.3	-0.4	1.4	1	1	1
12/15/2022 14:00	-0.4	12.5	2,076.8	-0.1	1.5	1	1	1
12/15/2022 15:00	-0.4	11.9	2,224.3	-0.1	1.6	1	1	1
12/15/2022 16:00	-0.2	11.9	2,242.6	0.1	1.6	1	1	1
12/15/2022 17:00	-0.4	11.9	2,240.4	-0.1	1.6	1	1	1
12/15/2022 18:00	-0.4	12.0	2,233.1	-0.1	1.6	1	1	1
12/15/2022 19:00	-0.5	12.0	2,230.3	-0.1	1.6	1	1	1
12/15/2022 20:00	-0.4	12.0	2,232.7	-0.1	1.6	1	1	1
12/15/2022 21:00	-0.5	12.1	2,238.4	-0.1	1.6	1	1	1
12/15/2022 22:00	-0.5	12.1	2,242.7	-0.1	1.6	1	1	1
12/15/2022 23:00	-0.5	12.2	2,230.3	-0.1	1.6	1	1	1
Average/Sum#:	-0.5	12.2	2,208.2	-0.1	1.6	24 #	24 #	24 #
Minimum:	-0.8	11.8	1,975.6	-0.5	1.4	1	1	1
Maximum:	-0.2	13.1	2,305.6	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2022 00:00	-0.9	13.1	1,993.7	-0.5	1.4	1	1	1
12/16/2022 01:00	-1.1	13.2	1,967.6	-0.7	1.4	1	1	1
12/16/2022 02:00	-1.1	13.2	1,966.9	-0.7	1.4	1	1	1
12/16/2022 03:00	-1.1	13.2	1,969.7	-0.7	1.4	1	1	1
12/16/2022 04:00	-1.1	13.2	1,968.6	-0.7	1.4	1	1	1
12/16/2022 05:00	-1.1	13.2	1,982.9	-0.7	1.4	1	1	1
12/16/2022 06:00	-0.8	12.7	2,114.1	-0.4	1.5	1	1	1
12/16/2022 07:00	-0.5	12.3	2,208.1	-0.1	1.5	1	1	1
12/16/2022 08:00	-0.5	12.6	2,142.7	-0.2	1.5	1	1	1
12/16/2022 09:00	-0.7	12.7	2,066.1	-0.2	1.4	1	1	1
12/16/2022 10:00	0.4	13.8	1,542.9	0.4	1.1	1	1	0
12/16/2022 11:00	0.3	13.9	1,461.4	0.4	1.0	1	1	0
12/16/2022 12:00	0.2	13.9	1,324.4	0.3	0.9	1	1	0
12/16/2022 13:00	0.3	13.9	1,326.3	0.4	0.9	1	1	0
12/16/2022 14:00	0.4	13.8	1,587.9	0.4	1.1	1	1	0
12/16/2022 15:00	0.1	13.8	1,555.8	0.2	1.1	1	1	1
12/16/2022 16:00	-0.7	12.4	2,147.0	-0.2	1.5	1	1	1
12/16/2022 17:00	-0.5	12.0	2,222.2	-0.1	1.6	1	1	1
12/16/2022 18:00	-0.5	12.4	2,150.0	-0.2	1.5	1	1	1
12/16/2022 19:00	-0.5	12.4	2,159.8	-0.2	1.5	1	1	1
12/16/2022 20:00	-0.4	11.9	2,243.7	-0.1	1.6	1	1	1
12/16/2022 21:00	-0.5	12.2	2,187.6	-0.1	1.5	1	1	1
12/16/2022 22:00	-0.7	12.7	2,087.4	-0.2	1.5	1	1	1
12/16/2022 23:00	-0.9	13.2	1,976.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.0	1,931.4	-0.2	1.4	24 #	24 #	19 #
Minimum:	-1.1	11.9	1,324.4	-0.7	0.9	1	1	0
Maximum:	0.4	13.9	2,243.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	-0.7	12.5	2,146.2	-0.2	1.5	1	1	1
12/17/2022 01:00	-0.7	12.5	2,148.8	-0.2	1.5	1	1	1
12/17/2022 02:00	-0.7	12.5	2,140.6	-0.2	1.5	1	1	1
12/17/2022 03:00	-0.7	12.5	2,153.2	-0.2	1.5	1	1	1
12/17/2022 04:00	-0.7	12.5	2,153.6	-0.2	1.5	1	1	1
12/17/2022 05:00	-0.7	12.5	2,151.4	-0.2	1.5	1	1	1
12/17/2022 06:00	-0.5	12.2	2,233.8	-0.1	1.6	1	1	1
12/17/2022 07:00	-0.7	12.7	2,099.2	-0.2	1.5	1	1	1
12/17/2022 08:00	-0.7	12.5	2,159.2	-0.2	1.5	1	1	1
12/17/2022 09:00	-0.7	12.6	2,117.2	-0.2	1.5	1	1	1
12/17/2022 10:00	-0.8	13.1	1,997.6	-0.5	1.4	1	1	1
12/17/2022 11:00	-0.9	13.2	1,964.4	-0.5	1.4	1	1	1
12/17/2022 12:00	-0.9	13.2	1,960.9	-0.5	1.4	1	1	1
12/17/2022 13:00	-0.8	13.1	1,956.6	-0.5	1.4	1	1	1
12/17/2022 14:00	-0.8	13.0	1,970.0	-0.4	1.4	1	1	1
12/17/2022 15:00	-0.5	12.5	2,100.3	-0.2	1.5	1	1	1
12/17/2022 16:00	-0.4	11.9	2,248.1	-0.1	1.6	1	1	1
12/17/2022 17:00	-0.5	12.0	2,217.8	-0.1	1.6	1	1	1
12/17/2022 18:00	-0.5	12.4	2,137.6	-0.2	1.5	1	1	1
12/17/2022 19:00	-0.5	11.8	2,260.0	-0.1	1.6	1	1	1
12/17/2022 20:00	-0.4	11.8	2,263.2	-0.1	1.6	1	1	1
12/17/2022 21:00	-0.4	11.8	2,264.7	-0.1	1.6	1	1	1
12/17/2022 22:00	-0.4	11.9	2,261.6	-0.1	1.6	1	1	1
12/17/2022 23:00	-0.5	12.3	2,180.2	-0.1	1.5	1	1	1
Average/Sum#:	-0.6	12.5	2,136.9	-0.2	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.8	1,956.6	-0.5	1.4	1	1	1
Maximum:	-0.4	13.2	2,264.7	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	-0.5	12.5	2,132.5	-0.2	1.5	1	1	1
12/18/2022 01:00	-0.7	12.6	2,135.5	-0.2	1.5	1	1	1
12/18/2022 02:00	-0.9	13.0	2,021.6	-0.5	1.4	1	1	1
12/18/2022 03:00	-1.1	13.2	1,975.9	-0.7	1.4	1	1	1
12/18/2022 04:00	-0.7	12.6	2,135.5	-0.2	1.5	1	1	1
12/18/2022 05:00	-0.7	12.5	2,156.2	-0.2	1.5	1	1	1
12/18/2022 06:00	-0.7	12.4	2,171.1	-0.2	1.5	1	1	1
12/18/2022 07:00	-0.7	12.3	2,208.2	-0.2	1.5	1	1	1
12/18/2022 08:00	-0.7	12.6	2,085.2	-0.2	1.5	1	1	1
12/18/2022 09:00	0.3	13.8	1,618.7	0.4	1.1	1	1	0
12/18/2022 10:00	0.3	13.8	1,561.3	0.4	1.1	1	1	0
12/18/2022 11:00	0.3	13.8	1,559.0	0.4	1.1	1	1	0
12/18/2022 12:00	0.2	13.8	1,408.9	0.3	1.0	1	1	0
12/18/2022 13:00	0.2	13.8	1,399.2	0.3	1.0	1	1	0
12/18/2022 14:00	0.3	13.8	1,643.4	0.4	1.2	1	1	0
12/18/2022 15:00	0.1	13.8	1,651.7	0.2	1.2	1	1	1
12/18/2022 16:00	-0.8	12.4	2,130.5	-0.4	1.5	1	1	1
12/18/2022 17:00	-0.5	12.0	2,242.0	-0.1	1.6	1	1	1
12/18/2022 18:00	-0.5	11.9	2,269.4	-0.1	1.6	1	1	1
12/18/2022 19:00	-0.5	11.9	2,270.4	-0.1	1.6	1	1	1
12/18/2022 20:00	-0.7	12.1	2,236.3	-0.2	1.6	1	1	1
12/18/2022 21:00	-0.7	12.3	2,210.2	-0.2	1.5	1	1	1
12/18/2022 22:00	-0.7	12.4	2,198.1	-0.2	1.5	1	1	1
12/18/2022 23:00	-0.9	12.9	2,049.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.4	12.8	1,977.9	-0.1	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.9	1,399.2	-0.7	1.0	1	1	0
Maximum:	0.3	13.8	2,270.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2022 00:00	-0.8	12.6	2,143.3	-0.4	1.5	1	1	1
12/19/2022 01:00	-0.7	12.5	2,153.6	-0.2	1.5	1	1	1
12/19/2022 02:00	-0.7	12.6	2,150.3	-0.2	1.5	1	1	1
12/19/2022 03:00	-0.7	12.6	2,151.5	-0.2	1.5	1	1	1
12/19/2022 04:00	-0.8	12.5	2,181.6	-0.4	1.5	1	1	1
12/19/2022 05:00	-0.7	12.0	2,296.4	-0.2	1.6	1	1	1
12/19/2022 06:00	-0.7	12.0	2,296.2	-0.2	1.6	1	1	1
12/19/2022 07:00	-0.7	12.0	2,295.5	-0.2	1.6	1	1	1
12/19/2022 08:00	-0.7	12.1	2,248.0	-0.2	1.6	1	1	1
12/19/2022 09:00	-0.7	12.1	2,257.3	-0.2	1.6	1	1	1
12/19/2022 10:00	-0.7	12.5	2,169.7	-0.2	1.5	1	1	1
12/19/2022 11:00	-0.7	12.5	2,172.8	-0.2	1.5	1	1	1
12/19/2022 12:00	-0.7	12.5	2,163.1	-0.2	1.5	1	1	1
12/19/2022 13:00	-0.7	12.5	2,154.7	-0.2	1.5	1	1	1
12/19/2022 14:00	-0.7	12.5	2,157.0	-0.2	1.5	1	1	1
12/19/2022 15:00	-0.7	12.3	2,218.7	-0.2	1.6	1	1	1
12/19/2022 16:00	-0.7	12.1	2,259.5	-0.2	1.6	1	1	1
12/19/2022 17:00	-0.7	12.1	2,264.7	-0.2	1.6	1	1	1
12/19/2022 18:00	-0.7	12.1	2,265.6	-0.2	1.6	1	1	1
12/19/2022 19:00	-0.7	12.1	2,264.2	-0.2	1.6	1	1	1
12/19/2022 20:00	-0.7	12.1	2,259.5	-0.2	1.6	1	1	1
12/19/2022 21:00	-0.7	12.1	2,259.7	-0.2	1.6	1	1	1
12/19/2022 22:00	-0.7	12.1	2,264.3	-0.2	1.6	1	1	1
12/19/2022 23:00	-0.7	12.1	2,263.6	-0.2	1.6	1	1	1
Average/Sum#:	-0.7	12.3	2,221.3	-0.2	1.6	24 #	24 #	24 #
Minimum:	-0.8	12.0	2,143.3	-0.4	1.5	1	1	1
Maximum:	-0.7	12.6	2,296.4	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	-0.7	12.5	2,172.5	-0.2	1.5	1	1	1
12/20/2022 01:00	-0.7	12.5	2,169.3	-0.2	1.5	1	1	1
12/20/2022 02:00	-0.7	12.5	2,173.2	-0.2	1.5	1	1	1
12/20/2022 03:00	-0.7	12.5	2,179.2	-0.2	1.5	1	1	1
12/20/2022 04:00	-0.7	12.5	2,184.8	-0.2	1.5	1	1	1
12/20/2022 05:00	-0.7	12.5	2,186.9	-0.2	1.5	1	1	1
12/20/2022 06:00	-0.7	12.1	2,279.9	-0.2	1.6	1	1	1
12/20/2022 07:00	-0.7	12.1	2,273.5	-0.2	1.6	1	1	1
12/20/2022 08:00	-0.7	12.5	2,163.7	-0.2	1.5	1	1	1
12/20/2022 09:00	-0.7	12.5	2,161.4	-0.2	1.5	1	1	1
12/20/2022 10:00	-0.7	12.6	2,120.5	-0.2	1.5	1	1	1
12/20/2022 11:00	-0.7	12.7	2,088.3	-0.2	1.5	1	1	1
12/20/2022 12:00	-1.1	13.2	1,961.1	-0.7	1.4	1	1	1
12/20/2022 13:00	-1.1	13.2	1,963.4	-0.7	1.4	1	1	1
12/20/2022 14:00	-1.1	13.2	1,958.0	-0.7	1.4	1	1	1
12/20/2022 15:00	-0.9	12.9	2,030.5	-0.5	1.4	1	1	1
12/20/2022 16:00	-0.5	12.3	2,184.0	-0.1	1.5	1	1	1
12/20/2022 17:00	-0.5	12.0	2,248.1	-0.1	1.6	1	1	1
12/20/2022 18:00	-0.5	12.0	2,246.6	-0.1	1.6	1	1	1
12/20/2022 19:00	-0.5	12.0	2,239.7	-0.1	1.6	1	1	1
12/20/2022 20:00	-0.5	12.0	2,241.8	-0.1	1.6	1	1	1
12/20/2022 21:00	-0.5	12.4	2,154.7	-0.2	1.5	1	1	1
12/20/2022 22:00	-0.5	12.4	2,156.3	-0.2	1.5	1	1	1
12/20/2022 23:00	-0.5	12.2	2,209.3	-0.1	1.5	1	1	1
Average/Sum#:	-0.7	12.5	2,156.1	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.1	12.0	1,958.0	-0.7	1.4	1	1	1
Maximum:	-0.5	13.2	2,279.9	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	-0.5	11.9	2,265.8	-0.1	1.6	1	1	1
12/21/2022 01:00	-0.5	11.9	2,263.2	-0.1	1.6	1	1	1
12/21/2022 02:00	-0.5	12.0	2,261.3	-0.1	1.6	1	1	1
12/21/2022 03:00	-0.5	12.0	2,267.1	-0.1	1.6	1	1	1
12/21/2022 04:00	-0.5	12.0	2,267.5	-0.1	1.6	1	1	1
12/21/2022 05:00	-0.5	12.0	2,262.9	-0.1	1.6	1	1	1
12/21/2022 06:00	-0.5	12.0	2,262.6	-0.1	1.6	1	1	1
12/21/2022 07:00	-0.5	12.0	2,260.4	-0.1	1.6	1	1	1
12/21/2022 08:00	-0.5	12.1	2,249.7	-0.1	1.6	1	1	1
12/21/2022 09:00	-0.7	12.1	2,235.5	-0.2	1.6	1	1	1
12/21/2022 10:00	-0.5	12.1	2,227.8	-0.1	1.6	1	1	1
12/21/2022 11:00	-0.5	12.2	2,195.0	-0.1	1.5	1	1	1
12/21/2022 12:00	-0.5	12.1	2,213.1	-0.1	1.5	1	1	1
12/21/2022 13:00	-0.5	12.1	2,208.4	-0.1	1.5	1	1	1
12/21/2022 14:00	-0.5	12.4	2,133.5	-0.2	1.5	1	1	1
12/21/2022 15:00	-0.5	12.1	2,205.0	-0.1	1.5	1	1	1
12/21/2022 16:00	-0.5	12.0	2,227.3	-0.1	1.6	1	1	1
12/21/2022 17:00	-0.5	12.0	2,234.1	-0.1	1.6	1	1	1
12/21/2022 18:00	-0.5	12.0	2,239.9	-0.1	1.6	1	1	1
12/21/2022 19:00	-0.5	12.0	2,241.3	-0.1	1.6	1	1	1
12/21/2022 20:00	-0.5	12.0	2,238.6	-0.1	1.6	1	1	1
12/21/2022 21:00	-0.5	12.0	2,238.6	-0.1	1.6	1	1	1
12/21/2022 22:00	-0.5	12.1	2,239.1	-0.1	1.6	1	1	1
12/21/2022 23:00	-0.7	12.1	2,239.7	-0.2	1.6	1	1	1
Average/Sum#:	-0.5	12.1	2,236.6	-0.1	1.6	24 #	24 #	24 #
Minimum:	-0.7	11.9	2,133.5	-0.2	1.5	1	1	1
Maximum:	-0.5	12.4	2,267.5	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2022 00:00	-0.7	12.3	2,179.5	-0.2	1.5	1	1	1
12/22/2022 01:00	-1.1	13.1	1,980.0	-0.7	1.4	1	1	1
12/22/2022 02:00	-1.4	13.2	1,961.4	-0.9	1.4	1	1	1
12/22/2022 03:00	-1.4	13.2	1,964.7	-0.9	1.4	1	1	1
12/22/2022 04:00	-1.1	12.8	2,094.8	-0.7	1.5	1	1	1
12/22/2022 05:00	-0.8	12.1	2,222.3	-0.4	1.6	1	1	1
12/22/2022 06:00	-0.7	12.1	2,261.4	-0.2	1.6	1	1	1
12/22/2022 07:00	-0.7	12.1	2,259.7	-0.2	1.6	1	1	1
12/22/2022 08:00	-0.7	12.1	2,238.6	-0.2	1.6	1	1	1
12/22/2022 09:00	-0.7	12.5	2,150.2	-0.2	1.5	1	1	1
12/22/2022 10:00	-0.7	12.6	2,145.1	-0.2	1.5	1	1	1
12/22/2022 11:00	-0.7	12.5	2,140.3	-0.2	1.5	1	1	1
12/22/2022 12:00	-0.7	12.5	2,137.6	-0.2	1.5	1	1	1
12/22/2022 13:00	-0.7	12.5	2,137.2	-0.2	1.5	1	1	1
12/22/2022 14:00	-0.7	12.5	2,144.7	-0.2	1.5	1	1	1
12/22/2022 15:00	-0.7	12.2	2,203.3	-0.2	1.5	1	1	1
12/22/2022 16:00	-0.7	12.2	2,198.4	-0.2	1.5	1	1	1
12/22/2022 17:00	-0.7	12.0	2,238.8	-0.2	1.6	1	1	1
12/22/2022 18:00	-0.7	12.0	2,242.2	-0.2	1.6	1	1	1
12/22/2022 19:00	-0.7	12.0	2,246.6	-0.2	1.6	1	1	1
12/22/2022 20:00	-0.7	12.0	2,243.5	-0.2	1.6	1	1	1
12/22/2022 21:00	-0.7	12.0	2,241.4	-0.2	1.6	1	1	1
12/22/2022 22:00	-0.7	12.2	2,200.2	-0.2	1.5	1	1	1
12/22/2022 23:00	-0.8	12.8	2,068.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.8	12.4	2,162.5	-0.3	1.5	24 #	24 #	24 #
Minimum:	-1.4	12.0	1,961.4	-0.9	1.4	1	1	1
Maximum:	-0.7	13.2	2,261.4	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	-0.7	12.2	2,215.5	-0.2	1.6	1	1	1
12/23/2022 01:00	-0.7	12.0	2,252.2	-0.2	1.6	1	1	1
12/23/2022 02:00	-0.7	12.0	2,250.3	-0.2	1.6	1	1	1
12/23/2022 03:00	-0.7	12.0	2,245.6	-0.2	1.6	1	1	1
12/23/2022 04:00	-0.7	12.0	2,248.2	-0.2	1.6	1	1	1
12/23/2022 05:00	-0.7	12.0	2,241.2	-0.2	1.6	1	1	1
12/23/2022 06:00	-0.7	12.0	2,250.7	-0.2	1.6	1	1	1
12/23/2022 07:00	-0.7	12.1	2,232.9	-0.2	1.6	1	1	1
12/23/2022 08:00	-0.7	12.3	2,172.6	-0.2	1.5	1	1	1
12/23/2022 09:00	-0.7	12.3	2,163.4	-0.2	1.5	1	1	1
12/23/2022 10:00	-0.7	12.5	2,122.9	-0.2	1.5	1	1	1
12/23/2022 11:00	-0.5	12.4	2,124.2	-0.2	1.5	1	1	1
12/23/2022 12:00	-0.8	12.8	2,017.4	-0.4	1.4	1	1	1
12/23/2022 13:00	-0.9	13.1	1,950.0	-0.5	1.4	1	1	1
12/23/2022 14:00	-1.1	13.1	1,941.4	-0.7	1.4	1	1	1
12/23/2022 15:00	-0.8	12.7	2,049.7	-0.4	1.4	1	1	1
12/23/2022 16:00	-0.5	11.9	2,228.2	-0.1	1.6	1	1	1
12/23/2022 17:00	-0.5	11.9	2,230.8	-0.1	1.6	1	1	1
12/23/2022 18:00	-0.5	11.9	2,231.0	-0.1	1.6	1	1	1
12/23/2022 19:00	-0.4	12.0	2,229.3	-0.1	1.6	1	1	1
12/23/2022 20:00	-0.4	12.0	2,230.7	-0.1	1.6	1	1	1
12/23/2022 21:00	-0.4	11.9	2,234.3	-0.1	1.6	1	1	1
12/23/2022 22:00	-0.5	11.9	2,233.5	-0.1	1.6	1	1	1
12/23/2022 23:00	-0.5	12.0	2,225.6	-0.1	1.6	1	1	1
Average/Sum#:	-0.6	12.2	2,180.1	-0.2	1.6	24 #	24 #	24 #
Minimum:	-1.1	11.9	1,941.4	-0.7	1.4	1	1	1
Maximum:	-0.4	13.1	2,252.2	-0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	-0.5	12.4	2,119.0	-0.2	1.5	1	1	1
12/24/2022 01:00	-0.5	12.5	2,113.9	-0.2	1.5	1	1	1
12/24/2022 02:00	-0.9	13.1	1,961.4	-0.5	1.4	1	1	1
12/24/2022 03:00	-1.1	13.2	1,955.3	-0.7	1.4	1	1	1
12/24/2022 04:00	-1.1	13.2	1,953.0	-0.7	1.4	1	1	1
12/24/2022 05:00	-1.1	13.2	1,951.1	-0.7	1.4	1	1	1
12/24/2022 06:00	-1.1	13.1	1,974.8	-0.7	1.4	1	1	1
12/24/2022 07:00	-0.9	13.0	1,998.9	-0.5	1.4	1	1	1
12/24/2022 08:00	-0.8	13.3	1,833.9	-0.5	1.3	1	1	1
12/24/2022 09:00	0.1	13.8	1,320.7	0.2	0.9	1	1	0
12/24/2022 10:00	0.3	13.8	1,559.7	0.4	1.1	1	1	0
12/24/2022 11:00	0.3	13.8	1,555.6	0.4	1.1	1	1	0
12/24/2022 12:00	0.3	13.8	1,554.9	0.4	1.1	1	1	0
12/24/2022 13:00	0.4	13.8	1,558.8	0.4	1.1	1	1	0
12/24/2022 14:00	0.4	13.8	1,730.9	0.4	1.2	1	1	0
12/24/2022 15:00	0.4	13.8	1,739.5	0.4	1.2	1	1	0
12/24/2022 16:00	0.1	13.8	1,594.1	0.2	1.1	1	1	1
12/24/2022 17:00	-1.1	13.1	1,944.9	-0.7	1.4	1	1	1
12/24/2022 18:00	-0.9	13.1	1,943.7	-0.5	1.4	1	1	1
12/24/2022 19:00	-0.9	13.1	1,944.1	-0.5	1.4	1	1	1
12/24/2022 20:00	-0.9	13.1	1,947.7	-0.5	1.4	1	1	1
12/24/2022 21:00	-0.9	13.1	1,944.2	-0.5	1.4	1	1	1
12/24/2022 22:00	-1.1	13.2	1,946.9	-0.7	1.4	1	1	1
12/24/2022 23:00	-1.1	13.2	1,949.6	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.3	1,837.4	-0.3	1.3	24 #	24 #	17 #
Minimum:	-1.1	12.4	1,320.7	-0.7	0.9	1	1	0
Maximum:	0.4	13.8	2,119.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	-1.1	13.2	1,930.0	-0.7	1.4	1	1	1
12/25/2022 01:00	0.0	15.6	591.4	0.0	0.4	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.6	14.4	1,260.7	-0.4	0.9	2 #	1 #	1 #
Minimum:	-1.1	13.2	591.4	-0.7	0.4	0	0	0
Maximum:	0.0	15.6	1,930.0	0.0	1.4	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.0	17.6	332.1	0.0	0.2	1	0	0
12/26/2022 01:00	0.0	15.1	969.8	0.0	0.7	1	0	0
12/26/2022 02:00	0.2	13.7	1,715.8	0.3	1.2	1	1	0
12/26/2022 03:00	0.2	13.7	1,736.0	0.3	1.2	1	1	0
12/26/2022 04:00	0.2	13.7	1,735.7	0.3	1.2	1	1	0
12/26/2022 05:00	0.2	13.7	1,750.8	0.3	1.2	1	1	0
12/26/2022 06:00	0.2	13.7	1,750.6	0.3	1.2	1	1	0
12/26/2022 07:00	0.2	13.7	1,742.3	0.3	1.2	1	1	0
12/26/2022 08:00	0.2	13.7	1,748.4	0.3	1.2	1	1	0
12/26/2022 09:00	0.2	13.8	1,563.8	0.3	1.1	1	1	0
12/26/2022 10:00	0.2	13.8	1,559.4	0.3	1.1	1	1	0
12/26/2022 11:00	0.2	13.8	1,550.2	0.3	1.1	1	1	0
12/26/2022 12:00	0.1	13.8	1,541.0	0.2	1.1	1	1	0
12/26/2022 13:00	0.2	13.8	1,561.8	0.3	1.1	1	1	0
12/26/2022 14:00	0.2	13.7	1,623.4	0.3	1.1	1	1	0
12/26/2022 15:00	0.2	13.7	1,751.1	0.3	1.2	1	1	0
12/26/2022 16:00	-0.1	13.7	1,782.9	0.1	1.2	1	1	1
12/26/2022 17:00	-1.2	12.5	2,103.9	-0.7	1.5	1	1	1
12/26/2022 18:00	-0.8	12.3	2,145.3	-0.4	1.5	1	1	1
12/26/2022 19:00	-1.1	12.9	2,004.1	-0.7	1.4	1	1	1
12/26/2022 20:00	-1.1	13.0	1,990.7	-0.7	1.4	1	1	1
12/26/2022 21:00	-1.4	13.1	1,960.1	-0.9	1.4	1	1	1
12/26/2022 22:00	-1.4	13.1	1,936.0	-0.9	1.4	1	1	1
12/26/2022 23:00	0.0	15.6	602.1	0.0	0.4	1	0	0
Average/Sum#:	-0.2	13.8	1,631.6	0.0	1.1	24 #	21 #	7 #
Minimum:	-1.4	12.3	332.1	-0.9	0.2	1	0	0
Maximum:	0.2	17.6	2,145.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 05:00	0.0	17.0	482.2	0.0	0.3	1	0	0
12/27/2022 06:00	0.0	14.3	1,185.6	0.0	0.8	1	0	0
12/27/2022 07:00	0.3	13.7	1,737.9	0.4	1.2	1	1	0
12/27/2022 08:00	-0.1	13.6	1,714.6	0.1	1.2	1	1	1
12/27/2022 09:00	-1.4	12.9	1,950.3	-0.8	1.4	1	1	1
12/27/2022 10:00	-1.1	12.9	1,947.7	-0.7	1.4	1	1	1
12/27/2022 11:00	-0.8	12.9	1,950.7	-0.4	1.4	1	1	1
12/27/2022 12:00	-0.7	12.9	1,949.0	-0.4	1.4	1	1	1
12/27/2022 13:00	-0.7	12.9	1,947.5	-0.4	1.4	1	1	1
12/27/2022 14:00	-0.7	12.9	1,948.0	-0.4	1.4	1	1	1
12/27/2022 15:00	-0.7	12.9	1,949.1	-0.4	1.4	1	1	1
12/27/2022 16:00	-0.8	12.9	1,950.9	-0.4	1.4	1	1	1
12/27/2022 17:00	-1.1	13.0	1,941.7	-0.7	1.4	1	1	1
12/27/2022 18:00	-1.1	13.1	1,938.3	-0.7	1.4	1	1	1
12/27/2022 19:00	-1.1	13.1	1,941.5	-0.7	1.4	1	1	1
12/27/2022 20:00	-1.2	13.1	1,950.2	-0.8	1.4	1	1	1
12/27/2022 21:00	-1.1	13.1	1,946.3	-0.7	1.4	1	1	1
12/27/2022 22:00	-1.1	13.1	1,927.1	-0.7	1.3	1	1	1
12/27/2022 23:00	0.2	13.9	1,398.6	0.3	1.0	1	1	0
Average/Sum#:	-0.7	13.4	1,776.7	-0.4	1.3	19 #	17 #	15 #
Minimum:	-1.4	12.9	482.2	-0.8	0.3	0	0	0
Maximum:	0.3	17.0	1,950.9	0.4	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.3	13.8	1,551.1	0.4	1.1	1	1	0
12/28/2022 01:00	0.2	13.8	1,473.8	0.3	1.0	1	1	0
12/28/2022 02:00	0.2	13.8	1,538.3	0.3	1.1	1	1	0
12/28/2022 03:00	0.2	13.8	1,537.5	0.3	1.1	1	1	0
12/28/2022 04:00	0.2	13.8	1,543.0	0.3	1.1	1	1	0
12/28/2022 05:00	0.3	13.7	1,735.6	0.4	1.2	1	1	0
12/28/2022 06:00	0.3	13.7	1,753.7	0.4	1.2	1	1	0
12/28/2022 07:00	0.3	13.7	1,756.5	0.4	1.2	1	1	0
12/28/2022 08:00	0.3	13.7	1,732.6	0.4	1.2	1	1	0
12/28/2022 09:00	0.3	13.7	1,723.8	0.4	1.2	1	1	0
12/28/2022 10:00	0.3	13.8	1,562.0	0.4	1.1	1	1	0
12/28/2022 11:00	0.3	13.8	1,577.9	0.4	1.1	1	1	0
12/28/2022 12:00	0.3	13.8	1,560.7	0.4	1.1	1	1	0
12/28/2022 13:00	0.3	13.8	1,535.3	0.4	1.1	1	1	0
12/28/2022 14:00	0.3	13.8	1,554.0	0.4	1.1	1	1	0
12/28/2022 15:00	-0.1	13.7	1,601.3	0.1	1.1	1	1	1
12/28/2022 16:00	-1.1	12.5	2,087.1	-0.5	1.5	1	1	1
12/28/2022 17:00	-0.9	13.0	1,974.8	-0.5	1.4	1	1	1
12/28/2022 18:00	-1.1	13.1	1,954.9	-0.7	1.4	1	1	1
12/28/2022 19:00	-1.1	13.1	1,956.3	-0.7	1.4	1	1	1
12/28/2022 20:00	-1.2	13.1	1,955.8	-0.8	1.4	1	1	1
12/28/2022 21:00	-1.1	13.0	1,967.9	-0.7	1.4	1	1	1
12/28/2022 22:00	-1.2	13.1	1,952.9	-0.8	1.4	1	1	1
12/28/2022 23:00	-1.2	13.1	1,957.6	-0.8	1.4	1	1	1
Average/Sum#:	-0.2	13.5	1,731.0	0.0	1.2	24 #	24 #	9 #
Minimum:	-1.2	12.5	1,473.8	-0.8	1.0	1	1	0
Maximum:	0.3	13.8	2,087.1	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2022 00:00	-1.2	13.1	1,953.1	-0.8	1.4	1	1	1
12/29/2022 01:00	-1.2	13.1	1,953.2	-0.8	1.4	1	1	1
12/29/2022 02:00	-1.2	13.1	1,953.7	-0.8	1.4	1	1	1
12/29/2022 03:00	-1.2	13.1	1,955.0	-0.8	1.4	1	1	1
12/29/2022 04:00	-1.2	13.1	1,957.5	-0.8	1.4	1	1	1
12/29/2022 05:00	-0.9	12.7	2,029.7	-0.5	1.4	1	1	1
12/29/2022 06:00	-0.9	12.8	2,039.0	-0.5	1.4	1	1	1
12/29/2022 07:00	-0.9	12.8	2,042.7	-0.5	1.4	1	1	1
12/29/2022 08:00	-0.8	12.2	2,185.5	-0.4	1.5	1	1	1
12/29/2022 09:00	-0.7	11.9	2,234.1	-0.2	1.6	1	1	1
12/29/2022 10:00	-0.7	12.3	2,142.2	-0.2	1.5	1	1	1
12/29/2022 11:00	-0.9	12.9	2,012.8	-0.5	1.4	1	1	1
12/29/2022 12:00	-1.1	13.0	1,975.6	-0.7	1.4	1	1	1
12/29/2022 13:00	-1.4	13.1	1,962.0	-0.9	1.4	1	1	1
12/29/2022 14:00	-1.2	13.0	1,971.1	-0.8	1.4	1	1	1
12/29/2022 15:00	-1.2	13.0	1,977.5	-0.8	1.4	1	1	1
12/29/2022 16:00	-1.1	12.6	2,082.3	-0.7	1.5	1	1	1
12/29/2022 17:00	-0.7	12.3	2,149.3	-0.2	1.5	1	1	1
12/29/2022 18:00	-0.8	12.6	2,062.6	-0.4	1.4	1	1	1
12/29/2022 19:00	-1.4	13.1	1,956.5	-0.9	1.4	1	1	1
12/29/2022 20:00	-1.4	13.1	1,963.5	-0.9	1.4	1	1	1
12/29/2022 21:00	-1.2	13.0	1,973.9	-0.8	1.4	1	1	1
12/29/2022 22:00	-1.4	13.0	1,958.1	-0.8	1.4	1	1	1
12/29/2022 23:00	-1.4	13.1	1,930.3	-0.9	1.4	1	1	1
Average/Sum#:	-1.1	12.8	2,017.6	-0.7	1.4	24 #	24 #	24 #
Minimum:	-1.4	11.9	1,930.3	-0.9	1.4	1	1	1
Maximum:	-0.7	13.1	2,234.1	-0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	0.0	15.6	627.2	0.0	0.4	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.6	627.2	0.0	0.4	1 #	0 #	0 #
Minimum:	0.0	15.6	627.2	0.0	0.4	0	0	0
Maximum:	0.0	15.6	627.2	0.0	0.4	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.2	12.1	2,166.3	0.4	0.6	1	1	1
10/01/2022 01:00	0.0	14.2	1,202.0	0.0	0.4	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	17.7	308.0	0.0	0.1	1	0	0
10/01/2022 13:00	0.0	17.2	376.4	0.0	0.1	1	0	0
10/01/2022 14:00	0.0	15.5	875.8	0.0	0.3	1	0	0
10/01/2022 15:00	0.4	14.1	1,414.5	0.4	0.4	1	1	0
10/01/2022 16:00	0.1	13.6	1,717.8	0.2	0.5	1	1	1
10/01/2022 17:00	0.1	11.6	2,258.0	0.2	0.7	1	1	1
10/01/2022 18:00	0.1	11.9	2,188.3	0.2	0.7	1	1	1
10/01/2022 19:00	-0.2	12.6	2,026.7	0.1	0.6	1	1	1
10/01/2022 20:00	0.1	11.9	2,210.8	0.2	0.7	1	1	1
10/01/2022 21:00	0.1	12.5	1,932.3	0.2	0.6	1	1	1
10/01/2022 22:00	0.4	13.8	1,569.8	0.4	0.5	1	1	0
10/01/2022 23:00	0.0	15.6	630.9	0.0	0.2	1	0	0
Average/Sum#:	0.1	13.9	1,491.3	0.2	0.5	14 #	9 #	8 #
Minimum:	-0.2	11.6	308.0	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,258.0	0.4	0.7	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	17.7	311.4	0.0	0.1	1	0	0
10/02/2022 12:00	0.0	17.2	404.4	0.0	0.1	1	0	0
10/02/2022 13:00	0.0	15.6	880.7	0.0	0.3	1	0	0
10/02/2022 14:00	0.4	13.8	1,730.7	0.4	0.5	1	1	0
10/02/2022 15:00	-0.2	13.2	1,719.8	-0.1	0.5	1	1	1
10/02/2022 16:00	-0.2	12.0	2,184.2	0.1	0.7	1	1	1
10/02/2022 17:00	0.1	11.6	2,265.0	0.2	0.7	1	1	1
10/02/2022 18:00	0.1	11.6	2,270.6	0.2	0.7	1	1	1
10/02/2022 19:00	0.2	11.6	2,272.9	0.4	0.7	1	1	1
10/02/2022 20:00	0.2	11.6	2,274.3	0.4	0.7	1	1	1
10/02/2022 21:00	-0.1	12.4	2,098.7	0.2	0.6	1	1	1
10/02/2022 22:00	0.1	12.7	1,912.0	0.2	0.6	1	1	1
10/02/2022 23:00	0.4	13.9	1,550.6	0.4	0.5	1	1	0
Average/Sum#:	0.1	13.5	1,682.7	0.2	0.5	13 #	10 #	8 #
Minimum:	-0.2	11.6	311.4	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	2,274.3	0.4	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.4	13.9	1,546.4	0.4	0.5	1	1	0
10/03/2022 01:00	0.4	13.9	1,550.3	0.4	0.5	1	1	0
10/03/2022 02:00	0.4	13.8	1,784.2	0.4	0.5	1	1	0
10/03/2022 03:00	0.4	13.9	1,582.9	0.4	0.5	1	1	0
10/03/2022 04:00	0.4	13.9	1,715.7	0.4	0.5	1	1	0
10/03/2022 05:00	0.4	13.9	1,713.6	0.4	0.5	1	1	0
10/03/2022 06:00	0.4	13.9	1,710.7	0.4	0.5	1	1	0
10/03/2022 07:00	0.4	13.9	1,711.1	0.4	0.5	1	1	0
10/03/2022 08:00	0.4	13.9	1,717.3	0.4	0.5	1	1	0
10/03/2022 09:00	0.4	13.9	1,722.1	0.4	0.5	1	1	0
10/03/2022 10:00	0.4	13.9	1,724.5	0.4	0.5	1	1	0
10/03/2022 11:00	0.4	13.9	1,724.7	0.4	0.5	1	1	0
10/03/2022 12:00	0.4	13.9	1,724.6	0.4	0.5	1	1	0
10/03/2022 13:00	0.4	13.9	1,725.3	0.4	0.5	1	1	0
10/03/2022 14:00	0.4	13.9	1,716.6	0.4	0.5	1	1	0
10/03/2022 15:00	0.2	13.8	1,754.9	0.4	0.5	1	1	1
10/03/2022 16:00	-0.2	12.5	2,060.1	0.1	0.6	1	1	1
10/03/2022 17:00	0.1	12.0	2,170.1	0.2	0.7	1	1	1
10/03/2022 18:00	0.2	11.8	2,202.2	0.4	0.7	1	1	1
10/03/2022 19:00	0.2	12.0	2,175.9	0.4	0.7	1	1	1
10/03/2022 20:00	0.2	11.9	2,186.8	0.4	0.7	1	1	1
10/03/2022 21:00	0.2	12.0	2,178.8	0.4	0.7	1	1	1
10/03/2022 22:00	0.2	12.2	2,156.6	0.4	0.6	1	1	1
10/03/2022 23:00	0.2	12.1	2,174.0	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.3	1,851.2	0.4	0.6	24 #	24 #	9 #
Minimum:	-0.2	11.8	1,546.4	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,202.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	0.2	12.2	2,156.2	0.4	0.6	1	1	1
10/04/2022 01:00	0.2	12.2	2,159.9	0.4	0.6	1	1	1
10/04/2022 02:00	0.2	12.2	2,158.6	0.4	0.6	1	1	1
10/04/2022 03:00	0.2	12.1	2,168.6	0.4	0.7	1	1	1
10/04/2022 04:00	0.2	12.1	2,182.7	0.4	0.7	1	1	1
10/04/2022 05:00	0.4	12.0	2,216.4	0.5	0.7	1	1	1
10/04/2022 06:00	0.2	12.3	2,179.8	0.4	0.7	1	1	1
10/04/2022 07:00	0.2	12.7	2,043.5	0.4	0.6	1	1	1
10/04/2022 08:00	0.4	13.8	1,586.2	0.4	0.5	1	1	0
10/04/2022 09:00	0.4	13.9	1,548.5	0.4	0.5	1	1	0
10/04/2022 10:00	0.6	0.0	1,554.2	0.6	0.5	1	1	0
10/04/2022 11:00	0.4	13.9	1,562.4	0.4	0.5	1	1	0
10/04/2022 12:00	0.4	13.9	1,707.0	0.4	0.5	1	1	0
10/04/2022 13:00	-0.1	13.8	1,733.0	0.1	0.5	1	1	1
10/04/2022 14:00	-0.2	12.7	2,019.5	0.1	0.6	1	1	1
10/04/2022 15:00	0.1	12.1	2,136.1	0.2	0.6	1	1	1
10/04/2022 16:00	0.1	12.1	2,128.5	0.2	0.6	1	1	1
10/04/2022 17:00	0.2	12.1	2,140.4	0.4	0.6	1	1	1
10/04/2022 18:00	0.2	12.0	2,169.9	0.4	0.7	1	1	1
10/04/2022 19:00	0.2	11.9	2,188.2	0.4	0.7	1	1	1
10/04/2022 20:00	0.4	11.7	2,242.8	0.5	0.7	1	1	1
10/04/2022 21:00	0.4	11.9	2,190.4	0.5	0.7	1	1	1
10/04/2022 22:00	0.2	12.0	2,179.1	0.4	0.7	1	1	1
10/04/2022 23:00	0.2	12.2	2,143.7	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.5	2,020.7	0.4	0.6	24 #	24 #	19 #
Minimum:	-0.2	11.7	1,548.5	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,242.8	0.5	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	0.2	12.2	2,136.6	0.4	0.6	1	1	1
10/05/2022 01:00	0.1	12.8	1,995.6	0.2	0.6	1	1	1
10/05/2022 02:00	-0.1	13.0	1,971.2	0.1	0.6	1	1	1
10/05/2022 03:00	0.1	12.5	2,088.5	0.2	0.6	1	1	1
10/05/2022 04:00	0.2	12.3	2,117.7	0.4	0.6	1	1	1
10/05/2022 05:00	0.4	12.0	2,204.8	0.5	0.7	1	1	1
10/05/2022 06:00	0.4	12.1	2,206.4	0.5	0.7	1	1	1
10/05/2022 07:00	0.1	12.9	1,980.3	0.2	0.6	1	1	1
10/05/2022 08:00	0.5	13.9	1,702.3	0.5	0.5	1	1	0
10/05/2022 09:00	0.4	13.9	1,667.6	0.4	0.5	1	1	0
10/05/2022 10:00	0.4	13.9	1,693.9	0.4	0.5	1	1	0
10/05/2022 11:00	0.4	13.9	1,706.3	0.4	0.5	1	1	0
10/05/2022 12:00	0.2	13.8	1,723.0	0.4	0.5	1	1	1
10/05/2022 13:00	-0.1	12.5	2,064.2	0.1	0.6	1	1	1
10/05/2022 14:00	0.2	11.9	2,181.4	0.4	0.7	1	1	1
10/05/2022 15:00	0.2	12.1	2,135.0	0.4	0.6	1	1	1
10/05/2022 16:00	0.2	12.0	2,157.2	0.4	0.6	1	1	1
10/05/2022 17:00	0.2	11.8	2,196.1	0.4	0.7	1	1	1
10/05/2022 18:00	0.4	11.7	2,231.0	0.5	0.7	1	1	1
10/05/2022 19:00	0.4	11.7	2,237.6	0.5	0.7	1	1	1
10/05/2022 20:00	0.2	11.9	2,188.3	0.4	0.7	1	1	1
10/05/2022 21:00	0.4	11.7	2,234.5	0.5	0.7	1	1	1
10/05/2022 22:00	0.2	12.1	2,163.4	0.4	0.6	1	1	1
10/05/2022 23:00	0.2	12.1	2,172.8	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,048.2	0.4	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.7	1,667.6	0.1	0.5	1	1	0
Maximum:	0.5	13.9	2,237.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	0.2	12.2	2,162.3	0.4	0.6	1	1	1
10/06/2022 01:00	0.2	12.1	2,166.4	0.4	0.6	1	1	1
10/06/2022 02:00	0.2	12.1	2,164.4	0.4	0.6	1	1	1
10/06/2022 03:00	0.2	12.2	2,142.9	0.4	0.6	1	1	1
10/06/2022 04:00	0.4	12.0	2,184.4	0.5	0.7	1	1	1
10/06/2022 05:00	0.4	11.8	2,246.2	0.5	0.7	1	1	1
10/06/2022 06:00	0.4	11.9	2,233.3	0.5	0.7	1	1	1
10/06/2022 07:00	0.2	12.3	2,131.1	0.4	0.6	1	1	1
10/06/2022 08:00	0.1	12.5	2,082.8	0.2	0.6	1	1	1
10/06/2022 09:00	0.1	12.6	2,065.4	0.2	0.6	1	1	1
10/06/2022 10:00	0.1	12.5	2,076.7	0.2	0.6	1	1	1
10/06/2022 11:00	0.1	12.3	2,113.6	0.2	0.6	1	1	1
10/06/2022 12:00	0.2	12.1	2,142.5	0.4	0.6	1	1	1
10/06/2022 13:00	0.4	11.9	2,198.7	0.5	0.7	1	1	1
10/06/2022 14:00	0.4	11.8	2,207.0	0.5	0.7	1	1	1
10/06/2022 15:00	0.2	12.0	2,158.9	0.4	0.6	1	1	1
10/06/2022 16:00	0.2	11.9	2,197.5	0.4	0.7	1	1	1
10/06/2022 17:00	0.4	11.7	2,245.6	0.5	0.7	1	1	1
10/06/2022 18:00	0.4	11.7	2,241.8	0.5	0.7	1	1	1
10/06/2022 19:00	0.4	11.7	2,251.9	0.5	0.7	1	1	1
10/06/2022 20:00	0.4	11.7	2,253.7	0.5	0.7	1	1	1
10/06/2022 21:00	0.4	11.8	2,243.5	0.5	0.7	1	1	1
10/06/2022 22:00	0.4	12.0	2,189.6	0.5	0.7	1	1	1
10/06/2022 23:00	0.2	12.1	2,168.9	0.4	0.7	1	1	1
Average/Sum#:	0.3	12.0	2,177.9	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.7	2,065.4	0.2	0.6	1	1	1
Maximum:	0.4	12.6	2,253.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	0.2	12.3	2,144.9	0.4	0.6	1	1	1
10/07/2022 01:00	0.2	12.2	2,158.5	0.4	0.6	1	1	1
10/07/2022 02:00	0.2	12.3	2,141.1	0.4	0.6	1	1	1
10/07/2022 03:00	0.2	12.4	2,115.0	0.4	0.6	1	1	1
10/07/2022 04:00	0.2	12.2	2,155.3	0.4	0.6	1	1	1
10/07/2022 05:00	0.2	12.1	2,191.5	0.4	0.7	1	1	1
10/07/2022 06:00	0.4	12.1	2,204.8	0.5	0.7	1	1	1
10/07/2022 07:00	0.2	12.4	2,111.6	0.4	0.6	1	1	1
10/07/2022 08:00	0.1	12.7	2,031.6	0.2	0.6	1	1	1
10/07/2022 09:00	0.2	12.3	2,132.5	0.4	0.6	1	1	1
10/07/2022 10:00	0.2	12.3	2,127.2	0.4	0.6	1	1	1
10/07/2022 11:00	0.2	12.3	2,117.0	0.4	0.6	1	1	1
10/07/2022 12:00	0.2	12.0	2,174.6	0.4	0.7	1	1	1
10/07/2022 13:00	0.2	12.1	2,147.2	0.4	0.6	1	1	1
10/07/2022 14:00	0.2	11.9	2,194.6	0.4	0.7	1	1	1
10/07/2022 15:00	0.4	11.8	2,203.8	0.5	0.7	1	1	1
10/07/2022 16:00	0.2	11.9	2,188.4	0.4	0.7	1	1	1
10/07/2022 17:00	0.4	11.7	2,238.4	0.5	0.7	1	1	1
10/07/2022 18:00	0.4	11.7	2,248.1	0.5	0.7	1	1	1
10/07/2022 19:00	0.4	11.7	2,254.3	0.5	0.7	1	1	1
10/07/2022 20:00	0.4	11.7	2,259.1	0.5	0.7	1	1	1
10/07/2022 21:00	0.4	11.7	2,262.1	0.5	0.7	1	1	1
10/07/2022 22:00	0.4	11.7	2,256.4	0.5	0.7	1	1	1
10/07/2022 23:00	0.4	12.0	2,191.4	0.5	0.7	1	1	1
Average/Sum#:	0.3	12.1	2,177.1	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.7	2,031.6	0.2	0.6	1	1	1
Maximum:	0.4	12.7	2,262.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	0.2	12.1	2,179.0	0.4	0.7	1	1	1
10/08/2022 01:00	0.2	12.1	2,173.7	0.4	0.7	1	1	1
10/08/2022 02:00	0.2	12.2	2,165.8	0.4	0.6	1	1	1
10/08/2022 03:00	0.2	12.1	2,178.8	0.4	0.7	1	1	1
10/08/2022 04:00	0.2	12.1	2,186.4	0.4	0.7	1	1	1
10/08/2022 05:00	0.2	12.2	2,175.0	0.4	0.7	1	1	1
10/08/2022 06:00	0.1	12.6	2,114.0	0.2	0.6	1	1	1
10/08/2022 07:00	0.2	13.7	1,700.8	0.4	0.5	1	1	1
10/08/2022 08:00	0.4	14.0	1,358.1	0.4	0.4	1	1	0
10/08/2022 09:00	0.5	14.1	1,309.6	0.5	0.4	1	1	0
10/08/2022 10:00	0.5	14.1	1,309.0	0.5	0.4	1	1	0
10/08/2022 11:00	0.5	14.1	1,314.2	0.5	0.4	1	1	0
10/08/2022 12:00	0.4	13.9	1,559.1	0.4	0.5	1	1	0
10/08/2022 13:00	0.4	13.9	1,711.4	0.4	0.5	1	1	0
10/08/2022 14:00	0.2	13.8	1,728.5	0.4	0.5	1	1	1
10/08/2022 15:00	-0.1	12.3	2,093.4	0.2	0.6	1	1	1
10/08/2022 16:00	0.2	11.8	2,196.4	0.4	0.7	1	1	1
10/08/2022 17:00	0.2	11.8	2,200.9	0.4	0.7	1	1	1
10/08/2022 18:00	0.2	12.0	2,169.3	0.4	0.7	1	1	1
10/08/2022 19:00	0.2	12.0	2,176.3	0.4	0.7	1	1	1
10/08/2022 20:00	0.2	12.0	2,183.4	0.4	0.7	1	1	1
10/08/2022 21:00	0.2	12.0	2,182.8	0.4	0.7	1	1	1
10/08/2022 22:00	0.2	12.1	2,179.0	0.4	0.7	1	1	1
10/08/2022 23:00	0.2	12.2	2,177.1	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.7	1,946.8	0.4	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.8	1,309.0	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,200.9	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	0.2	12.1	2,173.7	0.4	0.7	1	1	1
10/09/2022 01:00	0.2	12.2	2,176.5	0.4	0.7	1	1	1
10/09/2022 02:00	0.2	12.3	2,147.0	0.4	0.6	1	1	1
10/09/2022 03:00	0.2	12.3	2,158.6	0.4	0.6	1	1	1
10/09/2022 04:00	0.2	12.2	2,165.0	0.4	0.6	1	1	1
10/09/2022 05:00	0.2	12.2	2,156.0	0.4	0.6	1	1	1
10/09/2022 06:00	0.0	13.7	1,682.6	0.0	0.5	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 14:00	0.0	17.6	384.2	0.0	0.1	1	0	0
10/09/2022 15:00	0.0	14.5	1,309.2	0.0	0.4	1	0	0
10/09/2022 16:00	0.4	13.9	1,714.4	0.4	0.5	1	1	0
10/09/2022 17:00	0.2	13.7	1,764.8	0.4	0.5	1	1	1
10/09/2022 18:00	-0.1	12.4	2,079.4	0.2	0.6	1	1	1
10/09/2022 19:00	0.4	11.8	2,207.7	0.5	0.7	1	1	1
10/09/2022 20:00	0.4	12.0	2,185.0	0.5	0.7	1	1	1
10/09/2022 21:00	0.2	12.1	2,173.4	0.4	0.7	1	1	1
10/09/2022 22:00	0.2	12.2	2,156.8	0.4	0.6	1	1	1
10/09/2022 23:00	0.2	12.2	2,148.5	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,928.4	0.3	0.6	17 #	14 #	14 #
Minimum:	-0.1	11.8	384.2	0.0	0.1	0	0	0
Maximum:	0.4	17.6	2,207.7	0.5	0.7	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	0.2	12.3	2,123.4	0.4	0.6	1	1	1
10/10/2022 01:00	0.2	12.5	2,095.3	0.4	0.6	1	1	1
10/10/2022 02:00	-0.1	13.0	1,981.4	0.1	0.6	1	1	1
10/10/2022 03:00	0.1	12.5	2,093.7	0.2	0.6	1	1	1
10/10/2022 04:00	0.2	12.4	2,139.2	0.4	0.6	1	1	1
10/10/2022 05:00	0.4	12.0	2,225.5	0.5	0.7	1	1	1
10/10/2022 06:00	0.4	12.1	2,215.7	0.5	0.7	1	1	1
10/10/2022 07:00	0.2	13.4	1,803.1	0.4	0.5	1	1	1
10/10/2022 08:00	0.4	13.9	1,542.0	0.4	0.5	1	1	0
10/10/2022 09:00	0.4	14.0	1,535.7	0.4	0.5	1	1	0
10/10/2022 10:00	0.5	14.1	1,390.1	0.5	0.4	1	1	0
10/10/2022 11:00	0.4	14.0	1,562.7	0.4	0.5	1	1	0
10/10/2022 12:00	0.4	14.1	1,576.8	0.4	0.5	1	1	0
10/10/2022 13:00	0.4	13.9	1,704.6	0.4	0.5	1	1	0
10/10/2022 14:00	0.4	13.9	1,711.9	0.4	0.5	1	1	0
10/10/2022 15:00	0.4	13.9	1,584.5	0.4	0.5	1	1	0
10/10/2022 16:00	-0.1	12.8	1,953.3	0.1	0.6	1	1	1
10/10/2022 17:00	0.2	12.0	2,159.8	0.4	0.6	1	1	1
10/10/2022 18:00	0.2	11.9	2,194.5	0.4	0.7	1	1	1
10/10/2022 19:00	0.2	12.0	2,171.3	0.4	0.7	1	1	1
10/10/2022 20:00	0.2	12.1	2,163.2	0.4	0.6	1	1	1
10/10/2022 21:00	0.1	12.3	2,109.3	0.2	0.6	1	1	1
10/10/2022 22:00	0.1	12.5	2,091.9	0.2	0.6	1	1	1
10/10/2022 23:00	-0.1	13.0	1,947.6	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,919.9	0.4	0.6	24 #	24 #	16 #
Minimum:	-0.1	11.9	1,390.1	0.1	0.4	1	1	0
Maximum:	0.5	14.1	2,225.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.4	14.0	1,368.8	0.4	0.4	1	1	0
10/11/2022 01:00	0.4	14.0	1,294.0	0.4	0.4	1	1	0
10/11/2022 02:00	0.5	14.0	1,293.9	0.5	0.4	1	1	0
10/11/2022 03:00	0.4	14.0	1,345.8	0.4	0.4	1	1	0
10/11/2022 04:00	0.4	14.0	1,489.9	0.4	0.4	1	1	0
10/11/2022 05:00	0.4	14.0	1,314.3	0.4	0.4	1	1	0
10/11/2022 06:00	0.4	14.0	1,303.1	0.4	0.4	1	1	0
10/11/2022 07:00	0.4	14.0	1,318.9	0.4	0.4	1	1	0
10/11/2022 08:00	0.4	13.9	1,748.2	0.4	0.5	1	1	0
10/11/2022 09:00	0.4	14.0	1,592.2	0.4	0.5	1	1	0
10/11/2022 10:00	0.4	13.8	1,729.7	0.4	0.5	1	1	0
10/11/2022 11:00	0.4	13.8	1,747.4	0.4	0.5	1	1	0
10/11/2022 12:00	0.4	13.9	1,748.6	0.4	0.5	1	1	0
10/11/2022 13:00	0.4	13.9	1,740.2	0.4	0.5	1	1	0
10/11/2022 14:00	0.4	13.9	1,733.2	0.4	0.5	1	1	0
10/11/2022 15:00	0.4	13.9	1,737.7	0.4	0.5	1	1	0
10/11/2022 16:00	0.4	13.8	1,760.7	0.4	0.5	1	1	0
10/11/2022 17:00	0.4	13.7	1,770.9	0.4	0.5	1	1	0
10/11/2022 18:00	0.2	13.7	1,775.7	0.4	0.5	1	1	1
10/11/2022 19:00	-0.2	12.5	2,057.5	0.1	0.6	1	1	1
10/11/2022 20:00	0.1	12.3	2,104.9	0.2	0.6	1	1	1
10/11/2022 21:00	0.1	12.1	2,159.4	0.2	0.6	1	1	1
10/11/2022 22:00	0.1	12.4	2,094.6	0.2	0.6	1	1	1
10/11/2022 23:00	-0.1	13.0	1,961.3	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.6	1,674.6	0.4	0.5	24 #	24 #	6 #
Minimum:	-0.2	12.1	1,293.9	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,159.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	-0.4	13.1	1,948.6	-0.1	0.6	1	1	1
10/12/2022 01:00	-0.4	13.1	1,928.9	-0.1	0.6	1	1	1
10/12/2022 02:00	0.4	13.9	1,512.2	0.4	0.5	1	1	0
10/12/2022 03:00	0.4	13.9	1,624.7	0.4	0.5	1	1	0
10/12/2022 04:00	0.4	13.8	1,746.5	0.4	0.5	1	1	0
10/12/2022 05:00	-0.1	12.4	2,122.6	0.2	0.6	1	1	1
10/12/2022 06:00	0.2	11.9	2,254.3	0.4	0.7	1	1	1
10/12/2022 07:00	0.4	11.9	2,245.2	0.5	0.7	1	1	1
10/12/2022 08:00	0.4	11.9	2,243.2	0.5	0.7	1	1	1
10/12/2022 09:00	0.4	11.9	2,238.0	0.5	0.7	1	1	1
10/12/2022 10:00	0.4	11.9	2,234.1	0.5	0.7	1	1	1
10/12/2022 11:00	0.4	11.9	2,233.9	0.5	0.7	1	1	1
10/12/2022 12:00	0.4	11.9	2,231.6	0.5	0.7	1	1	1
10/12/2022 13:00	0.4	11.9	2,228.9	0.5	0.7	1	1	1
10/12/2022 14:00	0.4	11.9	2,229.7	0.5	0.7	1	1	1
10/12/2022 15:00	0.4	11.8	2,235.6	0.5	0.7	1	1	1
10/12/2022 16:00	0.4	11.6	2,251.1	0.5	0.7	1	1	1
10/12/2022 17:00	0.4	11.6	2,260.5	0.5	0.7	1	1	1
10/12/2022 18:00	0.4	11.8	2,224.2	0.5	0.7	1	1	1
10/12/2022 19:00	0.2	12.2	2,135.6	0.4	0.6	1	1	1
10/12/2022 20:00	0.2	12.2	2,150.7	0.4	0.6	1	1	1
10/12/2022 21:00	0.1	12.3	2,115.2	0.2	0.6	1	1	1
10/12/2022 22:00	0.1	12.5	2,084.9	0.2	0.6	1	1	1
10/12/2022 23:00	-0.2	13.0	1,959.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.3	2,101.6	0.4	0.6	24 #	24 #	21 #
Minimum:	-0.4	11.6	1,512.2	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,260.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	-0.2	13.0	1,956.6	0.1	0.6	1	1	1
10/13/2022 01:00	-0.2	12.8	2,000.9	0.1	0.6	1	1	1
10/13/2022 02:00	-0.5	13.1	1,947.1	-0.2	0.6	1	1	1
10/13/2022 03:00	-0.4	13.1	1,959.2	-0.1	0.6	1	1	1
10/13/2022 04:00	-0.5	13.1	1,939.6	-0.2	0.6	1	1	1
10/13/2022 05:00	0.4	13.9	1,307.9	0.4	0.4	1	1	0
10/13/2022 06:00	0.4	13.9	1,308.4	0.4	0.4	1	1	0
10/13/2022 07:00	0.4	14.0	1,308.7	0.4	0.4	1	1	0
10/13/2022 08:00	0.4	13.9	1,486.8	0.4	0.4	1	1	0
10/13/2022 09:00	0.4	13.9	1,537.2	0.4	0.5	1	1	0
10/13/2022 10:00	0.4	13.8	1,712.7	0.4	0.5	1	1	0
10/13/2022 11:00	0.4	13.7	1,794.6	0.4	0.5	1	1	0
10/13/2022 12:00	0.4	13.7	1,790.4	0.4	0.5	1	1	0
10/13/2022 13:00	0.4	13.7	1,784.6	0.4	0.5	1	1	0
10/13/2022 14:00	0.4	13.7	1,779.9	0.4	0.5	1	1	0
10/13/2022 15:00	0.4	13.7	1,777.3	0.4	0.5	1	1	0
10/13/2022 16:00	0.4	13.7	1,779.0	0.4	0.5	1	1	0
10/13/2022 17:00	0.4	13.7	1,779.7	0.4	0.5	1	1	0
10/13/2022 18:00	0.4	13.7	1,784.4	0.4	0.5	1	1	0
10/13/2022 19:00	0.2	13.7	1,788.0	0.4	0.5	1	1	1
10/13/2022 20:00	-0.2	12.6	2,057.0	0.1	0.6	1	1	1
10/13/2022 21:00	0.1	12.2	2,156.4	0.2	0.6	1	1	1
10/13/2022 22:00	0.1	12.5	2,080.5	0.2	0.6	1	1	1
10/13/2022 23:00	0.1	12.6	2,070.0	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,787.0	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.5	12.2	1,307.9	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	2,156.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2022 00:00	0.1	12.7	2,061.1	0.2	0.6	1	1	1
10/14/2022 01:00	0.1	12.6	2,074.7	0.2	0.6	1	1	1
10/14/2022 02:00	0.1	12.6	2,074.6	0.2	0.6	1	1	1
10/14/2022 03:00	0.1	12.6	2,071.6	0.2	0.6	1	1	1
10/14/2022 04:00	0.2	12.4	2,112.7	0.4	0.6	1	1	1
10/14/2022 05:00	0.4	11.8	2,260.2	0.5	0.7	1	1	1
10/14/2022 06:00	0.4	11.8	2,253.5	0.5	0.7	1	1	1
10/14/2022 07:00	0.4	11.9	2,225.2	0.5	0.7	1	1	1
10/14/2022 08:00	0.2	12.7	2,025.4	0.4	0.6	1	1	1
10/14/2022 09:00	0.1	13.0	1,963.8	0.2	0.6	1	1	1
10/14/2022 10:00	0.1	12.9	1,974.2	0.2	0.6	1	1	1
10/14/2022 11:00	0.1	12.8	1,981.1	0.2	0.6	1	1	1
10/14/2022 12:00	-0.1	12.8	1,989.4	0.1	0.6	1	1	1
10/14/2022 13:00	0.1	12.7	1,999.2	0.2	0.6	1	1	1
10/14/2022 14:00	0.1	12.3	2,098.0	0.2	0.6	1	1	1
10/14/2022 15:00	0.2	12.2	2,127.4	0.4	0.6	1	1	1
10/14/2022 16:00	0.2	12.2	2,119.3	0.4	0.6	1	1	1
10/14/2022 17:00	0.4	11.8	2,207.4	0.5	0.7	1	1	1
10/14/2022 18:00	0.2	12.1	2,149.5	0.4	0.6	1	1	1
10/14/2022 19:00	0.2	12.2	2,120.7	0.4	0.6	1	1	1
10/14/2022 20:00	0.2	12.2	2,129.6	0.4	0.6	1	1	1
10/14/2022 21:00	0.2	12.3	2,120.9	0.4	0.6	1	1	1
10/14/2022 22:00	0.2	12.4	2,093.7	0.4	0.6	1	1	1
10/14/2022 23:00	0.0	14.0	1,326.6	0.0	0.4	1	0	1
Average/Sum#:	0.2	12.5	2,065.0	0.3	0.6	24 #	23 #	24 #
Minimum:	-0.1	11.8	1,326.6	0.0	0.4	1	0	1
Maximum:	0.4	14.0	2,260.2	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	17.7	328.5	0.0	0.1	1	0	0
10/16/2022 18:00	0.0	16.5	574.4	0.0	0.2	1	0	0
10/16/2022 19:00	0.0	15.1	965.7	0.0	0.3	1	0	0
10/16/2022 20:00	0.4	13.8	1,770.5	0.4	0.5	1	1	0
10/16/2022 21:00	0.4	13.8	1,686.0	0.4	0.5	1	1	0
10/16/2022 22:00	0.4	13.9	1,594.4	0.4	0.5	1	1	0
10/16/2022 23:00	0.4	13.8	1,803.8	0.4	0.5	1	1	0
Average/Sum#:	0.2	14.9	1,246.2	0.2	0.4	7 #	4 #	0 #
Minimum:	0.0	13.8	328.5	0.0	0.1	0	0	0
Maximum:	0.4	17.7	1,803.8	0.4	0.5	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.4	13.9	1,642.9	0.4	0.5	1	1	0
10/17/2022 01:00	0.4	13.9	1,698.6	0.4	0.5	1	1	0
10/17/2022 02:00	0.4	13.9	1,702.5	0.4	0.5	1	1	0
10/17/2022 03:00	0.4	13.8	1,794.9	0.4	0.5	1	1	1
10/17/2022 04:00	0.1	12.7	2,058.2	0.2	0.6	1	1	1
10/17/2022 05:00	0.4	12.2	2,160.0	0.5	0.6	1	1	1
10/17/2022 06:00	0.4	12.3	2,145.3	0.5	0.6	1	1	1
10/17/2022 07:00	0.2	12.5	2,099.6	0.4	0.6	1	1	1
10/17/2022 08:00	0.4	13.8	1,683.3	0.4	0.5	1	1	1
10/17/2022 09:00	0.5	13.9	1,632.3	0.5	0.5	1	1	0
10/17/2022 10:00	0.4	14.0	1,522.6	0.4	0.5	1	1	0
10/17/2022 11:00	0.4	14.0	1,609.1	0.4	0.5	1	1	0
10/17/2022 12:00	0.4	14.0	1,506.6	0.4	0.5	1	1	0
10/17/2022 13:00	0.4	14.0	1,501.4	0.4	0.5	1	1	0
10/17/2022 14:00	0.4	14.0	1,657.9	0.4	0.5	1	1	0
10/17/2022 15:00	0.2	13.8	1,696.8	0.4	0.5	1	1	1
10/17/2022 16:00	-0.1	12.5	2,079.8	0.1	0.6	1	1	1
10/17/2022 17:00	0.2	11.8	2,230.9	0.4	0.7	1	1	1
10/17/2022 18:00	0.4	11.8	2,246.4	0.5	0.7	1	1	1
10/17/2022 19:00	0.4	11.9	2,223.6	0.5	0.7	1	1	1
10/17/2022 20:00	0.4	11.9	2,229.9	0.5	0.7	1	1	1
10/17/2022 21:00	0.4	11.8	2,239.7	0.5	0.7	1	1	1
10/17/2022 22:00	0.2	12.2	2,177.2	0.4	0.7	1	1	1
10/17/2022 23:00	0.2	12.2	2,183.6	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.0	1,905.1	0.4	0.6	24 #	24 #	15 #
Minimum:	-0.1	11.8	1,501.4	0.1	0.5	1	1	0
Maximum:	0.5	14.0	2,246.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	0.2	12.2	2,179.1	0.4	0.7	1	1	1
10/18/2022 01:00	0.4	12.3	2,170.9	0.5	0.7	1	1	1
10/18/2022 02:00	0.4	12.2	2,170.7	0.5	0.7	1	1	1
10/18/2022 03:00	0.4	12.1	2,176.9	0.5	0.7	1	1	1
10/18/2022 04:00	0.4	12.1	2,177.4	0.5	0.7	1	1	1
10/18/2022 05:00	0.2	12.2	2,182.6	0.4	0.7	1	1	1
10/18/2022 06:00	0.2	12.3	2,168.2	0.4	0.7	1	1	1
10/18/2022 07:00	0.2	12.3	2,166.7	0.4	0.7	1	1	1
10/18/2022 08:00	0.2	12.3	2,171.0	0.4	0.7	1	1	1
10/18/2022 09:00	0.2	12.4	2,155.8	0.4	0.6	1	1	1
10/18/2022 10:00	0.1	12.4	2,119.5	0.2	0.6	1	1	1
10/18/2022 11:00	0.1	12.5	2,098.2	0.2	0.6	1	1	1
10/18/2022 12:00	0.1	12.5	2,098.2	0.2	0.6	1	1	1
10/18/2022 13:00	0.1	12.5	2,102.8	0.2	0.6	1	1	1
10/18/2022 14:00	0.1	12.4	2,107.4	0.2	0.6	1	1	1
10/18/2022 15:00	0.1	12.3	2,134.7	0.2	0.6	1	1	1
10/18/2022 16:00	0.2	11.9	2,216.3	0.4	0.7	1	1	1
10/18/2022 17:00	0.2	12.1	2,188.4	0.4	0.7	1	1	1
10/18/2022 18:00	0.2	11.9	2,231.8	0.4	0.7	1	1	1
10/18/2022 19:00	0.4	11.8	2,253.5	0.5	0.7	1	1	1
10/18/2022 20:00	0.4	11.8	2,259.4	0.5	0.7	1	1	1
10/18/2022 21:00	0.4	11.8	2,259.3	0.5	0.7	1	1	1
10/18/2022 22:00	0.2	12.1	2,195.6	0.4	0.7	1	1	1
10/18/2022 23:00	0.2	12.1	2,192.8	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.2	2,174.1	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.8	2,098.2	0.2	0.6	1	1	1
Maximum:	0.4	12.5	2,259.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	0.2	12.2	2,182.0	0.4	0.7	1	1	1
10/19/2022 01:00	0.1	12.5	2,136.3	0.2	0.6	1	1	1
10/19/2022 02:00	0.1	12.6	2,103.7	0.2	0.6	1	1	1
10/19/2022 03:00	0.1	12.5	2,144.5	0.2	0.6	1	1	1
10/19/2022 04:00	0.2	12.3	2,188.0	0.4	0.7	1	1	1
10/19/2022 05:00	0.2	12.0	2,237.9	0.4	0.7	1	1	1
10/19/2022 06:00	0.2	12.2	2,213.4	0.4	0.7	1	1	1
10/19/2022 07:00	0.1	12.4	2,148.6	0.2	0.6	1	1	1
10/19/2022 08:00	0.1	12.5	2,138.1	0.2	0.6	1	1	1
10/19/2022 09:00	0.1	12.6	2,094.9	0.2	0.6	1	1	1
10/19/2022 10:00	0.1	12.6	2,079.5	0.2	0.6	1	1	1
10/19/2022 11:00	0.1	12.4	2,110.0	0.2	0.6	1	1	1
10/19/2022 12:00	0.1	12.3	2,130.2	0.2	0.6	1	1	1
10/19/2022 13:00	0.1	12.2	2,149.0	0.2	0.6	1	1	1
10/19/2022 14:00	0.1	12.2	2,141.4	0.2	0.6	1	1	1
10/19/2022 15:00	0.2	12.0	2,178.1	0.4	0.7	1	1	1
10/19/2022 16:00	0.2	12.0	2,194.2	0.4	0.7	1	1	1
10/19/2022 17:00	0.1	12.3	2,123.6	0.2	0.6	1	1	1
10/19/2022 18:00	0.1	12.4	2,099.3	0.2	0.6	1	1	1
10/19/2022 19:00	0.1	12.4	2,108.5	0.2	0.6	1	1	1
10/19/2022 20:00	0.1	12.3	2,147.1	0.2	0.6	1	1	1
10/19/2022 21:00	0.1	12.5	2,114.2	0.2	0.6	1	1	1
10/19/2022 22:00	0.1	12.6	2,087.5	0.2	0.6	1	1	1
10/19/2022 23:00	0.1	12.5	2,105.2	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.4	2,139.8	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	12.0	2,079.5	0.2	0.6	1	1	1
Maximum:	0.2	12.6	2,237.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	0.1	12.5	2,124.0	0.2	0.6	1	1	1
10/20/2022 01:00	0.1	12.6	2,087.9	0.2	0.6	1	1	1
10/20/2022 02:00	0.1	12.6	2,078.6	0.2	0.6	1	1	1
10/20/2022 03:00	-0.1	12.6	2,089.3	0.1	0.6	1	1	1
10/20/2022 04:00	0.1	12.5	2,135.5	0.2	0.6	1	1	1
10/20/2022 05:00	0.2	12.1	2,217.9	0.4	0.7	1	1	1
10/20/2022 06:00	0.2	12.3	2,191.7	0.4	0.7	1	1	1
10/20/2022 07:00	0.1	12.8	2,069.5	0.2	0.6	1	1	1
10/20/2022 08:00	0.1	12.8	2,056.4	0.2	0.6	1	1	1
10/20/2022 09:00	-0.1	12.7	2,066.1	0.1	0.6	1	1	1
10/20/2022 10:00	0.1	12.7	2,060.8	0.2	0.6	1	1	1
10/20/2022 11:00	0.1	12.5	2,079.4	0.2	0.6	1	1	1
10/20/2022 12:00	0.1	12.5	2,079.4	0.2	0.6	1	1	1
10/20/2022 13:00	0.1	12.4	2,099.7	0.2	0.6	1	1	1
10/20/2022 14:00	0.1	12.3	2,121.0	0.2	0.6	1	1	1
10/20/2022 15:00	0.1	12.2	2,147.2	0.2	0.6	1	1	1
10/20/2022 16:00	0.2	11.7	2,241.0	0.4	0.7	1	1	1
10/20/2022 17:00	0.2	12.0	2,178.6	0.4	0.7	1	1	1
10/20/2022 18:00	0.2	11.9	2,212.5	0.4	0.7	1	1	1
10/20/2022 19:00	0.1	12.3	2,107.9	0.2	0.6	1	1	1
10/20/2022 20:00	0.1	12.4	2,104.9	0.2	0.6	1	1	1
10/20/2022 21:00	0.1	12.6	2,083.3	0.2	0.6	1	1	1
10/20/2022 22:00	0.1	12.6	2,083.3	0.2	0.6	1	1	1
10/20/2022 23:00	0.1	12.4	2,136.7	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.4	2,118.9	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	2,056.4	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,241.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	-0.1	12.9	1,988.0	0.1	0.6	1	1	1
10/21/2022 01:00	0.4	14.0	1,577.0	0.4	0.5	1	1	0
10/21/2022 02:00	0.4	13.9	1,586.8	0.4	0.5	1	1	0
10/21/2022 03:00	0.4	13.9	1,543.4	0.4	0.5	1	1	0
10/21/2022 04:00	0.4	14.0	1,696.1	0.4	0.5	1	1	0
10/21/2022 05:00	0.4	14.0	1,698.2	0.4	0.5	1	1	0
10/21/2022 06:00	0.4	14.0	1,598.5	0.4	0.5	1	1	0
10/21/2022 07:00	0.4	14.0	1,668.5	0.4	0.5	1	1	0
10/21/2022 08:00	0.4	14.0	1,704.9	0.4	0.5	1	1	0
10/21/2022 09:00	0.4	14.0	1,708.4	0.4	0.5	1	1	0
10/21/2022 10:00	0.4	14.0	1,706.9	0.4	0.5	1	1	0
10/21/2022 11:00	0.4	14.0	1,671.9	0.4	0.5	1	1	0
10/21/2022 12:00	0.4	14.0	1,648.8	0.4	0.5	1	1	0
10/21/2022 13:00	0.4	14.0	1,624.1	0.4	0.5	1	1	0
10/21/2022 14:00	0.4	13.9	1,681.0	0.4	0.5	1	1	0
10/21/2022 15:00	0.2	13.9	1,556.4	0.2	0.5	1	1	1
10/21/2022 16:00	-0.1	12.4	2,095.8	0.2	0.6	1	1	1
10/21/2022 17:00	0.2	12.0	2,180.2	0.4	0.7	1	1	1
10/21/2022 18:00	0.1	12.2	2,136.5	0.2	0.6	1	1	1
10/21/2022 19:00	0.1	12.4	2,098.4	0.2	0.6	1	1	1
10/21/2022 20:00	0.1	12.3	2,116.7	0.2	0.6	1	1	1
10/21/2022 21:00	0.2	12.0	2,176.0	0.4	0.7	1	1	1
10/21/2022 22:00	0.0	14.3	1,201.6	0.0	0.4	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.5	1,768.0	0.3	0.5	23 #	22 #	9 #
Minimum:	-0.1	12.0	1,201.6	0.0	0.4	0	0	0
Maximum:	0.4	14.3	2,180.2	0.4	0.7	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	17.8	297.2	0.0	0.1	1	0	0
10/23/2022 21:00	0.0	17.3	370.7	0.0	0.1	1	0	0
10/23/2022 22:00	0.0	15.9	787.1	0.0	0.2	1	0	0
10/23/2022 23:00	0.5	14.1	1,353.7	0.5	0.4	1	1	0
Average/Sum#:	0.1	16.3	702.2	0.1	0.2	4 #	1 #	0 #
Minimum:	0.0	14.1	297.2	0.0	0.1	0	0	0
Maximum:	0.5	17.8	1,353.7	0.5	0.4	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.5	14.1	1,368.5	0.5	0.4	1	1	0
10/24/2022 01:00	0.5	14.1	1,359.7	0.5	0.4	1	1	0
10/24/2022 02:00	0.5	14.1	1,359.6	0.5	0.4	1	1	0
10/24/2022 03:00	0.5	14.1	1,359.6	0.5	0.4	1	1	0
10/24/2022 04:00	0.5	13.9	1,649.1	0.5	0.5	1	1	0
10/24/2022 05:00	0.5	13.8	1,820.4	0.5	0.5	1	1	0
10/24/2022 06:00	0.5	13.8	1,821.7	0.5	0.5	1	1	0
10/24/2022 07:00	0.5	13.8	1,819.3	0.5	0.5	1	1	0
10/24/2022 08:00	0.5	13.9	1,816.0	0.5	0.5	1	1	0
10/24/2022 09:00	0.4	13.9	1,793.7	0.4	0.5	1	1	0
10/24/2022 10:00	0.4	13.8	1,841.1	0.4	0.6	1	1	0
10/24/2022 11:00	0.4	13.8	1,831.5	0.4	0.5	1	1	0
10/24/2022 12:00	0.4	13.9	1,769.6	0.4	0.5	1	1	0
10/24/2022 13:00	0.4	13.9	1,746.6	0.4	0.5	1	1	0
10/24/2022 14:00	0.0	15.1	1,013.9	0.0	0.3	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.0	1,624.7	0.4	0.5	15 #	14 #	0 #
Minimum:	0.0	13.8	1,013.9	0.0	0.3	0	0	0
Maximum:	0.5	15.1	1,841.1	0.5	0.6	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	18.9	164.5	0.0	0.0	1	0	0
10/30/2022 20:00	0.0	17.3	372.9	0.0	0.1	1	0	0
10/30/2022 21:00	0.0	16.8	562.7	0.0	0.2	1	0	0
10/30/2022 22:00	0.0	16.0	878.4	0.0	0.3	1	0	0
10/30/2022 23:00	0.4	13.8	1,773.4	0.4	0.5	1	1	0
Average/Sum#:	0.1	16.6	750.4	0.1	0.2	5 #	1 #	0 #
Minimum:	0.0	13.8	164.5	0.0	0.0	0	0	0
Maximum:	0.4	18.9	1,773.4	0.4	0.5	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.4	14.0	1,565.8	0.4	0.5	1	1	0
10/31/2022 01:00	0.4	13.9	1,787.0	0.4	0.5	1	1	0
10/31/2022 02:00	0.4	14.0	1,671.4	0.4	0.5	1	1	0
10/31/2022 03:00	0.4	14.0	1,708.8	0.4	0.5	1	1	0
10/31/2022 04:00	0.4	14.0	1,723.8	0.4	0.5	1	1	0
10/31/2022 05:00	0.4	14.0	1,708.1	0.4	0.5	1	1	0
10/31/2022 06:00	0.4	14.0	1,699.3	0.4	0.5	1	1	0
10/31/2022 07:00	0.4	14.0	1,700.7	0.4	0.5	1	1	0
10/31/2022 08:00	0.4	14.0	1,704.0	0.4	0.5	1	1	0
10/31/2022 09:00	0.4	14.0	1,705.2	0.4	0.5	1	1	0
10/31/2022 10:00	0.4	14.0	1,708.1	0.4	0.5	1	1	0
10/31/2022 11:00	0.4	14.0	1,687.1	0.4	0.5	1	1	0
10/31/2022 12:00	0.4	14.0	1,677.9	0.4	0.5	1	1	0
10/31/2022 13:00	0.4	14.0	1,691.9	0.4	0.5	1	1	0
10/31/2022 14:00	0.2	13.9	1,760.4	0.2	0.5	1	1	1
10/31/2022 15:00	-0.2	12.6	2,079.3	0.1	0.6	1	1	1
10/31/2022 16:00	-0.1	12.5	2,105.8	0.1	0.6	1	1	1
10/31/2022 17:00	-0.1	12.6	2,078.5	0.1	0.6	1	1	1
10/31/2022 18:00	-0.1	12.6	2,081.3	0.1	0.6	1	1	1
10/31/2022 19:00	0.1	12.5	2,104.0	0.2	0.6	1	1	1
10/31/2022 20:00	0.1	12.5	2,108.1	0.2	0.6	1	1	1
10/31/2022 21:00	0.1	12.3	2,163.0	0.2	0.6	1	1	1
10/31/2022 22:00	0.2	12.5	2,119.3	0.4	0.6	1	1	1
10/31/2022 23:00	0.2	12.3	2,146.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,853.5	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	12.3	1,565.8	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,163.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	0.2	12.4	2,163.8	0.4	0.6	1	1	1
11/01/2022 01:00	0.2	12.4	2,153.2	0.4	0.6	1	1	1
11/01/2022 02:00	0.2	12.4	2,162.1	0.4	0.6	1	1	1
11/01/2022 03:00	0.2	12.4	2,163.5	0.4	0.6	1	1	1
11/01/2022 04:00	0.2	12.4	2,167.9	0.4	0.7	1	1	1
11/01/2022 05:00	0.2	12.4	2,167.4	0.4	0.7	1	1	1
11/01/2022 06:00	0.4	12.1	2,232.9	0.5	0.7	1	1	1
11/01/2022 07:00	0.4	12.3	2,179.4	0.5	0.7	1	1	1
11/01/2022 08:00	0.4	12.0	2,231.6	0.5	0.7	1	1	1
11/01/2022 09:00	0.4	12.4	2,116.2	0.5	0.6	1	1	1
11/01/2022 10:00	0.2	12.5	2,121.2	0.4	0.6	1	1	1
11/01/2022 11:00	0.4	12.2	2,178.7	0.5	0.7	1	1	1
11/01/2022 12:00	0.4	12.2	2,182.8	0.5	0.7	1	1	1
11/01/2022 13:00	0.4	12.3	2,169.2	0.5	0.7	1	1	1
11/01/2022 14:00	0.4	12.6	2,083.1	0.5	0.6	1	1	1
11/01/2022 15:00	0.1	12.7	2,094.6	0.2	0.6	1	1	1
11/01/2022 16:00	0.2	12.2	2,225.8	0.4	0.7	1	1	1
11/01/2022 17:00	0.5	11.9	2,292.1	0.5	0.7	1	1	1
11/01/2022 18:00	0.4	12.3	2,192.0	0.5	0.7	1	1	1
11/01/2022 19:00	0.4	12.5	2,163.6	0.5	0.6	1	1	1
11/01/2022 20:00	0.4	12.3	2,201.7	0.5	0.7	1	1	1
11/01/2022 21:00	0.2	12.8	2,080.8	0.4	0.6	1	1	1
11/01/2022 22:00	0.2	12.9	2,070.4	0.4	0.6	1	1	1
11/01/2022 23:00	0.4	13.4	1,845.9	0.4	0.6	1	1	1
Average/Sum#:	0.3	12.4	2,151.7	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,845.9	0.2	0.6	1	1	1
Maximum:	0.5	13.4	2,292.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.5	14.1	1,347.9	0.5	0.4	1	1	0
11/02/2022 01:00	0.5	14.0	1,630.5	0.5	0.5	1	1	0
11/02/2022 02:00	0.4	14.0	1,698.9	0.4	0.5	1	1	0
11/02/2022 03:00	0.4	14.0	1,348.8	0.4	0.4	1	1	0
11/02/2022 04:00	0.4	14.0	1,665.7	0.4	0.5	1	1	0
11/02/2022 05:00	0.2	13.5	1,907.9	0.4	0.6	1	1	1
11/02/2022 06:00	0.1	12.7	2,175.1	0.2	0.7	1	1	1
11/02/2022 07:00	0.2	12.8	2,135.9	0.4	0.6	1	1	1
11/02/2022 08:00	0.1	13.1	2,040.3	0.2	0.6	1	1	1
11/02/2022 09:00	0.5	14.0	1,710.1	0.5	0.5	1	1	0
11/02/2022 10:00	0.5	14.0	1,543.3	0.5	0.5	1	1	0
11/02/2022 11:00	0.5	14.0	1,672.4	0.5	0.5	1	1	0
11/02/2022 12:00	0.5	14.0	1,549.7	0.5	0.5	1	1	0
11/02/2022 13:00	0.5	14.0	1,552.9	0.5	0.5	1	1	0
11/02/2022 14:00	0.4	14.0	1,535.2	0.4	0.5	1	1	0
11/02/2022 15:00	0.4	14.0	1,604.0	0.4	0.5	1	1	1
11/02/2022 16:00	0.1	12.8	2,092.6	0.2	0.6	1	1	1
11/02/2022 17:00	0.2	12.5	2,182.8	0.4	0.7	1	1	1
11/02/2022 18:00	0.2	12.5	2,177.3	0.4	0.7	1	1	1
11/02/2022 19:00	0.2	12.5	2,175.0	0.4	0.7	1	1	1
11/02/2022 20:00	0.2	12.6	2,175.1	0.4	0.7	1	1	1
11/02/2022 21:00	0.2	12.6	2,157.6	0.4	0.6	1	1	1
11/02/2022 22:00	0.2	12.6	2,164.2	0.4	0.6	1	1	1
11/02/2022 23:00	0.2	12.6	2,177.5	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.4	1,850.9	0.4	0.6	24 #	24 #	13 #
Minimum:	0.1	12.5	1,347.9	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,182.8	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2022 00:00	0.2	12.6	2,169.0	0.4	0.7	1	1	1
11/03/2022 01:00	0.2	12.7	2,153.0	0.4	0.6	1	1	1
11/03/2022 02:00	0.2	12.5	2,194.3	0.4	0.7	1	1	1
11/03/2022 03:00	0.4	12.3	2,234.1	0.5	0.7	1	1	1
11/03/2022 04:00	0.2	12.6	2,163.9	0.4	0.6	1	1	1
11/03/2022 05:00	0.2	12.6	2,166.0	0.4	0.6	1	1	1
11/03/2022 06:00	0.4	12.4	2,231.2	0.5	0.7	1	1	1
11/03/2022 07:00	0.2	12.8	2,110.9	0.4	0.6	1	1	1
11/03/2022 08:00	0.5	14.1	1,456.2	0.5	0.4	1	1	0
11/03/2022 09:00	0.5	14.0	1,559.4	0.5	0.5	1	1	0
11/03/2022 10:00	0.5	14.0	1,574.2	0.5	0.5	1	1	0
11/03/2022 11:00	0.5	14.0	1,570.2	0.5	0.5	1	1	0
11/03/2022 12:00	0.5	14.0	1,579.0	0.5	0.5	1	1	0
11/03/2022 13:00	0.5	14.1	1,487.4	0.5	0.4	1	1	0
11/03/2022 14:00	0.4	14.1	1,553.3	0.4	0.5	1	1	0
11/03/2022 15:00	0.4	14.0	1,771.8	0.4	0.5	1	1	1
11/03/2022 16:00	0.1	12.8	2,084.1	0.2	0.6	1	1	1
11/03/2022 17:00	0.2	12.5	2,162.5	0.4	0.6	1	1	1
11/03/2022 18:00	0.4	12.5	2,175.5	0.5	0.7	1	1	1
11/03/2022 19:00	0.4	12.5	2,174.2	0.5	0.7	1	1	1
11/03/2022 20:00	0.4	12.5	2,163.4	0.5	0.6	1	1	1
11/03/2022 21:00	0.4	12.5	2,161.9	0.5	0.6	1	1	1
11/03/2022 22:00	0.4	12.5	2,161.6	0.5	0.6	1	1	1
11/03/2022 23:00	0.4	12.4	2,201.2	0.5	0.7	1	1	1
Average/Sum#:	0.4	13.0	1,969.1	0.5	0.6	24 #	24 #	17 #
Minimum:	0.1	12.3	1,456.2	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,234.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	0.2	12.7	2,139.4	0.4	0.6	1	1	1
11/04/2022 01:00	0.2	12.7	2,120.0	0.4	0.6	1	1	1
11/04/2022 02:00	0.2	12.9	2,069.1	0.4	0.6	1	1	1
11/04/2022 03:00	0.2	12.9	2,071.1	0.4	0.6	1	1	1
11/04/2022 04:00	0.2	12.7	2,149.6	0.4	0.6	1	1	1
11/04/2022 05:00	0.4	12.3	2,242.1	0.5	0.7	1	1	1
11/04/2022 06:00	0.2	12.6	2,177.1	0.4	0.7	1	1	1
11/04/2022 07:00	0.2	13.0	2,059.9	0.4	0.6	1	1	1
11/04/2022 08:00	0.5	14.0	1,718.3	0.5	0.5	1	1	1
11/04/2022 09:00	0.5	14.0	1,552.2	0.5	0.5	1	1	0
11/04/2022 10:00	0.5	14.1	1,390.6	0.5	0.4	1	1	0
11/04/2022 11:00	0.5	14.1	1,319.4	0.5	0.4	1	1	0
11/04/2022 12:00	0.5	14.1	1,316.8	0.5	0.4	1	1	0
11/04/2022 13:00	0.5	14.1	1,317.6	0.5	0.4	1	1	0
11/04/2022 14:00	0.4	14.1	1,398.3	0.4	0.4	1	1	0
11/04/2022 15:00	0.2	13.9	1,629.0	0.2	0.5	1	1	1
11/04/2022 16:00	0.1	12.7	2,105.1	0.2	0.6	1	1	1
11/04/2022 17:00	0.2	12.5	2,145.5	0.4	0.6	1	1	1
11/04/2022 18:00	0.2	12.8	2,089.4	0.4	0.6	1	1	1
11/04/2022 19:00	0.2	12.8	2,086.7	0.4	0.6	1	1	1
11/04/2022 20:00	0.2	12.8	2,076.1	0.4	0.6	1	1	1
11/04/2022 21:00	0.2	12.8	2,074.7	0.4	0.6	1	1	1
11/04/2022 22:00	0.2	12.8	2,082.6	0.4	0.6	1	1	1
11/04/2022 23:00	0.2	13.3	1,970.2	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,887.5	0.4	0.6	24 #	24 #	18 #
Minimum:	0.1	12.3	1,316.8	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,242.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	0.1	13.3	1,965.0	0.2	0.6	1	1	1
11/05/2022 01:00	0.2	13.3	1,965.4	0.4	0.6	1	1	1
11/05/2022 02:00	0.1	13.3	1,965.9	0.2	0.6	1	1	1
11/05/2022 03:00	0.1	13.3	1,965.1	0.2	0.6	1	1	1
11/05/2022 04:00	0.1	13.3	1,973.7	0.2	0.6	1	1	1
11/05/2022 05:00	0.1	13.3	1,978.5	0.2	0.6	1	1	1
11/05/2022 06:00	0.1	13.3	1,948.0	0.2	0.6	1	1	1
11/05/2022 07:00	0.0	15.9	568.2	0.0	0.2	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.6	1,791.2	0.2	0.6	8 #	7 #	7 #
Minimum:	0.0	13.3	568.2	0.0	0.2	0	0	0
Maximum:	0.2	15.9	1,978.5	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	18.2	259.0	0.0	0.1	1	0	0
11/06/2022 10:00	0.0	17.4	380.5	0.0	0.1	1	0	0
11/06/2022 11:00	0.0	15.7	828.7	0.0	0.2	1	0	0
11/06/2022 12:00	0.4	14.0	1,401.7	0.4	0.4	1	1	0
11/06/2022 13:00	0.4	14.0	1,533.1	0.4	0.5	1	1	0
11/06/2022 14:00	0.4	13.9	1,606.7	0.4	0.5	1	1	0
11/06/2022 15:00	0.1	12.9	1,957.5	0.2	0.6	1	1	1
11/06/2022 16:00	0.2	11.8	2,286.9	0.4	0.7	1	1	1
11/06/2022 17:00	0.4	11.7	2,303.5	0.5	0.7	1	1	1
11/06/2022 18:00	0.1	12.9	2,010.4	0.2	0.6	1	1	1
11/06/2022 19:00	-0.1	13.2	1,964.3	0.1	0.6	1	1	1
11/06/2022 20:00	-0.1	13.1	1,989.1	0.1	0.6	1	1	1
11/06/2022 21:00	0.0	13.3	1,677.6	0.0	0.5	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.0	1,553.8	0.2	0.5	13 #	9 #	7 #
Minimum:	-0.1	11.7	259.0	0.0	0.1	0	0	0
Maximum:	0.4	18.2	2,303.5	0.5	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	18.1	314.8	0.0	0.1	1	0	0
11/07/2022 01:00	0.0	15.3	1,013.6	0.0	0.3	1	0	0
11/07/2022 02:00	0.4	14.0	1,566.8	0.4	0.5	1	1	0
11/07/2022 03:00	0.4	14.0	1,619.9	0.4	0.5	1	1	0
11/07/2022 04:00	0.4	14.0	1,676.5	0.4	0.5	1	1	0
11/07/2022 05:00	0.4	13.9	1,708.4	0.4	0.5	1	1	0
11/07/2022 06:00	0.1	12.9	2,008.4	0.2	0.6	1	1	1
11/07/2022 07:00	0.2	12.2	2,239.0	0.4	0.7	1	1	1
11/07/2022 08:00	0.1	13.2	1,992.4	0.2	0.6	1	1	1
11/07/2022 09:00	0.1	13.2	1,975.3	0.2	0.6	1	1	1
11/07/2022 10:00	0.1	13.2	1,964.7	0.2	0.6	1	1	1
11/07/2022 11:00	0.1	13.2	1,962.6	0.2	0.6	1	1	1
11/07/2022 12:00	0.1	13.2	1,963.8	0.2	0.6	1	1	1
11/07/2022 13:00	0.1	13.2	1,962.7	0.2	0.6	1	1	1
11/07/2022 14:00	0.1	12.8	2,060.4	0.2	0.6	1	1	1
11/07/2022 15:00	0.2	12.3	2,192.5	0.4	0.7	1	1	1
11/07/2022 16:00	0.4	12.0	2,250.1	0.5	0.7	1	1	1
11/07/2022 17:00	0.5	11.9	2,290.9	0.5	0.7	1	1	1
11/07/2022 18:00	0.5	11.9	2,297.0	0.5	0.7	1	1	1
11/07/2022 19:00	0.5	11.9	2,293.7	0.5	0.7	1	1	1
11/07/2022 20:00	0.5	11.9	2,289.5	0.5	0.7	1	1	1
11/07/2022 21:00	0.5	11.9	2,293.4	0.5	0.7	1	1	1
11/07/2022 22:00	0.4	12.1	2,257.7	0.5	0.7	1	1	1
11/07/2022 23:00	0.2	12.4	2,181.0	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.1	1,932.3	0.3	0.6	24 #	22 #	18 #
Minimum:	0.0	11.9	314.8	0.0	0.1	1	0	0
Maximum:	0.5	18.1	2,297.0	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.2	12.4	2,172.6	0.4	0.7	1	1	1
11/08/2022 01:00	0.2	12.5	2,167.5	0.4	0.7	1	1	1
11/08/2022 02:00	0.2	12.6	2,112.2	0.4	0.6	1	1	1
11/08/2022 03:00	0.2	12.5	2,160.9	0.4	0.6	1	1	1
11/08/2022 04:00	0.4	12.3	2,200.1	0.5	0.7	1	1	1
11/08/2022 05:00	0.4	12.2	2,219.7	0.5	0.7	1	1	1
11/08/2022 06:00	0.5	11.8	2,300.5	0.5	0.7	1	1	1
11/08/2022 07:00	0.4	12.2	2,213.6	0.5	0.7	1	1	1
11/08/2022 08:00	0.4	12.2	2,202.3	0.5	0.7	1	1	1
11/08/2022 09:00	0.4	12.2	2,200.4	0.5	0.7	1	1	1
11/08/2022 10:00	0.4	12.3	2,185.6	0.5	0.7	1	1	1
11/08/2022 11:00	0.2	13.0	2,032.7	0.4	0.6	1	1	1
11/08/2022 12:00	0.1	13.2	1,987.2	0.2	0.6	1	1	1
11/08/2022 13:00	0.1	13.2	1,985.1	0.2	0.6	1	1	1
11/08/2022 14:00	0.1	12.9	2,056.2	0.2	0.6	1	1	1
11/08/2022 15:00	0.1	12.9	2,056.3	0.2	0.6	1	1	1
11/08/2022 16:00	0.2	12.3	2,217.1	0.4	0.7	1	1	1
11/08/2022 17:00	0.4	12.3	2,201.6	0.5	0.7	1	1	1
11/08/2022 18:00	0.2	12.4	2,173.9	0.4	0.7	1	1	1
11/08/2022 19:00	0.4	12.3	2,206.4	0.5	0.7	1	1	1
11/08/2022 20:00	0.4	12.3	2,206.2	0.5	0.7	1	1	1
11/08/2022 21:00	0.4	12.3	2,204.5	0.5	0.7	1	1	1
11/08/2022 22:00	0.4	12.3	2,190.4	0.5	0.7	1	1	1
11/08/2022 23:00	0.2	12.5	2,146.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	12.5	2,158.3	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.8	1,985.1	0.2	0.6	1	1	1
Maximum:	0.5	13.2	2,300.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2022 00:00	0.2	12.5	2,155.3	0.4	0.6	1	1	1
11/09/2022 01:00	0.2	12.5	2,154.5	0.4	0.6	1	1	1
11/09/2022 02:00	0.4	12.4	2,194.0	0.5	0.7	1	1	1
11/09/2022 03:00	0.4	12.4	2,195.1	0.5	0.7	1	1	1
11/09/2022 04:00	0.2	12.5	2,162.1	0.4	0.6	1	1	1
11/09/2022 05:00	0.4	12.2	2,258.0	0.5	0.7	1	1	1
11/09/2022 06:00	0.4	12.0	2,298.8	0.5	0.7	1	1	1
11/09/2022 07:00	0.4	12.4	2,203.8	0.5	0.7	1	1	1
11/09/2022 08:00	0.4	12.5	2,162.6	0.5	0.6	1	1	1
11/09/2022 09:00	0.4	13.8	1,742.9	0.4	0.5	1	1	1
11/09/2022 10:00	0.5	13.9	1,701.0	0.5	0.5	1	1	0
11/09/2022 11:00	0.5	13.9	1,628.8	0.5	0.5	1	1	0
11/09/2022 12:00	0.5	13.9	1,704.5	0.5	0.5	1	1	0
11/09/2022 13:00	0.5	14.0	1,617.1	0.5	0.5	1	1	0
11/09/2022 14:00	0.5	13.9	1,688.5	0.5	0.5	1	1	0
11/09/2022 15:00	0.5	13.9	1,636.8	0.5	0.5	1	1	1
11/09/2022 16:00	0.1	12.8	2,083.4	0.2	0.6	1	1	1
11/09/2022 17:00	0.2	12.5	2,158.5	0.4	0.6	1	1	1
11/09/2022 18:00	0.2	13.1	2,013.7	0.4	0.6	1	1	1
11/09/2022 19:00	0.2	13.3	1,976.3	0.4	0.6	1	1	1
11/09/2022 20:00	0.2	13.3	1,979.9	0.4	0.6	1	1	1
11/09/2022 21:00	0.2	13.3	2,004.2	0.4	0.6	1	1	1
11/09/2022 22:00	0.2	13.3	1,996.1	0.4	0.6	1	1	1
11/09/2022 23:00	0.2	13.3	1,995.5	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,988.0	0.4	0.6	24 #	24 #	19 #
Minimum:	0.1	12.0	1,617.1	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,298.8	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	0.2	13.3	1,995.0	0.4	0.6	1	1	1
11/10/2022 01:00	0.2	13.3	1,993.3	0.4	0.6	1	1	1
11/10/2022 02:00	0.2	13.3	1,991.3	0.4	0.6	1	1	1
11/10/2022 03:00	0.2	13.3	1,994.2	0.4	0.6	1	1	1
11/10/2022 04:00	0.2	13.0	2,084.2	0.4	0.6	1	1	1
11/10/2022 05:00	0.2	12.6	2,176.6	0.4	0.7	1	1	1
11/10/2022 06:00	0.4	12.0	2,294.6	0.5	0.7	1	1	1
11/10/2022 07:00	0.2	12.8	2,120.5	0.4	0.6	1	1	1
11/10/2022 08:00	0.2	13.3	1,983.8	0.4	0.6	1	1	1
11/10/2022 09:00	0.2	13.3	1,965.9	0.4	0.6	1	1	1
11/10/2022 10:00	0.5	14.0	1,725.4	0.5	0.5	1	1	0
11/10/2022 11:00	0.5	14.0	1,712.5	0.5	0.5	1	1	0
11/10/2022 12:00	0.5	14.0	1,711.2	0.5	0.5	1	1	0
11/10/2022 13:00	0.5	14.0	1,562.8	0.5	0.5	1	1	0
11/10/2022 14:00	0.5	14.0	1,712.6	0.5	0.5	1	1	0
11/10/2022 15:00	0.4	13.9	1,716.1	0.4	0.5	1	1	1
11/10/2022 16:00	0.2	12.7	2,137.8	0.4	0.6	1	1	1
11/10/2022 17:00	0.5	12.2	2,271.9	0.5	0.7	1	1	1
11/10/2022 18:00	0.5	12.2	2,274.5	0.5	0.7	1	1	1
11/10/2022 19:00	0.5	12.2	2,277.9	0.5	0.7	1	1	1
11/10/2022 20:00	0.5	12.2	2,279.9	0.5	0.7	1	1	1
11/10/2022 21:00	0.5	12.2	2,281.1	0.5	0.7	1	1	1
11/10/2022 22:00	0.5	12.2	2,281.8	0.5	0.7	1	1	1
11/10/2022 23:00	0.5	12.3	2,260.5	0.5	0.7	1	1	1
Average/Sum#:	0.4	13.0	2,033.6	0.5	0.6	24 #	24 #	19 #
Minimum:	0.2	12.0	1,562.8	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,294.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.5	12.2	2,281.0	0.5	0.7	1	1	1
11/11/2022 01:00	0.5	12.2	2,270.4	0.5	0.7	1	1	1
11/11/2022 02:00	0.4	12.7	2,154.0	0.5	0.6	1	1	1
11/11/2022 03:00	0.4	12.7	2,151.7	0.5	0.6	1	1	1
11/11/2022 04:00	0.5	12.3	2,272.4	0.5	0.7	1	1	1
11/11/2022 05:00	0.5	12.2	2,285.8	0.5	0.7	1	1	1
11/11/2022 06:00	0.5	12.3	2,289.0	0.5	0.7	1	1	1
11/11/2022 07:00	0.4	12.9	2,119.2	0.5	0.6	1	1	1
11/11/2022 08:00	0.2	13.4	1,954.8	0.4	0.6	1	1	1
11/11/2022 09:00	0.5	14.0	1,708.7	0.5	0.5	1	1	0
11/11/2022 10:00	0.5	14.0	1,712.4	0.5	0.5	1	1	0
11/11/2022 11:00	0.5	14.0	1,684.1	0.5	0.5	1	1	0
11/11/2022 12:00	0.5	14.0	1,684.6	0.5	0.5	1	1	0
11/11/2022 13:00	0.4	14.0	1,694.9	0.4	0.5	1	1	0
11/11/2022 14:00	0.4	14.0	1,573.1	0.4	0.5	1	1	0
11/11/2022 15:00	0.4	14.0	1,687.2	0.4	0.5	1	1	0
11/11/2022 16:00	0.2	13.1	1,984.8	0.4	0.6	1	1	1
11/11/2022 17:00	0.5	12.1	2,268.3	0.5	0.7	1	1	1
11/11/2022 18:00	0.5	12.1	2,263.3	0.5	0.7	1	1	1
11/11/2022 19:00	0.5	12.2	2,260.6	0.5	0.7	1	1	1
11/11/2022 20:00	0.5	12.2	2,253.7	0.5	0.7	1	1	1
11/11/2022 21:00	0.5	12.2	2,252.9	0.5	0.7	1	1	1
11/11/2022 22:00	0.5	12.3	2,246.0	0.5	0.7	1	1	1
11/11/2022 23:00	0.5	12.2	2,259.7	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.9	2,054.7	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.1	1,573.1	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,289.0	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.5	12.3	2,267.0	0.5	0.7	1	1	1
11/12/2022 01:00	0.5	12.3	2,275.6	0.5	0.7	1	1	1
11/12/2022 02:00	0.5	12.2	2,278.8	0.5	0.7	1	1	1
11/12/2022 03:00	0.5	12.2	2,280.4	0.5	0.7	1	1	1
11/12/2022 04:00	0.5	12.2	2,285.0	0.5	0.7	1	1	1
11/12/2022 05:00	0.5	12.2	2,285.3	0.5	0.7	1	1	1
11/12/2022 06:00	0.5	12.2	2,276.7	0.5	0.7	1	1	1
11/12/2022 07:00	0.2	12.8	2,103.5	0.4	0.6	1	1	1
11/12/2022 08:00	0.4	12.3	2,210.7	0.5	0.7	1	1	1
11/12/2022 09:00	0.5	13.8	1,747.7	0.5	0.5	1	1	1
11/12/2022 10:00	0.5	14.0	1,589.6	0.5	0.5	1	1	0
11/12/2022 11:00	0.5	14.0	1,554.3	0.5	0.5	1	1	0
11/12/2022 12:00	0.5	14.0	1,551.1	0.5	0.5	1	1	0
11/12/2022 13:00	0.5	14.0	1,570.2	0.5	0.5	1	1	0
11/12/2022 14:00	0.5	14.0	1,549.0	0.5	0.5	1	1	0
11/12/2022 15:00	0.4	13.9	1,791.5	0.4	0.5	1	1	1
11/12/2022 16:00	0.2	12.7	2,126.7	0.4	0.6	1	1	1
11/12/2022 17:00	0.5	12.2	2,245.9	0.5	0.7	1	1	1
11/12/2022 18:00	0.5	12.2	2,246.8	0.5	0.7	1	1	1
11/12/2022 19:00	0.5	12.2	2,251.2	0.5	0.7	1	1	1
11/12/2022 20:00	0.5	12.2	2,260.4	0.5	0.7	1	1	1
11/12/2022 21:00	0.5	12.2	2,259.8	0.5	0.7	1	1	1
11/12/2022 22:00	0.5	12.5	2,193.5	0.5	0.7	1	1	1
11/12/2022 23:00	0.5	12.5	2,190.6	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.8	2,058.0	0.5	0.6	24 #	24 #	19 #
Minimum:	0.2	12.2	1,549.0	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,285.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.4	12.6	2,180.8	0.5	0.7	1	1	1
11/13/2022 01:00	0.4	12.6	2,170.0	0.5	0.7	1	1	1
11/13/2022 02:00	0.4	12.7	2,165.0	0.5	0.6	1	1	1
11/13/2022 03:00	0.5	12.5	2,194.5	0.5	0.7	1	1	1
11/13/2022 04:00	0.5	12.6	2,189.7	0.5	0.7	1	1	1
11/13/2022 05:00	0.4	12.6	2,184.1	0.5	0.7	1	1	1
11/13/2022 06:00	0.5	12.5	2,195.0	0.5	0.7	1	1	1
11/13/2022 07:00	0.5	12.4	2,240.2	0.5	0.7	1	1	1
11/13/2022 08:00	0.5	13.1	1,966.4	0.5	0.6	1	1	1
11/13/2022 09:00	0.5	14.0	1,706.5	0.5	0.5	1	1	0
11/13/2022 10:00	0.5	14.0	1,707.9	0.5	0.5	1	1	0
11/13/2022 11:00	0.5	14.0	1,707.9	0.5	0.5	1	1	0
11/13/2022 12:00	0.5	14.0	1,706.8	0.5	0.5	1	1	0
11/13/2022 13:00	0.4	14.0	1,709.5	0.4	0.5	1	1	0
11/13/2022 14:00	0.4	14.0	1,677.7	0.4	0.5	1	1	0
11/13/2022 15:00	0.4	13.9	1,782.8	0.4	0.5	1	1	1
11/13/2022 16:00	0.2	12.5	2,138.8	0.4	0.6	1	1	1
11/13/2022 17:00	0.5	11.9	2,280.1	0.5	0.7	1	1	1
11/13/2022 18:00	0.5	11.9	2,280.5	0.5	0.7	1	1	1
11/13/2022 19:00	0.5	11.9	2,284.4	0.5	0.7	1	1	1
11/13/2022 20:00	0.5	11.9	2,288.2	0.5	0.7	1	1	1
11/13/2022 21:00	0.5	11.9	2,292.8	0.5	0.7	1	1	1
11/13/2022 22:00	0.5	11.9	2,295.1	0.5	0.7	1	1	1
11/13/2022 23:00	0.5	11.9	2,299.3	0.5	0.7	1	1	1
Average/Sum#:	0.5	12.8	2,068.5	0.5	0.6	24 #	24 #	18 #
Minimum:	0.2	11.9	1,677.7	0.4	0.5	1	1	0
Maximum:	0.5	14.0	2,299.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.5	11.9	2,298.5	0.5	0.7	1	1	1
11/14/2022 01:00	0.5	12.0	2,289.5	0.5	0.7	1	1	1
11/14/2022 02:00	0.4	12.1	2,286.2	0.5	0.7	1	1	1
11/14/2022 03:00	0.2	12.6	2,166.7	0.4	0.7	1	1	1
11/14/2022 04:00	0.4	12.3	2,241.5	0.5	0.7	1	1	1
11/14/2022 05:00	0.4	12.0	2,303.2	0.5	0.7	1	1	1
11/14/2022 06:00	0.4	12.1	2,299.4	0.5	0.7	1	1	1
11/14/2022 07:00	0.2	12.5	2,194.7	0.4	0.7	1	1	1
11/14/2022 08:00	0.2	12.7	2,159.1	0.4	0.6	1	1	1
11/14/2022 09:00	0.2	12.6	2,167.7	0.4	0.7	1	1	1
11/14/2022 10:00	0.2	12.6	2,158.5	0.4	0.6	1	1	1
11/14/2022 11:00	0.2	12.6	2,130.2	0.4	0.6	1	1	1
11/14/2022 12:00	0.2	12.6	2,126.0	0.4	0.6	1	1	1
11/14/2022 13:00	0.4	12.5	2,154.3	0.5	0.6	1	1	1
11/14/2022 14:00	0.4	12.4	2,150.3	0.5	0.6	1	1	1
11/14/2022 15:00	0.2	12.8	2,079.7	0.4	0.6	1	1	1
11/14/2022 16:00	0.4	12.0	2,254.0	0.5	0.7	1	1	1
11/14/2022 17:00	0.4	12.3	2,198.1	0.5	0.7	1	1	1
11/14/2022 18:00	0.4	12.4	2,182.1	0.5	0.7	1	1	1
11/14/2022 19:00	0.4	12.1	2,240.9	0.5	0.7	1	1	1
11/14/2022 20:00	0.4	12.1	2,243.9	0.5	0.7	1	1	1
11/14/2022 21:00	0.5	12.0	2,288.0	0.5	0.7	1	1	1
11/14/2022 22:00	0.5	12.0	2,288.7	0.5	0.7	1	1	1
11/14/2022 23:00	0.5	12.1	2,271.0	0.5	0.7	1	1	1
Average/Sum#:	0.4	12.3	2,215.5	0.5	0.7	24 #	24 #	24 #
Minimum:	0.2	11.9	2,079.7	0.4	0.6	1	1	1
Maximum:	0.5	12.8	2,303.2	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	0.5	12.0	2,301.3	0.5	0.7	1	1	1
11/15/2022 01:00	0.5	11.9	2,300.4	0.5	0.7	1	1	1
11/15/2022 02:00	0.5	12.0	2,290.8	0.5	0.7	1	1	1
11/15/2022 03:00	0.5	12.0	2,281.4	0.5	0.7	1	1	1
11/15/2022 04:00	0.5	12.1	2,264.5	0.5	0.7	1	1	1
11/15/2022 05:00	0.4	12.2	2,243.0	0.5	0.7	1	1	1
11/15/2022 06:00	0.4	12.3	2,213.0	0.5	0.7	1	1	1
11/15/2022 07:00	0.4	12.4	2,183.3	0.5	0.7	1	1	1
11/15/2022 08:00	0.4	12.6	2,133.4	0.5	0.6	1	1	1
11/15/2022 09:00	0.4	12.7	2,108.5	0.5	0.6	1	1	1
11/15/2022 10:00	0.2	12.6	2,141.8	0.4	0.6	1	1	1
11/15/2022 11:00	0.2	12.9	2,056.8	0.4	0.6	1	1	1
11/15/2022 12:00	0.1	13.3	1,977.9	0.2	0.6	1	1	1
11/15/2022 13:00	0.1	13.3	1,979.2	0.2	0.6	1	1	1
11/15/2022 14:00	0.1	13.3	1,979.2	0.2	0.6	1	1	1
11/15/2022 15:00	0.1	13.1	2,018.4	0.2	0.6	1	1	1
11/15/2022 16:00	0.2	12.6	2,149.3	0.4	0.6	1	1	1
11/15/2022 17:00	0.2	12.5	2,177.7	0.4	0.7	1	1	1
11/15/2022 18:00	0.2	12.4	2,193.7	0.4	0.7	1	1	1
11/15/2022 19:00	0.4	12.4	2,188.4	0.5	0.7	1	1	1
11/15/2022 20:00	0.4	12.3	2,196.2	0.5	0.7	1	1	1
11/15/2022 21:00	0.5	12.1	2,244.0	0.5	0.7	1	1	1
11/15/2022 22:00	0.4	12.4	2,174.7	0.5	0.7	1	1	1
11/15/2022 23:00	0.4	12.5	2,174.2	0.5	0.7	1	1	1
Average/Sum#:	0.3	12.5	2,165.5	0.4	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,977.9	0.2	0.6	1	1	1
Maximum:	0.5	13.3	2,301.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2022 00:00	0.4	12.5	2,168.0	0.5	0.7	1	1	1
11/16/2022 01:00	0.4	12.6	2,140.8	0.5	0.6	1	1	1
11/16/2022 02:00	0.4	12.5	2,165.7	0.5	0.6	1	1	1
11/16/2022 03:00	0.4	12.5	2,167.5	0.5	0.7	1	1	1
11/16/2022 04:00	0.4	12.4	2,178.7	0.5	0.7	1	1	1
11/16/2022 05:00	0.4	12.5	2,174.9	0.5	0.7	1	1	1
11/16/2022 06:00	0.4	12.5	2,168.0	0.5	0.7	1	1	1
11/16/2022 07:00	0.5	12.2	2,241.0	0.5	0.7	1	1	1
11/16/2022 08:00	0.2	13.2	1,987.0	0.4	0.6	1	1	1
11/16/2022 09:00	0.2	13.2	2,018.8	0.4	0.6	1	1	1
11/16/2022 10:00	0.1	13.3	1,985.3	0.2	0.6	1	1	1
11/16/2022 11:00	0.7	0.0	1,986.8	0.7	0.6	1	1	1
11/16/2022 12:00	0.7	13.2	1,985.9	0.7	0.6	1	1	1
11/16/2022 13:00	0.7	13.2	1,986.9	0.7	0.6	1	1	1
11/16/2022 14:00	0.7	13.2	1,985.4	0.7	0.6	1	1	1
11/16/2022 15:00	0.7	12.6	2,113.3	0.7	0.6	1	1	1
11/16/2022 16:00	0.7	12.3	2,177.2	0.7	0.7	1	1	1
11/16/2022 17:00	0.7	12.3	2,192.8	0.7	0.7	1	1	1
11/16/2022 18:00	0.7	11.9	2,278.4	0.7	0.7	1	1	1
11/16/2022 19:00	0.7	11.9	2,286.5	0.7	0.7	1	1	1
11/16/2022 20:00	0.7	11.9	2,286.7	0.7	0.7	1	1	1
11/16/2022 21:00	0.7	12.0	2,266.9	0.7	0.7	1	1	1
11/16/2022 22:00	0.7	12.2	2,230.9	0.7	0.7	1	1	1
11/16/2022 23:00	0.7	12.0	2,257.4	0.7	0.7	1	1	1
Average/Sum#:	0.5	12.5	2,143.0	0.6	0.7	24 #	24 #	24 #
Minimum:	0.1	11.9	1,985.3	0.2	0.6	1	1	1
Maximum:	0.7	13.3	2,286.7	0.7	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.7	12.4	2,177.8	0.7	0.7	1	1	1
11/17/2022 01:00	0.7	12.3	2,181.0	0.7	0.7	1	1	1
11/17/2022 02:00	0.7	12.4	2,165.8	0.7	0.6	1	1	1
11/17/2022 03:00	0.7	12.5	2,166.0	0.7	0.6	1	1	1
11/17/2022 04:00	0.7	12.5	2,169.1	0.7	0.7	1	1	1
11/17/2022 05:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
11/17/2022 06:00	0.7	11.9	2,291.5	0.7	0.7	1	1	1
11/17/2022 07:00	0.7	12.4	2,182.1	0.7	0.7	1	1	1
11/17/2022 08:00	0.7	13.1	1,994.1	0.7	0.6	1	1	1
11/17/2022 09:00	0.7	12.5	2,150.8	0.7	0.6	1	1	1
11/17/2022 10:00	0.7	12.5	2,143.2	0.7	0.6	1	1	1
11/17/2022 11:00	0.7	12.3	2,174.6	0.7	0.7	1	1	1
11/17/2022 12:00	0.7	12.1	2,198.3	0.7	0.7	1	1	1
11/17/2022 13:00	0.7	12.2	2,183.9	0.7	0.7	1	1	1
11/17/2022 14:00	0.7	12.9	2,015.7	0.7	0.6	1	1	1
11/17/2022 15:00	0.7	12.4	2,130.6	0.7	0.6	1	1	1
11/17/2022 16:00	0.7	11.9	2,243.2	0.7	0.7	1	1	1
11/17/2022 17:00	0.7	11.8	2,276.9	0.7	0.7	1	1	1
11/17/2022 18:00	0.7	11.8	2,275.4	0.7	0.7	1	1	1
11/17/2022 19:00	0.7	11.8	2,278.6	0.7	0.7	1	1	1
11/17/2022 20:00	0.7	11.8	2,280.8	0.7	0.7	1	1	1
11/17/2022 21:00	0.7	11.8	2,282.5	0.7	0.7	1	1	1
11/17/2022 22:00	0.7	11.9	2,269.7	0.7	0.7	1	1	1
11/17/2022 23:00	0.7	12.2	2,226.9	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,193.3	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.8	1,994.1	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,291.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.7	12.4	2,177.7	0.7	0.7	1	1	1
11/18/2022 01:00	0.7	12.3	2,188.2	0.7	0.7	1	1	1
11/18/2022 02:00	0.7	12.2	2,194.3	0.7	0.7	1	1	1
11/18/2022 03:00	0.7	12.3	2,188.5	0.7	0.7	1	1	1
11/18/2022 04:00	0.7	12.2	2,185.6	0.7	0.7	1	1	1
11/18/2022 05:00	0.7	12.3	2,173.7	0.7	0.7	1	1	1
11/18/2022 06:00	0.7	12.4	2,160.2	0.7	0.6	1	1	1
11/18/2022 07:00	0.7	12.0	2,255.3	0.7	0.7	1	1	1
11/18/2022 08:00	0.7	12.3	2,177.7	0.7	0.7	1	1	1
11/18/2022 09:00	0.7	12.3	2,185.0	0.7	0.7	1	1	1
11/18/2022 10:00	0.7	12.2	2,190.4	0.7	0.7	1	1	1
11/18/2022 11:00	0.7	12.5	2,120.3	0.7	0.6	1	1	1
11/18/2022 12:00	0.7	13.1	1,970.2	0.7	0.6	1	1	1
11/18/2022 13:00	0.7	13.1	1,973.1	0.7	0.6	1	1	1
11/18/2022 14:00	0.7	13.1	1,974.5	0.7	0.6	1	1	1
11/18/2022 15:00	0.7	12.8	2,058.5	0.7	0.6	1	1	1
11/18/2022 16:00	0.7	12.0	2,235.0	0.7	0.7	1	1	1
11/18/2022 17:00	0.7	11.9	2,257.9	0.7	0.7	1	1	1
11/18/2022 18:00	0.7	12.0	2,260.4	0.7	0.7	1	1	1
11/18/2022 19:00	0.7	12.0	2,263.4	0.7	0.7	1	1	1
11/18/2022 20:00	0.7	12.1	2,228.1	0.7	0.7	1	1	1
11/18/2022 21:00	0.7	12.3	2,181.4	0.7	0.7	1	1	1
11/18/2022 22:00	0.7	12.5	2,145.0	0.7	0.6	1	1	1
11/18/2022 23:00	0.7	12.1	2,239.0	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,166.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.2	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,263.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.7	12.3	2,194.0	0.7	0.7	1	1	1
11/19/2022 01:00	0.7	12.4	2,172.4	0.7	0.7	1	1	1
11/19/2022 02:00	0.7	12.5	2,168.7	0.7	0.7	1	1	1
11/19/2022 03:00	0.7	12.6	2,144.8	0.7	0.6	1	1	1
11/19/2022 04:00	0.7	12.2	2,238.2	0.7	0.7	1	1	1
11/19/2022 05:00	0.7	12.1	2,271.6	0.7	0.7	1	1	1
11/19/2022 06:00	0.7	12.3	2,218.2	0.7	0.7	1	1	1
11/19/2022 07:00	0.7	12.6	2,132.0	0.7	0.6	1	1	1
11/19/2022 08:00	0.7	13.2	1,978.8	0.7	0.6	1	1	1
11/19/2022 09:00	0.7	13.2	1,978.8	0.7	0.6	1	1	1
11/19/2022 10:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
11/19/2022 11:00	0.7	13.2	1,970.6	0.7	0.6	1	1	1
11/19/2022 12:00	0.7	13.1	1,971.0	0.7	0.6	1	1	1
11/19/2022 13:00	0.7	13.1	1,971.9	0.7	0.6	1	1	1
11/19/2022 14:00	0.7	13.1	1,970.2	0.7	0.6	1	1	1
11/19/2022 15:00	0.7	12.8	2,050.9	0.7	0.6	1	1	1
11/19/2022 16:00	0.7	12.2	2,184.1	0.7	0.7	1	1	1
11/19/2022 17:00	0.7	12.1	2,201.8	0.7	0.7	1	1	1
11/19/2022 18:00	0.7	12.2	2,197.4	0.7	0.7	1	1	1
11/19/2022 19:00	0.7	11.9	2,260.7	0.7	0.7	1	1	1
11/19/2022 20:00	0.7	12.1	2,219.4	0.7	0.7	1	1	1
11/19/2022 21:00	0.7	12.3	2,177.5	0.7	0.7	1	1	1
11/19/2022 22:00	0.7	12.5	2,175.6	0.7	0.7	1	1	1
11/19/2022 23:00	0.7	12.6	2,143.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,123.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.2	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,271.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.7	12.7	2,106.9	0.7	0.6	1	1	1
11/20/2022 01:00	0.7	12.8	2,078.9	0.7	0.6	1	1	1
11/20/2022 02:00	0.7	12.9	2,062.3	0.7	0.6	1	1	1
11/20/2022 03:00	0.7	12.9	2,063.5	0.7	0.6	1	1	1
11/20/2022 04:00	0.7	12.9	2,070.5	0.7	0.6	1	1	1
11/20/2022 05:00	0.7	12.5	2,183.5	0.7	0.7	1	1	1
11/20/2022 06:00	0.7	12.1	2,276.9	0.7	0.7	1	1	1
11/20/2022 07:00	0.7	12.6	2,113.0	0.7	0.6	1	1	1
11/20/2022 08:00	0.6	13.9	1,703.8	0.6	0.5	1	1	0
11/20/2022 09:00	0.6	13.9	1,708.6	0.6	0.5	1	1	0
11/20/2022 10:00	0.6	13.9	1,565.5	0.6	0.5	1	1	0
11/20/2022 11:00	0.6	13.9	1,563.6	0.6	0.5	1	1	0
11/20/2022 12:00	0.6	14.0	1,533.4	0.6	0.5	1	1	0
11/20/2022 13:00	0.6	14.0	1,523.9	0.6	0.5	1	1	0
11/20/2022 14:00	0.7	13.8	1,701.2	0.7	0.5	1	1	1
11/20/2022 15:00	0.7	13.8	1,723.3	0.7	0.5	1	1	1
11/20/2022 16:00	0.7	12.4	2,162.3	0.7	0.6	1	1	1
11/20/2022 17:00	0.7	11.9	2,276.4	0.7	0.7	1	1	1
11/20/2022 18:00	0.7	11.9	2,265.8	0.7	0.7	1	1	1
11/20/2022 19:00	0.7	11.9	2,256.8	0.7	0.7	1	1	1
11/20/2022 20:00	0.7	11.9	2,261.0	0.7	0.7	1	1	1
11/20/2022 21:00	0.7	12.2	2,204.5	0.7	0.7	1	1	1
11/20/2022 22:00	0.7	12.4	2,168.3	0.7	0.7	1	1	1
11/20/2022 23:00	0.7	12.5	2,153.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,988.6	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,523.9	0.6	0.5	1	1	0
Maximum:	0.7	14.0	2,276.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	0.7	12.5	2,160.3	0.7	0.6	1	1	1
11/21/2022 01:00	0.7	12.6	2,137.5	0.7	0.6	1	1	1
11/21/2022 02:00	0.7	12.9	2,062.0	0.7	0.6	1	1	1
11/21/2022 03:00	0.7	12.4	2,174.4	0.7	0.7	1	1	1
11/21/2022 04:00	0.7	12.1	2,256.2	0.7	0.7	1	1	1
11/21/2022 05:00	0.7	12.1	2,267.1	0.7	0.7	1	1	1
11/21/2022 06:00	0.7	12.0	2,284.1	0.7	0.7	1	1	1
11/21/2022 07:00	0.7	12.5	2,150.4	0.7	0.6	1	1	1
11/21/2022 08:00	0.7	13.3	1,968.4	0.7	0.6	1	1	1
11/21/2022 09:00	0.7	13.3	1,968.7	0.7	0.6	1	1	1
11/21/2022 10:00	0.7	13.2	1,969.1	0.7	0.6	1	1	1
11/21/2022 11:00	0.7	13.2	1,979.0	0.7	0.6	1	1	1
11/21/2022 12:00	0.7	13.1	1,980.5	0.7	0.6	1	1	1
11/21/2022 13:00	0.7	13.1	1,980.3	0.7	0.6	1	1	1
11/21/2022 14:00	0.7	12.3	2,160.9	0.7	0.6	1	1	1
11/21/2022 15:00	0.7	11.9	2,251.4	0.7	0.7	1	1	1
11/21/2022 16:00	0.7	12.1	2,226.7	0.7	0.7	1	1	1
11/21/2022 17:00	0.7	11.9	2,273.3	0.7	0.7	1	1	1
11/21/2022 18:00	0.7	12.0	2,283.4	0.7	0.7	1	1	1
11/21/2022 19:00	0.7	11.9	2,265.1	0.7	0.7	1	1	1
11/21/2022 20:00	0.7	11.9	2,265.4	0.7	0.7	1	1	1
11/21/2022 21:00	0.7	11.9	2,267.8	0.7	0.7	1	1	1
11/21/2022 22:00	0.7	11.9	2,264.5	0.7	0.7	1	1	1
11/21/2022 23:00	0.7	12.1	2,228.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,159.4	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,968.4	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,284.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	0.7	12.4	2,154.9	0.7	0.6	1	1	1
11/22/2022 01:00	0.7	12.6	2,130.2	0.7	0.6	1	1	1
11/22/2022 02:00	0.7	12.7	2,101.3	0.7	0.6	1	1	1
11/22/2022 03:00	0.7	13.1	1,980.1	0.7	0.6	1	1	1
11/22/2022 04:00	0.7	13.2	1,985.4	0.7	0.6	1	1	1
11/22/2022 05:00	0.7	12.8	2,071.1	0.7	0.6	1	1	1
11/22/2022 06:00	0.7	12.5	2,156.2	0.7	0.6	1	1	1
11/22/2022 07:00	0.7	12.8	2,097.2	0.7	0.6	1	1	1
11/22/2022 08:00	0.7	12.9	2,055.9	0.7	0.6	1	1	1
11/22/2022 09:00	0.7	13.8	1,648.0	0.7	0.5	1	1	1
11/22/2022 10:00	0.6	13.8	1,674.5	0.6	0.5	1	1	0
11/22/2022 11:00	0.6	13.9	1,795.0	0.6	0.5	1	1	0
11/22/2022 12:00	0.6	13.9	1,556.4	0.6	0.5	1	1	0
11/22/2022 13:00	0.6	13.9	1,617.1	0.6	0.5	1	1	0
11/22/2022 14:00	0.6	13.8	1,779.5	0.6	0.5	1	1	0
11/22/2022 15:00	0.6	13.8	1,781.6	0.6	0.5	1	1	0
11/22/2022 16:00	0.7	13.2	1,919.5	0.7	0.6	1	1	1
11/22/2022 17:00	0.7	12.3	2,191.5	0.7	0.7	1	1	1
11/22/2022 18:00	0.7	12.8	2,055.9	0.7	0.6	1	1	1
11/22/2022 19:00	0.7	13.1	1,999.0	0.7	0.6	1	1	1
11/22/2022 20:00	0.7	12.5	2,155.9	0.7	0.6	1	1	1
11/22/2022 21:00	0.7	12.9	2,034.0	0.7	0.6	1	1	1
11/22/2022 22:00	0.7	12.9	2,045.3	0.7	0.6	1	1	1
11/22/2022 23:00	0.7	13.2	1,973.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,956.6	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.3	1,556.4	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,191.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	0.7	13.2	1,974.3	0.7	0.6	1	1	1
11/23/2022 01:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
11/23/2022 02:00	0.7	13.2	1,973.8	0.7	0.6	1	1	1
11/23/2022 03:00	0.7	13.2	1,976.4	0.7	0.6	1	1	1
11/23/2022 04:00	0.7	13.2	1,982.4	0.7	0.6	1	1	1
11/23/2022 05:00	0.7	12.7	2,074.5	0.7	0.6	1	1	1
11/23/2022 06:00	0.7	12.7	2,056.8	0.7	0.6	1	1	1
11/23/2022 07:00	0.7	12.7	2,111.0	0.7	0.6	1	1	1
11/23/2022 08:00	0.7	13.0	2,004.8	0.7	0.6	1	1	1
11/23/2022 09:00	0.6	13.9	1,703.0	0.6	0.5	1	1	0
11/23/2022 10:00	0.6	13.9	1,554.3	0.6	0.5	1	1	0
11/23/2022 11:00	0.6	13.9	1,550.6	0.6	0.5	1	1	0
11/23/2022 12:00	0.6	14.0	1,422.8	0.6	0.4	1	1	0
11/23/2022 13:00	0.6	14.0	1,559.1	0.6	0.5	1	1	0
11/23/2022 14:00	0.6	14.0	1,630.2	0.6	0.5	1	1	0
11/23/2022 15:00	0.7	13.9	1,636.5	0.7	0.5	1	1	1
11/23/2022 16:00	0.5	12.6	2,110.6	0.5	0.6	1	1	1
11/23/2022 17:00	0.7	12.3	2,185.3	0.7	0.7	1	1	1
11/23/2022 18:00	0.7	12.7	2,100.4	0.7	0.6	1	1	1
11/23/2022 19:00	0.5	12.9	2,063.5	0.5	0.6	1	1	1
11/23/2022 20:00	0.7	12.3	2,182.9	0.7	0.7	1	1	1
11/23/2022 21:00	0.7	12.3	2,201.9	0.7	0.7	1	1	1
11/23/2022 22:00	0.7	12.4	2,176.3	0.7	0.7	1	1	1
11/23/2022 23:00	0.7	12.4	2,171.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	13.1	1,932.4	0.7	0.6	24 #	24 #	18 #
Minimum:	0.5	12.3	1,422.8	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,201.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	0.5	13.1	1,990.6	0.5	0.6	1	1	1
11/24/2022 01:00	0.4	13.2	1,976.9	0.4	0.6	1	1	1
11/24/2022 02:00	0.4	13.2	1,976.7	0.4	0.6	1	1	1
11/24/2022 03:00	0.7	13.1	2,019.5	0.7	0.6	1	1	1
11/24/2022 04:00	0.5	13.0	2,026.8	0.5	0.6	1	1	1
11/24/2022 05:00	0.7	12.8	2,102.0	0.7	0.6	1	1	1
11/24/2022 06:00	0.7	12.2	2,191.0	0.7	0.7	1	1	1
11/24/2022 07:00	0.7	12.5	2,097.3	0.7	0.6	1	1	1
11/24/2022 08:00	0.6	13.9	1,712.8	0.6	0.5	1	1	0
11/24/2022 09:00	0.6	13.9	1,696.5	0.6	0.5	1	1	0
11/24/2022 10:00	0.6	13.9	1,703.7	0.6	0.5	1	1	0
11/24/2022 11:00	0.6	14.0	1,549.0	0.6	0.5	1	1	0
11/24/2022 12:00	0.6	14.0	1,349.8	0.6	0.4	1	1	0
11/24/2022 13:00	0.6	14.0	1,345.2	0.6	0.4	1	1	0
11/24/2022 14:00	0.6	14.0	1,551.3	0.6	0.5	1	1	0
11/24/2022 15:00	0.6	14.0	1,440.8	0.6	0.4	1	1	0
11/24/2022 16:00	0.6	13.9	1,756.8	0.6	0.5	1	1	0
11/24/2022 17:00	0.6	13.9	1,755.3	0.6	0.5	1	1	0
11/24/2022 18:00	0.6	13.9	1,738.1	0.6	0.5	1	1	0
11/24/2022 19:00	0.6	13.9	1,735.7	0.6	0.5	1	1	0
11/24/2022 20:00	0.6	13.9	1,736.2	0.6	0.5	1	1	0
11/24/2022 21:00	0.6	13.9	1,739.4	0.6	0.5	1	1	0
11/24/2022 22:00	0.6	13.9	1,742.8	0.6	0.5	1	1	0
11/24/2022 23:00	0.6	13.9	1,744.5	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.6	1,778.3	0.6	0.5	24 #	24 #	8 #
Minimum:	0.4	12.2	1,345.2	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,191.0	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.6	13.9	1,746.5	0.6	0.5	1	1	0
11/25/2022 01:00	0.6	13.9	1,746.8	0.6	0.5	1	1	0
11/25/2022 02:00	0.6	13.9	1,749.6	0.6	0.5	1	1	0
11/25/2022 03:00	0.6	13.9	1,753.4	0.6	0.5	1	1	0
11/25/2022 04:00	0.6	13.9	1,763.9	0.6	0.5	1	1	0
11/25/2022 05:00	0.6	13.9	1,761.2	0.6	0.5	1	1	0
11/25/2022 06:00	0.6	13.9	1,755.3	0.6	0.5	1	1	0
11/25/2022 07:00	0.6	13.9	1,755.9	0.6	0.5	1	1	0
11/25/2022 08:00	0.7	13.5	1,878.1	0.7	0.6	1	1	1
11/25/2022 09:00	0.7	13.2	1,927.0	0.7	0.6	1	1	1
11/25/2022 10:00	0.6	13.9	1,661.2	0.6	0.5	1	1	0
11/25/2022 11:00	0.6	13.9	1,538.8	0.6	0.5	1	1	0
11/25/2022 12:00	0.6	13.9	1,565.4	0.6	0.5	1	1	0
11/25/2022 13:00	0.6	13.9	1,534.3	0.6	0.5	1	1	0
11/25/2022 14:00	0.6	13.9	1,521.7	0.6	0.5	1	1	0
11/25/2022 15:00	0.7	13.8	1,630.3	0.7	0.5	1	1	1
11/25/2022 16:00	0.5	12.6	2,098.5	0.5	0.6	1	1	1
11/25/2022 17:00	0.7	12.5	2,115.1	0.7	0.6	1	1	1
11/25/2022 18:00	0.7	13.1	1,976.4	0.7	0.6	1	1	1
11/25/2022 19:00	0.7	13.2	1,966.1	0.7	0.6	1	1	1
11/25/2022 20:00	0.7	13.2	1,974.0	0.7	0.6	1	1	1
11/25/2022 21:00	0.7	13.2	1,977.2	0.7	0.6	1	1	1
11/25/2022 22:00	0.7	12.6	2,131.7	0.7	0.6	1	1	1
11/25/2022 23:00	0.7	12.7	2,091.1	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,817.5	0.6	0.5	24 #	24 #	11 #
Minimum:	0.5	12.5	1,521.7	0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,131.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	0.7	13.0	2,033.3	0.7	0.6	1	1	1
11/26/2022 01:00	0.7	12.8	2,080.1	0.7	0.6	1	1	1
11/26/2022 02:00	0.0	13.9	1,574.8	0.0	0.5	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.2	1,896.1	0.5	0.6	3 #	2 #	3 #
Minimum:	0.0	12.8	1,574.8	0.0	0.5	0	0	0
Maximum:	0.7	13.9	2,080.1	0.7	0.6	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	17.7	330.2	0.0	0.1	1	0	0
11/27/2022 22:00	0.0	17.3	396.9	0.0	0.1	1	0	0
11/27/2022 23:00	0.0	15.5	901.6	0.0	0.3	1	0	0
Average/Sum#:	0.0	16.8	542.9	0.0	0.2	3 #	0 #	0 #
Minimum:	0.0	15.5	330.2	0.0	0.1	0	0	0
Maximum:	0.0	17.7	901.6	0.0	0.3	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.6	13.9	1,574.9	0.6	0.5	1	1	0
11/28/2022 01:00	0.6	13.9	1,487.8	0.6	0.4	1	1	0
11/28/2022 02:00	0.6	13.8	1,745.5	0.6	0.5	1	1	0
11/28/2022 03:00	0.6	13.9	1,530.8	0.6	0.5	1	1	0
11/28/2022 04:00	0.6	13.9	1,710.5	0.6	0.5	1	1	0
11/28/2022 05:00	0.7	13.8	1,642.2	0.7	0.5	1	1	1
11/28/2022 06:00	0.7	12.3	2,173.2	0.7	0.7	1	1	1
11/28/2022 07:00	0.7	12.0	2,270.2	0.7	0.7	1	1	1
11/28/2022 08:00	0.7	13.1	1,972.1	0.7	0.6	1	1	1
11/28/2022 09:00	0.6	13.9	1,601.7	0.6	0.5	1	1	0
11/28/2022 10:00	0.6	13.9	1,699.0	0.6	0.5	1	1	0
11/28/2022 11:00	0.6	13.9	1,519.7	0.6	0.5	1	1	0
11/28/2022 12:00	0.6	13.9	1,566.4	0.6	0.5	1	1	0
11/28/2022 13:00	0.6	13.9	1,634.0	0.6	0.5	1	1	0
11/28/2022 14:00	0.6	13.9	1,616.9	0.6	0.5	1	1	0
11/28/2022 15:00	0.7	13.8	1,620.0	0.7	0.5	1	1	1
11/28/2022 16:00	0.7	12.8	2,041.1	0.7	0.6	1	1	1
11/28/2022 17:00	0.7	12.6	2,100.3	0.7	0.6	1	1	1
11/28/2022 18:00	0.7	13.1	1,988.5	0.7	0.6	1	1	1
11/28/2022 19:00	0.7	13.2	1,967.8	0.7	0.6	1	1	1
11/28/2022 20:00	0.7	12.7	2,094.0	0.7	0.6	1	1	1
11/28/2022 21:00	0.7	12.1	2,238.4	0.7	0.7	1	1	1
11/28/2022 22:00	0.7	12.7	2,095.4	0.7	0.6	1	1	1
11/28/2022 23:00	0.7	13.1	1,996.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.3	1,828.6	0.7	0.6	24 #	24 #	13 #
Minimum:	0.6	12.0	1,487.8	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,270.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.7	12.5	2,165.2	0.7	0.6	1	1	1
11/29/2022 01:00	0.7	12.3	2,212.8	0.7	0.7	1	1	1
11/29/2022 02:00	0.7	12.4	2,192.2	0.7	0.7	1	1	1
11/29/2022 03:00	0.7	12.8	2,088.0	0.7	0.6	1	1	1
11/29/2022 04:00	0.7	12.5	2,152.8	0.7	0.6	1	1	1
11/29/2022 05:00	0.7	12.4	2,205.6	0.7	0.7	1	1	1
11/29/2022 06:00	0.7	11.9	2,296.9	0.7	0.7	1	1	1
11/29/2022 07:00	0.7	11.9	2,304.2	0.7	0.7	1	1	1
11/29/2022 08:00	0.7	12.0	2,274.9	0.7	0.7	1	1	1
11/29/2022 09:00	0.7	12.4	2,174.5	0.7	0.7	1	1	1
11/29/2022 10:00	0.7	12.4	2,167.1	0.7	0.7	1	1	1
11/29/2022 11:00	0.7	12.4	2,157.9	0.7	0.6	1	1	1
11/29/2022 12:00	0.7	12.4	2,151.2	0.7	0.6	1	1	1
11/29/2022 13:00	0.7	12.4	2,151.4	0.7	0.6	1	1	1
11/29/2022 14:00	0.7	12.4	2,156.0	0.7	0.6	1	1	1
11/29/2022 15:00	0.7	12.3	2,170.6	0.7	0.7	1	1	1
11/29/2022 16:00	0.7	11.9	2,281.5	0.7	0.7	1	1	1
11/29/2022 17:00	0.7	11.9	2,289.6	0.7	0.7	1	1	1
11/29/2022 18:00	0.7	11.9	2,292.8	0.7	0.7	1	1	1
11/29/2022 19:00	0.7	11.9	2,290.5	0.7	0.7	1	1	1
11/29/2022 20:00	0.7	12.0	2,289.3	0.7	0.7	1	1	1
11/29/2022 21:00	0.7	11.9	2,292.2	0.7	0.7	1	1	1
11/29/2022 22:00	0.7	12.0	2,297.8	0.7	0.7	1	1	1
11/29/2022 23:00	0.7	12.0	2,296.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,223.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	2,088.0	0.7	0.6	1	1	1
Maximum:	0.7	12.8	2,304.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	0.7	12.6	2,170.7	0.7	0.7	1	1	1
11/30/2022 01:00	0.7	12.6	2,153.2	0.7	0.6	1	1	1
11/30/2022 02:00	0.7	12.6	2,153.8	0.7	0.6	1	1	1
11/30/2022 03:00	0.7	12.6	2,151.0	0.7	0.6	1	1	1
11/30/2022 04:00	0.7	12.6	2,169.6	0.7	0.7	1	1	1
11/30/2022 05:00	0.7	12.6	2,169.3	0.7	0.7	1	1	1
11/30/2022 06:00	0.7	12.1	2,268.0	0.7	0.7	1	1	1
11/30/2022 07:00	0.7	12.6	2,158.0	0.7	0.6	1	1	1
11/30/2022 08:00	0.5	13.3	1,984.3	0.5	0.6	1	1	1
11/30/2022 09:00	0.5	13.2	1,998.7	0.5	0.6	1	1	1
11/30/2022 10:00	0.5	13.2	1,980.3	0.5	0.6	1	1	1
11/30/2022 11:00	0.5	13.2	1,984.1	0.5	0.6	1	1	1
11/30/2022 12:00	0.5	13.2	1,983.8	0.5	0.6	1	1	1
11/30/2022 13:00	0.7	13.1	1,978.8	0.7	0.6	1	1	1
11/30/2022 14:00	0.7	12.5	2,132.5	0.7	0.6	1	1	1
11/30/2022 15:00	0.7	12.4	2,140.8	0.7	0.6	1	1	1
11/30/2022 16:00	0.7	11.9	2,251.8	0.7	0.7	1	1	1
11/30/2022 17:00	0.7	11.7	2,297.3	0.7	0.7	1	1	1
11/30/2022 18:00	0.7	11.8	2,289.4	0.7	0.7	1	1	1
11/30/2022 19:00	0.7	11.8	2,289.6	0.7	0.7	1	1	1
11/30/2022 20:00	0.7	11.8	2,288.9	0.7	0.7	1	1	1
11/30/2022 21:00	0.7	12.0	2,256.6	0.7	0.7	1	1	1
11/30/2022 22:00	0.7	12.6	2,106.9	0.7	0.6	1	1	1
11/30/2022 23:00	0.0	13.8	1,590.5	0.0	0.5	1	0	1
Average/Sum#:	0.6	12.6	2,122.8	0.6	0.6	24 #	23 #	24 #
Minimum:	0.0	11.7	1,590.5	0.0	0.5	1	0	1
Maximum:	0.7	13.8	2,297.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	17.9	301.9	0.0	0.1	1	0	0
12/01/2022 03:00	0.0	14.8	1,144.0	0.0	0.3	1	0	0
12/01/2022 04:00	0.6	13.8	1,703.6	0.6	0.5	1	1	0
12/01/2022 05:00	0.7	13.5	1,790.5	0.7	0.5	1	1	1
12/01/2022 06:00	0.7	11.7	2,291.0	0.7	0.7	1	1	1
12/01/2022 07:00	0.7	11.6	2,326.9	0.7	0.7	1	1	1
12/01/2022 08:00	0.7	12.1	2,203.6	0.7	0.7	1	1	1
12/01/2022 09:00	0.7	12.2	2,190.4	0.7	0.7	1	1	1
12/01/2022 10:00	0.7	12.2	2,195.3	0.7	0.7	1	1	1
12/01/2022 11:00	0.7	12.3	2,173.6	0.7	0.7	1	1	1
12/01/2022 12:00	0.7	12.2	2,176.8	0.7	0.7	1	1	1
12/01/2022 13:00	0.7	12.2	2,177.9	0.7	0.7	1	1	1
12/01/2022 14:00	0.7	12.1	2,192.3	0.7	0.7	1	1	1
12/01/2022 15:00	0.7	11.6	2,311.4	0.7	0.7	1	1	1
12/01/2022 16:00	0.7	11.6	2,338.6	0.7	0.7	1	1	1
12/01/2022 17:00	0.7	11.6	2,347.2	0.7	0.7	1	1	1
12/01/2022 18:00	0.7	11.6	2,335.6	0.7	0.7	1	1	1
12/01/2022 19:00	0.7	11.7	2,345.2	0.7	0.7	1	1	1
12/01/2022 20:00	0.7	11.7	2,349.1	0.7	0.7	1	1	1
12/01/2022 21:00	0.7	11.8	2,324.3	0.7	0.7	1	1	1
12/01/2022 22:00	0.7	12.4	2,184.7	0.7	0.7	1	1	1
12/01/2022 23:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
Average/Sum#:	0.6	12.5	2,072.1	0.6	0.6	22 #	20 #	19 #
Minimum:	0.0	11.6	301.9	0.0	0.1	0	0	0
Maximum:	0.7	17.9	2,349.1	0.7	0.7	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.7	12.4	2,181.7	0.7	0.7	1	1	1
12/02/2022 01:00	0.7	12.4	2,185.0	0.7	0.7	1	1	1
12/02/2022 02:00	0.5	12.4	2,189.6	0.5	0.7	1	1	1
12/02/2022 03:00	0.5	12.5	2,168.0	0.5	0.7	1	1	1
12/02/2022 04:00	0.5	12.5	2,177.5	0.5	0.7	1	1	1
12/02/2022 05:00	0.5	12.5	2,174.2	0.5	0.7	1	1	1
12/02/2022 06:00	0.7	12.0	2,312.0	0.7	0.7	1	1	1
12/02/2022 07:00	0.7	11.9	2,323.5	0.7	0.7	1	1	1
12/02/2022 08:00	0.7	12.0	2,321.3	0.7	0.7	1	1	1
12/02/2022 09:00	0.5	12.4	2,196.4	0.5	0.7	1	1	1
12/02/2022 10:00	0.5	12.4	2,196.5	0.5	0.7	1	1	1
12/02/2022 11:00	0.7	12.3	2,214.2	0.7	0.7	1	1	1
12/02/2022 12:00	0.7	12.3	2,217.5	0.7	0.7	1	1	1
12/02/2022 13:00	0.7	12.3	2,208.5	0.7	0.7	1	1	1
12/02/2022 14:00	0.7	12.3	2,186.0	0.7	0.7	1	1	1
12/02/2022 15:00	0.7	11.9	2,306.4	0.7	0.7	1	1	1
12/02/2022 16:00	0.7	11.7	2,337.6	0.7	0.7	1	1	1
12/02/2022 17:00	0.7	11.8	2,328.6	0.7	0.7	1	1	1
12/02/2022 18:00	0.7	11.9	2,318.8	0.7	0.7	1	1	1
12/02/2022 19:00	0.7	11.9	2,324.2	0.7	0.7	1	1	1
12/02/2022 20:00	0.7	11.9	2,321.7	0.7	0.7	1	1	1
12/02/2022 21:00	0.7	11.9	2,315.9	0.7	0.7	1	1	1
12/02/2022 22:00	0.7	11.9	2,313.3	0.7	0.7	1	1	1
12/02/2022 23:00	0.7	11.9	2,317.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.1	2,255.7	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.7	2,168.0	0.5	0.7	1	1	1
Maximum:	0.7	12.5	2,337.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.7	12.0	2,310.3	0.7	0.7	1	1	1
12/03/2022 01:00	0.7	12.0	2,318.6	0.7	0.7	1	1	1
12/03/2022 02:00	0.7	11.9	2,322.5	0.7	0.7	1	1	1
12/03/2022 03:00	0.7	11.9	2,322.3	0.7	0.7	1	1	1
12/03/2022 04:00	0.7	11.9	2,317.9	0.7	0.7	1	1	1
12/03/2022 05:00	0.7	11.9	2,321.6	0.7	0.7	1	1	1
12/03/2022 06:00	0.7	11.9	2,325.5	0.7	0.7	1	1	1
12/03/2022 07:00	0.7	11.8	2,334.4	0.7	0.7	1	1	1
12/03/2022 08:00	0.7	11.9	2,328.6	0.7	0.7	1	1	1
12/03/2022 09:00	0.7	11.8	2,330.7	0.7	0.7	1	1	1
12/03/2022 10:00	0.7	11.9	2,311.2	0.7	0.7	1	1	1
12/03/2022 11:00	0.7	12.0	2,279.7	0.7	0.7	1	1	1
12/03/2022 12:00	0.7	11.9	2,308.6	0.7	0.7	1	1	1
12/03/2022 13:00	0.7	12.3	2,197.2	0.7	0.7	1	1	1
12/03/2022 14:00	0.5	12.4	2,185.4	0.5	0.7	1	1	1
12/03/2022 15:00	0.7	11.9	2,313.0	0.7	0.7	1	1	1
12/03/2022 16:00	0.7	11.7	2,334.9	0.7	0.7	1	1	1
12/03/2022 17:00	0.7	11.8	2,325.1	0.7	0.7	1	1	1
12/03/2022 18:00	0.7	11.8	2,312.8	0.7	0.7	1	1	1
12/03/2022 19:00	0.7	11.8	2,316.1	0.7	0.7	1	1	1
12/03/2022 20:00	0.7	11.7	2,329.1	0.7	0.7	1	1	1
12/03/2022 21:00	0.7	11.7	2,344.0	0.7	0.7	1	1	1
12/03/2022 22:00	0.7	11.7	2,350.9	0.7	0.7	1	1	1
12/03/2022 23:00	0.7	11.7	2,342.1	0.7	0.7	1	1	1
Average/Sum#:	0.7	11.9	2,311.8	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.7	2,185.4	0.5	0.7	1	1	1
Maximum:	0.7	12.4	2,350.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.7	12.3	2,200.3	0.7	0.7	1	1	1
12/04/2022 01:00	0.7	12.3	2,203.9	0.7	0.7	1	1	1
12/04/2022 02:00	0.7	12.3	2,208.7	0.7	0.7	1	1	1
12/04/2022 03:00	0.5	12.3	2,200.4	0.5	0.7	1	1	1
12/04/2022 04:00	0.7	12.3	2,211.5	0.7	0.7	1	1	1
12/04/2022 05:00	0.7	12.3	2,202.2	0.7	0.7	1	1	1
12/04/2022 06:00	0.7	11.8	2,326.8	0.7	0.7	1	1	1
12/04/2022 07:00	0.7	11.7	2,339.1	0.7	0.7	1	1	1
12/04/2022 08:00	0.7	12.3	2,214.8	0.7	0.7	1	1	1
12/04/2022 09:00	0.5	12.3	2,191.3	0.5	0.7	1	1	1
12/04/2022 10:00	0.7	12.2	2,206.1	0.7	0.7	1	1	1
12/04/2022 11:00	0.7	12.2	2,206.4	0.7	0.7	1	1	1
12/04/2022 12:00	0.7	12.1	2,197.7	0.7	0.7	1	1	1
12/04/2022 13:00	0.7	12.1	2,193.2	0.7	0.7	1	1	1
12/04/2022 14:00	0.7	12.1	2,207.4	0.7	0.7	1	1	1
12/04/2022 15:00	0.7	12.1	2,194.8	0.7	0.7	1	1	1
12/04/2022 16:00	0.7	11.6	2,322.7	0.7	0.7	1	1	1
12/04/2022 17:00	0.7	11.6	2,338.7	0.7	0.7	1	1	1
12/04/2022 18:00	0.7	11.6	2,323.4	0.7	0.7	1	1	1
12/04/2022 19:00	0.7	11.7	2,320.9	0.7	0.7	1	1	1
12/04/2022 20:00	0.7	11.7	2,321.9	0.7	0.7	1	1	1
12/04/2022 21:00	0.7	11.7	2,322.9	0.7	0.7	1	1	1
12/04/2022 22:00	0.7	11.8	2,311.7	0.7	0.7	1	1	1
12/04/2022 23:00	0.7	12.3	2,192.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.0	2,248.3	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.6	2,191.3	0.5	0.7	1	1	1
Maximum:	0.7	12.3	2,339.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.7	12.3	2,194.3	0.7	0.7	1	1	1
12/05/2022 01:00	0.7	12.3	2,191.4	0.7	0.7	1	1	1
12/05/2022 02:00	0.7	12.3	2,196.4	0.7	0.7	1	1	1
12/05/2022 03:00	0.7	12.3	2,190.0	0.7	0.7	1	1	1
12/05/2022 04:00	0.7	12.2	2,215.9	0.7	0.7	1	1	1
12/05/2022 05:00	0.7	11.8	2,320.8	0.7	0.7	1	1	1
12/05/2022 06:00	0.7	11.6	2,344.1	0.7	0.7	1	1	1
12/05/2022 07:00	0.7	11.7	2,340.6	0.7	0.7	1	1	1
12/05/2022 08:00	0.7	11.6	2,351.7	0.7	0.7	1	1	1
12/05/2022 09:00	0.7	11.5	2,366.0	0.7	0.7	1	1	1
12/05/2022 10:00	0.7	11.9	2,141.8	0.7	0.6	1	1	1
12/05/2022 11:00	0.7	13.2	1,826.8	0.7	0.5	1	1	1
12/05/2022 12:00	0.7	12.2	2,161.8	0.7	0.6	1	1	1
12/05/2022 13:00	0.7	12.8	2,027.0	0.7	0.6	1	1	1
12/05/2022 14:00	0.7	12.7	2,056.5	0.7	0.6	1	1	1
12/05/2022 15:00	0.7	12.6	2,074.4	0.7	0.6	1	1	1
12/05/2022 16:00	0.7	12.0	2,222.7	0.7	0.7	1	1	1
12/05/2022 17:00	0.7	11.7	2,298.0	0.7	0.7	1	1	1
12/05/2022 18:00	0.7	11.7	2,298.7	0.7	0.7	1	1	1
12/05/2022 19:00	0.7	11.8	2,302.3	0.7	0.7	1	1	1
12/05/2022 20:00	0.7	11.8	2,299.3	0.7	0.7	1	1	1
12/05/2022 21:00	0.7	12.1	2,221.1	0.7	0.7	1	1	1
12/05/2022 22:00	0.7	12.7	2,074.3	0.7	0.6	1	1	1
12/05/2022 23:00	0.7	12.8	2,049.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.2	2,198.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.5	1,826.8	0.7	0.5	1	1	1
Maximum:	0.7	13.2	2,366.0	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	0.7	13.2	1,968.4	0.7	0.6	1	1	1
12/06/2022 01:00	0.7	13.2	1,968.0	0.7	0.6	1	1	1
12/06/2022 02:00	0.5	13.2	1,968.0	0.5	0.6	1	1	1
12/06/2022 03:00	0.5	13.2	1,969.4	0.5	0.6	1	1	1
12/06/2022 04:00	0.7	13.1	1,984.1	0.7	0.6	1	1	1
12/06/2022 05:00	0.7	13.0	2,012.5	0.7	0.6	1	1	1
12/06/2022 06:00	0.7	13.1	1,985.5	0.7	0.6	1	1	1
12/06/2022 07:00	0.7	12.7	2,090.5	0.7	0.6	1	1	1
12/06/2022 08:00	0.7	11.9	2,283.2	0.7	0.7	1	1	1
12/06/2022 09:00	0.7	12.0	2,270.7	0.7	0.7	1	1	1
12/06/2022 10:00	0.7	12.0	2,264.3	0.7	0.7	1	1	1
12/06/2022 11:00	0.7	12.0	2,260.4	0.7	0.7	1	1	1
12/06/2022 12:00	0.7	12.0	2,241.0	0.7	0.7	1	1	1
12/06/2022 13:00	0.7	13.7	1,779.8	0.7	0.5	1	1	1
12/06/2022 14:00	0.6	14.0	1,314.5	0.6	0.4	1	1	0
12/06/2022 15:00	0.6	14.0	1,314.1	0.6	0.4	1	1	0
12/06/2022 16:00	0.6	13.9	1,512.4	0.6	0.5	1	1	0
12/06/2022 17:00	0.6	13.8	1,808.0	0.6	0.5	1	1	0
12/06/2022 18:00	0.6	13.8	1,807.8	0.6	0.5	1	1	0
12/06/2022 19:00	0.7	13.8	1,817.6	0.7	0.5	1	1	1
12/06/2022 20:00	0.7	12.5	2,137.3	0.7	0.6	1	1	1
12/06/2022 21:00	0.7	12.1	2,235.9	0.7	0.7	1	1	1
12/06/2022 22:00	0.7	12.6	2,105.7	0.7	0.6	1	1	1
12/06/2022 23:00	0.7	13.2	1,973.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,961.3	0.7	0.6	24 #	24 #	19 #
Minimum:	0.5	11.9	1,314.1	0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,283.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.7	12.7	2,084.1	0.7	0.6	1	1	1
12/07/2022 01:00	0.7	13.1	1,990.9	0.7	0.6	1	1	1
12/07/2022 02:00	0.7	12.6	2,139.0	0.7	0.6	1	1	1
12/07/2022 03:00	0.7	12.5	2,147.2	0.7	0.6	1	1	1
12/07/2022 04:00	0.7	12.5	2,164.6	0.7	0.6	1	1	1
12/07/2022 05:00	0.7	12.4	2,173.1	0.7	0.7	1	1	1
12/07/2022 06:00	0.7	12.1	2,253.6	0.7	0.7	1	1	1
12/07/2022 07:00	0.7	12.1	2,265.4	0.7	0.7	1	1	1
12/07/2022 08:00	0.7	12.6	2,137.8	0.7	0.6	1	1	1
12/07/2022 09:00	0.7	12.5	2,172.2	0.7	0.7	1	1	1
12/07/2022 10:00	0.7	12.5	2,171.5	0.7	0.7	1	1	1
12/07/2022 11:00	0.7	12.5	2,169.0	0.7	0.7	1	1	1
12/07/2022 12:00	0.7	12.5	2,144.8	0.7	0.6	1	1	1
12/07/2022 13:00	0.7	12.5	2,120.6	0.7	0.6	1	1	1
12/07/2022 14:00	0.7	12.8	2,065.4	0.7	0.6	1	1	1
12/07/2022 15:00	0.7	12.7	2,088.9	0.7	0.6	1	1	1
12/07/2022 16:00	0.7	12.0	2,262.1	0.7	0.7	1	1	1
12/07/2022 17:00	0.7	11.9	2,276.0	0.7	0.7	1	1	1
12/07/2022 18:00	0.7	11.9	2,279.2	0.7	0.7	1	1	1
12/07/2022 19:00	0.7	11.9	2,277.8	0.7	0.7	1	1	1
12/07/2022 20:00	0.7	11.9	2,278.1	0.7	0.7	1	1	1
12/07/2022 21:00	0.7	12.0	2,272.8	0.7	0.7	1	1	1
12/07/2022 22:00	0.7	12.4	2,185.4	0.7	0.7	1	1	1
12/07/2022 23:00	0.7	12.4	2,181.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,179.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,990.9	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,279.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.7	12.6	2,140.3	0.7	0.6	1	1	1
12/08/2022 01:00	0.7	12.6	2,134.5	0.7	0.6	1	1	1
12/08/2022 02:00	0.7	12.6	2,131.2	0.7	0.6	1	1	1
12/08/2022 03:00	0.7	12.7	2,128.7	0.7	0.6	1	1	1
12/08/2022 04:00	0.7	12.6	2,153.6	0.7	0.6	1	1	1
12/08/2022 05:00	0.7	12.4	2,211.4	0.7	0.7	1	1	1
12/08/2022 06:00	0.7	12.0	2,286.3	0.7	0.7	1	1	1
12/08/2022 07:00	0.7	12.2	2,241.1	0.7	0.7	1	1	1
12/08/2022 08:00	0.7	13.0	2,033.7	0.7	0.6	1	1	1
12/08/2022 09:00	0.7	12.8	2,111.2	0.7	0.6	1	1	1
12/08/2022 10:00	0.7	12.7	2,119.0	0.7	0.6	1	1	1
12/08/2022 11:00	0.7	12.5	2,150.5	0.7	0.6	1	1	1
12/08/2022 12:00	0.7	12.5	2,152.8	0.7	0.6	1	1	1
12/08/2022 13:00	0.7	12.4	2,166.9	0.7	0.7	1	1	1
12/08/2022 14:00	0.7	12.3	2,177.4	0.7	0.7	1	1	1
12/08/2022 15:00	0.7	12.3	2,183.9	0.7	0.7	1	1	1
12/08/2022 16:00	0.7	11.9	2,283.7	0.7	0.7	1	1	1
12/08/2022 17:00	0.7	11.9	2,284.7	0.7	0.7	1	1	1
12/08/2022 18:00	0.7	11.9	2,287.5	0.7	0.7	1	1	1
12/08/2022 19:00	0.7	11.9	2,285.8	0.7	0.7	1	1	1
12/08/2022 20:00	0.7	11.9	2,287.4	0.7	0.7	1	1	1
12/08/2022 21:00	0.7	11.9	2,285.0	0.7	0.7	1	1	1
12/08/2022 22:00	0.7	12.3	2,194.3	0.7	0.7	1	1	1
12/08/2022 23:00	0.7	12.3	2,195.7	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.3	2,192.8	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	2,033.7	0.7	0.6	1	1	1
Maximum:	0.7	13.0	2,287.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	0.7	12.5	2,144.3	0.7	0.6	1	1	1
12/09/2022 01:00	0.7	12.9	2,046.2	0.7	0.6	1	1	1
12/09/2022 02:00	0.7	12.6	2,142.3	0.7	0.6	1	1	1
12/09/2022 03:00	0.7	12.6	2,144.2	0.7	0.6	1	1	1
12/09/2022 04:00	0.7	12.4	2,194.9	0.7	0.7	1	1	1
12/09/2022 05:00	0.7	12.0	2,296.2	0.7	0.7	1	1	1
12/09/2022 06:00	0.7	12.0	2,298.6	0.7	0.7	1	1	1
12/09/2022 07:00	0.7	12.0	2,286.8	0.7	0.7	1	1	1
12/09/2022 08:00	0.7	12.9	2,072.5	0.7	0.6	1	1	1
12/09/2022 09:00	0.7	13.0	2,032.9	0.7	0.6	1	1	1
12/09/2022 10:00	0.5	13.2	1,984.3	0.5	0.6	1	1	1
12/09/2022 11:00	0.7	12.8	2,074.2	0.7	0.6	1	1	1
12/09/2022 12:00	0.7	13.0	2,007.8	0.7	0.6	1	1	1
12/09/2022 13:00	0.7	12.4	2,160.2	0.7	0.6	1	1	1
12/09/2022 14:00	0.7	12.4	2,163.1	0.7	0.6	1	1	1
12/09/2022 15:00	0.7	12.9	2,055.6	0.7	0.6	1	1	1
12/09/2022 16:00	0.7	11.9	2,286.0	0.7	0.7	1	1	1
12/09/2022 17:00	0.7	11.9	2,285.5	0.7	0.7	1	1	1
12/09/2022 18:00	0.7	11.9	2,285.9	0.7	0.7	1	1	1
12/09/2022 19:00	0.7	11.9	2,287.2	0.7	0.7	1	1	1
12/09/2022 20:00	0.7	11.9	2,289.2	0.7	0.7	1	1	1
12/09/2022 21:00	0.7	11.9	2,287.9	0.7	0.7	1	1	1
12/09/2022 22:00	0.7	11.9	2,286.6	0.7	0.7	1	1	1
12/09/2022 23:00	0.7	11.9	2,280.4	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,183.0	0.7	0.7	24 #	24 #	24 #
Minimum:	0.5	11.9	1,984.3	0.5	0.6	1	1	1
Maximum:	0.7	13.2	2,298.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	0.7	13.0	2,020.4	0.7	0.6	1	1	1
12/10/2022 01:00	0.7	13.0	2,016.4	0.7	0.6	1	1	1
12/10/2022 02:00	0.7	13.1	1,980.5	0.7	0.6	1	1	1
12/10/2022 03:00	0.7	13.1	1,981.2	0.7	0.6	1	1	1
12/10/2022 04:00	0.7	13.1	1,976.3	0.7	0.6	1	1	1
12/10/2022 05:00	0.7	13.0	1,986.7	0.7	0.6	1	1	1
12/10/2022 06:00	0.7	13.1	1,973.6	0.7	0.6	1	1	1
12/10/2022 07:00	0.7	13.1	1,981.0	0.7	0.6	1	1	1
12/10/2022 08:00	0.7	12.9	2,021.2	0.7	0.6	1	1	1
12/10/2022 09:00	0.7	12.9	1,998.2	0.7	0.6	1	1	1
12/10/2022 10:00	0.7	13.0	1,974.5	0.7	0.6	1	1	1
12/10/2022 11:00	0.7	12.8	2,015.4	0.7	0.6	1	1	1
12/10/2022 12:00	0.7	12.4	2,121.1	0.7	0.6	1	1	1
12/10/2022 13:00	0.7	12.0	2,182.6	0.7	0.7	1	1	1
12/10/2022 14:00	0.7	12.7	2,018.0	0.7	0.6	1	1	1
12/10/2022 15:00	0.7	12.6	2,043.8	0.7	0.6	1	1	1
12/10/2022 16:00	0.7	12.4	2,112.6	0.7	0.6	1	1	1
12/10/2022 17:00	0.7	12.5	2,071.9	0.7	0.6	1	1	1
12/10/2022 18:00	0.7	12.6	2,072.8	0.7	0.6	1	1	1
12/10/2022 19:00	0.7	11.8	2,252.8	0.7	0.7	1	1	1
12/10/2022 20:00	0.7	12.2	2,175.1	0.7	0.7	1	1	1
12/10/2022 21:00	0.7	12.5	2,080.6	0.7	0.6	1	1	1
12/10/2022 22:00	0.7	12.9	2,016.0	0.7	0.6	1	1	1
12/10/2022 23:00	0.7	12.6	2,077.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	2,047.9	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,973.6	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,252.8	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	0.7	13.1	1,967.5	0.7	0.6	1	1	1
12/11/2022 01:00	0.7	13.1	1,965.0	0.7	0.6	1	1	1
12/11/2022 02:00	0.7	13.1	1,964.9	0.7	0.6	1	1	1
12/11/2022 03:00	0.7	13.1	1,965.4	0.7	0.6	1	1	1
12/11/2022 04:00	0.7	13.1	1,969.0	0.7	0.6	1	1	1
12/11/2022 05:00	0.7	13.1	1,967.8	0.7	0.6	1	1	1
12/11/2022 06:00	0.7	13.1	1,969.4	0.7	0.6	1	1	1
12/11/2022 07:00	0.7	13.2	1,972.0	0.7	0.6	1	1	1
12/11/2022 08:00	0.7	13.2	1,973.7	0.7	0.6	1	1	1
12/11/2022 09:00	0.7	13.1	1,971.0	0.7	0.6	1	1	1
12/11/2022 10:00	0.7	13.1	1,969.2	0.7	0.6	1	1	1
12/11/2022 11:00	0.7	13.1	1,966.9	0.7	0.6	1	1	1
12/11/2022 12:00	0.7	13.1	1,966.8	0.7	0.6	1	1	1
12/11/2022 13:00	0.7	13.1	1,968.3	0.7	0.6	1	1	1
12/11/2022 14:00	0.7	13.1	1,963.5	0.7	0.6	1	1	1
12/11/2022 15:00	0.7	12.7	2,060.7	0.7	0.6	1	1	1
12/11/2022 16:00	0.7	12.8	2,068.6	0.7	0.6	1	1	1
12/11/2022 17:00	0.7	12.5	2,141.4	0.7	0.6	1	1	1
12/11/2022 18:00	0.7	12.9	2,048.1	0.7	0.6	1	1	1
12/11/2022 19:00	0.7	12.8	2,066.7	0.7	0.6	1	1	1
12/11/2022 20:00	0.7	12.6	2,120.2	0.7	0.6	1	1	1
12/11/2022 21:00	0.7	13.1	2,003.0	0.7	0.6	1	1	1
12/11/2022 22:00	0.7	13.2	1,972.7	0.7	0.6	1	1	1
12/11/2022 23:00	0.7	13.2	1,974.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,999.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.5	1,963.5	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,141.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	0.7	13.2	1,981.6	0.7	0.6	1	1	1
12/12/2022 01:00	0.7	13.2	1,982.3	0.7	0.6	1	1	1
12/12/2022 02:00	0.7	13.2	1,981.4	0.7	0.6	1	1	1
12/12/2022 03:00	0.7	13.2	1,978.4	0.7	0.6	1	1	1
12/12/2022 04:00	0.7	13.2	1,977.9	0.7	0.6	1	1	1
12/12/2022 05:00	0.7	12.7	2,119.2	0.7	0.6	1	1	1
12/12/2022 06:00	0.7	12.2	2,218.1	0.7	0.7	1	1	1
12/12/2022 07:00	0.7	12.3	2,198.9	0.7	0.7	1	1	1
12/12/2022 08:00	0.7	12.8	2,076.7	0.7	0.6	1	1	1
12/12/2022 09:00	0.7	12.9	2,068.8	0.7	0.6	1	1	1
12/12/2022 10:00	0.5	13.3	1,973.0	0.5	0.6	1	1	1
12/12/2022 11:00	0.5	13.2	1,970.2	0.5	0.6	1	1	1
12/12/2022 12:00	0.5	13.2	1,970.6	0.5	0.6	1	1	1
12/12/2022 13:00	0.5	13.2	1,969.6	0.5	0.6	1	1	1
12/12/2022 14:00	0.5	13.2	1,968.0	0.5	0.6	1	1	1
12/12/2022 15:00	0.7	13.2	1,967.7	0.7	0.6	1	1	1
12/12/2022 16:00	0.7	12.5	2,153.9	0.7	0.6	1	1	1
12/12/2022 17:00	0.7	12.1	2,250.2	0.7	0.7	1	1	1
12/12/2022 18:00	0.7	11.8	2,314.5	0.7	0.7	1	1	1
12/12/2022 19:00	0.7	11.8	2,316.4	0.7	0.7	1	1	1
12/12/2022 20:00	0.7	11.8	2,320.3	0.7	0.7	1	1	1
12/12/2022 21:00	0.7	12.0	2,269.9	0.7	0.7	1	1	1
12/12/2022 22:00	0.7	12.3	2,201.9	0.7	0.7	1	1	1
12/12/2022 23:00	0.7	13.0	2,035.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	2,094.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.5	11.8	1,967.7	0.5	0.6	1	1	1
Maximum:	0.7	13.3	2,320.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.7	12.6	2,155.3	0.7	0.6	1	1	1
12/13/2022 01:00	0.7	12.5	2,162.4	0.7	0.6	1	1	1
12/13/2022 02:00	0.7	12.5	2,171.0	0.7	0.7	1	1	1
12/13/2022 03:00	0.7	12.5	2,161.4	0.7	0.6	1	1	1
12/13/2022 04:00	0.7	12.4	2,201.7	0.7	0.7	1	1	1
12/13/2022 05:00	0.7	12.1	2,286.6	0.7	0.7	1	1	1
12/13/2022 06:00	0.7	11.9	2,323.5	0.7	0.7	1	1	1
12/13/2022 07:00	0.7	11.9	2,314.5	0.7	0.7	1	1	1
12/13/2022 08:00	0.7	12.5	2,149.7	0.7	0.6	1	1	1
12/13/2022 09:00	0.7	13.1	2,013.4	0.7	0.6	1	1	1
12/13/2022 10:00	0.7	13.3	1,978.2	0.7	0.6	1	1	1
12/13/2022 11:00	0.7	13.2	1,972.8	0.7	0.6	1	1	1
12/13/2022 12:00	0.7	13.2	1,971.6	0.7	0.6	1	1	1
12/13/2022 13:00	0.7	13.2	1,969.9	0.7	0.6	1	1	1
12/13/2022 14:00	0.7	13.2	1,968.6	0.7	0.6	1	1	1
12/13/2022 15:00	0.7	12.8	2,076.2	0.7	0.6	1	1	1
12/13/2022 16:00	0.7	11.9	2,282.3	0.7	0.7	1	1	1
12/13/2022 17:00	0.7	11.8	2,299.2	0.7	0.7	1	1	1
12/13/2022 18:00	0.7	11.9	2,297.3	0.7	0.7	1	1	1
12/13/2022 19:00	0.7	11.9	2,296.7	0.7	0.7	1	1	1
12/13/2022 20:00	0.7	11.9	2,293.3	0.7	0.7	1	1	1
12/13/2022 21:00	0.7	12.0	2,293.3	0.7	0.7	1	1	1
12/13/2022 22:00	0.7	12.0	2,297.4	0.7	0.7	1	1	1
12/13/2022 23:00	0.7	11.9	2,293.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.4	2,176.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.8	1,968.6	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,323.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.7	12.4	2,201.0	0.7	0.7	1	1	1
12/14/2022 01:00	0.7	12.4	2,205.8	0.7	0.7	1	1	1
12/14/2022 02:00	0.7	12.4	2,207.5	0.7	0.7	1	1	1
12/14/2022 03:00	0.7	12.5	2,202.0	0.7	0.7	1	1	1
12/14/2022 04:00	0.7	12.5	2,195.8	0.7	0.7	1	1	1
12/14/2022 05:00	0.7	12.0	2,307.3	0.7	0.7	1	1	1
12/14/2022 06:00	0.7	12.0	2,311.1	0.7	0.7	1	1	1
12/14/2022 07:00	0.7	12.1	2,277.8	0.7	0.7	1	1	1
12/14/2022 08:00	0.7	12.9	2,081.0	0.7	0.6	1	1	1
12/14/2022 09:00	0.7	13.1	2,011.1	0.7	0.6	1	1	1
12/14/2022 10:00	0.7	13.0	2,028.4	0.7	0.6	1	1	1
12/14/2022 11:00	0.7	13.2	1,974.9	0.7	0.6	1	1	1
12/14/2022 12:00	0.7	13.2	1,976.5	0.7	0.6	1	1	1
12/14/2022 13:00	0.7	13.2	1,978.3	0.7	0.6	1	1	1
12/14/2022 14:00	0.7	13.2	1,975.2	0.7	0.6	1	1	1
12/14/2022 15:00	0.7	13.1	2,018.4	0.7	0.6	1	1	1
12/14/2022 16:00	0.7	12.2	2,219.4	0.7	0.7	1	1	1
12/14/2022 17:00	0.7	11.9	2,291.2	0.7	0.7	1	1	1
12/14/2022 18:00	0.7	11.9	2,288.1	0.7	0.7	1	1	1
12/14/2022 19:00	0.7	11.9	2,292.6	0.7	0.7	1	1	1
12/14/2022 20:00	0.7	12.0	2,292.9	0.7	0.7	1	1	1
12/14/2022 21:00	0.7	12.0	2,291.3	0.7	0.7	1	1	1
12/14/2022 22:00	0.7	12.1	2,265.2	0.7	0.7	1	1	1
12/14/2022 23:00	0.7	12.5	2,178.6	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,169.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,974.9	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,311.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2022 00:00	0.7	12.0	2,300.0	0.7	0.7	1	1	1
12/15/2022 01:00	0.7	11.9	2,310.7	0.7	0.7	1	1	1
12/15/2022 02:00	0.7	11.9	2,310.7	0.7	0.7	1	1	1
12/15/2022 03:00	0.7	11.9	2,312.5	0.7	0.7	1	1	1
12/15/2022 04:00	0.7	11.9	2,317.5	0.7	0.7	1	1	1
12/15/2022 05:00	0.7	11.9	2,320.2	0.7	0.7	1	1	1
12/15/2022 06:00	0.7	11.9	2,319.6	0.7	0.7	1	1	1
12/15/2022 07:00	0.7	11.9	2,314.8	0.7	0.7	1	1	1
12/15/2022 08:00	0.7	12.2	2,232.9	0.7	0.7	1	1	1
12/15/2022 09:00	0.7	12.1	2,231.2	0.7	0.7	1	1	1
12/15/2022 10:00	0.7	13.1	1,978.7	0.7	0.6	1	1	1
12/15/2022 11:00	0.7	13.1	1,990.3	0.7	0.6	1	1	1
12/15/2022 12:00	0.7	12.9	2,023.1	0.7	0.6	1	1	1
12/15/2022 13:00	0.7	12.8	2,045.1	0.7	0.6	1	1	1
12/15/2022 14:00	0.7	12.6	2,102.6	0.7	0.6	1	1	1
12/15/2022 15:00	0.7	11.9	2,258.0	0.7	0.7	1	1	1
12/15/2022 16:00	0.7	11.9	2,270.0	0.7	0.7	1	1	1
12/15/2022 17:00	0.7	11.9	2,268.1	0.7	0.7	1	1	1
12/15/2022 18:00	0.7	12.0	2,258.2	0.7	0.7	1	1	1
12/15/2022 19:00	0.7	12.0	2,251.3	0.7	0.7	1	1	1
12/15/2022 20:00	0.7	12.0	2,253.0	0.7	0.7	1	1	1
12/15/2022 21:00	0.7	12.1	2,254.6	0.7	0.7	1	1	1
12/15/2022 22:00	0.7	12.1	2,260.1	0.7	0.7	1	1	1
12/15/2022 23:00	0.7	12.2	2,242.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.2	2,226.1	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	11.9	1,978.7	0.7	0.6	1	1	1
Maximum:	0.7	13.1	2,320.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	0.7	13.1	1,997.7	0.7	0.6	1	1	1
12/16/2022 01:00	0.7	13.2	1,975.0	0.7	0.6	1	1	1
12/16/2022 02:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
12/16/2022 03:00	0.7	13.2	1,977.9	0.7	0.6	1	1	1
12/16/2022 04:00	0.7	13.2	1,976.0	0.7	0.6	1	1	1
12/16/2022 05:00	0.7	13.2	1,986.3	0.7	0.6	1	1	1
12/16/2022 06:00	0.7	12.7	2,114.7	0.7	0.6	1	1	1
12/16/2022 07:00	0.7	12.4	2,213.4	0.7	0.7	1	1	1
12/16/2022 08:00	0.7	12.6	2,148.7	0.7	0.6	1	1	1
12/16/2022 09:00	0.7	12.8	2,073.1	0.7	0.6	1	1	1
12/16/2022 10:00	0.6	13.9	1,533.9	0.6	0.5	1	1	0
12/16/2022 11:00	0.6	14.0	1,455.0	0.6	0.4	1	1	0
12/16/2022 12:00	0.6	14.0	1,319.9	0.6	0.4	1	1	0
12/16/2022 13:00	0.6	14.0	1,322.2	0.6	0.4	1	1	0
12/16/2022 14:00	0.6	13.9	1,577.2	0.6	0.5	1	1	0
12/16/2022 15:00	0.7	13.9	1,550.0	0.7	0.5	1	1	1
12/16/2022 16:00	0.7	12.4	2,166.8	0.7	0.7	1	1	1
12/16/2022 17:00	0.7	12.1	2,236.7	0.7	0.7	1	1	1
12/16/2022 18:00	0.7	12.4	2,162.4	0.7	0.6	1	1	1
12/16/2022 19:00	0.7	12.4	2,168.7	0.7	0.7	1	1	1
12/16/2022 20:00	0.7	12.0	2,256.4	0.7	0.7	1	1	1
12/16/2022 21:00	0.7	12.2	2,198.9	0.7	0.7	1	1	1
12/16/2022 22:00	0.7	12.7	2,089.5	0.7	0.6	1	1	1
12/16/2022 23:00	0.7	13.2	1,975.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,935.4	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.0	1,319.9	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,256.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.7	12.5	2,148.3	0.7	0.6	1	1	1
12/17/2022 01:00	0.7	12.5	2,151.2	0.7	0.6	1	1	1
12/17/2022 02:00	0.7	12.6	2,142.6	0.7	0.6	1	1	1
12/17/2022 03:00	0.7	12.6	2,153.4	0.7	0.6	1	1	1
12/17/2022 04:00	0.7	12.5	2,154.4	0.7	0.6	1	1	1
12/17/2022 05:00	0.7	12.6	2,151.3	0.7	0.6	1	1	1
12/17/2022 06:00	0.7	12.1	2,242.2	0.7	0.7	1	1	1
12/17/2022 07:00	0.7	12.7	2,099.3	0.7	0.6	1	1	1
12/17/2022 08:00	0.7	12.5	2,165.9	0.7	0.6	1	1	1
12/17/2022 09:00	0.7	12.7	2,124.8	0.7	0.6	1	1	1
12/17/2022 10:00	0.7	13.1	2,009.5	0.7	0.6	1	1	1
12/17/2022 11:00	0.7	13.2	1,977.3	0.7	0.6	1	1	1
12/17/2022 12:00	0.7	13.2	1,970.0	0.7	0.6	1	1	1
12/17/2022 13:00	0.7	13.2	1,970.2	0.7	0.6	1	1	1
12/17/2022 14:00	0.7	13.1	1,991.1	0.7	0.6	1	1	1
12/17/2022 15:00	0.7	12.6	2,124.4	0.7	0.6	1	1	1
12/17/2022 16:00	0.7	11.9	2,279.1	0.7	0.7	1	1	1
12/17/2022 17:00	0.7	12.0	2,247.4	0.7	0.7	1	1	1
12/17/2022 18:00	0.7	12.4	2,159.7	0.7	0.6	1	1	1
12/17/2022 19:00	0.7	11.9	2,288.0	0.7	0.7	1	1	1
12/17/2022 20:00	0.7	11.9	2,291.4	0.7	0.7	1	1	1
12/17/2022 21:00	0.7	11.9	2,292.3	0.7	0.7	1	1	1
12/17/2022 22:00	0.7	11.9	2,284.2	0.7	0.7	1	1	1
12/17/2022 23:00	0.7	12.3	2,192.5	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,150.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.9	1,970.0	0.7	0.6	1	1	1
Maximum:	0.7	13.2	2,292.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.7	12.5	2,141.4	0.7	0.6	1	1	1
12/18/2022 01:00	0.7	12.6	2,140.8	0.7	0.6	1	1	1
12/18/2022 02:00	0.7	13.1	2,023.7	0.7	0.6	1	1	1
12/18/2022 03:00	0.7	13.3	1,985.2	0.7	0.6	1	1	1
12/18/2022 04:00	0.7	12.7	2,140.3	0.7	0.6	1	1	1
12/18/2022 05:00	0.7	12.6	2,162.0	0.7	0.6	1	1	1
12/18/2022 06:00	0.7	12.4	2,182.1	0.7	0.7	1	1	1
12/18/2022 07:00	0.7	12.3	2,219.3	0.7	0.7	1	1	1
12/18/2022 08:00	0.7	12.7	2,091.7	0.7	0.6	1	1	1
12/18/2022 09:00	0.6	13.9	1,607.9	0.6	0.5	1	1	0
12/18/2022 10:00	0.6	13.9	1,552.2	0.6	0.5	1	1	0
12/18/2022 11:00	0.6	13.9	1,544.4	0.6	0.5	1	1	0
12/18/2022 12:00	0.6	14.0	1,404.3	0.6	0.4	1	1	0
12/18/2022 13:00	0.6	14.0	1,395.8	0.6	0.4	1	1	0
12/18/2022 14:00	0.6	13.9	1,634.8	0.6	0.5	1	1	0
12/18/2022 15:00	0.7	13.9	1,645.9	0.7	0.5	1	1	1
12/18/2022 16:00	0.7	12.5	2,143.3	0.7	0.6	1	1	1
12/18/2022 17:00	0.7	12.0	2,254.0	0.7	0.7	1	1	1
12/18/2022 18:00	0.7	11.9	2,283.9	0.7	0.7	1	1	1
12/18/2022 19:00	0.7	11.9	2,288.7	0.7	0.7	1	1	1
12/18/2022 20:00	0.7	12.2	2,245.0	0.7	0.7	1	1	1
12/18/2022 21:00	0.7	12.4	2,208.9	0.7	0.7	1	1	1
12/18/2022 22:00	0.7	12.4	2,205.7	0.7	0.7	1	1	1
12/18/2022 23:00	0.7	13.0	2,049.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,981.3	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,395.8	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,288.7	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	0.7	12.7	2,141.9	0.7	0.6	1	1	1
12/19/2022 01:00	0.7	12.6	2,153.5	0.7	0.6	1	1	1
12/19/2022 02:00	0.7	12.6	2,149.7	0.7	0.6	1	1	1
12/19/2022 03:00	0.7	12.6	2,152.1	0.7	0.6	1	1	1
12/19/2022 04:00	0.7	12.5	2,185.5	0.7	0.7	1	1	1
12/19/2022 05:00	0.7	12.0	2,309.6	0.7	0.7	1	1	1
12/19/2022 06:00	0.7	12.0	2,310.1	0.7	0.7	1	1	1
12/19/2022 07:00	0.7	12.0	2,310.1	0.7	0.7	1	1	1
12/19/2022 08:00	0.7	12.2	2,262.0	0.7	0.7	1	1	1
12/19/2022 09:00	0.7	12.1	2,274.3	0.7	0.7	1	1	1
12/19/2022 10:00	0.7	12.5	2,181.5	0.7	0.7	1	1	1
12/19/2022 11:00	0.7	12.5	2,181.8	0.7	0.7	1	1	1
12/19/2022 12:00	0.7	12.6	2,174.1	0.7	0.7	1	1	1
12/19/2022 13:00	0.7	12.6	2,164.7	0.7	0.6	1	1	1
12/19/2022 14:00	0.7	12.6	2,166.8	0.7	0.7	1	1	1
12/19/2022 15:00	0.7	12.3	2,231.0	0.7	0.7	1	1	1
12/19/2022 16:00	0.7	12.1	2,274.5	0.7	0.7	1	1	1
12/19/2022 17:00	0.7	12.1	2,275.0	0.7	0.7	1	1	1
12/19/2022 18:00	0.7	12.1	2,277.1	0.7	0.7	1	1	1
12/19/2022 19:00	0.7	12.1	2,280.3	0.7	0.7	1	1	1
12/19/2022 20:00	0.7	12.2	2,277.2	0.7	0.7	1	1	1
12/19/2022 21:00	0.7	12.2	2,277.4	0.7	0.7	1	1	1
12/19/2022 22:00	0.7	12.1	2,283.3	0.7	0.7	1	1	1
12/19/2022 23:00	0.7	12.1	2,278.8	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.3	2,232.2	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	12.0	2,141.9	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,310.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.7	12.6	2,180.6	0.7	0.7	1	1	1
12/20/2022 01:00	0.7	12.6	2,178.9	0.7	0.7	1	1	1
12/20/2022 02:00	0.7	12.5	2,184.2	0.7	0.7	1	1	1
12/20/2022 03:00	0.7	12.5	2,189.6	0.7	0.7	1	1	1
12/20/2022 04:00	0.7	12.5	2,190.7	0.7	0.7	1	1	1
12/20/2022 05:00	0.7	12.5	2,190.8	0.7	0.7	1	1	1
12/20/2022 06:00	0.7	12.1	2,291.6	0.7	0.7	1	1	1
12/20/2022 07:00	0.7	12.1	2,284.8	0.7	0.7	1	1	1
12/20/2022 08:00	0.7	12.6	2,170.4	0.7	0.7	1	1	1
12/20/2022 09:00	0.7	12.5	2,170.0	0.7	0.7	1	1	1
12/20/2022 10:00	0.7	12.7	2,128.2	0.7	0.6	1	1	1
12/20/2022 11:00	0.7	12.8	2,095.1	0.7	0.6	1	1	1
12/20/2022 12:00	0.7	13.3	1,961.4	0.7	0.6	1	1	1
12/20/2022 13:00	0.7	13.3	1,965.5	0.7	0.6	1	1	1
12/20/2022 14:00	0.7	13.3	1,964.0	0.7	0.6	1	1	1
12/20/2022 15:00	0.7	13.0	2,038.6	0.7	0.6	1	1	1
12/20/2022 16:00	0.7	12.3	2,199.8	0.7	0.7	1	1	1
12/20/2022 17:00	0.7	12.0	2,266.0	0.7	0.7	1	1	1
12/20/2022 18:00	0.7	12.0	2,265.9	0.7	0.7	1	1	1
12/20/2022 19:00	0.7	12.0	2,259.4	0.7	0.7	1	1	1
12/20/2022 20:00	0.7	12.0	2,259.9	0.7	0.7	1	1	1
12/20/2022 21:00	0.7	12.4	2,168.4	0.7	0.7	1	1	1
12/20/2022 22:00	0.7	12.4	2,167.9	0.7	0.7	1	1	1
12/20/2022 23:00	0.7	12.2	2,226.6	0.7	0.7	1	1	1
Average/Sum#:	0.7	12.5	2,166.6	0.7	0.7	24 #	24 #	24 #
Minimum:	0.7	12.0	1,961.4	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,291.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2022 00:00	0.7	12.0	2,286.1	0.7	0.7	1	1	1
12/21/2022 01:00	0.7	12.0	2,284.9	0.7	0.7	1	1	1
12/21/2022 02:00	0.7	12.0	2,281.3	0.7	0.7	1	1	1
12/21/2022 03:00	0.7	12.0	2,289.0	0.7	0.7	1	1	1
12/21/2022 04:00	0.7	12.0	2,282.4	0.7	0.7	1	1	1
12/21/2022 05:00	0.7	12.0	2,284.7	0.7	0.7	1	1	1
12/21/2022 06:00	0.7	12.0	2,284.5	0.7	0.7	1	1	1
12/21/2022 07:00	0.7	12.0	2,283.3	0.7	0.7	1	1	1
12/21/2022 08:00	0.7	0.0	2,268.8	0.7	0.7	1	1	1
12/21/2022 09:00	0.5	12.2	2,259.9	0.5	0.7	1	1	1
12/21/2022 10:00	0.5	12.2	2,253.9	0.5	0.7	1	1	1
12/21/2022 11:00	0.5	12.3	2,219.0	0.5	0.7	1	1	1
12/21/2022 12:00	0.5	12.2	2,236.9	0.5	0.7	1	1	1
12/21/2022 13:00	0.5	12.1	2,229.8	0.5	0.7	1	1	1
12/21/2022 14:00	0.5	12.5	2,160.3	0.5	0.6	1	1	1
12/21/2022 15:00	0.5	12.1	2,234.3	0.5	0.7	1	1	1
12/21/2022 16:00	0.7	12.0	2,257.4	0.7	0.7	1	1	1
12/21/2022 17:00	0.5	12.0	2,255.2	0.5	0.7	1	1	1
12/21/2022 18:00	0.5	12.0	2,258.5	0.5	0.7	1	1	1
12/21/2022 19:00	0.7	12.0	2,256.4	0.7	0.7	1	1	1
12/21/2022 20:00	0.5	12.1	2,252.8	0.5	0.7	1	1	1
12/21/2022 21:00	0.5	12.1	2,253.7	0.5	0.7	1	1	1
12/21/2022 22:00	0.5	12.1	2,250.9	0.5	0.7	1	1	1
12/21/2022 23:00	0.5	12.1	2,248.9	0.5	0.7	1	1	1
Average/Sum#:	0.6	12.1	2,257.2	0.6	0.7	24 #	24 #	24 #
Minimum:	0.5	12.0	2,160.3	0.5	0.6	1	1	1
Maximum:	0.7	12.5	2,289.0	0.7	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	0.4	12.4	2,185.3	0.5	0.7	1	1	1
12/22/2022 01:00	0.2	13.2	1,981.3	0.4	0.6	1	1	1
12/22/2022 02:00	0.2	13.2	1,968.8	0.4	0.6	1	1	1
12/22/2022 03:00	0.2	13.2	1,968.0	0.4	0.6	1	1	1
12/22/2022 04:00	0.2	12.8	2,091.8	0.4	0.6	1	1	1
12/22/2022 05:00	0.5	12.4	2,221.8	0.5	0.7	1	1	1
12/22/2022 06:00	0.5	12.1	2,268.5	0.5	0.7	1	1	1
12/22/2022 07:00	0.5	12.1	2,266.2	0.5	0.7	1	1	1
12/22/2022 08:00	0.5	12.2	2,248.9	0.5	0.7	1	1	1
12/22/2022 09:00	0.4	12.6	2,149.4	0.5	0.6	1	1	1
12/22/2022 10:00	0.4	12.6	2,146.2	0.5	0.6	1	1	1
12/22/2022 11:00	0.4	12.6	2,143.8	0.5	0.6	1	1	1
12/22/2022 12:00	0.4	12.6	2,141.5	0.5	0.6	1	1	1
12/22/2022 13:00	0.5	12.6	2,143.3	0.5	0.6	1	1	1
12/22/2022 14:00	0.4	12.6	2,149.6	0.5	0.6	1	1	1
12/22/2022 15:00	0.5	12.3	2,214.6	0.5	0.7	1	1	1
12/22/2022 16:00	0.5	12.3	2,209.7	0.5	0.7	1	1	1
12/22/2022 17:00	0.5	12.1	2,256.5	0.5	0.7	1	1	1
12/22/2022 18:00	0.5	12.1	2,261.1	0.5	0.7	1	1	1
12/22/2022 19:00	0.5	12.1	2,267.4	0.5	0.7	1	1	1
12/22/2022 20:00	0.5	12.1	2,262.7	0.5	0.7	1	1	1
12/22/2022 21:00	0.7	12.1	2,260.5	0.7	0.7	1	1	1
12/22/2022 22:00	0.5	12.3	2,215.3	0.5	0.7	1	1	1
12/22/2022 23:00	0.4	12.8	2,077.3	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.5	2,170.8	0.5	0.7	24 #	24 #	24 #
Minimum:	0.2	12.1	1,968.0	0.4	0.6	1	1	1
Maximum:	0.7	13.2	2,268.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.5	12.3	2,228.2	0.5	0.7	1	1	1
12/23/2022 01:00	0.5	12.1	2,265.3	0.5	0.7	1	1	1
12/23/2022 02:00	0.5	12.1	2,261.5	0.5	0.7	1	1	1
12/23/2022 03:00	0.5	12.1	2,261.6	0.5	0.7	1	1	1
12/23/2022 04:00	0.5	12.1	2,262.1	0.5	0.7	1	1	1
12/23/2022 05:00	0.5	12.1	2,259.9	0.5	0.7	1	1	1
12/23/2022 06:00	0.5	12.1	2,259.7	0.5	0.7	1	1	1
12/23/2022 07:00	0.5	12.2	2,240.1	0.5	0.7	1	1	1
12/23/2022 08:00	0.5	12.4	2,187.9	0.5	0.7	1	1	1
12/23/2022 09:00	0.5	12.4	2,182.4	0.5	0.7	1	1	1
12/23/2022 10:00	0.5	12.5	2,137.6	0.5	0.6	1	1	1
12/23/2022 11:00	0.5	12.5	2,141.7	0.5	0.6	1	1	1
12/23/2022 12:00	0.4	12.9	2,027.4	0.5	0.6	1	1	1
12/23/2022 13:00	0.4	13.2	1,960.0	0.4	0.6	1	1	1
12/23/2022 14:00	0.4	13.2	1,953.8	0.4	0.6	1	1	1
12/23/2022 15:00	0.4	12.8	2,064.7	0.5	0.6	1	1	1
12/23/2022 16:00	0.7	12.0	2,253.1	0.7	0.7	1	1	1
12/23/2022 17:00	0.7	12.0	2,254.2	0.7	0.7	1	1	1
12/23/2022 18:00	0.7	12.0	2,260.1	0.7	0.7	1	1	1
12/23/2022 19:00	0.7	12.0	2,252.4	0.7	0.7	1	1	1
12/23/2022 20:00	0.7	12.0	2,248.8	0.7	0.7	1	1	1
12/23/2022 21:00	0.7	12.0	2,253.2	0.7	0.7	1	1	1
12/23/2022 22:00	0.7	12.0	2,252.2	0.7	0.7	1	1	1
12/23/2022 23:00	0.7	12.0	2,242.9	0.7	0.7	1	1	1
Average/Sum#:	0.6	12.3	2,196.3	0.6	0.7	24 #	24 #	24 #
Minimum:	0.4	12.0	1,953.8	0.4	0.6	1	1	1
Maximum:	0.7	13.2	2,265.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.5	12.5	2,130.9	0.5	0.6	1	1	1
12/24/2022 01:00	0.5	12.6	2,124.1	0.5	0.6	1	1	1
12/24/2022 02:00	0.4	13.2	1,963.2	0.4	0.6	1	1	1
12/24/2022 03:00	0.4	13.2	1,955.6	0.4	0.6	1	1	1
12/24/2022 04:00	0.4	13.2	1,955.0	0.4	0.6	1	1	1
12/24/2022 05:00	0.4	13.2	1,953.0	0.4	0.6	1	1	1
12/24/2022 06:00	0.4	13.1	1,979.9	0.4	0.6	1	1	1
12/24/2022 07:00	0.4	13.0	2,010.1	0.5	0.6	1	1	1
12/24/2022 08:00	0.4	13.4	1,837.3	0.4	0.6	1	1	1
12/24/2022 09:00	0.6	13.9	1,316.3	0.6	0.4	1	1	0
12/24/2022 10:00	0.5	13.9	1,548.3	0.5	0.5	1	1	0
12/24/2022 11:00	0.5	13.9	1,547.9	0.5	0.5	1	1	0
12/24/2022 12:00	0.5	13.9	1,552.0	0.5	0.5	1	1	0
12/24/2022 13:00	0.6	13.9	1,554.4	0.6	0.5	1	1	0
12/24/2022 14:00	0.6	13.9	1,730.3	0.6	0.5	1	1	0
12/24/2022 15:00	0.6	13.9	1,734.3	0.6	0.5	1	1	0
12/24/2022 16:00	0.7	13.9	1,590.2	0.7	0.5	1	1	1
12/24/2022 17:00	0.2	13.1	1,969.4	0.4	0.6	1	1	1
12/24/2022 18:00	0.4	13.1	1,965.8	0.4	0.6	1	1	1
12/24/2022 19:00	0.5	13.1	1,965.9	0.5	0.6	1	1	1
12/24/2022 20:00	0.5	13.1	1,967.3	0.5	0.6	1	1	1
12/24/2022 21:00	0.5	13.1	1,962.5	0.5	0.6	1	1	1
12/24/2022 22:00	0.5	13.2	1,965.3	0.5	0.6	1	1	1
12/24/2022 23:00	0.5	13.1	1,967.2	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.4	1,843.6	0.5	0.6	24 #	24 #	17 #
Minimum:	0.2	12.5	1,316.3	0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,130.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	0.5	13.1	1,946.8	0.5	0.6	1	1	1
12/25/2022 01:00	0.0	15.6	592.2	0.0	0.2	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	17.7	345.3	0.0	0.1	1	0	0
12/25/2022 19:00	0.0	17.3	411.1	0.0	0.1	1	0	0
12/25/2022 20:00	0.0	15.9	780.4	0.0	0.2	1	0	0
12/25/2022 21:00	0.5	13.9	1,417.5	0.5	0.4	1	1	0
12/25/2022 22:00	0.6	13.9	1,455.7	0.6	0.4	1	1	0
12/25/2022 23:00	0.5	13.9	1,477.4	0.5	0.4	1	1	0
Average/Sum#:	0.3	15.2	1,053.3	0.3	0.3	8 #	4 #	1 #
Minimum:	0.0	13.1	345.3	0.0	0.1	0	0	0
Maximum:	0.6	17.7	1,946.8	0.6	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.5	13.8	1,763.9	0.5	0.5	1	1	0
12/26/2022 01:00	0.5	13.8	1,543.0	0.5	0.5	1	1	0
12/26/2022 02:00	0.5	13.8	1,700.6	0.5	0.5	1	1	0
12/26/2022 03:00	0.5	13.8	1,721.9	0.5	0.5	1	1	0
12/26/2022 04:00	0.5	13.8	1,721.7	0.5	0.5	1	1	0
12/26/2022 05:00	0.5	13.8	1,737.5	0.5	0.5	1	1	0
12/26/2022 06:00	0.5	13.8	1,736.8	0.5	0.5	1	1	0
12/26/2022 07:00	0.5	13.8	1,728.0	0.5	0.5	1	1	0
12/26/2022 08:00	0.5	13.8	1,734.8	0.5	0.5	1	1	0
12/26/2022 09:00	0.5	13.9	1,548.8	0.5	0.5	1	1	0
12/26/2022 10:00	0.5	13.9	1,544.0	0.5	0.5	1	1	0
12/26/2022 11:00	0.5	13.9	1,535.6	0.5	0.5	1	1	0
12/26/2022 12:00	0.5	13.9	1,526.6	0.5	0.5	1	1	0
12/26/2022 13:00	0.5	13.9	1,547.1	0.5	0.5	1	1	0
12/26/2022 14:00	0.5	13.8	1,610.5	0.5	0.5	1	1	0
12/26/2022 15:00	0.5	13.8	1,740.0	0.5	0.5	1	1	0
12/26/2022 16:00	0.5	13.8	1,774.3	0.5	0.5	1	1	1
12/26/2022 17:00	0.2	12.6	2,122.6	0.4	0.6	1	1	1
12/26/2022 18:00	0.4	12.4	2,163.9	0.5	0.6	1	1	1
12/26/2022 19:00	0.2	13.0	2,015.8	0.4	0.6	1	1	1
12/26/2022 20:00	0.2	13.1	2,000.4	0.4	0.6	1	1	1
12/26/2022 21:00	0.2	13.2	1,969.8	0.4	0.6	1	1	1
12/26/2022 22:00	0.2	13.2	1,947.6	0.4	0.6	1	1	1
12/26/2022 23:00	0.0	15.6	609.2	0.0	0.2	1	0	0
Average/Sum#:	0.4	13.7	1,710.2	0.5	0.5	24 #	23 #	7 #
Minimum:	0.0	12.4	609.2	0.0	0.2	1	0	0
Maximum:	0.5	15.6	2,163.9	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	18.8	198.2	0.0	0.1	1	0	0
12/27/2022 02:00	0.0	16.0	756.8	0.0	0.2	1	0	0
12/27/2022 03:00	0.6	13.8	1,538.4	0.6	0.5	1	1	0
12/27/2022 04:00	0.6	13.9	1,539.3	0.6	0.5	1	1	0
12/27/2022 05:00	0.6	13.8	1,685.4	0.6	0.5	1	1	0
12/27/2022 06:00	0.6	13.9	1,397.3	0.6	0.4	1	1	0
12/27/2022 07:00	0.6	13.8	1,731.2	0.6	0.5	1	1	0
12/27/2022 08:00	0.5	13.8	1,701.6	0.5	0.5	1	1	1
12/27/2022 09:00	0.2	12.9	1,972.8	0.4	0.6	1	1	1
12/27/2022 10:00	0.2	12.9	1,967.9	0.4	0.6	1	1	1
12/27/2022 11:00	0.4	12.9	1,970.4	0.5	0.6	1	1	1
12/27/2022 12:00	0.4	12.9	1,969.6	0.5	0.6	1	1	1
12/27/2022 13:00	0.4	12.9	1,969.2	0.5	0.6	1	1	1
12/27/2022 14:00	0.4	12.9	1,970.6	0.5	0.6	1	1	1
12/27/2022 15:00	0.4	12.9	1,970.8	0.5	0.6	1	1	1
12/27/2022 16:00	0.4	13.0	1,970.5	0.5	0.6	1	1	1
12/27/2022 17:00	0.4	13.0	1,962.5	0.5	0.6	1	1	1
12/27/2022 18:00	0.4	13.1	1,960.1	0.4	0.6	1	1	1
12/27/2022 19:00	0.4	13.1	1,959.5	0.4	0.6	1	1	1
12/27/2022 20:00	0.4	13.1	1,971.6	0.4	0.6	1	1	1
12/27/2022 21:00	0.4	13.1	1,972.6	0.4	0.6	1	1	1
12/27/2022 22:00	0.4	13.2	1,945.8	0.4	0.6	1	1	1
12/27/2022 23:00	0.6	14.0	1,392.3	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.6	1,716.3	0.5	0.5	23 #	21 #	15 #
Minimum:	0.0	12.9	198.2	0.0	0.1	0	0	0
Maximum:	0.6	18.8	1,972.8	0.6	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.6	13.9	1,539.7	0.6	0.5	1	1	0
12/28/2022 01:00	0.6	13.9	1,465.2	0.6	0.4	1	1	0
12/28/2022 02:00	0.6	13.9	1,520.9	0.6	0.5	1	1	0
12/28/2022 03:00	0.6	13.9	1,518.1	0.6	0.5	1	1	0
12/28/2022 04:00	0.6	13.9	1,528.2	0.6	0.5	1	1	0
12/28/2022 05:00	0.5	13.8	1,718.9	0.5	0.5	1	1	0
12/28/2022 06:00	0.6	13.8	1,735.9	0.6	0.5	1	1	0
12/28/2022 07:00	0.5	13.8	1,738.4	0.5	0.5	1	1	0
12/28/2022 08:00	0.6	13.8	1,716.3	0.6	0.5	1	1	0
12/28/2022 09:00	0.5	13.8	1,707.8	0.5	0.5	1	1	0
12/28/2022 10:00	0.5	13.9	1,547.7	0.5	0.5	1	1	0
12/28/2022 11:00	0.6	13.9	1,563.0	0.6	0.5	1	1	0
12/28/2022 12:00	0.6	13.9	1,545.4	0.6	0.5	1	1	0
12/28/2022 13:00	0.6	13.9	1,525.3	0.6	0.5	1	1	0
12/28/2022 14:00	0.6	13.9	1,549.1	0.6	0.5	1	1	0
12/28/2022 15:00	0.5	13.9	1,592.4	0.5	0.5	1	1	1
12/28/2022 16:00	0.2	12.6	2,095.4	0.4	0.6	1	1	1
12/28/2022 17:00	0.2	13.1	1,976.0	0.4	0.6	1	1	1
12/28/2022 18:00	0.2	13.2	1,956.1	0.4	0.6	1	1	1
12/28/2022 19:00	0.2	13.2	1,957.5	0.4	0.6	1	1	1
12/28/2022 20:00	0.2	13.2	1,959.0	0.4	0.6	1	1	1
12/28/2022 21:00	0.2	13.1	1,970.4	0.4	0.6	1	1	1
12/28/2022 22:00	0.2	13.2	1,956.0	0.4	0.6	1	1	1
12/28/2022 23:00	0.2	13.2	1,960.9	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.6	1,722.7	0.5	0.5	24 #	24 #	9 #
Minimum:	0.2	12.6	1,465.2	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,095.4	0.6	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	0.2	13.2	1,956.9	0.4	0.6	1	1	1
12/29/2022 01:00	0.2	13.2	1,961.0	0.4	0.6	1	1	1
12/29/2022 02:00	0.2	13.2	1,965.0	0.4	0.6	1	1	1
12/29/2022 03:00	0.2	13.2	1,964.8	0.4	0.6	1	1	1
12/29/2022 04:00	0.2	13.2	1,969.1	0.4	0.6	1	1	1
12/29/2022 05:00	0.2	12.9	2,038.0	0.4	0.6	1	1	1
12/29/2022 06:00	0.2	12.6	2,047.5	0.4	0.6	1	1	1
12/29/2022 07:00	0.2	12.8	2,051.3	0.4	0.6	1	1	1
12/29/2022 08:00	0.4	12.2	2,206.4	0.5	0.7	1	1	1
12/29/2022 09:00	0.5	11.9	2,259.5	0.5	0.7	1	1	1
12/29/2022 10:00	0.5	12.4	2,161.9	0.5	0.6	1	1	1
12/29/2022 11:00	0.2	12.9	2,024.3	0.4	0.6	1	1	1
12/29/2022 12:00	0.2	13.1	1,986.2	0.4	0.6	1	1	1
12/29/2022 13:00	0.2	13.2	1,975.5	0.4	0.6	1	1	1
12/29/2022 14:00	0.2	13.1	1,985.1	0.4	0.6	1	1	1
12/29/2022 15:00	0.2	13.1	1,989.5	0.4	0.6	1	1	1
12/29/2022 16:00	0.2	12.7	2,100.3	0.4	0.6	1	1	1
12/29/2022 17:00	0.5	12.3	2,176.8	0.5	0.7	1	1	1
12/29/2022 18:00	0.4	12.6	2,085.5	0.5	0.6	1	1	1
12/29/2022 19:00	0.1	13.2	1,968.4	0.2	0.6	1	1	1
12/29/2022 20:00	0.1	13.2	1,977.8	0.2	0.6	1	1	1
12/29/2022 21:00	0.2	13.1	1,989.3	0.4	0.6	1	1	1
12/29/2022 22:00	0.1	13.1	1,972.1	0.2	0.6	1	1	1
12/29/2022 23:00	0.1	13.1	1,943.3	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	2,031.5	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	11.9	1,943.3	0.2	0.6	1	1	1
Maximum:	0.5	13.2	2,259.5	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	0.0	15.9	561.7	0.0	0.2	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.9	561.7	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	15.9	561.7	0.0	0.2	0	0	0
Maximum:	0.0	15.9	561.7	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:13 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 78.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**78.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:14 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,645.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 563.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,645.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:15 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:16 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 8.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**84.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:16 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:17 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 443.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	1.3	11.9	2,165.1	0.9	6.50	1	1	1
10/01/2022 01:00	2.4	14.1	1,211.1	2.1	4.66	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	13.0	1,688.1	1.5	11.16 #	2 #	1 #	2 #
Minimum:	1.3	11.9	1,211.1	0.9	4.66	0	0	0
Maximum:	2.4	14.1	2,165.1	2.1	6.50	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2022 02:00	29.3	17.5	336.0	50.8	51.50	1	0	0
10/03/2022 03:00	9.1	15.5	867.5	9.9	32.10	1	0	0
10/03/2022 04:00	1.1	13.8	1,711.7	0.9	5.10	1	1	0
10/03/2022 05:00	1.1	13.8	1,704.2	0.9	5.10	1	1	0
10/03/2022 06:00	1.1	13.8	1,701.6	0.9	5.10	1	1	0
10/03/2022 07:00	1.2	13.8	1,708.6	1.0	6.80	1	1	0
10/03/2022 08:00	1.1	13.8	1,718.8	0.9	5.20	1	1	0
10/03/2022 09:00	1.1	13.8	1,725.0	0.9	5.20	1	1	0
10/03/2022 10:00	0.1	13.9	1,728.2	0.1	0.00	1	1	0
10/03/2022 11:00	1.0	13.9	1,728.3	0.8	5.20	1	1	0
10/03/2022 12:00	1.1	13.9	1,728.4	0.9	5.20	1	1	0
10/03/2022 13:00	1.1	13.9	1,730.3	0.9	5.20	1	1	0
10/03/2022 14:00	1.1	13.9	1,724.6	0.9	5.20	1	1	0
10/03/2022 15:00	1.2	13.6	1,766.0	1.0	7.10	1	1	1
10/03/2022 16:00	1.3	12.3	2,061.1	0.9	6.20	1	1	1
10/03/2022 17:00	1.5	11.8	2,172.2	1.0	8.70	1	1	1
10/03/2022 18:00	1.5	11.6	2,206.8	1.0	8.80	1	1	1
10/03/2022 19:00	1.4	11.8	2,173.9	0.9	6.50	1	1	1
10/03/2022 20:00	1.4	11.7	2,187.2	0.9	6.60	1	1	1
10/03/2022 21:00	1.4	11.8	2,174.5	0.9	6.50	1	1	1
10/03/2022 22:00	1.4	12.0	2,152.4	0.9	6.50	1	1	1
10/03/2022 23:00	1.4	11.9	2,171.8	0.9	6.50	1	1	1
Average/Sum#:	2.8	13.4	1,780.9	3.6	200.30 #	22 #	20 #	9 #
Minimum:	0.1	11.6	336.0	0.1	0.00	0	0	0
Maximum:	29.3	17.5	2,206.8	50.8	51.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2022 00:00	1.4	12.0	2,154.5	0.9	6.50	1	1	1
10/04/2022 01:00	1.4	12.0	2,158.5	0.9	6.50	1	1	1
10/04/2022 02:00	1.4	12.0	2,156.3	0.9	6.50	1	1	1
10/04/2022 03:00	1.4	12.0	2,166.2	0.9	6.50	1	1	1
10/04/2022 04:00	1.4	12.0	2,173.6	0.9	6.50	1	1	1
10/04/2022 05:00	1.4	11.8	2,201.6	0.9	6.60	1	1	1
10/04/2022 06:00	1.4	12.0	2,166.7	0.9	6.50	1	1	1
10/04/2022 07:00	1.3	12.6	2,035.8	0.9	6.10	1	1	1
10/04/2022 08:00	1.1	13.7	1,595.1	0.9	4.80	1	1	0
10/04/2022 09:00	1.3	13.8	1,547.9	1.1	6.20	1	1	0
10/04/2022 10:00	1.4	13.7	1,555.2	1.1	6.20	1	1	0
10/04/2022 11:00	1.4	13.7	1,564.0	1.1	6.30	1	1	0
10/04/2022 12:00	1.5	13.7	1,722.8	1.2	8.60	1	1	0
10/04/2022 13:00	0.2	13.8	1,747.1	0.2	1.70	1	1	1
10/04/2022 14:00	0.3	12.8	2,032.9	0.2	2.00	1	1	1
10/04/2022 15:00	1.3	12.0	2,150.2	0.9	6.50	1	1	1
10/04/2022 16:00	1.2	12.1	2,131.5	0.8	6.40	1	1	1
10/04/2022 17:00	1.2	12.0	2,143.7	0.8	6.40	1	1	1
10/04/2022 18:00	1.2	11.9	2,169.2	0.8	6.50	1	1	1
10/04/2022 19:00	1.3	11.9	2,185.2	0.9	6.60	1	1	1
10/04/2022 20:00	1.2	11.6	2,243.7	0.8	6.70	1	1	1
10/04/2022 21:00	1.2	11.9	2,190.4	0.8	6.60	1	1	1
10/04/2022 22:00	1.3	11.9	2,177.9	0.9	6.50	1	1	1
10/04/2022 23:00	1.2	12.2	2,144.8	0.8	6.40	1	1	1
Average/Sum#:	1.2	12.5	2,021.5	0.9	146.10 #	24 #	24 #	19 #
Minimum:	0.2	11.6	1,547.9	0.2	1.70	1	1	0
Maximum:	1.5	13.8	2,243.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.2	12.2	2,136.7	0.8	6.40	1	1	1
10/05/2022 01:00	1.2	12.8	1,998.7	0.9	6.00	1	1	1
10/05/2022 02:00	1.1	13.0	1,971.1	0.8	5.90	1	1	1
10/05/2022 03:00	1.2	12.5	2,085.4	0.8	6.30	1	1	1
10/05/2022 04:00	1.2	12.3	2,111.1	0.8	6.30	1	1	1
10/05/2022 05:00	1.3	11.9	2,200.3	0.9	6.60	1	1	1
10/05/2022 06:00	1.2	11.9	2,201.4	0.8	6.60	1	1	1
10/05/2022 07:00	1.1	12.9	1,985.2	0.8	6.00	1	1	1
10/05/2022 08:00	1.0	13.9	1,718.1	0.8	5.20	1	1	0
10/05/2022 09:00	1.0	13.9	1,682.9	0.8	5.00	1	1	0
10/05/2022 10:00	0.9	13.9	1,710.7	0.8	5.10	1	1	0
10/05/2022 11:00	1.1	13.9	1,722.4	0.9	5.20	1	1	0
10/05/2022 12:00	0.6	13.8	1,738.9	0.5	3.50	1	1	1
10/05/2022 13:00	1.2	12.4	2,080.5	0.8	6.20	1	1	1
10/05/2022 14:00	1.2	11.8	2,190.4	0.8	6.60	1	1	1
10/05/2022 15:00	1.2	12.1	2,137.1	0.8	6.40	1	1	1
10/05/2022 16:00	1.3	11.9	2,159.1	0.9	6.50	1	1	1
10/05/2022 17:00	1.2	11.7	2,198.2	0.8	6.60	1	1	1
10/05/2022 18:00	1.2	11.6	2,230.9	0.8	6.70	1	1	1
10/05/2022 19:00	1.3	11.6	2,240.8	0.8	6.70	1	1	1
10/05/2022 20:00	1.2	11.9	2,190.7	0.8	6.60	1	1	1
10/05/2022 21:00	1.2	11.6	2,237.8	0.8	6.70	1	1	1
10/05/2022 22:00	1.2	12.0	2,166.4	0.8	6.50	1	1	1
10/05/2022 23:00	1.3	12.0	2,176.0	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.5	2,053.0	0.8	146.10 #	24 #	24 #	20 #
Minimum:	0.6	11.6	1,682.9	0.5	3.50	1	1	0
Maximum:	1.3	13.9	2,240.8	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.3	12.1	2,165.7	0.9	6.50	1	1	1
10/06/2022 01:00	1.2	12.1	2,167.7	0.8	6.50	1	1	1
10/06/2022 02:00	1.2	12.1	2,165.0	0.8	6.50	1	1	1
10/06/2022 03:00	1.2	12.2	2,141.6	0.8	6.40	1	1	1
10/06/2022 04:00	1.3	12.0	2,181.3	0.9	6.50	1	1	1
10/06/2022 05:00	1.0	11.6	2,250.8	0.6	4.50	1	1	1
10/06/2022 06:00	1.3	11.8	2,238.5	0.8	6.70	1	1	1
10/06/2022 07:00	1.2	12.2	2,135.9	0.8	6.40	1	1	1
10/06/2022 08:00	1.2	12.4	2,082.9	0.8	6.20	1	1	1
10/06/2022 09:00	1.2	12.5	2,071.3	0.8	6.20	1	1	1
10/06/2022 10:00	1.2	12.5	2,082.0	0.8	6.20	1	1	1
10/06/2022 11:00	1.2	12.3	2,114.5	0.8	6.30	1	1	1
10/06/2022 12:00	1.2	12.1	2,136.7	0.8	6.40	1	1	1
10/06/2022 13:00	1.2	11.8	2,192.4	0.8	6.60	1	1	1
10/06/2022 14:00	1.2	11.8	2,197.6	0.8	6.60	1	1	1
10/06/2022 15:00	1.2	12.0	2,150.8	0.8	6.50	1	1	1
10/06/2022 16:00	1.2	11.8	2,191.5	0.8	6.60	1	1	1
10/06/2022 17:00	1.2	11.6	2,240.1	0.8	6.70	1	1	1
10/06/2022 18:00	1.2	11.7	2,239.0	0.8	6.70	1	1	1
10/06/2022 19:00	1.2	11.6	2,255.1	0.8	6.80	1	1	1
10/06/2022 20:00	1.2	11.6	2,259.5	0.8	6.80	1	1	1
10/06/2022 21:00	1.2	11.7	2,245.4	0.8	6.70	1	1	1
10/06/2022 22:00	1.2	12.0	2,190.1	0.8	6.60	1	1	1
10/06/2022 23:00	1.2	12.1	2,168.8	0.8	6.50	1	1	1
Average/Sum#:	1.2	12.0	2,177.7	0.8	154.40 #	24 #	24 #	24 #
Minimum:	1.0	11.6	2,071.3	0.6	4.50	1	1	1
Maximum:	1.3	12.5	2,259.5	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.2	12.2	2,143.9	0.8	6.40	1	1	1
10/07/2022 01:00	1.2	12.2	2,159.9	0.8	6.50	1	1	1
10/07/2022 02:00	1.2	12.2	2,141.6	0.8	6.40	1	1	1
10/07/2022 03:00	1.2	12.3	2,114.7	0.8	6.30	1	1	1
10/07/2022 04:00	1.2	12.2	2,155.6	0.8	6.50	1	1	1
10/07/2022 05:00	1.4	12.0	2,191.6	0.9	6.60	1	1	1
10/07/2022 06:00	1.2	12.0	2,204.6	0.8	6.60	1	1	1
10/07/2022 07:00	1.2	12.4	2,110.8	0.8	6.30	1	1	1
10/07/2022 08:00	1.2	12.7	2,030.0	0.9	6.10	1	1	1
10/07/2022 09:00	1.2	12.3	2,127.6	0.8	6.40	1	1	1
10/07/2022 10:00	1.2	12.3	2,127.5	0.8	6.40	1	1	1
10/07/2022 11:00	1.3	12.3	2,111.0	0.9	6.30	1	1	1
10/07/2022 12:00	1.2	12.0	2,168.6	0.8	6.50	1	1	1
10/07/2022 13:00	1.2	12.1	2,136.9	0.8	6.40	1	1	1
10/07/2022 14:00	1.2	11.9	2,182.3	0.8	6.50	1	1	1
10/07/2022 15:00	1.3	11.8	2,193.0	0.8	6.60	1	1	1
10/07/2022 16:00	1.2	11.9	2,179.2	0.8	6.50	1	1	1
10/07/2022 17:00	1.2	11.6	2,229.9	0.8	6.70	1	1	1
10/07/2022 18:00	1.2	11.6	2,243.3	0.8	6.70	1	1	1
10/07/2022 19:00	1.2	11.6	2,258.3	0.8	6.80	1	1	1
10/07/2022 20:00	1.2	11.6	2,262.5	0.8	6.80	1	1	1
10/07/2022 21:00	1.2	11.6	2,265.6	0.8	6.80	1	1	1
10/07/2022 22:00	1.2	11.7	2,257.3	0.8	6.80	1	1	1
10/07/2022 23:00	1.2	12.0	2,184.9	0.8	6.60	1	1	1
Average/Sum#:	1.2	12.0	2,174.2	0.8	156.50 #	24 #	24 #	24 #
Minimum:	1.2	11.6	2,030.0	0.8	6.10	1	1	1
Maximum:	1.4	12.7	2,265.6	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.2	12.1	2,173.3	0.8	6.50	1	1	1
10/08/2022 01:00	1.2	12.1	2,176.2	0.8	6.50	1	1	1
10/08/2022 02:00	1.2	12.1	2,167.4	0.8	6.50	1	1	1
10/08/2022 03:00	1.3	12.1	2,178.3	0.9	6.50	1	1	1
10/08/2022 04:00	1.2	12.0	2,176.1	0.8	6.50	1	1	1
10/08/2022 05:00	1.0	12.1	2,170.4	0.7	4.30	1	1	1
10/08/2022 06:00	1.2	12.3	2,110.4	0.8	6.30	1	1	1
10/08/2022 07:00	1.3	13.8	1,711.8	1.1	6.80	1	1	1
10/08/2022 08:00	1.1	13.9	1,365.6	0.9	4.10	1	1	0
10/08/2022 09:00	1.1	13.9	1,315.8	0.9	3.90	1	1	0
10/08/2022 10:00	1.1	14.0	1,312.6	0.9	3.90	1	1	0
10/08/2022 11:00	1.1	14.0	1,318.8	0.9	4.00	1	1	0
10/08/2022 12:00	1.1	13.8	1,569.8	0.9	4.70	1	1	0
10/08/2022 13:00	1.2	13.8	1,728.0	1.0	6.90	1	1	0
10/08/2022 14:00	1.2	13.7	1,745.1	1.0	7.00	1	1	1
10/08/2022 15:00	1.4	12.2	2,069.6	0.9	6.20	1	1	1
10/08/2022 16:00	1.4	11.7	2,201.9	0.9	6.60	1	1	1
10/08/2022 17:00	1.4	11.7	2,201.4	0.9	6.60	1	1	1
10/08/2022 18:00	1.4	11.9	2,167.0	0.9	6.50	1	1	1
10/08/2022 19:00	1.4	11.9	2,177.6	0.9	6.50	1	1	1
10/08/2022 20:00	1.4	11.9	2,180.4	0.9	6.50	1	1	1
10/08/2022 21:00	1.4	11.9	2,177.9	0.9	6.50	1	1	1
10/08/2022 22:00	1.4	12.0	2,173.3	0.9	6.50	1	1	1
10/08/2022 23:00	1.4	12.1	2,170.3	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.6	1,947.5	0.9	142.80 #	24 #	24 #	18 #
Minimum:	1.0	11.7	1,312.6	0.7	3.90	1	1	0
Maximum:	1.4	14.0	2,201.9	1.1	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.4	12.0	2,166.8	0.9	6.50	1	1	1
10/09/2022 01:00	1.4	12.1	2,167.0	0.9	6.50	1	1	1
10/09/2022 02:00	1.3	12.2	2,138.4	0.9	6.40	1	1	1
10/09/2022 03:00	1.4	12.2	2,147.8	0.9	6.40	1	1	1
10/09/2022 04:00	1.4	12.1	2,158.6	0.9	6.50	1	1	1
10/09/2022 05:00	1.4	12.1	2,149.2	0.9	6.40	1	1	1
10/09/2022 06:00	1.7	13.0	1,685.1	1.3	8.40	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 10:00	0.6	18.7	209.6	1.6	0.29	1	0	0
10/09/2022 11:00	10.6	15.6	799.9	11.8	34.40	1	0	0
10/09/2022 12:00	1.1	13.9	1,387.0	0.9	4.20	1	1	0
10/09/2022 13:00	1.1	14.0	1,390.9	0.9	4.20	1	1	0
10/09/2022 14:00	1.2	13.7	1,726.4	1.0	6.90	1	1	0
10/09/2022 15:00	1.1	13.8	1,562.3	0.9	4.70	1	1	0
10/09/2022 16:00	1.2	13.8	1,729.7	1.0	6.90	1	1	0
10/09/2022 17:00	1.2	13.6	1,781.5	1.0	7.10	1	1	1
10/09/2022 18:00	1.4	12.3	2,081.7	1.0	8.30	1	1	1
10/09/2022 19:00	1.5	11.7	2,209.0	1.0	8.80	1	1	1
10/09/2022 20:00	1.4	11.8	2,188.3	0.9	6.60	1	1	1
10/09/2022 21:00	1.4	11.9	2,174.8	0.9	6.50	1	1	1
10/09/2022 22:00	1.4	12.0	2,156.1	0.9	6.50	1	1	1
10/09/2022 23:00	1.4	12.1	2,147.1	0.9	6.40	1	1	1
Average/Sum#:	1.7	13.1	1,817.0	1.5	158.89 #	21 #	18 #	14 #
Minimum:	0.6	11.7	209.6	0.9	0.29	0	0	0
Maximum:	10.6	18.7	2,209.0	11.8	34.40	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.4	12.2	2,121.9	0.9	6.40	1	1	1
10/10/2022 01:00	1.3	12.4	2,092.6	0.9	6.30	1	1	1
10/10/2022 02:00	1.3	12.9	1,980.8	1.0	7.90	1	1	1
10/10/2022 03:00	1.3	12.4	2,083.6	0.9	6.30	1	1	1
10/10/2022 04:00	1.4	12.3	2,127.1	1.0	8.50	1	1	1
10/10/2022 05:00	1.4	11.8	2,214.2	0.9	6.60	1	1	1
10/10/2022 06:00	1.4	11.9	2,205.4	0.9	6.60	1	1	1
10/10/2022 07:00	1.2	13.3	1,816.6	0.9	5.40	1	1	1
10/10/2022 08:00	1.1	13.8	1,551.8	0.9	4.70	1	1	0
10/10/2022 09:00	1.1	13.9	1,545.1	0.9	4.60	1	1	0
10/10/2022 10:00	1.1	14.0	1,390.8	0.9	4.20	1	1	0
10/10/2022 11:00	1.1	13.9	1,560.6	0.9	4.70	1	1	0
10/10/2022 12:00	1.1	13.9	1,574.2	0.9	4.70	1	1	0
10/10/2022 13:00	1.2	13.8	1,729.9	1.0	6.90	1	1	0
10/10/2022 14:00	1.2	13.8	1,718.4	1.0	6.90	1	1	0
10/10/2022 15:00	1.2	13.8	1,602.6	1.0	6.40	1	1	0
10/10/2022 16:00	1.3	12.6	1,973.3	0.9	5.90	1	1	1
10/10/2022 17:00	1.4	11.9	2,163.0	0.9	6.50	1	1	1
10/10/2022 18:00	1.4	11.7	2,198.7	0.9	6.60	1	1	1
10/10/2022 19:00	1.4	11.8	2,169.1	0.9	6.50	1	1	1
10/10/2022 20:00	1.4	11.9	2,160.6	0.9	6.50	1	1	1
10/10/2022 21:00	1.4	12.2	2,102.8	0.9	6.30	1	1	1
10/10/2022 22:00	1.3	12.4	2,085.4	0.9	6.30	1	1	1
10/10/2022 23:00	1.3	12.9	1,953.3	1.0	7.80	1	1	1
Average/Sum#:	1.3	12.8	1,921.7	0.9	149.50 #	24 #	24 #	16 #
Minimum:	1.1	11.7	1,390.8	0.9	4.20	1	1	0
Maximum:	1.4	14.0	2,214.2	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	1.1	13.9	1,376.2	0.9	4.10	1	1	0
10/11/2022 01:00	1.1	13.9	1,300.5	0.9	3.90	1	1	0
10/11/2022 02:00	1.1	13.9	1,300.2	0.9	3.90	1	1	0
10/11/2022 03:00	1.1	13.9	1,352.3	0.9	4.10	1	1	0
10/11/2022 04:00	1.0	13.9	1,495.7	0.8	4.50	1	1	0
10/11/2022 05:00	1.1	13.9	1,319.9	0.9	4.00	1	1	0
10/11/2022 06:00	1.1	13.9	1,313.8	0.9	3.90	1	1	0
10/11/2022 07:00	1.1	13.9	1,315.9	0.9	3.90	1	1	0
10/11/2022 08:00	1.1	13.9	1,317.2	0.9	4.00	1	1	0
10/11/2022 09:00	1.1	13.9	1,480.0	0.9	4.40	1	1	0
10/11/2022 10:00	1.1	13.9	1,548.1	0.9	4.60	1	1	0
10/11/2022 11:00	1.1	13.8	1,635.9	0.9	4.90	1	1	0
10/11/2022 12:00	1.2	13.6	1,802.5	1.0	7.20	1	1	0
10/11/2022 13:00	1.2	13.6	1,793.7	1.0	7.20	1	1	0
10/11/2022 14:00	1.2	13.6	1,789.9	1.0	7.20	1	1	0
10/11/2022 15:00	1.2	13.6	1,787.5	1.0	7.20	1	1	0
10/11/2022 16:00	1.2	13.6	1,788.3	1.0	7.20	1	1	0
10/11/2022 17:00	1.2	13.6	1,789.6	1.0	7.20	1	1	0
10/11/2022 18:00	1.2	13.6	1,794.2	1.0	7.20	1	1	1
10/11/2022 19:00	1.3	12.6	2,005.4	0.9	6.00	1	1	1
10/11/2022 20:00	1.4	12.1	2,131.3	0.9	6.40	1	1	1
10/11/2022 21:00	1.4	12.4	2,034.7	1.0	8.10	1	1	1
10/11/2022 22:00	1.4	12.2	2,102.6	0.9	6.30	1	1	1
10/11/2022 23:00	1.3	12.8	1,971.1	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.5	1,647.8	0.9	133.30 #	24 #	24 #	6 #
Minimum:	1.0	12.1	1,300.2	0.8	3.90	1	1	0
Maximum:	1.4	13.9	2,131.3	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2022 00:00	1.3	13.0	1,958.1	1.0	7.80	1	1	1
10/12/2022 01:00	1.2	13.0	1,935.0	0.9	5.80	1	1	1
10/12/2022 02:00	1.1	13.8	1,519.8	0.9	4.60	1	1	0
10/12/2022 03:00	1.1	13.9	1,637.4	0.9	4.90	1	1	0
10/12/2022 04:00	1.2	13.7	1,768.9	1.0	7.10	1	1	0
10/12/2022 05:00	1.3	12.0	2,131.1	0.9	6.40	1	1	1
10/12/2022 06:00	1.4	11.7	2,260.0	0.9	6.80	1	1	1
10/12/2022 07:00	1.4	11.7	2,255.1	0.9	6.80	1	1	1
10/12/2022 08:00	1.4	11.7	2,247.7	0.9	6.70	1	1	1
10/12/2022 09:00	1.4	11.7	2,246.9	0.9	6.70	1	1	1
10/12/2022 10:00	1.4	11.7	2,242.0	0.9	6.70	1	1	1
10/12/2022 11:00	1.4	11.7	2,245.9	0.9	6.70	1	1	1
10/12/2022 12:00	1.5	11.6	2,250.7	1.0	9.00	1	1	1
10/12/2022 13:00	1.4	11.6	2,248.0	0.9	6.70	1	1	1
10/12/2022 14:00	1.4	11.6	2,249.4	0.9	6.70	1	1	1
10/12/2022 15:00	1.5	11.6	2,250.4	1.0	9.00	1	1	1
10/12/2022 16:00	1.4	11.4	2,266.7	0.9	6.80	1	1	1
10/12/2022 17:00	1.4	11.4	2,274.9	0.9	6.80	1	1	1
10/12/2022 18:00	1.5	11.6	2,233.1	1.0	8.90	1	1	1
10/12/2022 19:00	1.4	12.1	2,138.2	0.9	6.40	1	1	1
10/12/2022 20:00	1.4	12.0	2,147.6	0.9	6.40	1	1	1
10/12/2022 21:00	1.4	12.2	2,119.1	0.9	6.40	1	1	1
10/12/2022 22:00	1.3	12.4	2,086.8	0.9	6.30	1	1	1
10/12/2022 23:00	1.3	12.9	1,967.8	1.0	7.90	1	1	1
Average/Sum#:	1.4	12.2	2,111.7	0.9	164.30 #	24 #	24 #	21 #
Minimum:	1.1	11.4	1,519.8	0.9	4.60	1	1	0
Maximum:	1.5	13.9	2,274.9	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.3	12.9	1,961.3	1.0	7.80	1	1	1
10/13/2022 01:00	1.3	12.7	2,005.0	0.9	6.00	1	1	1
10/13/2022 02:00	1.2	13.0	1,953.3	0.9	5.90	1	1	1
10/13/2022 03:00	1.3	13.0	1,959.2	1.0	7.80	1	1	1
10/13/2022 04:00	1.2	13.0	1,926.0	0.9	5.80	1	1	1
10/13/2022 05:00	1.2	13.9	1,311.2	1.0	5.20	1	1	0
10/13/2022 06:00	1.1	13.9	1,311.4	0.9	3.90	1	1	0
10/13/2022 07:00	1.1	13.9	1,339.8	0.9	4.00	1	1	0
10/13/2022 08:00	1.2	13.8	1,587.0	1.0	6.30	1	1	0
10/13/2022 09:00	1.1	13.8	1,535.6	0.9	4.60	1	1	0
10/13/2022 10:00	1.2	13.6	1,804.0	1.0	7.20	1	1	0
10/13/2022 11:00	1.2	13.5	1,810.3	1.0	7.20	1	1	0
10/13/2022 12:00	1.2	13.6	1,808.3	1.0	7.20	1	1	0
10/13/2022 13:00	1.2	13.6	1,802.3	1.0	7.20	1	1	0
10/13/2022 14:00	1.2	13.6	1,793.3	1.0	7.20	1	1	0
10/13/2022 15:00	1.2	13.6	1,792.5	1.0	7.20	1	1	0
10/13/2022 16:00	1.2	13.6	1,790.7	1.0	7.20	1	1	0
10/13/2022 17:00	1.2	13.6	1,796.8	1.0	7.20	1	1	0
10/13/2022 18:00	1.2	13.5	1,804.3	1.0	7.20	1	1	0
10/13/2022 19:00	1.2	13.5	1,807.0	1.0	7.20	1	1	1
10/13/2022 20:00	1.3	12.4	2,059.6	0.9	6.20	1	1	1
10/13/2022 21:00	1.4	12.0	2,159.9	0.9	6.50	1	1	1
10/13/2022 22:00	1.4	12.4	2,083.7	1.0	8.30	1	1	1
10/13/2022 23:00	1.3	12.5	2,071.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.3	1,803.1	1.0	156.50 #	24 #	24 #	10 #
Minimum:	1.1	12.0	1,311.2	0.9	3.90	1	1	0
Maximum:	1.4	13.9	2,159.9	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.3	12.6	2,061.0	0.9	6.20	1	1	1
10/14/2022 01:00	1.3	12.5	2,055.5	0.9	6.20	1	1	1
10/14/2022 02:00	1.3	12.5	2,056.0	0.9	6.20	1	1	1
10/14/2022 03:00	1.3	12.5	2,053.2	0.9	6.20	1	1	1
10/14/2022 04:00	1.4	12.3	2,098.1	1.0	8.40	1	1	1
10/14/2022 05:00	1.7	11.5	2,254.4	1.1	9.00	1	1	1
10/14/2022 06:00	1.4	11.5	2,261.5	0.9	6.80	1	1	1
10/14/2022 07:00	1.4	11.5	2,266.0	0.9	6.80	1	1	1
10/14/2022 08:00	1.3	12.5	2,033.0	0.9	6.10	1	1	1
10/14/2022 09:00	1.3	12.9	1,968.5	1.0	7.90	1	1	1
10/14/2022 10:00	1.3	12.7	1,978.5	0.9	5.90	1	1	1
10/14/2022 11:00	1.3	12.7	1,988.2	0.9	6.00	1	1	1
10/14/2022 12:00	1.3	12.7	1,992.9	0.9	6.00	1	1	1
10/14/2022 13:00	1.3	12.6	1,998.9	0.9	6.00	1	1	1
10/14/2022 14:00	1.4	12.2	2,104.1	0.9	6.30	1	1	1
10/14/2022 15:00	1.4	12.0	2,146.5	0.9	6.40	1	1	1
10/14/2022 16:00	1.4	12.0	2,145.1	0.9	6.40	1	1	1
10/14/2022 17:00	1.4	11.5	2,227.8	0.9	6.70	1	1	1
10/14/2022 18:00	1.4	11.9	2,153.4	0.9	6.50	1	1	1
10/14/2022 19:00	1.4	12.1	2,127.2	0.9	6.40	1	1	1
10/14/2022 20:00	1.4	12.0	2,134.2	0.9	6.40	1	1	1
10/14/2022 21:00	1.4	12.1	2,122.5	0.9	6.40	1	1	1
10/14/2022 22:00	1.3	12.3	2,095.3	0.9	6.30	1	1	1
10/14/2022 23:00	1.9	13.9	1,333.3	1.6	4.40	1	0	1
Average/Sum#:	1.4	12.3	2,069.0	0.9	155.90 #	24 #	23 #	24 #
Minimum:	1.3	11.5	1,333.3	0.9	4.40	1	0	1
Maximum:	1.9	13.9	2,266.0	1.6	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 23:00	25.7	17.8	305.8	48.9	27.50	1	0	0
Average/Sum#:	25.7	17.8	305.8	48.9	27.50 #	1 #	0 #	0 #
Minimum:	25.7	17.8	305.8	48.9	27.50	0	0	0
Maximum:	25.7	17.8	305.8	48.9	27.50	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	19.1	15.6	846.3	21.3	66.00	1	0	0
10/17/2022 01:00	1.2	13.8	1,704.0	1.0	6.80	1	1	0
10/17/2022 02:00	1.2	13.8	1,714.0	1.0	6.90	1	1	0
10/17/2022 03:00	1.2	13.7	1,810.2	1.0	7.20	1	1	1
10/17/2022 04:00	1.4	12.3	2,087.2	1.0	8.30	1	1	1
10/17/2022 05:00	1.6	11.9	2,182.2	1.0	8.70	1	1	1
10/17/2022 06:00	1.4	12.2	2,151.6	0.9	6.50	1	1	1
10/17/2022 07:00	1.3	12.4	2,100.6	0.9	6.30	1	1	1
10/17/2022 08:00	1.2	13.6	1,691.4	1.0	6.80	1	1	1
10/17/2022 09:00	1.2	13.8	1,644.4	1.0	6.60	1	1	0
10/17/2022 10:00	1.1	13.9	1,523.9	0.9	4.60	1	1	0
10/17/2022 11:00	1.1	13.8	1,608.2	0.9	4.80	1	1	0
10/17/2022 12:00	1.1	13.9	1,506.8	0.9	4.50	1	1	0
10/17/2022 13:00	1.2	13.9	1,513.1	1.0	6.10	1	1	0
10/17/2022 14:00	1.1	13.9	1,670.2	0.9	5.00	1	1	0
10/17/2022 15:00	1.2	13.7	1,713.7	1.0	6.90	1	1	1
10/17/2022 16:00	1.4	12.4	2,086.6	1.0	8.30	1	1	1
10/17/2022 17:00	1.4	11.6	2,242.9	0.9	6.70	1	1	1
10/17/2022 18:00	1.5	11.6	2,260.4	1.0	9.00	1	1	1
10/17/2022 19:00	1.4	11.7	2,236.0	0.9	6.70	1	1	1
10/17/2022 20:00	1.4	11.7	2,243.1	0.9	6.70	1	1	1
10/17/2022 21:00	1.5	11.6	2,256.3	1.0	9.00	1	1	1
10/17/2022 22:00	1.4	12.0	2,182.4	0.9	6.50	1	1	1
10/17/2022 23:00	1.4	12.0	2,180.6	0.9	6.50	1	1	1
Average/Sum#:	2.0	13.0	1,881.5	1.8	221.40 #	24 #	23 #	15 #
Minimum:	1.1	11.6	846.3	0.9	4.50	1	0	0
Maximum:	19.1	15.6	2,260.4	21.3	66.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.4	12.0	2,175.4	0.9	6.50	1	1	1
10/18/2022 01:00	1.4	12.1	2,166.0	0.9	6.50	1	1	1
10/18/2022 02:00	1.4	12.0	2,168.9	0.9	6.50	1	1	1
10/18/2022 03:00	1.4	11.9	2,193.4	0.9	6.60	1	1	1
10/18/2022 04:00	1.4	11.9	2,192.8	0.9	6.60	1	1	1
10/18/2022 05:00	1.4	12.0	2,173.8	0.9	6.50	1	1	1
10/18/2022 06:00	1.4	12.2	2,149.9	0.9	6.40	1	1	1
10/18/2022 07:00	1.4	12.1	2,148.0	0.9	6.40	1	1	1
10/18/2022 08:00	1.4	12.1	2,167.9	0.9	6.50	1	1	1
10/18/2022 09:00	1.4	12.1	2,165.6	0.9	6.50	1	1	1
10/18/2022 10:00	1.4	12.2	2,133.5	0.9	6.40	1	1	1
10/18/2022 11:00	1.4	12.3	2,107.8	1.0	8.40	1	1	1
10/18/2022 12:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
10/18/2022 13:00	1.4	12.3	2,109.2	1.0	8.40	1	1	1
10/18/2022 14:00	1.4	12.2	2,117.2	0.9	6.40	1	1	1
10/18/2022 15:00	1.4	12.1	2,149.3	0.9	6.40	1	1	1
10/18/2022 16:00	1.4	11.7	2,239.2	0.9	6.70	1	1	1
10/18/2022 17:00	1.4	11.9	2,202.8	0.9	6.60	1	1	1
10/18/2022 18:00	1.5	11.7	2,249.3	1.0	9.00	1	1	1
10/18/2022 19:00	1.4	11.6	2,271.7	0.9	6.80	1	1	1
10/18/2022 20:00	1.4	11.6	2,277.4	0.9	6.80	1	1	1
10/18/2022 21:00	1.4	11.6	2,277.9	0.9	6.80	1	1	1
10/18/2022 22:00	1.4	11.9	2,202.9	0.9	6.60	1	1	1
10/18/2022 23:00	1.4	11.9	2,201.6	0.9	6.60	1	1	1
Average/Sum#:	1.4	12.0	2,181.1	0.9	163.20 #	24 #	24 #	24 #
Minimum:	1.3	11.6	2,105.5	0.9	6.30	1	1	1
Maximum:	1.5	12.3	2,277.9	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2022 00:00	1.4	12.0	2,189.4	0.9	6.60	1	1	1
10/19/2022 01:00	1.3	12.4	2,117.8	0.9	6.40	1	1	1
10/19/2022 02:00	1.3	12.5	2,070.1	0.9	6.20	1	1	1
10/19/2022 03:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
10/19/2022 04:00	1.4	12.1	2,139.4	0.9	6.40	1	1	1
10/19/2022 05:00	1.4	11.7	2,201.4	0.9	6.60	1	1	1
10/19/2022 06:00	1.3	11.9	2,222.6	0.9	6.70	1	1	1
10/19/2022 07:00	1.4	12.2	2,151.9	0.9	6.50	1	1	1
10/19/2022 08:00	1.4	12.3	2,140.6	1.0	8.60	1	1	1
10/19/2022 09:00	1.3	12.4	2,101.5	0.9	6.30	1	1	1
10/19/2022 10:00	1.4	12.4	2,092.4	1.0	8.40	1	1	1
10/19/2022 11:00	1.3	12.2	2,121.8	0.9	6.40	1	1	1
10/19/2022 12:00	1.4	12.1	2,136.5	0.9	6.40	1	1	1
10/19/2022 13:00	1.4	12.0	2,154.1	0.9	6.50	1	1	1
10/19/2022 14:00	1.4	12.1	2,145.1	0.9	6.40	1	1	1
10/19/2022 15:00	1.4	11.8	2,185.0	0.9	6.60	1	1	1
10/19/2022 16:00	1.4	11.7	2,199.7	0.9	6.60	1	1	1
10/19/2022 17:00	1.4	12.1	2,124.9	0.9	6.40	1	1	1
10/19/2022 18:00	1.3	12.2	2,109.1	0.9	6.30	1	1	1
10/19/2022 19:00	1.4	12.2	2,115.7	0.9	6.30	1	1	1
10/19/2022 20:00	1.4	12.1	2,154.7	0.9	6.50	1	1	1
10/19/2022 21:00	1.3	12.3	2,120.2	0.9	6.40	1	1	1
10/19/2022 22:00	1.4	12.4	2,092.4	1.0	8.40	1	1	1
10/19/2022 23:00	1.4	12.3	2,111.2	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.2	2,137.6	0.9	162.60 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,070.1	0.9	6.20	1	1	1
Maximum:	1.4	12.5	2,222.6	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.3	12.3	2,129.2	0.9	6.40	1	1	1
10/20/2022 01:00	1.4	12.4	2,089.4	1.0	8.40	1	1	1
10/20/2022 02:00	1.3	12.5	2,083.4	0.9	6.30	1	1	1
10/20/2022 03:00	1.3	12.4	2,093.7	0.9	6.30	1	1	1
10/20/2022 04:00	1.4	12.3	2,133.0	1.0	8.50	1	1	1
10/20/2022 05:00	1.4	11.8	2,202.7	0.9	6.60	1	1	1
10/20/2022 06:00	1.4	12.0	2,196.1	0.9	6.60	1	1	1
10/20/2022 07:00	1.3	12.6	2,066.6	0.9	6.20	1	1	1
10/20/2022 08:00	1.3	12.6	2,058.0	0.9	6.20	1	1	1
10/20/2022 09:00	1.3	12.5	2,072.7	0.9	6.20	1	1	1
10/20/2022 10:00	1.3	12.5	2,068.4	0.9	6.20	1	1	1
10/20/2022 11:00	1.4	12.4	2,087.7	1.0	8.40	1	1	1
10/20/2022 12:00	1.4	12.3	2,089.8	1.0	8.40	1	1	1
10/20/2022 13:00	1.3	12.3	2,104.8	0.9	6.30	1	1	1
10/20/2022 14:00	1.4	12.2	2,117.9	0.9	6.40	1	1	1
10/20/2022 15:00	1.4	12.1	2,149.5	0.9	6.40	1	1	1
10/20/2022 16:00	1.4	11.5	2,255.7	0.9	6.80	1	1	1
10/20/2022 17:00	1.4	11.8	2,184.0	0.9	6.60	1	1	1
10/20/2022 18:00	1.4	11.7	2,231.4	0.9	6.70	1	1	1
10/20/2022 19:00	1.4	12.2	2,115.3	0.9	6.30	1	1	1
10/20/2022 20:00	1.4	12.2	2,110.7	0.9	6.30	1	1	1
10/20/2022 21:00	1.4	12.4	2,086.7	1.0	8.30	1	1	1
10/20/2022 22:00	1.3	12.4	2,088.4	0.9	6.30	1	1	1
10/20/2022 23:00	1.4	12.2	2,125.0	0.9	6.40	1	1	1
Average/Sum#:	1.4	12.2	2,122.5	0.9	163.50 #	24 #	24 #	24 #
Minimum:	1.3	11.5	2,058.0	0.9	6.20	1	1	1
Maximum:	1.4	12.6	2,255.7	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	1.2	12.8	1,944.1	0.9	5.80	1	1	1
10/21/2022 01:00	1.1	13.9	1,583.3	0.9	4.70	1	1	0
10/21/2022 02:00	1.1	13.9	1,597.9	0.9	4.80	1	1	0
10/21/2022 03:00	1.1	13.9	1,547.4	0.9	4.60	1	1	0
10/21/2022 04:00	1.1	13.9	1,708.6	0.9	5.10	1	1	0
10/21/2022 05:00	1.1	13.9	1,710.6	0.9	5.10	1	1	0
10/21/2022 06:00	1.1	13.9	1,608.8	0.9	4.80	1	1	0
10/21/2022 07:00	1.1	13.9	1,676.8	0.9	5.00	1	1	0
10/21/2022 08:00	1.1	13.9	1,716.7	0.9	5.20	1	1	0
10/21/2022 09:00	1.1	13.9	1,720.8	0.9	5.20	1	1	0
10/21/2022 10:00	1.1	13.9	1,719.5	0.9	5.20	1	1	0
10/21/2022 11:00	1.1	13.9	1,683.4	0.9	5.10	1	1	0
10/21/2022 12:00	1.1	13.8	1,661.0	0.9	5.00	1	1	0
10/21/2022 13:00	1.2	13.8	1,633.6	1.0	6.50	1	1	0
10/21/2022 14:00	1.2	13.8	1,692.1	1.0	6.80	1	1	0
10/21/2022 15:00	1.1	13.8	1,568.6	0.9	4.70	1	1	1
10/21/2022 16:00	1.4	12.2	2,099.1	0.9	6.30	1	1	1
10/21/2022 17:00	1.5	11.8	2,183.0	1.0	8.70	1	1	1
10/21/2022 18:00	1.4	12.0	2,142.7	0.9	6.40	1	1	1
10/21/2022 19:00	1.4	12.3	2,098.0	1.0	8.40	1	1	1
10/21/2022 20:00	1.4	12.2	2,114.4	0.9	6.30	1	1	1
10/21/2022 21:00	1.4	11.9	2,175.3	0.9	6.50	1	1	1
10/21/2022 22:00	2.4	14.0	1,230.6	2.1	4.70	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.3	13.4	1,774.6	1.0	130.90 #	23 #	22 #	9 #
Minimum:	1.1	11.8	1,230.6	0.9	4.60	0	0	0
Maximum:	2.4	14.0	2,183.0	2.1	8.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 12:00	0.3	21.0	2.2	0.3	0.00	1	0	0
10/24/2022 13:00	35.7	17.0	429.7	54.0	85.50	1	0	0
10/24/2022 14:00	8.3	14.1	1,572.3	7.2	42.50	1	0	0
10/24/2022 15:00	1.1	13.7	1,771.7	0.9	5.30	1	1	0
10/24/2022 16:00	1.2	13.7	1,770.8	1.0	7.10	1	1	0
10/24/2022 17:00	1.2	13.7	1,779.7	1.0	7.10	1	1	0
10/24/2022 18:00	1.1	13.7	1,791.6	0.9	5.40	1	1	0
10/24/2022 19:00	1.2	13.7	1,799.7	1.0	7.20	1	1	0
10/24/2022 20:00	1.2	13.7	1,806.0	1.0	7.20	1	1	0
10/24/2022 21:00	1.1	13.7	1,813.9	0.9	5.40	1	1	0
10/24/2022 22:00	1.2	13.7	1,810.6	1.0	7.20	1	1	0
10/24/2022 23:00	1.1	13.7	1,822.7	0.9	5.50	1	1	0
Average/Sum#:	4.6	14.6	1,514.2	5.8	185.40 #	12 #	9 #	0 #
Minimum:	0.3	13.7	2.2	0.3	0.00	0	0	0
Maximum:	35.7	21.0	1,822.7	54.0	85.50	1	1	0
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	1.2	13.7	1,809.3	1.0	7.20	1	1	0
10/25/2022 01:00	1.2	13.7	1,804.8	1.0	7.20	1	1	0
10/25/2022 02:00	1.1	13.8	1,804.4	0.9	5.40	1	1	0
10/25/2022 03:00	1.1	13.8	1,802.4	0.9	5.40	1	1	0
10/25/2022 04:00	1.2	13.8	1,805.0	1.0	7.20	1	1	0
10/25/2022 05:00	1.1	13.8	1,808.1	0.9	5.40	1	1	0
10/25/2022 06:00	1.1	13.8	1,808.2	0.9	5.40	1	1	0
10/25/2022 07:00	1.1	13.8	1,807.7	0.9	5.40	1	1	0
10/25/2022 08:00	1.1	13.7	1,812.1	0.9	5.40	1	1	0
10/25/2022 09:00	1.2	13.7	1,815.9	1.0	7.30	1	1	0
10/25/2022 10:00	1.2	13.7	1,814.8	1.0	7.30	1	1	0
10/25/2022 11:00	1.2	13.7	1,829.7	1.0	7.30	1	1	0
10/25/2022 12:00	1.2	13.7	1,832.3	1.0	7.30	1	1	0
10/25/2022 13:00	1.2	13.6	1,836.6	1.0	7.30	1	1	0
10/25/2022 14:00	1.2	13.6	1,831.6	1.0	7.30	1	1	0
10/25/2022 15:00	1.2	13.6	1,832.4	1.0	7.30	1	1	0
10/25/2022 16:00	1.2	13.6	1,831.0	1.0	7.30	1	1	0
10/25/2022 17:00	1.2	13.6	1,834.2	1.0	7.30	1	1	0
10/25/2022 18:00	1.2	13.7	1,826.1	1.0	7.30	1	1	0
10/25/2022 19:00	1.2	13.7	1,814.8	1.0	7.30	1	1	0
10/25/2022 20:00	1.2	13.7	1,807.6	1.0	7.20	1	1	0
10/25/2022 21:00	1.2	13.7	1,809.8	1.0	7.20	1	1	0
10/25/2022 22:00	1.1	13.7	1,804.5	0.9	5.40	1	1	0
10/25/2022 23:00	1.1	13.9	1,635.5	0.9	4.90	1	1	0
Average/Sum#:	1.2	13.7	1,809.1	1.0	159.00 #	24 #	24 #	0 #
Minimum:	1.1	13.6	1,635.5	0.9	4.90	1	1	0
Maximum:	1.2	13.9	1,836.6	1.0	7.30	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2022 00:00	1.1	13.8	1,630.9	0.9	4.90	1	1	0
10/26/2022 01:00	1.1	13.9	1,631.9	0.9	4.90	1	1	0
10/26/2022 02:00	1.1	13.9	1,628.9	0.9	4.90	1	1	0
10/26/2022 03:00	1.1	13.9	1,616.4	0.9	4.80	1	1	0
10/26/2022 04:00	1.1	13.8	1,794.6	0.9	5.40	1	1	0
10/26/2022 05:00	1.0	13.9	1,733.8	0.8	5.20	1	1	0
10/26/2022 06:00	1.1	13.9	1,691.8	0.9	5.10	1	1	0
10/26/2022 07:00	1.1	13.8	1,742.7	0.9	5.20	1	1	0
10/26/2022 08:00	3.4	15.4	735.2	3.6	2.59	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 16:00	20.6	18.3	240.1	46.7	13.22	1	0	0
10/26/2022 17:00	32.8	17.6	391.6	58.6	44.84	1	0	0
10/26/2022 18:00	23.7	15.4	828.0	25.4	77.80	1	0	0
10/26/2022 19:00	1.1	13.7	1,825.1	0.9	5.50	1	1	0
10/26/2022 20:00	1.2	13.7	1,820.3	1.0	7.30	1	1	0
10/26/2022 21:00	1.1	13.7	1,810.2	0.9	5.40	1	1	0
10/26/2022 22:00	1.1	13.7	1,764.5	0.9	5.30	1	1	0
10/26/2022 23:00	1.9	14.5	1,164.0	1.8	6.09	1	0	0
Average/Sum#:	5.6	14.5	1,414.7	8.6	208.44 #	17 #	12 #	0 #
Minimum:	1.0	13.7	240.1	0.8	2.59	0	0	0
Maximum:	32.8	18.3	1,825.1	58.6	77.80	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/31/2022 01:00	29.1	17.7	299.3	53.7	57.52	1	0	0
10/31/2022 02:00	14.2	16.0	725.0	17.1	45.70	1	0	0
10/31/2022 03:00	1.1	13.8	1,712.6	0.9	5.10	1	1	0
10/31/2022 04:00	1.1	13.8	1,726.3	0.9	5.20	1	1	0
10/31/2022 05:00	1.1	13.8	1,711.3	0.9	5.10	1	1	0
10/31/2022 06:00	1.1	13.8	1,692.8	0.9	5.10	1	1	0
10/31/2022 07:00	1.1	13.8	1,693.6	0.9	5.10	1	1	0
10/31/2022 08:00	1.1	13.8	1,704.5	0.9	5.10	1	1	0
10/31/2022 09:00	1.1	13.9	1,706.8	0.9	5.10	1	1	0
10/31/2022 10:00	1.1	13.9	1,708.4	0.9	5.10	1	1	0
10/31/2022 11:00	1.1	13.9	1,689.0	0.9	5.10	1	1	0
10/31/2022 12:00	1.1	13.9	1,687.9	0.9	5.10	1	1	0
10/31/2022 13:00	1.1	13.9	1,702.8	0.9	5.10	1	1	0
10/31/2022 14:00	1.2	13.7	1,767.7	1.0	7.10	1	1	1
10/31/2022 15:00	1.4	12.5	2,082.4	1.0	8.30	1	1	1
10/31/2022 16:00	1.3	12.3	2,105.6	0.9	6.30	1	1	1
10/31/2022 17:00	1.4	12.4	2,076.3	1.0	8.30	1	1	1
10/31/2022 18:00	1.3	12.4	2,082.4	0.9	6.20	1	1	1
10/31/2022 19:00	1.4	12.4	2,103.6	1.0	8.40	1	1	1
10/31/2022 20:00	1.3	12.4	2,089.0	0.9	6.30	1	1	1
10/31/2022 21:00	1.4	12.2	2,130.3	0.9	6.40	1	1	1
10/31/2022 22:00	1.3	12.3	2,096.7	0.9	6.30	1	1	1
10/31/2022 23:00	1.4	12.2	2,136.9	0.9	6.40	1	1	1
Average/Sum#:	3.0	13.5	1,757.9	3.9	229.42 #	23 #	21 #	10 #
Minimum:	1.1	12.2	299.3	0.9	5.10	0	0	0
Maximum:	29.1	17.7	2,136.9	53.7	57.52	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.4	12.2	2,154.2	0.9	6.50	1	1	1
11/01/2022 01:00	1.3	12.2	2,150.3	0.9	6.50	1	1	1
11/01/2022 02:00	1.4	12.2	2,158.5	0.9	6.50	1	1	1
11/01/2022 03:00	1.4	12.2	2,167.8	0.9	6.50	1	1	1
11/01/2022 04:00	1.4	12.2	2,175.8	0.9	6.50	1	1	1
11/01/2022 05:00	1.5	12.1	2,176.4	1.0	8.70	1	1	1
11/01/2022 06:00	1.4	11.8	2,250.2	0.9	6.80	1	1	1
11/01/2022 07:00	1.4	12.0	2,187.2	0.9	6.60	1	1	1
11/01/2022 08:00	1.4	11.7	2,240.2	0.9	6.70	1	1	1
11/01/2022 09:00	1.3	12.2	2,118.9	0.9	6.40	1	1	1
11/01/2022 10:00	1.3	12.3	2,123.0	0.9	6.40	1	1	1
11/01/2022 11:00	1.4	12.0	2,183.5	0.9	6.60	1	1	1
11/01/2022 12:00	1.4	11.9	2,189.4	0.9	6.60	1	1	1
11/01/2022 13:00	1.4	12.0	2,180.9	0.9	6.50	1	1	1
11/01/2022 14:00	1.3	12.4	2,089.8	0.9	6.30	1	1	1
11/01/2022 15:00	1.3	12.6	2,087.1	0.9	6.30	1	1	1
11/01/2022 16:00	1.4	12.1	2,204.2	0.9	6.60	1	1	1
11/01/2022 17:00	1.4	11.6	2,294.1	0.9	6.90	1	1	1
11/01/2022 18:00	1.3	12.1	2,186.6	0.9	6.60	1	1	1
11/01/2022 19:00	1.4	12.3	2,168.2	1.0	8.70	1	1	1
11/01/2022 20:00	1.4	12.1	2,209.2	0.9	6.60	1	1	1
11/01/2022 21:00	1.3	12.6	2,087.6	0.9	6.30	1	1	1
11/01/2022 22:00	1.3	12.7	2,075.1	0.9	6.20	1	1	1
11/01/2022 23:00	1.2	13.3	1,849.2	0.9	5.50	1	1	1
Average/Sum#:	1.4	12.2	2,154.5	0.9	159.80 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,849.2	0.9	5.50	1	1	1
Maximum:	1.5	13.3	2,294.1	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	1.1	13.9	1,353.8	0.9	4.10	1	1	0
11/02/2022 01:00	1.1	13.9	1,639.5	0.9	4.90	1	1	0
11/02/2022 02:00	1.1	13.8	1,709.9	0.9	5.10	1	1	0
11/02/2022 03:00	1.1	13.9	1,353.8	0.9	4.10	1	1	0
11/02/2022 04:00	1.1	13.8	1,683.4	0.9	5.10	1	1	0
11/02/2022 05:00	1.3	13.1	1,917.9	1.0	7.70	1	1	1
11/02/2022 06:00	1.3	12.5	2,169.6	0.9	6.50	1	1	1
11/02/2022 07:00	1.3	12.7	2,129.3	0.9	6.40	1	1	1
11/02/2022 08:00	1.3	12.9	2,028.9	1.0	8.10	1	1	1
11/02/2022 09:00	1.1	13.8	1,719.4	0.9	5.20	1	1	0
11/02/2022 10:00	1.1	13.9	1,549.8	0.9	4.60	1	1	0
11/02/2022 11:00	1.1	13.9	1,678.6	0.9	5.00	1	1	0
11/02/2022 12:00	1.1	13.9	1,558.6	0.9	4.70	1	1	0
11/02/2022 13:00	1.1	13.9	1,562.4	0.9	4.70	1	1	0
11/02/2022 14:00	1.1	13.9	1,544.2	0.9	4.60	1	1	0
11/02/2022 15:00	1.1	13.9	1,612.7	0.9	4.80	1	1	1
11/02/2022 16:00	1.3	12.6	2,080.8	0.9	6.20	1	1	1
11/02/2022 17:00	1.4	12.3	2,172.4	1.0	8.70	1	1	1
11/02/2022 18:00	1.4	12.4	2,164.8	1.0	8.70	1	1	1
11/02/2022 19:00	1.3	12.4	2,165.2	0.9	6.50	1	1	1
11/02/2022 20:00	1.3	12.4	2,166.8	0.9	6.50	1	1	1
11/02/2022 21:00	1.3	12.5	2,152.9	0.9	6.50	1	1	1
11/02/2022 22:00	1.3	12.4	2,163.4	0.9	6.50	1	1	1
11/02/2022 23:00	1.3	12.4	2,176.3	0.9	6.50	1	1	1
Average/Sum#:	1.2	13.2	1,852.3	0.9	141.70 #	24 #	24 #	13 #
Minimum:	1.1	12.3	1,353.8	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,176.3	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.4	12.4	2,167.7	1.0	8.70	1	1	1
11/03/2022 01:00	1.3	12.5	2,153.5	0.9	6.50	1	1	1
11/03/2022 02:00	1.3	12.3	2,199.7	0.9	6.60	1	1	1
11/03/2022 03:00	1.4	12.1	2,243.0	0.9	6.70	1	1	1
11/03/2022 04:00	1.4	12.4	2,170.3	1.0	8.70	1	1	1
11/03/2022 05:00	1.2	12.4	2,175.5	0.8	6.50	1	1	1
11/03/2022 06:00	1.4	12.1	2,246.8	0.9	6.70	1	1	1
11/03/2022 07:00	1.3	12.6	2,117.7	0.9	6.40	1	1	1
11/03/2022 08:00	1.1	13.9	1,461.2	0.9	4.40	1	1	0
11/03/2022 09:00	1.1	13.9	1,567.5	0.9	4.70	1	1	0
11/03/2022 10:00	1.1	13.9	1,581.7	0.9	4.70	1	1	0
11/03/2022 11:00	1.1	13.9	1,575.7	0.9	4.70	1	1	0
11/03/2022 12:00	1.1	13.9	1,587.6	0.9	4.80	1	1	0
11/03/2022 13:00	1.1	13.9	1,496.8	0.9	4.50	1	1	0
11/03/2022 14:00	1.1	13.9	1,564.2	0.9	4.70	1	1	0
11/03/2022 15:00	1.1	13.8	1,787.2	0.9	5.40	1	1	1
11/03/2022 16:00	1.3	12.7	2,081.8	0.9	6.20	1	1	1
11/03/2022 17:00	1.3	12.4	2,162.4	0.9	6.50	1	1	1
11/03/2022 18:00	1.3	12.3	2,178.2	0.9	6.50	1	1	1
11/03/2022 19:00	1.4	12.3	2,176.0	1.0	8.70	1	1	1
11/03/2022 20:00	1.3	12.3	2,164.2	0.9	6.50	1	1	1
11/03/2022 21:00	1.3	12.3	2,163.9	0.9	6.50	1	1	1
11/03/2022 22:00	1.4	12.3	2,163.3	1.0	8.70	1	1	1
11/03/2022 23:00	1.4	12.1	2,220.6	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.9	1,975.3	0.9	151.00 #	24 #	24 #	17 #
Minimum:	1.1	12.1	1,461.2	0.8	4.40	1	1	0
Maximum:	1.4	13.9	2,246.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.3	12.5	2,148.4	0.9	6.40	1	1	1
11/04/2022 01:00	1.3	12.6	2,120.9	0.9	6.40	1	1	1
11/04/2022 02:00	1.3	12.8	2,070.3	0.9	6.20	1	1	1
11/04/2022 03:00	1.3	12.8	2,074.1	0.9	6.20	1	1	1
11/04/2022 04:00	1.3	12.5	2,153.1	0.9	6.50	1	1	1
11/04/2022 05:00	1.4	12.0	2,266.7	0.9	6.80	1	1	1
11/04/2022 06:00	1.3	12.4	2,187.8	0.9	6.60	1	1	1
11/04/2022 07:00	1.3	12.8	2,062.9	0.9	6.20	1	1	1
11/04/2022 08:00	1.1	13.8	1,733.8	0.9	5.20	1	1	0
11/04/2022 09:00	1.1	13.9	1,557.3	0.9	4.70	1	1	0
11/04/2022 10:00	1.1	13.9	1,396.0	0.9	4.20	1	1	0
11/04/2022 11:00	1.1	14.0	1,324.8	0.9	4.00	1	1	0
11/04/2022 12:00	1.1	14.0	1,322.8	0.9	4.00	1	1	0
11/04/2022 13:00	1.1	14.0	1,324.0	0.9	4.00	1	1	0
11/04/2022 14:00	1.1	13.9	1,404.7	0.9	4.20	1	1	0
11/04/2022 15:00	1.1	13.8	1,636.8	0.9	4.90	1	1	1
11/04/2022 16:00	1.3	12.6	2,081.0	0.9	6.20	1	1	1
11/04/2022 17:00	1.3	12.4	2,119.5	0.9	6.40	1	1	1
11/04/2022 18:00	1.3	12.7	2,057.5	0.9	6.20	1	1	1
11/04/2022 19:00	1.3	12.7	2,056.8	0.9	6.20	1	1	1
11/04/2022 20:00	1.3	12.8	2,052.8	0.9	6.20	1	1	1
11/04/2022 21:00	1.3	12.8	2,054.4	0.9	6.20	1	1	1
11/04/2022 22:00	1.3	12.8	2,054.9	0.9	6.20	1	1	1
11/04/2022 23:00	1.2	13.3	1,952.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.1	1,883.9	0.9	136.00 #	24 #	24 #	17 #
Minimum:	1.1	12.0	1,322.8	0.9	4.00	1	1	0
Maximum:	1.4	14.0	2,266.7	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2022 00:00	1.2	13.3	1,950.5	0.9	5.90	1	1	1
11/05/2022 01:00	1.2	13.3	1,950.4	0.9	5.90	1	1	1
11/05/2022 02:00	1.2	13.3	1,950.1	0.9	5.90	1	1	1
11/05/2022 03:00	1.2	13.3	1,950.9	0.9	5.90	1	1	1
11/05/2022 04:00	1.2	13.3	1,954.3	0.9	5.90	1	1	1
11/05/2022 05:00	1.2	13.3	1,956.6	0.9	5.90	1	1	1
11/05/2022 06:00	1.2	13.3	1,927.6	0.9	5.80	1	1	1
11/05/2022 07:00	3.4	15.8	567.3	3.9	1.82	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 13:00	6.9	18.8	195.5	19.4	2.78	1	0	0
11/05/2022 14:00	27.9	16.1	711.5	34.3	89.60	1	0	0
11/05/2022 15:00	1.1	13.9	1,436.7	0.9	4.30	1	1	0
11/05/2022 16:00	1.2	13.4	1,707.2	0.9	5.10	1	1	1
11/05/2022 17:00	1.3	13.0	1,981.9	1.0	7.90	1	1	1
11/05/2022 18:00	1.3	13.0	1,971.9	1.0	7.90	1	1	1
11/05/2022 19:00	1.3	13.0	1,972.1	1.0	7.90	1	1	1
11/05/2022 20:00	1.3	13.0	1,975.2	1.0	7.90	1	1	1
11/05/2022 21:00	1.2	13.5	1,647.5	1.0	6.60	1	1	1
11/05/2022 22:00	1.1	13.9	1,409.8	0.9	4.20	1	1	0
11/05/2022 23:00	1.1	13.8	1,653.4	0.9	5.00	1	1	0
Average/Sum#:	3.0	13.9	1,624.8	3.8	192.20 #	19 #	16 #	13 #
Minimum:	1.1	13.0	195.5	0.9	1.82	0	0	0
Maximum:	27.9	18.8	1,981.9	34.3	89.60	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	1.1	13.8	1,564.1	0.9	4.70	1	1	0
11/06/2022 01:00	1.1	13.8	1,463.6	0.9	4.40	1	1	0
11/06/2022 02:00	2.7	16.3	377.6	3.5	0.88	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	14.6	1,135.1	1.8	9.98 #	3 #	2 #	0 #
Minimum:	1.1	13.8	377.6	0.9	0.88	0	0	0
Maximum:	2.7	16.3	1,564.1	3.5	4.70	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2022 03:00	22.6	18.1	281.0	47.6	19.68	1	0	0
11/07/2022 04:00	24.0	16.6	549.1	32.9	66.40	1	0	0
11/07/2022 05:00	1.7	13.7	1,723.5	1.4	8.60	1	0	0
11/07/2022 06:00	1.3	12.9	2,000.6	1.0	8.00	1	1	1
11/07/2022 07:00	1.4	12.1	2,210.3	0.9	6.60	1	1	1
11/07/2022 08:00	1.3	13.0	1,980.7	1.0	7.90	1	1	1
11/07/2022 09:00	1.2	13.0	1,964.2	0.9	5.90	1	1	1
11/07/2022 10:00	1.2	13.0	1,956.5	0.9	5.90	1	1	1
11/07/2022 11:00	1.2	13.1	1,957.6	0.9	5.90	1	1	1
11/07/2022 12:00	1.2	13.1	1,957.2	0.9	5.90	1	1	1
11/07/2022 13:00	1.2	13.1	1,960.7	0.9	5.90	1	1	1
11/07/2022 14:00	1.3	12.8	2,055.3	0.9	6.20	1	1	1
11/07/2022 15:00	1.3	12.2	2,186.1	0.9	6.60	1	1	1
11/07/2022 16:00	1.4	11.9	2,241.6	0.9	6.70	1	1	1
11/07/2022 17:00	1.5	11.8	2,276.8	1.0	9.10	1	1	1
11/07/2022 18:00	1.4	11.8	2,279.9	0.9	6.80	1	1	1
11/07/2022 19:00	1.4	11.8	2,279.4	0.9	6.80	1	1	1
11/07/2022 20:00	1.4	11.8	2,276.6	0.9	6.80	1	1	1
11/07/2022 21:00	1.4	11.8	2,272.9	0.9	6.80	1	1	1
11/07/2022 22:00	1.4	12.0	2,232.3	0.9	6.70	1	1	1
11/07/2022 23:00	1.4	12.4	2,159.5	1.0	8.60	1	1	1
Average/Sum#:	3.4	13.0	1,942.9	4.7	217.78 #	21 #	18 #	18 #
Minimum:	1.2	11.8	281.0	0.9	5.90	0	0	0
Maximum:	24.0	18.1	2,279.9	47.6	66.40	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	1.4	12.4	2,151.8	1.0	8.60	1	1	1
11/08/2022 01:00	1.3	12.4	2,149.8	0.9	6.40	1	1	1
11/08/2022 02:00	1.3	12.6	2,096.5	0.9	6.30	1	1	1
11/08/2022 03:00	1.3	12.4	2,143.2	0.9	6.40	1	1	1
11/08/2022 04:00	1.4	12.2	2,180.4	0.9	6.50	1	1	1
11/08/2022 05:00	1.5	12.1	2,197.5	1.0	8.80	1	1	1
11/08/2022 06:00	1.4	11.7	2,281.0	0.9	6.80	1	1	1
11/08/2022 07:00	1.4	12.1	2,193.7	0.9	6.60	1	1	1
11/08/2022 08:00	1.4	12.1	2,185.1	0.9	6.60	1	1	1
11/08/2022 09:00	1.4	12.2	2,181.7	0.9	6.50	1	1	1
11/08/2022 10:00	1.4	12.3	2,165.2	1.0	8.70	1	1	1
11/08/2022 11:00	1.3	12.9	2,016.4	1.0	8.10	1	1	1
11/08/2022 12:00	1.2	13.1	1,972.3	0.9	5.90	1	1	1
11/08/2022 13:00	1.2	13.2	1,972.1	0.9	5.90	1	1	1
11/08/2022 14:00	1.3	12.9	2,046.8	1.0	8.20	1	1	1
11/08/2022 15:00	1.3	12.9	2,043.8	1.0	8.20	1	1	1
11/08/2022 16:00	1.4	12.2	2,202.3	0.9	6.60	1	1	1
11/08/2022 17:00	1.4	12.2	2,181.5	0.9	6.50	1	1	1
11/08/2022 18:00	1.3	12.4	2,151.7	0.9	6.50	1	1	1
11/08/2022 19:00	1.4	12.2	2,186.1	0.9	6.60	1	1	1
11/08/2022 20:00	1.4	12.2	2,194.5	0.9	6.60	1	1	1
11/08/2022 21:00	1.4	12.2	2,195.9	0.9	6.60	1	1	1
11/08/2022 22:00	1.4	12.2	2,180.1	0.9	6.50	1	1	1
11/08/2022 23:00	1.4	12.4	2,137.2	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.4	2,141.9	0.9	168.90 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,972.1	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,281.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	1.3	12.4	2,147.1	0.9	6.40	1	1	1
11/09/2022 01:00	1.3	12.4	2,147.0	0.9	6.40	1	1	1
11/09/2022 02:00	1.4	12.3	2,184.9	1.0	8.70	1	1	1
11/09/2022 03:00	1.3	12.3	2,187.0	0.9	6.60	1	1	1
11/09/2022 04:00	1.3	12.5	2,154.3	0.9	6.50	1	1	1
11/09/2022 05:00	1.5	11.9	2,246.2	1.0	9.00	1	1	1
11/09/2022 06:00	1.4	11.9	2,284.3	0.9	6.90	1	1	1
11/09/2022 07:00	1.4	12.4	2,184.8	1.0	8.70	1	1	1
11/09/2022 08:00	1.4	12.5	2,147.6	1.0	8.60	1	1	1
11/09/2022 09:00	1.2	13.7	1,760.8	1.0	7.00	1	1	1
11/09/2022 10:00	1.1	13.9	1,725.2	0.9	5.20	1	1	0
11/09/2022 11:00	1.1	13.9	1,641.0	0.9	4.90	1	1	0
11/09/2022 12:00	1.1	13.9	1,716.3	0.9	5.10	1	1	0
11/09/2022 13:00	1.1	13.9	1,625.0	0.9	4.90	1	1	0
11/09/2022 14:00	1.1	13.9	1,698.0	0.9	5.10	1	1	0
11/09/2022 15:00	1.1	13.9	1,645.4	0.9	4.90	1	1	1
11/09/2022 16:00	1.3	12.8	2,074.2	0.9	6.20	1	1	1
11/09/2022 17:00	1.3	12.5	2,153.5	0.9	6.50	1	1	1
11/09/2022 18:00	1.2	13.1	2,009.9	0.9	6.00	1	1	1
11/09/2022 19:00	1.2	13.3	1,973.0	0.9	5.90	1	1	1
11/09/2022 20:00	1.2	13.3	1,976.7	0.9	5.90	1	1	1
11/09/2022 21:00	1.2	13.3	1,988.3	0.9	6.00	1	1	1
11/09/2022 22:00	1.2	13.3	1,979.1	0.9	5.90	1	1	1
11/09/2022 23:00	1.2	13.3	1,977.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.0	1,984.5	0.9	153.20 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,625.0	0.9	4.90	1	1	0
Maximum:	1.5	13.9	2,284.3	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.2	13.3	1,977.3	0.9	5.90	1	1	1
11/10/2022 01:00	1.2	13.3	1,975.5	0.9	5.90	1	1	1
11/10/2022 02:00	1.2	13.3	1,974.4	0.9	5.90	1	1	1
11/10/2022 03:00	1.2	13.3	1,977.4	0.9	5.90	1	1	1
11/10/2022 04:00	1.3	12.9	2,073.4	1.0	8.30	1	1	1
11/10/2022 05:00	1.5	12.3	2,174.8	1.0	8.70	1	1	1
11/10/2022 06:00	1.3	12.0	2,299.8	0.9	6.90	1	1	1
11/10/2022 07:00	1.3	12.7	2,110.5	0.9	6.30	1	1	1
11/10/2022 08:00	1.2	13.3	1,967.3	0.9	5.90	1	1	1
11/10/2022 09:00	1.2	13.3	1,948.5	0.9	5.80	1	1	1
11/10/2022 10:00	1.1	13.9	1,736.2	0.9	5.20	1	1	0
11/10/2022 11:00	1.2	13.9	1,728.1	1.0	6.90	1	1	0
11/10/2022 12:00	1.1	13.9	1,714.9	0.9	5.10	1	1	0
11/10/2022 13:00	1.1	14.0	1,570.6	0.9	4.70	1	1	0
11/10/2022 14:00	1.1	13.9	1,724.2	0.9	5.20	1	1	0
11/10/2022 15:00	1.1	13.9	1,723.1	0.9	5.20	1	1	1
11/10/2022 16:00	1.3	12.6	2,126.5	0.9	6.40	1	1	1
11/10/2022 17:00	1.4	11.9	2,271.9	0.9	6.80	1	1	1
11/10/2022 18:00	1.4	11.9	2,274.6	0.9	6.80	1	1	1
11/10/2022 19:00	1.4	11.9	2,278.5	0.9	6.80	1	1	1
11/10/2022 20:00	1.4	11.9	2,278.8	0.9	6.80	1	1	1
11/10/2022 21:00	1.4	11.9	2,281.7	0.9	6.80	1	1	1
11/10/2022 22:00	1.4	11.9	2,281.2	0.9	6.80	1	1	1
11/10/2022 23:00	1.4	12.0	2,256.4	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.9	2,030.2	0.9	151.80 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,570.6	0.9	4.70	1	1	0
Maximum:	1.5	14.0	2,299.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	1.4	12.0	2,281.8	0.9	6.80	1	1	1
11/11/2022 01:00	1.4	12.0	2,275.8	0.9	6.80	1	1	1
11/11/2022 02:00	1.3	12.6	2,145.1	0.9	6.40	1	1	1
11/11/2022 03:00	1.3	12.6	2,142.7	0.9	6.40	1	1	1
11/11/2022 04:00	1.4	12.1	2,271.6	0.9	6.80	1	1	1
11/11/2022 05:00	1.4	12.0	2,285.2	0.9	6.90	1	1	1
11/11/2022 06:00	1.4	12.0	2,284.1	0.9	6.90	1	1	1
11/11/2022 07:00	1.3	12.7	2,108.2	0.9	6.30	1	1	1
11/11/2022 08:00	1.2	13.3	1,940.2	0.9	5.80	1	1	1
11/11/2022 09:00	1.1	13.9	1,718.1	0.9	5.20	1	1	0
11/11/2022 10:00	1.1	13.9	1,724.0	0.9	5.20	1	1	0
11/11/2022 11:00	1.1	13.9	1,688.9	0.9	5.10	1	1	0
11/11/2022 12:00	1.1	13.9	1,687.5	0.9	5.10	1	1	0
11/11/2022 13:00	1.1	13.9	1,700.7	0.9	5.10	1	1	0
11/11/2022 14:00	1.1	13.9	1,582.3	0.9	4.70	1	1	0
11/11/2022 15:00	1.1	13.9	1,688.6	0.9	5.10	1	1	0
11/11/2022 16:00	1.3	13.0	1,979.8	1.0	7.90	1	1	1
11/11/2022 17:00	1.4	11.8	2,273.3	0.9	6.80	1	1	1
11/11/2022 18:00	1.4	11.9	2,266.1	0.9	6.80	1	1	1
11/11/2022 19:00	1.4	11.9	2,254.1	0.9	6.80	1	1	1
11/11/2022 20:00	1.4	11.9	2,250.8	0.9	6.80	1	1	1
11/11/2022 21:00	1.4	11.9	2,249.2	0.9	6.70	1	1	1
11/11/2022 22:00	1.4	12.1	2,243.3	0.9	6.70	1	1	1
11/11/2022 23:00	1.4	12.0	2,260.9	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.7	2,054.3	0.9	149.90 #	24 #	24 #	17 #
Minimum:	1.1	11.8	1,582.3	0.9	4.70	1	1	0
Maximum:	1.4	13.9	2,285.2	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	1.4	12.0	2,265.2	0.9	6.80	1	1	1
11/12/2022 01:00	1.4	12.0	2,268.8	0.9	6.80	1	1	1
11/12/2022 02:00	1.4	12.0	2,275.3	0.9	6.80	1	1	1
11/12/2022 03:00	1.4	12.0	2,278.8	0.9	6.80	1	1	1
11/12/2022 04:00	1.4	12.0	2,285.3	0.9	6.90	1	1	1
11/12/2022 05:00	1.4	12.0	2,286.6	0.9	6.90	1	1	1
11/12/2022 06:00	1.4	12.0	2,277.1	0.9	6.80	1	1	1
11/12/2022 07:00	1.3	12.7	2,119.5	0.9	6.40	1	1	1
11/12/2022 08:00	1.4	12.2	2,196.2	0.9	6.60	1	1	1
11/12/2022 09:00	1.1	13.7	1,755.8	0.9	5.30	1	1	1
11/12/2022 10:00	1.1	13.9	1,596.8	0.9	4.80	1	1	0
11/12/2022 11:00	1.1	13.9	1,557.9	0.9	4.70	1	1	0
11/12/2022 12:00	1.1	13.9	1,557.2	0.9	4.70	1	1	0
11/12/2022 13:00	1.1	13.9	1,580.9	0.9	4.70	1	1	0
11/12/2022 14:00	1.1	13.9	1,557.8	0.9	4.70	1	1	0
11/12/2022 15:00	1.1	13.8	1,793.1	0.9	5.40	1	1	1
11/12/2022 16:00	1.3	12.5	2,136.2	0.9	6.40	1	1	1
11/12/2022 17:00	1.4	11.8	2,289.6	0.9	6.90	1	1	1
11/12/2022 18:00	1.4	11.8	2,288.4	0.9	6.90	1	1	1
11/12/2022 19:00	1.4	11.8	2,294.2	0.9	6.90	1	1	1
11/12/2022 20:00	1.4	11.8	2,304.8	0.9	6.90	1	1	1
11/12/2022 21:00	1.4	11.8	2,300.6	0.9	6.90	1	1	1
11/12/2022 22:00	1.4	12.3	2,197.1	1.0	8.80	1	1	1
11/12/2022 23:00	1.3	12.3	2,192.7	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.6	2,069.0	0.9	151.40 #	24 #	24 #	19 #
Minimum:	1.1	11.8	1,557.2	0.9	4.70	1	1	0
Maximum:	1.4	13.9	2,304.8	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	1.3	12.4	2,183.0	0.9	6.50	1	1	1
11/13/2022 01:00	1.4	12.4	2,169.4	1.0	8.70	1	1	1
11/13/2022 02:00	1.3	12.5	2,162.2	0.9	6.50	1	1	1
11/13/2022 03:00	1.3	12.3	2,198.3	0.9	6.60	1	1	1
11/13/2022 04:00	1.4	12.4	2,192.5	1.0	8.80	1	1	1
11/13/2022 05:00	1.3	12.4	2,185.1	0.9	6.60	1	1	1
11/13/2022 06:00	1.4	12.3	2,201.5	1.0	8.80	1	1	1
11/13/2022 07:00	1.4	12.0	2,269.1	0.9	6.80	1	1	1
11/13/2022 08:00	1.2	12.9	1,972.8	0.9	5.90	1	1	1
11/13/2022 09:00	1.1	13.9	1,713.6	0.9	5.10	1	1	0
11/13/2022 10:00	1.1	13.9	1,714.5	0.9	5.10	1	1	0
11/13/2022 11:00	1.1	13.9	1,714.3	0.9	5.10	1	1	0
11/13/2022 12:00	1.1	13.9	1,712.3	0.9	5.10	1	1	0
11/13/2022 13:00	1.1	14.0	1,713.9	0.9	5.10	1	1	0
11/13/2022 14:00	1.1	14.0	1,686.9	0.9	5.10	1	1	0
11/13/2022 15:00	1.1	13.8	1,797.5	0.9	5.40	1	1	1
11/13/2022 16:00	1.4	12.6	2,132.3	1.0	8.50	1	1	1
11/13/2022 17:00	1.4	12.0	2,273.8	0.9	6.80	1	1	1
11/13/2022 18:00	1.4	12.0	2,273.5	0.9	6.80	1	1	1
11/13/2022 19:00	1.4	12.0	2,277.3	0.9	6.80	1	1	1
11/13/2022 20:00	1.3	12.0	2,280.0	0.9	6.80	1	1	1
11/13/2022 21:00	1.4	12.0	2,284.9	0.9	6.90	1	1	1
11/13/2022 22:00	1.3	12.0	2,287.2	0.9	6.90	1	1	1
11/13/2022 23:00	1.4	12.0	2,294.0	0.9	6.90	1	1	1
Average/Sum#:	1.3	12.7	2,070.4	0.9	157.60 #	24 #	24 #	18 #
Minimum:	1.1	12.0	1,686.9	0.9	5.10	1	1	0
Maximum:	1.4	14.0	2,294.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	1.3	12.1	2,288.4	0.9	6.90	1	1	1
11/14/2022 01:00	1.4	12.1	2,277.6	0.9	6.80	1	1	1
11/14/2022 02:00	1.3	12.2	2,265.6	0.9	6.80	1	1	1
11/14/2022 03:00	1.3	12.7	2,149.5	0.9	6.40	1	1	1
11/14/2022 04:00	1.4	12.4	2,230.6	1.0	8.90	1	1	1
11/14/2022 05:00	1.4	12.2	2,291.8	0.9	6.90	1	1	1
11/14/2022 06:00	1.4	12.2	2,286.5	0.9	6.90	1	1	1
11/14/2022 07:00	1.3	12.6	2,184.1	0.9	6.60	1	1	1
11/14/2022 08:00	1.3	12.7	2,143.2	0.9	6.40	1	1	1
11/14/2022 09:00	1.3	12.6	2,149.5	0.9	6.40	1	1	1
11/14/2022 10:00	1.3	12.6	2,141.4	0.9	6.40	1	1	1
11/14/2022 11:00	1.3	12.7	2,116.8	0.9	6.40	1	1	1
11/14/2022 12:00	1.3	12.7	2,106.1	0.9	6.30	1	1	1
11/14/2022 13:00	1.3	12.5	2,137.1	0.9	6.40	1	1	1
11/14/2022 14:00	1.3	12.5	2,137.4	0.9	6.40	1	1	1
11/14/2022 15:00	1.3	12.8	2,062.7	0.9	6.20	1	1	1
11/14/2022 16:00	1.4	12.1	2,229.8	0.9	6.70	1	1	1
11/14/2022 17:00	1.3	12.3	2,177.1	0.9	6.50	1	1	1
11/14/2022 18:00	1.3	12.5	2,159.1	0.9	6.50	1	1	1
11/14/2022 19:00	1.4	12.1	2,265.3	0.9	6.80	1	1	1
11/14/2022 20:00	1.3	12.0	2,281.3	0.9	6.80	1	1	1
11/14/2022 21:00	1.4	12.1	2,256.1	0.9	6.80	1	1	1
11/14/2022 22:00	1.3	12.1	2,259.7	0.9	6.80	1	1	1
11/14/2022 23:00	1.3	12.2	2,239.5	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,201.5	0.9	160.70 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,062.7	0.9	6.20	1	1	1
Maximum:	1.4	12.8	2,291.8	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2022 00:00	1.4	12.1	2,265.0	0.9	6.80	1	1	1
11/15/2022 01:00	1.3	12.1	2,268.0	0.9	6.80	1	1	1
11/15/2022 02:00	1.4	12.0	2,286.6	0.9	6.90	1	1	1
11/15/2022 03:00	1.4	12.0	2,296.0	0.9	6.90	1	1	1
11/15/2022 04:00	1.3	12.0	2,299.8	0.9	6.90	1	1	1
11/15/2022 05:00	1.3	11.7	2,332.5	0.8	7.00	1	1	1
11/15/2022 06:00	1.4	12.2	2,202.6	0.9	6.60	1	1	1
11/15/2022 07:00	1.4	11.8	2,323.2	0.9	7.00	1	1	1
11/15/2022 08:00	1.4	12.0	2,234.7	0.9	6.70	1	1	1
11/15/2022 09:00	1.3	12.6	2,114.0	0.9	6.30	1	1	1
11/15/2022 10:00	1.3	12.5	2,135.7	0.9	6.40	1	1	1
11/15/2022 11:00	1.2	12.9	2,037.3	0.9	6.10	1	1	1
11/15/2022 12:00	1.2	13.3	1,961.1	0.9	5.90	1	1	1
11/15/2022 13:00	1.2	13.3	1,967.3	0.9	5.90	1	1	1
11/15/2022 14:00	0.0	0.0	1,973.8	0.0	0.00	1	1	1
11/15/2022 15:00	0.0	0.0	2,007.0	0.0	0.00	1	1	1
11/15/2022 16:00	1.3	12.5	2,120.1	0.9	6.40	1	1	1
11/15/2022 17:00	1.4	12.4	2,133.8	1.0	8.50	1	1	1
11/15/2022 18:00	1.4	12.4	2,123.0	1.0	8.50	1	1	1
11/15/2022 19:00	1.3	12.3	2,137.1	0.9	6.40	1	1	1
11/15/2022 20:00	1.4	12.2	2,175.2	0.9	6.50	1	1	1
11/15/2022 21:00	1.4	11.9	2,237.4	0.9	6.70	1	1	1
11/15/2022 22:00	1.4	12.3	2,149.1	1.0	8.60	1	1	1
11/15/2022 23:00	1.4	12.3	2,148.1	1.0	8.60	1	1	1
Average/Sum#:	1.3	12.3	2,163.7	0.9	152.40 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,961.1	0.8	5.90	1	1	1
Maximum:	1.4	13.3	2,332.5	1.0	8.60	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	1.4	12.3	2,142.4	1.0	8.60	1	1	1
11/16/2022 01:00	1.3	12.5	2,116.0	0.9	6.30	1	1	1
11/16/2022 02:00	1.4	12.4	2,139.8	1.0	8.60	1	1	1
11/16/2022 03:00	1.4	12.4	2,144.4	1.0	8.60	1	1	1
11/16/2022 04:00	1.4	11.9	2,274.6	0.9	6.80	1	1	1
11/16/2022 05:00	1.5	11.5	2,340.0	0.9	7.00	1	1	1
11/16/2022 06:00	1.4	11.5	2,346.5	0.9	7.00	1	1	1
11/16/2022 07:00	1.4	11.9	2,254.3	0.9	6.80	1	1	1
11/16/2022 08:00	0.5	13.3	1,966.8	0.4	2.00	1	1	1
11/16/2022 09:00	0.0	13.6	1,997.0	0.0	0.00	1	1	1
11/16/2022 10:00	1.2	13.2	1,964.8	0.9	5.90	1	1	1
11/16/2022 11:00	1.2	13.2	1,969.2	0.9	5.90	1	1	1
11/16/2022 12:00	1.3	13.1	1,978.0	1.0	7.90	1	1	1
11/16/2022 13:00	1.2	13.1	1,980.5	0.9	5.90	1	1	1
11/16/2022 14:00	1.3	13.1	1,981.2	1.0	7.90	1	1	1
11/16/2022 15:00	1.3	12.6	2,101.9	0.9	6.30	1	1	1
11/16/2022 16:00	1.3	12.3	2,161.6	0.9	6.50	1	1	1
11/16/2022 17:00	1.4	12.3	2,165.8	1.0	8.70	1	1	1
11/16/2022 18:00	1.4	12.0	2,221.6	0.9	6.70	1	1	1
11/16/2022 19:00	1.4	11.9	2,228.4	0.9	6.70	1	1	1
11/16/2022 20:00	1.4	11.9	2,229.7	0.9	6.70	1	1	1
11/16/2022 21:00	1.4	12.0	2,244.6	0.9	6.70	1	1	1
11/16/2022 22:00	1.4	12.2	2,216.3	0.9	6.60	1	1	1
11/16/2022 23:00	1.4	12.0	2,243.9	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,142.1	0.9	156.80 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,964.8	0.0	0.00	1	1	1
Maximum:	1.5	13.6	2,346.5	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	1.3	12.4	2,159.1	0.9	6.50	1	1	1
11/17/2022 01:00	1.4	12.4	2,159.4	1.0	8.60	1	1	1
11/17/2022 02:00	1.3	12.5	2,146.1	0.9	6.40	1	1	1
11/17/2022 03:00	1.3	12.5	2,149.6	0.9	6.40	1	1	1
11/17/2022 04:00	1.4	12.2	2,231.0	0.9	6.70	1	1	1
11/17/2022 05:00	1.3	11.6	2,357.0	0.8	7.10	1	1	1
11/17/2022 06:00	1.4	11.9	2,276.3	0.9	6.80	1	1	1
11/17/2022 07:00	1.4	12.4	2,162.7	1.0	8.70	1	1	1
11/17/2022 08:00	1.3	13.1	1,985.4	1.0	7.90	1	1	1
11/17/2022 09:00	1.4	12.5	2,129.0	1.0	8.50	1	1	1
11/17/2022 10:00	1.3	12.5	2,110.8	0.9	6.30	1	1	1
11/17/2022 11:00	1.3	12.3	2,133.9	0.9	6.40	1	1	1
11/17/2022 12:00	1.4	12.1	2,171.5	0.9	6.50	1	1	1
11/17/2022 13:00	1.4	12.2	2,169.8	0.9	6.50	1	1	1
11/17/2022 14:00	1.3	12.9	2,005.0	1.0	8.00	1	1	1
11/17/2022 15:00	1.3	12.4	2,118.7	0.9	6.40	1	1	1
11/17/2022 16:00	1.4	11.9	2,234.9	0.9	6.70	1	1	1
11/17/2022 17:00	1.4	11.8	2,268.2	0.9	6.80	1	1	1
11/17/2022 18:00	1.4	11.8	2,255.7	0.9	6.80	1	1	1
11/17/2022 19:00	1.4	11.8	2,258.8	0.9	6.80	1	1	1
11/17/2022 20:00	1.4	11.8	2,260.2	0.9	6.80	1	1	1
11/17/2022 21:00	1.4	11.8	2,262.4	0.9	6.80	1	1	1
11/17/2022 22:00	1.4	11.9	2,246.4	0.9	6.70	1	1	1
11/17/2022 23:00	1.4	12.2	2,206.6	0.9	6.60	1	1	1
Average/Sum#:	1.4	12.2	2,185.8	0.9	167.70 #	24 #	24 #	24 #
Minimum:	1.3	11.6	1,985.4	0.8	6.30	1	1	1
Maximum:	1.4	13.1	2,357.0	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	1.3	12.4	2,157.1	0.9	6.50	1	1	1
11/18/2022 01:00	1.4	12.3	2,164.4	1.0	8.70	1	1	1
11/18/2022 02:00	1.4	12.2	2,166.7	0.9	6.50	1	1	1
11/18/2022 03:00	1.4	12.3	2,166.0	1.0	8.70	1	1	1
11/18/2022 04:00	1.4	11.6	2,308.1	0.9	6.90	1	1	1
11/18/2022 05:00	1.4	11.5	2,326.0	0.9	7.00	1	1	1
11/18/2022 06:00	1.4	11.5	2,333.1	0.9	7.00	1	1	1
11/18/2022 07:00	1.4	11.8	2,267.0	0.9	6.80	1	1	1
11/18/2022 08:00	1.4	12.3	2,145.7	1.0	8.60	1	1	1
11/18/2022 09:00	1.4	12.3	2,153.7	1.0	8.60	1	1	1
11/18/2022 10:00	1.4	12.2	2,162.8	0.9	6.50	1	1	1
11/18/2022 11:00	1.3	12.4	2,100.8	0.9	6.30	1	1	1
11/18/2022 12:00	1.3	13.1	1,958.4	1.0	7.80	1	1	1
11/18/2022 13:00	1.3	13.1	1,960.1	1.0	7.80	1	1	1
11/18/2022 14:00	1.2	13.0	1,964.5	0.9	5.90	1	1	1
11/18/2022 15:00	1.3	12.7	2,040.1	0.9	6.10	1	1	1
11/18/2022 16:00	1.4	12.0	2,220.5	0.9	6.70	1	1	1
11/18/2022 17:00	1.4	11.9	2,244.9	0.9	6.70	1	1	1
11/18/2022 18:00	1.4	11.9	2,243.3	0.9	6.70	1	1	1
11/18/2022 19:00	1.4	11.9	2,245.4	0.9	6.70	1	1	1
11/18/2022 20:00	1.4	11.8	2,276.3	0.9	6.80	1	1	1
11/18/2022 21:00	1.4	11.6	2,328.6	0.9	7.00	1	1	1
11/18/2022 22:00	1.4	11.6	2,341.0	0.9	7.00	1	1	1
11/18/2022 23:00	1.4	11.8	2,301.5	0.9	6.90	1	1	1
Average/Sum#:	1.4	12.1	2,190.7	0.9	170.20 #	24 #	24 #	24 #
Minimum:	1.2	11.5	1,958.4	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,341.0	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	1.3	12.3	2,163.6	0.9	6.50	1	1	1
11/19/2022 01:00	1.3	12.5	2,142.3	0.9	6.40	1	1	1
11/19/2022 02:00	1.3	12.5	2,139.1	0.9	6.40	1	1	1
11/19/2022 03:00	1.3	12.6	2,118.3	0.9	6.40	1	1	1
11/19/2022 04:00	1.4	12.1	2,231.5	0.9	6.70	1	1	1
11/19/2022 05:00	1.3	11.9	2,257.3	0.9	6.80	1	1	1
11/19/2022 06:00	1.4	12.3	2,191.6	1.0	8.80	1	1	1
11/19/2022 07:00	1.3	12.5	2,123.0	0.9	6.40	1	1	1
11/19/2022 08:00	1.2	13.2	1,963.6	0.9	5.90	1	1	1
11/19/2022 09:00	1.2	13.2	1,961.7	0.9	5.90	1	1	1
11/19/2022 10:00	1.2	13.2	1,956.6	0.9	5.90	1	1	1
11/19/2022 11:00	1.3	13.1	1,953.3	1.0	7.80	1	1	1
11/19/2022 12:00	1.2	13.1	1,953.3	0.9	5.90	1	1	1
11/19/2022 13:00	1.3	13.1	1,954.1	1.0	7.80	1	1	1
11/19/2022 14:00	1.3	13.1	1,960.9	1.0	7.80	1	1	1
11/19/2022 15:00	1.3	12.8	2,021.3	0.9	6.10	1	1	1
11/19/2022 16:00	1.4	12.2	2,156.6	0.9	6.50	1	1	1
11/19/2022 17:00	1.4	12.1	2,176.7	0.9	6.50	1	1	1
11/19/2022 18:00	1.4	12.2	2,169.1	0.9	6.50	1	1	1
11/19/2022 19:00	1.4	11.8	2,273.1	0.9	6.80	1	1	1
11/19/2022 20:00	1.4	11.6	2,305.7	0.9	6.90	1	1	1
11/19/2022 21:00	1.4	11.6	2,312.8	0.9	6.90	1	1	1
11/19/2022 22:00	1.4	11.7	2,340.7	0.9	7.00	1	1	1
11/19/2022 23:00	1.5	11.6	2,358.5	1.0	9.40	1	1	1
Average/Sum#:	1.3	12.4	2,132.7	0.9	164.00 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,953.3	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,358.5	1.0	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	1.4	12.0	2,254.8	0.9	6.80	1	1	1
11/20/2022 01:00	1.4	11.9	2,273.0	0.9	6.80	1	1	1
11/20/2022 02:00	1.4	11.8	2,301.3	0.9	6.90	1	1	1
11/20/2022 03:00	1.5	11.9	2,301.2	1.0	9.20	1	1	1
11/20/2022 04:00	1.4	11.9	2,306.4	0.9	6.90	1	1	1
11/20/2022 05:00	1.5	11.7	2,350.0	1.0	9.40	1	1	1
11/20/2022 06:00	1.4	12.1	2,254.5	0.9	6.80	1	1	1
11/20/2022 07:00	1.3	12.6	2,096.3	0.9	6.30	1	1	1
11/20/2022 08:00	1.2	13.8	1,722.3	1.0	6.90	1	1	0
11/20/2022 09:00	1.1	13.8	1,725.4	0.9	5.20	1	1	0
11/20/2022 10:00	1.2	13.8	1,571.5	1.0	6.30	1	1	0
11/20/2022 11:00	1.1	13.9	1,573.6	0.9	4.70	1	1	0
11/20/2022 12:00	1.1	13.9	1,545.9	0.9	4.60	1	1	0
11/20/2022 13:00	1.1	13.9	1,536.5	0.9	4.60	1	1	0
11/20/2022 14:00	1.2	13.8	1,695.0	1.0	6.80	1	1	0
11/20/2022 15:00	1.2	13.8	1,732.2	1.0	6.90	1	1	1
11/20/2022 16:00	1.3	12.3	2,147.2	0.9	6.40	1	1	1
11/20/2022 17:00	1.4	11.8	2,265.5	0.9	6.80	1	1	1
11/20/2022 18:00	1.4	11.8	2,252.2	0.9	6.80	1	1	1
11/20/2022 19:00	1.4	11.8	2,253.5	0.9	6.80	1	1	1
11/20/2022 20:00	1.4	11.8	2,257.4	0.9	6.80	1	1	1
11/20/2022 21:00	1.4	12.1	2,192.6	0.9	6.60	1	1	1
11/20/2022 22:00	1.3	12.4	2,157.4	0.9	6.50	1	1	1
11/20/2022 23:00	1.3	12.5	2,147.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.6	2,038.1	0.9	158.20 #	24 #	24 #	17 #
Minimum:	1.1	11.7	1,536.5	0.9	4.60	1	1	0
Maximum:	1.5	13.9	2,350.0	1.0	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2022 00:00	1.3	12.4	2,156.8	0.9	6.50	1	1	1
11/21/2022 01:00	1.3	12.6	2,130.5	0.9	6.40	1	1	1
11/21/2022 02:00	1.3	12.9	2,058.0	1.0	8.20	1	1	1
11/21/2022 03:00	1.4	12.4	2,172.2	1.0	8.70	1	1	1
11/21/2022 04:00	1.4	12.0	2,259.2	0.9	6.80	1	1	1
11/21/2022 05:00	1.5	12.0	2,267.5	1.0	9.10	1	1	1
11/21/2022 06:00	1.4	12.0	2,284.4	0.9	6.90	1	1	1
11/21/2022 07:00	1.3	12.5	2,147.1	0.9	6.40	1	1	1
11/21/2022 08:00	1.2	13.2	1,965.1	0.9	5.90	1	1	1
11/21/2022 09:00	1.2	13.2	1,965.2	0.9	5.90	1	1	1
11/21/2022 10:00	1.2	13.2	1,961.7	0.9	5.90	1	1	1
11/21/2022 11:00	1.3	13.1	1,958.9	1.0	7.80	1	1	1
11/21/2022 12:00	1.3	13.0	1,966.2	1.0	7.90	1	1	1
11/21/2022 13:00	1.2	13.0	1,977.7	0.9	5.90	1	1	1
11/21/2022 14:00	1.4	12.2	2,161.3	0.9	6.50	1	1	1
11/21/2022 15:00	1.4	11.8	2,272.0	0.9	6.80	1	1	1
11/21/2022 16:00	1.4	12.0	2,229.0	0.9	6.70	1	1	1
11/21/2022 17:00	1.4	11.9	2,230.9	0.9	6.70	1	1	1
11/21/2022 18:00	1.4	11.9	2,230.5	0.9	6.70	1	1	1
11/21/2022 19:00	1.4	11.8	2,258.6	0.9	6.80	1	1	1
11/21/2022 20:00	1.4	11.8	2,263.5	0.9	6.80	1	1	1
11/21/2022 21:00	1.4	11.8	2,264.2	0.9	6.80	1	1	1
11/21/2022 22:00	1.4	11.8	2,264.8	0.9	6.80	1	1	1
11/21/2022 23:00	1.4	12.0	2,226.0	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,153.0	0.9	165.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,958.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,284.4	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2022 00:00	1.3	12.4	2,143.9	0.9	6.40	1	1	1
11/22/2022 01:00	1.3	12.6	2,125.4	0.9	6.40	1	1	1
11/22/2022 02:00	1.3	12.6	2,094.4	0.9	6.30	1	1	1
11/22/2022 03:00	1.2	13.1	1,973.7	0.9	5.90	1	1	1
11/22/2022 04:00	1.3	13.1	1,977.2	1.0	7.90	1	1	1
11/22/2022 05:00	1.3	12.6	2,065.9	0.9	6.20	1	1	1
11/22/2022 06:00	1.3	12.5	2,149.0	0.9	6.40	1	1	1
11/22/2022 07:00	1.3	12.7	2,088.9	0.9	6.30	1	1	1
11/22/2022 08:00	1.3	12.9	2,051.0	1.0	8.20	1	1	1
11/22/2022 09:00	1.9	14.2	1,444.6	1.7	7.40	1	0	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2022 11:00	0.0	19.5	58.0	0.0	0.00	1	0	0
11/22/2022 12:00	12.6	15.8	756.7	14.6	40.90	1	0	0
11/22/2022 13:00	1.1	13.8	1,622.5	0.9	4.90	1	1	0
11/22/2022 14:00	1.1	13.8	1,790.4	0.9	5.40	1	1	0
11/22/2022 15:00	1.2	13.8	1,790.4	1.0	7.20	1	1	0
11/22/2022 16:00	1.3	13.2	1,897.6	1.0	7.60	1	1	1
11/22/2022 17:00	1.4	12.3	2,141.8	1.0	8.60	1	1	1
11/22/2022 18:00	1.3	12.7	2,035.3	0.9	6.10	1	1	1
11/22/2022 19:00	1.3	13.0	1,982.5	1.0	7.90	1	1	1
11/22/2022 20:00	1.4	12.4	2,138.7	1.0	8.60	1	1	1
11/22/2022 21:00	1.3	12.9	2,017.6	1.0	8.10	1	1	1
11/22/2022 22:00	1.3	12.8	2,028.8	0.9	6.10	1	1	1
11/22/2022 23:00	1.2	13.2	1,957.5	0.9	5.90	1	1	1
Average/Sum#:	1.7	13.4	1,840.5	1.5	184.70 #	23 #	20 #	18 #
Minimum:	0.0	12.3	58.0	0.0	0.00	0	0	0
Maximum:	12.6	19.5	2,149.0	14.6	40.90	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.2	13.2	1,958.7	0.9	5.90	1	1	1
11/23/2022 01:00	1.2	13.2	1,960.6	0.9	5.90	1	1	1
11/23/2022 02:00	1.2	13.2	1,958.4	0.9	5.90	1	1	1
11/23/2022 03:00	1.2	13.2	1,962.5	0.9	5.90	1	1	1
11/23/2022 04:00	1.2	13.1	1,969.2	0.9	5.90	1	1	1
11/23/2022 05:00	1.5	12.5	2,057.1	1.1	8.20	1	1	1
11/23/2022 06:00	1.3	12.8	2,048.5	0.9	6.10	1	1	1
11/23/2022 07:00	1.3	12.6	2,103.9	0.9	6.30	1	1	1
11/23/2022 08:00	1.3	13.0	1,993.7	1.0	8.00	1	1	1
11/23/2022 09:00	1.1	13.8	1,707.7	0.9	5.10	1	1	0
11/23/2022 10:00	1.1	13.8	1,562.1	0.9	4.70	1	1	0
11/23/2022 11:00	1.1	13.9	1,556.2	0.9	4.70	1	1	0
11/23/2022 12:00	1.1	13.9	1,424.7	0.9	4.30	1	1	0
11/23/2022 13:00	1.1	13.9	1,558.7	0.9	4.70	1	1	0
11/23/2022 14:00	1.1	13.9	1,628.7	0.9	4.90	1	1	0
11/23/2022 15:00	1.2	13.8	1,649.5	1.0	6.60	1	1	1
11/23/2022 16:00	1.3	12.5	2,097.1	0.9	6.30	1	1	1
11/23/2022 17:00	1.4	12.3	2,159.6	1.0	8.60	1	1	1
11/23/2022 18:00	1.3	12.6	2,078.6	0.9	6.20	1	1	1
11/23/2022 19:00	1.3	12.8	2,045.2	0.9	6.10	1	1	1
11/23/2022 20:00	1.4	12.3	2,155.0	1.0	8.60	1	1	1
11/23/2022 21:00	1.4	12.2	2,168.6	0.9	6.50	1	1	1
11/23/2022 22:00	1.4	12.4	2,143.6	1.0	8.60	1	1	1
11/23/2022 23:00	1.3	12.4	2,140.6	0.9	6.40	1	1	1
Average/Sum#:	1.3	13.1	1,920.4	0.9	150.40 #	24 #	24 #	18 #
Minimum:	1.1	12.2	1,424.7	0.9	4.30	1	1	0
Maximum:	1.5	13.9	2,168.6	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.3	13.1	1,975.4	1.0	7.90	1	1	1
11/24/2022 01:00	1.3	13.2	1,962.5	1.0	7.90	1	1	1
11/24/2022 02:00	1.2	13.2	1,963.6	0.9	5.90	1	1	1
11/24/2022 03:00	1.3	13.0	1,975.0	1.0	7.90	1	1	1
11/24/2022 04:00	1.3	12.9	1,985.5	1.0	7.90	1	1	1
11/24/2022 05:00	1.4	12.5	2,052.9	1.0	8.20	1	1	1
11/24/2022 06:00	1.4	12.2	2,165.6	0.9	6.50	1	1	1
11/24/2022 07:00	1.3	12.5	2,079.4	0.9	6.20	1	1	1
11/24/2022 08:00	1.1	13.8	1,712.0	0.9	5.10	1	1	0
11/24/2022 09:00	1.1	13.8	1,709.0	0.9	5.10	1	1	0
11/24/2022 10:00	1.2	13.8	1,716.4	1.0	6.90	1	1	0
11/24/2022 11:00	1.1	13.9	1,560.1	0.9	4.70	1	1	0
11/24/2022 12:00	1.1	13.9	1,351.9	0.9	4.10	1	1	0
11/24/2022 13:00	1.1	13.9	1,350.9	0.9	4.10	1	1	0
11/24/2022 14:00	1.1	13.9	1,562.2	0.9	4.70	1	1	0
11/24/2022 15:00	1.1	13.9	1,450.2	0.9	4.40	1	1	0
11/24/2022 16:00	1.2	13.8	1,769.5	1.0	7.10	1	1	0
11/24/2022 17:00	1.2	13.8	1,768.6	1.0	7.10	1	1	0
11/24/2022 18:00	1.1	13.8	1,745.4	0.9	5.20	1	1	0
11/24/2022 19:00	1.2	13.8	1,737.1	1.0	6.90	1	1	0
11/24/2022 20:00	1.1	13.8	1,746.5	0.9	5.20	1	1	0
11/24/2022 21:00	1.1	13.8	1,747.1	0.9	5.20	1	1	0
11/24/2022 22:00	1.2	13.8	1,751.3	1.0	7.00	1	1	0
11/24/2022 23:00	1.2	13.8	1,753.2	1.0	7.00	1	1	0
Average/Sum#:	1.2	13.5	1,774.6	0.9	148.20 #	24 #	24 #	8 #
Minimum:	1.1	12.2	1,350.9	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,165.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	1.1	13.8	1,757.2	0.9	5.30	1	1	0
11/25/2022 01:00	1.2	13.8	1,758.4	1.0	7.00	1	1	0
11/25/2022 02:00	1.1	13.8	1,761.0	0.9	5.30	1	1	0
11/25/2022 03:00	1.2	13.8	1,764.3	1.0	7.10	1	1	0
11/25/2022 04:00	1.2	13.8	1,775.1	1.0	7.10	1	1	0
11/25/2022 05:00	1.1	13.8	1,771.2	0.9	5.30	1	1	0
11/25/2022 06:00	1.2	13.8	1,766.8	1.0	7.10	1	1	0
11/25/2022 07:00	1.1	13.8	1,766.8	0.9	5.30	1	1	0
11/25/2022 08:00	1.2	13.4	1,882.1	0.9	5.60	1	1	1
11/25/2022 09:00	1.2	13.1	1,919.7	0.9	5.80	1	1	1
11/25/2022 10:00	1.1	13.8	1,668.0	0.9	5.00	1	1	0
11/25/2022 11:00	1.1	13.8	1,549.0	0.9	4.60	1	1	0
11/25/2022 12:00	1.1	13.8	1,574.7	0.9	4.70	1	1	0
11/25/2022 13:00	1.1	13.8	1,543.3	0.9	4.60	1	1	0
11/25/2022 14:00	1.1	13.8	1,531.6	0.9	4.60	1	1	0
11/25/2022 15:00	1.1	13.7	1,644.3	0.9	4.90	1	1	1
11/25/2022 16:00	1.4	12.6	2,082.1	1.0	8.30	1	1	1
11/25/2022 17:00	1.3	12.5	2,096.7	0.9	6.30	1	1	1
11/25/2022 18:00	1.3	13.0	1,970.2	1.0	7.90	1	1	1
11/25/2022 19:00	1.3	13.1	1,955.6	1.0	7.80	1	1	1
11/25/2022 20:00	1.2	13.1	1,955.0	0.9	5.90	1	1	1
11/25/2022 21:00	1.2	13.1	1,966.3	0.9	5.90	1	1	1
11/25/2022 22:00	1.3	12.5	2,118.6	0.9	6.40	1	1	1
11/25/2022 23:00	1.3	12.6	2,080.0	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.4	1,819.1	0.9	144.00 #	24 #	24 #	11 #
Minimum:	1.1	12.5	1,531.6	0.9	4.60	1	1	0
Maximum:	1.4	13.8	2,118.6	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.3	12.9	2,016.8	1.0	8.10	1	1	1
11/26/2022 01:00	1.3	12.7	2,062.0	0.9	6.20	1	1	1
11/26/2022 02:00	1.9	13.8	1,575.4	1.6	9.50	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	13.1	1,884.7	1.2	23.80 #	3 #	2 #	3 #
Minimum:	1.3	12.7	1,575.4	0.9	6.20	0	0	0
Maximum:	1.9	13.8	2,062.0	1.6	9.50	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2022 02:00	31.3	17.4	344.2	52.8	63.46	1	0	0
11/28/2022 03:00	11.2	15.2	949.6	11.6	40.80	1	0	0
11/28/2022 04:00	1.2	13.7	1,724.6	1.0	6.90	1	1	0
11/28/2022 05:00	1.2	13.7	1,654.5	1.0	6.60	1	1	1
11/28/2022 06:00	1.3	12.5	2,164.7	0.9	6.50	1	1	1
11/28/2022 07:00	1.4	12.0	2,260.4	0.9	6.80	1	1	1
11/28/2022 08:00	1.3	13.0	1,970.9	1.0	7.90	1	1	1
11/28/2022 09:00	1.2	13.8	1,613.8	1.0	6.50	1	1	0
11/28/2022 10:00	1.2	13.8	1,719.0	1.0	6.90	1	1	0
11/28/2022 11:00	1.1	13.8	1,526.4	0.9	4.60	1	1	0
11/28/2022 12:00	1.1	13.8	1,571.0	0.9	4.70	1	1	0
11/28/2022 13:00	1.2	13.8	1,644.0	1.0	6.60	1	1	0
11/28/2022 14:00	1.1	13.8	1,627.3	0.9	4.90	1	1	0
11/28/2022 15:00	1.2	13.7	1,623.7	1.0	6.50	1	1	1
11/28/2022 16:00	1.3	12.8	2,023.4	0.9	6.10	1	1	1
11/28/2022 17:00	1.3	12.5	2,090.0	0.9	6.30	1	1	1
11/28/2022 18:00	1.3	13.0	1,980.4	1.0	7.90	1	1	1
11/28/2022 19:00	1.2	13.1	1,958.5	0.9	5.90	1	1	1
11/28/2022 20:00	1.3	12.7	2,080.3	0.9	6.20	1	1	1
11/28/2022 21:00	1.4	12.1	2,212.4	0.9	6.60	1	1	1
11/28/2022 22:00	1.3	12.7	2,084.2	0.9	6.30	1	1	1
11/28/2022 23:00	1.3	13.1	1,981.7	1.0	7.90	1	1	1
Average/Sum#:	3.1	13.5	1,763.9	3.8	232.86 #	22 #	20 #	13 #
Minimum:	1.1	12.0	344.2	0.9	4.60	0	0	0
Maximum:	31.3	17.4	2,260.4	52.8	63.46	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	1.3	12.4	2,141.8	0.9	6.40	1	1	1
11/29/2022 01:00	1.4	12.3	2,186.9	1.0	8.70	1	1	1
11/29/2022 02:00	1.4	12.3	2,175.4	1.0	8.70	1	1	1
11/29/2022 03:00	1.3	12.7	2,087.1	0.9	6.30	1	1	1
11/29/2022 04:00	1.3	12.5	2,149.0	0.9	6.40	1	1	1
11/29/2022 05:00	1.3	12.3	2,196.7	0.9	6.60	1	1	1
11/29/2022 06:00	1.4	11.9	2,281.7	0.9	6.80	1	1	1
11/29/2022 07:00	1.4	11.9	2,281.4	0.9	6.80	1	1	1
11/29/2022 08:00	1.4	11.9	2,244.1	0.9	6.70	1	1	1
11/29/2022 09:00	1.4	12.3	2,150.7	1.0	8.60	1	1	1
11/29/2022 10:00	1.4	12.3	2,145.0	1.0	8.60	1	1	1
11/29/2022 11:00	1.4	12.3	2,136.9	1.0	8.50	1	1	1
11/29/2022 12:00	1.3	12.3	2,126.6	0.9	6.40	1	1	1
11/29/2022 13:00	1.4	12.3	2,125.1	1.0	8.50	1	1	1
11/29/2022 14:00	1.4	12.3	2,128.4	1.0	8.50	1	1	1
11/29/2022 15:00	1.4	12.3	2,146.5	1.0	8.60	1	1	1
11/29/2022 16:00	1.4	11.8	2,253.8	0.9	6.80	1	1	1
11/29/2022 17:00	1.4	11.8	2,262.7	0.9	6.80	1	1	1
11/29/2022 18:00	1.4	11.8	2,269.7	0.9	6.80	1	1	1
11/29/2022 19:00	1.4	11.8	2,270.4	0.9	6.80	1	1	1
11/29/2022 20:00	1.4	11.9	2,275.0	0.9	6.80	1	1	1
11/29/2022 21:00	1.4	11.9	2,279.4	0.9	6.80	1	1	1
11/29/2022 22:00	1.4	11.9	2,281.0	0.9	6.80	1	1	1
11/29/2022 23:00	1.4	11.9	2,279.2	0.9	6.80	1	1	1
Average/Sum#:	1.4	12.1	2,203.1	0.9	175.50 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,087.1	0.9	6.30	1	1	1
Maximum:	1.4	12.7	2,281.7	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2022 00:00	1.3	12.5	2,172.7	0.9	6.50	1	1	1
11/30/2022 01:00	1.3	12.5	2,154.2	0.9	6.50	1	1	1
11/30/2022 02:00	1.3	12.5	2,150.7	0.9	6.50	1	1	1
11/30/2022 03:00	1.3	12.5	2,151.7	0.9	6.50	1	1	1
11/30/2022 04:00	1.4	12.5	2,168.0	1.0	8.70	1	1	1
11/30/2022 05:00	1.5	12.5	2,165.1	1.1	8.70	1	1	1
11/30/2022 06:00	1.4	12.1	2,258.1	0.9	6.80	1	1	1
11/30/2022 07:00	1.3	12.5	2,146.1	0.9	6.40	1	1	1
11/30/2022 08:00	1.2	13.2	1,980.7	0.9	5.90	1	1	1
11/30/2022 09:00	1.3	13.1	1,994.5	1.0	8.00	1	1	1
11/30/2022 10:00	1.2	13.2	1,971.3	0.9	5.90	1	1	1
11/30/2022 11:00	1.2	13.1	1,965.9	0.9	5.90	1	1	1
11/30/2022 12:00	1.3	13.1	1,966.2	1.0	7.90	1	1	1
11/30/2022 13:00	1.3	13.0	1,964.4	1.0	7.90	1	1	1
11/30/2022 14:00	1.4	12.4	2,104.4	1.0	8.40	1	1	1
11/30/2022 15:00	1.4	12.3	2,113.2	1.0	8.50	1	1	1
11/30/2022 16:00	1.4	11.9	2,217.4	0.9	6.70	1	1	1
11/30/2022 17:00	1.4	11.7	2,265.7	0.9	6.80	1	1	1
11/30/2022 18:00	1.4	11.7	2,264.2	0.9	6.80	1	1	1
11/30/2022 19:00	1.4	11.7	2,263.8	0.9	6.80	1	1	1
11/30/2022 20:00	1.4	11.8	2,258.6	0.9	6.80	1	1	1
11/30/2022 21:00	1.4	11.9	2,224.8	0.9	6.70	1	1	1
11/30/2022 22:00	1.3	12.5	2,086.6	0.9	6.30	1	1	1
11/30/2022 23:00	1.8	13.7	1,584.9	1.5	7.90	1	0	1
Average/Sum#:	1.4	12.5	2,108.1	1.0	169.80 #	24 #	23 #	24 #
Minimum:	1.2	11.7	1,584.9	0.9	5.90	1	0	1
Maximum:	1.8	13.7	2,265.7	1.5	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2022 09:00	1.7	20.2	1.9	14.3	0.00	1	0	0
12/05/2022 10:00	31.0	16.6	470.2	42.5	73.80	1	0	0
12/05/2022 11:00	3.4	13.2	1,793.9	2.6	17.90	1	0	1
12/05/2022 12:00	1.4	12.2	2,140.7	0.9	6.40	1	1	1
12/05/2022 13:00	1.3	12.7	2,012.1	0.9	6.00	1	1	1
12/05/2022 14:00	1.3	12.7	2,032.3	0.9	6.10	1	1	1
12/05/2022 15:00	1.4	12.6	2,051.5	1.0	8.20	1	1	1
12/05/2022 16:00	1.3	12.0	2,193.6	0.9	6.60	1	1	1
12/05/2022 17:00	1.4	11.7	2,269.5	0.9	6.80	1	1	1
12/05/2022 18:00	1.4	11.7	2,271.5	0.9	6.80	1	1	1
12/05/2022 19:00	1.4	11.7	2,271.1	0.9	6.80	1	1	1
12/05/2022 20:00	1.4	11.8	2,272.1	0.9	6.80	1	1	1
12/05/2022 21:00	1.4	12.1	2,201.5	0.9	6.60	1	1	1
12/05/2022 22:00	1.3	12.7	2,067.0	0.9	6.20	1	1	1
12/05/2022 23:00	1.3	12.8	2,045.9	0.9	6.10	1	1	1
Average/Sum#:	3.5	13.1	1,873.0	4.7	171.10 #	15 #	12 #	13 #
Minimum:	1.3	11.7	1.9	0.9	0.00	0	0	0
Maximum:	31.0	20.2	2,272.1	42.5	73.80	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2022 00:00	1.2	13.2	1,967.2	0.9	5.90	1	1	1
12/06/2022 01:00	1.2	13.2	1,966.1	0.9	5.90	1	1	1
12/06/2022 02:00	1.2	13.2	1,965.7	0.9	5.90	1	1	1
12/06/2022 03:00	1.2	13.2	1,967.0	0.9	5.90	1	1	1
12/06/2022 04:00	1.3	13.1	1,982.2	1.0	7.90	1	1	1
12/06/2022 05:00	1.4	12.9	2,009.3	1.0	8.00	1	1	1
12/06/2022 06:00	1.2	13.1	1,982.0	0.9	5.90	1	1	1
12/06/2022 07:00	1.3	12.7	2,084.6	0.9	6.30	1	1	1
12/06/2022 08:00	1.4	11.9	2,259.2	0.9	6.80	1	1	1
12/06/2022 09:00	1.4	12.0	2,240.1	0.9	6.70	1	1	1
12/06/2022 10:00	1.4	12.0	2,234.8	0.9	6.70	1	1	1
12/06/2022 11:00	1.4	12.0	2,230.6	0.9	6.70	1	1	1
12/06/2022 12:00	1.4	12.0	2,217.9	0.9	6.70	1	1	1
12/06/2022 13:00	1.2	13.6	1,788.8	1.0	7.20	1	1	1
12/06/2022 14:00	1.1	13.9	1,318.8	0.9	4.00	1	1	0
12/06/2022 15:00	1.1	13.9	1,318.6	0.9	4.00	1	1	0
12/06/2022 16:00	1.1	13.8	1,520.8	0.9	4.60	1	1	0
12/06/2022 17:00	1.2	13.7	1,823.5	1.0	7.30	1	1	0
12/06/2022 18:00	1.2	13.7	1,825.1	1.0	7.30	1	1	0
12/06/2022 19:00	1.2	13.7	1,829.3	1.0	7.30	1	1	1
12/06/2022 20:00	1.3	12.5	2,123.4	0.9	6.40	1	1	1
12/06/2022 21:00	1.4	12.0	2,220.9	0.9	6.70	1	1	1
12/06/2022 22:00	1.3	12.5	2,096.6	0.9	6.30	1	1	1
12/06/2022 23:00	1.2	13.2	1,968.7	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,955.9	0.9	152.30 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,318.6	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,259.2	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	1.3	12.7	2,080.4	0.9	6.20	1	1	1
12/07/2022 01:00	1.3	13.1	1,983.5	1.0	7.90	1	1	1
12/07/2022 02:00	1.3	12.5	2,133.1	0.9	6.40	1	1	1
12/07/2022 03:00	1.3	12.5	2,140.6	0.9	6.40	1	1	1
12/07/2022 04:00	1.3	12.4	2,147.2	0.9	6.40	1	1	1
12/07/2022 05:00	1.5	12.3	2,161.2	1.0	8.60	1	1	1
12/07/2022 06:00	1.4	12.1	2,240.0	0.9	6.70	1	1	1
12/07/2022 07:00	1.4	12.0	2,240.5	0.9	6.70	1	1	1
12/07/2022 08:00	1.3	12.6	2,123.6	0.9	6.40	1	1	1
12/07/2022 09:00	1.4	12.5	2,160.5	1.0	8.60	1	1	1
12/07/2022 10:00	1.3	12.4	2,154.7	0.9	6.50	1	1	1
12/07/2022 11:00	1.3	12.4	2,152.0	0.9	6.50	1	1	1
12/07/2022 12:00	1.3	12.5	2,125.4	0.9	6.40	1	1	1
12/07/2022 13:00	1.3	12.5	2,105.1	0.9	6.30	1	1	1
12/07/2022 14:00	1.3	12.7	2,045.2	0.9	6.10	1	1	1
12/07/2022 15:00	1.3	12.6	2,072.9	0.9	6.20	1	1	1
12/07/2022 16:00	1.4	11.9	2,242.3	0.9	6.70	1	1	1
12/07/2022 17:00	1.4	11.8	2,263.1	0.9	6.80	1	1	1
12/07/2022 18:00	1.4	11.9	2,262.6	0.9	6.80	1	1	1
12/07/2022 19:00	1.4	11.9	2,259.5	0.9	6.80	1	1	1
12/07/2022 20:00	1.4	11.9	2,260.4	0.9	6.80	1	1	1
12/07/2022 21:00	1.4	12.0	2,254.9	0.9	6.80	1	1	1
12/07/2022 22:00	1.4	12.4	2,171.8	1.0	8.70	1	1	1
12/07/2022 23:00	1.3	12.4	2,171.2	0.9	6.50	1	1	1
Average/Sum#:	1.4	12.3	2,164.7	0.9	164.20 #	24 #	24 #	24 #
Minimum:	1.3	11.8	1,983.5	0.9	6.10	1	1	1
Maximum:	1.5	13.1	2,263.1	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	1.3	12.6	2,128.3	0.9	6.40	1	1	1
12/08/2022 01:00	1.4	12.6	2,124.0	1.0	8.50	1	1	1
12/08/2022 02:00	1.3	12.6	2,125.4	0.9	6.40	1	1	1
12/08/2022 03:00	1.3	12.6	2,126.6	0.9	6.40	1	1	1
12/08/2022 04:00	1.3	12.5	2,151.8	0.9	6.50	1	1	1
12/08/2022 05:00	1.5	12.1	2,206.3	1.0	8.80	1	1	1
12/08/2022 06:00	1.4	12.0	2,276.7	0.9	6.80	1	1	1
12/08/2022 07:00	1.4	12.2	2,235.9	0.9	6.70	1	1	1
12/08/2022 08:00	1.3	13.0	2,033.3	1.0	8.10	1	1	1
12/08/2022 09:00	1.3	12.7	2,119.8	0.9	6.40	1	1	1
12/08/2022 10:00	1.3	12.6	2,125.2	0.9	6.40	1	1	1
12/08/2022 11:00	1.4	12.5	2,152.4	1.0	8.60	1	1	1
12/08/2022 12:00	1.3	12.4	2,146.3	0.9	6.40	1	1	1
12/08/2022 13:00	1.3	12.3	2,151.6	0.9	6.50	1	1	1
12/08/2022 14:00	1.4	12.3	2,154.1	1.0	8.60	1	1	1
12/08/2022 15:00	1.4	12.3	2,161.0	1.0	8.60	1	1	1
12/08/2022 16:00	1.4	11.8	2,252.5	0.9	6.80	1	1	1
12/08/2022 17:00	1.4	11.9	2,253.7	0.9	6.80	1	1	1
12/08/2022 18:00	1.4	11.8	2,260.9	0.9	6.80	1	1	1
12/08/2022 19:00	1.4	11.8	2,258.9	0.9	6.80	1	1	1
12/08/2022 20:00	1.4	11.8	2,260.5	0.9	6.80	1	1	1
12/08/2022 21:00	1.4	11.8	2,262.3	0.9	6.80	1	1	1
12/08/2022 22:00	1.4	12.2	2,175.3	0.9	6.50	1	1	1
12/08/2022 23:00	1.4	12.3	2,175.7	1.0	8.70	1	1	1
Average/Sum#:	1.4	12.3	2,179.9	0.9	172.10 #	24 #	24 #	24 #
Minimum:	1.3	11.8	2,033.3	0.9	6.40	1	1	1
Maximum:	1.5	13.0	2,276.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2022 00:00	1.3	12.4	2,133.4	0.9	6.40	1	1	1
12/09/2022 01:00	1.3	12.9	2,049.3	1.0	8.20	1	1	1
12/09/2022 02:00	1.3	12.5	2,145.6	0.9	6.40	1	1	1
12/09/2022 03:00	1.3	12.5	2,141.8	0.9	6.40	1	1	1
12/09/2022 04:00	1.3	12.3	2,188.2	0.9	6.60	1	1	1
12/09/2022 05:00	1.5	11.9	2,279.0	1.0	9.10	1	1	1
12/09/2022 06:00	1.4	11.9	2,284.6	0.9	6.90	1	1	1
12/09/2022 07:00	1.4	12.0	2,273.6	0.9	6.80	1	1	1
12/09/2022 08:00	1.3	12.8	2,069.7	0.9	6.20	1	1	1
12/09/2022 09:00	1.3	13.0	2,024.0	1.0	8.10	1	1	1
12/09/2022 10:00	1.2	13.2	1,975.9	0.9	5.90	1	1	1
12/09/2022 11:00	1.3	12.8	2,071.4	0.9	6.20	1	1	1
12/09/2022 12:00	1.2	13.0	2,003.4	0.9	6.00	1	1	1
12/09/2022 13:00	1.3	12.4	2,147.1	0.9	6.40	1	1	1
12/09/2022 14:00	1.4	12.4	2,137.6	1.0	8.60	1	1	1
12/09/2022 15:00	1.3	12.8	2,036.0	0.9	6.10	1	1	1
12/09/2022 16:00	1.4	11.9	2,251.5	0.9	6.80	1	1	1
12/09/2022 17:00	1.4	11.9	2,251.1	0.9	6.80	1	1	1
12/09/2022 18:00	1.4	11.9	2,251.7	0.9	6.80	1	1	1
12/09/2022 19:00	1.4	11.9	2,253.6	0.9	6.80	1	1	1
12/09/2022 20:00	1.4	11.9	2,258.2	0.9	6.80	1	1	1
12/09/2022 21:00	1.4	11.9	2,257.3	0.9	6.80	1	1	1
12/09/2022 22:00	1.4	11.9	2,255.6	0.9	6.80	1	1	1
12/09/2022 23:00	1.4	11.9	2,249.1	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.3	2,166.2	0.9	164.60 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,975.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,284.6	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.3	12.9	2,006.4	1.0	8.00	1	1	1
12/10/2022 01:00	1.3	12.9	1,999.6	1.0	8.00	1	1	1
12/10/2022 02:00	1.2	13.1	1,963.4	0.9	5.90	1	1	1
12/10/2022 03:00	1.3	13.0	1,964.2	1.0	7.90	1	1	1
12/10/2022 04:00	1.3	13.0	1,959.0	1.0	7.80	1	1	1
12/10/2022 05:00	1.3	12.9	1,970.7	1.0	7.90	1	1	1
12/10/2022 06:00	1.3	13.0	1,958.3	1.0	7.80	1	1	1
12/10/2022 07:00	1.3	13.0	1,965.3	1.0	7.90	1	1	1
12/10/2022 08:00	1.3	12.8	2,005.5	0.9	6.00	1	1	1
12/10/2022 09:00	1.3	12.9	1,981.7	1.0	7.90	1	1	1
12/10/2022 10:00	1.3	13.0	1,958.2	1.0	7.80	1	1	1
12/10/2022 11:00	1.3	12.7	2,001.0	0.9	6.00	1	1	1
12/10/2022 12:00	1.4	12.3	2,097.7	1.0	8.40	1	1	1
12/10/2022 13:00	1.4	12.0	2,155.9	0.9	6.50	1	1	1
12/10/2022 14:00	1.3	12.6	2,002.4	0.9	6.00	1	1	1
12/10/2022 15:00	1.3	12.6	2,024.6	0.9	6.10	1	1	1
12/10/2022 16:00	1.4	12.3	2,094.2	1.0	8.40	1	1	1
12/10/2022 17:00	1.3	12.5	2,057.1	0.9	6.20	1	1	1
12/10/2022 18:00	1.3	12.5	2,058.1	0.9	6.20	1	1	1
12/10/2022 19:00	1.4	11.8	2,229.9	0.9	6.70	1	1	1
12/10/2022 20:00	1.4	12.1	2,153.8	0.9	6.50	1	1	1
12/10/2022 21:00	1.3	12.5	2,068.8	0.9	6.20	1	1	1
12/10/2022 22:00	1.3	12.8	2,009.3	0.9	6.00	1	1	1
12/10/2022 23:00	1.3	12.5	2,063.5	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.7	2,031.2	0.9	168.30 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,958.2	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,229.9	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.2	13.0	1,956.5	0.9	5.90	1	1	1
12/11/2022 01:00	1.3	13.1	1,954.5	1.0	7.80	1	1	1
12/11/2022 02:00	1.2	13.1	1,954.5	0.9	5.90	1	1	1
12/11/2022 03:00	1.2	13.1	1,953.0	0.9	5.90	1	1	1
12/11/2022 04:00	1.3	13.1	1,955.4	1.0	7.80	1	1	1
12/11/2022 05:00	1.1	13.1	1,956.0	0.8	5.90	1	1	1
12/11/2022 06:00	1.3	13.1	1,958.5	1.0	7.80	1	1	1
12/11/2022 07:00	1.2	13.1	1,960.5	0.9	5.90	1	1	1
12/11/2022 08:00	1.2	13.1	1,961.5	0.9	5.90	1	1	1
12/11/2022 09:00	1.3	13.1	1,964.5	1.0	7.90	1	1	1
12/11/2022 10:00	1.3	13.1	1,963.7	1.0	7.90	1	1	1
12/11/2022 11:00	1.2	13.1	1,959.8	0.9	5.90	1	1	1
12/11/2022 12:00	1.3	13.1	1,958.4	1.0	7.80	1	1	1
12/11/2022 13:00	1.2	13.0	1,960.6	0.9	5.90	1	1	1
12/11/2022 14:00	1.3	13.0	1,958.2	1.0	7.80	1	1	1
12/11/2022 15:00	1.3	12.7	2,050.1	0.9	6.20	1	1	1
12/11/2022 16:00	1.3	12.7	2,053.8	0.9	6.20	1	1	1
12/11/2022 17:00	1.3	12.4	2,123.8	0.9	6.40	1	1	1
12/11/2022 18:00	1.3	12.9	2,040.4	1.0	8.20	1	1	1
12/11/2022 19:00	1.3	12.8	2,068.4	0.9	6.20	1	1	1
12/11/2022 20:00	1.3	12.6	2,119.1	0.9	6.40	1	1	1
12/11/2022 21:00	1.2	13.1	2,002.7	0.9	6.00	1	1	1
12/11/2022 22:00	1.3	13.2	1,968.1	1.0	7.90	1	1	1
12/11/2022 23:00	1.2	13.2	1,965.9	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,990.3	0.9	161.40 #	24 #	24 #	24 #
Minimum:	1.1	12.4	1,953.0	0.8	5.90	1	1	1
Maximum:	1.3	13.2	2,123.8	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.3	13.2	1,974.6	1.0	7.90	1	1	1
12/12/2022 01:00	1.2	13.2	1,974.7	0.9	5.90	1	1	1
12/12/2022 02:00	1.3	13.2	1,974.6	1.0	7.90	1	1	1
12/12/2022 03:00	1.2	13.2	1,972.4	0.9	5.90	1	1	1
12/12/2022 04:00	1.3	13.2	1,975.3	1.0	7.90	1	1	1
12/12/2022 05:00	1.3	12.4	2,111.2	0.9	6.30	1	1	1
12/12/2022 06:00	1.4	12.3	2,205.4	1.0	8.80	1	1	1
12/12/2022 07:00	1.4	12.3	2,187.8	1.0	8.80	1	1	1
12/12/2022 08:00	1.3	12.8	2,074.1	0.9	6.20	1	1	1
12/12/2022 09:00	1.3	12.8	2,066.2	0.9	6.20	1	1	1
12/12/2022 10:00	1.2	13.2	1,973.4	0.9	5.90	1	1	1
12/12/2022 11:00	1.2	13.2	1,968.1	0.9	5.90	1	1	1
12/12/2022 12:00	1.2	13.2	1,964.0	0.9	5.90	1	1	1
12/12/2022 13:00	1.2	13.1	1,961.0	0.9	5.90	1	1	1
12/12/2022 14:00	1.2	13.1	1,953.7	0.9	5.90	1	1	1
12/12/2022 15:00	1.3	13.1	1,956.5	1.0	7.80	1	1	1
12/12/2022 16:00	1.3	12.4	2,131.9	0.9	6.40	1	1	1
12/12/2022 17:00	1.4	12.0	2,216.3	0.9	6.60	1	1	1
12/12/2022 18:00	1.4	11.8	2,275.3	0.9	6.80	1	1	1
12/12/2022 19:00	1.4	11.8	2,277.0	0.9	6.80	1	1	1
12/12/2022 20:00	1.4	11.8	2,281.0	0.9	6.80	1	1	1
12/12/2022 21:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/12/2022 22:00	1.4	12.3	2,188.8	1.0	8.80	1	1	1
12/12/2022 23:00	1.3	13.0	2,025.1	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.7	2,080.6	0.9	166.10 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,953.7	0.9	5.90	1	1	1
Maximum:	1.4	13.2	2,281.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	1.3	12.6	2,151.0	0.9	6.50	1	1	1
12/13/2022 01:00	1.3	12.5	2,157.4	0.9	6.50	1	1	1
12/13/2022 02:00	1.4	12.4	2,161.4	1.0	8.60	1	1	1
12/13/2022 03:00	1.3	12.5	2,146.4	0.9	6.40	1	1	1
12/13/2022 04:00	1.3	12.4	2,189.1	0.9	6.60	1	1	1
12/13/2022 05:00	1.3	12.0	2,273.8	0.9	6.80	1	1	1
12/13/2022 06:00	1.4	11.9	2,310.2	0.9	6.90	1	1	1
12/13/2022 07:00	1.4	11.9	2,287.8	0.9	6.90	1	1	1
12/13/2022 08:00	1.3	12.5	2,134.0	0.9	6.40	1	1	1
12/13/2022 09:00	1.3	13.0	2,010.3	1.0	8.00	1	1	1
12/13/2022 10:00	1.2	13.2	1,963.5	0.9	5.90	1	1	1
12/13/2022 11:00	1.2	13.2	1,966.2	0.9	5.90	1	1	1
12/13/2022 12:00	1.3	13.1	1,963.9	1.0	7.90	1	1	1
12/13/2022 13:00	1.2	13.1	1,958.8	0.9	5.90	1	1	1
12/13/2022 14:00	1.2	13.1	1,948.4	0.9	5.80	1	1	1
12/13/2022 15:00	1.3	12.7	2,055.9	0.9	6.20	1	1	1
12/13/2022 16:00	1.4	11.9	2,251.4	0.9	6.80	1	1	1
12/13/2022 17:00	1.4	11.8	2,271.2	0.9	6.80	1	1	1
12/13/2022 18:00	1.4	11.8	2,273.1	0.9	6.80	1	1	1
12/13/2022 19:00	1.4	11.9	2,270.7	0.9	6.80	1	1	1
12/13/2022 20:00	1.4	11.9	2,269.3	0.9	6.80	1	1	1
12/13/2022 21:00	1.4	12.0	2,274.0	0.9	6.80	1	1	1
12/13/2022 22:00	1.4	12.0	2,272.2	0.9	6.80	1	1	1
12/13/2022 23:00	1.4	11.9	2,268.0	0.9	6.80	1	1	1
Average/Sum#:	1.3	12.4	2,159.5	0.9	161.60 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,948.4	0.9	5.80	1	1	1
Maximum:	1.4	13.2	2,310.2	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	1.4	12.3	2,186.8	1.0	8.70	1	1	1
12/14/2022 01:00	1.3	12.4	2,187.5	0.9	6.60	1	1	1
12/14/2022 02:00	1.3	12.4	2,188.4	0.9	6.60	1	1	1
12/14/2022 03:00	1.3	12.4	2,189.7	0.9	6.60	1	1	1
12/14/2022 04:00	1.4	12.4	2,186.4	1.0	8.70	1	1	1
12/14/2022 05:00	1.5	12.0	2,291.8	1.0	9.20	1	1	1
12/14/2022 06:00	1.4	12.0	2,297.1	0.9	6.90	1	1	1
12/14/2022 07:00	1.4	12.1	2,255.1	0.9	6.80	1	1	1
12/14/2022 08:00	1.3	12.9	2,069.6	1.0	8.30	1	1	1
12/14/2022 09:00	1.3	13.1	2,007.9	1.0	8.00	1	1	1
12/14/2022 10:00	1.2	13.0	2,023.9	0.9	6.10	1	1	1
12/14/2022 11:00	1.2	13.2	1,967.4	0.9	5.90	1	1	1
12/14/2022 12:00	1.2	13.2	1,967.7	0.9	5.90	1	1	1
12/14/2022 13:00	1.2	13.2	1,966.4	0.9	5.90	1	1	1
12/14/2022 14:00	1.2	13.2	1,961.9	0.9	5.90	1	1	1
12/14/2022 15:00	1.3	13.0	2,003.9	1.0	8.00	1	1	1
12/14/2022 16:00	1.4	12.2	2,196.7	0.9	6.60	1	1	1
12/14/2022 17:00	1.4	11.9	2,270.2	0.9	6.80	1	1	1
12/14/2022 18:00	1.4	11.9	2,263.7	0.9	6.80	1	1	1
12/14/2022 19:00	1.4	11.9	2,270.0	0.9	6.80	1	1	1
12/14/2022 20:00	1.4	11.9	2,269.8	0.9	6.80	1	1	1
12/14/2022 21:00	1.4	12.0	2,270.9	0.9	6.80	1	1	1
12/14/2022 22:00	1.4	12.1	2,250.1	0.9	6.80	1	1	1
12/14/2022 23:00	1.3	12.4	2,172.6	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.5	2,154.8	0.9	168.00 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,961.9	0.9	5.90	1	1	1
Maximum:	1.5	13.2	2,297.1	1.0	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2022 00:00	1.4	11.9	2,285.2	0.9	6.90	1	1	1
12/15/2022 01:00	1.4	11.9	2,294.2	0.9	6.90	1	1	1
12/15/2022 02:00	1.4	11.9	2,295.1	0.9	6.90	1	1	1
12/15/2022 03:00	1.4	11.9	2,296.8	0.9	6.90	1	1	1
12/15/2022 04:00	1.4	11.9	2,302.4	0.9	6.90	1	1	1
12/15/2022 05:00	1.2	11.8	2,305.6	0.8	6.90	1	1	1
12/15/2022 06:00	1.4	11.8	2,303.9	0.9	6.90	1	1	1
12/15/2022 07:00	1.4	11.9	2,297.7	0.9	6.90	1	1	1
12/15/2022 08:00	1.4	12.2	2,216.9	0.9	6.70	1	1	1
12/15/2022 09:00	1.4	12.1	2,210.5	0.9	6.60	1	1	1
12/15/2022 10:00	1.2	13.1	1,975.6	0.9	5.90	1	1	1
12/15/2022 11:00	1.3	13.0	1,984.0	1.0	7.90	1	1	1
12/15/2022 12:00	1.3	12.8	2,010.5	0.9	6.00	1	1	1
12/15/2022 13:00	1.3	12.8	2,027.3	0.9	6.10	1	1	1
12/15/2022 14:00	1.3	12.5	2,076.8	0.9	6.20	1	1	1
12/15/2022 15:00	1.4	11.9	2,224.3	0.9	6.70	1	1	1
12/15/2022 16:00	1.4	11.9	2,242.6	0.9	6.70	1	1	1
12/15/2022 17:00	1.4	11.9	2,240.4	0.9	6.70	1	1	1
12/15/2022 18:00	1.4	12.0	2,233.1	0.9	6.70	1	1	1
12/15/2022 19:00	1.4	12.0	2,230.3	0.9	6.70	1	1	1
12/15/2022 20:00	1.4	12.0	2,232.7	0.9	6.70	1	1	1
12/15/2022 21:00	1.4	12.1	2,238.4	0.9	6.70	1	1	1
12/15/2022 22:00	1.4	12.1	2,242.7	0.9	6.70	1	1	1
12/15/2022 23:00	1.4	12.2	2,230.3	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.2	2,208.2	0.9	160.90 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,975.6	0.8	5.90	1	1	1
Maximum:	1.4	13.1	2,305.6	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2022 00:00	1.3	13.1	1,993.7	1.0	8.00	1	1	1
12/16/2022 01:00	1.2	13.2	1,967.6	0.9	5.90	1	1	1
12/16/2022 02:00	1.3	13.2	1,966.9	1.0	7.90	1	1	1
12/16/2022 03:00	1.2	13.2	1,969.7	0.9	5.90	1	1	1
12/16/2022 04:00	1.3	13.2	1,968.6	1.0	7.90	1	1	1
12/16/2022 05:00	1.2	13.2	1,982.9	0.9	5.90	1	1	1
12/16/2022 06:00	1.3	12.7	2,114.1	0.9	6.30	1	1	1
12/16/2022 07:00	1.4	12.3	2,208.1	1.0	8.80	1	1	1
12/16/2022 08:00	1.3	12.6	2,142.7	0.9	6.40	1	1	1
12/16/2022 09:00	1.3	12.7	2,066.1	0.9	6.20	1	1	1
12/16/2022 10:00	1.1	13.8	1,542.9	0.9	4.60	1	1	0
12/16/2022 11:00	1.1	13.9	1,461.4	0.9	4.40	1	1	0
12/16/2022 12:00	1.1	13.9	1,324.4	0.9	4.00	1	1	0
12/16/2022 13:00	1.1	13.9	1,326.3	0.9	4.00	1	1	0
12/16/2022 14:00	1.1	13.8	1,587.9	0.9	4.80	1	1	0
12/16/2022 15:00	1.1	13.8	1,555.8	0.9	4.70	1	1	1
12/16/2022 16:00	1.4	12.4	2,147.0	1.0	8.60	1	1	1
12/16/2022 17:00	1.4	12.0	2,222.2	0.9	6.70	1	1	1
12/16/2022 18:00	1.4	12.4	2,150.0	1.0	8.60	1	1	1
12/16/2022 19:00	1.4	12.4	2,159.8	1.0	8.60	1	1	1
12/16/2022 20:00	1.4	11.9	2,243.7	0.9	6.70	1	1	1
12/16/2022 21:00	1.4	12.2	2,187.6	0.9	6.60	1	1	1
12/16/2022 22:00	1.3	12.7	2,087.4	0.9	6.30	1	1	1
12/16/2022 23:00	1.2	13.2	1,976.6	0.9	5.90	1	1	1
Average/Sum#:	1.3	13.0	1,931.4	0.9	153.70 #	24 #	24 #	19 #
Minimum:	1.1	11.9	1,324.4	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,243.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	1.3	12.5	2,146.2	0.9	6.40	1	1	1
12/17/2022 01:00	1.3	12.5	2,148.8	0.9	6.40	1	1	1
12/17/2022 02:00	1.3	12.5	2,140.6	0.9	6.40	1	1	1
12/17/2022 03:00	1.3	12.5	2,153.2	0.9	6.50	1	1	1
12/17/2022 04:00	1.3	12.5	2,153.6	0.9	6.50	1	1	1
12/17/2022 05:00	1.2	12.5	2,151.4	0.8	6.50	1	1	1
12/17/2022 06:00	1.4	12.2	2,233.8	0.9	6.70	1	1	1
12/17/2022 07:00	1.3	12.7	2,099.2	0.9	6.30	1	1	1
12/17/2022 08:00	1.3	12.5	2,159.2	0.9	6.50	1	1	1
12/17/2022 09:00	1.3	12.6	2,117.2	0.9	6.40	1	1	1
12/17/2022 10:00	1.3	13.1	1,997.6	1.0	8.00	1	1	1
12/17/2022 11:00	1.2	13.2	1,964.4	0.9	5.90	1	1	1
12/17/2022 12:00	1.2	13.2	1,960.9	0.9	5.90	1	1	1
12/17/2022 13:00	1.2	13.1	1,956.6	0.9	5.90	1	1	1
12/17/2022 14:00	1.3	13.0	1,970.0	1.0	7.90	1	1	1
12/17/2022 15:00	1.3	12.5	2,100.3	0.9	6.30	1	1	1
12/17/2022 16:00	1.4	11.9	2,248.1	0.9	6.70	1	1	1
12/17/2022 17:00	1.4	12.0	2,217.8	0.9	6.70	1	1	1
12/17/2022 18:00	1.4	12.4	2,137.6	1.0	8.60	1	1	1
12/17/2022 19:00	1.4	11.8	2,260.0	0.9	6.80	1	1	1
12/17/2022 20:00	1.4	11.8	2,263.2	0.9	6.80	1	1	1
12/17/2022 21:00	1.4	11.8	2,264.7	0.9	6.80	1	1	1
12/17/2022 22:00	1.4	11.9	2,261.6	0.9	6.80	1	1	1
12/17/2022 23:00	1.4	12.3	2,180.2	1.0	8.70	1	1	1
Average/Sum#:	1.3	12.5	2,136.9	0.9	162.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,956.6	0.8	5.90	1	1	1
Maximum:	1.4	13.2	2,264.7	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	1.3	12.5	2,132.5	0.9	6.40	1	1	1
12/18/2022 01:00	1.3	12.6	2,135.5	0.9	6.40	1	1	1
12/18/2022 02:00	1.3	13.0	2,021.6	1.0	8.10	1	1	1
12/18/2022 03:00	1.2	13.2	1,975.9	0.9	5.90	1	1	1
12/18/2022 04:00	1.3	12.6	2,135.5	0.9	6.40	1	1	1
12/18/2022 05:00	1.4	12.5	2,156.2	1.0	8.60	1	1	1
12/18/2022 06:00	1.3	12.4	2,171.1	0.9	6.50	1	1	1
12/18/2022 07:00	1.4	12.3	2,208.2	1.0	8.80	1	1	1
12/18/2022 08:00	1.3	12.6	2,085.2	0.9	6.30	1	1	1
12/18/2022 09:00	1.1	13.8	1,618.7	0.9	4.90	1	1	0
12/18/2022 10:00	1.2	13.8	1,561.3	1.0	6.20	1	1	0
12/18/2022 11:00	1.1	13.8	1,559.0	0.9	4.70	1	1	0
12/18/2022 12:00	1.1	13.8	1,408.9	0.9	4.20	1	1	0
12/18/2022 13:00	1.1	13.8	1,399.2	0.9	4.20	1	1	0
12/18/2022 14:00	1.2	13.8	1,643.4	1.0	6.60	1	1	0
12/18/2022 15:00	1.1	13.8	1,651.7	0.9	5.00	1	1	1
12/18/2022 16:00	1.3	12.4	2,130.5	0.9	6.40	1	1	1
12/18/2022 17:00	1.4	12.0	2,242.0	0.9	6.70	1	1	1
12/18/2022 18:00	1.4	11.9	2,269.4	0.9	6.80	1	1	1
12/18/2022 19:00	1.4	11.9	2,270.4	0.9	6.80	1	1	1
12/18/2022 20:00	1.4	12.1	2,236.3	0.9	6.70	1	1	1
12/18/2022 21:00	1.4	12.3	2,210.2	1.0	8.80	1	1	1
12/18/2022 22:00	1.4	12.4	2,198.1	1.0	8.80	1	1	1
12/18/2022 23:00	1.3	12.9	2,049.0	1.0	8.20	1	1	1
Average/Sum#:	1.3	12.8	1,977.9	0.9	158.40 #	24 #	24 #	18 #
Minimum:	1.1	11.9	1,399.2	0.9	4.20	1	1	0
Maximum:	1.4	13.8	2,270.4	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2022 00:00	1.3	12.6	2,143.3	0.9	6.40	1	1	1
12/19/2022 01:00	1.3	12.5	2,153.6	0.9	6.50	1	1	1
12/19/2022 02:00	1.4	12.6	2,150.3	1.0	8.60	1	1	1
12/19/2022 03:00	1.4	12.6	2,151.5	1.0	8.60	1	1	1
12/19/2022 04:00	1.3	12.5	2,181.6	0.9	6.50	1	1	1
12/19/2022 05:00	1.3	12.0	2,296.4	0.9	6.90	1	1	1
12/19/2022 06:00	1.4	12.0	2,296.2	0.9	6.90	1	1	1
12/19/2022 07:00	1.4	12.0	2,295.5	0.9	6.90	1	1	1
12/19/2022 08:00	1.4	12.1	2,248.0	0.9	6.70	1	1	1
12/19/2022 09:00	1.4	12.1	2,257.3	0.9	6.80	1	1	1
12/19/2022 10:00	1.3	12.5	2,169.7	0.9	6.50	1	1	1
12/19/2022 11:00	1.3	12.5	2,172.8	0.9	6.50	1	1	1
12/19/2022 12:00	1.3	12.5	2,163.1	0.9	6.50	1	1	1
12/19/2022 13:00	1.3	12.5	2,154.7	0.9	6.50	1	1	1
12/19/2022 14:00	1.3	12.5	2,157.0	0.9	6.50	1	1	1
12/19/2022 15:00	1.4	12.3	2,218.7	1.0	8.90	1	1	1
12/19/2022 16:00	1.4	12.1	2,259.5	0.9	6.80	1	1	1
12/19/2022 17:00	1.4	12.1	2,264.7	0.9	6.80	1	1	1
12/19/2022 18:00	1.4	12.1	2,265.6	0.9	6.80	1	1	1
12/19/2022 19:00	1.4	12.1	2,264.2	0.9	6.80	1	1	1
12/19/2022 20:00	1.4	12.1	2,259.5	0.9	6.80	1	1	1
12/19/2022 21:00	1.4	12.1	2,259.7	0.9	6.80	1	1	1
12/19/2022 22:00	1.4	12.1	2,264.3	0.9	6.80	1	1	1
12/19/2022 23:00	1.4	12.1	2,263.6	0.9	6.80	1	1	1
Average/Sum#:	1.4	12.3	2,221.3	0.9	166.60 #	24 #	24 #	24 #
Minimum:	1.3	12.0	2,143.3	0.9	6.40	1	1	1
Maximum:	1.4	12.6	2,296.4	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	1.3	12.5	2,172.5	0.9	6.50	1	1	1
12/20/2022 01:00	1.4	12.5	2,169.3	1.0	8.70	1	1	1
12/20/2022 02:00	1.3	12.5	2,173.2	0.9	6.50	1	1	1
12/20/2022 03:00	1.3	12.5	2,179.2	0.9	6.50	1	1	1
12/20/2022 04:00	1.4	12.5	2,184.8	1.0	8.70	1	1	1
12/20/2022 05:00	1.4	12.5	2,186.9	1.0	8.70	1	1	1
12/20/2022 06:00	1.4	12.1	2,279.9	0.9	6.80	1	1	1
12/20/2022 07:00	1.4	12.1	2,273.5	0.9	6.80	1	1	1
12/20/2022 08:00	1.3	12.5	2,163.7	0.9	6.50	1	1	1
12/20/2022 09:00	1.4	12.5	2,161.4	1.0	8.60	1	1	1
12/20/2022 10:00	1.3	12.6	2,120.5	0.9	6.40	1	1	1
12/20/2022 11:00	1.3	12.7	2,088.3	0.9	6.30	1	1	1
12/20/2022 12:00	1.2	13.2	1,961.1	0.9	5.90	1	1	1
12/20/2022 13:00	1.2	13.2	1,963.4	0.9	5.90	1	1	1
12/20/2022 14:00	1.2	13.2	1,958.0	0.9	5.90	1	1	1
12/20/2022 15:00	1.3	12.9	2,030.5	1.0	8.10	1	1	1
12/20/2022 16:00	1.4	12.3	2,184.0	1.0	8.70	1	1	1
12/20/2022 17:00	1.4	12.0	2,248.1	0.9	6.70	1	1	1
12/20/2022 18:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/20/2022 19:00	1.4	12.0	2,239.7	0.9	6.70	1	1	1
12/20/2022 20:00	1.4	12.0	2,241.8	0.9	6.70	1	1	1
12/20/2022 21:00	1.3	12.4	2,154.7	0.9	6.50	1	1	1
12/20/2022 22:00	1.3	12.4	2,156.3	0.9	6.50	1	1	1
12/20/2022 23:00	1.4	12.2	2,209.3	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.5	2,156.1	0.9	167.90 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,958.0	0.9	5.90	1	1	1
Maximum:	1.4	13.2	2,279.9	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	1.4	11.9	2,265.8	0.9	6.80	1	1	1
12/21/2022 01:00	1.4	11.9	2,263.2	0.9	6.80	1	1	1
12/21/2022 02:00	1.4	12.0	2,261.3	0.9	6.80	1	1	1
12/21/2022 03:00	1.4	12.0	2,267.1	0.9	6.80	1	1	1
12/21/2022 04:00	1.4	12.0	2,267.5	0.9	6.80	1	1	1
12/21/2022 05:00	1.3	12.0	2,262.9	0.9	6.80	1	1	1
12/21/2022 06:00	1.4	12.0	2,262.6	0.9	6.80	1	1	1
12/21/2022 07:00	1.4	12.0	2,260.4	0.9	6.80	1	1	1
12/21/2022 08:00	1.4	12.1	2,249.7	0.9	6.70	1	1	1
12/21/2022 09:00	1.4	12.1	2,235.5	0.9	6.70	1	1	1
12/21/2022 10:00	1.4	12.1	2,227.8	0.9	6.70	1	1	1
12/21/2022 11:00	1.4	12.2	2,195.0	0.9	6.60	1	1	1
12/21/2022 12:00	1.4	12.1	2,213.1	0.9	6.60	1	1	1
12/21/2022 13:00	1.4	12.1	2,208.4	0.9	6.60	1	1	1
12/21/2022 14:00	1.4	12.4	2,133.5	1.0	8.50	1	1	1
12/21/2022 15:00	1.4	12.1	2,205.0	0.9	6.60	1	1	1
12/21/2022 16:00	1.4	12.0	2,227.3	0.9	6.70	1	1	1
12/21/2022 17:00	1.4	12.0	2,234.1	0.9	6.70	1	1	1
12/21/2022 18:00	1.4	12.0	2,239.9	0.9	6.70	1	1	1
12/21/2022 19:00	1.4	12.0	2,241.3	0.9	6.70	1	1	1
12/21/2022 20:00	1.4	12.0	2,238.6	0.9	6.70	1	1	1
12/21/2022 21:00	1.4	12.0	2,238.6	0.9	6.70	1	1	1
12/21/2022 22:00	1.4	12.1	2,239.1	0.9	6.70	1	1	1
12/21/2022 23:00	1.4	12.1	2,239.7	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.1	2,236.6	0.9	163.00 #	24 #	24 #	24 #
Minimum:	1.3	11.9	2,133.5	0.9	6.60	1	1	1
Maximum:	1.4	12.4	2,267.5	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2022 00:00	1.3	12.3	2,179.5	0.9	6.50	1	1	1
12/22/2022 01:00	1.3	13.1	1,980.0	1.0	7.90	1	1	1
12/22/2022 02:00	1.2	13.2	1,961.4	0.9	5.90	1	1	1
12/22/2022 03:00	1.3	13.2	1,964.7	1.0	7.90	1	1	1
12/22/2022 04:00	1.3	12.8	2,094.8	0.9	6.30	1	1	1
12/22/2022 05:00	1.2	12.1	2,222.3	0.8	6.70	1	1	1
12/22/2022 06:00	1.4	12.1	2,261.4	0.9	6.80	1	1	1
12/22/2022 07:00	1.4	12.1	2,259.7	0.9	6.80	1	1	1
12/22/2022 08:00	1.4	12.1	2,238.6	0.9	6.70	1	1	1
12/22/2022 09:00	1.3	12.5	2,150.2	0.9	6.50	1	1	1
12/22/2022 10:00	1.3	12.6	2,145.1	0.9	6.40	1	1	1
12/22/2022 11:00	1.3	12.5	2,140.3	0.9	6.40	1	1	1
12/22/2022 12:00	1.3	12.5	2,137.6	0.9	6.40	1	1	1
12/22/2022 13:00	1.3	12.5	2,137.2	0.9	6.40	1	1	1
12/22/2022 14:00	1.3	12.5	2,144.7	0.9	6.40	1	1	1
12/22/2022 15:00	1.4	12.2	2,203.3	0.9	6.60	1	1	1
12/22/2022 16:00	1.4	12.2	2,198.4	0.9	6.60	1	1	1
12/22/2022 17:00	1.4	12.0	2,238.8	0.9	6.70	1	1	1
12/22/2022 18:00	1.4	12.0	2,242.2	0.9	6.70	1	1	1
12/22/2022 19:00	1.4	12.0	2,246.6	0.9	6.70	1	1	1
12/22/2022 20:00	1.4	12.0	2,243.5	0.9	6.70	1	1	1
12/22/2022 21:00	1.4	12.0	2,241.4	0.9	6.70	1	1	1
12/22/2022 22:00	1.4	12.2	2,200.2	0.9	6.60	1	1	1
12/22/2022 23:00	1.3	12.8	2,068.8	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.4	2,162.5	0.9	159.50 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,961.4	0.8	5.90	1	1	1
Maximum:	1.4	13.2	2,261.4	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	1.4	12.2	2,215.5	0.9	6.60	1	1	1
12/23/2022 01:00	1.4	12.0	2,252.2	0.9	6.80	1	1	1
12/23/2022 02:00	1.4	12.0	2,250.3	0.9	6.80	1	1	1
12/23/2022 03:00	1.4	12.0	2,245.6	0.9	6.70	1	1	1
12/23/2022 04:00	1.4	12.0	2,248.2	0.9	6.70	1	1	1
12/23/2022 05:00	1.3	12.0	2,241.2	0.9	6.70	1	1	1
12/23/2022 06:00	1.4	12.0	2,250.7	0.9	6.80	1	1	1
12/23/2022 07:00	1.4	12.1	2,232.9	0.9	6.70	1	1	1
12/23/2022 08:00	1.4	12.3	2,172.6	1.0	8.70	1	1	1
12/23/2022 09:00	1.4	12.3	2,163.4	1.0	8.70	1	1	1
12/23/2022 10:00	1.3	12.5	2,122.9	0.9	6.40	1	1	1
12/23/2022 11:00	1.4	12.4	2,124.2	1.0	8.50	1	1	1
12/23/2022 12:00	1.3	12.8	2,017.4	0.9	6.10	1	1	1
12/23/2022 13:00	1.2	13.1	1,950.0	0.9	5.90	1	1	1
12/23/2022 14:00	1.3	13.1	1,941.4	1.0	7.80	1	1	1
12/23/2022 15:00	1.3	12.7	2,049.7	0.9	6.10	1	1	1
12/23/2022 16:00	1.4	11.9	2,228.2	0.9	6.70	1	1	1
12/23/2022 17:00	1.4	11.9	2,230.8	0.9	6.70	1	1	1
12/23/2022 18:00	1.4	11.9	2,231.0	0.9	6.70	1	1	1
12/23/2022 19:00	1.4	12.0	2,229.3	0.9	6.70	1	1	1
12/23/2022 20:00	1.4	12.0	2,230.7	0.9	6.70	1	1	1
12/23/2022 21:00	1.4	11.9	2,234.3	0.9	6.70	1	1	1
12/23/2022 22:00	1.4	11.9	2,233.5	0.9	6.70	1	1	1
12/23/2022 23:00	1.4	12.0	2,225.6	0.9	6.70	1	1	1
Average/Sum#:	1.4	12.2	2,180.1	0.9	165.60 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,941.4	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,252.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	1.4	12.4	2,119.0	1.0	8.50	1	1	1
12/24/2022 01:00	1.3	12.5	2,113.9	0.9	6.30	1	1	1
12/24/2022 02:00	1.2	13.1	1,961.4	0.9	5.90	1	1	1
12/24/2022 03:00	1.2	13.2	1,955.3	0.9	5.90	1	1	1
12/24/2022 04:00	1.2	13.2	1,953.0	0.9	5.90	1	1	1
12/24/2022 05:00	1.3	13.2	1,951.1	1.0	7.80	1	1	1
12/24/2022 06:00	1.2	13.1	1,974.8	0.9	5.90	1	1	1
12/24/2022 07:00	1.3	13.0	1,998.9	1.0	8.00	1	1	1
12/24/2022 08:00	1.2	13.3	1,833.9	0.9	5.50	1	1	1
12/24/2022 09:00	1.1	13.8	1,320.7	0.9	4.00	1	1	0
12/24/2022 10:00	1.1	13.8	1,559.7	0.9	4.70	1	1	0
12/24/2022 11:00	1.1	13.8	1,555.6	0.9	4.70	1	1	0
12/24/2022 12:00	1.1	13.8	1,554.9	0.9	4.70	1	1	0
12/24/2022 13:00	1.2	13.8	1,558.8	1.0	6.20	1	1	0
12/24/2022 14:00	1.1	13.8	1,730.9	0.9	5.20	1	1	0
12/24/2022 15:00	1.1	13.8	1,739.5	0.9	5.20	1	1	0
12/24/2022 16:00	1.1	13.8	1,594.1	0.9	4.80	1	1	1
12/24/2022 17:00	1.2	13.1	1,944.9	0.9	5.80	1	1	1
12/24/2022 18:00	1.3	13.1	1,943.7	1.0	7.80	1	1	1
12/24/2022 19:00	1.2	13.1	1,944.1	0.9	5.80	1	1	1
12/24/2022 20:00	1.2	13.1	1,947.7	0.9	5.80	1	1	1
12/24/2022 21:00	1.3	13.1	1,944.2	1.0	7.80	1	1	1
12/24/2022 22:00	1.2	13.2	1,946.9	0.9	5.80	1	1	1
12/24/2022 23:00	1.2	13.2	1,949.6	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.3	1,837.4	0.9	143.80 #	24 #	24 #	17 #
Minimum:	1.1	12.4	1,320.7	0.9	4.00	1	1	0
Maximum:	1.4	13.8	2,119.0	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.2	13.2	1,930.0	0.9	5.80	1	1	1
12/25/2022 01:00	4.1	15.6	591.4	4.6	2.22	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.7	14.4	1,260.7	2.8	8.02 #	2 #	1 #	1 #
Minimum:	1.2	13.2	591.4	0.9	2.22	0	0	0
Maximum:	4.1	15.6	1,930.0	4.6	5.80	1	1	1
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2022 00:00	30.0	17.6	332.1	53.6	41.45	1	0	0
12/26/2022 01:00	14.9	15.1	969.8	15.2	54.30	1	0	0
12/26/2022 02:00	1.2	13.7	1,715.8	1.0	6.90	1	1	0
12/26/2022 03:00	1.2	13.7	1,736.0	1.0	6.90	1	1	0
12/26/2022 04:00	1.2	13.7	1,735.7	1.0	6.90	1	1	0
12/26/2022 05:00	1.2	13.7	1,750.8	1.0	7.00	1	1	0
12/26/2022 06:00	1.2	13.7	1,750.6	1.0	7.00	1	1	0
12/26/2022 07:00	1.2	13.7	1,742.3	1.0	7.00	1	1	0
12/26/2022 08:00	1.2	13.7	1,748.4	1.0	7.00	1	1	0
12/26/2022 09:00	1.1	13.8	1,563.8	0.9	4.70	1	1	0
12/26/2022 10:00	1.1	13.8	1,559.4	0.9	4.70	1	1	0
12/26/2022 11:00	1.1	13.8	1,550.2	0.9	4.70	1	1	0
12/26/2022 12:00	1.1	13.8	1,541.0	0.9	4.60	1	1	0
12/26/2022 13:00	1.1	13.8	1,561.8	0.9	4.70	1	1	0
12/26/2022 14:00	1.1	13.7	1,623.4	0.9	4.90	1	1	0
12/26/2022 15:00	1.2	13.7	1,751.1	1.0	7.00	1	1	0
12/26/2022 16:00	1.2	13.7	1,782.9	1.0	7.10	1	1	1
12/26/2022 17:00	1.3	12.5	2,103.9	0.9	6.30	1	1	1
12/26/2022 18:00	1.3	12.3	2,145.3	0.9	6.40	1	1	1
12/26/2022 19:00	1.3	12.9	2,004.1	1.0	8.00	1	1	1
12/26/2022 20:00	1.3	13.0	1,990.7	1.0	8.00	1	1	1
12/26/2022 21:00	1.2	13.1	1,960.1	0.9	5.90	1	1	1
12/26/2022 22:00	1.3	13.1	1,936.0	1.0	7.70	1	1	1
12/26/2022 23:00	3.2	15.6	602.1	3.6	1.79	1	0	0
Average/Sum#:	3.1	13.8	1,631.6	3.9	230.94 #	24 #	21 #	7 #
Minimum:	1.1	12.3	332.1	0.9	1.79	1	0	0
Maximum:	30.0	17.6	2,145.3	53.6	54.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 05:00	9.3	17.0	482.2	14.1	11.30	1	0	0
12/27/2022 06:00	6.3	14.3	1,185.6	5.6	24.90	1	0	0
12/27/2022 07:00	1.2	13.7	1,737.9	1.0	7.00	1	1	0
12/27/2022 08:00	1.2	13.6	1,714.6	1.0	6.90	1	1	1
12/27/2022 09:00	1.3	12.9	1,950.3	1.0	7.80	1	1	1
12/27/2022 10:00	1.2	12.9	1,947.7	0.9	5.80	1	1	1
12/27/2022 11:00	1.3	12.9	1,950.7	1.0	7.80	1	1	1
12/27/2022 12:00	1.3	12.9	1,949.0	1.0	7.80	1	1	1
12/27/2022 13:00	1.3	12.9	1,947.5	1.0	7.80	1	1	1
12/27/2022 14:00	1.3	12.9	1,948.0	1.0	7.80	1	1	1
12/27/2022 15:00	1.3	12.9	1,949.1	1.0	7.80	1	1	1
12/27/2022 16:00	1.3	12.9	1,950.9	1.0	7.80	1	1	1
12/27/2022 17:00	1.2	13.0	1,941.7	0.9	5.80	1	1	1
12/27/2022 18:00	1.3	13.1	1,938.3	1.0	7.80	1	1	1
12/27/2022 19:00	1.2	13.1	1,941.5	0.9	5.80	1	1	1
12/27/2022 20:00	1.2	13.1	1,950.2	0.9	5.90	1	1	1
12/27/2022 21:00	1.3	13.1	1,946.3	1.0	7.80	1	1	1
12/27/2022 22:00	1.2	13.1	1,927.1	0.9	5.80	1	1	1
12/27/2022 23:00	1.1	13.9	1,398.6	0.9	4.20	1	1	0
Average/Sum#:	1.9	13.4	1,776.7	1.9	153.60 #	19 #	17 #	15 #
Minimum:	1.1	12.9	482.2	0.9	4.20	0	0	0
Maximum:	9.3	17.0	1,950.9	14.1	24.90	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	1.1	13.8	1,551.1	0.9	4.70	1	1	0
12/28/2022 01:00	1.1	13.8	1,473.8	0.9	4.40	1	1	0
12/28/2022 02:00	1.1	13.8	1,538.3	0.9	4.60	1	1	0
12/28/2022 03:00	1.1	13.8	1,537.5	0.9	4.60	1	1	0
12/28/2022 04:00	1.2	13.8	1,543.0	1.0	6.20	1	1	0
12/28/2022 05:00	1.1	13.7	1,735.6	0.9	5.20	1	1	0
12/28/2022 06:00	1.2	13.7	1,753.7	1.0	7.00	1	1	0
12/28/2022 07:00	1.2	13.7	1,756.5	1.0	7.00	1	1	0
12/28/2022 08:00	1.2	13.7	1,732.6	1.0	6.90	1	1	0
12/28/2022 09:00	1.1	13.7	1,723.8	0.9	5.20	1	1	0
12/28/2022 10:00	1.1	13.8	1,562.0	0.9	4.70	1	1	0
12/28/2022 11:00	1.1	13.8	1,577.9	0.9	4.70	1	1	0
12/28/2022 12:00	1.1	13.8	1,560.7	0.9	4.70	1	1	0
12/28/2022 13:00	1.1	13.8	1,535.3	0.9	4.60	1	1	0
12/28/2022 14:00	1.1	13.8	1,554.0	0.9	4.70	1	1	0
12/28/2022 15:00	1.2	13.7	1,601.3	1.0	6.40	1	1	1
12/28/2022 16:00	1.3	12.5	2,087.1	0.9	6.30	1	1	1
12/28/2022 17:00	1.3	13.0	1,974.8	1.0	7.90	1	1	1
12/28/2022 18:00	1.2	13.1	1,954.9	0.9	5.90	1	1	1
12/28/2022 19:00	1.3	13.1	1,956.3	1.0	7.80	1	1	1
12/28/2022 20:00	1.2	13.1	1,955.8	0.9	5.90	1	1	1
12/28/2022 21:00	1.2	13.0	1,967.9	0.9	5.90	1	1	1
12/28/2022 22:00	1.3	13.1	1,952.9	1.0	7.80	1	1	1
12/28/2022 23:00	1.2	13.1	1,957.6	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.5	1,731.0	0.9	139.00 #	24 #	24 #	9 #
Minimum:	1.1	12.5	1,473.8	0.9	4.40	1	1	0
Maximum:	1.3	13.8	2,087.1	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2022 00:00	1.2	13.1	1,953.1	0.9	5.90	1	1	1
12/29/2022 01:00	1.2	13.1	1,953.2	0.9	5.90	1	1	1
12/29/2022 02:00	1.2	13.1	1,953.7	0.9	5.90	1	1	1
12/29/2022 03:00	1.3	13.1	1,955.0	1.0	7.80	1	1	1
12/29/2022 04:00	1.2	13.1	1,957.5	0.9	5.90	1	1	1
12/29/2022 05:00	1.2	12.7	2,029.7	0.9	6.10	1	1	1
12/29/2022 06:00	1.3	12.8	2,039.0	0.9	6.10	1	1	1
12/29/2022 07:00	1.3	12.8	2,042.7	0.9	6.10	1	1	1
12/29/2022 08:00	1.4	12.2	2,185.5	0.9	6.60	1	1	1
12/29/2022 09:00	1.4	11.9	2,234.1	0.9	6.70	1	1	1
12/29/2022 10:00	1.4	12.3	2,142.2	1.0	8.60	1	1	1
12/29/2022 11:00	1.3	12.9	2,012.8	1.0	8.10	1	1	1
12/29/2022 12:00	1.3	13.0	1,975.6	1.0	7.90	1	1	1
12/29/2022 13:00	1.2	13.1	1,962.0	0.9	5.90	1	1	1
12/29/2022 14:00	1.3	13.0	1,971.1	1.0	7.90	1	1	1
12/29/2022 15:00	1.2	13.0	1,977.5	0.9	5.90	1	1	1
12/29/2022 16:00	1.3	12.6	2,082.3	0.9	6.20	1	1	1
12/29/2022 17:00	1.3	12.3	2,149.3	0.9	6.40	1	1	1
12/29/2022 18:00	1.3	12.6	2,062.6	0.9	6.20	1	1	1
12/29/2022 19:00	1.3	13.1	1,956.5	1.0	7.80	1	1	1
12/29/2022 20:00	1.2	13.1	1,963.5	0.9	5.90	1	1	1
12/29/2022 21:00	1.3	13.0	1,973.9	1.0	7.90	1	1	1
12/29/2022 22:00	1.2	13.0	1,958.1	0.9	5.90	1	1	1
12/29/2022 23:00	1.3	13.1	1,930.3	1.0	7.70	1	1	1
Average/Sum#:	1.3	12.8	2,017.6	0.9	161.30 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,930.3	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,234.1	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	2.9	15.6	627.2	3.2	1.88	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.9	15.6	627.2	3.2	1.88 #	1 #	0 #	0 #
Minimum:	2.9	15.6	627.2	3.2	1.88	0	0	0
Maximum:	2.9	15.6	627.2	3.2	1.88	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	1.7	12.1	2,166.3	1.1	8.70	1	1	1
10/01/2022 01:00	3.0	14.2	1,202.0	2.6	5.76	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2022 12:00	25.8	17.7	308.0	47.6	38.81	1	0	0
10/01/2022 13:00	10.2	17.2	376.4	16.3	22.60	1	0	0
10/01/2022 14:00	14.9	15.5	875.8	16.3	52.50	1	0	0
10/01/2022 15:00	0.3	14.1	1,414.5	0.3	1.40	1	1	0
10/01/2022 16:00	0.8	13.6	1,717.8	0.6	3.40	1	1	1
10/01/2022 17:00	1.6	11.6	2,258.0	1.0	9.00	1	1	1
10/01/2022 18:00	1.7	11.9	2,188.3	1.1	8.80	1	1	1
10/01/2022 19:00	1.5	12.6	2,026.7	1.1	8.10	1	1	1
10/01/2022 20:00	1.7	11.9	2,210.8	1.1	8.80	1	1	1
10/01/2022 21:00	1.4	12.5	1,932.3	1.0	7.70	1	1	1
10/01/2022 22:00	0.7	13.8	1,569.8	0.6	3.10	1	1	0
10/01/2022 23:00	2.2	15.6	630.9	2.4	1.43	1	0	0
Average/Sum#:	4.8	13.9	1,491.3	6.7	180.10 #	14 #	9 #	8 #
Minimum:	0.3	11.6	308.0	0.3	1.40	0	0	0
Maximum:	25.8	17.7	2,258.0	47.6	52.50	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/02/2022 11:00	24.6	17.7	311.4	45.4	34.84	1	0	0
10/02/2022 12:00	8.4	17.2	404.4	13.4	19.80	1	0	0
10/02/2022 13:00	10.0	15.6	880.7	11.1	36.10	1	0	0
10/02/2022 14:00	0.8	13.8	1,730.7	0.7	3.50	1	1	0
10/02/2022 15:00	0.9	13.2	1,719.8	0.7	5.20	1	1	1
10/02/2022 16:00	1.7	12.0	2,184.2	1.1	8.70	1	1	1
10/02/2022 17:00	1.7	11.6	2,265.0	1.1	9.10	1	1	1
10/02/2022 18:00	1.8	11.6	2,270.6	1.1	9.10	1	1	1
10/02/2022 19:00	1.8	11.6	2,272.9	1.1	9.10	1	1	1
10/02/2022 20:00	1.8	11.6	2,274.3	1.1	9.10	1	1	1
10/02/2022 21:00	1.5	12.4	2,098.7	1.0	8.40	1	1	1
10/02/2022 22:00	1.3	12.7	1,912.0	0.9	5.70	1	1	1
10/02/2022 23:00	0.6	13.9	1,550.6	0.5	3.10	1	1	0
Average/Sum#:	4.4	13.5	1,682.7	6.1	161.74 #	13 #	10 #	8 #
Minimum:	0.6	11.6	311.4	0.5	3.10	0	0	0
Maximum:	24.6	17.7	2,274.3	45.4	36.10	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.6	13.9	1,546.4	0.5	3.10	1	1	0
10/03/2022 01:00	0.6	13.9	1,550.3	0.5	3.10	1	1	0
10/03/2022 02:00	0.8	13.8	1,784.2	0.7	3.60	1	1	0
10/03/2022 03:00	0.6	13.9	1,582.9	0.5	3.20	1	1	0
10/03/2022 04:00	0.5	13.9	1,715.7	0.4	3.40	1	1	0
10/03/2022 05:00	0.5	13.9	1,713.6	0.4	3.40	1	1	0
10/03/2022 06:00	0.5	13.9	1,710.7	0.4	3.40	1	1	0
10/03/2022 07:00	0.5	13.9	1,711.1	0.4	3.40	1	1	0
10/03/2022 08:00	0.5	13.9	1,717.3	0.4	3.40	1	1	0
10/03/2022 09:00	0.6	13.9	1,722.1	0.5	3.40	1	1	0
10/03/2022 10:00	0.6	13.9	1,724.5	0.5	3.40	1	1	0
10/03/2022 11:00	0.6	13.9	1,724.7	0.5	3.40	1	1	0
10/03/2022 12:00	0.7	13.9	1,724.6	0.6	3.40	1	1	0
10/03/2022 13:00	0.7	13.9	1,725.3	0.6	3.50	1	1	0
10/03/2022 14:00	0.7	13.9	1,716.6	0.6	3.40	1	1	0
10/03/2022 15:00	0.7	13.8	1,754.9	0.6	3.50	1	1	1
10/03/2022 16:00	1.2	12.5	2,060.1	0.8	6.20	1	1	1
10/03/2022 17:00	1.5	12.0	2,170.1	1.0	8.70	1	1	1
10/03/2022 18:00	1.7	11.8	2,202.2	1.1	8.80	1	1	1
10/03/2022 19:00	1.6	12.0	2,175.9	1.1	8.70	1	1	1
10/03/2022 20:00	1.7	11.9	2,186.8	1.1	8.70	1	1	1
10/03/2022 21:00	1.6	12.0	2,178.8	1.1	8.70	1	1	1
10/03/2022 22:00	1.5	12.2	2,156.6	1.0	8.60	1	1	1
10/03/2022 23:00	1.6	12.1	2,174.0	1.1	8.70	1	1	1
Average/Sum#:	0.9	13.3	1,851.2	0.7	121.10 #	24 #	24 #	9 #
Minimum:	0.5	11.8	1,546.4	0.4	3.10	1	1	0
Maximum:	1.7	13.9	2,202.2	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	1.5	12.2	2,156.2	1.0	8.60	1	1	1
10/04/2022 01:00	1.6	12.2	2,159.9	1.1	8.60	1	1	1
10/04/2022 02:00	1.5	12.2	2,158.6	1.0	8.60	1	1	1
10/04/2022 03:00	1.5	12.1	2,168.6	1.0	8.70	1	1	1
10/04/2022 04:00	1.6	12.1	2,182.7	1.1	8.70	1	1	1
10/04/2022 05:00	1.6	12.0	2,216.4	1.1	8.90	1	1	1
10/04/2022 06:00	1.5	12.3	2,179.8	1.0	8.70	1	1	1
10/04/2022 07:00	1.3	12.7	2,043.5	0.9	6.10	1	1	1
10/04/2022 08:00	0.6	13.8	1,586.2	0.5	3.20	1	1	0
10/04/2022 09:00	0.5	13.9	1,548.5	0.4	3.10	1	1	0
10/04/2022 10:00	0.0	0.0	1,554.2	0.0	0.00	1	1	0
10/04/2022 11:00	0.6	13.9	1,562.4	0.5	3.10	1	1	0
10/04/2022 12:00	0.7	13.9	1,707.0	0.6	3.40	1	1	0
10/04/2022 13:00	0.9	13.8	1,733.0	0.7	5.20	1	1	1
10/04/2022 14:00	1.2	12.7	2,019.5	0.9	6.10	1	1	1
10/04/2022 15:00	1.5	12.1	2,136.1	1.0	8.50	1	1	1
10/04/2022 16:00	1.5	12.1	2,128.5	1.0	8.50	1	1	1
10/04/2022 17:00	1.6	12.1	2,140.4	1.1	8.60	1	1	1
10/04/2022 18:00	1.6	12.0	2,169.9	1.1	8.70	1	1	1
10/04/2022 19:00	1.7	11.9	2,188.2	1.1	8.80	1	1	1
10/04/2022 20:00	1.8	11.7	2,242.8	1.2	9.00	1	1	1
10/04/2022 21:00	1.7	11.9	2,190.4	1.1	8.80	1	1	1
10/04/2022 22:00	1.7	12.0	2,179.1	1.1	8.70	1	1	1
10/04/2022 23:00	1.5	12.2	2,143.7	1.0	8.60	1	1	1
Average/Sum#:	1.4	12.5	2,020.7	0.9	169.20 #	24 #	24 #	19 #
Minimum:	0.5	11.7	1,548.5	0.4	3.10	1	1	0
Maximum:	1.8	13.9	2,242.8	1.2	9.00	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.5	12.2	2,136.6	1.0	8.50	1	1	1
10/05/2022 01:00	1.3	12.8	1,995.6	0.9	6.00	1	1	1
10/05/2022 02:00	1.2	13.0	1,971.2	0.9	5.90	1	1	1
10/05/2022 03:00	1.3	12.5	2,088.5	0.9	6.30	1	1	1
10/05/2022 04:00	1.4	12.3	2,117.7	1.0	8.50	1	1	1
10/05/2022 05:00	1.6	12.0	2,204.8	1.1	8.80	1	1	1
10/05/2022 06:00	1.6	12.1	2,206.4	1.1	8.80	1	1	1
10/05/2022 07:00	1.2	12.9	1,980.3	0.9	5.90	1	1	1
10/05/2022 08:00	0.6	13.9	1,702.3	0.5	3.40	1	1	0
10/05/2022 09:00	0.6	13.9	1,667.6	0.5	3.30	1	1	0
10/05/2022 10:00	0.7	13.9	1,693.9	0.6	3.40	1	1	0
10/05/2022 11:00	0.7	13.9	1,706.3	0.6	3.40	1	1	0
10/05/2022 12:00	0.8	13.8	1,723.0	0.7	3.40	1	1	1
10/05/2022 13:00	1.2	12.5	2,064.2	0.8	6.20	1	1	1
10/05/2022 14:00	1.6	11.9	2,181.4	1.0	8.70	1	1	1
10/05/2022 15:00	1.5	12.1	2,135.0	1.0	8.50	1	1	1
10/05/2022 16:00	1.6	12.0	2,157.2	1.1	8.60	1	1	1
10/05/2022 17:00	1.7	11.8	2,196.1	1.1	8.80	1	1	1
10/05/2022 18:00	1.8	11.7	2,231.0	1.2	8.90	1	1	1
10/05/2022 19:00	1.8	11.7	2,237.6	1.2	9.00	1	1	1
10/05/2022 20:00	1.7	11.9	2,188.3	1.1	8.80	1	1	1
10/05/2022 21:00	1.8	11.7	2,234.5	1.2	8.90	1	1	1
10/05/2022 22:00	1.6	12.1	2,163.4	1.1	8.70	1	1	1
10/05/2022 23:00	1.6	12.1	2,172.8	1.1	8.70	1	1	1
Average/Sum#:	1.4	12.5	2,048.2	0.9	169.40 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,667.6	0.5	3.30	1	1	0
Maximum:	1.8	13.9	2,237.6	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.6	12.2	2,162.3	1.1	8.60	1	1	1
10/06/2022 01:00	1.5	12.1	2,166.4	1.0	8.70	1	1	1
10/06/2022 02:00	1.6	12.1	2,164.4	1.1	8.70	1	1	1
10/06/2022 03:00	1.5	12.2	2,142.9	1.0	8.60	1	1	1
10/06/2022 04:00	1.6	12.0	2,184.4	1.1	8.70	1	1	1
10/06/2022 05:00	1.7	11.8	2,246.2	1.1	9.00	1	1	1
10/06/2022 06:00	1.6	11.9	2,233.3	1.0	8.90	1	1	1
10/06/2022 07:00	1.4	12.3	2,131.1	1.0	8.50	1	1	1
10/06/2022 08:00	1.3	12.5	2,082.8	0.9	6.20	1	1	1
10/06/2022 09:00	1.3	12.6	2,065.4	0.9	6.20	1	1	1
10/06/2022 10:00	1.4	12.5	2,076.7	1.0	8.30	1	1	1
10/06/2022 11:00	1.5	12.3	2,113.6	1.0	8.50	1	1	1
10/06/2022 12:00	1.6	12.1	2,142.5	1.1	8.60	1	1	1
10/06/2022 13:00	1.7	11.9	2,198.7	1.1	8.80	1	1	1
10/06/2022 14:00	1.7	11.8	2,207.0	1.1	8.80	1	1	1
10/06/2022 15:00	1.6	12.0	2,158.9	1.1	8.60	1	1	1
10/06/2022 16:00	1.7	11.9	2,197.5	1.1	8.80	1	1	1
10/06/2022 17:00	1.8	11.7	2,245.6	1.2	9.00	1	1	1
10/06/2022 18:00	1.7	11.7	2,241.8	1.1	9.00	1	1	1
10/06/2022 19:00	1.8	11.7	2,251.9	1.2	9.00	1	1	1
10/06/2022 20:00	1.7	11.7	2,253.7	1.1	9.00	1	1	1
10/06/2022 21:00	1.8	11.8	2,243.5	1.2	9.00	1	1	1
10/06/2022 22:00	1.7	12.0	2,189.6	1.1	8.80	1	1	1
10/06/2022 23:00	1.6	12.1	2,168.9	1.1	8.70	1	1	1
Average/Sum#:	1.6	12.0	2,177.9	1.1	205.00 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,065.4	0.9	6.20	1	1	1
Maximum:	1.8	12.6	2,253.7	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.5	12.3	2,144.9	1.0	8.60	1	1	1
10/07/2022 01:00	1.6	12.2	2,158.5	1.1	8.60	1	1	1
10/07/2022 02:00	1.6	12.3	2,141.1	1.1	8.60	1	1	1
10/07/2022 03:00	1.4	12.4	2,115.0	1.0	8.50	1	1	1
10/07/2022 04:00	1.5	12.2	2,155.3	1.0	8.60	1	1	1
10/07/2022 05:00	1.6	12.1	2,191.5	1.1	8.80	1	1	1
10/07/2022 06:00	1.6	12.1	2,204.8	1.1	8.80	1	1	1
10/07/2022 07:00	1.4	12.4	2,111.6	1.0	8.40	1	1	1
10/07/2022 08:00	1.3	12.7	2,031.6	0.9	6.10	1	1	1
10/07/2022 09:00	1.5	12.3	2,132.5	1.0	8.50	1	1	1
10/07/2022 10:00	1.6	12.3	2,127.2	1.1	8.50	1	1	1
10/07/2022 11:00	1.5	12.3	2,117.0	1.0	8.50	1	1	1
10/07/2022 12:00	1.7	12.0	2,174.6	1.1	8.70	1	1	1
10/07/2022 13:00	1.6	12.1	2,147.2	1.1	8.60	1	1	1
10/07/2022 14:00	1.7	11.9	2,194.6	1.1	8.80	1	1	1
10/07/2022 15:00	1.7	11.8	2,203.8	1.1	8.80	1	1	1
10/07/2022 16:00	1.7	11.9	2,188.4	1.1	8.80	1	1	1
10/07/2022 17:00	1.8	11.7	2,238.4	1.2	9.00	1	1	1
10/07/2022 18:00	1.7	11.7	2,248.1	1.1	9.00	1	1	1
10/07/2022 19:00	1.8	11.7	2,254.3	1.2	9.00	1	1	1
10/07/2022 20:00	1.7	11.7	2,259.1	1.1	9.00	1	1	1
10/07/2022 21:00	1.7	11.7	2,262.1	1.1	9.00	1	1	1
10/07/2022 22:00	1.7	11.7	2,256.4	1.1	9.00	1	1	1
10/07/2022 23:00	1.7	12.0	2,191.4	1.1	8.80	1	1	1
Average/Sum#:	1.6	12.1	2,177.1	1.1	207.00 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,031.6	0.9	6.10	1	1	1
Maximum:	1.8	12.7	2,262.1	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.6	12.1	2,179.0	1.1	8.70	1	1	1
10/08/2022 01:00	1.6	12.1	2,173.7	1.1	8.70	1	1	1
10/08/2022 02:00	1.6	12.2	2,165.8	1.1	8.70	1	1	1
10/08/2022 03:00	1.6	12.1	2,178.8	1.1	8.70	1	1	1
10/08/2022 04:00	1.7	12.1	2,186.4	1.1	8.70	1	1	1
10/08/2022 05:00	1.6	12.2	2,175.0	1.1	8.70	1	1	1
10/08/2022 06:00	1.3	12.6	2,114.0	0.9	6.30	1	1	1
10/08/2022 07:00	0.8	13.7	1,700.8	0.7	3.40	1	1	1
10/08/2022 08:00	0.4	14.0	1,358.1	0.3	1.40	1	1	0
10/08/2022 09:00	0.3	14.1	1,309.6	0.3	1.30	1	1	0
10/08/2022 10:00	0.3	14.1	1,309.0	0.3	1.30	1	1	0
10/08/2022 11:00	0.3	14.1	1,314.2	0.3	1.30	1	1	0
10/08/2022 12:00	0.6	13.9	1,559.1	0.5	3.10	1	1	0
10/08/2022 13:00	0.7	13.9	1,711.4	0.6	3.40	1	1	0
10/08/2022 14:00	0.8	13.8	1,728.5	0.7	3.50	1	1	1
10/08/2022 15:00	1.3	12.3	2,093.4	0.9	6.30	1	1	1
10/08/2022 16:00	1.7	11.8	2,196.4	1.1	8.80	1	1	1
10/08/2022 17:00	1.7	11.8	2,200.9	1.1	8.80	1	1	1
10/08/2022 18:00	1.7	12.0	2,169.3	1.1	8.70	1	1	1
10/08/2022 19:00	1.7	12.0	2,176.3	1.1	8.70	1	1	1
10/08/2022 20:00	1.7	12.0	2,183.4	1.1	8.70	1	1	1
10/08/2022 21:00	1.7	12.0	2,182.8	1.1	8.70	1	1	1
10/08/2022 22:00	1.7	12.1	2,179.0	1.1	8.70	1	1	1
10/08/2022 23:00	1.6	12.2	2,177.1	1.1	8.70	1	1	1
Average/Sum#:	1.3	12.7	1,946.8	0.9	153.30 #	24 #	24 #	18 #
Minimum:	0.3	11.8	1,309.0	0.3	1.30	1	1	0
Maximum:	1.7	14.1	2,200.9	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.6	12.1	2,173.7	1.1	8.70	1	1	1
10/09/2022 01:00	1.6	12.2	2,176.5	1.1	8.70	1	1	1
10/09/2022 02:00	1.5	12.3	2,147.0	1.0	8.60	1	1	1
10/09/2022 03:00	1.5	12.3	2,158.6	1.0	8.60	1	1	1
10/09/2022 04:00	1.5	12.2	2,165.0	1.0	8.70	1	1	1
10/09/2022 05:00	1.5	12.2	2,156.0	1.0	8.60	1	1	1
10/09/2022 06:00	2.8	13.7	1,682.6	2.3	13.50	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2022 14:00	18.1	17.6	384.2	32.4	32.90	1	0	0
10/09/2022 15:00	10.0	14.5	1,309.2	9.2	44.50	1	0	0
10/09/2022 16:00	0.7	13.9	1,714.4	0.6	3.40	1	1	0
10/09/2022 17:00	0.9	13.7	1,764.8	0.7	5.30	1	1	1
10/09/2022 18:00	1.2	12.4	2,079.4	0.8	6.20	1	1	1
10/09/2022 19:00	1.7	11.8	2,207.7	1.1	8.80	1	1	1
10/09/2022 20:00	1.7	12.0	2,185.0	1.1	8.70	1	1	1
10/09/2022 21:00	1.6	12.1	2,173.4	1.1	8.70	1	1	1
10/09/2022 22:00	1.6	12.2	2,156.8	1.1	8.60	1	1	1
10/09/2022 23:00	1.5	12.2	2,148.5	1.0	8.60	1	1	1
Average/Sum#:	3.0	12.9	1,928.4	3.4	201.10 #	17 #	14 #	14 #
Minimum:	0.7	11.8	384.2	0.6	3.40	0	0	0
Maximum:	18.1	17.6	2,207.7	32.4	44.50	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.5	12.3	2,123.4	1.0	8.50	1	1	1
10/10/2022 01:00	1.3	12.5	2,095.3	0.9	6.30	1	1	1
10/10/2022 02:00	1.2	13.0	1,981.4	0.9	5.90	1	1	1
10/10/2022 03:00	1.3	12.5	2,093.7	0.9	6.30	1	1	1
10/10/2022 04:00	1.4	12.4	2,139.2	1.0	8.60	1	1	1
10/10/2022 05:00	1.6	12.0	2,225.5	1.1	8.90	1	1	1
10/10/2022 06:00	1.5	12.1	2,215.7	1.0	8.90	1	1	1
10/10/2022 07:00	0.9	13.4	1,803.1	0.7	5.40	1	1	1
10/10/2022 08:00	0.5	13.9	1,542.0	0.4	3.10	1	1	0
10/10/2022 09:00	0.5	14.0	1,535.7	0.4	3.10	1	1	0
10/10/2022 10:00	0.4	14.1	1,390.1	0.3	1.40	1	1	0
10/10/2022 11:00	0.5	14.0	1,562.7	0.4	3.10	1	1	0
10/10/2022 12:00	0.5	14.1	1,576.8	0.4	3.20	1	1	0
10/10/2022 13:00	0.8	13.9	1,704.6	0.7	3.40	1	1	0
10/10/2022 14:00	0.7	13.9	1,711.9	0.6	3.40	1	1	0
10/10/2022 15:00	0.8	13.9	1,584.5	0.7	3.20	1	1	0
10/10/2022 16:00	1.1	12.8	1,953.3	0.8	5.90	1	1	1
10/10/2022 17:00	1.5	12.0	2,159.8	1.0	8.60	1	1	1
10/10/2022 18:00	1.7	11.9	2,194.5	1.1	8.80	1	1	1
10/10/2022 19:00	1.6	12.0	2,171.3	1.1	8.70	1	1	1
10/10/2022 20:00	1.6	12.1	2,163.2	1.1	8.70	1	1	1
10/10/2022 21:00	1.5	12.3	2,109.3	1.0	8.40	1	1	1
10/10/2022 22:00	1.4	12.5	2,091.9	1.0	8.40	1	1	1
10/10/2022 23:00	1.2	13.0	1,947.6	0.9	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,919.9	0.8	146.00 #	24 #	24 #	16 #
Minimum:	0.4	11.9	1,390.1	0.3	1.40	1	1	0
Maximum:	1.7	14.1	2,225.5	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.5	14.0	1,368.8	0.4	2.70	1	1	0
10/11/2022 01:00	0.3	14.0	1,294.0	0.3	1.30	1	1	0
10/11/2022 02:00	0.3	14.0	1,293.9	0.3	1.30	1	1	0
10/11/2022 03:00	0.3	14.0	1,345.8	0.3	1.30	1	1	0
10/11/2022 04:00	0.4	14.0	1,489.9	0.3	1.50	1	1	0
10/11/2022 05:00	0.3	14.0	1,314.3	0.3	1.30	1	1	0
10/11/2022 06:00	0.3	14.0	1,303.1	0.3	1.30	1	1	0
10/11/2022 07:00	0.3	14.0	1,318.9	0.3	1.30	1	1	0
10/11/2022 08:00	0.6	13.9	1,748.2	0.5	3.50	1	1	0
10/11/2022 09:00	0.5	14.0	1,592.2	0.4	3.20	1	1	0
10/11/2022 10:00	0.9	13.8	1,729.7	0.7	5.20	1	1	0
10/11/2022 11:00	0.8	13.8	1,747.4	0.7	3.50	1	1	0
10/11/2022 12:00	0.7	13.9	1,748.6	0.6	3.50	1	1	0
10/11/2022 13:00	0.7	13.9	1,740.2	0.6	3.50	1	1	0
10/11/2022 14:00	0.7	13.9	1,733.2	0.6	3.50	1	1	0
10/11/2022 15:00	0.7	13.9	1,737.7	0.6	3.50	1	1	0
10/11/2022 16:00	0.8	13.8	1,760.7	0.7	3.50	1	1	0
10/11/2022 17:00	0.9	13.7	1,770.9	0.7	5.30	1	1	0
10/11/2022 18:00	0.9	13.7	1,775.7	0.7	5.30	1	1	1
10/11/2022 19:00	1.2	12.5	2,057.5	0.8	6.20	1	1	1
10/11/2022 20:00	1.4	12.3	2,104.9	1.0	8.40	1	1	1
10/11/2022 21:00	1.5	12.1	2,159.4	1.0	8.60	1	1	1
10/11/2022 22:00	1.4	12.4	2,094.6	1.0	8.40	1	1	1
10/11/2022 23:00	1.2	13.0	1,961.3	0.9	5.90	1	1	1
Average/Sum#:	0.7	13.6	1,674.6	0.6	93.00 #	24 #	24 #	6 #
Minimum:	0.3	12.1	1,293.9	0.3	1.30	1	1	0
Maximum:	1.5	14.0	2,159.4	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	1.2	13.1	1,948.6	0.9	5.80	1	1	1
10/12/2022 01:00	1.1	13.1	1,928.9	0.8	5.80	1	1	1
10/12/2022 02:00	0.5	13.9	1,512.2	0.4	3.00	1	1	0
10/12/2022 03:00	0.5	13.9	1,624.7	0.4	3.20	1	1	0
10/12/2022 04:00	0.7	13.8	1,746.5	0.6	3.50	1	1	0
10/12/2022 05:00	1.2	12.4	2,122.6	0.8	6.40	1	1	1
10/12/2022 06:00	1.6	11.9	2,254.3	1.0	9.00	1	1	1
10/12/2022 07:00	1.6	11.9	2,245.2	1.0	9.00	1	1	1
10/12/2022 08:00	1.6	11.9	2,243.2	1.0	9.00	1	1	1
10/12/2022 09:00	1.7	11.9	2,238.0	1.1	9.00	1	1	1
10/12/2022 10:00	1.6	11.9	2,234.1	1.0	8.90	1	1	1
10/12/2022 11:00	1.7	11.9	2,233.9	1.1	8.90	1	1	1
10/12/2022 12:00	1.7	11.9	2,231.6	1.1	8.90	1	1	1
10/12/2022 13:00	1.7	11.9	2,228.9	1.1	8.90	1	1	1
10/12/2022 14:00	1.7	11.9	2,229.7	1.1	8.90	1	1	1
10/12/2022 15:00	1.8	11.8	2,235.6	1.2	8.90	1	1	1
10/12/2022 16:00	1.8	11.6	2,251.1	1.1	9.00	1	1	1
10/12/2022 17:00	1.8	11.6	2,260.5	1.1	9.00	1	1	1
10/12/2022 18:00	1.7	11.8	2,224.2	1.1	8.90	1	1	1
10/12/2022 19:00	1.5	12.2	2,135.6	1.0	8.50	1	1	1
10/12/2022 20:00	1.6	12.2	2,150.7	1.1	8.60	1	1	1
10/12/2022 21:00	1.5	12.3	2,115.2	1.0	8.50	1	1	1
10/12/2022 22:00	1.4	12.5	2,084.9	1.0	8.30	1	1	1
10/12/2022 23:00	1.2	13.0	1,959.2	0.9	5.90	1	1	1
Average/Sum#:	1.4	12.3	2,101.6	1.0	183.80 #	24 #	24 #	21 #
Minimum:	0.5	11.6	1,512.2	0.4	3.00	1	1	0
Maximum:	1.8	13.9	2,260.5	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.2	13.0	1,956.6	0.9	5.90	1	1	1
10/13/2022 01:00	1.3	12.8	2,000.9	0.9	6.00	1	1	1
10/13/2022 02:00	1.2	13.1	1,947.1	0.9	5.80	1	1	1
10/13/2022 03:00	1.2	13.1	1,959.2	0.9	5.90	1	1	1
10/13/2022 04:00	1.2	13.1	1,939.6	0.9	5.80	1	1	1
10/13/2022 05:00	0.4	13.9	1,307.9	0.3	1.30	1	1	0
10/13/2022 06:00	0.4	13.9	1,308.4	0.3	1.30	1	1	0
10/13/2022 07:00	0.3	14.0	1,308.7	0.3	1.30	1	1	0
10/13/2022 08:00	0.5	13.9	1,486.8	0.4	3.00	1	1	0
10/13/2022 09:00	0.5	13.9	1,537.2	0.4	3.10	1	1	0
10/13/2022 10:00	0.8	13.8	1,712.7	0.7	3.40	1	1	0
10/13/2022 11:00	0.9	13.7	1,794.6	0.7	5.40	1	1	0
10/13/2022 12:00	0.9	13.7	1,790.4	0.7	5.40	1	1	0
10/13/2022 13:00	1.1	13.7	1,784.6	0.9	5.40	1	1	0
10/13/2022 14:00	1.3	13.7	1,779.9	1.1	7.10	1	1	0
10/13/2022 15:00	1.3	13.7	1,777.3	1.1	7.10	1	1	0
10/13/2022 16:00	1.2	13.7	1,779.0	1.0	7.10	1	1	0
10/13/2022 17:00	1.2	13.7	1,779.7	1.0	7.10	1	1	0
10/13/2022 18:00	1.2	13.7	1,784.4	1.0	7.10	1	1	0
10/13/2022 19:00	1.2	13.7	1,788.0	1.0	7.20	1	1	1
10/13/2022 20:00	1.4	12.6	2,057.0	1.0	8.20	1	1	1
10/13/2022 21:00	1.6	12.2	2,156.4	1.1	8.60	1	1	1
10/13/2022 22:00	1.6	12.5	2,080.5	1.1	8.30	1	1	1
10/13/2022 23:00	1.6	12.6	2,070.0	1.1	8.30	1	1	1
Average/Sum#:	1.1	13.4	1,787.0	0.8	135.10 #	24 #	24 #	10 #
Minimum:	0.3	12.2	1,307.9	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,156.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.5	12.7	2,061.1	1.1	8.20	1	1	1
10/14/2022 01:00	1.5	12.6	2,074.7	1.1	8.30	1	1	1
10/14/2022 02:00	1.6	12.6	2,074.6	1.1	8.30	1	1	1
10/14/2022 03:00	1.6	12.6	2,071.6	1.1	8.30	1	1	1
10/14/2022 04:00	1.6	12.4	2,112.7	1.1	8.50	1	1	1
10/14/2022 05:00	1.7	11.8	2,260.2	1.1	9.00	1	1	1
10/14/2022 06:00	1.6	11.8	2,253.5	1.0	9.00	1	1	1
10/14/2022 07:00	1.7	11.9	2,225.2	1.1	8.90	1	1	1
10/14/2022 08:00	1.6	12.7	2,025.4	1.2	8.10	1	1	1
10/14/2022 09:00	1.5	13.0	1,963.8	1.1	7.90	1	1	1
10/14/2022 10:00	1.6	12.9	1,974.2	1.2	7.90	1	1	1
10/14/2022 11:00	1.6	12.8	1,981.1	1.2	7.90	1	1	1
10/14/2022 12:00	1.6	12.8	1,989.4	1.2	8.00	1	1	1
10/14/2022 13:00	1.6	12.7	1,999.2	1.2	8.00	1	1	1
10/14/2022 14:00	1.7	12.3	2,098.0	1.2	8.40	1	1	1
10/14/2022 15:00	1.7	12.2	2,127.4	1.2	8.50	1	1	1
10/14/2022 16:00	1.7	12.2	2,119.3	1.2	8.50	1	1	1
10/14/2022 17:00	1.7	11.8	2,207.4	1.1	8.80	1	1	1
10/14/2022 18:00	1.7	12.1	2,149.5	1.1	8.60	1	1	1
10/14/2022 19:00	1.7	12.2	2,120.7	1.2	8.50	1	1	1
10/14/2022 20:00	1.7	12.2	2,129.6	1.2	8.50	1	1	1
10/14/2022 21:00	1.6	12.3	2,120.9	1.1	8.50	1	1	1
10/14/2022 22:00	1.6	12.4	2,093.7	1.1	8.40	1	1	1
10/14/2022 23:00	2.8	14.0	1,326.6	2.4	6.55	1	0	1
Average/Sum#:	1.7	12.5	2,065.0	1.2	199.55 #	24 #	23 #	24 #
Minimum:	1.5	11.8	1,326.6	1.0	6.55	1	0	1
Maximum:	2.8	14.0	2,260.2	2.4	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2022 17:00	27.1	17.7	328.5	50.0	44.09	1	0	0
10/16/2022 18:00	16.7	16.5	574.4	22.4	47.10	1	0	0
10/16/2022 19:00	12.3	15.1	965.7	12.5	44.40	1	0	0
10/16/2022 20:00	1.1	13.8	1,770.5	0.9	5.30	1	1	0
10/16/2022 21:00	1.2	13.8	1,686.0	1.0	6.70	1	1	0
10/16/2022 22:00	1.0	13.9	1,594.4	0.8	4.80	1	1	0
10/16/2022 23:00	1.2	13.8	1,803.8	1.0	7.20	1	1	0
Average/Sum#:	8.7	14.9	1,246.2	12.7	159.59 #	7 #	4 #	0 #
Minimum:	1.0	13.8	328.5	0.8	4.80	0	0	0
Maximum:	27.1	17.7	1,803.8	50.0	47.10	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	1.0	13.9	1,642.9	0.8	4.90	1	1	0
10/17/2022 01:00	1.0	13.9	1,698.6	0.8	5.10	1	1	0
10/17/2022 02:00	0.9	13.9	1,702.5	0.8	5.10	1	1	0
10/17/2022 03:00	1.1	13.8	1,794.9	0.9	5.40	1	1	1
10/17/2022 04:00	1.5	12.7	2,058.2	1.1	8.20	1	1	1
10/17/2022 05:00	1.6	12.2	2,160.0	1.1	8.60	1	1	1
10/17/2022 06:00	1.6	12.3	2,145.3	1.1	8.60	1	1	1
10/17/2022 07:00	1.6	12.5	2,099.6	1.1	8.40	1	1	1
10/17/2022 08:00	1.0	13.8	1,683.3	0.8	5.00	1	1	1
10/17/2022 09:00	0.9	13.9	1,632.3	0.8	4.90	1	1	0
10/17/2022 10:00	0.9	14.0	1,522.6	0.8	4.60	1	1	0
10/17/2022 11:00	0.9	14.0	1,609.1	0.8	4.80	1	1	0
10/17/2022 12:00	0.9	14.0	1,506.6	0.8	4.50	1	1	0
10/17/2022 13:00	0.9	14.0	1,501.4	0.8	4.50	1	1	0
10/17/2022 14:00	0.9	14.0	1,657.9	0.8	5.00	1	1	0
10/17/2022 15:00	1.1	13.8	1,696.8	0.9	5.10	1	1	1
10/17/2022 16:00	1.5	12.5	2,079.8	1.1	8.30	1	1	1
10/17/2022 17:00	1.7	11.8	2,230.9	1.1	8.90	1	1	1
10/17/2022 18:00	1.7	11.8	2,246.4	1.1	9.00	1	1	1
10/17/2022 19:00	1.7	11.9	2,223.6	1.1	8.90	1	1	1
10/17/2022 20:00	1.7	11.9	2,229.9	1.1	8.90	1	1	1
10/17/2022 21:00	1.7	11.8	2,239.7	1.1	9.00	1	1	1
10/17/2022 22:00	1.7	12.2	2,177.2	1.2	8.70	1	1	1
10/17/2022 23:00	1.7	12.2	2,183.6	1.2	8.70	1	1	1
Average/Sum#:	1.3	13.0	1,905.1	1.0	163.10 #	24 #	24 #	15 #
Minimum:	0.9	11.8	1,501.4	0.8	4.50	1	1	0
Maximum:	1.7	14.0	2,246.4	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.6	12.2	2,179.1	1.1	8.70	1	1	1
10/18/2022 01:00	1.7	12.3	2,170.9	1.2	8.70	1	1	1
10/18/2022 02:00	1.6	12.2	2,170.7	1.1	8.70	1	1	1
10/18/2022 03:00	1.6	12.1	2,176.9	1.1	8.70	1	1	1
10/18/2022 04:00	1.6	12.1	2,177.4	1.1	8.70	1	1	1
10/18/2022 05:00	1.7	12.2	2,182.6	1.2	8.70	1	1	1
10/18/2022 06:00	1.7	12.3	2,168.2	1.2	8.70	1	1	1
10/18/2022 07:00	1.6	12.3	2,166.7	1.1	8.70	1	1	1
10/18/2022 08:00	1.6	12.3	2,171.0	1.1	8.70	1	1	1
10/18/2022 09:00	1.6	12.4	2,155.8	1.1	8.60	1	1	1
10/18/2022 10:00	1.6	12.4	2,119.5	1.1	8.50	1	1	1
10/18/2022 11:00	1.6	12.5	2,098.2	1.1	8.40	1	1	1
10/18/2022 12:00	1.6	12.5	2,098.2	1.1	8.40	1	1	1
10/18/2022 13:00	1.6	12.5	2,102.8	1.1	8.40	1	1	1
10/18/2022 14:00	1.6	12.4	2,107.4	1.1	8.40	1	1	1
10/18/2022 15:00	1.6	12.3	2,134.7	1.1	8.50	1	1	1
10/18/2022 16:00	1.7	11.9	2,216.3	1.1	8.90	1	1	1
10/18/2022 17:00	1.7	12.1	2,188.4	1.1	8.80	1	1	1
10/18/2022 18:00	1.7	11.9	2,231.8	1.1	8.90	1	1	1
10/18/2022 19:00	1.7	11.8	2,253.5	1.1	9.00	1	1	1
10/18/2022 20:00	1.7	11.8	2,259.4	1.1	9.00	1	1	1
10/18/2022 21:00	1.7	11.8	2,259.3	1.1	9.00	1	1	1
10/18/2022 22:00	1.7	12.1	2,195.6	1.1	8.80	1	1	1
10/18/2022 23:00	1.7	12.1	2,192.8	1.1	8.80	1	1	1
Average/Sum#:	1.6	12.2	2,174.1	1.1	208.70 #	24 #	24 #	24 #
Minimum:	1.6	11.8	2,098.2	1.1	8.40	1	1	1
Maximum:	1.7	12.5	2,259.4	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	1.6	12.2	2,182.0	1.1	8.70	1	1	1
10/19/2022 01:00	1.6	12.5	2,136.3	1.1	8.50	1	1	1
10/19/2022 02:00	1.6	12.6	2,103.7	1.1	8.40	1	1	1
10/19/2022 03:00	1.6	12.5	2,144.5	1.1	8.60	1	1	1
10/19/2022 04:00	1.6	12.3	2,188.0	1.1	8.80	1	1	1
10/19/2022 05:00	1.7	12.0	2,237.9	1.1	9.00	1	1	1
10/19/2022 06:00	1.6	12.2	2,213.4	1.1	8.90	1	1	1
10/19/2022 07:00	1.6	12.4	2,148.6	1.1	8.60	1	1	1
10/19/2022 08:00	1.6	12.5	2,138.1	1.1	8.60	1	1	1
10/19/2022 09:00	1.6	12.6	2,094.9	1.1	8.40	1	1	1
10/19/2022 10:00	1.6	12.6	2,079.5	1.1	8.30	1	1	1
10/19/2022 11:00	1.6	12.4	2,110.0	1.1	8.40	1	1	1
10/19/2022 12:00	1.6	12.3	2,130.2	1.1	8.50	1	1	1
10/19/2022 13:00	1.6	12.2	2,149.0	1.1	8.60	1	1	1
10/19/2022 14:00	1.7	12.2	2,141.4	1.2	8.60	1	1	1
10/19/2022 15:00	1.7	12.0	2,178.1	1.1	8.70	1	1	1
10/19/2022 16:00	1.7	12.0	2,194.2	1.1	8.80	1	1	1
10/19/2022 17:00	1.6	12.3	2,123.6	1.1	8.50	1	1	1
10/19/2022 18:00	1.6	12.4	2,099.3	1.1	8.40	1	1	1
10/19/2022 19:00	1.6	12.4	2,108.5	1.1	8.40	1	1	1
10/19/2022 20:00	1.6	12.3	2,147.1	1.1	8.60	1	1	1
10/19/2022 21:00	1.6	12.5	2,114.2	1.1	8.50	1	1	1
10/19/2022 22:00	1.6	12.6	2,087.5	1.1	8.40	1	1	1
10/19/2022 23:00	1.6	12.5	2,105.2	1.1	8.40	1	1	1
Average/Sum#:	1.6	12.4	2,139.8	1.1	205.60 #	24 #	24 #	24 #
Minimum:	1.6	12.0	2,079.5	1.1	8.30	1	1	1
Maximum:	1.7	12.6	2,237.9	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.6	12.5	2,124.0	1.1	8.50	1	1	1
10/20/2022 01:00	1.6	12.6	2,087.9	1.1	8.40	1	1	1
10/20/2022 02:00	1.6	12.6	2,078.6	1.1	8.30	1	1	1
10/20/2022 03:00	1.6	12.6	2,089.3	1.1	8.40	1	1	1
10/20/2022 04:00	1.6	12.5	2,135.5	1.1	8.50	1	1	1
10/20/2022 05:00	1.7	12.1	2,217.9	1.1	8.90	1	1	1
10/20/2022 06:00	1.5	12.3	2,191.7	1.0	8.80	1	1	1
10/20/2022 07:00	1.5	12.8	2,069.5	1.1	8.30	1	1	1
10/20/2022 08:00	1.6	12.8	2,056.4	1.2	8.20	1	1	1
10/20/2022 09:00	1.6	12.7	2,066.1	1.2	8.30	1	1	1
10/20/2022 10:00	1.6	12.7	2,060.8	1.2	8.20	1	1	1
10/20/2022 11:00	1.6	12.5	2,079.4	1.1	8.30	1	1	1
10/20/2022 12:00	1.6	12.5	2,079.4	1.1	8.30	1	1	1
10/20/2022 13:00	1.6	12.4	2,099.7	1.1	8.40	1	1	1
10/20/2022 14:00	1.6	12.3	2,121.0	1.1	8.50	1	1	1
10/20/2022 15:00	1.6	12.2	2,147.2	1.1	8.60	1	1	1
10/20/2022 16:00	1.7	11.7	2,241.0	1.1	9.00	1	1	1
10/20/2022 17:00	1.7	12.0	2,178.6	1.1	8.70	1	1	1
10/20/2022 18:00	1.7	11.9	2,212.5	1.1	8.90	1	1	1
10/20/2022 19:00	1.6	12.3	2,107.9	1.1	8.40	1	1	1
10/20/2022 20:00	1.6	12.4	2,104.9	1.1	8.40	1	1	1
10/20/2022 21:00	1.6	12.6	2,083.3	1.1	8.30	1	1	1
10/20/2022 22:00	1.6	12.6	2,083.3	1.1	8.30	1	1	1
10/20/2022 23:00	1.6	12.4	2,136.7	1.1	8.50	1	1	1
Average/Sum#:	1.6	12.4	2,118.9	1.1	203.40 #	24 #	24 #	24 #
Minimum:	1.5	11.7	2,056.4	1.0	8.20	1	1	1
Maximum:	1.7	12.8	2,241.0	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	1.5	12.9	1,988.0	1.1	8.00	1	1	1
10/21/2022 01:00	1.0	14.0	1,577.0	0.9	4.70	1	1	0
10/21/2022 02:00	1.0	13.9	1,586.8	0.8	4.80	1	1	0
10/21/2022 03:00	0.9	13.9	1,543.4	0.8	4.60	1	1	0
10/21/2022 04:00	0.9	14.0	1,696.1	0.8	5.10	1	1	0
10/21/2022 05:00	0.9	14.0	1,698.2	0.8	5.10	1	1	0
10/21/2022 06:00	0.8	14.0	1,598.5	0.7	4.80	1	1	0
10/21/2022 07:00	0.9	14.0	1,668.5	0.8	5.00	1	1	0
10/21/2022 08:00	0.9	14.0	1,704.9	0.8	5.10	1	1	0
10/21/2022 09:00	0.9	14.0	1,708.4	0.8	5.10	1	1	0
10/21/2022 10:00	0.9	14.0	1,706.9	0.8	5.10	1	1	0
10/21/2022 11:00	0.9	14.0	1,671.9	0.8	5.00	1	1	0
10/21/2022 12:00	1.1	14.0	1,648.8	0.9	4.90	1	1	0
10/21/2022 13:00	1.0	14.0	1,624.1	0.9	4.90	1	1	0
10/21/2022 14:00	1.1	13.9	1,681.0	0.9	5.00	1	1	0
10/21/2022 15:00	1.0	13.9	1,556.4	0.8	4.70	1	1	1
10/21/2022 16:00	1.6	12.4	2,095.8	1.1	8.40	1	1	1
10/21/2022 17:00	1.7	12.0	2,180.2	1.1	8.70	1	1	1
10/21/2022 18:00	1.7	12.2	2,136.5	1.2	8.50	1	1	1
10/21/2022 19:00	1.6	12.4	2,098.4	1.1	8.40	1	1	1
10/21/2022 20:00	1.7	12.3	2,116.7	1.2	8.50	1	1	1
10/21/2022 21:00	1.7	12.0	2,176.0	1.1	8.70	1	1	1
10/21/2022 22:00	2.8	14.3	1,201.6	2.5	5.62	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.5	1,768.0	1.0	138.72 #	23 #	22 #	9 #
Minimum:	0.8	12.0	1,201.6	0.7	4.60	0	0	0
Maximum:	2.8	14.3	2,180.2	2.5	8.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2022 20:00	29.9	17.8	297.2	56.9	44.93	1	0	0
10/23/2022 21:00	14.6	17.3	370.7	23.9	32.60	1	0	0
10/23/2022 22:00	12.7	15.9	787.1	15.0	43.30	1	0	0
10/23/2022 23:00	0.6	14.1	1,353.7	0.5	2.70	1	1	0
Average/Sum#:	14.5	16.3	702.2	24.1	123.53 #	4 #	1 #	0 #
Minimum:	0.6	14.1	297.2	0.5	2.70	0	0	0
Maximum:	29.9	17.8	1,353.7	56.9	44.93	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.7	14.1	1,368.5	0.6	2.70	1	1	0
10/24/2022 01:00	0.7	14.1	1,359.7	0.6	2.70	1	1	0
10/24/2022 02:00	0.7	14.1	1,359.6	0.6	2.70	1	1	0
10/24/2022 03:00	0.7	14.1	1,359.6	0.6	2.70	1	1	0
10/24/2022 04:00	1.0	13.9	1,649.1	0.8	4.90	1	1	0
10/24/2022 05:00	1.1	13.8	1,820.4	0.9	5.50	1	1	0
10/24/2022 06:00	1.2	13.8	1,821.7	1.0	7.30	1	1	0
10/24/2022 07:00	1.1	13.8	1,819.3	0.9	5.50	1	1	0
10/24/2022 08:00	1.2	13.9	1,816.0	1.0	7.30	1	1	0
10/24/2022 09:00	1.1	13.9	1,793.7	0.9	5.40	1	1	0
10/24/2022 10:00	1.2	13.8	1,841.1	1.0	7.40	1	1	0
10/24/2022 11:00	1.2	13.8	1,831.5	1.0	7.30	1	1	0
10/24/2022 12:00	0.9	13.9	1,769.6	0.8	5.30	1	1	0
10/24/2022 13:00	0.9	13.9	1,746.6	0.8	5.20	1	1	0
10/24/2022 14:00	2.2	15.1	1,013.9	2.2	3.40	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	14.0	1,624.7	0.9	75.30 #	15 #	14 #	0 #
Minimum:	0.7	13.8	1,013.9	0.6	2.70	0	0	0
Maximum:	2.2	15.1	1,841.1	2.2	7.40	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/30/2022 19:00	10.7	18.9	164.5	31.6	3.82	1	0	0
10/30/2022 20:00	29.2	17.3	372.9	47.9	65.60	1	0	0
10/30/2022 21:00	13.4	16.8	562.7	19.3	40.00	1	0	0
10/30/2022 22:00	15.3	16.0	878.4	18.4	59.70	1	0	0
10/30/2022 23:00	1.0	13.8	1,773.4	0.8	5.30	1	1	0
Average/Sum#:	13.9	16.6	750.4	23.6	174.42 #	5 #	1 #	0 #
Minimum:	1.0	13.8	164.5	0.8	3.82	0	0	0
Maximum:	29.2	18.9	1,773.4	47.9	65.60	1	1	0
%SI	79.17	79.17	79.17	79.17	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.9	14.0	1,565.8	0.8	4.70	1	1	0
10/31/2022 01:00	1.1	13.9	1,787.0	0.9	5.40	1	1	0
10/31/2022 02:00	0.9	14.0	1,671.4	0.8	5.00	1	1	0
10/31/2022 03:00	0.9	14.0	1,708.8	0.8	5.10	1	1	0
10/31/2022 04:00	0.9	14.0	1,723.8	0.8	5.20	1	1	0
10/31/2022 05:00	0.8	14.0	1,708.1	0.7	5.10	1	1	0
10/31/2022 06:00	0.8	14.0	1,699.3	0.7	5.10	1	1	0
10/31/2022 07:00	0.8	14.0	1,700.7	0.7	5.10	1	1	0
10/31/2022 08:00	0.8	14.0	1,704.0	0.7	5.10	1	1	0
10/31/2022 09:00	0.8	14.0	1,705.2	0.7	5.10	1	1	0
10/31/2022 10:00	0.9	14.0	1,708.1	0.8	5.10	1	1	0
10/31/2022 11:00	0.9	14.0	1,687.1	0.8	5.10	1	1	0
10/31/2022 12:00	0.9	14.0	1,677.9	0.8	5.00	1	1	0
10/31/2022 13:00	0.9	14.0	1,691.9	0.8	5.10	1	1	0
10/31/2022 14:00	1.1	13.9	1,760.4	0.9	5.30	1	1	1
10/31/2022 15:00	1.5	12.6	2,079.3	1.1	8.30	1	1	1
10/31/2022 16:00	1.6	12.5	2,105.8	1.1	8.40	1	1	1
10/31/2022 17:00	1.6	12.6	2,078.5	1.1	8.30	1	1	1
10/31/2022 18:00	1.6	12.6	2,081.3	1.1	8.30	1	1	1
10/31/2022 19:00	1.6	12.5	2,104.0	1.1	8.40	1	1	1
10/31/2022 20:00	1.6	12.5	2,108.1	1.1	8.40	1	1	1
10/31/2022 21:00	1.6	12.3	2,163.0	1.1	8.70	1	1	1
10/31/2022 22:00	1.6	12.5	2,119.3	1.1	8.50	1	1	1
10/31/2022 23:00	1.6	12.3	2,146.3	1.1	8.60	1	1	1
Average/Sum#:	1.2	13.4	1,853.5	0.9	152.40 #	24 #	24 #	10 #
Minimum:	0.8	12.3	1,565.8	0.7	4.70	1	1	0
Maximum:	1.6	14.0	2,163.0	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.6	12.4	2,163.8	1.1	8.70	1	1	1
11/01/2022 01:00	1.6	12.4	2,153.2	1.1	8.60	1	1	1
11/01/2022 02:00	1.6	12.4	2,162.1	1.1	8.60	1	1	1
11/01/2022 03:00	1.6	12.4	2,163.5	1.1	8.70	1	1	1
11/01/2022 04:00	1.6	12.4	2,167.9	1.1	8.70	1	1	1
11/01/2022 05:00	1.6	12.4	2,167.4	1.1	8.70	1	1	1
11/01/2022 06:00	1.7	12.1	2,232.9	1.1	8.90	1	1	1
11/01/2022 07:00	1.7	12.3	2,179.4	1.2	8.70	1	1	1
11/01/2022 08:00	1.7	12.0	2,231.6	1.1	8.90	1	1	1
11/01/2022 09:00	1.6	12.4	2,116.2	1.1	8.50	1	1	1
11/01/2022 10:00	1.6	12.5	2,121.2	1.1	8.50	1	1	1
11/01/2022 11:00	1.6	12.2	2,178.7	1.1	8.70	1	1	1
11/01/2022 12:00	1.6	12.2	2,182.8	1.1	8.70	1	1	1
11/01/2022 13:00	1.6	12.3	2,169.2	1.1	8.70	1	1	1
11/01/2022 14:00	1.5	12.6	2,083.1	1.1	8.30	1	1	1
11/01/2022 15:00	1.6	12.7	2,094.6	1.2	8.40	1	1	1
11/01/2022 16:00	1.7	12.2	2,225.8	1.2	8.90	1	1	1
11/01/2022 17:00	1.7	11.9	2,292.1	1.1	9.20	1	1	1
11/01/2022 18:00	1.6	12.3	2,192.0	1.1	8.80	1	1	1
11/01/2022 19:00	1.6	12.5	2,163.6	1.1	8.70	1	1	1
11/01/2022 20:00	1.6	12.3	2,201.7	1.1	8.80	1	1	1
11/01/2022 21:00	1.6	12.8	2,080.8	1.2	8.30	1	1	1
11/01/2022 22:00	1.4	12.9	2,070.4	1.0	8.30	1	1	1
11/01/2022 23:00	1.2	13.4	1,845.9	0.9	5.50	1	1	1
Average/Sum#:	1.6	12.4	2,151.7	1.1	204.80 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,845.9	0.9	5.50	1	1	1
Maximum:	1.7	13.4	2,292.1	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.6	14.1	1,347.9	0.5	2.70	1	1	0
11/02/2022 01:00	0.8	14.0	1,630.5	0.7	4.90	1	1	0
11/02/2022 02:00	0.8	14.0	1,698.9	0.7	5.10	1	1	0
11/02/2022 03:00	0.6	14.0	1,348.8	0.5	2.70	1	1	0
11/02/2022 04:00	0.9	14.0	1,665.7	0.8	5.00	1	1	0
11/02/2022 05:00	1.1	13.5	1,907.9	0.9	5.70	1	1	1
11/02/2022 06:00	1.4	12.7	2,175.1	1.0	8.70	1	1	1
11/02/2022 07:00	1.5	12.8	2,135.9	1.1	8.50	1	1	1
11/02/2022 08:00	1.4	13.1	2,040.3	1.1	8.20	1	1	1
11/02/2022 09:00	0.9	14.0	1,710.1	0.8	5.10	1	1	0
11/02/2022 10:00	0.8	14.0	1,543.3	0.7	4.60	1	1	0
11/02/2022 11:00	0.9	14.0	1,672.4	0.8	5.00	1	1	0
11/02/2022 12:00	0.8	14.0	1,549.7	0.7	4.60	1	1	0
11/02/2022 13:00	0.8	14.0	1,552.9	0.7	4.70	1	1	0
11/02/2022 14:00	0.8	14.0	1,535.2	0.7	4.60	1	1	0
11/02/2022 15:00	1.0	14.0	1,604.0	0.9	4.80	1	1	1
11/02/2022 16:00	1.5	12.8	2,092.6	1.1	8.40	1	1	1
11/02/2022 17:00	1.6	12.5	2,182.8	1.1	8.70	1	1	1
11/02/2022 18:00	1.6	12.5	2,177.3	1.1	8.70	1	1	1
11/02/2022 19:00	1.6	12.5	2,175.0	1.1	8.70	1	1	1
11/02/2022 20:00	1.6	12.6	2,175.1	1.1	8.70	1	1	1
11/02/2022 21:00	1.6	12.6	2,157.6	1.1	8.60	1	1	1
11/02/2022 22:00	1.6	12.6	2,164.2	1.1	8.70	1	1	1
11/02/2022 23:00	1.6	12.6	2,177.5	1.1	8.70	1	1	1
Average/Sum#:	1.2	13.4	1,850.9	0.9	154.10 #	24 #	24 #	13 #
Minimum:	0.6	12.5	1,347.9	0.5	2.70	1	1	0
Maximum:	1.6	14.1	2,182.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.6	12.6	2,169.0	1.1	8.70	1	1	1
11/03/2022 01:00	1.6	12.7	2,153.0	1.2	8.60	1	1	1
11/03/2022 02:00	1.6	12.5	2,194.3	1.1	8.80	1	1	1
11/03/2022 03:00	1.6	12.3	2,234.1	1.1	8.90	1	1	1
11/03/2022 04:00	1.6	12.6	2,163.9	1.1	8.70	1	1	1
11/03/2022 05:00	1.6	12.6	2,166.0	1.1	8.70	1	1	1
11/03/2022 06:00	1.3	12.4	2,231.2	0.9	6.70	1	1	1
11/03/2022 07:00	1.5	12.8	2,110.9	1.1	8.40	1	1	1
11/03/2022 08:00	0.8	14.1	1,456.2	0.7	4.40	1	1	0
11/03/2022 09:00	0.8	14.0	1,559.4	0.7	4.70	1	1	0
11/03/2022 10:00	0.8	14.0	1,574.2	0.7	4.70	1	1	0
11/03/2022 11:00	0.8	14.0	1,570.2	0.7	4.70	1	1	0
11/03/2022 12:00	0.8	14.0	1,579.0	0.7	4.70	1	1	0
11/03/2022 13:00	0.8	14.1	1,487.4	0.7	4.50	1	1	0
11/03/2022 14:00	0.8	14.1	1,553.3	0.7	4.70	1	1	0
11/03/2022 15:00	1.0	14.0	1,771.8	0.9	5.30	1	1	1
11/03/2022 16:00	1.5	12.8	2,084.1	1.1	8.30	1	1	1
11/03/2022 17:00	1.6	12.5	2,162.5	1.1	8.70	1	1	1
11/03/2022 18:00	1.6	12.5	2,175.5	1.1	8.70	1	1	1
11/03/2022 19:00	1.6	12.5	2,174.2	1.1	8.70	1	1	1
11/03/2022 20:00	1.5	12.5	2,163.4	1.1	8.70	1	1	1
11/03/2022 21:00	1.6	12.5	2,161.9	1.1	8.60	1	1	1
11/03/2022 22:00	1.6	12.5	2,161.6	1.1	8.60	1	1	1
11/03/2022 23:00	1.6	12.4	2,201.2	1.1	8.80	1	1	1
Average/Sum#:	1.3	13.0	1,969.1	1.0	174.30 #	24 #	24 #	17 #
Minimum:	0.8	12.3	1,456.2	0.7	4.40	1	1	0
Maximum:	1.6	14.1	2,234.1	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.5	12.7	2,139.4	1.1	8.60	1	1	1
11/04/2022 01:00	1.6	12.7	2,120.0	1.2	8.50	1	1	1
11/04/2022 02:00	1.5	12.9	2,069.1	1.1	8.30	1	1	1
11/04/2022 03:00	1.5	12.9	2,071.1	1.1	8.30	1	1	1
11/04/2022 04:00	1.6	12.7	2,149.6	1.2	8.60	1	1	1
11/04/2022 05:00	1.6	12.3	2,242.1	1.1	9.00	1	1	1
11/04/2022 06:00	1.5	12.6	2,177.1	1.1	8.70	1	1	1
11/04/2022 07:00	1.4	13.0	2,059.9	1.0	8.20	1	1	1
11/04/2022 08:00	0.8	14.0	1,718.3	0.7	5.20	1	1	1
11/04/2022 09:00	0.8	14.0	1,552.2	0.7	4.70	1	1	0
11/04/2022 10:00	0.7	14.1	1,390.6	0.6	2.80	1	1	0
11/04/2022 11:00	0.7	14.1	1,319.4	0.6	2.60	1	1	0
11/04/2022 12:00	0.7	14.1	1,316.8	0.6	2.60	1	1	0
11/04/2022 13:00	0.7	14.1	1,317.6	0.6	2.60	1	1	0
11/04/2022 14:00	0.8	14.1	1,398.3	0.7	4.20	1	1	0
11/04/2022 15:00	1.0	13.9	1,629.0	0.8	4.90	1	1	1
11/04/2022 16:00	1.6	12.7	2,105.1	1.2	8.40	1	1	1
11/04/2022 17:00	1.6	12.5	2,145.5	1.1	8.60	1	1	1
11/04/2022 18:00	1.5	12.8	2,089.4	1.1	8.40	1	1	1
11/04/2022 19:00	1.6	12.8	2,086.7	1.2	8.30	1	1	1
11/04/2022 20:00	1.5	12.8	2,076.1	1.1	8.30	1	1	1
11/04/2022 21:00	1.6	12.8	2,074.7	1.2	8.30	1	1	1
11/04/2022 22:00	1.5	12.8	2,082.6	1.1	8.30	1	1	1
11/04/2022 23:00	1.3	13.3	1,970.2	1.0	7.90	1	1	1
Average/Sum#:	1.3	13.2	1,887.5	1.0	164.30 #	24 #	24 #	18 #
Minimum:	0.7	12.3	1,316.8	0.6	2.60	1	1	0
Maximum:	1.6	14.1	2,242.1	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	1.3	13.3	1,965.0	1.0	7.90	1	1	1
11/05/2022 01:00	1.3	13.3	1,965.4	1.0	7.90	1	1	1
11/05/2022 02:00	1.2	13.3	1,965.9	0.9	5.90	1	1	1
11/05/2022 03:00	1.3	13.3	1,965.1	1.0	7.90	1	1	1
11/05/2022 04:00	1.3	13.3	1,973.7	1.0	7.90	1	1	1
11/05/2022 05:00	1.3	13.3	1,978.5	1.0	7.90	1	1	1
11/05/2022 06:00	1.4	13.3	1,948.0	1.1	7.80	1	1	1
11/05/2022 07:00	7.3	15.9	568.2	8.6	4.19	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	13.6	1,791.2	2.0	57.39 #	8 #	7 #	7 #
Minimum:	1.2	13.3	568.2	0.9	4.19	0	0	0
Maximum:	7.3	15.9	1,978.5	8.6	7.90	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 09:00	21.3	18.2	259.0	46.5	15.51	1	0	0
11/06/2022 10:00	18.5	17.4	380.5	31.2	43.80	1	0	0
11/06/2022 11:00	12.6	15.7	828.7	14.3	43.90	1	0	0
11/06/2022 12:00	0.7	14.0	1,401.7	0.6	2.80	1	1	0
11/06/2022 13:00	0.9	14.0	1,533.1	0.8	4.60	1	1	0
11/06/2022 14:00	1.1	13.9	1,606.7	0.9	4.80	1	1	0
11/06/2022 15:00	1.6	12.9	1,957.5	1.2	7.80	1	1	1
11/06/2022 16:00	1.7	11.8	2,286.9	1.1	9.10	1	1	1
11/06/2022 17:00	1.7	11.7	2,303.5	1.1	9.20	1	1	1
11/06/2022 18:00	1.5	12.9	2,010.4	1.1	8.00	1	1	1
11/06/2022 19:00	1.5	13.2	1,964.3	1.1	7.90	1	1	1
11/06/2022 20:00	1.5	13.1	1,989.1	1.1	8.00	1	1	1
11/06/2022 21:00	2.0	13.3	1,677.6	1.6	9.80	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.1	14.0	1,553.8	7.9	175.21 #	13 #	9 #	7 #
Minimum:	0.7	11.7	259.0	0.6	2.80	0	0	0
Maximum:	21.3	18.2	2,303.5	46.5	43.90	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	2.6	18.1	314.8	5.5	2.84	1	0	0
11/07/2022 01:00	10.4	15.3	1,013.6	11.0	40.50	1	0	0
11/07/2022 02:00	0.8	14.0	1,566.8	0.7	4.70	1	1	0
11/07/2022 03:00	0.9	14.0	1,619.9	0.8	4.90	1	1	0
11/07/2022 04:00	0.9	14.0	1,676.5	0.8	5.00	1	1	0
11/07/2022 05:00	1.0	13.9	1,708.4	0.8	5.10	1	1	0
11/07/2022 06:00	1.4	12.9	2,008.4	1.0	8.00	1	1	1
11/07/2022 07:00	1.7	12.2	2,239.0	1.2	9.00	1	1	1
11/07/2022 08:00	1.4	13.2	1,992.4	1.1	8.00	1	1	1
11/07/2022 09:00	1.4	13.2	1,975.3	1.1	7.90	1	1	1
11/07/2022 10:00	1.5	13.2	1,964.7	1.1	7.90	1	1	1
11/07/2022 11:00	1.5	13.2	1,962.6	1.1	7.90	1	1	1
11/07/2022 12:00	1.5	13.2	1,963.8	1.1	7.90	1	1	1
11/07/2022 13:00	1.4	13.2	1,962.7	1.1	7.90	1	1	1
11/07/2022 14:00	1.5	12.8	2,060.4	1.1	8.20	1	1	1
11/07/2022 15:00	1.6	12.3	2,192.5	1.1	8.80	1	1	1
11/07/2022 16:00	1.7	12.0	2,250.1	1.1	9.00	1	1	1
11/07/2022 17:00	1.7	11.9	2,290.9	1.1	9.20	1	1	1
11/07/2022 18:00	1.7	11.9	2,297.0	1.1	9.20	1	1	1
11/07/2022 19:00	1.7	11.9	2,293.7	1.1	9.20	1	1	1
11/07/2022 20:00	1.7	11.9	2,289.5	1.1	9.20	1	1	1
11/07/2022 21:00	1.7	11.9	2,293.4	1.1	9.20	1	1	1
11/07/2022 22:00	1.7	12.1	2,257.7	1.1	9.00	1	1	1
11/07/2022 23:00	1.6	12.4	2,181.0	1.1	8.70	1	1	1
Average/Sum#:	1.9	13.1	1,932.3	1.6	217.24 #	24 #	22 #	18 #
Minimum:	0.8	11.9	314.8	0.7	2.84	1	0	0
Maximum:	10.4	18.1	2,297.0	11.0	40.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	1.6	12.4	2,172.6	1.1	8.70	1	1	1
11/08/2022 01:00	1.6	12.5	2,167.5	1.1	8.70	1	1	1
11/08/2022 02:00	1.6	12.6	2,112.2	1.1	8.40	1	1	1
11/08/2022 03:00	1.6	12.5	2,160.9	1.1	8.60	1	1	1
11/08/2022 04:00	1.7	12.3	2,200.1	1.2	8.80	1	1	1
11/08/2022 05:00	1.7	12.2	2,219.7	1.2	8.90	1	1	1
11/08/2022 06:00	1.6	11.8	2,300.5	1.0	9.20	1	1	1
11/08/2022 07:00	1.7	12.2	2,213.6	1.2	8.90	1	1	1
11/08/2022 08:00	1.7	12.2	2,202.3	1.2	8.80	1	1	1
11/08/2022 09:00	1.6	12.2	2,200.4	1.1	8.80	1	1	1
11/08/2022 10:00	1.6	12.3	2,185.6	1.1	8.70	1	1	1
11/08/2022 11:00	1.5	13.0	2,032.7	1.1	8.10	1	1	1
11/08/2022 12:00	1.4	13.2	1,987.2	1.1	7.90	1	1	1
11/08/2022 13:00	1.3	13.2	1,985.1	1.0	7.90	1	1	1
11/08/2022 14:00	1.5	12.9	2,056.2	1.1	8.20	1	1	1
11/08/2022 15:00	1.4	12.9	2,056.3	1.0	8.20	1	1	1
11/08/2022 16:00	1.6	12.3	2,217.1	1.1	8.90	1	1	1
11/08/2022 17:00	1.7	12.3	2,201.6	1.2	8.80	1	1	1
11/08/2022 18:00	1.6	12.4	2,173.9	1.1	8.70	1	1	1
11/08/2022 19:00	1.6	12.3	2,206.4	1.1	8.80	1	1	1
11/08/2022 20:00	1.7	12.3	2,206.2	1.2	8.80	1	1	1
11/08/2022 21:00	1.6	12.3	2,204.5	1.1	8.80	1	1	1
11/08/2022 22:00	1.6	12.3	2,190.4	1.1	8.80	1	1	1
11/08/2022 23:00	1.6	12.5	2,146.3	1.1	8.60	1	1	1
Average/Sum#:	1.6	12.5	2,158.3	1.1	207.00 #	24 #	24 #	24 #
Minimum:	1.3	11.8	1,985.1	1.0	7.90	1	1	1
Maximum:	1.7	13.2	2,300.5	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2022 00:00	1.6	12.5	2,155.3	1.1	8.60	1	1	1
11/09/2022 01:00	1.6	12.5	2,154.5	1.1	8.60	1	1	1
11/09/2022 02:00	1.6	12.4	2,194.0	1.1	8.80	1	1	1
11/09/2022 03:00	1.6	12.4	2,195.1	1.1	8.80	1	1	1
11/09/2022 04:00	1.6	12.5	2,162.1	1.1	8.60	1	1	1
11/09/2022 05:00	1.7	12.2	2,258.0	1.2	9.00	1	1	1
11/09/2022 06:00	1.6	12.0	2,298.8	1.1	9.20	1	1	1
11/09/2022 07:00	1.5	12.4	2,203.8	1.0	8.80	1	1	1
11/09/2022 08:00	1.6	12.5	2,162.6	1.1	8.70	1	1	1
11/09/2022 09:00	1.0	13.8	1,742.9	0.8	5.20	1	1	1
11/09/2022 10:00	0.9	13.9	1,701.0	0.8	5.10	1	1	0
11/09/2022 11:00	0.9	13.9	1,628.8	0.8	4.90	1	1	0
11/09/2022 12:00	0.9	13.9	1,704.5	0.8	5.10	1	1	0
11/09/2022 13:00	0.8	14.0	1,617.1	0.7	4.90	1	1	0
11/09/2022 14:00	0.9	13.9	1,688.5	0.8	5.10	1	1	0
11/09/2022 15:00	0.9	13.9	1,636.8	0.8	4.90	1	1	1
11/09/2022 16:00	1.5	12.8	2,083.4	1.1	8.30	1	1	1
11/09/2022 17:00	1.6	12.5	2,158.5	1.1	8.60	1	1	1
11/09/2022 18:00	1.4	13.1	2,013.7	1.1	8.10	1	1	1
11/09/2022 19:00	1.3	13.3	1,976.3	1.0	7.90	1	1	1
11/09/2022 20:00	1.3	13.3	1,979.9	1.0	7.90	1	1	1
11/09/2022 21:00	1.3	13.3	2,004.2	1.0	8.00	1	1	1
11/09/2022 22:00	1.3	13.3	1,996.1	1.0	8.00	1	1	1
11/09/2022 23:00	1.3	13.3	1,995.5	1.0	8.00	1	1	1
Average/Sum#:	1.3	13.1	1,988.0	1.0	179.10 #	24 #	24 #	19 #
Minimum:	0.8	12.0	1,617.1	0.7	4.90	1	1	0
Maximum:	1.7	14.0	2,298.8	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.3	13.3	1,995.0	1.0	8.00	1	1	1
11/10/2022 01:00	1.3	13.3	1,993.3	1.0	8.00	1	1	1
11/10/2022 02:00	1.3	13.3	1,991.3	1.0	8.00	1	1	1
11/10/2022 03:00	1.3	13.3	1,994.2	1.0	8.00	1	1	1
11/10/2022 04:00	1.5	13.0	2,084.2	1.1	8.30	1	1	1
11/10/2022 05:00	1.6	12.6	2,176.6	1.1	8.70	1	1	1
11/10/2022 06:00	1.6	12.0	2,294.6	1.1	9.20	1	1	1
11/10/2022 07:00	1.5	12.8	2,120.5	1.1	8.50	1	1	1
11/10/2022 08:00	1.3	13.3	1,983.8	1.0	7.90	1	1	1
11/10/2022 09:00	1.3	13.3	1,965.9	1.0	7.90	1	1	1
11/10/2022 10:00	0.9	14.0	1,725.4	0.8	5.20	1	1	0
11/10/2022 11:00	0.9	14.0	1,712.5	0.8	5.10	1	1	0
11/10/2022 12:00	0.9	14.0	1,711.2	0.8	5.10	1	1	0
11/10/2022 13:00	0.8	14.0	1,562.8	0.7	4.70	1	1	0
11/10/2022 14:00	0.9	14.0	1,712.6	0.8	5.10	1	1	0
11/10/2022 15:00	0.9	13.9	1,716.1	0.8	5.10	1	1	1
11/10/2022 16:00	1.5	12.7	2,137.8	1.1	8.60	1	1	1
11/10/2022 17:00	1.6	12.2	2,271.9	1.1	9.10	1	1	1
11/10/2022 18:00	1.6	12.2	2,274.5	1.1	9.10	1	1	1
11/10/2022 19:00	1.6	12.2	2,277.9	1.1	9.10	1	1	1
11/10/2022 20:00	1.6	12.2	2,279.9	1.1	9.10	1	1	1
11/10/2022 21:00	1.6	12.2	2,281.1	1.1	9.10	1	1	1
11/10/2022 22:00	1.6	12.2	2,281.8	1.1	9.10	1	1	1
11/10/2022 23:00	1.6	12.3	2,260.5	1.1	9.00	1	1	1
Average/Sum#:	1.3	13.0	2,033.6	1.0	185.00 #	24 #	24 #	19 #
Minimum:	0.8	12.0	1,562.8	0.7	4.70	1	1	0
Maximum:	1.6	14.0	2,294.6	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	1.6	12.2	2,281.0	1.1	9.10	1	1	1
11/11/2022 01:00	1.6	12.2	2,270.4	1.1	9.10	1	1	1
11/11/2022 02:00	1.6	12.7	2,154.0	1.2	8.60	1	1	1
11/11/2022 03:00	1.6	12.7	2,151.7	1.2	8.60	1	1	1
11/11/2022 04:00	1.6	12.3	2,272.4	1.1	9.10	1	1	1
11/11/2022 05:00	1.6	12.2	2,285.8	1.1	9.10	1	1	1
11/11/2022 06:00	1.6	12.3	2,289.0	1.1	9.20	1	1	1
11/11/2022 07:00	1.4	12.9	2,119.2	1.0	8.50	1	1	1
11/11/2022 08:00	1.2	13.4	1,954.8	0.9	5.90	1	1	1
11/11/2022 09:00	0.8	14.0	1,708.7	0.7	5.10	1	1	0
11/11/2022 10:00	0.8	14.0	1,712.4	0.7	5.10	1	1	0
11/11/2022 11:00	0.8	14.0	1,684.1	0.7	5.10	1	1	0
11/11/2022 12:00	0.9	14.0	1,684.6	0.8	5.10	1	1	0
11/11/2022 13:00	0.9	14.0	1,694.9	0.8	5.10	1	1	0
11/11/2022 14:00	0.8	14.0	1,573.1	0.7	4.70	1	1	0
11/11/2022 15:00	0.9	14.0	1,687.2	0.8	5.10	1	1	0
11/11/2022 16:00	1.4	13.1	1,984.8	1.1	7.90	1	1	1
11/11/2022 17:00	1.7	12.1	2,268.3	1.1	9.10	1	1	1
11/11/2022 18:00	1.6	12.1	2,263.3	1.1	9.10	1	1	1
11/11/2022 19:00	1.6	12.2	2,260.6	1.1	9.00	1	1	1
11/11/2022 20:00	1.6	12.2	2,253.7	1.1	9.00	1	1	1
11/11/2022 21:00	1.6	12.2	2,252.9	1.1	9.00	1	1	1
11/11/2022 22:00	1.6	12.3	2,246.0	1.1	9.00	1	1	1
11/11/2022 23:00	1.6	12.2	2,259.7	1.1	9.00	1	1	1
Average/Sum#:	1.4	12.9	2,054.7	1.0	183.60 #	24 #	24 #	17 #
Minimum:	0.8	12.1	1,573.1	0.7	4.70	1	1	0
Maximum:	1.7	14.0	2,289.0	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	1.6	12.3	2,267.0	1.1	9.10	1	1	1
11/12/2022 01:00	1.6	12.3	2,275.6	1.1	9.10	1	1	1
11/12/2022 02:00	1.6	12.2	2,278.8	1.1	9.10	1	1	1
11/12/2022 03:00	1.7	12.2	2,280.4	1.2	9.10	1	1	1
11/12/2022 04:00	1.6	12.2	2,285.0	1.1	9.10	1	1	1
11/12/2022 05:00	1.7	12.2	2,285.3	1.2	9.10	1	1	1
11/12/2022 06:00	1.6	12.2	2,276.7	1.1	9.10	1	1	1
11/12/2022 07:00	1.5	12.8	2,103.5	1.1	8.40	1	1	1
11/12/2022 08:00	1.6	12.3	2,210.7	1.1	8.80	1	1	1
11/12/2022 09:00	1.0	13.8	1,747.7	0.8	5.20	1	1	1
11/12/2022 10:00	0.8	14.0	1,589.6	0.7	4.80	1	1	0
11/12/2022 11:00	0.8	14.0	1,554.3	0.7	4.70	1	1	0
11/12/2022 12:00	0.8	14.0	1,551.1	0.7	4.70	1	1	0
11/12/2022 13:00	0.8	14.0	1,570.2	0.7	4.70	1	1	0
11/12/2022 14:00	0.8	14.0	1,549.0	0.7	4.60	1	1	0
11/12/2022 15:00	1.0	13.9	1,791.5	0.8	5.40	1	1	1
11/12/2022 16:00	1.5	12.7	2,126.7	1.1	8.50	1	1	1
11/12/2022 17:00	1.6	12.2	2,245.9	1.1	9.00	1	1	1
11/12/2022 18:00	1.6	12.2	2,246.8	1.1	9.00	1	1	1
11/12/2022 19:00	1.6	12.2	2,251.2	1.1	9.00	1	1	1
11/12/2022 20:00	1.6	12.2	2,260.4	1.1	9.00	1	1	1
11/12/2022 21:00	1.6	12.2	2,259.8	1.1	9.00	1	1	1
11/12/2022 22:00	1.6	12.5	2,193.5	1.1	8.80	1	1	1
11/12/2022 23:00	1.6	12.5	2,190.6	1.1	8.80	1	1	1
Average/Sum#:	1.4	12.8	2,058.0	1.0	186.10 #	24 #	24 #	19 #
Minimum:	0.8	12.2	1,549.0	0.7	4.60	1	1	0
Maximum:	1.7	14.0	2,285.3	1.2	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	1.6	12.6	2,180.8	1.1	8.70	1	1	1
11/13/2022 01:00	1.6	12.6	2,170.0	1.1	8.70	1	1	1
11/13/2022 02:00	1.6	12.7	2,165.0	1.2	8.70	1	1	1
11/13/2022 03:00	1.6	12.5	2,194.5	1.1	8.80	1	1	1
11/13/2022 04:00	1.6	12.6	2,189.7	1.1	8.80	1	1	1
11/13/2022 05:00	1.6	12.6	2,184.1	1.1	8.70	1	1	1
11/13/2022 06:00	1.5	12.5	2,195.0	1.1	8.80	1	1	1
11/13/2022 07:00	1.6	12.4	2,240.2	1.1	9.00	1	1	1
11/13/2022 08:00	1.4	13.1	1,966.4	1.1	7.90	1	1	1
11/13/2022 09:00	0.8	14.0	1,706.5	0.7	5.10	1	1	0
11/13/2022 10:00	0.8	14.0	1,707.9	0.7	5.10	1	1	0
11/13/2022 11:00	0.8	14.0	1,707.9	0.7	5.10	1	1	0
11/13/2022 12:00	0.8	14.0	1,706.8	0.7	5.10	1	1	0
11/13/2022 13:00	0.8	14.0	1,709.5	0.7	5.10	1	1	0
11/13/2022 14:00	0.8	14.0	1,677.7	0.7	5.00	1	1	0
11/13/2022 15:00	1.1	13.9	1,782.8	0.9	5.30	1	1	1
11/13/2022 16:00	1.6	12.5	2,138.8	1.1	8.60	1	1	1
11/13/2022 17:00	1.6	11.9	2,280.1	1.0	9.10	1	1	1
11/13/2022 18:00	1.6	11.9	2,280.5	1.0	9.10	1	1	1
11/13/2022 19:00	1.6	11.9	2,284.4	1.0	9.10	1	1	1
11/13/2022 20:00	1.6	11.9	2,288.2	1.0	9.20	1	1	1
11/13/2022 21:00	1.6	11.9	2,292.8	1.0	9.20	1	1	1
11/13/2022 22:00	1.6	11.9	2,295.1	1.0	9.20	1	1	1
11/13/2022 23:00	1.7	11.9	2,299.3	1.1	9.20	1	1	1
Average/Sum#:	1.4	12.8	2,068.5	1.0	186.60 #	24 #	24 #	18 #
Minimum:	0.8	11.9	1,677.7	0.7	5.00	1	1	0
Maximum:	1.7	14.0	2,299.3	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	1.6	11.9	2,298.5	1.0	9.20	1	1	1
11/14/2022 01:00	1.7	12.0	2,289.5	1.1	9.20	1	1	1
11/14/2022 02:00	1.7	12.1	2,286.2	1.1	9.10	1	1	1
11/14/2022 03:00	1.6	12.6	2,166.7	1.1	8.70	1	1	1
11/14/2022 04:00	1.6	12.3	2,241.5	1.1	9.00	1	1	1
11/14/2022 05:00	1.7	12.0	2,303.2	1.1	9.20	1	1	1
11/14/2022 06:00	1.6	12.1	2,299.4	1.1	9.20	1	1	1
11/14/2022 07:00	1.5	12.5	2,194.7	1.1	8.80	1	1	1
11/14/2022 08:00	1.6	12.7	2,159.1	1.2	8.60	1	1	1
11/14/2022 09:00	1.6	12.6	2,167.7	1.1	8.70	1	1	1
11/14/2022 10:00	1.6	12.6	2,158.5	1.1	8.60	1	1	1
11/14/2022 11:00	1.6	12.6	2,130.2	1.1	8.50	1	1	1
11/14/2022 12:00	1.6	12.6	2,126.0	1.1	8.50	1	1	1
11/14/2022 13:00	1.6	12.5	2,154.3	1.1	8.60	1	1	1
11/14/2022 14:00	1.6	12.4	2,150.3	1.1	8.60	1	1	1
11/14/2022 15:00	1.5	12.8	2,079.7	1.1	8.30	1	1	1
11/14/2022 16:00	1.6	12.0	2,254.0	1.1	9.00	1	1	1
11/14/2022 17:00	1.6	12.3	2,198.1	1.1	8.80	1	1	1
11/14/2022 18:00	1.6	12.4	2,182.1	1.1	8.70	1	1	1
11/14/2022 19:00	1.6	12.1	2,240.9	1.1	9.00	1	1	1
11/14/2022 20:00	1.7	12.1	2,243.9	1.1	9.00	1	1	1
11/14/2022 21:00	1.6	12.0	2,288.0	1.1	9.20	1	1	1
11/14/2022 22:00	1.6	12.0	2,288.7	1.1	9.20	1	1	1
11/14/2022 23:00	1.6	12.1	2,271.0	1.1	9.10	1	1	1
Average/Sum#:	1.6	12.3	2,215.5	1.1	212.80 #	24 #	24 #	24 #
Minimum:	1.5	11.9	2,079.7	1.0	8.30	1	1	1
Maximum:	1.7	12.8	2,303.2	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	1.6	12.0	2,301.3	1.1	9.20	1	1	1
11/15/2022 01:00	1.6	11.9	2,300.4	1.0	9.20	1	1	1
11/15/2022 02:00	1.6	12.0	2,290.8	1.1	9.20	1	1	1
11/15/2022 03:00	1.6	12.0	2,281.4	1.1	9.10	1	1	1
11/15/2022 04:00	1.6	12.1	2,264.5	1.1	9.10	1	1	1
11/15/2022 05:00	1.7	12.2	2,243.0	1.2	9.00	1	1	1
11/15/2022 06:00	1.5	12.3	2,213.0	1.0	8.90	1	1	1
11/15/2022 07:00	1.6	12.4	2,183.3	1.1	8.70	1	1	1
11/15/2022 08:00	1.6	12.6	2,133.4	1.1	8.50	1	1	1
11/15/2022 09:00	1.5	12.7	2,108.5	1.1	8.40	1	1	1
11/15/2022 10:00	1.6	12.6	2,141.8	1.1	8.60	1	1	1
11/15/2022 11:00	1.5	12.9	2,056.8	1.1	8.20	1	1	1
11/15/2022 12:00	1.3	13.3	1,977.9	1.0	7.90	1	1	1
11/15/2022 13:00	1.4	13.3	1,979.2	1.1	7.90	1	1	1
11/15/2022 14:00	1.3	13.3	1,979.2	1.0	7.90	1	1	1
11/15/2022 15:00	1.4	13.1	2,018.4	1.1	8.10	1	1	1
11/15/2022 16:00	1.6	12.6	2,149.3	1.1	8.60	1	1	1
11/15/2022 17:00	1.6	12.5	2,177.7	1.1	8.70	1	1	1
11/15/2022 18:00	1.6	12.4	2,193.7	1.1	8.80	1	1	1
11/15/2022 19:00	1.6	12.4	2,188.4	1.1	8.80	1	1	1
11/15/2022 20:00	1.6	12.3	2,196.2	1.1	8.80	1	1	1
11/15/2022 21:00	1.6	12.1	2,244.0	1.1	9.00	1	1	1
11/15/2022 22:00	1.6	12.4	2,174.7	1.1	8.70	1	1	1
11/15/2022 23:00	1.5	12.5	2,174.2	1.1	8.70	1	1	1
Average/Sum#:	1.5	12.5	2,165.5	1.1	208.00 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,977.9	1.0	7.90	1	1	1
Maximum:	1.7	13.3	2,301.3	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2022 00:00	1.5	12.5	2,168.0	1.1	8.70	1	1	1
11/16/2022 01:00	1.6	12.6	2,140.8	1.1	8.60	1	1	1
11/16/2022 02:00	1.6	12.5	2,165.7	1.1	8.70	1	1	1
11/16/2022 03:00	1.6	12.5	2,167.5	1.1	8.70	1	1	1
11/16/2022 04:00	1.6	12.4	2,178.7	1.1	8.70	1	1	1
11/16/2022 05:00	1.6	12.5	2,174.9	1.1	8.70	1	1	1
11/16/2022 06:00	1.5	12.5	2,168.0	1.1	8.70	1	1	1
11/16/2022 07:00	1.5	12.2	2,241.0	1.0	9.00	1	1	1
11/16/2022 08:00	1.4	13.2	1,987.0	1.1	7.90	1	1	1
11/16/2022 09:00	1.4	13.2	2,018.8	1.1	8.10	1	1	1
11/16/2022 10:00	1.4	13.3	1,985.3	1.1	7.90	1	1	1
11/16/2022 11:00	0.0	0.0	1,986.8	0.0	0.00	1	1	1
11/16/2022 12:00	1.0	13.2	1,985.9	0.8	6.00	1	1	1
11/16/2022 13:00	1.0	13.2	1,986.9	0.8	6.00	1	1	1
11/16/2022 14:00	1.1	13.2	1,985.4	0.8	6.00	1	1	1
11/16/2022 15:00	1.4	12.6	2,113.3	1.0	8.50	1	1	1
11/16/2022 16:00	1.7	12.3	2,177.2	1.2	8.70	1	1	1
11/16/2022 17:00	1.7	12.3	2,192.8	1.2	8.80	1	1	1
11/16/2022 18:00	1.7	11.9	2,278.4	1.1	9.10	1	1	1
11/16/2022 19:00	1.7	11.9	2,286.5	1.1	9.10	1	1	1
11/16/2022 20:00	1.7	11.9	2,286.7	1.1	9.10	1	1	1
11/16/2022 21:00	1.6	12.0	2,266.9	1.1	9.10	1	1	1
11/16/2022 22:00	1.6	12.2	2,230.9	1.1	8.90	1	1	1
11/16/2022 23:00	1.6	12.0	2,257.4	1.1	9.00	1	1	1
Average/Sum#:	1.5	12.5	2,143.0	1.1	192.00 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,985.3	0.8	6.00	1	1	1
Maximum:	1.7	13.3	2,286.7	1.2	9.10	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	1.6	12.4	2,177.8	1.1	8.70	1	1	1
11/17/2022 01:00	1.6	12.3	2,181.0	1.1	8.70	1	1	1
11/17/2022 02:00	1.6	12.4	2,165.8	1.1	8.70	1	1	1
11/17/2022 03:00	1.6	12.5	2,166.0	1.1	8.70	1	1	1
11/17/2022 04:00	1.5	12.5	2,169.1	1.1	8.70	1	1	1
11/17/2022 05:00	1.3	12.4	2,181.8	0.9	6.50	1	1	1
11/17/2022 06:00	1.6	11.9	2,291.5	1.0	9.20	1	1	1
11/17/2022 07:00	1.6	12.4	2,182.1	1.1	8.70	1	1	1
11/17/2022 08:00	1.2	13.1	1,994.1	0.9	6.00	1	1	1
11/17/2022 09:00	1.6	12.5	2,150.8	1.1	8.60	1	1	1
11/17/2022 10:00	1.6	12.5	2,143.2	1.1	8.60	1	1	1
11/17/2022 11:00	1.6	12.3	2,174.6	1.1	8.70	1	1	1
11/17/2022 12:00	1.6	12.1	2,198.3	1.1	8.80	1	1	1
11/17/2022 13:00	1.6	12.2	2,183.9	1.1	8.70	1	1	1
11/17/2022 14:00	1.5	12.9	2,015.7	1.1	8.10	1	1	1
11/17/2022 15:00	1.6	12.4	2,130.6	1.1	8.50	1	1	1
11/17/2022 16:00	1.6	11.9	2,243.2	1.0	9.00	1	1	1
11/17/2022 17:00	1.6	11.8	2,276.9	1.0	9.10	1	1	1
11/17/2022 18:00	1.6	11.8	2,275.4	1.0	9.10	1	1	1
11/17/2022 19:00	1.6	11.8	2,278.6	1.0	9.10	1	1	1
11/17/2022 20:00	1.6	11.8	2,280.8	1.0	9.10	1	1	1
11/17/2022 21:00	1.6	11.8	2,282.5	1.0	9.10	1	1	1
11/17/2022 22:00	1.6	11.9	2,269.7	1.0	9.10	1	1	1
11/17/2022 23:00	1.6	12.2	2,226.9	1.1	8.90	1	1	1
Average/Sum#:	1.6	12.2	2,193.3	1.1	206.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,994.1	0.9	6.00	1	1	1
Maximum:	1.6	13.1	2,291.5	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	1.6	12.4	2,177.7	1.1	8.70	1	1	1
11/18/2022 01:00	1.6	12.3	2,188.2	1.1	8.80	1	1	1
11/18/2022 02:00	1.6	12.2	2,194.3	1.1	8.80	1	1	1
11/18/2022 03:00	1.6	12.3	2,188.5	1.1	8.80	1	1	1
11/18/2022 04:00	1.6	12.2	2,185.6	1.1	8.70	1	1	1
11/18/2022 05:00	1.5	12.3	2,173.7	1.0	8.70	1	1	1
11/18/2022 06:00	1.4	12.4	2,160.2	1.0	8.60	1	1	1
11/18/2022 07:00	1.6	12.0	2,255.3	1.1	9.00	1	1	1
11/18/2022 08:00	1.6	12.3	2,177.7	1.1	8.70	1	1	1
11/18/2022 09:00	1.6	12.3	2,185.0	1.1	8.70	1	1	1
11/18/2022 10:00	1.6	12.2	2,190.4	1.1	8.80	1	1	1
11/18/2022 11:00	1.5	12.5	2,120.3	1.1	8.50	1	1	1
11/18/2022 12:00	1.5	13.1	1,970.2	1.1	7.90	1	1	1
11/18/2022 13:00	1.5	13.1	1,973.1	1.1	7.90	1	1	1
11/18/2022 14:00	1.5	13.1	1,974.5	1.1	7.90	1	1	1
11/18/2022 15:00	1.5	12.8	2,058.5	1.1	8.20	1	1	1
11/18/2022 16:00	1.6	12.0	2,235.0	1.1	8.90	1	1	1
11/18/2022 17:00	1.6	11.9	2,257.9	1.0	9.00	1	1	1
11/18/2022 18:00	1.6	12.0	2,260.4	1.1	9.00	1	1	1
11/18/2022 19:00	1.6	12.0	2,263.4	1.1	9.10	1	1	1
11/18/2022 20:00	1.6	12.1	2,228.1	1.1	8.90	1	1	1
11/18/2022 21:00	1.5	12.3	2,181.4	1.0	8.70	1	1	1
11/18/2022 22:00	1.3	12.5	2,145.0	0.9	6.40	1	1	1
11/18/2022 23:00	1.5	12.1	2,239.0	1.0	9.00	1	1	1
Average/Sum#:	1.5	12.4	2,166.0	1.1	205.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,970.2	0.9	6.40	1	1	1
Maximum:	1.6	13.1	2,263.4	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	1.6	12.3	2,194.0	1.1	8.80	1	1	1
11/19/2022 01:00	1.6	12.4	2,172.4	1.1	8.70	1	1	1
11/19/2022 02:00	1.6	12.5	2,168.7	1.1	8.70	1	1	1
11/19/2022 03:00	1.6	12.6	2,144.8	1.1	8.60	1	1	1
11/19/2022 04:00	1.6	12.2	2,238.2	1.1	9.00	1	1	1
11/19/2022 05:00	1.6	12.1	2,271.6	1.1	9.10	1	1	1
11/19/2022 06:00	1.5	12.3	2,218.2	1.0	8.90	1	1	1
11/19/2022 07:00	1.5	12.6	2,132.0	1.1	8.50	1	1	1
11/19/2022 08:00	1.1	13.2	1,978.8	0.8	5.90	1	1	1
11/19/2022 09:00	1.3	13.2	1,978.8	1.0	7.90	1	1	1
11/19/2022 10:00	1.4	13.2	1,975.1	1.1	7.90	1	1	1
11/19/2022 11:00	1.5	13.2	1,970.6	1.1	7.90	1	1	1
11/19/2022 12:00	1.5	13.1	1,971.0	1.1	7.90	1	1	1
11/19/2022 13:00	1.5	13.1	1,971.9	1.1	7.90	1	1	1
11/19/2022 14:00	1.5	13.1	1,970.2	1.1	7.90	1	1	1
11/19/2022 15:00	1.5	12.8	2,050.9	1.1	8.20	1	1	1
11/19/2022 16:00	1.5	12.2	2,184.1	1.0	8.70	1	1	1
11/19/2022 17:00	1.6	12.1	2,201.8	1.1	8.80	1	1	1
11/19/2022 18:00	1.6	12.2	2,197.4	1.1	8.80	1	1	1
11/19/2022 19:00	1.6	11.9	2,260.7	1.0	9.00	1	1	1
11/19/2022 20:00	1.6	12.1	2,219.4	1.1	8.90	1	1	1
11/19/2022 21:00	1.5	12.3	2,177.5	1.0	8.70	1	1	1
11/19/2022 22:00	1.3	12.5	2,175.6	0.9	6.50	1	1	1
11/19/2022 23:00	1.2	12.6	2,143.8	0.9	6.40	1	1	1
Average/Sum#:	1.5	12.6	2,123.6	1.1	197.60 #	24 #	24 #	24 #
Minimum:	1.1	11.9	1,970.2	0.8	5.90	1	1	1
Maximum:	1.6	13.2	2,271.6	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	1.2	12.7	2,106.9	0.9	6.30	1	1	1
11/20/2022 01:00	1.1	12.8	2,078.9	0.8	6.20	1	1	1
11/20/2022 02:00	1.0	12.9	2,062.3	0.7	6.20	1	1	1
11/20/2022 03:00	0.9	12.9	2,063.5	0.7	4.10	1	1	1
11/20/2022 04:00	0.9	12.9	2,070.5	0.7	4.10	1	1	1
11/20/2022 05:00	1.2	12.5	2,183.5	0.8	6.60	1	1	1
11/20/2022 06:00	1.6	12.1	2,276.9	1.1	9.10	1	1	1
11/20/2022 07:00	1.4	12.6	2,113.0	1.0	8.50	1	1	1
11/20/2022 08:00	0.5	13.9	1,703.8	0.4	3.40	1	1	0
11/20/2022 09:00	0.5	13.9	1,708.6	0.4	3.40	1	1	0
11/20/2022 10:00	0.5	13.9	1,565.5	0.4	3.10	1	1	0
11/20/2022 11:00	0.5	13.9	1,563.6	0.4	3.10	1	1	0
11/20/2022 12:00	0.5	14.0	1,533.4	0.4	3.10	1	1	0
11/20/2022 13:00	0.5	14.0	1,523.9	0.4	3.00	1	1	0
11/20/2022 14:00	0.6	13.8	1,701.2	0.5	3.40	1	1	1
11/20/2022 15:00	0.7	13.8	1,723.3	0.6	3.40	1	1	1
11/20/2022 16:00	1.5	12.4	2,162.3	1.0	8.60	1	1	1
11/20/2022 17:00	1.6	11.9	2,276.4	1.0	9.10	1	1	1
11/20/2022 18:00	1.6	11.9	2,265.8	1.0	9.10	1	1	1
11/20/2022 19:00	1.6	11.9	2,256.8	1.0	9.00	1	1	1
11/20/2022 20:00	1.6	11.9	2,261.0	1.0	9.00	1	1	1
11/20/2022 21:00	1.6	12.2	2,204.5	1.1	8.80	1	1	1
11/20/2022 22:00	1.6	12.4	2,168.3	1.1	8.70	1	1	1
11/20/2022 23:00	1.6	12.5	2,153.3	1.1	8.60	1	1	1
Average/Sum#:	1.1	12.9	1,988.6	0.8	147.90 #	24 #	24 #	18 #
Minimum:	0.5	11.9	1,523.9	0.4	3.00	1	1	0
Maximum:	1.6	14.0	2,276.9	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	1.5	12.5	2,160.3	1.1	8.60	1	1	1
11/21/2022 01:00	1.6	12.6	2,137.5	1.1	8.60	1	1	1
11/21/2022 02:00	1.4	12.9	2,062.0	1.0	8.20	1	1	1
11/21/2022 03:00	1.6	12.4	2,174.4	1.1	8.70	1	1	1
11/21/2022 04:00	1.6	12.1	2,256.2	1.1	9.00	1	1	1
11/21/2022 05:00	1.6	12.1	2,267.1	1.1	9.10	1	1	1
11/21/2022 06:00	1.7	12.0	2,284.1	1.1	9.10	1	1	1
11/21/2022 07:00	1.4	12.5	2,150.4	1.0	8.60	1	1	1
11/21/2022 08:00	1.0	13.3	1,968.4	0.8	5.90	1	1	1
11/21/2022 09:00	1.0	13.3	1,968.7	0.8	5.90	1	1	1
11/21/2022 10:00	1.2	13.2	1,969.1	0.9	5.90	1	1	1
11/21/2022 11:00	1.4	13.2	1,979.0	1.1	7.90	1	1	1
11/21/2022 12:00	1.5	13.1	1,980.5	1.1	7.90	1	1	1
11/21/2022 13:00	1.5	13.1	1,980.3	1.1	7.90	1	1	1
11/21/2022 14:00	1.5	12.3	2,160.9	1.0	8.60	1	1	1
11/21/2022 15:00	1.6	11.9	2,251.4	1.0	9.00	1	1	1
11/21/2022 16:00	1.6	12.1	2,226.7	1.1	8.90	1	1	1
11/21/2022 17:00	1.7	11.9	2,273.3	1.1	9.10	1	1	1
11/21/2022 18:00	1.7	12.0	2,283.4	1.1	9.10	1	1	1
11/21/2022 19:00	1.7	11.9	2,265.1	1.1	9.10	1	1	1
11/21/2022 20:00	1.6	11.9	2,265.4	1.0	9.10	1	1	1
11/21/2022 21:00	1.7	11.9	2,267.8	1.1	9.10	1	1	1
11/21/2022 22:00	1.6	11.9	2,264.5	1.0	9.10	1	1	1
11/21/2022 23:00	1.6	12.1	2,228.8	1.1	8.90	1	1	1
Average/Sum#:	1.5	12.4	2,159.4	1.0	201.30 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,968.4	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,284.1	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	1.6	12.4	2,154.9	1.1	8.60	1	1	1
11/22/2022 01:00	1.6	12.6	2,130.2	1.1	8.50	1	1	1
11/22/2022 02:00	1.6	12.7	2,101.3	1.2	8.40	1	1	1
11/22/2022 03:00	1.1	13.1	1,980.1	0.8	5.90	1	1	1
11/22/2022 04:00	1.1	13.2	1,985.4	0.8	6.00	1	1	1
11/22/2022 05:00	1.3	12.8	2,071.1	0.9	6.20	1	1	1
11/22/2022 06:00	1.6	12.5	2,156.2	1.1	8.60	1	1	1
11/22/2022 07:00	1.2	12.8	2,097.2	0.9	6.30	1	1	1
11/22/2022 08:00	1.3	12.9	2,055.9	1.0	8.20	1	1	1
11/22/2022 09:00	0.7	13.8	1,648.0	0.6	3.30	1	1	1
11/22/2022 10:00	0.7	13.8	1,674.5	0.6	3.30	1	1	0
11/22/2022 11:00	0.7	13.9	1,795.0	0.6	3.60	1	1	0
11/22/2022 12:00	0.5	13.9	1,556.4	0.4	3.10	1	1	0
11/22/2022 13:00	0.6	13.9	1,617.1	0.5	3.20	1	1	0
11/22/2022 14:00	0.7	13.8	1,779.5	0.6	3.60	1	1	0
11/22/2022 15:00	0.6	13.8	1,781.6	0.5	3.60	1	1	0
11/22/2022 16:00	0.9	13.2	1,919.5	0.7	5.80	1	1	1
11/22/2022 17:00	1.6	12.3	2,191.5	1.1	8.80	1	1	1
11/22/2022 18:00	1.5	12.8	2,055.9	1.1	8.20	1	1	1
11/22/2022 19:00	1.3	13.1	1,999.0	1.0	8.00	1	1	1
11/22/2022 20:00	1.6	12.5	2,155.9	1.1	8.60	1	1	1
11/22/2022 21:00	1.3	12.9	2,034.0	1.0	8.10	1	1	1
11/22/2022 22:00	1.3	12.9	2,045.3	1.0	8.20	1	1	1
11/22/2022 23:00	1.1	13.2	1,973.0	0.8	5.90	1	1	1
Average/Sum#:	1.1	13.1	1,956.6	0.9	152.00 #	24 #	24 #	18 #
Minimum:	0.5	12.3	1,556.4	0.4	3.10	1	1	0
Maximum:	1.6	13.9	2,191.5	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.1	13.2	1,974.3	0.8	5.90	1	1	1
11/23/2022 01:00	1.1	13.2	1,975.1	0.8	5.90	1	1	1
11/23/2022 02:00	1.1	13.2	1,973.8	0.8	5.90	1	1	1
11/23/2022 03:00	1.0	13.2	1,976.4	0.8	5.90	1	1	1
11/23/2022 04:00	1.2	13.2	1,982.4	0.9	5.90	1	1	1
11/23/2022 05:00	1.5	12.7	2,074.5	1.1	8.30	1	1	1
11/23/2022 06:00	1.4	12.7	2,056.8	1.0	8.20	1	1	1
11/23/2022 07:00	1.5	12.7	2,111.0	1.1	8.40	1	1	1
11/23/2022 08:00	1.3	13.0	2,004.8	1.0	8.00	1	1	1
11/23/2022 09:00	0.6	13.9	1,703.0	0.5	3.40	1	1	0
11/23/2022 10:00	0.5	13.9	1,554.3	0.4	3.10	1	1	0
11/23/2022 11:00	0.5	13.9	1,550.6	0.4	3.10	1	1	0
11/23/2022 12:00	0.4	14.0	1,422.8	0.3	1.40	1	1	0
11/23/2022 13:00	0.5	14.0	1,559.1	0.4	3.10	1	1	0
11/23/2022 14:00	0.5	14.0	1,630.2	0.4	3.30	1	1	0
11/23/2022 15:00	0.8	13.9	1,636.5	0.7	3.30	1	1	1
11/23/2022 16:00	1.5	12.6	2,110.6	1.1	8.40	1	1	1
11/23/2022 17:00	1.6	12.3	2,185.3	1.1	8.70	1	1	1
11/23/2022 18:00	1.4	12.7	2,100.4	1.0	8.40	1	1	1
11/23/2022 19:00	1.3	12.9	2,063.5	1.0	8.30	1	1	1
11/23/2022 20:00	1.6	12.3	2,182.9	1.1	8.70	1	1	1
11/23/2022 21:00	1.7	12.3	2,201.9	1.2	8.80	1	1	1
11/23/2022 22:00	1.6	12.4	2,176.3	1.1	8.70	1	1	1
11/23/2022 23:00	1.6	12.4	2,171.5	1.1	8.70	1	1	1
Average/Sum#:	1.1	13.1	1,932.4	0.8	151.80 #	24 #	24 #	18 #
Minimum:	0.4	12.3	1,422.8	0.3	1.40	1	1	0
Maximum:	1.7	14.0	2,201.9	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.1	13.1	1,990.6	0.8	6.00	1	1	1
11/24/2022 01:00	1.0	13.2	1,976.9	0.8	5.90	1	1	1
11/24/2022 02:00	1.0	13.2	1,976.7	0.8	5.90	1	1	1
11/24/2022 03:00	1.3	13.1	2,019.5	1.0	8.10	1	1	1
11/24/2022 04:00	1.2	13.0	2,026.8	0.9	6.10	1	1	1
11/24/2022 05:00	1.3	12.8	2,102.0	0.9	6.30	1	1	1
11/24/2022 06:00	1.6	12.2	2,191.0	1.1	8.80	1	1	1
11/24/2022 07:00	1.5	12.5	2,097.3	1.1	8.40	1	1	1
11/24/2022 08:00	0.5	13.9	1,712.8	0.4	3.40	1	1	0
11/24/2022 09:00	0.5	13.9	1,696.5	0.4	3.40	1	1	0
11/24/2022 10:00	0.5	13.9	1,703.7	0.4	3.40	1	1	0
11/24/2022 11:00	0.5	14.0	1,549.0	0.4	3.10	1	1	0
11/24/2022 12:00	0.4	14.0	1,349.8	0.3	1.30	1	1	0
11/24/2022 13:00	0.4	14.0	1,345.2	0.3	1.30	1	1	0
11/24/2022 14:00	0.5	14.0	1,551.3	0.4	3.10	1	1	0
11/24/2022 15:00	0.5	14.0	1,440.8	0.4	2.90	1	1	0
11/24/2022 16:00	0.7	13.9	1,756.8	0.6	3.50	1	1	0
11/24/2022 17:00	0.6	13.9	1,755.3	0.5	3.50	1	1	0
11/24/2022 18:00	0.6	13.9	1,738.1	0.5	3.50	1	1	0
11/24/2022 19:00	0.6	13.9	1,735.7	0.5	3.50	1	1	0
11/24/2022 20:00	0.6	13.9	1,736.2	0.5	3.50	1	1	0
11/24/2022 21:00	0.6	13.9	1,739.4	0.5	3.50	1	1	0
11/24/2022 22:00	0.6	13.9	1,742.8	0.5	3.50	1	1	0
11/24/2022 23:00	0.6	13.9	1,744.5	0.5	3.50	1	1	0
Average/Sum#:	0.8	13.6	1,778.3	0.6	105.40 #	24 #	24 #	8 #
Minimum:	0.4	12.2	1,345.2	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,191.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.6	13.9	1,746.5	0.5	3.50	1	1	0
11/25/2022 01:00	0.6	13.9	1,746.8	0.5	3.50	1	1	0
11/25/2022 02:00	0.6	13.9	1,749.6	0.5	3.50	1	1	0
11/25/2022 03:00	0.6	13.9	1,753.4	0.5	3.50	1	1	0
11/25/2022 04:00	0.6	13.9	1,763.9	0.5	3.50	1	1	0
11/25/2022 05:00	0.6	13.9	1,761.2	0.5	3.50	1	1	0
11/25/2022 06:00	0.6	13.9	1,755.3	0.5	3.50	1	1	0
11/25/2022 07:00	0.6	13.9	1,755.9	0.5	3.50	1	1	0
11/25/2022 08:00	0.8	13.5	1,878.1	0.6	3.80	1	1	1
11/25/2022 09:00	1.1	13.2	1,927.0	0.8	5.80	1	1	1
11/25/2022 10:00	0.6	13.9	1,661.2	0.5	3.30	1	1	0
11/25/2022 11:00	0.5	13.9	1,538.8	0.4	3.10	1	1	0
11/25/2022 12:00	0.5	13.9	1,565.4	0.4	3.10	1	1	0
11/25/2022 13:00	0.5	13.9	1,534.3	0.4	3.10	1	1	0
11/25/2022 14:00	0.5	13.9	1,521.7	0.4	3.00	1	1	0
11/25/2022 15:00	0.8	13.8	1,630.3	0.7	3.30	1	1	1
11/25/2022 16:00	1.5	12.6	2,098.5	1.1	8.40	1	1	1
11/25/2022 17:00	1.6	12.5	2,115.1	1.1	8.50	1	1	1
11/25/2022 18:00	1.3	13.1	1,976.4	1.0	7.90	1	1	1
11/25/2022 19:00	1.2	13.2	1,966.1	0.9	5.90	1	1	1
11/25/2022 20:00	1.2	13.2	1,974.0	0.9	5.90	1	1	1
11/25/2022 21:00	1.1	13.2	1,977.2	0.8	5.90	1	1	1
11/25/2022 22:00	1.6	12.6	2,131.7	1.1	8.50	1	1	1
11/25/2022 23:00	1.6	12.7	2,091.1	1.2	8.40	1	1	1
Average/Sum#:	0.9	13.5	1,817.5	0.7	115.90 #	24 #	24 #	11 #
Minimum:	0.5	12.5	1,521.7	0.4	3.00	1	1	0
Maximum:	1.6	13.9	2,131.7	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.4	13.0	2,033.3	1.0	8.10	1	1	1
11/26/2022 01:00	1.5	12.8	2,080.1	1.1	8.30	1	1	1
11/26/2022 02:00	2.2	13.9	1,574.8	1.9	11.00	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	13.2	1,896.1	1.3	27.40 #	3 #	2 #	3 #
Minimum:	1.4	12.8	1,574.8	1.0	8.10	0	0	0
Maximum:	2.2	13.9	2,080.1	1.9	11.00	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2022 21:00	30.1	17.7	330.2	55.5	47.18	1	0	0
11/27/2022 22:00	14.6	17.3	396.9	23.9	34.90	1	0	0
11/27/2022 23:00	13.0	15.5	901.6	14.2	46.90	1	0	0
Average/Sum#:	19.2	16.8	542.9	31.2	128.98 #	3 #	0 #	0 #
Minimum:	13.0	15.5	330.2	14.2	34.90	0	0	0
Maximum:	30.1	17.7	901.6	55.5	47.18	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2022 00:00	0.4	13.9	1,574.9	0.3	1.60	1	1	0
11/28/2022 01:00	0.5	13.9	1,487.8	0.4	3.00	1	1	0
11/28/2022 02:00	0.7	13.8	1,745.5	0.6	3.50	1	1	0
11/28/2022 03:00	0.5	13.9	1,530.8	0.4	3.10	1	1	0
11/28/2022 04:00	0.6	13.9	1,710.5	0.5	3.40	1	1	0
11/28/2022 05:00	0.6	13.8	1,642.2	0.5	3.30	1	1	1
11/28/2022 06:00	1.4	12.3	2,173.2	1.0	8.70	1	1	1
11/28/2022 07:00	1.7	12.0	2,270.2	1.1	9.10	1	1	1
11/28/2022 08:00	1.1	13.1	1,972.1	0.8	5.90	1	1	1
11/28/2022 09:00	0.6	13.9	1,601.7	0.5	3.20	1	1	0
11/28/2022 10:00	0.6	13.9	1,699.0	0.5	3.40	1	1	0
11/28/2022 11:00	0.5	13.9	1,519.7	0.4	3.00	1	1	0
11/28/2022 12:00	0.6	13.9	1,566.4	0.5	3.10	1	1	0
11/28/2022 13:00	0.6	13.9	1,634.0	0.5	3.30	1	1	0
11/28/2022 14:00	0.5	13.9	1,616.9	0.4	3.20	1	1	0
11/28/2022 15:00	0.7	13.8	1,620.0	0.6	3.20	1	1	1
11/28/2022 16:00	1.3	12.8	2,041.1	0.9	6.10	1	1	1
11/28/2022 17:00	1.5	12.6	2,100.3	1.1	8.40	1	1	1
11/28/2022 18:00	1.3	13.1	1,988.5	1.0	8.00	1	1	1
11/28/2022 19:00	1.2	13.2	1,967.8	0.9	5.90	1	1	1
11/28/2022 20:00	1.5	12.7	2,094.0	1.1	8.40	1	1	1
11/28/2022 21:00	1.6	12.1	2,238.4	1.1	9.00	1	1	1
11/28/2022 22:00	1.4	12.7	2,095.4	1.0	8.40	1	1	1
11/28/2022 23:00	1.2	13.1	1,996.1	0.9	6.00	1	1	1
Average/Sum#:	0.9	13.3	1,828.6	0.7	124.20 #	24 #	24 #	13 #
Minimum:	0.4	12.0	1,487.8	0.3	1.60	1	1	0
Maximum:	1.7	13.9	2,270.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	1.6	12.5	2,165.2	1.1	8.70	1	1	1
11/29/2022 01:00	1.6	12.3	2,212.8	1.1	8.90	1	1	1
11/29/2022 02:00	1.6	12.4	2,192.2	1.1	8.80	1	1	1
11/29/2022 03:00	1.4	12.8	2,088.0	1.0	8.40	1	1	1
11/29/2022 04:00	1.6	12.5	2,152.8	1.1	8.60	1	1	1
11/29/2022 05:00	1.6	12.4	2,205.6	1.1	8.80	1	1	1
11/29/2022 06:00	1.6	11.9	2,296.9	1.0	9.20	1	1	1
11/29/2022 07:00	1.7	11.9	2,304.2	1.1	9.20	1	1	1
11/29/2022 08:00	1.7	12.0	2,274.9	1.1	9.10	1	1	1
11/29/2022 09:00	1.6	12.4	2,174.5	1.1	8.70	1	1	1
11/29/2022 10:00	1.6	12.4	2,167.1	1.1	8.70	1	1	1
11/29/2022 11:00	1.6	12.4	2,157.9	1.1	8.60	1	1	1
11/29/2022 12:00	1.6	12.4	2,151.2	1.1	8.60	1	1	1
11/29/2022 13:00	1.6	12.4	2,151.4	1.1	8.60	1	1	1
11/29/2022 14:00	1.6	12.4	2,156.0	1.1	8.60	1	1	1
11/29/2022 15:00	1.6	12.3	2,170.6	1.1	8.70	1	1	1
11/29/2022 16:00	1.6	11.9	2,281.5	1.0	9.10	1	1	1
11/29/2022 17:00	1.6	11.9	2,289.6	1.0	9.20	1	1	1
11/29/2022 18:00	1.7	11.9	2,292.8	1.1	9.20	1	1	1
11/29/2022 19:00	1.6	11.9	2,290.5	1.0	9.20	1	1	1
11/29/2022 20:00	1.7	12.0	2,289.3	1.1	9.20	1	1	1
11/29/2022 21:00	1.7	11.9	2,292.2	1.1	9.20	1	1	1
11/29/2022 22:00	1.6	12.0	2,297.8	1.1	9.20	1	1	1
11/29/2022 23:00	1.6	12.0	2,296.7	1.1	9.20	1	1	1
Average/Sum#:	1.6	12.2	2,223.0	1.1	213.70 #	24 #	24 #	24 #
Minimum:	1.4	11.9	2,088.0	1.0	8.40	1	1	1
Maximum:	1.7	12.8	2,304.2	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	1.5	12.6	2,170.7	1.1	8.70	1	1	1
11/30/2022 01:00	1.6	12.6	2,153.2	1.1	8.60	1	1	1
11/30/2022 02:00	1.6	12.6	2,153.8	1.1	8.60	1	1	1
11/30/2022 03:00	1.6	12.6	2,151.0	1.1	8.60	1	1	1
11/30/2022 04:00	1.6	12.6	2,169.6	1.1	8.70	1	1	1
11/30/2022 05:00	1.5	12.6	2,169.3	1.1	8.70	1	1	1
11/30/2022 06:00	1.3	12.1	2,268.0	0.9	6.80	1	1	1
11/30/2022 07:00	1.4	12.6	2,158.0	1.0	8.60	1	1	1
11/30/2022 08:00	1.0	13.3	1,984.3	0.8	6.00	1	1	1
11/30/2022 09:00	1.1	13.2	1,998.7	0.8	6.00	1	1	1
11/30/2022 10:00	1.0	13.2	1,980.3	0.8	5.90	1	1	1
11/30/2022 11:00	1.1	13.2	1,984.1	0.8	6.00	1	1	1
11/30/2022 12:00	1.3	13.2	1,983.8	1.0	7.90	1	1	1
11/30/2022 13:00	1.4	13.1	1,978.8	1.1	7.90	1	1	1
11/30/2022 14:00	1.6	12.5	2,132.5	1.1	8.50	1	1	1
11/30/2022 15:00	1.6	12.4	2,140.8	1.1	8.60	1	1	1
11/30/2022 16:00	1.7	11.9	2,251.8	1.1	9.00	1	1	1
11/30/2022 17:00	1.7	11.7	2,297.3	1.1	9.20	1	1	1
11/30/2022 18:00	1.7	11.8	2,289.4	1.1	9.20	1	1	1
11/30/2022 19:00	1.7	11.8	2,289.6	1.1	9.20	1	1	1
11/30/2022 20:00	1.7	11.8	2,288.9	1.1	9.20	1	1	1
11/30/2022 21:00	1.6	12.0	2,256.6	1.1	9.00	1	1	1
11/30/2022 22:00	1.5	12.6	2,106.9	1.1	8.40	1	1	1
11/30/2022 23:00	2.1	13.8	1,590.5	1.7	9.50	1	0	1
Average/Sum#:	1.5	12.6	2,122.8	1.1	196.80 #	24 #	23 #	24 #
Minimum:	1.0	11.7	1,590.5	0.8	5.90	1	0	1
Maximum:	2.1	13.8	2,297.3	1.7	9.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/01/2022 02:00	2.4	17.9	301.9	4.7	2.40	1	0	0
12/01/2022 03:00	7.0	14.8	1,144.0	6.8	28.60	1	0	0
12/01/2022 04:00	0.6	13.8	1,703.6	0.5	3.40	1	1	0
12/01/2022 05:00	0.8	13.5	1,790.5	0.6	3.60	1	1	1
12/01/2022 06:00	1.7	11.7	2,291.0	1.1	9.20	1	1	1
12/01/2022 07:00	1.7	11.6	2,326.9	1.1	9.30	1	1	1
12/01/2022 08:00	1.7	12.1	2,203.6	1.1	8.80	1	1	1
12/01/2022 09:00	1.7	12.2	2,190.4	1.2	8.80	1	1	1
12/01/2022 10:00	1.7	12.2	2,195.3	1.2	8.80	1	1	1
12/01/2022 11:00	1.7	12.3	2,173.6	1.2	8.70	1	1	1
12/01/2022 12:00	1.7	12.2	2,176.8	1.2	8.70	1	1	1
12/01/2022 13:00	1.7	12.2	2,177.9	1.2	8.70	1	1	1
12/01/2022 14:00	1.7	12.1	2,192.3	1.1	8.80	1	1	1
12/01/2022 15:00	1.8	11.6	2,311.4	1.1	9.20	1	1	1
12/01/2022 16:00	1.7	11.6	2,338.6	1.1	9.40	1	1	1
12/01/2022 17:00	1.7	11.6	2,347.2	1.1	9.40	1	1	1
12/01/2022 18:00	1.7	11.6	2,335.6	1.1	9.30	1	1	1
12/01/2022 19:00	1.7	11.7	2,345.2	1.1	9.40	1	1	1
12/01/2022 20:00	1.7	11.7	2,349.1	1.1	9.40	1	1	1
12/01/2022 21:00	1.7	11.8	2,324.3	1.1	9.30	1	1	1
12/01/2022 22:00	1.7	12.4	2,184.7	1.2	8.70	1	1	1
12/01/2022 23:00	1.6	12.4	2,181.8	1.1	8.70	1	1	1
Average/Sum#:	1.9	12.5	2,072.1	1.5	200.60 #	22 #	20 #	19 #
Minimum:	0.6	11.6	301.9	0.5	2.40	0	0	0
Maximum:	7.0	17.9	2,349.1	6.8	28.60	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	1.7	12.4	2,181.7	1.2	8.70	1	1	1
12/02/2022 01:00	1.6	12.4	2,185.0	1.1	8.70	1	1	1
12/02/2022 02:00	1.6	12.4	2,189.6	1.1	8.80	1	1	1
12/02/2022 03:00	1.6	12.5	2,168.0	1.1	8.70	1	1	1
12/02/2022 04:00	1.6	12.5	2,177.5	1.1	8.70	1	1	1
12/02/2022 05:00	1.6	12.5	2,174.2	1.1	8.70	1	1	1
12/02/2022 06:00	1.7	12.0	2,312.0	1.1	9.20	1	1	1
12/02/2022 07:00	1.7	11.9	2,323.5	1.1	9.30	1	1	1
12/02/2022 08:00	1.7	12.0	2,321.3	1.1	9.30	1	1	1
12/02/2022 09:00	1.6	12.4	2,196.4	1.1	8.80	1	1	1
12/02/2022 10:00	1.7	12.4	2,196.5	1.2	8.80	1	1	1
12/02/2022 11:00	1.7	12.3	2,214.2	1.2	8.90	1	1	1
12/02/2022 12:00	1.7	12.3	2,217.5	1.2	8.90	1	1	1
12/02/2022 13:00	1.7	12.3	2,208.5	1.2	8.80	1	1	1
12/02/2022 14:00	1.7	12.3	2,186.0	1.2	8.70	1	1	1
12/02/2022 15:00	1.7	11.9	2,306.4	1.1	9.20	1	1	1
12/02/2022 16:00	1.7	11.7	2,337.6	1.1	9.40	1	1	1
12/02/2022 17:00	1.7	11.8	2,328.6	1.1	9.30	1	1	1
12/02/2022 18:00	1.7	11.9	2,318.8	1.1	9.30	1	1	1
12/02/2022 19:00	1.7	11.9	2,324.2	1.1	9.30	1	1	1
12/02/2022 20:00	1.7	11.9	2,321.7	1.1	9.30	1	1	1
12/02/2022 21:00	1.7	11.9	2,315.9	1.1	9.30	1	1	1
12/02/2022 22:00	1.7	11.9	2,313.3	1.1	9.30	1	1	1
12/02/2022 23:00	1.7	11.9	2,317.7	1.1	9.30	1	1	1
Average/Sum#:	1.7	12.1	2,255.7	1.1	216.70 #	24 #	24 #	24 #
Minimum:	1.6	11.7	2,168.0	1.1	8.70	1	1	1
Maximum:	1.7	12.5	2,337.6	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	1.7	12.0	2,310.3	1.1	9.20	1	1	1
12/03/2022 01:00	1.7	12.0	2,318.6	1.1	9.30	1	1	1
12/03/2022 02:00	1.7	11.9	2,322.5	1.1	9.30	1	1	1
12/03/2022 03:00	1.7	11.9	2,322.3	1.1	9.30	1	1	1
12/03/2022 04:00	1.7	11.9	2,317.9	1.1	9.30	1	1	1
12/03/2022 05:00	1.7	11.9	2,321.6	1.1	9.30	1	1	1
12/03/2022 06:00	1.6	11.9	2,325.5	1.0	9.30	1	1	1
12/03/2022 07:00	1.7	11.8	2,334.4	1.1	9.30	1	1	1
12/03/2022 08:00	1.7	11.9	2,328.6	1.1	9.30	1	1	1
12/03/2022 09:00	1.7	11.8	2,330.7	1.1	9.30	1	1	1
12/03/2022 10:00	1.7	11.9	2,311.2	1.1	9.20	1	1	1
12/03/2022 11:00	1.7	12.0	2,279.7	1.1	9.10	1	1	1
12/03/2022 12:00	1.7	11.9	2,308.6	1.1	9.20	1	1	1
12/03/2022 13:00	1.6	12.3	2,197.2	1.1	8.80	1	1	1
12/03/2022 14:00	1.7	12.4	2,185.4	1.2	8.70	1	1	1
12/03/2022 15:00	1.7	11.9	2,313.0	1.1	9.30	1	1	1
12/03/2022 16:00	1.7	11.7	2,334.9	1.1	9.30	1	1	1
12/03/2022 17:00	1.8	11.8	2,325.1	1.2	9.30	1	1	1
12/03/2022 18:00	1.7	11.8	2,312.8	1.1	9.30	1	1	1
12/03/2022 19:00	1.7	11.8	2,316.1	1.1	9.30	1	1	1
12/03/2022 20:00	1.7	11.7	2,329.1	1.1	9.30	1	1	1
12/03/2022 21:00	1.8	11.7	2,344.0	1.2	9.40	1	1	1
12/03/2022 22:00	1.8	11.7	2,350.9	1.2	9.40	1	1	1
12/03/2022 23:00	1.7	11.7	2,342.1	1.1	9.40	1	1	1
Average/Sum#:	1.7	11.9	2,311.8	1.1	221.90 #	24 #	24 #	24 #
Minimum:	1.6	11.7	2,185.4	1.0	8.70	1	1	1
Maximum:	1.8	12.4	2,350.9	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	1.6	12.3	2,200.3	1.1	8.80	1	1	1
12/04/2022 01:00	1.7	12.3	2,203.9	1.2	8.80	1	1	1
12/04/2022 02:00	1.7	12.3	2,208.7	1.2	8.80	1	1	1
12/04/2022 03:00	1.7	12.3	2,200.4	1.2	8.80	1	1	1
12/04/2022 04:00	1.7	12.3	2,211.5	1.2	8.80	1	1	1
12/04/2022 05:00	1.7	12.3	2,202.2	1.2	8.80	1	1	1
12/04/2022 06:00	1.7	11.8	2,326.8	1.1	9.30	1	1	1
12/04/2022 07:00	1.8	11.7	2,339.1	1.2	9.40	1	1	1
12/04/2022 08:00	1.7	12.3	2,214.8	1.2	8.90	1	1	1
12/04/2022 09:00	1.7	12.3	2,191.3	1.2	8.80	1	1	1
12/04/2022 10:00	1.7	12.2	2,206.1	1.2	8.80	1	1	1
12/04/2022 11:00	1.7	12.2	2,206.4	1.2	8.80	1	1	1
12/04/2022 12:00	1.7	12.1	2,197.7	1.1	8.80	1	1	1
12/04/2022 13:00	1.7	12.1	2,193.2	1.1	8.80	1	1	1
12/04/2022 14:00	1.7	12.1	2,207.4	1.1	8.80	1	1	1
12/04/2022 15:00	1.7	12.1	2,194.8	1.1	8.80	1	1	1
12/04/2022 16:00	1.8	11.6	2,322.7	1.1	9.30	1	1	1
12/04/2022 17:00	1.8	11.6	2,338.7	1.1	9.40	1	1	1
12/04/2022 18:00	1.7	11.6	2,323.4	1.1	9.30	1	1	1
12/04/2022 19:00	1.7	11.7	2,320.9	1.1	9.30	1	1	1
12/04/2022 20:00	1.8	11.7	2,321.9	1.2	9.30	1	1	1
12/04/2022 21:00	1.7	11.7	2,322.9	1.1	9.30	1	1	1
12/04/2022 22:00	1.7	11.8	2,311.7	1.1	9.20	1	1	1
12/04/2022 23:00	1.7	12.3	2,192.7	1.2	8.80	1	1	1
Average/Sum#:	1.7	12.0	2,248.3	1.2	215.90 #	24 #	24 #	24 #
Minimum:	1.6	11.6	2,191.3	1.1	8.80	1	1	1
Maximum:	1.8	12.3	2,339.1	1.2	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	1.7	12.3	2,194.3	1.2	8.80	1	1	1
12/05/2022 01:00	1.7	12.3	2,191.4	1.2	8.80	1	1	1
12/05/2022 02:00	1.7	12.3	2,196.4	1.2	8.80	1	1	1
12/05/2022 03:00	1.7	12.3	2,190.0	1.2	8.80	1	1	1
12/05/2022 04:00	1.7	12.2	2,215.9	1.2	8.90	1	1	1
12/05/2022 05:00	1.7	11.8	2,320.8	1.1	9.30	1	1	1
12/05/2022 06:00	1.7	11.6	2,344.1	1.1	9.40	1	1	1
12/05/2022 07:00	1.7	11.7	2,340.6	1.1	9.40	1	1	1
12/05/2022 08:00	1.7	11.6	2,351.7	1.1	9.40	1	1	1
12/05/2022 09:00	1.8	11.5	2,366.0	1.1	9.50	1	1	1
12/05/2022 10:00	1.6	11.9	2,141.8	1.0	8.60	1	1	1
12/05/2022 11:00	1.0	13.2	1,826.8	0.8	5.50	1	1	1
12/05/2022 12:00	1.7	12.2	2,161.8	1.2	8.60	1	1	1
12/05/2022 13:00	1.5	12.8	2,027.0	1.1	8.10	1	1	1
12/05/2022 14:00	1.5	12.7	2,056.5	1.1	8.20	1	1	1
12/05/2022 15:00	1.5	12.6	2,074.4	1.1	8.30	1	1	1
12/05/2022 16:00	1.6	12.0	2,222.7	1.1	8.90	1	1	1
12/05/2022 17:00	1.7	11.7	2,298.0	1.1	9.20	1	1	1
12/05/2022 18:00	1.7	11.7	2,298.7	1.1	9.20	1	1	1
12/05/2022 19:00	1.7	11.8	2,302.3	1.1	9.20	1	1	1
12/05/2022 20:00	1.7	11.8	2,299.3	1.1	9.20	1	1	1
12/05/2022 21:00	1.6	12.1	2,221.1	1.1	8.90	1	1	1
12/05/2022 22:00	1.4	12.7	2,074.3	1.0	8.30	1	1	1
12/05/2022 23:00	1.3	12.8	2,049.9	0.9	6.10	1	1	1
Average/Sum#:	1.6	12.2	2,198.6	1.1	207.40 #	24 #	24 #	24 #
Minimum:	1.0	11.5	1,826.8	0.8	5.50	1	1	1
Maximum:	1.8	13.2	2,366.0	1.2	9.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	1.0	13.2	1,968.4	0.8	5.90	1	1	1
12/06/2022 01:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/06/2022 02:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/06/2022 03:00	1.0	13.2	1,969.4	0.8	5.90	1	1	1
12/06/2022 04:00	1.1	13.1	1,984.1	0.8	6.00	1	1	1
12/06/2022 05:00	1.2	13.0	2,012.5	0.9	6.00	1	1	1
12/06/2022 06:00	1.2	13.1	1,985.5	0.9	6.00	1	1	1
12/06/2022 07:00	1.3	12.7	2,090.5	0.9	6.30	1	1	1
12/06/2022 08:00	1.7	11.9	2,283.2	1.1	9.10	1	1	1
12/06/2022 09:00	1.7	12.0	2,270.7	1.1	9.10	1	1	1
12/06/2022 10:00	1.7	12.0	2,264.3	1.1	9.10	1	1	1
12/06/2022 11:00	1.7	12.0	2,260.4	1.1	9.00	1	1	1
12/06/2022 12:00	1.6	12.0	2,241.0	1.1	9.00	1	1	1
12/06/2022 13:00	0.7	13.7	1,779.8	0.6	3.60	1	1	1
12/06/2022 14:00	0.3	14.0	1,314.5	0.3	1.30	1	1	0
12/06/2022 15:00	0.4	14.0	1,314.1	0.3	1.30	1	1	0
12/06/2022 16:00	0.5	13.9	1,512.4	0.4	3.00	1	1	0
12/06/2022 17:00	0.7	13.8	1,808.0	0.6	3.60	1	1	0
12/06/2022 18:00	0.7	13.8	1,807.8	0.6	3.60	1	1	0
12/06/2022 19:00	0.7	13.8	1,817.6	0.6	3.60	1	1	1
12/06/2022 20:00	1.4	12.5	2,137.3	1.0	8.50	1	1	1
12/06/2022 21:00	1.6	12.1	2,235.9	1.1	8.90	1	1	1
12/06/2022 22:00	1.4	12.6	2,105.7	1.0	8.40	1	1	1
12/06/2022 23:00	1.2	13.2	1,973.2	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.0	1,961.3	0.8	144.90 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,314.1	0.3	1.30	1	1	0
Maximum:	1.7	14.0	2,283.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	1.5	12.7	2,084.1	1.1	8.30	1	1	1
12/07/2022 01:00	1.2	13.1	1,990.9	0.9	6.00	1	1	1
12/07/2022 02:00	1.5	12.6	2,139.0	1.1	8.60	1	1	1
12/07/2022 03:00	1.6	12.5	2,147.2	1.1	8.60	1	1	1
12/07/2022 04:00	1.6	12.5	2,164.6	1.1	8.70	1	1	1
12/07/2022 05:00	1.6	12.4	2,173.1	1.1	8.70	1	1	1
12/07/2022 06:00	1.3	12.1	2,253.6	0.9	6.80	1	1	1
12/07/2022 07:00	1.6	12.1	2,265.4	1.1	9.10	1	1	1
12/07/2022 08:00	1.5	12.6	2,137.8	1.1	8.60	1	1	1
12/07/2022 09:00	1.6	12.5	2,172.2	1.1	8.70	1	1	1
12/07/2022 10:00	1.6	12.5	2,171.5	1.1	8.70	1	1	1
12/07/2022 11:00	1.6	12.5	2,169.0	1.1	8.70	1	1	1
12/07/2022 12:00	1.6	12.5	2,144.8	1.1	8.60	1	1	1
12/07/2022 13:00	1.6	12.5	2,120.6	1.1	8.50	1	1	1
12/07/2022 14:00	1.5	12.8	2,065.4	1.1	8.30	1	1	1
12/07/2022 15:00	1.5	12.7	2,088.9	1.1	8.40	1	1	1
12/07/2022 16:00	1.6	12.0	2,262.1	1.1	9.00	1	1	1
12/07/2022 17:00	1.7	11.9	2,276.0	1.1	9.10	1	1	1
12/07/2022 18:00	1.7	11.9	2,279.2	1.1	9.10	1	1	1
12/07/2022 19:00	1.7	11.9	2,277.8	1.1	9.10	1	1	1
12/07/2022 20:00	1.7	11.9	2,278.1	1.1	9.10	1	1	1
12/07/2022 21:00	1.7	12.0	2,272.8	1.1	9.10	1	1	1
12/07/2022 22:00	1.6	12.4	2,185.4	1.1	8.70	1	1	1
12/07/2022 23:00	1.6	12.4	2,181.8	1.1	8.70	1	1	1
Average/Sum#:	1.6	12.4	2,179.2	1.1	205.20 #	24 #	24 #	24 #
Minimum:	1.2	11.9	1,990.9	0.9	6.00	1	1	1
Maximum:	1.7	13.1	2,279.2	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	1.6	12.6	2,140.3	1.1	8.60	1	1	1
12/08/2022 01:00	1.6	12.6	2,134.5	1.1	8.50	1	1	1
12/08/2022 02:00	1.6	12.6	2,131.2	1.1	8.50	1	1	1
12/08/2022 03:00	1.6	12.7	2,128.7	1.2	8.50	1	1	1
12/08/2022 04:00	1.6	12.6	2,153.6	1.1	8.60	1	1	1
12/08/2022 05:00	1.6	12.4	2,211.4	1.1	8.80	1	1	1
12/08/2022 06:00	1.7	12.0	2,286.3	1.1	9.10	1	1	1
12/08/2022 07:00	1.6	12.2	2,241.1	1.1	9.00	1	1	1
12/08/2022 08:00	1.2	13.0	2,033.7	0.9	6.10	1	1	1
12/08/2022 09:00	1.4	12.8	2,111.2	1.0	8.40	1	1	1
12/08/2022 10:00	1.5	12.7	2,119.0	1.1	8.50	1	1	1
12/08/2022 11:00	1.5	12.5	2,150.5	1.1	8.60	1	1	1
12/08/2022 12:00	1.6	12.5	2,152.8	1.1	8.60	1	1	1
12/08/2022 13:00	1.6	12.4	2,166.9	1.1	8.70	1	1	1
12/08/2022 14:00	1.7	12.3	2,177.4	1.2	8.70	1	1	1
12/08/2022 15:00	1.6	12.3	2,183.9	1.1	8.70	1	1	1
12/08/2022 16:00	1.7	11.9	2,283.7	1.1	9.10	1	1	1
12/08/2022 17:00	1.7	11.9	2,284.7	1.1	9.10	1	1	1
12/08/2022 18:00	1.7	11.9	2,287.5	1.1	9.20	1	1	1
12/08/2022 19:00	1.7	11.9	2,285.8	1.1	9.10	1	1	1
12/08/2022 20:00	1.7	11.9	2,287.4	1.1	9.10	1	1	1
12/08/2022 21:00	1.7	11.9	2,285.0	1.1	9.10	1	1	1
12/08/2022 22:00	1.7	12.3	2,194.3	1.2	8.80	1	1	1
12/08/2022 23:00	1.7	12.3	2,195.7	1.2	8.80	1	1	1
Average/Sum#:	1.6	12.3	2,192.8	1.1	208.20 #	24 #	24 #	24 #
Minimum:	1.2	11.9	2,033.7	0.9	6.10	1	1	1
Maximum:	1.7	13.0	2,287.5	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	1.5	12.5	2,144.3	1.1	8.60	1	1	1
12/09/2022 01:00	1.3	12.9	2,046.2	1.0	8.20	1	1	1
12/09/2022 02:00	1.5	12.6	2,142.3	1.1	8.60	1	1	1
12/09/2022 03:00	1.6	12.6	2,144.2	1.1	8.60	1	1	1
12/09/2022 04:00	1.6	12.4	2,194.9	1.1	8.80	1	1	1
12/09/2022 05:00	1.7	12.0	2,296.2	1.1	9.20	1	1	1
12/09/2022 06:00	1.7	12.0	2,298.6	1.1	9.20	1	1	1
12/09/2022 07:00	1.7	12.0	2,286.8	1.1	9.10	1	1	1
12/09/2022 08:00	1.3	12.9	2,072.5	1.0	8.30	1	1	1
12/09/2022 09:00	1.2	13.0	2,032.9	0.9	6.10	1	1	1
12/09/2022 10:00	1.0	13.2	1,984.3	0.8	6.00	1	1	1
12/09/2022 11:00	1.4	12.8	2,074.2	1.0	8.30	1	1	1
12/09/2022 12:00	1.2	13.0	2,007.8	0.9	6.00	1	1	1
12/09/2022 13:00	1.6	12.4	2,160.2	1.1	8.60	1	1	1
12/09/2022 14:00	1.7	12.4	2,163.1	1.2	8.70	1	1	1
12/09/2022 15:00	1.4	12.9	2,055.6	1.0	8.20	1	1	1
12/09/2022 16:00	1.7	11.9	2,286.0	1.1	9.10	1	1	1
12/09/2022 17:00	1.7	11.9	2,285.5	1.1	9.10	1	1	1
12/09/2022 18:00	1.7	11.9	2,285.9	1.1	9.10	1	1	1
12/09/2022 19:00	1.7	11.9	2,287.2	1.1	9.10	1	1	1
12/09/2022 20:00	1.7	11.9	2,289.2	1.1	9.20	1	1	1
12/09/2022 21:00	1.7	11.9	2,287.9	1.1	9.20	1	1	1
12/09/2022 22:00	1.7	11.9	2,286.6	1.1	9.10	1	1	1
12/09/2022 23:00	1.7	11.9	2,280.4	1.1	9.10	1	1	1
Average/Sum#:	1.5	12.4	2,183.0	1.1	203.50 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,984.3	0.8	6.00	1	1	1
Maximum:	1.7	13.2	2,298.6	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.2	13.0	2,020.4	0.9	6.10	1	1	1
12/10/2022 01:00	1.2	13.0	2,016.4	0.9	6.00	1	1	1
12/10/2022 02:00	1.1	13.1	1,980.5	0.8	5.90	1	1	1
12/10/2022 03:00	1.2	13.1	1,981.2	0.9	5.90	1	1	1
12/10/2022 04:00	1.1	13.1	1,976.3	0.8	5.90	1	1	1
12/10/2022 05:00	1.2	13.0	1,986.7	0.9	6.00	1	1	1
12/10/2022 06:00	1.1	13.1	1,973.6	0.8	5.90	1	1	1
12/10/2022 07:00	1.1	13.1	1,981.0	0.8	5.90	1	1	1
12/10/2022 08:00	1.2	12.9	2,021.2	0.9	6.10	1	1	1
12/10/2022 09:00	1.2	12.9	1,998.2	0.9	6.00	1	1	1
12/10/2022 10:00	1.2	13.0	1,974.5	0.9	5.90	1	1	1
12/10/2022 11:00	1.3	12.8	2,015.4	0.9	6.00	1	1	1
12/10/2022 12:00	1.5	12.4	2,121.1	1.0	8.50	1	1	1
12/10/2022 13:00	1.7	12.0	2,182.6	1.1	8.70	1	1	1
12/10/2022 14:00	1.5	12.7	2,018.0	1.1	8.10	1	1	1
12/10/2022 15:00	1.5	12.6	2,043.8	1.1	8.20	1	1	1
12/10/2022 16:00	1.5	12.4	2,112.6	1.0	8.50	1	1	1
12/10/2022 17:00	1.5	12.5	2,071.9	1.1	8.30	1	1	1
12/10/2022 18:00	1.5	12.6	2,072.8	1.1	8.30	1	1	1
12/10/2022 19:00	1.7	11.8	2,252.8	1.1	9.00	1	1	1
12/10/2022 20:00	1.7	12.2	2,175.1	1.2	8.70	1	1	1
12/10/2022 21:00	1.5	12.5	2,080.6	1.1	8.30	1	1	1
12/10/2022 22:00	1.4	12.9	2,016.0	1.0	8.10	1	1	1
12/10/2022 23:00	1.5	12.6	2,077.4	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.7	2,047.9	1.0	172.60 #	24 #	24 #	24 #
Minimum:	1.1	11.8	1,973.6	0.8	5.90	1	1	1
Maximum:	1.7	13.1	2,252.8	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.2	13.1	1,967.5	0.9	5.90	1	1	1
12/11/2022 01:00	1.2	13.1	1,965.0	0.9	5.90	1	1	1
12/11/2022 02:00	1.2	13.1	1,964.9	0.9	5.90	1	1	1
12/11/2022 03:00	1.1	13.1	1,965.4	0.8	5.90	1	1	1
12/11/2022 04:00	1.1	13.1	1,969.0	0.8	5.90	1	1	1
12/11/2022 05:00	1.0	13.1	1,967.8	0.8	5.90	1	1	1
12/11/2022 06:00	1.0	13.1	1,969.4	0.8	5.90	1	1	1
12/11/2022 07:00	1.0	13.2	1,972.0	0.8	5.90	1	1	1
12/11/2022 08:00	1.0	13.2	1,973.7	0.8	5.90	1	1	1
12/11/2022 09:00	1.0	13.1	1,971.0	0.8	5.90	1	1	1
12/11/2022 10:00	1.2	13.1	1,969.2	0.9	5.90	1	1	1
12/11/2022 11:00	1.2	13.1	1,966.9	0.9	5.90	1	1	1
12/11/2022 12:00	1.2	13.1	1,966.8	0.9	5.90	1	1	1
12/11/2022 13:00	1.3	13.1	1,968.3	1.0	7.90	1	1	1
12/11/2022 14:00	1.4	13.1	1,963.5	1.1	7.90	1	1	1
12/11/2022 15:00	1.5	12.7	2,060.7	1.1	8.20	1	1	1
12/11/2022 16:00	1.4	12.8	2,068.6	1.0	8.30	1	1	1
12/11/2022 17:00	1.6	12.5	2,141.4	1.1	8.60	1	1	1
12/11/2022 18:00	1.3	12.9	2,048.1	1.0	8.20	1	1	1
12/11/2022 19:00	1.4	12.8	2,066.7	1.0	8.30	1	1	1
12/11/2022 20:00	1.5	12.6	2,120.2	1.1	8.50	1	1	1
12/11/2022 21:00	1.2	13.1	2,003.0	0.9	6.00	1	1	1
12/11/2022 22:00	1.0	13.2	1,972.7	0.8	5.90	1	1	1
12/11/2022 23:00	1.0	13.2	1,974.3	0.8	5.90	1	1	1
Average/Sum#:	1.2	13.0	1,999.0	0.9	160.40 #	24 #	24 #	24 #
Minimum:	1.0	12.5	1,963.5	0.8	5.90	1	1	1
Maximum:	1.6	13.2	2,141.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.0	13.2	1,981.6	0.8	5.90	1	1	1
12/12/2022 01:00	1.0	13.2	1,982.3	0.8	5.90	1	1	1
12/12/2022 02:00	1.0	13.2	1,981.4	0.8	5.90	1	1	1
12/12/2022 03:00	1.0	13.2	1,978.4	0.8	5.90	1	1	1
12/12/2022 04:00	1.0	13.2	1,977.9	0.8	5.90	1	1	1
12/12/2022 05:00	1.4	12.7	2,119.2	1.0	8.50	1	1	1
12/12/2022 06:00	1.6	12.2	2,218.1	1.1	8.90	1	1	1
12/12/2022 07:00	1.5	12.3	2,198.9	1.0	8.80	1	1	1
12/12/2022 08:00	1.3	12.8	2,076.7	0.9	6.20	1	1	1
12/12/2022 09:00	1.3	12.9	2,068.8	1.0	8.30	1	1	1
12/12/2022 10:00	1.0	13.3	1,973.0	0.8	5.90	1	1	1
12/12/2022 11:00	1.0	13.2	1,970.2	0.8	5.90	1	1	1
12/12/2022 12:00	1.0	13.2	1,970.6	0.8	5.90	1	1	1
12/12/2022 13:00	1.1	13.2	1,969.6	0.8	5.90	1	1	1
12/12/2022 14:00	1.1	13.2	1,968.0	0.8	5.90	1	1	1
12/12/2022 15:00	1.2	13.2	1,967.7	0.9	5.90	1	1	1
12/12/2022 16:00	1.5	12.5	2,153.9	1.1	8.60	1	1	1
12/12/2022 17:00	1.7	12.1	2,250.2	1.1	9.00	1	1	1
12/12/2022 18:00	1.6	11.8	2,314.5	1.0	9.30	1	1	1
12/12/2022 19:00	1.7	11.8	2,316.4	1.1	9.30	1	1	1
12/12/2022 20:00	1.6	11.8	2,320.3	1.0	9.30	1	1	1
12/12/2022 21:00	1.7	12.0	2,269.9	1.1	9.10	1	1	1
12/12/2022 22:00	1.6	12.3	2,201.9	1.1	8.80	1	1	1
12/12/2022 23:00	1.3	13.0	2,035.1	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.7	2,094.4	0.9	177.10 #	24 #	24 #	24 #
Minimum:	1.0	11.8	1,967.7	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,320.3	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	1.6	12.6	2,155.3	1.1	8.60	1	1	1
12/13/2022 01:00	1.6	12.5	2,162.4	1.1	8.60	1	1	1
12/13/2022 02:00	1.6	12.5	2,171.0	1.1	8.70	1	1	1
12/13/2022 03:00	1.6	12.5	2,161.4	1.1	8.60	1	1	1
12/13/2022 04:00	1.6	12.4	2,201.7	1.1	8.80	1	1	1
12/13/2022 05:00	1.6	12.1	2,286.6	1.1	9.10	1	1	1
12/13/2022 06:00	1.6	11.9	2,323.5	1.0	9.30	1	1	1
12/13/2022 07:00	1.7	11.9	2,314.5	1.1	9.30	1	1	1
12/13/2022 08:00	1.4	12.5	2,149.7	1.0	8.60	1	1	1
12/13/2022 09:00	1.2	13.1	2,013.4	0.9	6.00	1	1	1
12/13/2022 10:00	1.0	13.3	1,978.2	0.8	5.90	1	1	1
12/13/2022 11:00	1.1	13.2	1,972.8	0.8	5.90	1	1	1
12/13/2022 12:00	1.2	13.2	1,971.6	0.9	5.90	1	1	1
12/13/2022 13:00	1.2	13.2	1,969.9	0.9	5.90	1	1	1
12/13/2022 14:00	1.3	13.2	1,968.6	1.0	7.90	1	1	1
12/13/2022 15:00	1.5	12.8	2,076.2	1.1	8.30	1	1	1
12/13/2022 16:00	1.6	11.9	2,282.3	1.0	9.10	1	1	1
12/13/2022 17:00	1.7	11.8	2,299.2	1.1	9.20	1	1	1
12/13/2022 18:00	1.7	11.9	2,297.3	1.1	9.20	1	1	1
12/13/2022 19:00	1.6	11.9	2,296.7	1.0	9.20	1	1	1
12/13/2022 20:00	1.7	11.9	2,293.3	1.1	9.20	1	1	1
12/13/2022 21:00	1.7	12.0	2,293.3	1.1	9.20	1	1	1
12/13/2022 22:00	1.7	12.0	2,297.4	1.1	9.20	1	1	1
12/13/2022 23:00	1.6	11.9	2,293.5	1.0	9.20	1	1	1
Average/Sum#:	1.5	12.4	2,176.2	1.0	198.90 #	24 #	24 #	24 #
Minimum:	1.0	11.8	1,968.6	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,323.5	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	1.6	12.4	2,201.0	1.1	8.80	1	1	1
12/14/2022 01:00	1.6	12.4	2,205.8	1.1	8.80	1	1	1
12/14/2022 02:00	1.6	12.4	2,207.5	1.1	8.80	1	1	1
12/14/2022 03:00	1.6	12.5	2,202.0	1.1	8.80	1	1	1
12/14/2022 04:00	1.6	12.5	2,195.8	1.1	8.80	1	1	1
12/14/2022 05:00	1.6	12.0	2,307.3	1.1	9.20	1	1	1
12/14/2022 06:00	1.6	12.0	2,311.1	1.1	9.20	1	1	1
12/14/2022 07:00	1.6	12.1	2,277.8	1.1	9.10	1	1	1
12/14/2022 08:00	1.4	12.9	2,081.0	1.0	8.30	1	1	1
12/14/2022 09:00	1.2	13.1	2,011.1	0.9	6.00	1	1	1
12/14/2022 10:00	1.2	13.0	2,028.4	0.9	6.10	1	1	1
12/14/2022 11:00	1.0	13.2	1,974.9	0.8	5.90	1	1	1
12/14/2022 12:00	1.0	13.2	1,976.5	0.8	5.90	1	1	1
12/14/2022 13:00	1.0	13.2	1,978.3	0.8	5.90	1	1	1
12/14/2022 14:00	1.0	13.2	1,975.2	0.8	5.90	1	1	1
12/14/2022 15:00	1.2	13.1	2,018.4	0.9	6.10	1	1	1
12/14/2022 16:00	1.6	12.2	2,219.4	1.1	8.90	1	1	1
12/14/2022 17:00	1.7	11.9	2,291.2	1.1	9.20	1	1	1
12/14/2022 18:00	1.7	11.9	2,288.1	1.1	9.20	1	1	1
12/14/2022 19:00	1.7	11.9	2,292.6	1.1	9.20	1	1	1
12/14/2022 20:00	1.7	12.0	2,292.9	1.1	9.20	1	1	1
12/14/2022 21:00	1.6	12.0	2,291.3	1.1	9.20	1	1	1
12/14/2022 22:00	1.6	12.1	2,265.2	1.1	9.10	1	1	1
12/14/2022 23:00	1.6	12.5	2,178.6	1.1	8.70	1	1	1
Average/Sum#:	1.5	12.5	2,169.6	1.0	194.30 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,974.9	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,311.1	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2022 00:00	1.6	12.0	2,300.0	1.1	9.20	1	1	1
12/15/2022 01:00	1.7	11.9	2,310.7	1.1	9.20	1	1	1
12/15/2022 02:00	1.6	11.9	2,310.7	1.0	9.20	1	1	1
12/15/2022 03:00	1.7	11.9	2,312.5	1.1	9.30	1	1	1
12/15/2022 04:00	1.7	11.9	2,317.5	1.1	9.30	1	1	1
12/15/2022 05:00	1.7	11.9	2,320.2	1.1	9.30	1	1	1
12/15/2022 06:00	1.5	11.9	2,319.6	1.0	9.30	1	1	1
12/15/2022 07:00	1.7	11.9	2,314.8	1.1	9.30	1	1	1
12/15/2022 08:00	1.6	12.2	2,232.9	1.1	8.90	1	1	1
12/15/2022 09:00	1.6	12.1	2,231.2	1.1	8.90	1	1	1
12/15/2022 10:00	1.3	13.1	1,978.7	1.0	7.90	1	1	1
12/15/2022 11:00	1.4	13.1	1,990.3	1.1	8.00	1	1	1
12/15/2022 12:00	1.5	12.9	2,023.1	1.1	8.10	1	1	1
12/15/2022 13:00	1.5	12.8	2,045.1	1.1	8.20	1	1	1
12/15/2022 14:00	1.6	12.6	2,102.6	1.1	8.40	1	1	1
12/15/2022 15:00	1.6	11.9	2,258.0	1.0	9.00	1	1	1
12/15/2022 16:00	1.6	11.9	2,270.0	1.0	9.10	1	1	1
12/15/2022 17:00	1.6	11.9	2,268.1	1.0	9.10	1	1	1
12/15/2022 18:00	1.6	12.0	2,258.2	1.1	9.00	1	1	1
12/15/2022 19:00	1.7	12.0	2,251.3	1.1	9.00	1	1	1
12/15/2022 20:00	1.6	12.0	2,253.0	1.1	9.00	1	1	1
12/15/2022 21:00	1.6	12.1	2,254.6	1.1	9.00	1	1	1
12/15/2022 22:00	1.6	12.1	2,260.1	1.1	9.00	1	1	1
12/15/2022 23:00	1.6	12.2	2,242.5	1.1	9.00	1	1	1
Average/Sum#:	1.6	12.2	2,226.1	1.1	213.70 #	24 #	24 #	24 #
Minimum:	1.3	11.9	1,978.7	1.0	7.90	1	1	1
Maximum:	1.7	13.1	2,320.2	1.1	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	1.1	13.1	1,997.7	0.8	6.00	1	1	1
12/16/2022 01:00	1.0	13.2	1,975.0	0.8	5.90	1	1	1
12/16/2022 02:00	1.0	13.2	1,975.1	0.8	5.90	1	1	1
12/16/2022 03:00	1.0	13.2	1,977.9	0.8	5.90	1	1	1
12/16/2022 04:00	1.0	13.2	1,976.0	0.8	5.90	1	1	1
12/16/2022 05:00	1.1	13.2	1,986.3	0.8	6.00	1	1	1
12/16/2022 06:00	1.2	12.7	2,114.7	0.9	6.30	1	1	1
12/16/2022 07:00	1.5	12.4	2,213.4	1.0	8.90	1	1	1
12/16/2022 08:00	1.6	12.6	2,148.7	1.1	8.60	1	1	1
12/16/2022 09:00	1.4	12.8	2,073.1	1.0	8.30	1	1	1
12/16/2022 10:00	0.5	13.9	1,533.9	0.4	3.10	1	1	0
12/16/2022 11:00	0.5	14.0	1,455.0	0.4	2.90	1	1	0
12/16/2022 12:00	0.4	14.0	1,319.9	0.3	1.30	1	1	0
12/16/2022 13:00	0.4	14.0	1,322.2	0.3	1.30	1	1	0
12/16/2022 14:00	0.6	13.9	1,577.2	0.5	3.20	1	1	0
12/16/2022 15:00	0.6	13.9	1,550.0	0.5	3.10	1	1	1
12/16/2022 16:00	1.5	12.4	2,166.8	1.0	8.70	1	1	1
12/16/2022 17:00	1.6	12.1	2,236.7	1.1	8.90	1	1	1
12/16/2022 18:00	1.6	12.4	2,162.4	1.1	8.60	1	1	1
12/16/2022 19:00	1.6	12.4	2,168.7	1.1	8.70	1	1	1
12/16/2022 20:00	1.6	12.0	2,256.4	1.1	9.00	1	1	1
12/16/2022 21:00	1.6	12.2	2,198.9	1.1	8.80	1	1	1
12/16/2022 22:00	1.3	12.7	2,089.5	0.9	6.30	1	1	1
12/16/2022 23:00	1.1	13.2	1,975.1	0.8	5.90	1	1	1
Average/Sum#:	1.1	13.0	1,935.4	0.8	147.50 #	24 #	24 #	19 #
Minimum:	0.4	12.0	1,319.9	0.3	1.30	1	1	0
Maximum:	1.6	14.0	2,256.4	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	1.6	12.5	2,148.3	1.1	8.60	1	1	1
12/17/2022 01:00	1.6	12.5	2,151.2	1.1	8.60	1	1	1
12/17/2022 02:00	1.6	12.6	2,142.6	1.1	8.60	1	1	1
12/17/2022 03:00	1.6	12.6	2,153.4	1.1	8.60	1	1	1
12/17/2022 04:00	1.6	12.5	2,154.4	1.1	8.60	1	1	1
12/17/2022 05:00	1.6	12.6	2,151.3	1.1	8.60	1	1	1
12/17/2022 06:00	1.6	12.1	2,242.2	1.1	9.00	1	1	1
12/17/2022 07:00	1.4	12.7	2,099.3	1.0	8.40	1	1	1
12/17/2022 08:00	1.6	12.5	2,165.9	1.1	8.70	1	1	1
12/17/2022 09:00	1.5	12.7	2,124.8	1.1	8.50	1	1	1
12/17/2022 10:00	1.2	13.1	2,009.5	0.9	6.00	1	1	1
12/17/2022 11:00	1.0	13.2	1,977.3	0.8	5.90	1	1	1
12/17/2022 12:00	1.1	13.2	1,970.0	0.8	5.90	1	1	1
12/17/2022 13:00	1.2	13.2	1,970.2	0.9	5.90	1	1	1
12/17/2022 14:00	1.3	13.1	1,991.1	1.0	8.00	1	1	1
12/17/2022 15:00	1.6	12.6	2,124.4	1.1	8.50	1	1	1
12/17/2022 16:00	1.6	11.9	2,279.1	1.0	9.10	1	1	1
12/17/2022 17:00	1.6	12.0	2,247.4	1.1	9.00	1	1	1
12/17/2022 18:00	1.6	12.4	2,159.7	1.1	8.60	1	1	1
12/17/2022 19:00	1.6	11.9	2,288.0	1.0	9.20	1	1	1
12/17/2022 20:00	1.7	11.9	2,291.4	1.1	9.20	1	1	1
12/17/2022 21:00	1.6	11.9	2,292.3	1.0	9.20	1	1	1
12/17/2022 22:00	1.6	11.9	2,284.2	1.0	9.10	1	1	1
12/17/2022 23:00	1.6	12.3	2,192.5	1.1	8.80	1	1	1
Average/Sum#:	1.5	12.5	2,150.4	1.0	198.60 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,970.0	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,292.3	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	1.6	12.5	2,141.4	1.1	8.60	1	1	1
12/18/2022 01:00	1.6	12.6	2,140.8	1.1	8.60	1	1	1
12/18/2022 02:00	1.2	13.1	2,023.7	0.9	6.10	1	1	1
12/18/2022 03:00	1.1	13.3	1,985.2	0.9	6.00	1	1	1
12/18/2022 04:00	1.5	12.7	2,140.3	1.1	8.60	1	1	1
12/18/2022 05:00	1.6	12.6	2,162.0	1.1	8.60	1	1	1
12/18/2022 06:00	1.5	12.4	2,182.1	1.0	8.70	1	1	1
12/18/2022 07:00	1.7	12.3	2,219.3	1.2	8.90	1	1	1
12/18/2022 08:00	1.4	12.7	2,091.7	1.0	8.40	1	1	1
12/18/2022 09:00	0.6	13.9	1,607.9	0.5	3.20	1	1	0
12/18/2022 10:00	0.5	13.9	1,552.2	0.4	3.10	1	1	0
12/18/2022 11:00	0.5	13.9	1,544.4	0.4	3.10	1	1	0
12/18/2022 12:00	0.5	14.0	1,404.3	0.4	2.80	1	1	0
12/18/2022 13:00	0.5	14.0	1,395.8	0.4	2.80	1	1	0
12/18/2022 14:00	0.6	13.9	1,634.8	0.5	3.30	1	1	0
12/18/2022 15:00	0.6	13.9	1,645.9	0.5	3.30	1	1	1
12/18/2022 16:00	1.4	12.5	2,143.3	1.0	8.60	1	1	1
12/18/2022 17:00	1.6	12.0	2,254.0	1.1	9.00	1	1	1
12/18/2022 18:00	1.6	11.9	2,283.9	1.0	9.10	1	1	1
12/18/2022 19:00	1.7	11.9	2,288.7	1.1	9.20	1	1	1
12/18/2022 20:00	1.6	12.2	2,245.0	1.1	9.00	1	1	1
12/18/2022 21:00	1.6	12.4	2,208.9	1.1	8.80	1	1	1
12/18/2022 22:00	1.6	12.4	2,205.7	1.1	8.80	1	1	1
12/18/2022 23:00	1.2	13.0	2,049.4	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.9	1,981.3	0.9	162.70 #	24 #	24 #	18 #
Minimum:	0.5	11.9	1,395.8	0.4	2.80	1	1	0
Maximum:	1.7	14.0	2,288.7	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	1.5	12.7	2,141.9	1.1	8.60	1	1	1
12/19/2022 01:00	1.5	12.6	2,153.5	1.1	8.60	1	1	1
12/19/2022 02:00	1.5	12.6	2,149.7	1.1	8.60	1	1	1
12/19/2022 03:00	1.5	12.6	2,152.1	1.1	8.60	1	1	1
12/19/2022 04:00	1.6	12.5	2,185.5	1.1	8.70	1	1	1
12/19/2022 05:00	1.7	12.0	2,309.6	1.1	9.20	1	1	1
12/19/2022 06:00	1.6	12.0	2,310.1	1.1	9.20	1	1	1
12/19/2022 07:00	1.7	12.0	2,310.1	1.1	9.20	1	1	1
12/19/2022 08:00	1.6	12.2	2,262.0	1.1	9.00	1	1	1
12/19/2022 09:00	1.7	12.1	2,274.3	1.1	9.10	1	1	1
12/19/2022 10:00	1.6	12.5	2,181.5	1.1	8.70	1	1	1
12/19/2022 11:00	1.6	12.5	2,181.8	1.1	8.70	1	1	1
12/19/2022 12:00	1.6	12.6	2,174.1	1.1	8.70	1	1	1
12/19/2022 13:00	1.6	12.6	2,164.7	1.1	8.70	1	1	1
12/19/2022 14:00	1.6	12.6	2,166.8	1.1	8.70	1	1	1
12/19/2022 15:00	1.6	12.3	2,231.0	1.1	8.90	1	1	1
12/19/2022 16:00	1.6	12.1	2,274.5	1.1	9.10	1	1	1
12/19/2022 17:00	1.7	12.1	2,275.0	1.1	9.10	1	1	1
12/19/2022 18:00	1.7	12.1	2,277.1	1.1	9.10	1	1	1
12/19/2022 19:00	1.6	12.1	2,280.3	1.1	9.10	1	1	1
12/19/2022 20:00	1.7	12.2	2,277.2	1.2	9.10	1	1	1
12/19/2022 21:00	1.7	12.2	2,277.4	1.2	9.10	1	1	1
12/19/2022 22:00	1.7	12.1	2,283.3	1.1	9.10	1	1	1
12/19/2022 23:00	1.7	12.1	2,278.8	1.1	9.10	1	1	1
Average/Sum#:	1.6	12.3	2,232.2	1.1	214.00 #	24 #	24 #	24 #
Minimum:	1.5	12.0	2,141.9	1.1	8.60	1	1	1
Maximum:	1.7	12.7	2,310.1	1.2	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	1.6	12.6	2,180.6	1.1	8.70	1	1	1
12/20/2022 01:00	1.6	12.6	2,178.9	1.1	8.70	1	1	1
12/20/2022 02:00	1.6	12.5	2,184.2	1.1	8.70	1	1	1
12/20/2022 03:00	1.6	12.5	2,189.6	1.1	8.80	1	1	1
12/20/2022 04:00	1.6	12.5	2,190.7	1.1	8.80	1	1	1
12/20/2022 05:00	1.6	12.5	2,190.8	1.1	8.80	1	1	1
12/20/2022 06:00	1.5	12.1	2,291.6	1.0	9.20	1	1	1
12/20/2022 07:00	1.7	12.1	2,284.8	1.1	9.10	1	1	1
12/20/2022 08:00	1.5	12.6	2,170.4	1.1	8.70	1	1	1
12/20/2022 09:00	1.6	12.5	2,170.0	1.1	8.70	1	1	1
12/20/2022 10:00	1.5	12.7	2,128.2	1.1	8.50	1	1	1
12/20/2022 11:00	1.5	12.8	2,095.1	1.1	8.40	1	1	1
12/20/2022 12:00	1.0	13.3	1,961.4	0.8	5.90	1	1	1
12/20/2022 13:00	1.0	13.3	1,965.5	0.8	5.90	1	1	1
12/20/2022 14:00	1.0	13.3	1,964.0	0.8	5.90	1	1	1
12/20/2022 15:00	1.3	13.0	2,038.6	1.0	8.20	1	1	1
12/20/2022 16:00	1.6	12.3	2,199.8	1.1	8.80	1	1	1
12/20/2022 17:00	1.7	12.0	2,266.0	1.1	9.10	1	1	1
12/20/2022 18:00	1.6	12.0	2,265.9	1.1	9.10	1	1	1
12/20/2022 19:00	1.6	12.0	2,259.4	1.1	9.00	1	1	1
12/20/2022 20:00	1.7	12.0	2,259.9	1.1	9.00	1	1	1
12/20/2022 21:00	1.6	12.4	2,168.4	1.1	8.70	1	1	1
12/20/2022 22:00	1.6	12.4	2,167.9	1.1	8.70	1	1	1
12/20/2022 23:00	1.6	12.2	2,226.6	1.1	8.90	1	1	1
Average/Sum#:	1.5	12.5	2,166.6	1.1	202.30 #	24 #	24 #	24 #
Minimum:	1.0	12.0	1,961.4	0.8	5.90	1	1	1
Maximum:	1.7	13.3	2,291.6	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2022 00:00	1.7	12.0	2,286.1	1.1	9.10	1	1	1
12/21/2022 01:00	1.7	12.0	2,284.9	1.1	9.10	1	1	1
12/21/2022 02:00	1.7	12.0	2,281.3	1.1	9.10	1	1	1
12/21/2022 03:00	1.7	12.0	2,289.0	1.1	9.20	1	1	1
12/21/2022 04:00	1.7	12.0	2,282.4	1.1	9.10	1	1	1
12/21/2022 05:00	1.7	12.0	2,284.7	1.1	9.10	1	1	1
12/21/2022 06:00	1.6	12.0	2,284.5	1.1	9.10	1	1	1
12/21/2022 07:00	1.7	12.0	2,283.3	1.1	9.10	1	1	1
12/21/2022 08:00	0.0	0.0	2,268.8	0.0	0.00	1	1	1
12/21/2022 09:00	1.6	12.2	2,259.9	1.1	9.00	1	1	1
12/21/2022 10:00	1.6	12.2	2,253.9	1.1	9.00	1	1	1
12/21/2022 11:00	1.6	12.3	2,219.0	1.1	8.90	1	1	1
12/21/2022 12:00	1.6	12.2	2,236.9	1.1	8.90	1	1	1
12/21/2022 13:00	1.7	12.1	2,229.8	1.1	8.90	1	1	1
12/21/2022 14:00	1.6	12.5	2,160.3	1.1	8.60	1	1	1
12/21/2022 15:00	1.6	12.1	2,234.3	1.1	8.90	1	1	1
12/21/2022 16:00	1.6	12.0	2,257.4	1.1	9.00	1	1	1
12/21/2022 17:00	1.7	12.0	2,255.2	1.1	9.00	1	1	1
12/21/2022 18:00	1.6	12.0	2,258.5	1.1	9.00	1	1	1
12/21/2022 19:00	1.7	12.0	2,256.4	1.1	9.00	1	1	1
12/21/2022 20:00	1.7	12.1	2,252.8	1.1	9.00	1	1	1
12/21/2022 21:00	1.7	12.1	2,253.7	1.1	9.00	1	1	1
12/21/2022 22:00	1.6	12.1	2,250.9	1.1	9.00	1	1	1
12/21/2022 23:00	1.7	12.1	2,248.9	1.1	9.00	1	1	1
Average/Sum#:	1.7	12.1	2,257.2	1.1	207.10 #	24 #	24 #	24 #
Minimum:	1.6	12.0	2,160.3	1.1	8.60	1	1	1
Maximum:	1.7	12.5	2,289.0	1.1	9.20	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	1.6	12.4	2,185.3	1.1	8.70	1	1	1
12/22/2022 01:00	1.1	13.2	1,981.3	0.8	5.90	1	1	1
12/22/2022 02:00	1.0	13.2	1,968.8	0.8	5.90	1	1	1
12/22/2022 03:00	1.0	13.2	1,968.0	0.8	5.90	1	1	1
12/22/2022 04:00	1.3	12.8	2,091.8	0.9	6.30	1	1	1
12/22/2022 05:00	1.6	12.4	2,221.8	1.1	8.90	1	1	1
12/22/2022 06:00	1.7	12.1	2,268.5	1.1	9.10	1	1	1
12/22/2022 07:00	1.7	12.1	2,266.2	1.1	9.10	1	1	1
12/22/2022 08:00	1.7	12.2	2,248.9	1.2	9.00	1	1	1
12/22/2022 09:00	1.5	12.6	2,149.4	1.1	8.60	1	1	1
12/22/2022 10:00	1.5	12.6	2,146.2	1.1	8.60	1	1	1
12/22/2022 11:00	1.5	12.6	2,143.8	1.1	8.60	1	1	1
12/22/2022 12:00	1.5	12.6	2,141.5	1.1	8.60	1	1	1
12/22/2022 13:00	1.5	12.6	2,143.3	1.1	8.60	1	1	1
12/22/2022 14:00	1.5	12.6	2,149.6	1.1	8.60	1	1	1
12/22/2022 15:00	1.6	12.3	2,214.6	1.1	8.90	1	1	1
12/22/2022 16:00	1.6	12.3	2,209.7	1.1	8.80	1	1	1
12/22/2022 17:00	1.7	12.1	2,256.5	1.1	9.00	1	1	1
12/22/2022 18:00	1.7	12.1	2,261.1	1.1	9.00	1	1	1
12/22/2022 19:00	1.7	12.1	2,267.4	1.1	9.10	1	1	1
12/22/2022 20:00	1.7	12.1	2,262.7	1.1	9.10	1	1	1
12/22/2022 21:00	1.7	12.1	2,260.5	1.1	9.00	1	1	1
12/22/2022 22:00	1.7	12.3	2,215.3	1.2	8.90	1	1	1
12/22/2022 23:00	1.4	12.8	2,077.3	1.0	8.30	1	1	1
Average/Sum#:	1.5	12.5	2,170.8	1.1	200.50 #	24 #	24 #	24 #
Minimum:	1.0	12.1	1,968.0	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,268.5	1.2	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	1.6	12.3	2,228.2	1.1	8.90	1	1	1
12/23/2022 01:00	1.7	12.1	2,265.3	1.1	9.10	1	1	1
12/23/2022 02:00	1.7	12.1	2,261.5	1.1	9.00	1	1	1
12/23/2022 03:00	1.7	12.1	2,261.6	1.1	9.00	1	1	1
12/23/2022 04:00	1.7	12.1	2,262.1	1.1	9.00	1	1	1
12/23/2022 05:00	1.7	12.1	2,259.9	1.1	9.00	1	1	1
12/23/2022 06:00	1.6	12.1	2,259.7	1.1	9.00	1	1	1
12/23/2022 07:00	1.6	12.2	2,240.1	1.1	9.00	1	1	1
12/23/2022 08:00	1.6	12.4	2,187.9	1.1	8.80	1	1	1
12/23/2022 09:00	1.6	12.4	2,182.4	1.1	8.70	1	1	1
12/23/2022 10:00	1.6	12.5	2,137.6	1.1	8.60	1	1	1
12/23/2022 11:00	1.6	12.5	2,141.7	1.1	8.60	1	1	1
12/23/2022 12:00	1.4	12.9	2,027.4	1.0	8.10	1	1	1
12/23/2022 13:00	1.1	13.2	1,960.0	0.8	5.90	1	1	1
12/23/2022 14:00	1.1	13.2	1,953.8	0.8	5.90	1	1	1
12/23/2022 15:00	1.4	12.8	2,064.7	1.0	8.30	1	1	1
12/23/2022 16:00	1.7	12.0	2,253.1	1.1	9.00	1	1	1
12/23/2022 17:00	1.7	12.0	2,254.2	1.1	9.00	1	1	1
12/23/2022 18:00	1.7	12.0	2,260.1	1.1	9.00	1	1	1
12/23/2022 19:00	1.7	12.0	2,252.4	1.1	9.00	1	1	1
12/23/2022 20:00	1.7	12.0	2,248.8	1.1	9.00	1	1	1
12/23/2022 21:00	1.7	12.0	2,253.2	1.1	9.00	1	1	1
12/23/2022 22:00	1.7	12.0	2,252.2	1.1	9.00	1	1	1
12/23/2022 23:00	1.6	12.0	2,242.9	1.1	9.00	1	1	1
Average/Sum#:	1.6	12.3	2,196.3	1.1	206.90 #	24 #	24 #	24 #
Minimum:	1.1	12.0	1,953.8	0.8	5.90	1	1	1
Maximum:	1.7	13.2	2,265.3	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	1.6	12.5	2,130.9	1.1	8.50	1	1	1
12/24/2022 01:00	1.6	12.6	2,124.1	1.1	8.50	1	1	1
12/24/2022 02:00	1.1	13.2	1,963.2	0.8	5.90	1	1	1
12/24/2022 03:00	1.1	13.2	1,955.6	0.8	5.90	1	1	1
12/24/2022 04:00	1.1	13.2	1,955.0	0.8	5.90	1	1	1
12/24/2022 05:00	1.1	13.2	1,953.0	0.8	5.90	1	1	1
12/24/2022 06:00	1.2	13.1	1,979.9	0.9	5.90	1	1	1
12/24/2022 07:00	1.2	13.0	2,010.1	0.9	6.00	1	1	1
12/24/2022 08:00	0.9	13.4	1,837.3	0.7	5.50	1	1	1
12/24/2022 09:00	0.4	13.9	1,316.3	0.3	1.30	1	1	0
12/24/2022 10:00	0.6	13.9	1,548.3	0.5	3.10	1	1	0
12/24/2022 11:00	0.6	13.9	1,547.9	0.5	3.10	1	1	0
12/24/2022 12:00	0.6	13.9	1,552.0	0.5	3.10	1	1	0
12/24/2022 13:00	0.6	13.9	1,554.4	0.5	3.10	1	1	0
12/24/2022 14:00	0.7	13.9	1,730.3	0.6	3.50	1	1	0
12/24/2022 15:00	0.7	13.9	1,734.3	0.6	3.50	1	1	0
12/24/2022 16:00	0.6	13.9	1,590.2	0.5	3.20	1	1	1
12/24/2022 17:00	1.1	13.1	1,969.4	0.8	5.90	1	1	1
12/24/2022 18:00	1.1	13.1	1,965.8	0.8	5.90	1	1	1
12/24/2022 19:00	1.1	13.1	1,965.9	0.8	5.90	1	1	1
12/24/2022 20:00	1.1	13.1	1,967.3	0.8	5.90	1	1	1
12/24/2022 21:00	1.1	13.1	1,962.5	0.8	5.90	1	1	1
12/24/2022 22:00	1.1	13.2	1,965.3	0.8	5.90	1	1	1
12/24/2022 23:00	1.1	13.1	1,967.2	0.8	5.90	1	1	1
Average/Sum#:	1.0	13.4	1,843.6	0.7	123.20 #	24 #	24 #	17 #
Minimum:	0.4	12.5	1,316.3	0.3	1.30	1	1	0
Maximum:	1.6	13.9	2,130.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.1	13.1	1,946.8	0.8	5.80	1	1	1
12/25/2022 01:00	6.3	15.6	592.2	7.0	3.39	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/25/2022 18:00	28.4	17.7	345.3	52.4	47.95	1	0	0
12/25/2022 19:00	9.6	17.3	411.1	15.7	23.80	1	0	0
12/25/2022 20:00	10.3	15.9	780.4	12.2	35.10	1	0	0
12/25/2022 21:00	0.4	13.9	1,417.5	0.3	1.40	1	1	0
12/25/2022 22:00	0.6	13.9	1,455.7	0.5	2.90	1	1	0
12/25/2022 23:00	0.6	13.9	1,477.4	0.5	3.00	1	1	0
Average/Sum#:	7.2	15.2	1,053.3	11.2	123.34 #	8 #	4 #	1 #
Minimum:	0.4	13.1	345.3	0.3	1.40	0	0	0
Maximum:	28.4	17.7	1,946.8	52.4	47.95	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2022 00:00	0.8	13.8	1,763.9	0.7	3.50	1	1	0
12/26/2022 01:00	0.5	13.8	1,543.0	0.4	3.10	1	1	0
12/26/2022 02:00	0.6	13.8	1,700.6	0.5	3.40	1	1	0
12/26/2022 03:00	0.6	13.8	1,721.9	0.5	3.40	1	1	0
12/26/2022 04:00	0.6	13.8	1,721.7	0.5	3.40	1	1	0
12/26/2022 05:00	0.6	13.8	1,737.5	0.5	3.50	1	1	0
12/26/2022 06:00	0.6	13.8	1,736.8	0.5	3.50	1	1	0
12/26/2022 07:00	0.6	13.8	1,728.0	0.5	3.50	1	1	0
12/26/2022 08:00	0.6	13.8	1,734.8	0.5	3.50	1	1	0
12/26/2022 09:00	0.5	13.9	1,548.8	0.4	3.10	1	1	0
12/26/2022 10:00	0.5	13.9	1,544.0	0.4	3.10	1	1	0
12/26/2022 11:00	0.5	13.9	1,535.6	0.4	3.10	1	1	0
12/26/2022 12:00	0.5	13.9	1,526.6	0.4	3.10	1	1	0
12/26/2022 13:00	0.6	13.9	1,547.1	0.5	3.10	1	1	0
12/26/2022 14:00	0.6	13.8	1,610.5	0.5	3.20	1	1	0
12/26/2022 15:00	0.6	13.8	1,740.0	0.5	3.50	1	1	0
12/26/2022 16:00	0.7	13.8	1,774.3	0.6	3.50	1	1	1
12/26/2022 17:00	1.3	12.6	2,122.6	0.9	6.40	1	1	1
12/26/2022 18:00	1.6	12.4	2,163.9	1.1	8.70	1	1	1
12/26/2022 19:00	1.2	13.0	2,015.8	0.9	6.00	1	1	1
12/26/2022 20:00	1.2	13.1	2,000.4	0.9	6.00	1	1	1
12/26/2022 21:00	1.1	13.2	1,969.8	0.8	5.90	1	1	1
12/26/2022 22:00	1.1	13.2	1,947.6	0.8	5.80	1	1	1
12/26/2022 23:00	4.9	15.6	609.2	5.5	2.81	1	0	0
Average/Sum#:	0.9	13.7	1,710.2	0.8	98.11 #	24 #	23 #	7 #
Minimum:	0.5	12.4	609.2	0.4	2.81	1	0	0
Maximum:	4.9	15.6	2,163.9	5.5	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/27/2022 01:00	0.1	18.8	198.2	0.3	0.04	1	0	0
12/27/2022 02:00	7.2	16.0	756.8	8.7	24.20	1	0	0
12/27/2022 03:00	0.5	13.8	1,538.4	0.4	3.10	1	1	0
12/27/2022 04:00	0.6	13.9	1,539.3	0.5	3.10	1	1	0
12/27/2022 05:00	0.7	13.8	1,685.4	0.6	3.40	1	1	0
12/27/2022 06:00	0.5	13.9	1,397.3	0.4	2.80	1	1	0
12/27/2022 07:00	0.8	13.8	1,731.2	0.7	3.50	1	1	0
12/27/2022 08:00	0.7	13.8	1,701.6	0.6	3.40	1	1	1
12/27/2022 09:00	1.1	12.9	1,972.8	0.8	5.90	1	1	1
12/27/2022 10:00	1.3	12.9	1,967.9	1.0	7.90	1	1	1
12/27/2022 11:00	1.4	12.9	1,970.4	1.0	7.90	1	1	1
12/27/2022 12:00	1.5	12.9	1,969.6	1.1	7.90	1	1	1
12/27/2022 13:00	1.5	12.9	1,969.2	1.1	7.90	1	1	1
12/27/2022 14:00	1.5	12.9	1,970.6	1.1	7.90	1	1	1
12/27/2022 15:00	1.5	12.9	1,970.8	1.1	7.90	1	1	1
12/27/2022 16:00	1.5	13.0	1,970.5	1.1	7.90	1	1	1
12/27/2022 17:00	1.4	13.0	1,962.5	1.0	7.90	1	1	1
12/27/2022 18:00	1.4	13.1	1,960.1	1.1	7.80	1	1	1
12/27/2022 19:00	1.3	13.1	1,959.5	1.0	7.80	1	1	1
12/27/2022 20:00	1.4	13.1	1,971.6	1.1	7.90	1	1	1
12/27/2022 21:00	1.4	13.1	1,972.6	1.1	7.90	1	1	1
12/27/2022 22:00	1.1	13.2	1,945.8	0.8	5.80	1	1	1
12/27/2022 23:00	0.5	14.0	1,392.3	0.4	2.80	1	1	0
Average/Sum#:	1.3	13.6	1,716.3	1.2	152.64 #	23 #	21 #	15 #
Minimum:	0.1	12.9	198.2	0.3	0.04	0	0	0
Maximum:	7.2	18.8	1,972.8	8.7	24.20	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.6	13.9	1,539.7	0.5	3.10	1	1	0
12/28/2022 01:00	0.5	13.9	1,465.2	0.4	2.90	1	1	0
12/28/2022 02:00	0.6	13.9	1,520.9	0.5	3.00	1	1	0
12/28/2022 03:00	0.5	13.9	1,518.1	0.4	3.00	1	1	0
12/28/2022 04:00	0.5	13.9	1,528.2	0.4	3.10	1	1	0
12/28/2022 05:00	0.6	13.8	1,718.9	0.5	3.40	1	1	0
12/28/2022 06:00	0.6	13.8	1,735.9	0.5	3.50	1	1	0
12/28/2022 07:00	0.6	13.8	1,738.4	0.5	3.50	1	1	0
12/28/2022 08:00	0.6	13.8	1,716.3	0.5	3.40	1	1	0
12/28/2022 09:00	0.6	13.8	1,707.8	0.5	3.40	1	1	0
12/28/2022 10:00	0.5	13.9	1,547.7	0.4	3.10	1	1	0
12/28/2022 11:00	0.5	13.9	1,563.0	0.4	3.10	1	1	0
12/28/2022 12:00	0.6	13.9	1,545.4	0.5	3.10	1	1	0
12/28/2022 13:00	0.5	13.9	1,525.3	0.4	3.10	1	1	0
12/28/2022 14:00	0.6	13.9	1,549.1	0.5	3.10	1	1	0
12/28/2022 15:00	0.6	13.9	1,592.4	0.5	3.20	1	1	1
12/28/2022 16:00	1.4	12.6	2,095.4	1.0	8.40	1	1	1
12/28/2022 17:00	1.2	13.1	1,976.0	0.9	5.90	1	1	1
12/28/2022 18:00	1.1	13.2	1,956.1	0.8	5.90	1	1	1
12/28/2022 19:00	1.1	13.2	1,957.5	0.8	5.90	1	1	1
12/28/2022 20:00	1.1	13.2	1,959.0	0.8	5.90	1	1	1
12/28/2022 21:00	1.2	13.1	1,970.4	0.9	5.90	1	1	1
12/28/2022 22:00	1.1	13.2	1,956.0	0.8	5.90	1	1	1
12/28/2022 23:00	1.1	13.2	1,960.9	0.8	5.90	1	1	1
Average/Sum#:	0.8	13.6	1,722.7	0.6	100.70 #	24 #	24 #	9 #
Minimum:	0.5	12.6	1,465.2	0.4	2.90	1	1	0
Maximum:	1.4	13.9	2,095.4	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	1.1	13.2	1,956.9	0.8	5.90	1	1	1
12/29/2022 01:00	1.1	13.2	1,961.0	0.8	5.90	1	1	1
12/29/2022 02:00	1.1	13.2	1,965.0	0.8	5.90	1	1	1
12/29/2022 03:00	1.1	13.2	1,964.8	0.8	5.90	1	1	1
12/29/2022 04:00	1.1	13.2	1,969.1	0.8	5.90	1	1	1
12/29/2022 05:00	1.3	12.9	2,038.0	1.0	8.20	1	1	1
12/29/2022 06:00	1.5	12.6	2,047.5	1.1	8.20	1	1	1
12/29/2022 07:00	1.3	12.8	2,051.3	0.9	6.20	1	1	1
12/29/2022 08:00	1.6	12.2	2,206.4	1.1	8.80	1	1	1
12/29/2022 09:00	1.7	11.9	2,259.5	1.1	9.00	1	1	1
12/29/2022 10:00	1.6	12.4	2,161.9	1.1	8.60	1	1	1
12/29/2022 11:00	1.3	12.9	2,024.3	1.0	8.10	1	1	1
12/29/2022 12:00	1.2	13.1	1,986.2	0.9	6.00	1	1	1
12/29/2022 13:00	1.1	13.2	1,975.5	0.8	5.90	1	1	1
12/29/2022 14:00	1.2	13.1	1,985.1	0.9	6.00	1	1	1
12/29/2022 15:00	1.2	13.1	1,989.5	0.9	6.00	1	1	1
12/29/2022 16:00	1.4	12.7	2,100.3	1.0	8.40	1	1	1
12/29/2022 17:00	1.6	12.3	2,176.8	1.1	8.70	1	1	1
12/29/2022 18:00	1.4	12.6	2,085.5	1.0	8.30	1	1	1
12/29/2022 19:00	1.1	13.2	1,968.4	0.8	5.90	1	1	1
12/29/2022 20:00	1.1	13.2	1,977.8	0.8	5.90	1	1	1
12/29/2022 21:00	1.1	13.1	1,989.3	0.8	6.00	1	1	1
12/29/2022 22:00	1.1	13.1	1,972.1	0.8	5.90	1	1	1
12/29/2022 23:00	1.0	13.1	1,943.3	0.8	5.80	1	1	1
Average/Sum#:	1.3	12.9	2,031.5	0.9	165.40 #	24 #	24 #	24 #
Minimum:	1.0	11.9	1,943.3	0.8	5.80	1	1	1
Maximum:	1.7	13.2	2,259.5	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	5.0	15.9	561.7	5.9	2.85	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.0	15.9	561.7	5.9	2.85 #	1 #	0 #	0 #
Minimum:	5.0	15.9	561.7	5.9	2.85	0	0	0
Maximum:	5.0	15.9	561.7	5.9	2.85	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.8	11.9	2,165.1	0.6	2.5	1	1	1
10/01/2022 01:00	12.5	14.1	1,211.1	0.0	14.1	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.7	13.0	1,688.1	0.6	16.6 #	2 #	9 #	2 #
Minimum:	0.8	11.9	1,211.1	0.6	2.5	0	0	0
Maximum:	12.5	14.1	2,165.1	0.6	14.1	1	1	1
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	10 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/03/2022 02:00	60.6	17.5	336.0	0.0	64.9	1	1	0
10/03/2022 03:00	24.8	15.5	867.5	0.0	52.6	1	1	0
10/03/2022 04:00	0.4	13.8	1,711.7	0.0	1.3	1	1	0
10/03/2022 05:00	0.4	13.8	1,704.2	0.0	1.3	1	1	0
10/03/2022 06:00	0.4	13.8	1,701.6	0.3	1.3	1	1	0
10/03/2022 07:00	0.4	13.8	1,708.6	0.3	1.3	1	1	0
10/03/2022 08:00	0.3	13.8	1,718.8	0.3	1.0	1	1	0
10/03/2022 09:00	0.3	13.8	1,725.0	0.2	1.0	1	1	0
10/03/2022 10:00	0.5	13.9	1,728.2	0.3	1.6	1	1	0
10/03/2022 11:00	0.5	13.9	1,728.3	0.3	1.6	1	1	0
10/03/2022 12:00	0.5	13.9	1,728.4	0.4	1.6	1	1	0
10/03/2022 13:00	0.5	13.9	1,730.3	0.4	1.6	1	1	0
10/03/2022 14:00	0.5	13.9	1,724.6	0.4	1.6	1	1	0
10/03/2022 15:00	0.5	13.6	1,766.0	0.4	1.6	1	1	1
10/03/2022 16:00	1.2	12.3	2,061.1	0.5	3.8	1	1	1
10/03/2022 17:00	1.1	11.8	2,172.2	0.6	3.5	1	1	1
10/03/2022 18:00	1.0	11.6	2,206.8	0.7	3.1	1	1	1
10/03/2022 19:00	1.0	11.8	2,173.9	0.6	3.2	1	1	1
10/03/2022 20:00	1.0	11.7	2,187.2	0.6	3.1	1	1	1
10/03/2022 21:00	1.0	11.8	2,174.5	0.6	3.2	1	1	1
10/03/2022 22:00	1.0	12.0	2,152.4	0.6	3.2	1	1	1
10/03/2022 23:00	1.0	11.9	2,171.8	0.7	3.2	1	1	1
Average/Sum#:	4.5	13.4	1,780.9	0.5	160.6 #	22 #	24 #	9 #
Minimum:	0.3	11.6	336.0	0.2	1.0	0	1	0
Maximum:	60.6	17.5	2,206.8	0.7	64.9	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	1.0	12.0	2,154.5	0.7	3.2	1	1	1
10/04/2022 01:00	1.0	12.0	2,158.5	0.7	3.2	1	1	1
10/04/2022 02:00	1.0	12.0	2,156.3	0.7	3.2	1	1	1
10/04/2022 03:00	1.0	12.0	2,166.2	0.7	3.2	1	1	1
10/04/2022 04:00	1.0	12.0	2,173.6	0.7	3.2	1	1	1
10/04/2022 05:00	0.9	11.8	2,201.6	0.7	2.9	1	1	1
10/04/2022 06:00	0.9	12.0	2,166.7	0.6	2.9	1	1	1
10/04/2022 07:00	0.9	12.6	2,035.8	0.6	2.9	1	1	1
10/04/2022 08:00	0.4	13.7	1,595.1	0.5	1.2	1	1	0
10/04/2022 09:00	0.5	13.8	1,547.9	0.4	1.4	1	1	0
10/04/2022 10:00	0.6	13.7	1,555.2	0.4	1.7	1	1	0
10/04/2022 11:00	0.6	13.7	1,564.0	0.5	1.7	1	1	0
10/04/2022 12:00	0.5	13.7	1,722.8	0.5	1.6	1	1	0
10/04/2022 13:00	0.5	13.8	1,747.1	0.4	1.6	1	1	1
10/04/2022 14:00	1.3	12.8	2,032.9	0.6	4.3	1	1	1
10/04/2022 15:00	1.1	12.0	2,150.2	0.7	3.5	1	1	1
10/04/2022 16:00	1.0	12.1	2,131.5	0.8	3.2	1	1	1
10/04/2022 17:00	1.0	12.0	2,143.7	0.7	3.2	1	1	1
10/04/2022 18:00	1.0	11.9	2,169.2	0.7	3.2	1	1	1
10/04/2022 19:00	1.0	11.9	2,185.2	0.7	3.2	1	1	1
10/04/2022 20:00	0.9	11.6	2,243.7	0.7	2.9	1	1	1
10/04/2022 21:00	0.9	11.9	2,190.4	0.6	2.9	1	1	1
10/04/2022 22:00	0.9	11.9	2,177.9	0.6	2.9	1	1	1
10/04/2022 23:00	1.0	12.2	2,144.8	0.6	3.3	1	1	1
Average/Sum#:	0.9	12.5	2,021.5	0.6	66.5 #	24 #	24 #	19 #
Minimum:	0.4	11.6	1,547.9	0.4	1.2	1	1	0
Maximum:	1.3	13.8	2,243.7	0.8	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2022 00:00	1.0	12.2	2,136.7	0.7	3.2	1	1	1
10/05/2022 01:00	1.0	12.8	1,998.7	0.7	3.3	1	1	1
10/05/2022 02:00	1.1	13.0	1,971.1	0.7	3.6	1	1	1
10/05/2022 03:00	1.1	12.5	2,085.4	0.8	3.6	1	1	1
10/05/2022 04:00	1.1	12.3	2,111.1	0.8	3.6	1	1	1
10/05/2022 05:00	1.0	11.9	2,200.3	0.8	3.2	1	1	1
10/05/2022 06:00	0.9	11.9	2,201.4	0.7	2.9	1	1	1
10/05/2022 07:00	1.1	12.9	1,985.2	0.7	3.6	1	1	1
10/05/2022 08:00	0.4	13.9	1,718.1	0.6	1.3	1	1	0
10/05/2022 09:00	0.4	13.9	1,682.9	0.5	1.3	1	1	0
10/05/2022 10:00	0.5	13.9	1,710.7	0.3	1.6	1	1	0
10/05/2022 11:00	0.5	13.9	1,722.4	0.4	1.6	1	1	0
10/05/2022 12:00	0.7	13.8	1,738.9	0.5	2.3	1	1	1
10/05/2022 13:00	1.3	12.4	2,080.5	0.6	4.2	1	1	1
10/05/2022 14:00	1.1	11.8	2,190.4	0.7	3.5	1	1	1
10/05/2022 15:00	1.1	12.1	2,137.1	0.8	3.5	1	1	1
10/05/2022 16:00	1.0	11.9	2,159.1	0.7	3.2	1	1	1
10/05/2022 17:00	0.9	11.7	2,198.2	0.7	2.8	1	1	1
10/05/2022 18:00	0.9	11.6	2,230.9	0.6	2.9	1	1	1
10/05/2022 19:00	0.9	11.6	2,240.8	0.6	2.9	1	1	1
10/05/2022 20:00	0.9	11.9	2,190.7	0.6	2.9	1	1	1
10/05/2022 21:00	0.9	11.6	2,237.8	0.6	2.9	1	1	1
10/05/2022 22:00	1.0	12.0	2,166.4	0.6	3.2	1	1	1
10/05/2022 23:00	1.0	12.0	2,176.0	0.7	3.2	1	1	1
Average/Sum#:	0.9	12.5	2,053.0	0.6	70.3 #	24 #	24 #	20 #
Minimum:	0.4	11.6	1,682.9	0.3	1.3	1	1	0
Maximum:	1.3	13.9	2,240.8	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2022 00:00	1.0	12.1	2,165.7	0.7	3.3	1	1	1
10/06/2022 01:00	1.0	12.1	2,167.7	0.7	3.3	1	1	1
10/06/2022 02:00	1.0	12.1	2,165.0	0.7	3.2	1	1	1
10/06/2022 03:00	1.0	12.2	2,141.6	0.7	3.3	1	1	1
10/06/2022 04:00	0.8	12.0	2,181.3	0.6	2.6	1	1	1
10/06/2022 05:00	0.9	11.6	2,250.8	0.6	2.9	1	1	1
10/06/2022 06:00	0.8	11.8	2,238.5	0.5	2.6	1	1	1
10/06/2022 07:00	1.0	12.2	2,135.9	0.6	3.2	1	1	1
10/06/2022 08:00	1.0	12.4	2,082.9	0.6	3.2	1	1	1
10/06/2022 09:00	1.0	12.5	2,071.3	0.7	3.3	1	1	1
10/06/2022 10:00	1.0	12.5	2,082.0	0.7	3.3	1	1	1
10/06/2022 11:00	1.0	12.3	2,114.5	0.7	3.2	1	1	1
10/06/2022 12:00	1.0	12.1	2,136.7	0.7	3.2	1	1	1
10/06/2022 13:00	0.9	11.8	2,192.4	0.7	2.9	1	1	1
10/06/2022 14:00	0.9	11.8	2,197.6	0.6	2.9	1	1	1
10/06/2022 15:00	0.9	12.0	2,150.8	0.6	2.9	1	1	1
10/06/2022 16:00	0.9	11.8	2,191.5	0.6	2.9	1	1	1
10/06/2022 17:00	0.8	11.6	2,240.1	0.6	2.5	1	1	1
10/06/2022 18:00	0.8	11.7	2,239.0	0.5	2.6	1	1	1
10/06/2022 19:00	0.8	11.6	2,255.1	0.5	2.6	1	1	1
10/06/2022 20:00	0.8	11.6	2,259.5	0.5	2.6	1	1	1
10/06/2022 21:00	0.8	11.7	2,245.4	0.5	2.6	1	1	1
10/06/2022 22:00	0.9	12.0	2,190.1	0.5	2.9	1	1	1
10/06/2022 23:00	1.0	12.1	2,168.8	0.6	3.3	1	1	1
Average/Sum#:	0.9	12.0	2,177.7	0.6	71.3 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,071.3	0.5	2.5	1	1	1
Maximum:	1.0	12.5	2,259.5	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2022 00:00	1.0	12.2	2,143.9	0.7	3.3	1	1	1
10/07/2022 01:00	1.0	12.2	2,159.9	0.7	3.3	1	1	1
10/07/2022 02:00	1.0	12.2	2,141.6	0.7	3.3	1	1	1
10/07/2022 03:00	1.0	12.3	2,114.7	0.7	3.2	1	1	1
10/07/2022 04:00	1.0	12.2	2,155.6	0.7	3.3	1	1	1
10/07/2022 05:00	1.0	12.0	2,191.6	0.7	3.3	1	1	1
10/07/2022 06:00	0.9	12.0	2,204.6	0.7	2.9	1	1	1
10/07/2022 07:00	1.0	12.4	2,110.8	0.7	3.3	1	1	1
10/07/2022 08:00	1.0	12.7	2,030.0	0.7	3.3	1	1	1
10/07/2022 09:00	1.0	12.3	2,127.6	0.7	3.3	1	1	1
10/07/2022 10:00	1.0	12.3	2,127.5	0.7	3.3	1	1	1
10/07/2022 11:00	1.0	12.3	2,111.0	0.7	3.2	1	1	1
10/07/2022 12:00	1.0	12.0	2,168.6	0.7	3.2	1	1	1
10/07/2022 13:00	1.0	12.1	2,136.9	0.7	3.2	1	1	1
10/07/2022 14:00	0.9	11.9	2,182.3	0.7	2.9	1	1	1
10/07/2022 15:00	0.9	11.8	2,193.0	0.6	2.9	1	1	1
10/07/2022 16:00	0.9	11.9	2,179.2	0.6	2.9	1	1	1
10/07/2022 17:00	0.9	11.6	2,229.9	0.6	2.9	1	1	1
10/07/2022 18:00	0.8	11.6	2,243.3	0.6	2.5	1	1	1
10/07/2022 19:00	0.8	11.6	2,258.3	0.5	2.6	1	1	1
10/07/2022 20:00	0.8	11.6	2,262.5	0.5	2.6	1	1	1
10/07/2022 21:00	0.8	11.6	2,265.6	0.5	2.6	1	1	1
10/07/2022 22:00	0.8	11.7	2,257.3	0.5	2.6	1	1	1
10/07/2022 23:00	0.9	12.0	2,184.9	0.5	2.9	1	1	1
Average/Sum#:	0.9	12.0	2,174.2	0.6	72.8 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,030.0	0.5	2.5	1	1	1
Maximum:	1.0	12.7	2,265.6	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2022 00:00	1.0	12.1	2,173.3	0.6	3.3	1	1	1
10/08/2022 01:00	1.0	12.1	2,176.2	0.7	3.3	1	1	1
10/08/2022 02:00	1.0	12.1	2,167.4	0.7	3.3	1	1	1
10/08/2022 03:00	1.0	12.1	2,178.3	0.7	3.3	1	1	1
10/08/2022 04:00	1.0	12.0	2,176.1	0.7	3.2	1	1	1
10/08/2022 05:00	1.0	12.1	2,170.4	0.7	3.3	1	1	1
10/08/2022 06:00	1.0	12.3	2,110.4	0.7	3.2	1	1	1
10/08/2022 07:00	0.5	13.8	1,711.8	0.6	1.6	1	1	1
10/08/2022 08:00	0.6	13.9	1,365.6	0.5	1.5	1	1	0
10/08/2022 09:00	0.4	13.9	1,315.8	0.4	1.0	1	1	0
10/08/2022 10:00	0.4	14.0	1,312.6	0.4	1.0	1	1	0
10/08/2022 11:00	0.4	14.0	1,318.8	0.3	1.0	1	1	0
10/08/2022 12:00	0.5	13.8	1,569.8	0.3	1.5	1	1	0
10/08/2022 13:00	0.5	13.8	1,728.0	0.4	1.6	1	1	0
10/08/2022 14:00	0.5	13.7	1,745.1	0.4	1.6	1	1	1
10/08/2022 15:00	1.1	12.2	2,069.6	0.5	3.5	1	1	1
10/08/2022 16:00	1.0	11.7	2,201.9	0.6	3.2	1	1	1
10/08/2022 17:00	0.9	11.7	2,201.4	0.6	2.8	1	1	1
10/08/2022 18:00	1.0	11.9	2,167.0	0.6	3.2	1	1	1
10/08/2022 19:00	1.0	11.9	2,177.6	0.7	3.2	1	1	1
10/08/2022 20:00	1.0	11.9	2,180.4	0.7	3.2	1	1	1
10/08/2022 21:00	1.0	11.9	2,177.9	0.7	3.2	1	1	1
10/08/2022 22:00	1.0	12.0	2,173.3	0.7	3.2	1	1	1
10/08/2022 23:00	1.0	12.1	2,170.3	0.7	3.3	1	1	1
Average/Sum#:	0.8	12.6	1,947.5	0.6	62.5 #	24 #	24 #	18 #
Minimum:	0.4	11.7	1,312.6	0.3	1.0	1	1	0
Maximum:	1.1	14.0	2,201.9	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2022 00:00	1.0	12.0	2,166.8	0.7	3.2	1	1	1
10/09/2022 01:00	1.0	12.1	2,167.0	0.7	3.3	1	1	1
10/09/2022 02:00	1.0	12.2	2,138.4	0.7	3.2	1	1	1
10/09/2022 03:00	1.1	12.2	2,147.8	0.7	3.6	1	1	1
10/09/2022 04:00	1.0	12.1	2,158.6	0.7	3.2	1	1	1
10/09/2022 05:00	1.0	12.1	2,149.2	0.7	3.2	1	1	1
10/09/2022 06:00	6.4	13.0	1,685.1	0.0	18.0	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	14.0	18.7	209.6	0.0	3.9	1	0	0
10/09/2022 11:00	34.6	15.6	799.9	0.0	69.0	1	0	0
10/09/2022 12:00	0.4	13.9	1,387.0	0.0	1.0	1	0	0
10/09/2022 13:00	0.4	14.0	1,390.9	0.0	1.1	1	0	0
10/09/2022 14:00	0.5	13.7	1,726.4	0.3	1.6	1	0	0
10/09/2022 15:00	0.5	13.8	1,562.3	0.4	1.5	1	0	0
10/09/2022 16:00	0.5	13.8	1,729.7	0.4	1.6	1	1	0
10/09/2022 17:00	0.5	13.6	1,781.5	0.4	1.6	1	1	1
10/09/2022 18:00	1.3	12.3	2,081.7	0.6	4.2	1	1	1
10/09/2022 19:00	1.0	11.7	2,209.0	0.6	3.2	1	1	1
10/09/2022 20:00	1.0	11.8	2,188.3	0.7	3.2	1	1	1
10/09/2022 21:00	1.0	11.9	2,174.8	0.6	3.2	1	1	1
10/09/2022 22:00	1.0	12.0	2,156.1	0.7	3.2	1	1	1
10/09/2022 23:00	1.0	12.1	2,147.1	0.7	3.2	1	1	1
Average/Sum#:	3.3	13.1	1,817.0	0.6	139.2 #	21 #	14 #	14 #
Minimum:	0.4	11.7	209.6	0.3	1.0	0	0	0
Maximum:	34.6	18.7	2,209.0	0.7	69.0	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2022 00:00	1.0	12.2	2,121.9	0.7	3.2	1	1	1
10/10/2022 01:00	1.0	12.4	2,092.6	0.7	3.3	1	1	1
10/10/2022 02:00	1.2	12.9	1,980.8	0.8	3.9	1	1	1
10/10/2022 03:00	1.1	12.4	2,083.6	0.8	3.6	1	1	1
10/10/2022 04:00	1.0	12.3	2,127.1	0.8	3.3	1	1	1
10/10/2022 05:00	0.9	11.8	2,214.2	0.7	2.9	1	1	1
10/10/2022 06:00	0.9	11.9	2,205.4	0.6	2.9	1	1	1
10/10/2022 07:00	0.7	13.3	1,816.6	0.6	2.2	1	1	1
10/10/2022 08:00	0.6	13.8	1,551.8	0.5	1.7	1	1	0
10/10/2022 09:00	0.4	13.9	1,545.1	0.4	1.2	1	1	0
10/10/2022 10:00	0.4	14.0	1,390.8	0.4	1.1	1	1	0
10/10/2022 11:00	0.4	13.9	1,560.6	0.3	1.2	1	1	0
10/10/2022 12:00	0.4	13.9	1,574.2	0.3	1.2	1	1	0
10/10/2022 13:00	0.4	13.8	1,729.9	0.3	1.3	1	1	0
10/10/2022 14:00	0.5	13.8	1,718.4	0.3	1.6	1	1	0
10/10/2022 15:00	0.5	13.8	1,602.6	0.4	1.5	1	1	0
10/10/2022 16:00	1.2	12.6	1,973.3	0.6	3.8	1	1	1
10/10/2022 17:00	1.1	11.9	2,163.0	0.7	3.5	1	1	1
10/10/2022 18:00	1.0	11.7	2,198.7	0.7	3.2	1	1	1
10/10/2022 19:00	1.1	11.8	2,169.1	0.7	3.5	1	1	1
10/10/2022 20:00	1.1	11.9	2,160.6	0.7	3.5	1	1	1
10/10/2022 21:00	1.2	12.2	2,102.8	0.7	3.8	1	1	1
10/10/2022 22:00	1.2	12.4	2,085.4	0.8	3.9	1	1	1
10/10/2022 23:00	1.2	12.9	1,953.3	0.8	3.9	1	1	1
Average/Sum#:	0.9	12.8	1,921.7	0.6	65.2 #	24 #	24 #	16 #
Minimum:	0.4	11.7	1,390.8	0.3	1.1	1	1	0
Maximum:	1.2	14.0	2,214.2	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.7	13.9	1,376.2	0.8	1.8	1	1	0
10/11/2022 01:00	0.5	13.9	1,300.5	0.6	1.2	1	1	0
10/11/2022 02:00	0.5	13.9	1,300.2	0.5	1.2	1	1	0
10/11/2022 03:00	0.6	13.9	1,352.3	0.4	1.5	1	1	0
10/11/2022 04:00	0.5	13.9	1,495.7	0.4	1.4	1	1	0
10/11/2022 05:00	0.7	13.9	1,319.9	0.5	1.7	1	1	0
10/11/2022 06:00	0.8	13.9	1,313.8	0.6	2.0	1	1	0
10/11/2022 07:00	0.7	13.9	1,315.9	0.6	1.7	1	1	0
10/11/2022 08:00	0.6	13.9	1,317.2	0.6	1.5	1	1	0
10/11/2022 09:00	0.5	13.9	1,480.0	0.5	1.4	1	1	0
10/11/2022 10:00	0.5	13.9	1,548.1	0.4	1.5	1	1	0
10/11/2022 11:00	0.4	13.8	1,635.9	0.4	1.2	1	1	0
10/11/2022 12:00	0.5	13.6	1,802.5	0.4	1.6	1	1	0
10/11/2022 13:00	0.5	13.6	1,793.7	0.4	1.6	1	1	0
10/11/2022 14:00	0.5	13.6	1,789.9	0.4	1.6	1	1	0
10/11/2022 15:00	0.5	13.6	1,787.5	0.4	1.6	1	1	0
10/11/2022 16:00	0.5	13.6	1,788.3	0.4	1.6	1	1	0
10/11/2022 17:00	0.5	13.6	1,789.6	0.4	1.6	1	1	0
10/11/2022 18:00	0.5	13.6	1,794.2	0.4	1.6	1	1	1
10/11/2022 19:00	1.2	12.6	2,005.4	0.6	3.8	1	1	1
10/11/2022 20:00	1.1	12.1	2,131.3	0.7	3.5	1	1	1
10/11/2022 21:00	1.0	12.4	2,034.7	0.8	3.2	1	1	1
10/11/2022 22:00	1.0	12.2	2,102.6	0.7	3.2	1	1	1
10/11/2022 23:00	0.9	12.8	1,971.1	0.7	2.9	1	1	1
Average/Sum#:	0.7	13.5	1,647.8	0.5	45.9 #	24 #	24 #	6 #
Minimum:	0.4	12.1	1,300.2	0.4	1.2	1	1	0
Maximum:	1.2	13.9	2,131.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	1.1	13.0	1,958.1	0.7	3.6	1	1	1
10/12/2022 01:00	1.1	13.0	1,935.0	0.8	3.6	1	1	1
10/12/2022 02:00	0.6	13.8	1,519.8	0.7	1.7	1	1	0
10/12/2022 03:00	0.5	13.9	1,637.4	0.6	1.5	1	1	0
10/12/2022 04:00	0.5	13.7	1,768.9	0.4	1.6	1	1	0
10/12/2022 05:00	1.2	12.0	2,131.1	0.5	3.8	1	1	1
10/12/2022 06:00	1.0	11.7	2,260.0	0.6	3.2	1	1	1
10/12/2022 07:00	0.9	11.7	2,255.1	0.7	2.9	1	1	1
10/12/2022 08:00	0.9	11.7	2,247.7	0.6	2.9	1	1	1
10/12/2022 09:00	0.9	11.7	2,246.9	0.6	2.9	1	1	1
10/12/2022 10:00	0.9	11.7	2,242.0	0.6	2.9	1	1	1
10/12/2022 11:00	0.9	11.7	2,245.9	0.6	2.9	1	1	1
10/12/2022 12:00	0.8	11.6	2,250.7	0.6	2.6	1	1	1
10/12/2022 13:00	0.8	11.6	2,248.0	0.5	2.6	1	1	1
10/12/2022 14:00	0.9	11.6	2,249.4	0.5	2.9	1	1	1
10/12/2022 15:00	0.9	11.6	2,250.4	0.6	2.9	1	1	1
10/12/2022 16:00	0.9	11.4	2,266.7	0.6	2.8	1	1	1
10/12/2022 17:00	0.9	11.4	2,274.9	0.6	2.8	1	1	1
10/12/2022 18:00	0.9	11.6	2,233.1	0.6	2.9	1	1	1
10/12/2022 19:00	1.1	12.1	2,138.2	0.6	3.5	1	1	1
10/12/2022 20:00	1.1	12.0	2,147.6	0.7	3.5	1	1	1
10/12/2022 21:00	1.1	12.2	2,119.1	0.7	3.5	1	1	1
10/12/2022 22:00	1.2	12.4	2,086.8	0.7	3.9	1	1	1
10/12/2022 23:00	1.3	12.9	1,967.8	0.8	4.2	1	1	1
Average/Sum#:	0.9	12.2	2,111.7	0.6	71.6 #	24 #	24 #	21 #
Minimum:	0.5	11.4	1,519.8	0.4	1.5	1	1	0
Maximum:	1.3	13.9	2,274.9	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2022 00:00	1.4	12.9	1,961.3	0.9	4.5	1	1	1
10/13/2022 01:00	1.3	12.7	2,005.0	1.0	4.2	1	1	1
10/13/2022 02:00	1.5	13.0	1,953.3	1.0	4.9	1	1	1
10/13/2022 03:00	1.4	13.0	1,959.2	1.0	4.6	1	1	1
10/13/2022 04:00	1.3	13.0	1,926.0	1.0	4.2	1	1	1
10/13/2022 05:00	0.8	13.9	1,311.2	0.9	2.0	1	1	0
10/13/2022 06:00	0.8	13.9	1,311.4	0.8	2.0	1	1	0
10/13/2022 07:00	0.7	13.9	1,339.8	0.7	1.8	1	1	0
10/13/2022 08:00	0.5	13.8	1,587.0	0.6	1.5	1	1	0
10/13/2022 09:00	0.5	13.8	1,535.6	0.5	1.4	1	1	0
10/13/2022 10:00	0.5	13.6	1,804.0	0.4	1.6	1	1	0
10/13/2022 11:00	0.5	13.5	1,810.3	0.4	1.6	1	1	0
10/13/2022 12:00	0.5	13.6	1,808.3	0.4	1.6	1	1	0
10/13/2022 13:00	0.5	13.6	1,802.3	0.4	1.6	1	1	0
10/13/2022 14:00	0.5	13.6	1,793.3	0.4	1.6	1	1	0
10/13/2022 15:00	0.5	13.6	1,792.5	0.4	1.6	1	1	0
10/13/2022 16:00	0.5	13.6	1,790.7	0.4	1.6	1	1	0
10/13/2022 17:00	0.5	13.6	1,796.8	0.4	1.6	1	1	0
10/13/2022 18:00	0.5	13.5	1,804.3	0.4	1.6	1	1	0
10/13/2022 19:00	0.6	13.5	1,807.0	0.4	1.9	1	1	1
10/13/2022 20:00	1.3	12.4	2,059.6	0.6	4.2	1	1	1
10/13/2022 21:00	1.2	12.0	2,159.9	0.7	3.8	1	1	1
10/13/2022 22:00	1.1	12.4	2,083.7	0.8	3.6	1	1	1
10/13/2022 23:00	1.1	12.5	2,071.5	0.8	3.6	1	1	1
Average/Sum#:	0.8	13.3	1,803.1	0.6	62.6 #	24 #	24 #	10 #
Minimum:	0.5	12.0	1,311.2	0.4	1.4	1	1	0
Maximum:	1.5	13.9	2,159.9	1.0	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2022 00:00	1.0	12.6	2,061.0	0.8	3.3	1	1	1
10/14/2022 01:00	1.0	12.5	2,055.5	0.7	3.2	1	1	1
10/14/2022 02:00	1.0	12.5	2,056.0	0.7	3.2	1	1	1
10/14/2022 03:00	0.9	12.5	2,053.2	0.7	2.9	1	1	1
10/14/2022 04:00	0.9	12.3	2,098.1	0.6	2.9	1	1	1
10/14/2022 05:00	0.8	11.5	2,254.4	0.6	2.5	1	1	1
10/14/2022 06:00	0.7	11.5	2,261.5	0.5	2.2	1	1	1
10/14/2022 07:00	0.7	11.5	2,266.0	0.4	2.2	1	1	1
10/14/2022 08:00	0.9	12.5	2,033.0	0.5	2.9	1	1	1
10/14/2022 09:00	1.0	12.9	1,968.5	0.6	3.2	1	1	1
10/14/2022 10:00	1.0	12.7	1,978.5	0.7	3.2	1	1	1
10/14/2022 11:00	1.0	12.7	1,988.2	0.7	3.2	1	1	1
10/14/2022 12:00	1.0	12.7	1,992.9	0.7	3.2	1	1	1
10/14/2022 13:00	1.0	12.6	1,998.9	0.7	3.2	1	1	1
10/14/2022 14:00	1.0	12.2	2,104.1	0.7	3.2	1	1	1
10/14/2022 15:00	1.0	12.0	2,146.5	0.7	3.2	1	1	1
10/14/2022 16:00	0.9	12.0	2,145.1	0.7	2.9	1	1	1
10/14/2022 17:00	0.9	11.5	2,227.8	0.6	2.8	1	1	1
10/14/2022 18:00	1.0	11.9	2,153.4	0.6	3.2	1	1	1
10/14/2022 19:00	1.0	12.1	2,127.2	0.7	3.2	1	1	1
10/14/2022 20:00	1.0	12.0	2,134.2	0.7	3.2	1	1	1
10/14/2022 21:00	1.0	12.1	2,122.5	0.7	3.2	1	1	1
10/14/2022 22:00	1.0	12.3	2,095.3	0.7	3.2	1	1	1
10/14/2022 23:00	10.2	13.9	1,333.3	0.0	14.1	1	0	1
Average/Sum#:	1.3	12.3	2,069.0	0.7	83.5 #	24 #	23 #	24 #
Minimum:	0.7	11.5	1,333.3	0.4	2.2	1	0	1
Maximum:	10.2	13.9	2,266.0	0.8	14.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/16/2022 23:00	97.7	17.8	305.8	0.0	63.7	1	1	0
Average/Sum#:	97.7	17.8	305.8	0.0	63.7 #	1 #	4 #	0 #
Minimum:	97.7	17.8	305.8	0.0	63.7	0	0	0
Maximum:	97.7	17.8	305.8	0.0	63.7	1	1	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2022 00:00	34.8	15.6	846.3	0.0	73.4	1	1	0
10/17/2022 01:00	0.5	13.8	1,704.0	0.0	1.6	1	1	0
10/17/2022 02:00	0.5	13.8	1,714.0	0.0	1.6	1	1	0
10/17/2022 03:00	0.5	13.7	1,810.2	0.4	1.7	1	1	1
10/17/2022 04:00	1.1	12.3	2,087.2	0.5	3.5	1	1	1
10/17/2022 05:00	1.0	11.9	2,182.2	0.6	3.2	1	1	1
10/17/2022 06:00	1.0	12.2	2,151.6	0.7	3.3	1	1	1
10/17/2022 07:00	1.0	12.4	2,100.6	0.7	3.3	1	1	1
10/17/2022 08:00	0.6	13.6	1,691.4	0.6	1.8	1	1	1
10/17/2022 09:00	0.4	13.8	1,644.4	0.5	1.2	1	1	0
10/17/2022 10:00	0.5	13.9	1,523.9	0.4	1.4	1	1	0
10/17/2022 11:00	0.4	13.8	1,608.2	0.3	1.2	1	1	0
10/17/2022 12:00	0.5	13.9	1,506.8	0.4	1.4	1	1	0
10/17/2022 13:00	0.5	13.9	1,513.1	0.4	1.4	1	1	0
10/17/2022 14:00	0.4	13.9	1,670.2	0.4	1.3	1	1	0
10/17/2022 15:00	0.5	13.7	1,713.7	0.4	1.6	1	1	1
10/17/2022 16:00	1.1	12.4	2,086.6	0.5	3.6	1	1	1
10/17/2022 17:00	0.9	11.6	2,242.9	0.6	2.9	1	1	1
10/17/2022 18:00	0.9	11.6	2,260.4	0.7	2.9	1	1	1
10/17/2022 19:00	0.9	11.7	2,236.0	0.6	2.9	1	1	1
10/17/2022 20:00	0.9	11.7	2,243.1	0.6	2.9	1	1	1
10/17/2022 21:00	0.9	11.6	2,256.3	0.6	2.9	1	1	1
10/17/2022 22:00	1.0	12.0	2,182.4	0.6	3.2	1	1	1
10/17/2022 23:00	1.0	12.0	2,180.6	0.7	3.2	1	1	1
Average/Sum#:	2.2	13.0	1,881.5	0.5	127.4 #	24 #	24 #	15 #
Minimum:	0.4	11.6	846.3	0.3	1.2	1	1	0
Maximum:	34.8	15.6	2,260.4	0.7	73.4	1	1	1
%SI	0.00	0.00	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2022 00:00	1.0	12.0	2,175.4	0.7	3.2	1	1	1
10/18/2022 01:00	0.9	12.1	2,166.0	0.7	2.9	1	1	1
10/18/2022 02:00	0.8	12.0	2,168.9	0.6	2.6	1	1	1
10/18/2022 03:00	0.8	11.9	2,193.4	0.5	2.6	1	1	1
10/18/2022 04:00	0.8	11.9	2,192.8	0.5	2.6	1	1	1
10/18/2022 05:00	0.8	12.0	2,173.8	0.5	2.6	1	1	1
10/18/2022 06:00	0.9	12.2	2,149.9	0.5	2.9	1	1	1
10/18/2022 07:00	0.9	12.1	2,148.0	0.6	2.9	1	1	1
10/18/2022 08:00	1.0	12.1	2,167.9	0.6	3.3	1	1	1
10/18/2022 09:00	1.0	12.1	2,165.6	0.7	3.3	1	1	1
10/18/2022 10:00	1.1	12.2	2,133.5	0.7	3.6	1	1	1
10/18/2022 11:00	1.1	12.3	2,107.8	0.7	3.6	1	1	1
10/18/2022 12:00	1.0	12.3	2,105.5	0.7	3.2	1	1	1
10/18/2022 13:00	1.1	12.3	2,109.2	0.8	3.6	1	1	1
10/18/2022 14:00	1.1	12.2	2,117.2	0.7	3.5	1	1	1
10/18/2022 15:00	1.1	12.1	2,149.3	0.7	3.5	1	1	1
10/18/2022 16:00	0.9	11.7	2,239.2	0.7	2.9	1	1	1
10/18/2022 17:00	1.0	11.9	2,202.8	0.7	3.2	1	1	1
10/18/2022 18:00	0.9	11.7	2,249.3	0.6	2.9	1	1	1
10/18/2022 19:00	0.9	11.6	2,271.7	0.6	2.9	1	1	1
10/18/2022 20:00	0.9	11.6	2,277.4	0.6	2.9	1	1	1
10/18/2022 21:00	0.9	11.6	2,277.9	0.6	2.9	1	1	1
10/18/2022 22:00	1.0	11.9	2,202.9	0.6	3.2	1	1	1
10/18/2022 23:00	1.0	11.9	2,201.6	0.7	3.2	1	1	1
Average/Sum#:	1.0	12.0	2,181.1	0.6	74.0 #	24 #	24 #	24 #
Minimum:	0.8	11.6	2,105.5	0.5	2.6	1	1	1
Maximum:	1.1	12.3	2,277.9	0.8	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	1.1	12.0	2,189.4	0.7	3.6	1	1	1
10/19/2022 01:00	1.0	12.4	2,117.8	0.7	3.3	1	1	1
10/19/2022 02:00	0.9	12.5	2,070.1	0.7	2.9	1	1	1
10/19/2022 03:00	0.8	12.3	2,105.5	0.6	2.6	1	1	1
10/19/2022 04:00	0.8	12.1	2,139.4	0.5	2.6	1	1	1
10/19/2022 05:00	0.7	11.7	2,201.4	0.5	2.2	1	1	1
10/19/2022 06:00	1.0	11.9	2,222.6	0.5	3.3	1	1	1
10/19/2022 07:00	1.1	12.2	2,151.9	0.6	3.6	1	1	1
10/19/2022 08:00	1.1	12.3	2,140.6	0.7	3.6	1	1	1
10/19/2022 09:00	1.1	12.4	2,101.5	0.8	3.6	1	1	1
10/19/2022 10:00	1.1	12.4	2,092.4	0.8	3.6	1	1	1
10/19/2022 11:00	1.1	12.2	2,121.8	0.8	3.5	1	1	1
10/19/2022 12:00	1.1	12.1	2,136.5	0.7	3.5	1	1	1
10/19/2022 13:00	1.0	12.0	2,154.1	0.7	3.2	1	1	1
10/19/2022 14:00	1.0	12.1	2,145.1	0.7	3.2	1	1	1
10/19/2022 15:00	1.0	11.8	2,185.0	0.7	3.2	1	1	1
10/19/2022 16:00	1.0	11.7	2,199.7	0.6	3.2	1	1	1
10/19/2022 17:00	1.1	12.1	2,124.9	0.6	3.5	1	1	1
10/19/2022 18:00	1.1	12.2	2,109.1	0.7	3.5	1	1	1
10/19/2022 19:00	1.1	12.2	2,115.7	0.7	3.5	1	1	1
10/19/2022 20:00	1.1	12.1	2,154.7	0.7	3.6	1	1	1
10/19/2022 21:00	1.1	12.3	2,120.2	0.7	3.6	1	1	1
10/19/2022 22:00	1.1	12.4	2,092.4	0.8	3.6	1	1	1
10/19/2022 23:00	1.1	12.3	2,111.2	0.8	3.6	1	1	1
Average/Sum#:	1.0	12.2	2,137.6	0.7	79.6 #	24 #	24 #	24 #
Minimum:	0.7	11.7	2,070.1	0.5	2.2	1	1	1
Maximum:	1.1	12.5	2,222.6	0.8	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2022 00:00	1.1	12.3	2,129.2	0.8	3.6	1	1	1
10/20/2022 01:00	1.1	12.4	2,089.4	0.8	3.6	1	1	1
10/20/2022 02:00	1.1	12.5	2,083.4	0.8	3.6	1	1	1
10/20/2022 03:00	1.2	12.4	2,093.7	0.8	3.9	1	1	1
10/20/2022 04:00	1.1	12.3	2,133.0	0.8	3.6	1	1	1
10/20/2022 05:00	0.9	11.8	2,202.7	0.7	2.9	1	1	1
10/20/2022 06:00	1.0	12.0	2,196.1	0.7	3.3	1	1	1
10/20/2022 07:00	1.1	12.6	2,066.6	0.7	3.6	1	1	1
10/20/2022 08:00	1.1	12.6	2,058.0	0.8	3.6	1	1	1
10/20/2022 09:00	1.1	12.5	2,072.7	0.8	3.6	1	1	1
10/20/2022 10:00	1.1	12.5	2,068.4	0.8	3.6	1	1	1
10/20/2022 11:00	1.1	12.4	2,087.7	0.8	3.6	1	1	1
10/20/2022 12:00	1.1	12.3	2,089.8	0.8	3.5	1	1	1
10/20/2022 13:00	1.1	12.3	2,104.8	0.8	3.6	1	1	1
10/20/2022 14:00	1.1	12.2	2,117.9	0.8	3.5	1	1	1
10/20/2022 15:00	1.0	12.1	2,149.5	0.7	3.2	1	1	1
10/20/2022 16:00	0.9	11.5	2,255.7	0.7	2.9	1	1	1
10/20/2022 17:00	1.0	11.8	2,184.0	0.6	3.2	1	1	1
10/20/2022 18:00	1.0	11.7	2,231.4	0.6	3.2	1	1	1
10/20/2022 19:00	1.1	12.2	2,115.3	0.6	3.5	1	1	1
10/20/2022 20:00	1.1	12.2	2,110.7	0.7	3.5	1	1	1
10/20/2022 21:00	1.1	12.4	2,086.7	0.7	3.6	1	1	1
10/20/2022 22:00	1.1	12.4	2,088.4	0.8	3.6	1	1	1
10/20/2022 23:00	1.0	12.2	2,125.0	0.8	3.2	1	1	1
Average/Sum#:	1.1	12.2	2,122.5	0.7	83.0 #	24 #	24 #	24 #
Minimum:	0.9	11.5	2,058.0	0.6	2.9	1	1	1
Maximum:	1.2	12.6	2,255.7	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2022 00:00	0.8	12.8	1,944.1	0.7	2.5	1	1	1
10/21/2022 01:00	0.4	13.9	1,583.3	0.5	1.2	1	1	0
10/21/2022 02:00	0.4	13.9	1,597.9	0.4	1.2	1	1	0
10/21/2022 03:00	0.5	13.9	1,547.4	0.3	1.5	1	1	0
10/21/2022 04:00	0.4	13.9	1,708.6	0.3	1.3	1	1	0
10/21/2022 05:00	0.5	13.9	1,710.6	0.4	1.6	1	1	0
10/21/2022 06:00	0.5	13.9	1,608.8	0.4	1.5	1	1	0
10/21/2022 07:00	0.5	13.9	1,676.8	0.4	1.6	1	1	0
10/21/2022 08:00	0.4	13.9	1,716.7	0.4	1.3	1	1	0
10/21/2022 09:00	0.4	13.9	1,720.8	0.3	1.3	1	1	0
10/21/2022 10:00	0.4	13.9	1,719.5	0.3	1.3	1	1	0
10/21/2022 11:00	0.4	13.9	1,683.4	0.3	1.3	1	1	0
10/21/2022 12:00	0.5	13.8	1,661.0	0.3	1.5	1	1	0
10/21/2022 13:00	0.5	13.8	1,633.6	0.4	1.5	1	1	0
10/21/2022 14:00	0.6	13.8	1,692.1	0.4	1.9	1	1	0
10/21/2022 15:00	0.7	13.8	1,568.6	0.5	2.0	1	1	1
10/21/2022 16:00	1.2	12.2	2,099.1	0.6	3.8	1	1	1
10/21/2022 17:00	1.1	11.8	2,183.0	0.7	3.5	1	1	1
10/21/2022 18:00	1.1	12.0	2,142.7	0.7	3.5	1	1	1
10/21/2022 19:00	1.2	12.3	2,098.0	0.7	3.9	1	1	1
10/21/2022 20:00	1.1	12.2	2,114.4	0.7	3.5	1	1	1
10/21/2022 21:00	1.1	11.9	2,175.3	0.7	3.5	1	1	1
10/21/2022 22:00	12.5	14.0	1,230.6	0.0	14.1	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.2	13.4	1,774.6	0.5	60.3 #	23 #	22 #	9 #
Minimum:	0.4	11.8	1,230.6	0.3	1.2	0	0	0
Maximum:	12.5	14.0	2,183.0	0.7	14.1	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2022 12:00	16.3	21.0	2.2	0.0	0.0	1	1	0
10/24/2022 13:00	51.2	17.0	429.7	0.0	74.5	1	1	0
10/24/2022 14:00	10.1	14.1	1,572.3	0.0	30.8	1	0	0
10/24/2022 15:00	0.4	13.7	1,771.7	0.0	1.3	1	0	0
10/24/2022 16:00	0.4	13.7	1,770.8	0.0	1.3	1	0	0
10/24/2022 17:00	0.4	13.7	1,779.7	0.3	1.3	1	0	0
10/24/2022 18:00	0.4	13.7	1,791.6	0.3	1.3	1	0	0
10/24/2022 19:00	0.4	13.7	1,799.7	0.3	1.3	1	0	0
10/24/2022 20:00	0.4	13.7	1,806.0	0.3	1.3	1	0	0
10/24/2022 21:00	0.4	13.7	1,813.9	0.3	1.3	1	0	0
10/24/2022 22:00	0.4	13.7	1,810.6	0.3	1.3	1	0	0
10/24/2022 23:00	0.4	13.7	1,822.7	0.3	1.3	1	0	0
Average/Sum#:	6.8	14.6	1,514.2	0.3	117.0 #	12 #	14 #	0 #
Minimum:	0.4	13.7	2.2	0.3	0.0	0	0	0
Maximum:	51.2	21.0	1,822.7	0.3	74.5	1	1	0
%SI	50.00	50.00	50.00	70.83	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.4	13.7	1,809.3	0.3	1.3	1	0	0
10/25/2022 01:00	0.4	13.7	1,804.8	0.3	1.3	1	0	0
10/25/2022 02:00	0.4	13.8	1,804.4	0.3	1.3	1	0	0
10/25/2022 03:00	0.4	13.8	1,802.4	0.3	1.3	1	0	0
10/25/2022 04:00	0.4	13.8	1,805.0	0.3	1.3	1	0	0
10/25/2022 05:00	0.4	13.8	1,808.1	0.3	1.3	1	0	0
10/25/2022 06:00	0.4	13.8	1,808.2	0.3	1.3	1	0	0
10/25/2022 07:00	0.4	13.8	1,807.7	0.3	1.3	1	0	0
10/25/2022 08:00	0.4	13.7	1,812.1	0.3	1.3	1	0	0
10/25/2022 09:00	0.4	13.7	1,815.9	0.3	1.3	1	0	0
10/25/2022 10:00	0.4	13.7	1,814.8	0.3	1.3	1	0	0
10/25/2022 11:00	0.5	13.7	1,829.7	0.3	1.7	1	0	0
10/25/2022 12:00	0.5	13.7	1,832.3	0.4	1.7	1	0	0
10/25/2022 13:00	0.5	13.6	1,836.6	0.4	1.7	1	0	0
10/25/2022 14:00	0.5	13.6	1,831.6	0.4	1.7	1	0	0
10/25/2022 15:00	0.5	13.6	1,832.4	0.4	1.7	1	0	0
10/25/2022 16:00	0.5	13.6	1,831.0	0.4	1.7	1	0	0
10/25/2022 17:00	0.5	13.6	1,834.2	0.4	1.7	1	0	0
10/25/2022 18:00	0.5	13.7	1,826.1	0.4	1.7	1	0	0
10/25/2022 19:00	0.5	13.7	1,814.8	0.4	1.7	1	0	0
10/25/2022 20:00	0.5	13.7	1,807.6	0.4	1.7	1	0	0
10/25/2022 21:00	0.5	13.7	1,809.8	0.4	1.7	1	0	0
10/25/2022 22:00	0.4	13.7	1,804.5	0.4	1.3	1	0	0
10/25/2022 23:00	0.4	13.9	1,635.5	0.3	1.2	1	0	0
Average/Sum#:	0.4	13.7	1,809.1	0.3	35.5 #	24 #	0 #	0 #
Minimum:	0.4	13.6	1,635.5	0.3	1.2	1	0	0
Maximum:	0.5	13.9	1,836.6	0.4	1.7	1	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	0.4	13.8	1,630.9	0.3	1.2	1	0	0
10/26/2022 01:00	0.4	13.9	1,631.9	0.3	1.2	1	0	0
10/26/2022 02:00	0.4	13.9	1,628.9	0.3	1.2	1	0	0
10/26/2022 03:00	0.4	13.9	1,616.4	0.3	1.2	1	0	0
10/26/2022 04:00	0.4	13.8	1,794.6	0.3	1.3	1	0	0
10/26/2022 05:00	0.4	13.9	1,733.8	0.3	1.3	1	0	0
10/26/2022 06:00	0.4	13.9	1,691.8	0.3	1.3	1	0	0
10/26/2022 07:00	0.4	13.8	1,742.7	0.3	1.3	1	0	0
10/26/2022 08:00	14.0	15.4	735.2	0.0	6.7	1	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	36.8	18.3	240.1	0.0	14.4	1	0	0
10/26/2022 17:00	30.7	17.6	391.6	0.0	25.5	1	0	0
10/26/2022 18:00	61.2	15.4	828.0	0.0	121.7	1	0	0
10/26/2022 19:00	0.5	13.7	1,825.1	0.0	1.7	1	0	0
10/26/2022 20:00	0.5	13.7	1,820.3	0.0	1.7	1	0	0
10/26/2022 21:00	0.5	13.7	1,810.2	0.4	1.7	1	0	0
10/26/2022 22:00	0.5	13.7	1,764.5	0.4	1.6	1	0	0
10/26/2022 23:00	6.0	14.5	1,164.0	0.0	12.5	1	0	0
Average/Sum#:	9.1	14.5	1,414.7	0.3	197.5 #	17 #	0 #	0 #
Minimum:	0.4	13.7	240.1	0.3	1.2	0	0	0
Maximum:	61.2	18.3	1,825.1	0.4	121.7	1	0	0
%SI	29.17	29.17	29.17	58.33	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/31/2022 01:00	64.0	17.7	299.3	0.0	76.7	1	1	0
10/31/2022 02:00	38.7	16.0	725.0	0.0	75.6	1	1	0
10/31/2022 03:00	0.5	13.8	1,712.6	0.0	1.6	1	1	0
10/31/2022 04:00	0.5	13.8	1,726.3	0.0	1.6	1	1	0
10/31/2022 05:00	0.5	13.8	1,711.3	0.4	1.6	1	1	0
10/31/2022 06:00	0.5	13.8	1,692.8	0.4	1.6	1	1	0
10/31/2022 07:00	0.5	13.8	1,693.6	0.4	1.6	1	1	0
10/31/2022 08:00	0.5	13.8	1,704.5	0.4	1.6	1	1	0
10/31/2022 09:00	0.5	13.9	1,706.8	0.4	1.6	1	1	0
10/31/2022 10:00	0.5	13.9	1,708.4	0.4	1.6	1	1	0
10/31/2022 11:00	0.5	13.9	1,689.0	0.4	1.6	1	1	0
10/31/2022 12:00	0.4	13.9	1,687.9	0.4	1.3	1	1	0
10/31/2022 13:00	0.4	13.9	1,702.8	0.3	1.3	1	1	0
10/31/2022 14:00	0.6	13.7	1,767.7	0.4	1.9	1	1	1
10/31/2022 15:00	1.3	12.5	2,082.4	0.6	4.3	1	1	1
10/31/2022 16:00	1.2	12.3	2,105.6	0.7	3.9	1	1	1
10/31/2022 17:00	1.2	12.4	2,076.3	0.8	3.9	1	1	1
10/31/2022 18:00	1.2	12.4	2,082.4	0.8	3.9	1	1	1
10/31/2022 19:00	1.2	12.4	2,103.6	0.8	3.9	1	1	1
10/31/2022 20:00	1.1	12.4	2,089.0	0.8	3.6	1	1	1
10/31/2022 21:00	1.0	12.2	2,130.3	0.8	3.2	1	1	1
10/31/2022 22:00	1.0	12.3	2,096.7	0.7	3.2	1	1	1
10/31/2022 23:00	1.0	12.2	2,136.9	0.7	3.2	1	1	1
Average/Sum#:	5.2	13.5	1,757.9	0.6	204.3 #	23 #	24 #	10 #
Minimum:	0.4	12.2	299.3	0.3	1.3	0	1	0
Maximum:	64.0	17.7	2,136.9	0.8	76.7	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2022 00:00	1.0	12.2	2,154.2	0.7	3.3	1	1	1
11/01/2022 01:00	1.0	12.2	2,150.3	0.7	3.3	1	1	1
11/01/2022 02:00	1.0	12.2	2,158.5	0.7	3.3	1	1	1
11/01/2022 03:00	1.0	12.2	2,167.8	0.7	3.3	1	1	1
11/01/2022 04:00	1.0	12.2	2,175.8	0.7	3.3	1	1	1
11/01/2022 05:00	1.0	12.1	2,176.4	0.7	3.3	1	1	1
11/01/2022 06:00	0.9	11.8	2,250.2	0.7	2.9	1	1	1
11/01/2022 07:00	0.9	12.0	2,187.2	0.6	2.9	1	1	1
11/01/2022 08:00	0.8	11.7	2,240.2	0.6	2.6	1	1	1
11/01/2022 09:00	0.9	12.2	2,118.9	0.6	2.9	1	1	1
11/01/2022 10:00	1.0	12.3	2,123.0	0.6	3.3	1	1	1
11/01/2022 11:00	0.9	12.0	2,183.5	0.6	2.9	1	1	1
11/01/2022 12:00	0.9	11.9	2,189.4	0.6	2.9	1	1	1
11/01/2022 13:00	0.8	12.0	2,180.9	0.6	2.6	1	1	1
11/01/2022 14:00	0.9	12.4	2,089.8	0.6	2.9	1	1	1
11/01/2022 15:00	1.1	12.6	2,087.1	0.6	3.7	1	1	1
11/01/2022 16:00	0.9	12.1	2,204.2	0.7	3.0	1	1	1
11/01/2022 17:00	0.8	11.6	2,294.1	0.6	2.6	1	1	1
11/01/2022 18:00	0.9	12.1	2,186.6	0.6	3.0	1	1	1
11/01/2022 19:00	0.9	12.3	2,168.2	0.6	3.0	1	1	1
11/01/2022 20:00	0.9	12.1	2,209.2	0.6	3.0	1	1	1
11/01/2022 21:00	0.9	12.6	2,087.6	0.6	3.0	1	1	1
11/01/2022 22:00	0.9	12.7	2,075.1	0.6	3.0	1	1	1
11/01/2022 23:00	0.8	13.3	1,849.2	0.6	2.6	1	1	1
Average/Sum#:	0.9	12.2	2,154.5	0.6	72.6 #	24 #	24 #	24 #
Minimum:	0.8	11.6	1,849.2	0.6	2.6	1	1	1
Maximum:	1.1	13.3	2,294.1	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.7	13.9	1,353.8	0.6	1.8	1	1	0
11/02/2022 01:00	0.5	13.9	1,639.5	0.5	1.5	1	1	0
11/02/2022 02:00	0.5	13.8	1,709.9	0.5	1.6	1	1	0
11/02/2022 03:00	1.0	13.9	1,353.8	0.5	2.6	1	1	0
11/02/2022 04:00	0.5	13.8	1,683.4	0.5	1.6	1	1	0
11/02/2022 05:00	1.0	13.1	1,917.9	0.7	3.2	1	1	1
11/02/2022 06:00	1.1	12.5	2,169.6	0.7	3.8	1	1	1
11/02/2022 07:00	1.0	12.7	2,129.3	0.8	3.4	1	1	1
11/02/2022 08:00	1.0	12.9	2,028.9	0.7	3.3	1	1	1
11/02/2022 09:00	0.5	13.8	1,719.4	0.6	1.6	1	1	0
11/02/2022 10:00	0.5	13.9	1,549.8	0.5	1.5	1	1	0
11/02/2022 11:00	0.5	13.9	1,678.6	0.4	1.6	1	1	0
11/02/2022 12:00	0.5	13.9	1,558.6	0.4	1.5	1	1	0
11/02/2022 13:00	0.5	13.9	1,562.4	0.4	1.5	1	1	0
11/02/2022 14:00	0.5	13.9	1,544.2	0.4	1.5	1	1	0
11/02/2022 15:00	0.5	13.9	1,612.7	0.4	1.5	1	1	1
11/02/2022 16:00	1.1	12.6	2,080.8	0.5	3.6	1	1	1
11/02/2022 17:00	1.0	12.3	2,172.4	0.6	3.3	1	1	1
11/02/2022 18:00	1.0	12.4	2,164.8	0.7	3.4	1	1	1
11/02/2022 19:00	1.0	12.4	2,165.2	0.7	3.4	1	1	1
11/02/2022 20:00	1.0	12.4	2,166.8	0.7	3.4	1	1	1
11/02/2022 21:00	1.0	12.5	2,152.9	0.7	3.4	1	1	1
11/02/2022 22:00	1.0	12.4	2,163.4	0.7	3.4	1	1	1
11/02/2022 23:00	1.0	12.4	2,176.3	0.7	3.4	1	1	1
Average/Sum#:	0.8	13.2	1,852.3	0.6	60.8 #	24 #	24 #	13 #
Minimum:	0.5	12.3	1,353.8	0.4	1.5	1	1	0
Maximum:	1.1	13.9	2,176.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2022 00:00	1.0	12.4	2,167.7	0.7	3.4	1	1	1
11/03/2022 01:00	1.0	12.5	2,153.5	0.7	3.4	1	1	1
11/03/2022 02:00	1.0	12.3	2,199.7	0.7	3.4	1	1	1
11/03/2022 03:00	0.9	12.1	2,243.0	0.7	3.0	1	1	1
11/03/2022 04:00	1.0	12.4	2,170.3	0.7	3.4	1	1	1
11/03/2022 05:00	1.0	12.4	2,175.5	0.7	3.4	1	1	1
11/03/2022 06:00	0.9	12.1	2,246.8	0.7	3.0	1	1	1
11/03/2022 07:00	0.9	12.6	2,117.7	0.6	3.0	1	1	1
11/03/2022 08:00	0.5	13.9	1,461.2	0.5	1.4	1	1	0
11/03/2022 09:00	0.5	13.9	1,567.5	0.5	1.5	1	1	0
11/03/2022 10:00	0.5	13.9	1,581.7	0.4	1.5	1	1	0
11/03/2022 11:00	0.4	13.9	1,575.7	0.4	1.2	1	1	0
11/03/2022 12:00	0.4	13.9	1,587.6	0.3	1.2	1	1	0
11/03/2022 13:00	0.5	13.9	1,496.8	0.3	1.4	1	1	0
11/03/2022 14:00	0.4	13.9	1,564.2	0.3	1.2	1	1	0
11/03/2022 15:00	0.4	13.8	1,787.2	0.3	1.3	1	1	1
11/03/2022 16:00	1.1	12.7	2,081.8	0.5	3.7	1	1	1
11/03/2022 17:00	1.0	12.4	2,162.4	0.6	3.4	1	1	1
11/03/2022 18:00	1.0	12.3	2,178.2	0.7	3.3	1	1	1
11/03/2022 19:00	0.9	12.3	2,176.0	0.7	3.0	1	1	1
11/03/2022 20:00	0.9	12.3	2,164.2	0.6	3.0	1	1	1
11/03/2022 21:00	0.9	12.3	2,163.9	0.6	3.0	1	1	1
11/03/2022 22:00	0.9	12.3	2,163.3	0.6	3.0	1	1	1
11/03/2022 23:00	0.9	12.1	2,220.6	0.6	3.0	1	1	1
Average/Sum#:	0.8	12.9	1,975.3	0.6	62.1 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,461.2	0.3	1.2	1	1	0
Maximum:	1.1	13.9	2,246.8	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2022 00:00	1.0	12.5	2,148.4	0.6	3.4	1	1	1
11/04/2022 01:00	1.0	12.6	2,120.9	0.7	3.4	1	1	1
11/04/2022 02:00	0.9	12.8	2,070.3	0.7	3.0	1	1	1
11/04/2022 03:00	1.0	12.8	2,074.1	0.7	3.4	1	1	1
11/04/2022 04:00	1.0	12.5	2,153.1	0.7	3.4	1	1	1
11/04/2022 05:00	0.9	12.0	2,266.7	0.7	3.0	1	1	1
11/04/2022 06:00	1.0	12.4	2,187.8	0.7	3.4	1	1	1
11/04/2022 07:00	1.0	12.8	2,062.9	0.7	3.4	1	1	1
11/04/2022 08:00	0.4	13.8	1,733.8	0.6	1.3	1	1	0
11/04/2022 09:00	0.5	13.9	1,557.3	0.5	1.5	1	1	0
11/04/2022 10:00	0.5	13.9	1,396.0	0.4	1.3	1	1	0
11/04/2022 11:00	0.6	14.0	1,324.8	0.4	1.5	1	1	0
11/04/2022 12:00	0.6	14.0	1,322.8	0.5	1.5	1	1	0
11/04/2022 13:00	0.5	14.0	1,324.0	0.5	1.3	1	1	0
11/04/2022 14:00	0.6	13.9	1,404.7	0.5	1.6	1	1	0
11/04/2022 15:00	0.6	13.8	1,636.8	0.5	1.8	1	1	1
11/04/2022 16:00	1.1	12.6	2,081.0	0.6	3.6	1	1	1
11/04/2022 17:00	1.0	12.4	2,119.5	0.7	3.3	1	1	1
11/04/2022 18:00	0.9	12.7	2,057.5	0.7	3.0	1	1	1
11/04/2022 19:00	0.9	12.7	2,056.8	0.6	3.0	1	1	1
11/04/2022 20:00	0.9	12.8	2,052.8	0.6	3.0	1	1	1
11/04/2022 21:00	0.9	12.8	2,054.4	0.7	3.0	1	1	1
11/04/2022 22:00	0.9	12.8	2,054.9	0.7	3.0	1	1	1
11/04/2022 23:00	1.1	13.3	1,952.5	0.8	3.7	1	1	1
Average/Sum#:	0.8	13.1	1,883.9	0.6	63.8 #	24 #	24 #	17 #
Minimum:	0.4	12.0	1,322.8	0.4	1.3	1	1	0
Maximum:	1.1	14.0	2,266.7	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	1.2	13.3	1,950.5	0.8	4.1	1	1	1
11/05/2022 01:00	1.2	13.3	1,950.4	0.9	4.1	1	1	1
11/05/2022 02:00	1.2	13.3	1,950.1	0.9	4.1	1	1	1
11/05/2022 03:00	1.3	13.3	1,950.9	0.9	4.4	1	1	1
11/05/2022 04:00	1.3	13.3	1,954.3	1.0	4.4	1	1	1
11/05/2022 05:00	1.3	13.3	1,956.6	1.0	4.4	1	1	1
11/05/2022 06:00	1.3	13.3	1,927.6	1.0	4.4	1	1	1
11/05/2022 07:00	21.2	15.8	567.3	0.0	7.2	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	19.1	18.8	195.5	0.0	4.7	1	0	0
11/05/2022 14:00	38.9	16.1	711.5	0.0	76.2	1	0	0
11/05/2022 15:00	0.5	13.9	1,436.7	0.0	1.4	1	0	0
11/05/2022 16:00	1.1	13.4	1,707.2	0.0	3.3	1	0	1
11/05/2022 17:00	1.2	13.0	1,981.9	0.7	4.0	1	0	1
11/05/2022 18:00	1.3	13.0	1,971.9	0.9	4.3	1	0	1
11/05/2022 19:00	1.4	13.0	1,972.1	1.0	4.6	1	0	1
11/05/2022 20:00	1.5	13.0	1,975.2	1.0	5.0	1	0	1
11/05/2022 21:00	1.1	13.5	1,647.5	1.0	3.2	1	0	1
11/05/2022 22:00	0.7	13.9	1,409.8	0.9	1.9	1	0	0
11/05/2022 23:00	0.5	13.8	1,653.4	0.6	1.5	1	0	0
Average/Sum#:	5.1	13.9	1,624.8	0.9	147.2 #	19 #	7 #	13 #
Minimum:	0.5	13.0	195.5	0.6	1.4	0	0	0
Maximum:	38.9	18.8	1,981.9	1.0	76.2	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.5	13.8	1,564.1	0.5	1.5	1	0	0
11/06/2022 01:00	0.6	13.8	1,463.6	0.4	1.6	1	0	0
11/06/2022 02:00	29.7	16.3	377.6	0.0	5.8	1	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	10.3	14.6	1,135.1	0.5	8.9 #	3 #	9 #	0 #
Minimum:	0.5	13.8	377.6	0.4	1.5	0	0	0
Maximum:	29.7	16.3	1,564.1	0.5	5.8	1	1	0
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/07/2022 03:00	85.1	18.1	281.0	0.0	45.1	1	1	0
11/07/2022 04:00	40.7	16.6	549.1	0.0	68.6	1	1	0
11/07/2022 05:00	0.6	13.7	1,723.5	0.0	1.9	1	1	0
11/07/2022 06:00	1.0	12.9	2,000.6	0.0	3.3	1	1	1
11/07/2022 07:00	1.0	12.1	2,210.3	0.0	3.3	1	1	1
11/07/2022 08:00	1.0	13.0	1,980.7	0.7	3.3	1	1	1
11/07/2022 09:00	1.1	13.0	1,964.2	0.7	3.6	1	1	1
11/07/2022 10:00	1.0	13.0	1,956.5	0.7	3.3	1	1	1
11/07/2022 11:00	0.8	13.1	1,957.6	0.7	2.7	1	1	1
11/07/2022 12:00	0.7	13.1	1,957.2	0.6	2.3	1	1	1
11/07/2022 13:00	0.8	13.1	1,960.7	0.6	2.7	1	1	1
11/07/2022 14:00	0.9	12.8	2,055.3	0.6	3.0	1	1	1
11/07/2022 15:00	0.9	12.2	2,186.1	0.6	3.0	1	1	1
11/07/2022 16:00	0.8	11.9	2,241.6	0.6	2.6	1	1	1
11/07/2022 17:00	0.7	11.8	2,276.8	0.5	2.3	1	1	1
11/07/2022 18:00	0.7	11.8	2,279.9	0.5	2.3	1	1	1
11/07/2022 19:00	0.7	11.8	2,279.4	0.5	2.3	1	1	1
11/07/2022 20:00	0.7	11.8	2,276.6	0.5	2.3	1	1	1
11/07/2022 21:00	0.7	11.8	2,272.9	0.5	2.3	1	1	1
11/07/2022 22:00	0.8	12.0	2,232.3	0.5	2.7	1	1	1
11/07/2022 23:00	0.8	12.4	2,159.5	0.5	2.7	1	1	1
Average/Sum#:	6.7	13.0	1,942.9	0.6	165.6 #	21 #	22 #	18 #
Minimum:	0.6	11.8	281.0	0.5	1.9	0	0	0
Maximum:	85.1	18.1	2,279.9	0.7	68.6	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.9	12.4	2,151.8	0.6	3.0	1	1	1
11/08/2022 01:00	0.9	12.4	2,149.8	0.6	3.0	1	1	1
11/08/2022 02:00	0.8	12.6	2,096.5	0.6	2.7	1	1	1
11/08/2022 03:00	0.9	12.4	2,143.2	0.6	3.0	1	1	1
11/08/2022 04:00	0.9	12.2	2,180.4	0.6	3.0	1	1	1
11/08/2022 05:00	0.8	12.1	2,197.5	0.6	2.6	1	1	1
11/08/2022 06:00	0.7	11.7	2,281.0	0.5	2.3	1	1	1
11/08/2022 07:00	0.8	12.1	2,193.7	0.5	2.6	1	1	1
11/08/2022 08:00	0.8	12.1	2,185.1	0.5	2.6	1	1	1
11/08/2022 09:00	0.8	12.2	2,181.7	0.5	2.6	1	1	1
11/08/2022 10:00	0.9	12.3	2,165.2	0.5	3.0	1	1	1
11/08/2022 11:00	0.8	12.9	2,016.4	0.6	2.7	1	1	1
11/08/2022 12:00	0.8	13.1	1,972.3	0.6	2.7	1	1	1
11/08/2022 13:00	0.8	13.2	1,972.1	0.6	2.7	1	1	1
11/08/2022 14:00	0.9	12.9	2,046.8	0.6	3.0	1	1	1
11/08/2022 15:00	0.8	12.9	2,043.8	0.6	2.7	1	1	1
11/08/2022 16:00	0.8	12.2	2,202.3	0.6	2.7	1	1	1
11/08/2022 17:00	0.8	12.2	2,181.5	0.5	2.6	1	1	1
11/08/2022 18:00	0.9	12.4	2,151.7	0.5	3.0	1	1	1
11/08/2022 19:00	0.8	12.2	2,186.1	0.5	2.7	1	1	1
11/08/2022 20:00	0.8	12.2	2,194.5	0.5	2.7	1	1	1
11/08/2022 21:00	0.8	12.2	2,195.9	0.5	2.7	1	1	1
11/08/2022 22:00	0.8	12.2	2,180.1	0.5	2.6	1	1	1
11/08/2022 23:00	0.9	12.4	2,137.2	0.5	3.0	1	1	1
Average/Sum#:	0.8	12.4	2,141.9	0.6	66.2 #	24 #	24 #	24 #
Minimum:	0.7	11.7	1,972.1	0.5	2.3	1	1	1
Maximum:	0.9	13.2	2,281.0	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2022 00:00	0.9	12.4	2,147.1	0.6	3.0	1	1	1
11/09/2022 01:00	0.9	12.4	2,147.0	0.6	3.0	1	1	1
11/09/2022 02:00	0.9	12.3	2,184.9	0.6	3.0	1	1	1
11/09/2022 03:00	0.9	12.3	2,187.0	0.6	3.0	1	1	1
11/09/2022 04:00	0.9	12.5	2,154.3	0.6	3.0	1	1	1
11/09/2022 05:00	0.8	11.9	2,246.2	0.6	2.6	1	1	1
11/09/2022 06:00	0.7	11.9	2,284.3	0.5	2.3	1	1	1
11/09/2022 07:00	0.8	12.4	2,184.8	0.5	2.7	1	1	1
11/09/2022 08:00	0.8	12.5	2,147.6	0.6	2.7	1	1	1
11/09/2022 09:00	0.4	13.7	1,760.8	0.5	1.3	1	1	1
11/09/2022 10:00	0.3	13.9	1,725.2	0.4	1.0	1	1	0
11/09/2022 11:00	0.3	13.9	1,641.0	0.3	0.9	1	1	0
11/09/2022 12:00	0.3	13.9	1,716.3	0.3	1.0	1	1	0
11/09/2022 13:00	0.3	13.9	1,625.0	0.3	0.9	1	1	0
11/09/2022 14:00	0.3	13.9	1,698.0	0.3	1.0	1	1	0
11/09/2022 15:00	0.4	13.9	1,645.4	0.3	1.2	1	1	1
11/09/2022 16:00	1.0	12.8	2,074.2	0.4	3.4	1	1	1
11/09/2022 17:00	0.9	12.5	2,153.5	0.5	3.0	1	1	1
11/09/2022 18:00	0.9	13.1	2,009.9	0.7	3.1	1	1	1
11/09/2022 19:00	1.1	13.3	1,973.0	0.7	3.8	1	1	1
11/09/2022 20:00	1.1	13.3	1,976.7	0.8	3.8	1	1	1
11/09/2022 21:00	1.1	13.3	1,988.3	0.9	3.8	1	1	1
11/09/2022 22:00	1.1	13.3	1,979.1	0.9	3.8	1	1	1
11/09/2022 23:00	1.1	13.3	1,977.5	0.9	3.8	1	1	1
Average/Sum#:	0.8	13.0	1,984.5	0.6	61.1 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,625.0	0.3	0.9	1	1	0
Maximum:	1.1	13.9	2,284.3	0.9	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2022 00:00	1.1	13.3	1,977.3	0.9	3.8	1	1	1
11/10/2022 01:00	1.1	13.3	1,975.5	0.9	3.8	1	1	1
11/10/2022 02:00	1.1	13.3	1,974.4	0.9	3.8	1	1	1
11/10/2022 03:00	1.1	13.3	1,977.4	0.9	3.8	1	1	1
11/10/2022 04:00	1.0	12.9	2,073.4	0.8	3.4	1	1	1
11/10/2022 05:00	0.8	12.3	2,174.8	0.7	2.7	1	1	1
11/10/2022 06:00	0.8	12.0	2,299.8	0.6	2.7	1	1	1
11/10/2022 07:00	0.9	12.7	2,110.5	0.5	3.1	1	1	1
11/10/2022 08:00	1.1	13.3	1,967.3	0.7	3.8	1	1	1
11/10/2022 09:00	1.1	13.3	1,948.5	0.8	3.7	1	1	1
11/10/2022 10:00	0.3	13.9	1,736.2	0.7	1.0	1	1	0
11/10/2022 11:00	0.3	13.9	1,728.1	0.5	1.0	1	1	0
11/10/2022 12:00	0.3	13.9	1,714.9	0.3	1.0	1	1	0
11/10/2022 13:00	0.3	14.0	1,570.6	0.3	0.9	1	1	0
11/10/2022 14:00	0.3	13.9	1,724.2	0.3	1.0	1	1	0
11/10/2022 15:00	0.3	13.9	1,723.1	0.3	1.0	1	1	1
11/10/2022 16:00	1.2	12.6	2,126.5	0.5	4.1	1	1	1
11/10/2022 17:00	0.7	11.9	2,271.9	0.6	2.3	1	1	1
11/10/2022 18:00	0.7	11.9	2,274.6	0.6	2.3	1	1	1
11/10/2022 19:00	0.7	11.9	2,278.5	0.5	2.3	1	1	1
11/10/2022 20:00	0.7	11.9	2,278.8	0.5	2.3	1	1	1
11/10/2022 21:00	0.7	11.9	2,281.7	0.5	2.3	1	1	1
11/10/2022 22:00	0.7	11.9	2,281.2	0.5	2.3	1	1	1
11/10/2022 23:00	0.7	12.0	2,256.4	0.5	2.3	1	1	1
Average/Sum#:	0.8	12.9	2,030.2	0.6	60.7 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,570.6	0.3	0.9	1	1	0
Maximum:	1.2	14.0	2,299.8	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.7	12.0	2,281.8	0.5	2.4	1	1	1
11/11/2022 01:00	0.7	12.0	2,275.8	0.5	2.4	1	1	1
11/11/2022 02:00	0.8	12.6	2,145.1	0.5	2.7	1	1	1
11/11/2022 03:00	0.8	12.6	2,142.7	0.6	2.7	1	1	1
11/11/2022 04:00	0.8	12.1	2,271.6	0.6	2.7	1	1	1
11/11/2022 05:00	0.8	12.0	2,285.2	0.5	2.7	1	1	1
11/11/2022 06:00	0.7	12.0	2,284.1	0.5	2.4	1	1	1
11/11/2022 07:00	0.9	12.7	2,108.2	0.5	3.1	1	1	1
11/11/2022 08:00	1.1	13.3	1,940.2	0.7	3.7	1	1	1
11/11/2022 09:00	0.3	13.9	1,718.1	0.6	1.0	1	1	0
11/11/2022 10:00	0.3	13.9	1,724.0	0.5	1.0	1	1	0
11/11/2022 11:00	0.3	13.9	1,688.9	0.3	1.0	1	1	0
11/11/2022 12:00	0.3	13.9	1,687.5	0.3	1.0	1	1	0
11/11/2022 13:00	0.3	13.9	1,700.7	0.3	1.0	1	1	0
11/11/2022 14:00	0.3	13.9	1,582.3	0.3	0.9	1	1	0
11/11/2022 15:00	0.3	13.9	1,688.6	0.3	1.0	1	1	0
11/11/2022 16:00	1.0	13.0	1,979.8	0.4	3.3	1	1	1
11/11/2022 17:00	0.7	11.8	2,273.3	0.5	2.3	1	1	1
11/11/2022 18:00	0.7	11.9	2,266.1	0.6	2.3	1	1	1
11/11/2022 19:00	0.7	11.9	2,254.1	0.5	2.3	1	1	1
11/11/2022 20:00	0.7	11.9	2,250.8	0.5	2.3	1	1	1
11/11/2022 21:00	0.7	11.9	2,249.2	0.5	2.3	1	1	1
11/11/2022 22:00	0.8	12.1	2,243.3	0.5	2.7	1	1	1
11/11/2022 23:00	0.8	12.0	2,260.9	0.5	2.7	1	1	1
Average/Sum#:	0.6	12.7	2,054.3	0.5	51.9 #	24 #	24 #	17 #
Minimum:	0.3	11.8	1,582.3	0.3	0.9	1	1	0
Maximum:	1.1	13.9	2,285.2	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.8	12.0	2,265.2	0.5	2.7	1	1	1
11/12/2022 01:00	0.8	12.0	2,268.8	0.5	2.7	1	1	1
11/12/2022 02:00	0.8	12.0	2,275.3	0.5	2.7	1	1	1
11/12/2022 03:00	0.8	12.0	2,278.8	0.5	2.7	1	1	1
11/12/2022 04:00	0.8	12.0	2,285.3	0.5	2.7	1	1	1
11/12/2022 05:00	0.8	12.0	2,286.6	0.5	2.7	1	1	1
11/12/2022 06:00	0.8	12.0	2,277.1	0.5	2.7	1	1	1
11/12/2022 07:00	0.8	12.7	2,119.5	0.5	2.7	1	1	1
11/12/2022 08:00	0.8	12.2	2,196.2	0.5	2.7	1	1	1
11/12/2022 09:00	0.4	13.7	1,755.8	0.5	1.3	1	1	1
11/12/2022 10:00	0.3	13.9	1,596.8	0.4	0.9	1	1	0
11/12/2022 11:00	0.3	13.9	1,557.9	0.3	0.9	1	1	0
11/12/2022 12:00	0.3	13.9	1,557.2	0.3	0.9	1	1	0
11/12/2022 13:00	0.3	13.9	1,580.9	0.3	0.9	1	1	0
11/12/2022 14:00	0.3	13.9	1,557.8	0.3	0.9	1	1	0
11/12/2022 15:00	0.3	13.8	1,793.1	0.3	1.0	1	1	1
11/12/2022 16:00	1.2	12.5	2,136.2	0.4	4.0	1	1	1
11/12/2022 17:00	0.7	11.8	2,289.6	0.5	2.3	1	1	1
11/12/2022 18:00	0.7	11.8	2,288.4	0.6	2.3	1	1	1
11/12/2022 19:00	0.7	11.8	2,294.2	0.5	2.3	1	1	1
11/12/2022 20:00	0.7	11.8	2,304.8	0.5	2.3	1	1	1
11/12/2022 21:00	0.7	11.8	2,300.6	0.5	2.3	1	1	1
11/12/2022 22:00	0.8	12.3	2,197.1	0.5	2.7	1	1	1
11/12/2022 23:00	0.8	12.3	2,192.7	0.5	2.7	1	1	1
Average/Sum#:	0.7	12.6	2,069.0	0.5	52.0 #	24 #	24 #	19 #
Minimum:	0.3	11.8	1,557.2	0.3	0.9	1	1	0
Maximum:	1.2	13.9	2,304.8	0.6	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.8	12.4	2,183.0	0.5	2.7	1	1	1
11/13/2022 01:00	0.8	12.4	2,169.4	0.6	2.7	1	1	1
11/13/2022 02:00	0.8	12.5	2,162.2	0.6	2.7	1	1	1
11/13/2022 03:00	0.8	12.3	2,198.3	0.6	2.7	1	1	1
11/13/2022 04:00	0.8	12.4	2,192.5	0.6	2.7	1	1	1
11/13/2022 05:00	0.8	12.4	2,185.1	0.6	2.7	1	1	1
11/13/2022 06:00	0.8	12.3	2,201.5	0.6	2.7	1	1	1
11/13/2022 07:00	0.7	12.0	2,269.1	0.5	2.4	1	1	1
11/13/2022 08:00	0.6	12.9	1,972.8	0.5	2.0	1	1	1
11/13/2022 09:00	0.3	13.9	1,713.6	0.4	1.0	1	1	0
11/13/2022 10:00	0.3	13.9	1,714.5	0.3	1.0	1	1	0
11/13/2022 11:00	0.3	13.9	1,714.3	0.3	1.0	1	1	0
11/13/2022 12:00	0.3	13.9	1,712.3	0.3	1.0	1	1	0
11/13/2022 13:00	0.3	14.0	1,713.9	0.3	1.0	1	1	0
11/13/2022 14:00	0.3	14.0	1,686.9	0.3	1.0	1	1	0
11/13/2022 15:00	0.3	13.8	1,797.5	0.3	1.0	1	1	1
11/13/2022 16:00	0.8	12.6	2,132.3	0.4	2.7	1	1	1
11/13/2022 17:00	0.6	12.0	2,273.8	0.4	2.0	1	1	1
11/13/2022 18:00	0.6	12.0	2,273.5	0.5	2.0	1	1	1
11/13/2022 19:00	0.6	12.0	2,277.3	0.4	2.0	1	1	1
11/13/2022 20:00	0.6	12.0	2,280.0	0.4	2.0	1	1	1
11/13/2022 21:00	0.6	12.0	2,284.9	0.4	2.0	1	1	1
11/13/2022 22:00	0.6	12.0	2,287.2	0.4	2.0	1	1	1
11/13/2022 23:00	0.6	12.0	2,294.0	0.4	2.0	1	1	1
Average/Sum#:	0.6	12.7	2,070.4	0.4	47.0 #	24 #	24 #	18 #
Minimum:	0.3	12.0	1,686.9	0.3	1.0	1	1	0
Maximum:	0.8	14.0	2,294.0	0.6	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.6	12.1	2,288.4	0.4	2.1	1	1	1
11/14/2022 01:00	0.7	12.1	2,277.6	0.4	2.4	1	1	1
11/14/2022 02:00	0.7	12.2	2,265.6	0.5	2.4	1	1	1
11/14/2022 03:00	0.8	12.7	2,149.5	0.5	2.8	1	1	1
11/14/2022 04:00	0.8	12.4	2,230.6	0.6	2.8	1	1	1
11/14/2022 05:00	0.7	12.2	2,291.8	0.6	2.4	1	1	1
11/14/2022 06:00	0.7	12.2	2,286.5	0.5	2.4	1	1	1
11/14/2022 07:00	0.8	12.6	2,184.1	0.5	2.8	1	1	1
11/14/2022 08:00	0.8	12.7	2,143.2	0.6	2.8	1	1	1
11/14/2022 09:00	0.8	12.6	2,149.5	0.6	2.7	1	1	1
11/14/2022 10:00	0.8	12.6	2,141.4	0.6	2.7	1	1	1
11/14/2022 11:00	0.7	12.7	2,116.8	0.6	2.4	1	1	1
11/14/2022 12:00	0.7	12.7	2,106.1	0.5	2.4	1	1	1
11/14/2022 13:00	0.7	12.5	2,137.1	0.5	2.4	1	1	1
11/14/2022 14:00	0.7	12.5	2,137.4	0.5	2.4	1	1	1
11/14/2022 15:00	0.7	12.8	2,062.7	0.5	2.4	1	1	1
11/14/2022 16:00	0.6	12.1	2,229.8	0.5	2.0	1	1	1
11/14/2022 17:00	0.7	12.3	2,177.1	0.5	2.3	1	1	1
11/14/2022 18:00	0.7	12.5	2,159.1	0.5	2.4	1	1	1
11/14/2022 19:00	0.6	12.1	2,265.3	0.5	2.0	1	1	1
11/14/2022 20:00	0.6	12.0	2,281.3	0.4	2.0	1	1	1
11/14/2022 21:00	0.6	12.1	2,256.1	0.4	2.0	1	1	1
11/14/2022 22:00	0.6	12.1	2,259.7	0.4	2.0	1	1	1
11/14/2022 23:00	0.6	12.2	2,239.5	0.4	2.0	1	1	1
Average/Sum#:	0.7	12.4	2,201.5	0.5	57.0 #	24 #	24 #	24 #
Minimum:	0.6	12.0	2,062.7	0.4	2.0	1	1	1
Maximum:	0.8	12.8	2,291.8	0.6	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	0.6	12.1	2,265.0	0.4	2.0	1	1	1
11/15/2022 01:00	0.6	12.1	2,268.0	0.4	2.0	1	1	1
11/15/2022 02:00	0.6	12.0	2,286.6	0.4	2.0	1	1	1
11/15/2022 03:00	0.6	12.0	2,296.0	0.4	2.0	1	1	1
11/15/2022 04:00	0.6	12.0	2,299.8	0.4	2.0	1	1	1
11/15/2022 05:00	0.6	11.7	2,332.5	0.4	2.0	1	1	1
11/15/2022 06:00	0.7	12.2	2,202.6	0.4	2.3	1	1	1
11/15/2022 07:00	0.6	11.8	2,323.2	0.4	2.0	1	1	1
11/15/2022 08:00	0.6	12.0	2,234.7	0.4	2.0	1	1	1
11/15/2022 09:00	0.7	12.6	2,114.0	0.4	2.4	1	1	1
11/15/2022 10:00	0.8	12.5	2,135.7	0.5	2.7	1	1	1
11/15/2022 11:00	0.9	12.9	2,037.3	0.6	3.0	1	1	1
11/15/2022 12:00	1.3	13.3	1,961.1	0.8	4.4	1	1	1
11/15/2022 13:00	1.3	13.3	1,967.3	0.9	4.4	1	1	1
11/15/2022 14:00	0.0	0.0	1,973.8	0.0	0.0	1	1	1
11/15/2022 15:00	0.0	0.0	2,007.0	0.0	0.0	1	1	1
11/15/2022 16:00	0.9	12.5	2,120.1	0.0	3.0	1	1	1
11/15/2022 17:00	0.9	12.4	2,133.8	0.0	3.0	1	1	1
11/15/2022 18:00	0.8	12.4	2,123.0	0.6	2.6	1	1	1
11/15/2022 19:00	0.8	12.3	2,137.1	0.6	2.6	1	1	1
11/15/2022 20:00	0.8	12.2	2,175.2	0.5	2.6	1	1	1
11/15/2022 21:00	0.7	11.9	2,237.4	0.5	2.3	1	1	1
11/15/2022 22:00	0.8	12.3	2,149.1	0.5	2.6	1	1	1
11/15/2022 23:00	0.8	12.3	2,148.1	0.5	2.6	1	1	1
Average/Sum#:	0.8	12.3	2,163.7	0.5	56.5 #	24 #	24 #	24 #
Minimum:	0.6	11.7	1,961.1	0.4	2.0	1	1	1
Maximum:	1.3	13.3	2,332.5	0.9	4.4	1	1	1
%SI	8.33	8.33	0.00	16.67	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2022 00:00	0.8	12.3	2,142.4	0.5	2.6	1	1	1
11/16/2022 01:00	0.8	12.5	2,116.0	0.5	2.7	1	1	1
11/16/2022 02:00	0.8	12.4	2,139.8	0.6	2.7	1	1	1
11/16/2022 03:00	0.8	12.4	2,144.4	0.6	2.7	1	1	1
11/16/2022 04:00	0.8	11.9	2,274.6	0.6	2.7	1	1	1
11/16/2022 05:00	0.7	11.5	2,340.0	0.5	2.3	1	1	1
11/16/2022 06:00	0.6	11.5	2,346.5	0.4	2.0	1	1	1
11/16/2022 07:00	0.7	11.9	2,254.3	0.4	2.3	1	1	1
11/16/2022 08:00	1.0	13.3	1,966.8	0.6	3.4	1	1	1
11/16/2022 09:00	1.2	13.6	1,997.0	0.8	4.3	1	1	1
11/16/2022 10:00	1.2	13.2	1,964.8	0.9	4.0	1	1	1
11/16/2022 11:00	1.2	13.2	1,969.2	0.9	4.1	1	1	1
11/16/2022 12:00	1.2	13.1	1,978.0	0.9	4.0	1	1	1
11/16/2022 13:00	1.2	13.1	1,980.5	0.9	4.0	1	1	1
11/16/2022 14:00	1.2	13.1	1,981.2	0.9	4.0	1	1	1
11/16/2022 15:00	1.0	12.6	2,101.9	0.8	3.3	1	1	1
11/16/2022 16:00	0.8	12.3	2,161.6	0.7	2.7	1	1	1
11/16/2022 17:00	0.8	12.3	2,165.8	0.6	2.7	1	1	1
11/16/2022 18:00	0.7	12.0	2,221.6	0.5	2.3	1	1	1
11/16/2022 19:00	0.7	11.9	2,228.4	0.5	2.3	1	1	1
11/16/2022 20:00	0.7	11.9	2,229.7	0.5	2.3	1	1	1
11/16/2022 21:00	0.8	12.0	2,244.6	0.5	2.7	1	1	1
11/16/2022 22:00	0.8	12.2	2,216.3	0.5	2.7	1	1	1
11/16/2022 23:00	0.8	12.0	2,243.9	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.4	2,142.1	0.6	71.5 #	24 #	24 #	24 #
Minimum:	0.6	11.5	1,964.8	0.4	2.0	1	1	1
Maximum:	1.2	13.6	2,346.5	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.8	12.4	2,159.1	0.5	2.7	1	1	1
11/17/2022 01:00	0.8	12.4	2,159.4	0.6	2.7	1	1	1
11/17/2022 02:00	0.8	12.5	2,146.1	0.6	2.7	1	1	1
11/17/2022 03:00	0.8	12.5	2,149.6	0.6	2.7	1	1	1
11/17/2022 04:00	0.8	12.2	2,231.0	0.6	2.7	1	1	1
11/17/2022 05:00	0.7	11.6	2,357.0	0.5	2.3	1	1	1
11/17/2022 06:00	0.7	11.9	2,276.3	0.5	2.3	1	1	1
11/17/2022 07:00	0.8	12.4	2,162.7	0.5	2.7	1	1	1
11/17/2022 08:00	1.0	13.1	1,985.4	0.6	3.4	1	1	1
11/17/2022 09:00	0.8	12.5	2,129.0	0.7	2.7	1	1	1
11/17/2022 10:00	0.8	12.5	2,110.8	0.7	2.7	1	1	1
11/17/2022 11:00	0.8	12.3	2,133.9	0.6	2.6	1	1	1
11/17/2022 12:00	0.7	12.1	2,171.5	0.5	2.3	1	1	1
11/17/2022 13:00	0.7	12.2	2,169.8	0.5	2.3	1	1	1
11/17/2022 14:00	0.7	12.9	2,005.0	0.5	2.3	1	1	1
11/17/2022 15:00	0.7	12.4	2,118.7	0.5	2.3	1	1	1
11/17/2022 16:00	0.7	11.9	2,234.9	0.5	2.3	1	1	1
11/17/2022 17:00	0.6	11.8	2,268.2	0.5	2.0	1	1	1
11/17/2022 18:00	0.6	11.8	2,255.7	0.4	2.0	1	1	1
11/17/2022 19:00	0.6	11.8	2,258.8	0.4	2.0	1	1	1
11/17/2022 20:00	0.7	11.8	2,260.2	0.4	2.3	1	1	1
11/17/2022 21:00	0.6	11.8	2,262.4	0.4	2.0	1	1	1
11/17/2022 22:00	0.7	11.9	2,246.4	0.5	2.3	1	1	1
11/17/2022 23:00	0.8	12.2	2,206.6	0.5	2.7	1	1	1
Average/Sum#:	0.7	12.2	2,185.8	0.5	59.0 #	24 #	24 #	24 #
Minimum:	0.6	11.6	1,985.4	0.4	2.0	1	1	1
Maximum:	1.0	13.1	2,357.0	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.8	12.4	2,157.1	0.5	2.7	1	1	1
11/18/2022 01:00	0.8	12.3	2,164.4	0.5	2.7	1	1	1
11/18/2022 02:00	0.8	12.2	2,166.7	0.5	2.6	1	1	1
11/18/2022 03:00	0.8	12.3	2,166.0	0.5	2.7	1	1	1
11/18/2022 04:00	0.6	11.6	2,308.1	0.5	2.0	1	1	1
11/18/2022 05:00	0.6	11.5	2,326.0	0.4	2.0	1	1	1
11/18/2022 06:00	0.6	11.5	2,333.1	0.4	2.0	1	1	1
11/18/2022 07:00	0.7	11.8	2,267.0	0.4	2.3	1	1	1
11/18/2022 08:00	0.8	12.3	2,145.7	0.5	2.6	1	1	1
11/18/2022 09:00	0.8	12.3	2,153.7	0.5	2.6	1	1	1
11/18/2022 10:00	0.7	12.2	2,162.8	0.5	2.3	1	1	1
11/18/2022 11:00	0.7	12.4	2,100.8	0.5	2.3	1	1	1
11/18/2022 12:00	0.8	13.1	1,958.4	0.5	2.7	1	1	1
11/18/2022 13:00	0.8	13.1	1,960.1	0.6	2.7	1	1	1
11/18/2022 14:00	0.8	13.0	1,964.5	0.6	2.6	1	1	1
11/18/2022 15:00	0.8	12.7	2,040.1	0.6	2.6	1	1	1
11/18/2022 16:00	0.7	12.0	2,220.5	0.6	2.3	1	1	1
11/18/2022 17:00	0.7	11.9	2,244.9	0.5	2.3	1	1	1
11/18/2022 18:00	0.7	11.9	2,243.3	0.5	2.3	1	1	1
11/18/2022 19:00	0.7	11.9	2,245.4	0.5	2.3	1	1	1
11/18/2022 20:00	0.7	11.8	2,276.3	0.5	2.3	1	1	1
11/18/2022 21:00	0.6	11.6	2,328.6	0.5	2.0	1	1	1
11/18/2022 22:00	0.6	11.6	2,341.0	0.4	2.0	1	1	1
11/18/2022 23:00	0.6	11.8	2,301.5	0.4	2.0	1	1	1
Average/Sum#:	0.7	12.1	2,190.7	0.5	56.9 #	24 #	24 #	24 #
Minimum:	0.6	11.5	1,958.4	0.4	2.0	1	1	1
Maximum:	0.8	13.1	2,341.0	0.6	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.8	12.3	2,163.6	0.4	2.7	1	1	1
11/19/2022 01:00	0.8	12.5	2,142.3	0.5	2.7	1	1	1
11/19/2022 02:00	0.8	12.5	2,139.1	0.6	2.7	1	1	1
11/19/2022 03:00	0.8	12.6	2,118.3	0.6	2.7	1	1	1
11/19/2022 04:00	0.8	12.1	2,231.5	0.6	2.7	1	1	1
11/19/2022 05:00	0.7	11.9	2,257.3	0.5	2.3	1	1	1
11/19/2022 06:00	0.8	12.3	2,191.6	0.5	2.7	1	1	1
11/19/2022 07:00	0.8	12.5	2,123.0	0.5	2.7	1	1	1
11/19/2022 08:00	1.1	13.2	1,963.6	0.6	3.7	1	1	1
11/19/2022 09:00	1.1	13.2	1,961.7	0.7	3.7	1	1	1
11/19/2022 10:00	1.1	13.2	1,956.6	0.8	3.7	1	1	1
11/19/2022 11:00	1.1	13.1	1,953.3	0.8	3.6	1	1	1
11/19/2022 12:00	1.0	13.1	1,953.3	0.8	3.3	1	1	1
11/19/2022 13:00	0.9	13.1	1,954.1	0.8	3.0	1	1	1
11/19/2022 14:00	0.9	13.1	1,960.9	0.7	3.0	1	1	1
11/19/2022 15:00	0.8	12.8	2,021.3	0.7	2.6	1	1	1
11/19/2022 16:00	0.7	12.2	2,156.6	0.6	2.3	1	1	1
11/19/2022 17:00	0.7	12.1	2,176.7	0.5	2.3	1	1	1
11/19/2022 18:00	0.7	12.2	2,169.1	0.5	2.3	1	1	1
11/19/2022 19:00	0.6	11.8	2,273.1	0.5	2.0	1	1	1
11/19/2022 20:00	0.6	11.6	2,305.7	0.4	2.0	1	1	1
11/19/2022 21:00	0.6	11.6	2,312.8	0.4	2.0	1	1	1
11/19/2022 22:00	0.7	11.7	2,340.7	0.4	2.4	1	1	1
11/19/2022 23:00	0.7	11.6	2,358.5	0.4	2.3	1	1	1
Average/Sum#:	0.8	12.4	2,132.7	0.6	65.4 #	24 #	24 #	24 #
Minimum:	0.6	11.6	1,953.3	0.4	2.0	1	1	1
Maximum:	1.1	13.2	2,358.5	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.8	12.0	2,254.8	0.4	2.7	1	1	1
11/20/2022 01:00	0.7	11.9	2,273.0	0.5	2.3	1	1	1
11/20/2022 02:00	0.7	11.8	2,301.3	0.5	2.3	1	1	1
11/20/2022 03:00	0.7	11.9	2,301.2	0.5	2.4	1	1	1
11/20/2022 04:00	0.7	11.9	2,306.4	0.5	2.4	1	1	1
11/20/2022 05:00	0.7	11.7	2,350.0	0.5	2.4	1	1	1
11/20/2022 06:00	0.8	12.1	2,254.5	0.5	2.7	1	1	1
11/20/2022 07:00	0.8	12.6	2,096.3	0.5	2.7	1	1	1
11/20/2022 08:00	0.3	13.8	1,722.3	0.4	1.0	1	1	0
11/20/2022 09:00	0.3	13.8	1,725.4	0.3	1.0	1	1	0
11/20/2022 10:00	0.3	13.8	1,571.5	0.2	0.9	1	1	0
11/20/2022 11:00	0.3	13.9	1,573.6	0.2	0.9	1	1	0
11/20/2022 12:00	0.3	13.9	1,545.9	0.3	0.9	1	1	0
11/20/2022 13:00	0.3	13.9	1,536.5	0.3	0.9	1	1	0
11/20/2022 14:00	0.3	13.8	1,695.0	0.3	0.9	1	1	0
11/20/2022 15:00	0.3	13.8	1,732.2	0.2	1.0	1	1	1
11/20/2022 16:00	0.8	12.3	2,147.2	0.3	2.6	1	1	1
11/20/2022 17:00	0.7	11.8	2,265.5	0.4	2.3	1	1	1
11/20/2022 18:00	0.7	11.8	2,252.2	0.5	2.3	1	1	1
11/20/2022 19:00	0.7	11.8	2,253.5	0.5	2.3	1	1	1
11/20/2022 20:00	0.7	11.8	2,257.4	0.5	2.3	1	1	1
11/20/2022 21:00	0.7	12.1	2,192.6	0.5	2.3	1	1	1
11/20/2022 22:00	0.8	12.4	2,157.4	0.5	2.7	1	1	1
11/20/2022 23:00	0.9	12.5	2,147.5	0.6	3.0	1	1	1
Average/Sum#:	0.6	12.6	2,038.1	0.4	47.2 #	24 #	24 #	17 #
Minimum:	0.3	11.7	1,536.5	0.2	0.9	1	1	0
Maximum:	0.9	13.9	2,350.0	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	0.8	12.4	2,156.8	0.6	2.7	1	1	1
11/21/2022 01:00	0.8	12.6	2,130.5	0.6	2.7	1	1	1
11/21/2022 02:00	1.0	12.9	2,058.0	0.6	3.4	1	1	1
11/21/2022 03:00	0.9	12.4	2,172.2	0.6	3.0	1	1	1
11/21/2022 04:00	0.8	12.0	2,259.2	0.6	2.7	1	1	1
11/21/2022 05:00	0.8	12.0	2,267.5	0.5	2.7	1	1	1
11/21/2022 06:00	0.8	12.0	2,284.4	0.5	2.7	1	1	1
11/21/2022 07:00	0.9	12.5	2,147.1	0.5	3.0	1	1	1
11/21/2022 08:00	1.2	13.2	1,965.1	0.7	4.0	1	1	1
11/21/2022 09:00	1.3	13.2	1,965.2	0.8	4.4	1	1	1
11/21/2022 10:00	1.2	13.2	1,961.7	0.9	4.0	1	1	1
11/21/2022 11:00	1.0	13.1	1,958.9	0.9	3.3	1	1	1
11/21/2022 12:00	0.9	13.0	1,966.2	0.8	3.0	1	1	1
11/21/2022 13:00	0.8	13.0	1,977.7	0.7	2.6	1	1	1
11/21/2022 14:00	0.8	12.2	2,161.3	0.6	2.6	1	1	1
11/21/2022 15:00	0.6	11.8	2,272.0	0.5	2.0	1	1	1
11/21/2022 16:00	0.8	12.0	2,229.0	0.5	2.6	1	1	1
11/21/2022 17:00	0.7	11.9	2,230.9	0.5	2.3	1	1	1
11/21/2022 18:00	0.7	11.9	2,230.5	0.5	2.3	1	1	1
11/21/2022 19:00	0.7	11.8	2,258.6	0.5	2.3	1	1	1
11/21/2022 20:00	0.7	11.8	2,263.5	0.5	2.3	1	1	1
11/21/2022 21:00	0.7	11.8	2,264.2	0.5	2.3	1	1	1
11/21/2022 22:00	0.7	11.8	2,264.8	0.5	2.3	1	1	1
11/21/2022 23:00	0.7	12.0	2,226.0	0.5	2.3	1	1	1
Average/Sum#:	0.8	12.4	2,153.0	0.6	67.5 #	24 #	24 #	24 #
Minimum:	0.6	11.8	1,958.9	0.5	2.0	1	1	1
Maximum:	1.3	13.2	2,284.4	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	0.8	12.4	2,143.9	0.5	2.7	1	1	1
11/22/2022 01:00	0.9	12.6	2,125.4	0.6	3.0	1	1	1
11/22/2022 02:00	0.9	12.6	2,094.4	0.6	3.0	1	1	1
11/22/2022 03:00	1.0	13.1	1,973.7	0.7	3.3	1	1	1
11/22/2022 04:00	1.1	13.1	1,977.2	0.7	3.7	1	1	1
11/22/2022 05:00	1.0	12.6	2,065.9	0.8	3.3	1	1	1
11/22/2022 06:00	0.9	12.5	2,149.0	0.7	3.0	1	1	1
11/22/2022 07:00	1.0	12.7	2,088.9	0.7	3.4	1	1	1
11/22/2022 08:00	1.1	12.9	2,051.0	0.7	3.7	1	1	1
11/22/2022 09:00	6.2	14.2	1,444.6	0.0	15.0	1	1	1
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/22/2022 11:00	1.0	19.5	58.0	0.0	0.1	1	1	0
11/22/2022 12:00	42.6	15.8	756.7	0.0	83.5	1	1	0
11/22/2022 13:00	0.4	13.8	1,622.5	0.0	1.2	1	1	0
11/22/2022 14:00	0.3	13.8	1,790.4	0.0	1.0	1	1	0
11/22/2022 15:00	0.3	13.8	1,790.4	0.2	1.0	1	1	0
11/22/2022 16:00	0.7	13.2	1,897.6	0.3	2.3	1	1	1
11/22/2022 17:00	0.9	12.3	2,141.8	0.4	3.0	1	1	1
11/22/2022 18:00	0.9	12.7	2,035.3	0.6	3.0	1	1	1
11/22/2022 19:00	1.0	13.0	1,982.5	0.6	3.3	1	1	1
11/22/2022 20:00	0.9	12.4	2,138.7	0.6	3.0	1	1	1
11/22/2022 21:00	1.0	12.9	2,017.6	0.7	3.3	1	1	1
11/22/2022 22:00	1.0	12.8	2,028.8	0.7	3.3	1	1	1
11/22/2022 23:00	1.2	13.2	1,957.5	0.8	4.0	1	1	1
Average/Sum#:	2.9	13.4	1,840.5	0.6	156.1 #	23 #	24 #	18 #
Minimum:	0.3	12.3	58.0	0.2	0.1	0	1	0
Maximum:	42.6	19.5	2,149.0	0.8	83.5	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2022 00:00	1.2	13.2	1,958.7	0.8	4.0	1	1	1
11/23/2022 01:00	1.2	13.2	1,960.6	0.9	4.0	1	1	1
11/23/2022 02:00	1.2	13.2	1,958.4	0.9	4.0	1	1	1
11/23/2022 03:00	1.2	13.2	1,962.5	0.9	4.0	1	1	1
11/23/2022 04:00	1.2	13.1	1,969.2	0.9	4.0	1	1	1
11/23/2022 05:00	0.9	12.5	2,057.1	0.8	2.9	1	1	1
11/23/2022 06:00	1.0	12.8	2,048.5	0.7	3.3	1	1	1
11/23/2022 07:00	0.9	12.6	2,103.9	0.6	3.0	1	1	1
11/23/2022 08:00	1.0	13.0	1,993.7	0.7	3.3	1	1	1
11/23/2022 09:00	0.3	13.8	1,707.7	0.5	1.0	1	1	0
11/23/2022 10:00	0.3	13.8	1,562.1	0.4	0.9	1	1	0
11/23/2022 11:00	0.3	13.9	1,556.2	0.2	0.9	1	1	0
11/23/2022 12:00	0.3	13.9	1,424.7	0.3	0.8	1	1	0
11/23/2022 13:00	0.3	13.9	1,558.7	0.3	0.9	1	1	0
11/23/2022 14:00	0.3	13.9	1,628.7	0.3	0.9	1	1	0
11/23/2022 15:00	0.3	13.8	1,649.5	0.3	0.9	1	1	1
11/23/2022 16:00	1.0	12.5	2,097.1	0.4	3.3	1	1	1
11/23/2022 17:00	0.9	12.3	2,159.6	0.5	3.0	1	1	1
11/23/2022 18:00	1.0	12.6	2,078.6	0.7	3.3	1	1	1
11/23/2022 19:00	1.1	12.8	2,045.2	0.7	3.7	1	1	1
11/23/2022 20:00	0.9	12.3	2,155.0	0.7	3.0	1	1	1
11/23/2022 21:00	0.9	12.2	2,168.6	0.7	3.0	1	1	1
11/23/2022 22:00	0.9	12.4	2,143.6	0.6	3.0	1	1	1
11/23/2022 23:00	0.9	12.4	2,140.6	0.6	3.0	1	1	1
Average/Sum#:	0.8	13.1	1,920.4	0.6	64.1 #	24 #	24 #	18 #
Minimum:	0.3	12.2	1,424.7	0.2	0.8	1	1	0
Maximum:	1.2	13.9	2,168.6	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2022 00:00	1.2	13.1	1,975.4	0.7	4.0	1	1	1
11/24/2022 01:00	1.4	13.2	1,962.5	0.9	4.7	1	1	1
11/24/2022 02:00	1.4	13.2	1,963.6	1.0	4.7	1	1	1
11/24/2022 03:00	1.0	13.0	1,975.0	1.0	3.3	1	1	1
11/24/2022 04:00	0.9	12.9	1,985.5	0.8	3.0	1	1	1
11/24/2022 05:00	0.9	12.5	2,052.9	0.7	2.9	1	1	1
11/24/2022 06:00	0.8	12.2	2,165.6	0.6	2.6	1	1	1
11/24/2022 07:00	0.8	12.5	2,079.4	0.6	2.6	1	1	1
11/24/2022 08:00	0.3	13.8	1,712.0	0.4	1.0	1	1	0
11/24/2022 09:00	0.3	13.8	1,709.0	0.3	1.0	1	1	0
11/24/2022 10:00	0.3	13.8	1,716.4	0.2	1.0	1	1	0
11/24/2022 11:00	0.3	13.9	1,560.1	0.2	0.9	1	1	0
11/24/2022 12:00	0.3	13.9	1,351.9	0.3	0.8	1	1	0
11/24/2022 13:00	0.3	13.9	1,350.9	0.3	0.8	1	1	0
11/24/2022 14:00	0.3	13.9	1,562.2	0.3	0.9	1	1	0
11/24/2022 15:00	0.3	13.9	1,450.2	0.3	0.8	1	1	0
11/24/2022 16:00	0.3	13.8	1,769.5	0.3	1.0	1	1	0
11/24/2022 17:00	0.3	13.8	1,768.6	0.2	1.0	1	1	0
11/24/2022 18:00	0.3	13.8	1,745.4	0.2	1.0	1	1	0
11/24/2022 19:00	0.3	13.8	1,737.1	0.2	1.0	1	1	0
11/24/2022 20:00	0.4	13.8	1,746.5	0.2	1.3	1	1	0
11/24/2022 21:00	0.4	13.8	1,747.1	0.3	1.3	1	1	0
11/24/2022 22:00	0.4	13.8	1,751.3	0.3	1.3	1	1	0
11/24/2022 23:00	0.4	13.8	1,753.2	0.3	1.3	1	1	0
Average/Sum#:	0.6	13.5	1,774.6	0.4	44.2 #	24 #	24 #	8 #
Minimum:	0.3	12.2	1,350.9	0.2	0.8	1	1	0
Maximum:	1.4	13.9	2,165.6	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.4	13.8	1,757.2	0.3	1.3	1	1	0
11/25/2022 01:00	0.4	13.8	1,758.4	0.3	1.3	1	1	0
11/25/2022 02:00	0.4	13.8	1,761.0	0.3	1.3	1	1	0
11/25/2022 03:00	0.4	13.8	1,764.3	0.3	1.3	1	1	0
11/25/2022 04:00	0.3	13.8	1,775.1	0.3	1.0	1	1	0
11/25/2022 05:00	0.4	13.8	1,771.2	0.3	1.3	1	1	0
11/25/2022 06:00	0.4	13.8	1,766.8	0.3	1.3	1	1	0
11/25/2022 07:00	0.4	13.8	1,766.8	0.3	1.3	1	1	0
11/25/2022 08:00	0.8	13.4	1,882.1	0.4	2.7	1	1	1
11/25/2022 09:00	0.9	13.1	1,919.7	0.5	2.9	1	1	1
11/25/2022 10:00	0.3	13.8	1,668.0	0.5	0.9	1	1	0
11/25/2022 11:00	0.4	13.8	1,549.0	0.4	1.2	1	1	0
11/25/2022 12:00	0.3	13.8	1,574.7	0.2	0.9	1	1	0
11/25/2022 13:00	0.3	13.8	1,543.3	0.2	0.9	1	1	0
11/25/2022 14:00	0.4	13.8	1,531.6	0.2	1.1	1	1	0
11/25/2022 15:00	0.4	13.7	1,644.3	0.3	1.2	1	1	1
11/25/2022 16:00	1.0	12.6	2,082.1	0.4	3.3	1	1	1
11/25/2022 17:00	0.9	12.5	2,096.7	0.5	3.0	1	1	1
11/25/2022 18:00	1.0	13.0	1,970.2	0.7	3.3	1	1	1
11/25/2022 19:00	1.1	13.1	1,955.6	0.7	3.6	1	1	1
11/25/2022 20:00	1.1	13.1	1,955.0	0.8	3.6	1	1	1
11/25/2022 21:00	1.2	13.1	1,966.3	0.8	4.0	1	1	1
11/25/2022 22:00	0.9	12.5	2,118.6	0.8	3.0	1	1	1
11/25/2022 23:00	0.9	12.6	2,080.0	0.7	3.0	1	1	1
Average/Sum#:	0.6	13.4	1,819.1	0.4	48.7 #	24 #	24 #	11 #
Minimum:	0.3	12.5	1,531.6	0.2	0.9	1	1	0
Maximum:	1.2	13.8	2,118.6	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2022 00:00	1.0	12.9	2,016.8	0.6	3.3	1	1	1
11/26/2022 01:00	1.0	12.7	2,062.0	0.7	3.3	1	1	1
11/26/2022 02:00	5.6	13.8	1,575.4	0.0	16.4	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.5	13.1	1,884.7	0.7	23.0 #	3 #	2 #	3 #
Minimum:	1.0	12.7	1,575.4	0.6	3.3	0	0	0
Maximum:	5.6	13.8	2,062.0	0.7	16.4	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/28/2022 02:00	54.8	17.4	344.2	0.0	67.6	1	1	0
11/28/2022 03:00	28.0	15.2	949.6	0.0	61.6	1	1	0
11/28/2022 04:00	0.4	13.7	1,724.6	0.0	1.3	1	1	0
11/28/2022 05:00	0.5	13.7	1,654.5	0.0	1.5	1	1	1
11/28/2022 06:00	1.1	12.5	2,164.7	0.5	3.7	1	1	1
11/28/2022 07:00	0.9	12.0	2,260.4	0.6	3.0	1	1	1
11/28/2022 08:00	1.0	13.0	1,970.9	0.7	3.3	1	1	1
11/28/2022 09:00	0.4	13.8	1,613.8	0.5	1.2	1	1	0
11/28/2022 10:00	0.4	13.8	1,719.0	0.4	1.3	1	1	0
11/28/2022 11:00	0.4	13.8	1,526.4	0.3	1.1	1	1	0
11/28/2022 12:00	0.3	13.8	1,571.0	0.3	0.9	1	1	0
11/28/2022 13:00	0.3	13.8	1,644.0	0.2	0.9	1	1	0
11/28/2022 14:00	0.3	13.8	1,627.3	0.2	0.9	1	1	0
11/28/2022 15:00	0.4	13.7	1,623.7	0.2	1.2	1	1	1
11/28/2022 16:00	1.0	12.8	2,023.4	0.4	3.3	1	1	1
11/28/2022 17:00	0.9	12.5	2,090.0	0.5	3.0	1	1	1
11/28/2022 18:00	0.9	13.0	1,980.4	0.7	3.0	1	1	1
11/28/2022 19:00	1.1	13.1	1,958.5	0.7	3.6	1	1	1
11/28/2022 20:00	1.0	12.7	2,080.3	0.7	3.4	1	1	1
11/28/2022 21:00	0.8	12.1	2,212.4	0.7	2.7	1	1	1
11/28/2022 22:00	0.9	12.7	2,084.2	0.6	3.0	1	1	1
11/28/2022 23:00	1.0	13.1	1,981.7	0.6	3.4	1	1	1
Average/Sum#:	4.4	13.5	1,763.9	0.5	174.9 #	22 #	24 #	13 #
Minimum:	0.3	12.0	344.2	0.2	0.9	0	1	0
Maximum:	54.8	17.4	2,260.4	0.7	67.6	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.9	12.4	2,141.8	0.7	3.0	1	1	1
11/29/2022 01:00	0.9	12.3	2,186.9	0.7	3.0	1	1	1
11/29/2022 02:00	0.9	12.3	2,175.4	0.6	3.0	1	1	1
11/29/2022 03:00	1.0	12.7	2,087.1	0.6	3.4	1	1	1
11/29/2022 04:00	0.9	12.5	2,149.0	0.6	3.0	1	1	1
11/29/2022 05:00	0.9	12.3	2,196.7	0.6	3.0	1	1	1
11/29/2022 06:00	0.8	11.9	2,281.7	0.6	2.7	1	1	1
11/29/2022 07:00	0.8	11.9	2,281.4	0.5	2.7	1	1	1
11/29/2022 08:00	0.8	11.9	2,244.1	0.5	2.6	1	1	1
11/29/2022 09:00	0.8	12.3	2,150.7	0.5	2.6	1	1	1
11/29/2022 10:00	0.8	12.3	2,145.0	0.5	2.6	1	1	1
11/29/2022 11:00	0.8	12.3	2,136.9	0.5	2.6	1	1	1
11/29/2022 12:00	0.8	12.3	2,126.6	0.5	2.6	1	1	1
11/29/2022 13:00	0.8	12.3	2,125.1	0.5	2.6	1	1	1
11/29/2022 14:00	0.8	12.3	2,128.4	0.5	2.6	1	1	1
11/29/2022 15:00	0.8	12.3	2,146.5	0.5	2.6	1	1	1
11/29/2022 16:00	0.7	11.8	2,253.8	0.5	2.3	1	1	1
11/29/2022 17:00	0.7	11.8	2,262.7	0.5	2.3	1	1	1
11/29/2022 18:00	0.7	11.8	2,269.7	0.5	2.3	1	1	1
11/29/2022 19:00	0.7	11.8	2,270.4	0.5	2.3	1	1	1
11/29/2022 20:00	0.8	11.9	2,275.0	0.5	2.7	1	1	1
11/29/2022 21:00	0.8	11.9	2,279.4	0.5	2.7	1	1	1
11/29/2022 22:00	0.8	11.9	2,281.0	0.5	2.7	1	1	1
11/29/2022 23:00	0.8	11.9	2,279.2	0.5	2.7	1	1	1
Average/Sum#:	0.8	12.1	2,203.1	0.5	64.6 #	24 #	24 #	24 #
Minimum:	0.7	11.8	2,087.1	0.5	2.3	1	1	1
Maximum:	1.0	12.7	2,281.7	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	0.9	12.5	2,172.7	0.5	3.1	1	1	1
11/30/2022 01:00	0.9	12.5	2,154.2	0.6	3.0	1	1	1
11/30/2022 02:00	0.9	12.5	2,150.7	0.6	3.0	1	1	1
11/30/2022 03:00	0.9	12.5	2,151.7	0.6	3.0	1	1	1
11/30/2022 04:00	0.9	12.5	2,168.0	0.6	3.1	1	1	1
11/30/2022 05:00	1.0	12.5	2,165.1	0.6	3.4	1	1	1
11/30/2022 06:00	0.9	12.1	2,258.1	0.6	3.1	1	1	1
11/30/2022 07:00	0.9	12.5	2,146.1	0.6	3.0	1	1	1
11/30/2022 08:00	1.3	13.2	1,980.7	0.7	4.4	1	1	1
11/30/2022 09:00	1.3	13.1	1,994.5	0.9	4.4	1	1	1
11/30/2022 10:00	1.2	13.2	1,971.3	1.0	4.1	1	1	1
11/30/2022 11:00	1.2	13.1	1,965.9	0.9	4.0	1	1	1
11/30/2022 12:00	1.2	13.1	1,966.2	0.9	4.0	1	1	1
11/30/2022 13:00	1.1	13.0	1,964.4	0.9	3.6	1	1	1
11/30/2022 14:00	0.9	12.4	2,104.4	0.8	2.9	1	1	1
11/30/2022 15:00	0.9	12.3	2,113.2	0.7	2.9	1	1	1
11/30/2022 16:00	0.8	11.9	2,217.4	0.6	2.6	1	1	1
11/30/2022 17:00	0.7	11.7	2,265.7	0.5	2.3	1	1	1
11/30/2022 18:00	0.7	11.7	2,264.2	0.4	2.3	1	1	1
11/30/2022 19:00	0.7	11.7	2,263.8	0.4	2.3	1	1	1
11/30/2022 20:00	0.7	11.8	2,258.6	0.4	2.3	1	1	1
11/30/2022 21:00	0.8	11.9	2,224.8	0.5	2.6	1	1	1
11/30/2022 22:00	0.9	12.5	2,086.6	0.5	3.0	1	1	1
11/30/2022 23:00	5.9	13.7	1,584.9	0.0	17.2	1	0	1
Average/Sum#:	1.2	12.5	2,108.1	0.6	89.6 #	24 #	23 #	24 #
Minimum:	0.7	11.7	1,584.9	0.4	2.3	1	0	1
Maximum:	5.9	13.7	2,265.7	1.0	17.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	20 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/05/2022 09:00	115.0	20.2	1.9	0.0	0.5	1	1	0
12/05/2022 10:00	62.0	16.6	470.2	0.0	89.5	1	1	0
12/05/2022 11:00	2.2	13.2	1,793.9	0.0	6.8	1	1	1
12/05/2022 12:00	0.9	12.2	2,140.7	0.0	2.9	1	1	1
12/05/2022 13:00	0.9	12.7	2,012.1	0.0	2.9	1	1	1
12/05/2022 14:00	0.9	12.7	2,032.3	0.6	2.9	1	1	1
12/05/2022 15:00	0.8	12.6	2,051.5	0.6	2.6	1	1	1
12/05/2022 16:00	0.8	12.0	2,193.6	0.6	2.6	1	1	1
12/05/2022 17:00	0.7	11.7	2,269.5	0.5	2.3	1	1	1
12/05/2022 18:00	0.7	11.7	2,271.5	0.4	2.3	1	1	1
12/05/2022 19:00	0.7	11.7	2,271.1	0.4	2.3	1	1	1
12/05/2022 20:00	0.8	11.8	2,272.1	0.4	2.6	1	1	1
12/05/2022 21:00	0.8	12.1	2,201.5	0.5	2.6	1	1	1
12/05/2022 22:00	1.0	12.7	2,067.0	0.6	3.3	1	1	1
12/05/2022 23:00	1.0	12.8	2,045.9	0.6	3.3	1	1	1
Average/Sum#:	12.6	13.1	1,873.0	0.5	129.4 #	15 #	24 #	13 #
Minimum:	0.7	11.7	1.9	0.4	0.5	0	1	0
Maximum:	115.0	20.2	2,272.1	0.6	89.5	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	1.2	13.2	1,967.2	0.8	4.0	1	1	1
12/06/2022 01:00	1.3	13.2	1,966.1	0.9	4.4	1	1	1
12/06/2022 02:00	1.3	13.2	1,965.7	1.0	4.4	1	1	1
12/06/2022 03:00	1.3	13.2	1,967.0	1.0	4.4	1	1	1
12/06/2022 04:00	1.2	13.1	1,982.2	1.0	4.0	1	1	1
12/06/2022 05:00	1.0	12.9	2,009.3	0.9	3.3	1	1	1
12/06/2022 06:00	1.2	13.1	1,982.0	0.8	4.0	1	1	1
12/06/2022 07:00	1.0	12.7	2,084.6	0.8	3.4	1	1	1
12/06/2022 08:00	0.9	11.9	2,259.2	0.7	3.0	1	1	1
12/06/2022 09:00	0.8	12.0	2,240.1	0.6	2.7	1	1	1
12/06/2022 10:00	0.8	12.0	2,234.8	0.5	2.7	1	1	1
12/06/2022 11:00	0.8	12.0	2,230.6	0.5	2.6	1	1	1
12/06/2022 12:00	0.8	12.0	2,217.9	0.5	2.6	1	1	1
12/06/2022 13:00	0.4	13.6	1,788.8	0.4	1.3	1	1	1
12/06/2022 14:00	0.4	13.9	1,318.8	0.4	1.0	1	1	0
12/06/2022 15:00	0.4	13.9	1,318.6	0.3	1.0	1	1	0
12/06/2022 16:00	0.4	13.8	1,520.8	0.3	1.1	1	1	0
12/06/2022 17:00	0.3	13.7	1,823.5	0.3	1.0	1	1	0
12/06/2022 18:00	0.3	13.7	1,825.1	0.2	1.0	1	1	0
12/06/2022 19:00	0.4	13.7	1,829.3	0.2	1.3	1	1	1
12/06/2022 20:00	1.0	12.5	2,123.4	0.4	3.3	1	1	1
12/06/2022 21:00	0.8	12.0	2,220.9	0.5	2.6	1	1	1
12/06/2022 22:00	0.9	12.5	2,096.6	0.6	3.0	1	1	1
12/06/2022 23:00	1.0	13.2	1,968.7	0.6	3.4	1	1	1
Average/Sum#:	0.8	13.0	1,955.9	0.6	65.5 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,318.6	0.2	1.0	1	1	0
Maximum:	1.3	13.9	2,259.2	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.9	12.7	2,080.4	0.7	3.0	1	1	1
12/07/2022 01:00	1.0	13.1	1,983.5	0.7	3.4	1	1	1
12/07/2022 02:00	0.9	12.5	2,133.1	0.7	3.0	1	1	1
12/07/2022 03:00	0.9	12.5	2,140.6	0.7	3.0	1	1	1
12/07/2022 04:00	0.9	12.4	2,147.2	0.6	3.0	1	1	1
12/07/2022 05:00	0.9	12.3	2,161.2	0.6	3.0	1	1	1
12/07/2022 06:00	0.9	12.1	2,240.0	0.6	3.0	1	1	1
12/07/2022 07:00	0.8	12.0	2,240.5	0.6	2.7	1	1	1
12/07/2022 08:00	0.9	12.6	2,123.6	0.6	3.0	1	1	1
12/07/2022 09:00	0.9	12.5	2,160.5	0.6	3.1	1	1	1
12/07/2022 10:00	0.9	12.4	2,154.7	0.6	3.0	1	1	1
12/07/2022 11:00	0.9	12.4	2,152.0	0.6	3.0	1	1	1
12/07/2022 12:00	0.9	12.5	2,125.4	0.6	3.0	1	1	1
12/07/2022 13:00	0.8	12.5	2,105.1	0.6	2.6	1	1	1
12/07/2022 14:00	0.9	12.7	2,045.2	0.6	3.0	1	1	1
12/07/2022 15:00	0.9	12.6	2,072.9	0.6	3.0	1	1	1
12/07/2022 16:00	0.8	11.9	2,242.3	0.6	2.6	1	1	1
12/07/2022 17:00	0.8	11.8	2,263.1	0.5	2.6	1	1	1
12/07/2022 18:00	0.8	11.9	2,262.6	0.5	2.7	1	1	1
12/07/2022 19:00	0.8	11.9	2,259.5	0.5	2.7	1	1	1
12/07/2022 20:00	0.8	11.9	2,260.4	0.5	2.7	1	1	1
12/07/2022 21:00	0.8	12.0	2,254.9	0.5	2.7	1	1	1
12/07/2022 22:00	0.9	12.4	2,171.8	0.5	3.0	1	1	1
12/07/2022 23:00	0.9	12.4	2,171.2	0.6	3.0	1	1	1
Average/Sum#:	0.9	12.3	2,164.7	0.6	69.8 #	24 #	24 #	24 #
Minimum:	0.8	11.8	1,983.5	0.5	2.6	1	1	1
Maximum:	1.0	13.1	2,263.1	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.9	12.6	2,128.3	0.6	3.0	1	1	1
12/08/2022 01:00	0.9	12.6	2,124.0	0.6	3.0	1	1	1
12/08/2022 02:00	0.9	12.6	2,125.4	0.6	3.0	1	1	1
12/08/2022 03:00	0.9	12.6	2,126.6	0.6	3.0	1	1	1
12/08/2022 04:00	0.9	12.5	2,151.8	0.6	3.0	1	1	1
12/08/2022 05:00	1.0	12.1	2,206.3	0.6	3.3	1	1	1
12/08/2022 06:00	0.9	12.0	2,276.7	0.6	3.0	1	1	1
12/08/2022 07:00	0.9	12.2	2,235.9	0.6	3.1	1	1	1
12/08/2022 08:00	1.1	13.0	2,033.3	0.7	3.7	1	1	1
12/08/2022 09:00	1.0	12.7	2,119.8	0.7	3.4	1	1	1
12/08/2022 10:00	0.9	12.6	2,125.2	0.7	3.0	1	1	1
12/08/2022 11:00	0.9	12.5	2,152.4	0.6	3.0	1	1	1
12/08/2022 12:00	0.9	12.4	2,146.3	0.6	3.0	1	1	1
12/08/2022 13:00	0.9	12.3	2,151.6	0.6	3.0	1	1	1
12/08/2022 14:00	0.9	12.3	2,154.1	0.6	3.0	1	1	1
12/08/2022 15:00	0.9	12.3	2,161.0	0.6	3.0	1	1	1
12/08/2022 16:00	0.8	11.8	2,252.5	0.6	2.6	1	1	1
12/08/2022 17:00	0.8	11.9	2,253.7	0.5	2.6	1	1	1
12/08/2022 18:00	0.8	11.8	2,260.9	0.5	2.6	1	1	1
12/08/2022 19:00	0.8	11.8	2,258.9	0.5	2.6	1	1	1
12/08/2022 20:00	0.8	11.8	2,260.5	0.5	2.6	1	1	1
12/08/2022 21:00	0.8	11.8	2,262.3	0.5	2.6	1	1	1
12/08/2022 22:00	0.9	12.2	2,175.3	0.5	3.0	1	1	1
12/08/2022 23:00	0.9	12.3	2,175.7	0.6	3.0	1	1	1
Average/Sum#:	0.9	12.3	2,179.9	0.6	71.1 #	24 #	24 #	24 #
Minimum:	0.8	11.8	2,033.3	0.5	2.6	1	1	1
Maximum:	1.1	13.0	2,276.7	0.7	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	0.9	12.4	2,133.4	0.6	3.0	1	1	1
12/09/2022 01:00	1.0	12.9	2,049.3	0.6	3.4	1	1	1
12/09/2022 02:00	0.9	12.5	2,145.6	0.6	3.0	1	1	1
12/09/2022 03:00	0.9	12.5	2,141.8	0.6	3.0	1	1	1
12/09/2022 04:00	0.9	12.3	2,188.2	0.6	3.0	1	1	1
12/09/2022 05:00	0.9	11.9	2,279.0	0.6	3.0	1	1	1
12/09/2022 06:00	0.9	11.9	2,284.6	0.6	3.0	1	1	1
12/09/2022 07:00	0.9	12.0	2,273.6	0.6	3.0	1	1	1
12/09/2022 08:00	1.1	12.8	2,069.7	0.7	3.7	1	1	1
12/09/2022 09:00	1.1	13.0	2,024.0	0.7	3.7	1	1	1
12/09/2022 10:00	1.3	13.2	1,975.9	0.9	4.4	1	1	1
12/09/2022 11:00	1.0	12.8	2,071.4	0.8	3.4	1	1	1
12/09/2022 12:00	1.1	13.0	2,003.4	0.8	3.7	1	1	1
12/09/2022 13:00	0.9	12.4	2,147.1	0.7	3.0	1	1	1
12/09/2022 14:00	0.9	12.4	2,137.6	0.7	3.0	1	1	1
12/09/2022 15:00	1.1	12.8	2,036.0	0.7	3.7	1	1	1
12/09/2022 16:00	0.8	11.9	2,251.5	0.6	2.6	1	1	1
12/09/2022 17:00	0.8	11.9	2,251.1	0.6	2.6	1	1	1
12/09/2022 18:00	0.8	11.9	2,251.7	0.5	2.6	1	1	1
12/09/2022 19:00	0.8	11.9	2,253.6	0.5	2.6	1	1	1
12/09/2022 20:00	0.8	11.9	2,258.2	0.5	2.7	1	1	1
12/09/2022 21:00	0.8	11.9	2,257.3	0.5	2.6	1	1	1
12/09/2022 22:00	0.8	11.9	2,255.6	0.5	2.6	1	1	1
12/09/2022 23:00	0.8	11.9	2,249.1	0.5	2.6	1	1	1
Average/Sum#:	0.9	12.3	2,166.2	0.6	73.9 #	24 #	24 #	24 #
Minimum:	0.8	11.9	1,975.9	0.5	2.6	1	1	1
Maximum:	1.3	13.2	2,284.6	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2022 00:00	1.1	12.9	2,006.4	0.6	3.6	1	1	1
12/10/2022 01:00	1.1	12.9	1,999.6	0.7	3.6	1	1	1
12/10/2022 02:00	1.2	13.1	1,963.4	0.8	4.0	1	1	1
12/10/2022 03:00	1.2	13.0	1,964.2	0.9	3.9	1	1	1
12/10/2022 04:00	1.2	13.0	1,959.0	0.9	3.9	1	1	1
12/10/2022 05:00	1.2	12.9	1,970.7	0.9	3.9	1	1	1
12/10/2022 06:00	1.3	13.0	1,958.3	0.9	4.3	1	1	1
12/10/2022 07:00	1.3	13.0	1,965.3	1.0	4.3	1	1	1
12/10/2022 08:00	1.1	12.8	2,005.5	0.9	3.6	1	1	1
12/10/2022 09:00	1.2	12.9	1,981.7	0.9	3.9	1	1	1
12/10/2022 10:00	1.3	13.0	1,958.2	0.9	4.3	1	1	1
12/10/2022 11:00	1.1	12.7	2,001.0	0.9	3.5	1	1	1
12/10/2022 12:00	0.9	12.3	2,097.7	0.8	2.9	1	1	1
12/10/2022 13:00	0.8	12.0	2,155.9	0.6	2.6	1	1	1
12/10/2022 14:00	0.9	12.6	2,002.4	0.6	2.9	1	1	1
12/10/2022 15:00	0.9	12.6	2,024.6	0.6	2.9	1	1	1
12/10/2022 16:00	0.9	12.3	2,094.2	0.6	2.9	1	1	1
12/10/2022 17:00	0.9	12.5	2,057.1	0.6	2.9	1	1	1
12/10/2022 18:00	1.0	12.5	2,058.1	0.6	3.2	1	1	1
12/10/2022 19:00	0.8	11.8	2,229.9	0.6	2.6	1	1	1
12/10/2022 20:00	0.8	12.1	2,153.8	0.6	2.6	1	1	1
12/10/2022 21:00	0.9	12.5	2,068.8	0.5	2.9	1	1	1
12/10/2022 22:00	1.0	12.8	2,009.3	0.6	3.3	1	1	1
12/10/2022 23:00	0.9	12.5	2,063.5	0.6	2.9	1	1	1
Average/Sum#:	1.0	12.7	2,031.2	0.7	81.4 #	24 #	24 #	24 #
Minimum:	0.8	11.8	1,958.2	0.5	2.6	1	1	1
Maximum:	1.3	13.1	2,229.9	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2022 00:00	1.1	13.0	1,956.5	0.7	3.6	1	1	1
12/11/2022 01:00	1.2	13.1	1,954.5	0.8	4.0	1	1	1
12/11/2022 02:00	1.2	13.1	1,954.5	0.9	4.0	1	1	1
12/11/2022 03:00	1.2	13.1	1,953.0	0.9	4.0	1	1	1
12/11/2022 04:00	1.3	13.1	1,955.4	0.9	4.3	1	1	1
12/11/2022 05:00	1.3	13.1	1,956.0	1.0	4.3	1	1	1
12/11/2022 06:00	1.3	13.1	1,958.5	1.0	4.3	1	1	1
12/11/2022 07:00	1.3	13.1	1,960.5	1.0	4.3	1	1	1
12/11/2022 08:00	1.3	13.1	1,961.5	1.0	4.3	1	1	1
12/11/2022 09:00	1.3	13.1	1,964.5	1.0	4.3	1	1	1
12/11/2022 10:00	1.3	13.1	1,963.7	1.0	4.3	1	1	1
12/11/2022 11:00	1.2	13.1	1,959.8	1.0	4.0	1	1	1
12/11/2022 12:00	1.2	13.1	1,958.4	0.9	4.0	1	1	1
12/11/2022 13:00	1.2	13.0	1,960.6	0.9	3.9	1	1	1
12/11/2022 14:00	1.2	13.0	1,958.2	0.9	3.9	1	1	1
12/11/2022 15:00	1.0	12.7	2,050.1	0.8	3.3	1	1	1
12/11/2022 16:00	1.0	12.7	2,053.8	0.8	3.3	1	1	1
12/11/2022 17:00	0.9	12.4	2,123.8	0.7	3.0	1	1	1
12/11/2022 18:00	1.1	12.9	2,040.4	0.7	3.7	1	1	1
12/11/2022 19:00	1.0	12.8	2,068.4	0.7	3.4	1	1	1
12/11/2022 20:00	1.0	12.6	2,119.1	0.7	3.4	1	1	1
12/11/2022 21:00	1.2	13.1	2,002.7	0.8	4.1	1	1	1
12/11/2022 22:00	1.3	13.2	1,968.1	0.9	4.4	1	1	1
12/11/2022 23:00	1.3	13.2	1,965.9	1.0	4.4	1	1	1
Average/Sum#:	1.2	13.0	1,990.3	0.9	94.5 #	24 #	24 #	24 #
Minimum:	0.9	12.4	1,953.0	0.7	3.0	1	1	1
Maximum:	1.3	13.2	2,123.8	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2022 00:00	1.3	13.2	1,974.6	1.0	4.4	1	1	1
12/12/2022 01:00	1.3	13.2	1,974.7	1.0	4.4	1	1	1
12/12/2022 02:00	1.3	13.2	1,974.6	1.0	4.4	1	1	1
12/12/2022 03:00	1.3	13.2	1,972.4	1.0	4.4	1	1	1
12/12/2022 04:00	1.3	13.2	1,975.3	1.0	4.4	1	1	1
12/12/2022 05:00	1.0	12.4	2,111.2	0.9	3.3	1	1	1
12/12/2022 06:00	0.9	12.3	2,205.4	0.8	3.0	1	1	1
12/12/2022 07:00	0.9	12.3	2,187.8	0.6	3.0	1	1	1
12/12/2022 08:00	1.1	12.8	2,074.1	0.7	3.7	1	1	1
12/12/2022 09:00	1.0	12.8	2,066.2	0.7	3.4	1	1	1
12/12/2022 10:00	1.3	13.2	1,973.4	0.8	4.4	1	1	1
12/12/2022 11:00	1.3	13.2	1,968.1	0.9	4.4	1	1	1
12/12/2022 12:00	1.3	13.2	1,964.0	1.0	4.4	1	1	1
12/12/2022 13:00	1.2	13.1	1,961.0	1.0	4.0	1	1	1
12/12/2022 14:00	1.2	13.1	1,953.7	0.9	4.0	1	1	1
12/12/2022 15:00	1.2	13.1	1,956.5	0.9	4.0	1	1	1
12/12/2022 16:00	0.9	12.4	2,131.9	0.8	3.0	1	1	1
12/12/2022 17:00	0.8	12.0	2,216.3	0.7	2.6	1	1	1
12/12/2022 18:00	0.7	11.8	2,275.3	0.5	2.3	1	1	1
12/12/2022 19:00	0.7	11.8	2,277.0	0.5	2.3	1	1	1
12/12/2022 20:00	0.7	11.8	2,281.0	0.5	2.3	1	1	1
12/12/2022 21:00	0.8	12.0	2,246.6	0.5	2.7	1	1	1
12/12/2022 22:00	0.8	12.3	2,188.8	0.5	2.7	1	1	1
12/12/2022 23:00	1.0	13.0	2,025.1	0.6	3.4	1	1	1
Average/Sum#:	1.1	12.7	2,080.6	0.8	84.9 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,953.7	0.5	2.3	1	1	1
Maximum:	1.3	13.2	2,281.0	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.9	12.6	2,151.0	0.6	3.1	1	1	1
12/13/2022 01:00	0.9	12.5	2,157.4	0.6	3.1	1	1	1
12/13/2022 02:00	0.9	12.4	2,161.4	0.6	3.0	1	1	1
12/13/2022 03:00	0.9	12.5	2,146.4	0.6	3.0	1	1	1
12/13/2022 04:00	0.9	12.4	2,189.1	0.6	3.1	1	1	1
12/13/2022 05:00	0.9	12.0	2,273.8	0.6	3.0	1	1	1
12/13/2022 06:00	0.8	11.9	2,310.2	0.6	2.7	1	1	1
12/13/2022 07:00	0.8	11.9	2,287.8	0.5	2.7	1	1	1
12/13/2022 08:00	0.9	12.5	2,134.0	0.5	3.0	1	1	1
12/13/2022 09:00	1.1	13.0	2,010.3	0.6	3.7	1	1	1
12/13/2022 10:00	1.2	13.2	1,963.5	0.8	4.0	1	1	1
12/13/2022 11:00	1.2	13.2	1,966.2	0.9	4.0	1	1	1
12/13/2022 12:00	1.2	13.1	1,963.9	0.9	4.0	1	1	1
12/13/2022 13:00	1.2	13.1	1,958.8	0.9	4.0	1	1	1
12/13/2022 14:00	1.2	13.1	1,948.4	0.9	4.0	1	1	1
12/13/2022 15:00	1.0	12.7	2,055.9	0.8	3.3	1	1	1
12/13/2022 16:00	0.7	11.9	2,251.4	0.7	2.3	1	1	1
12/13/2022 17:00	0.7	11.8	2,271.2	0.6	2.3	1	1	1
12/13/2022 18:00	0.7	11.8	2,273.1	0.5	2.3	1	1	1
12/13/2022 19:00	0.7	11.9	2,270.7	0.5	2.3	1	1	1
12/13/2022 20:00	0.8	11.9	2,269.3	0.5	2.7	1	1	1
12/13/2022 21:00	0.8	12.0	2,274.0	0.5	2.7	1	1	1
12/13/2022 22:00	0.8	12.0	2,272.2	0.5	2.7	1	1	1
12/13/2022 23:00	0.8	11.9	2,268.0	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.4	2,159.5	0.6	73.7 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,948.4	0.5	2.3	1	1	1
Maximum:	1.2	13.2	2,310.2	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.8	12.3	2,186.8	0.5	2.7	1	1	1
12/14/2022 01:00	0.9	12.4	2,187.5	0.5	3.1	1	1	1
12/14/2022 02:00	0.9	12.4	2,188.4	0.6	3.1	1	1	1
12/14/2022 03:00	0.9	12.4	2,189.7	0.6	3.1	1	1	1
12/14/2022 04:00	0.9	12.4	2,186.4	0.6	3.1	1	1	1
12/14/2022 05:00	0.9	12.0	2,291.8	0.6	3.1	1	1	1
12/14/2022 06:00	0.8	12.0	2,297.1	0.6	2.7	1	1	1
12/14/2022 07:00	0.8	12.1	2,255.1	0.5	2.7	1	1	1
12/14/2022 08:00	1.0	12.9	2,069.6	0.6	3.4	1	1	1
12/14/2022 09:00	1.1	13.1	2,007.9	0.7	3.7	1	1	1
12/14/2022 10:00	1.0	13.0	2,023.9	0.7	3.4	1	1	1
12/14/2022 11:00	1.1	13.2	1,967.4	0.8	3.7	1	1	1
12/14/2022 12:00	1.2	13.2	1,967.7	0.8	4.0	1	1	1
12/14/2022 13:00	1.1	13.2	1,966.4	0.8	3.7	1	1	1
12/14/2022 14:00	1.1	13.2	1,961.9	0.8	3.7	1	1	1
12/14/2022 15:00	1.1	13.0	2,003.9	0.8	3.7	1	1	1
12/14/2022 16:00	0.8	12.2	2,196.7	0.7	2.7	1	1	1
12/14/2022 17:00	0.8	11.9	2,270.2	0.6	2.7	1	1	1
12/14/2022 18:00	0.8	11.9	2,263.7	0.5	2.7	1	1	1
12/14/2022 19:00	0.8	11.9	2,270.0	0.5	2.7	1	1	1
12/14/2022 20:00	0.8	11.9	2,269.8	0.5	2.7	1	1	1
12/14/2022 21:00	0.8	12.0	2,270.9	0.5	2.7	1	1	1
12/14/2022 22:00	0.8	12.1	2,250.1	0.5	2.7	1	1	1
12/14/2022 23:00	0.8	12.4	2,172.6	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,154.8	0.6	74.5 #	24 #	24 #	24 #
Minimum:	0.8	11.9	1,961.9	0.5	2.7	1	1	1
Maximum:	1.2	13.2	2,297.1	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0.8	11.9	2,285.2	0.5	2.7	1	1	1
12/15/2022 01:00	0.8	11.9	2,294.2	0.5	2.7	1	1	1
12/15/2022 02:00	0.7	11.9	2,295.1	0.5	2.4	1	1	1
12/15/2022 03:00	0.8	11.9	2,296.8	0.5	2.7	1	1	1
12/15/2022 04:00	0.7	11.9	2,302.4	0.5	2.4	1	1	1
12/15/2022 05:00	0.7	11.8	2,305.6	0.5	2.3	1	1	1
12/15/2022 06:00	0.7	11.8	2,303.9	0.5	2.3	1	1	1
12/15/2022 07:00	0.7	11.9	2,297.7	0.5	2.4	1	1	1
12/15/2022 08:00	0.7	12.2	2,216.9	0.5	2.4	1	1	1
12/15/2022 09:00	0.8	12.1	2,210.5	0.5	2.7	1	1	1
12/15/2022 10:00	1.0	13.1	1,975.6	0.6	3.3	1	1	1
12/15/2022 11:00	1.0	13.0	1,984.0	0.7	3.3	1	1	1
12/15/2022 12:00	0.9	12.8	2,010.5	0.7	3.0	1	1	1
12/15/2022 13:00	0.9	12.8	2,027.3	0.7	3.0	1	1	1
12/15/2022 14:00	0.7	12.5	2,076.8	0.6	2.3	1	1	1
12/15/2022 15:00	0.7	11.9	2,224.3	0.6	2.3	1	1	1
12/15/2022 16:00	0.6	11.9	2,242.6	0.5	2.0	1	1	1
12/15/2022 17:00	0.7	11.9	2,240.4	0.5	2.3	1	1	1
12/15/2022 18:00	0.7	12.0	2,233.1	0.5	2.3	1	1	1
12/15/2022 19:00	0.8	12.0	2,230.3	0.5	2.6	1	1	1
12/15/2022 20:00	0.7	12.0	2,232.7	0.5	2.3	1	1	1
12/15/2022 21:00	0.8	12.1	2,238.4	0.5	2.7	1	1	1
12/15/2022 22:00	0.8	12.1	2,242.7	0.5	2.7	1	1	1
12/15/2022 23:00	0.8	12.2	2,230.3	0.5	2.7	1	1	1
Average/Sum#:	0.8	12.2	2,208.2	0.5	61.8 #	24 #	24 #	24 #
Minimum:	0.6	11.8	1,975.6	0.5	2.0	1	1	1
Maximum:	1.0	13.1	2,305.6	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	1.1	13.1	1,993.7	0.6	3.7	1	1	1
12/16/2022 01:00	1.2	13.2	1,967.6	0.7	4.0	1	1	1
12/16/2022 02:00	1.2	13.2	1,966.9	0.9	4.0	1	1	1
12/16/2022 03:00	1.2	13.2	1,969.7	0.9	4.1	1	1	1
12/16/2022 04:00	1.2	13.2	1,968.6	0.9	4.1	1	1	1
12/16/2022 05:00	1.2	13.2	1,982.9	0.9	4.1	1	1	1
12/16/2022 06:00	1.0	12.7	2,114.1	0.8	3.4	1	1	1
12/16/2022 07:00	0.8	12.3	2,208.1	0.7	2.7	1	1	1
12/16/2022 08:00	0.8	12.6	2,142.7	0.6	2.7	1	1	1
12/16/2022 09:00	0.9	12.7	2,066.1	0.6	3.0	1	1	1
12/16/2022 10:00	0.3	13.8	1,542.9	0.5	0.9	1	1	0
12/16/2022 11:00	0.4	13.9	1,461.4	0.4	1.1	1	1	0
12/16/2022 12:00	0.5	13.9	1,324.4	0.3	1.2	1	1	0
12/16/2022 13:00	0.4	13.9	1,326.3	0.3	1.0	1	1	0
12/16/2022 14:00	0.3	13.8	1,587.9	0.3	0.9	1	1	0
12/16/2022 15:00	0.4	13.8	1,555.8	0.3	1.2	1	1	1
12/16/2022 16:00	0.9	12.4	2,147.0	0.4	3.0	1	1	1
12/16/2022 17:00	0.8	12.0	2,222.2	0.5	2.6	1	1	1
12/16/2022 18:00	0.8	12.4	2,150.0	0.6	2.7	1	1	1
12/16/2022 19:00	0.8	12.4	2,159.8	0.6	2.7	1	1	1
12/16/2022 20:00	0.7	11.9	2,243.7	0.6	2.3	1	1	1
12/16/2022 21:00	0.8	12.2	2,187.6	0.5	2.7	1	1	1
12/16/2022 22:00	0.9	12.7	2,087.4	0.5	3.0	1	1	1
12/16/2022 23:00	1.1	13.2	1,976.6	0.6	3.7	1	1	1
Average/Sum#:	0.8	13.0	1,931.4	0.6	64.8 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,324.4	0.3	0.9	1	1	0
Maximum:	1.2	13.9	2,243.7	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.9	12.5	2,146.2	0.7	3.0	1	1	1
12/17/2022 01:00	0.9	12.5	2,148.8	0.7	3.0	1	1	1
12/17/2022 02:00	0.9	12.5	2,140.6	0.6	3.0	1	1	1
12/17/2022 03:00	0.9	12.5	2,153.2	0.6	3.0	1	1	1
12/17/2022 04:00	0.9	12.5	2,153.6	0.6	3.0	1	1	1
12/17/2022 05:00	0.9	12.5	2,151.4	0.6	3.0	1	1	1
12/17/2022 06:00	0.8	12.2	2,233.8	0.6	2.7	1	1	1
12/17/2022 07:00	0.9	12.7	2,099.2	0.6	3.0	1	1	1
12/17/2022 08:00	0.9	12.5	2,159.2	0.6	3.1	1	1	1
12/17/2022 09:00	0.9	12.6	2,117.2	0.6	3.0	1	1	1
12/17/2022 10:00	1.0	13.1	1,997.6	0.7	3.4	1	1	1
12/17/2022 11:00	1.1	13.2	1,964.4	0.7	3.7	1	1	1
12/17/2022 12:00	1.1	13.2	1,960.9	0.8	3.7	1	1	1
12/17/2022 13:00	1.0	13.1	1,956.6	0.8	3.3	1	1	1
12/17/2022 14:00	1.0	13.0	1,970.0	0.8	3.3	1	1	1
12/17/2022 15:00	0.8	12.5	2,100.3	0.7	2.6	1	1	1
12/17/2022 16:00	0.7	11.9	2,248.1	0.6	2.3	1	1	1
12/17/2022 17:00	0.8	12.0	2,217.8	0.5	2.6	1	1	1
12/17/2022 18:00	0.8	12.4	2,137.6	0.5	2.7	1	1	1
12/17/2022 19:00	0.8	11.8	2,260.0	0.5	2.6	1	1	1
12/17/2022 20:00	0.7	11.8	2,263.2	0.5	2.3	1	1	1
12/17/2022 21:00	0.7	11.8	2,264.7	0.5	2.3	1	1	1
12/17/2022 22:00	0.7	11.9	2,261.6	0.5	2.3	1	1	1
12/17/2022 23:00	0.8	12.3	2,180.2	0.5	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,136.9	0.6	69.6 #	24 #	24 #	24 #
Minimum:	0.7	11.8	1,956.6	0.5	2.3	1	1	1
Maximum:	1.1	13.2	2,264.7	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.8	12.5	2,132.5	0.5	2.7	1	1	1
12/18/2022 01:00	0.9	12.6	2,135.5	0.6	3.1	1	1	1
12/18/2022 02:00	1.1	13.0	2,021.6	0.7	3.7	1	1	1
12/18/2022 03:00	1.2	13.2	1,975.9	0.8	4.1	1	1	1
12/18/2022 04:00	0.9	12.6	2,135.5	0.8	3.1	1	1	1
12/18/2022 05:00	0.9	12.5	2,156.2	0.7	3.1	1	1	1
12/18/2022 06:00	0.9	12.4	2,171.1	0.6	3.0	1	1	1
12/18/2022 07:00	0.9	12.3	2,208.2	0.6	3.1	1	1	1
12/18/2022 08:00	0.9	12.6	2,085.2	0.6	3.0	1	1	1
12/18/2022 09:00	0.4	13.8	1,618.7	0.5	1.2	1	1	0
12/18/2022 10:00	0.4	13.8	1,561.3	0.4	1.2	1	1	0
12/18/2022 11:00	0.4	13.8	1,559.0	0.3	1.2	1	1	0
12/18/2022 12:00	0.5	13.8	1,408.9	0.3	1.3	1	1	0
12/18/2022 13:00	0.5	13.8	1,399.2	0.4	1.3	1	1	0
12/18/2022 14:00	0.4	13.8	1,643.4	0.4	1.2	1	1	0
12/18/2022 15:00	0.4	13.8	1,651.7	0.3	1.2	1	1	1
12/18/2022 16:00	1.0	12.4	2,130.5	0.4	3.3	1	1	1
12/18/2022 17:00	0.8	12.0	2,242.0	0.5	2.7	1	1	1
12/18/2022 18:00	0.8	11.9	2,269.4	0.6	2.7	1	1	1
12/18/2022 19:00	0.8	11.9	2,270.4	0.5	2.7	1	1	1
12/18/2022 20:00	0.9	12.1	2,236.3	0.5	3.0	1	1	1
12/18/2022 21:00	0.9	12.3	2,210.2	0.6	3.1	1	1	1
12/18/2022 22:00	0.9	12.4	2,198.1	0.6	3.1	1	1	1
12/18/2022 23:00	1.1	12.9	2,049.0	0.7	3.7	1	1	1
Average/Sum#:	0.8	12.8	1,977.9	0.5	61.8 #	24 #	24 #	18 #
Minimum:	0.4	11.9	1,399.2	0.3	1.2	1	1	0
Maximum:	1.2	13.8	2,270.4	0.8	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	1.0	12.6	2,143.3	0.7	3.4	1	1	1
12/19/2022 01:00	0.9	12.5	2,153.6	0.7	3.0	1	1	1
12/19/2022 02:00	0.9	12.6	2,150.3	0.6	3.1	1	1	1
12/19/2022 03:00	0.9	12.6	2,151.5	0.6	3.1	1	1	1
12/19/2022 04:00	1.0	12.5	2,181.6	0.6	3.4	1	1	1
12/19/2022 05:00	0.9	12.0	2,296.4	0.6	3.1	1	1	1
12/19/2022 06:00	0.9	12.0	2,296.2	0.6	3.1	1	1	1
12/19/2022 07:00	0.9	12.0	2,295.5	0.6	3.1	1	1	1
12/19/2022 08:00	0.9	12.1	2,248.0	0.6	3.0	1	1	1
12/19/2022 09:00	0.9	12.1	2,257.3	0.6	3.0	1	1	1
12/19/2022 10:00	0.9	12.5	2,169.7	0.6	3.1	1	1	1
12/19/2022 11:00	0.9	12.5	2,172.8	0.6	3.1	1	1	1
12/19/2022 12:00	0.9	12.5	2,163.1	0.6	3.1	1	1	1
12/19/2022 13:00	0.9	12.5	2,154.7	0.6	3.0	1	1	1
12/19/2022 14:00	0.9	12.5	2,157.0	0.6	3.1	1	1	1
12/19/2022 15:00	0.9	12.3	2,218.7	0.6	3.1	1	1	1
12/19/2022 16:00	0.9	12.1	2,259.5	0.6	3.1	1	1	1
12/19/2022 17:00	0.9	12.1	2,264.7	0.6	3.1	1	1	1
12/19/2022 18:00	0.9	12.1	2,265.6	0.6	3.1	1	1	1
12/19/2022 19:00	0.9	12.1	2,264.2	0.6	3.1	1	1	1
12/19/2022 20:00	0.9	12.1	2,259.5	0.6	3.1	1	1	1
12/19/2022 21:00	0.9	12.1	2,259.7	0.6	3.1	1	1	1
12/19/2022 22:00	0.9	12.1	2,264.3	0.6	3.1	1	1	1
12/19/2022 23:00	0.9	12.1	2,263.6	0.6	3.1	1	1	1
Average/Sum#:	0.9	12.3	2,221.3	0.6	74.6 #	24 #	24 #	24 #
Minimum:	0.9	12.0	2,143.3	0.6	3.0	1	1	1
Maximum:	1.0	12.6	2,296.4	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.9	12.5	2,172.5	0.6	3.1	1	1	1
12/20/2022 01:00	0.9	12.5	2,169.3	0.6	3.1	1	1	1
12/20/2022 02:00	0.9	12.5	2,173.2	0.6	3.1	1	1	1
12/20/2022 03:00	0.9	12.5	2,179.2	0.6	3.1	1	1	1
12/20/2022 04:00	0.9	12.5	2,184.8	0.6	3.1	1	1	1
12/20/2022 05:00	0.9	12.5	2,186.9	0.6	3.1	1	1	1
12/20/2022 06:00	0.9	12.1	2,279.9	0.6	3.1	1	1	1
12/20/2022 07:00	0.9	12.1	2,273.5	0.6	3.1	1	1	1
12/20/2022 08:00	0.9	12.5	2,163.7	0.6	3.1	1	1	1
12/20/2022 09:00	0.9	12.5	2,161.4	0.6	3.1	1	1	1
12/20/2022 10:00	0.9	12.6	2,120.5	0.6	3.0	1	1	1
12/20/2022 11:00	0.9	12.7	2,088.3	0.6	3.0	1	1	1
12/20/2022 12:00	1.2	13.2	1,961.1	0.7	4.0	1	1	1
12/20/2022 13:00	1.2	13.2	1,963.4	0.8	4.0	1	1	1
12/20/2022 14:00	1.2	13.2	1,958.0	0.9	4.0	1	1	1
12/20/2022 15:00	1.1	12.9	2,030.5	0.9	3.7	1	1	1
12/20/2022 16:00	0.8	12.3	2,184.0	0.7	2.7	1	1	1
12/20/2022 17:00	0.8	12.0	2,248.1	0.6	2.7	1	1	1
12/20/2022 18:00	0.8	12.0	2,246.6	0.5	2.7	1	1	1
12/20/2022 19:00	0.8	12.0	2,239.7	0.5	2.7	1	1	1
12/20/2022 20:00	0.8	12.0	2,241.8	0.5	2.7	1	1	1
12/20/2022 21:00	0.8	12.4	2,154.7	0.5	2.7	1	1	1
12/20/2022 22:00	0.8	12.4	2,156.3	0.6	2.7	1	1	1
12/20/2022 23:00	0.8	12.2	2,209.3	0.6	2.7	1	1	1
Average/Sum#:	0.9	12.5	2,156.1	0.6	74.3 #	24 #	24 #	24 #
Minimum:	0.8	12.0	1,958.0	0.5	2.7	1	1	1
Maximum:	1.2	13.2	2,279.9	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2022 00:00	0.8	11.9	2,265.8	0.5	2.7	1	1	1
12/21/2022 01:00	0.8	11.9	2,263.2	0.5	2.7	1	1	1
12/21/2022 02:00	0.8	12.0	2,261.3	0.5	2.7	1	1	1
12/21/2022 03:00	0.8	12.0	2,267.1	0.5	2.7	1	1	1
12/21/2022 04:00	0.8	12.0	2,267.5	0.5	2.7	1	1	1
12/21/2022 05:00	0.8	12.0	2,262.9	0.5	2.7	1	1	1
12/21/2022 06:00	0.8	12.0	2,262.6	0.5	2.7	1	1	1
12/21/2022 07:00	0.8	12.0	2,260.4	0.5	2.7	1	1	1
12/21/2022 08:00	0.8	12.1	2,249.7	0.5	2.7	1	1	1
12/21/2022 09:00	0.9	12.1	2,235.5	0.5	3.0	1	1	1
12/21/2022 10:00	0.8	12.1	2,227.8	0.5	2.7	1	1	1
12/21/2022 11:00	0.8	12.2	2,195.0	0.5	2.7	1	1	1
12/21/2022 12:00	0.8	12.1	2,213.1	0.5	2.7	1	1	1
12/21/2022 13:00	0.8	12.1	2,208.4	0.5	2.7	1	1	1
12/21/2022 14:00	0.8	12.4	2,133.5	0.5	2.7	1	1	1
12/21/2022 15:00	0.8	12.1	2,205.0	0.5	2.6	1	1	1
12/21/2022 16:00	0.8	12.0	2,227.3	0.5	2.6	1	1	1
12/21/2022 17:00	0.8	12.0	2,234.1	0.5	2.7	1	1	1
12/21/2022 18:00	0.8	12.0	2,239.9	0.5	2.7	1	1	1
12/21/2022 19:00	0.8	12.0	2,241.3	0.5	2.7	1	1	1
12/21/2022 20:00	0.8	12.0	2,238.6	0.5	2.7	1	1	1
12/21/2022 21:00	0.8	12.0	2,238.6	0.5	2.7	1	1	1
12/21/2022 22:00	0.8	12.1	2,239.1	0.5	2.7	1	1	1
12/21/2022 23:00	0.9	12.1	2,239.7	0.5	3.0	1	1	1
Average/Sum#:	0.8	12.1	2,236.6	0.5	65.2 #	24 #	24 #	24 #
Minimum:	0.8	11.9	2,133.5	0.5	2.6	1	1	1
Maximum:	0.9	12.4	2,267.5	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	0.9	12.3	2,179.5	0.6	3.0	1	1	1
12/22/2022 01:00	1.2	13.1	1,980.0	0.7	4.0	1	1	1
12/22/2022 02:00	1.4	13.2	1,961.4	0.9	4.7	1	1	1
12/22/2022 03:00	1.4	13.2	1,964.7	1.0	4.7	1	1	1
12/22/2022 04:00	1.2	12.8	2,094.8	1.0	4.1	1	1	1
12/22/2022 05:00	1.0	12.1	2,222.3	0.9	3.3	1	1	1
12/22/2022 06:00	0.9	12.1	2,261.4	0.7	3.1	1	1	1
12/22/2022 07:00	0.9	12.1	2,259.7	0.6	3.1	1	1	1
12/22/2022 08:00	0.9	12.1	2,238.6	0.6	3.0	1	1	1
12/22/2022 09:00	0.9	12.5	2,150.2	0.6	3.0	1	1	1
12/22/2022 10:00	0.9	12.6	2,145.1	0.6	3.1	1	1	1
12/22/2022 11:00	0.9	12.5	2,140.3	0.6	3.0	1	1	1
12/22/2022 12:00	0.9	12.5	2,137.6	0.6	3.0	1	1	1
12/22/2022 13:00	0.9	12.5	2,137.2	0.6	3.0	1	1	1
12/22/2022 14:00	0.9	12.5	2,144.7	0.6	3.0	1	1	1
12/22/2022 15:00	0.9	12.2	2,203.3	0.6	3.0	1	1	1
12/22/2022 16:00	0.9	12.2	2,198.4	0.6	3.0	1	1	1
12/22/2022 17:00	0.9	12.0	2,238.8	0.6	3.0	1	1	1
12/22/2022 18:00	0.9	12.0	2,242.2	0.6	3.0	1	1	1
12/22/2022 19:00	0.9	12.0	2,246.6	0.6	3.0	1	1	1
12/22/2022 20:00	0.9	12.0	2,243.5	0.6	3.0	1	1	1
12/22/2022 21:00	0.9	12.0	2,241.4	0.6	3.0	1	1	1
12/22/2022 22:00	0.9	12.2	2,200.2	0.6	3.0	1	1	1
12/22/2022 23:00	1.0	12.8	2,068.8	0.6	3.4	1	1	1
Average/Sum#:	1.0	12.4	2,162.5	0.7	78.5 #	24 #	24 #	24 #
Minimum:	0.9	12.0	1,961.4	0.6	3.0	1	1	1
Maximum:	1.4	13.2	2,261.4	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.9	12.2	2,215.5	0.6	3.0	1	1	1
12/23/2022 01:00	0.9	12.0	2,252.2	0.6	3.0	1	1	1
12/23/2022 02:00	0.9	12.0	2,250.3	0.6	3.0	1	1	1
12/23/2022 03:00	0.9	12.0	2,245.6	0.6	3.0	1	1	1
12/23/2022 04:00	0.9	12.0	2,248.2	0.6	3.0	1	1	1
12/23/2022 05:00	0.9	12.0	2,241.2	0.6	3.0	1	1	1
12/23/2022 06:00	0.9	12.0	2,250.7	0.6	3.0	1	1	1
12/23/2022 07:00	0.9	12.1	2,232.9	0.6	3.0	1	1	1
12/23/2022 08:00	0.9	12.3	2,172.6	0.6	3.0	1	1	1
12/23/2022 09:00	0.9	12.3	2,163.4	0.6	3.0	1	1	1
12/23/2022 10:00	0.9	12.5	2,122.9	0.6	3.0	1	1	1
12/23/2022 11:00	0.8	12.4	2,124.2	0.6	2.6	1	1	1
12/23/2022 12:00	1.0	12.8	2,017.4	0.6	3.3	1	1	1
12/23/2022 13:00	1.1	13.1	1,950.0	0.7	3.6	1	1	1
12/23/2022 14:00	1.2	13.1	1,941.4	0.8	3.9	1	1	1
12/23/2022 15:00	1.0	12.7	2,049.7	0.8	3.3	1	1	1
12/23/2022 16:00	0.8	11.9	2,228.2	0.7	2.6	1	1	1
12/23/2022 17:00	0.8	11.9	2,230.8	0.6	2.6	1	1	1
12/23/2022 18:00	0.8	11.9	2,231.0	0.5	2.6	1	1	1
12/23/2022 19:00	0.7	12.0	2,229.3	0.5	2.3	1	1	1
12/23/2022 20:00	0.7	12.0	2,230.7	0.5	2.3	1	1	1
12/23/2022 21:00	0.7	11.9	2,234.3	0.5	2.3	1	1	1
12/23/2022 22:00	0.8	11.9	2,233.5	0.5	2.6	1	1	1
12/23/2022 23:00	0.8	12.0	2,225.6	0.5	2.6	1	1	1
Average/Sum#:	0.9	12.2	2,180.1	0.6	69.6 #	24 #	24 #	24 #
Minimum:	0.7	11.9	1,941.4	0.5	2.3	1	1	1
Maximum:	1.2	13.1	2,252.2	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.8	12.4	2,119.0	0.5	2.6	1	1	1
12/24/2022 01:00	0.8	12.5	2,113.9	0.6	2.7	1	1	1
12/24/2022 02:00	1.1	13.1	1,961.4	0.7	3.7	1	1	1
12/24/2022 03:00	1.2	13.2	1,955.3	0.8	4.0	1	1	1
12/24/2022 04:00	1.2	13.2	1,953.0	0.9	4.0	1	1	1
12/24/2022 05:00	1.2	13.2	1,951.1	0.9	4.0	1	1	1
12/24/2022 06:00	1.2	13.1	1,974.8	0.9	4.0	1	1	1
12/24/2022 07:00	1.1	13.0	1,998.9	0.9	3.7	1	1	1
12/24/2022 08:00	1.0	13.3	1,833.9	0.8	3.2	1	1	1
12/24/2022 09:00	0.6	13.8	1,320.7	0.7	1.5	1	1	0
12/24/2022 10:00	0.4	13.8	1,559.7	0.5	1.2	1	1	0
12/24/2022 11:00	0.4	13.8	1,555.6	0.4	1.2	1	1	0
12/24/2022 12:00	0.4	13.8	1,554.9	0.3	1.2	1	1	0
12/24/2022 13:00	0.3	13.8	1,558.8	0.3	0.9	1	1	0
12/24/2022 14:00	0.3	13.8	1,730.9	0.2	1.0	1	1	0
12/24/2022 15:00	0.3	13.8	1,739.5	0.2	1.0	1	1	0
12/24/2022 16:00	0.4	13.8	1,594.1	0.2	1.2	1	1	1
12/24/2022 17:00	1.2	13.1	1,944.9	0.5	4.0	1	1	1
12/24/2022 18:00	1.1	13.1	1,943.7	0.7	3.6	1	1	1
12/24/2022 19:00	1.1	13.1	1,944.1	0.8	3.6	1	1	1
12/24/2022 20:00	1.1	13.1	1,947.7	0.8	3.6	1	1	1
12/24/2022 21:00	1.1	13.1	1,944.2	0.8	3.6	1	1	1
12/24/2022 22:00	1.2	13.2	1,946.9	0.8	4.0	1	1	1
12/24/2022 23:00	1.2	13.2	1,949.6	0.9	4.0	1	1	1
Average/Sum#:	0.9	13.3	1,837.4	0.6	67.5 #	24 #	24 #	17 #
Minimum:	0.3	12.4	1,320.7	0.2	0.9	1	1	0
Maximum:	1.2	13.8	2,119.0	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2022 00:00	1.2	13.2	1,930.0	0.9	4.0	1	1	1
12/25/2022 01:00	22.2	15.6	591.4	0.0	7.2	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	11.7	14.4	1,260.7	0.9	11.2 #	2 #	4 #	1 #
Minimum:	1.2	13.2	591.4	0.9	4.0	0	0	0
Maximum:	22.2	15.6	1,930.0	0.9	7.2	1	1	1
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	60.1	17.6	332.1	0.0	50.3	1	1	0
12/26/2022 01:00	38.4	15.1	969.8	0.0	84.8	1	1	0
12/26/2022 02:00	0.5	13.7	1,715.8	0.0	1.6	1	1	0
12/26/2022 03:00	0.5	13.7	1,736.0	0.0	1.6	1	1	0
12/26/2022 04:00	0.5	13.7	1,735.7	0.4	1.6	1	1	0
12/26/2022 05:00	0.5	13.7	1,750.8	0.4	1.6	1	1	0
12/26/2022 06:00	0.5	13.7	1,750.6	0.4	1.6	1	1	0
12/26/2022 07:00	0.5	13.7	1,742.3	0.4	1.6	1	1	0
12/26/2022 08:00	0.5	13.7	1,748.4	0.4	1.6	1	1	0
12/26/2022 09:00	0.5	13.8	1,563.8	0.4	1.5	1	1	0
12/26/2022 10:00	0.5	13.8	1,559.4	0.4	1.5	1	1	0
12/26/2022 11:00	0.5	13.8	1,550.2	0.4	1.4	1	1	0
12/26/2022 12:00	0.6	13.8	1,541.0	0.4	1.7	1	1	0
12/26/2022 13:00	0.5	13.8	1,561.8	0.4	1.5	1	1	0
12/26/2022 14:00	0.5	13.7	1,623.4	0.4	1.5	1	1	0
12/26/2022 15:00	0.5	13.7	1,751.1	0.4	1.6	1	1	0
12/26/2022 16:00	0.5	13.7	1,782.9	0.4	1.6	1	1	1
12/26/2022 17:00	1.3	12.5	2,103.9	0.6	4.3	1	1	1
12/26/2022 18:00	1.0	12.3	2,145.3	0.7	3.3	1	1	1
12/26/2022 19:00	1.2	12.9	2,004.1	0.8	4.0	1	1	1
12/26/2022 20:00	1.2	13.0	1,990.7	0.8	4.0	1	1	1
12/26/2022 21:00	1.4	13.1	1,960.1	1.0	4.6	1	1	1
12/26/2022 22:00	1.4	13.1	1,936.0	1.0	4.6	1	1	1
12/26/2022 23:00	21.0	15.6	602.1	0.0	7.2	1	0	0
Average/Sum#:	5.6	13.8	1,631.6	0.5	190.6 #	24 #	23 #	7 #
Minimum:	0.5	12.3	332.1	0.4	1.4	1	0	0
Maximum:	60.1	17.6	2,145.3	1.0	84.8	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/27/2022 05:00	59.8	17.0	482.2	0.0	43.9	1	1	0
12/27/2022 06:00	25.6	14.3	1,185.6	0.0	60.7	1	1	0
12/27/2022 07:00	0.4	13.7	1,737.9	0.0	1.3	1	1	0
12/27/2022 08:00	0.5	13.6	1,714.6	0.0	1.6	1	1	1
12/27/2022 09:00	1.4	12.9	1,950.3	0.6	4.5	1	1	1
12/27/2022 10:00	1.2	12.9	1,947.7	0.8	3.9	1	1	1
12/27/2022 11:00	1.0	12.9	1,950.7	0.9	3.2	1	1	1
12/27/2022 12:00	0.9	12.9	1,949.0	0.8	2.9	1	1	1
12/27/2022 13:00	0.9	12.9	1,947.5	0.7	2.9	1	1	1
12/27/2022 14:00	0.9	12.9	1,948.0	0.7	2.9	1	1	1
12/27/2022 15:00	0.9	12.9	1,949.1	0.7	2.9	1	1	1
12/27/2022 16:00	1.0	12.9	1,950.9	0.7	3.2	1	1	1
12/27/2022 17:00	1.2	13.0	1,941.7	0.8	3.9	1	1	1
12/27/2022 18:00	1.2	13.1	1,938.3	0.8	3.9	1	1	1
12/27/2022 19:00	1.2	13.1	1,941.5	0.9	3.9	1	1	1
12/27/2022 20:00	1.3	13.1	1,950.2	0.9	4.3	1	1	1
12/27/2022 21:00	1.2	13.1	1,946.3	0.9	4.0	1	1	1
12/27/2022 22:00	1.2	13.1	1,927.1	0.9	3.9	1	1	1
12/27/2022 23:00	0.5	13.9	1,398.6	0.7	1.3	1	1	0
Average/Sum#:	5.4	13.4	1,776.7	0.8	159.1 #	19 #	21 #	15 #
Minimum:	0.4	12.9	482.2	0.6	1.3	0	0	0
Maximum:	59.8	17.0	1,950.9	0.9	60.7	1	1	1
%SI	20.83	20.83	20.83	37.50	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.4	13.8	1,551.1	0.5	1.2	1	1	0
12/28/2022 01:00	0.5	13.8	1,473.8	0.4	1.4	1	1	0
12/28/2022 02:00	0.5	13.8	1,538.3	0.4	1.4	1	1	0
12/28/2022 03:00	0.5	13.8	1,537.5	0.4	1.4	1	1	0
12/28/2022 04:00	0.5	13.8	1,543.0	0.4	1.4	1	1	0
12/28/2022 05:00	0.4	13.7	1,735.6	0.4	1.3	1	1	0
12/28/2022 06:00	0.4	13.7	1,753.7	0.3	1.3	1	1	0
12/28/2022 07:00	0.4	13.7	1,756.5	0.3	1.3	1	1	0
12/28/2022 08:00	0.4	13.7	1,732.6	0.3	1.3	1	1	0
12/28/2022 09:00	0.4	13.7	1,723.8	0.3	1.3	1	1	0
12/28/2022 10:00	0.4	13.8	1,562.0	0.3	1.2	1	1	0
12/28/2022 11:00	0.4	13.8	1,577.9	0.3	1.2	1	1	0
12/28/2022 12:00	0.4	13.8	1,560.7	0.3	1.2	1	1	0
12/28/2022 13:00	0.4	13.8	1,535.3	0.3	1.1	1	1	0
12/28/2022 14:00	0.4	13.8	1,554.0	0.3	1.2	1	1	0
12/28/2022 15:00	0.5	13.7	1,601.3	0.3	1.5	1	1	1
12/28/2022 16:00	1.2	12.5	2,087.1	0.5	3.9	1	1	1
12/28/2022 17:00	1.1	13.0	1,974.8	0.7	3.6	1	1	1
12/28/2022 18:00	1.2	13.1	1,954.9	0.8	4.0	1	1	1
12/28/2022 19:00	1.2	13.1	1,956.3	0.9	4.0	1	1	1
12/28/2022 20:00	1.3	13.1	1,955.8	0.9	4.3	1	1	1
12/28/2022 21:00	1.2	13.0	1,967.9	0.9	3.9	1	1	1
12/28/2022 22:00	1.3	13.1	1,952.9	1.0	4.3	1	1	1
12/28/2022 23:00	1.3	13.1	1,957.6	1.0	4.3	1	1	1
Average/Sum#:	0.7	13.5	1,731.0	0.5	53.0 #	24 #	24 #	9 #
Minimum:	0.4	12.5	1,473.8	0.3	1.1	1	1	0
Maximum:	1.3	13.8	2,087.1	1.0	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	1.3	13.1	1,953.1	1.0	4.3	1	1	1
12/29/2022 01:00	1.3	13.1	1,953.2	1.0	4.3	1	1	1
12/29/2022 02:00	1.3	13.1	1,953.7	1.0	4.3	1	1	1
12/29/2022 03:00	1.3	13.1	1,955.0	1.0	4.3	1	1	1
12/29/2022 04:00	1.3	13.1	1,957.5	1.0	4.3	1	1	1
12/29/2022 05:00	1.1	12.7	2,029.7	0.9	3.6	1	1	1
12/29/2022 06:00	1.1	12.8	2,039.0	0.9	3.7	1	1	1
12/29/2022 07:00	1.1	12.8	2,042.7	0.8	3.7	1	1	1
12/29/2022 08:00	1.0	12.2	2,185.5	0.8	3.3	1	1	1
12/29/2022 09:00	0.9	11.9	2,234.1	0.7	3.0	1	1	1
12/29/2022 10:00	0.9	12.3	2,142.2	0.6	3.0	1	1	1
12/29/2022 11:00	1.1	12.9	2,012.8	0.7	3.7	1	1	1
12/29/2022 12:00	1.2	13.0	1,975.6	0.8	4.0	1	1	1
12/29/2022 13:00	1.4	13.1	1,962.0	0.9	4.7	1	1	1
12/29/2022 14:00	1.3	13.0	1,971.1	1.0	4.3	1	1	1
12/29/2022 15:00	1.3	13.0	1,977.5	1.0	4.3	1	1	1
12/29/2022 16:00	1.2	12.6	2,082.3	1.0	4.0	1	1	1
12/29/2022 17:00	0.9	12.3	2,149.3	0.8	3.0	1	1	1
12/29/2022 18:00	1.0	12.6	2,062.6	0.7	3.3	1	1	1
12/29/2022 19:00	1.4	13.1	1,956.5	0.8	4.6	1	1	1
12/29/2022 20:00	1.4	13.1	1,963.5	1.0	4.7	1	1	1
12/29/2022 21:00	1.3	13.0	1,973.9	1.1	4.3	1	1	1
12/29/2022 22:00	1.4	13.0	1,958.1	1.0	4.6	1	1	1
12/29/2022 23:00	1.4	13.1	1,930.3	1.0	4.6	1	1	1
Average/Sum#:	1.2	12.8	2,017.6	0.9	95.9 #	24 #	24 #	24 #
Minimum:	0.9	11.9	1,930.3	0.6	3.0	1	1	1
Maximum:	1.4	13.1	2,234.1	1.1	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2022 00:00	19.6	15.6	627.2	0.0	7.7	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	19.6	15.6	627.2	0.0	7.7 #	1 #	0 #	0 #
Minimum:	19.6	15.6	627.2	0.0	7.7	0	0	0
Maximum:	19.6	15.6	627.2	0.0	7.7	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2022 00:00	0.3	12.1	2,166.3	0.2	1.0	1	1	1
10/01/2022 01:00	8.5	14.2	1,202.0	0.0	9.6	1	0	1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2022 12:00	21.9	17.7	308.0	0.0	20.0	1	0	0
10/01/2022 13:00	12.2	17.2	376.4	0.0	16.4	1	0	0
10/01/2022 14:00	17.3	15.5	875.8	0.0	37.1	1	0	0
10/01/2022 15:00	0.2	14.1	1,414.5	0.0	0.5	1	1	0
10/01/2022 16:00	0.4	13.6	1,717.8	0.0	1.2	1	1	1
10/01/2022 17:00	0.4	11.6	2,258.0	0.3	1.3	1	1	1
10/01/2022 18:00	0.4	11.9	2,188.3	0.3	1.3	1	1	1
10/01/2022 19:00	0.6	12.6	2,026.7	0.3	1.9	1	1	1
10/01/2022 20:00	0.4	11.9	2,210.8	0.3	1.3	1	1	1
10/01/2022 21:00	0.4	12.5	1,932.3	0.3	1.2	1	1	1
10/01/2022 22:00	0.3	13.8	1,569.8	0.3	0.9	1	1	0
10/01/2022 23:00	17.4	15.6	630.9	0.0	6.9	1	0	0
Average/Sum#:	5.8	13.9	1,491.3	0.3	100.6 #	14 #	9 #	8 #
Minimum:	0.2	11.6	308.0	0.2	0.5	0	0	0
Maximum:	21.9	17.7	2,258.0	0.3	37.1	1	1	1
%SI	41.67	41.67	41.67	70.83	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/02/2022 11:00	46.2	17.7	311.4	0.0	39.8	1	0	0
10/02/2022 12:00	16.4	17.2	404.4	0.0	23.7	1	0	0
10/02/2022 13:00	22.5	15.6	880.7	0.0	49.4	1	0	0
10/02/2022 14:00	0.3	13.8	1,730.7	0.0	1.0	1	1	0
10/02/2022 15:00	0.6	13.2	1,719.8	0.0	1.8	1	1	1
10/02/2022 16:00	0.6	12.0	2,184.2	0.4	1.9	1	1	1
10/02/2022 17:00	0.4	11.6	2,265.0	0.4	1.3	1	1	1
10/02/2022 18:00	0.4	11.6	2,270.6	0.3	1.3	1	1	1
10/02/2022 19:00	0.3	11.6	2,272.9	0.3	1.0	1	1	1
10/02/2022 20:00	0.3	11.6	2,274.3	0.2	1.0	1	1	1
10/02/2022 21:00	0.5	12.4	2,098.7	0.2	1.6	1	1	1
10/02/2022 22:00	0.4	12.7	1,912.0	0.3	1.2	1	1	1
10/02/2022 23:00	0.3	13.9	1,550.6	0.3	0.9	1	1	0
Average/Sum#:	6.9	13.5	1,682.7	0.3	125.9 #	13 #	10 #	8 #
Minimum:	0.3	11.6	311.4	0.2	0.9	0	0	0
Maximum:	46.2	17.7	2,274.3	0.4	49.4	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2022 00:00	0.3	13.9	1,546.4	0.3	0.9	1	1	0
10/03/2022 01:00	0.3	13.9	1,550.3	0.3	0.9	1	1	0
10/03/2022 02:00	0.3	13.8	1,784.2	0.3	1.0	1	1	0
10/03/2022 03:00	0.3	13.9	1,582.9	0.3	0.9	1	1	0
10/03/2022 04:00	0.2	13.9	1,715.7	0.2	0.6	1	1	0
10/03/2022 05:00	0.2	13.9	1,713.6	0.2	0.6	1	1	0
10/03/2022 06:00	0.2	13.9	1,710.7	0.2	0.6	1	1	0
10/03/2022 07:00	0.2	13.9	1,711.1	0.2	0.6	1	1	0
10/03/2022 08:00	0.2	13.9	1,717.3	0.2	0.6	1	1	0
10/03/2022 09:00	0.2	13.9	1,722.1	0.2	0.6	1	1	0
10/03/2022 10:00	0.3	13.9	1,724.5	0.2	1.0	1	1	0
10/03/2022 11:00	0.3	13.9	1,724.7	0.3	1.0	1	1	0
10/03/2022 12:00	0.3	13.9	1,724.6	0.3	1.0	1	1	0
10/03/2022 13:00	0.3	13.9	1,725.3	0.3	1.0	1	1	0
10/03/2022 14:00	0.3	13.9	1,716.6	0.3	1.0	1	1	0
10/03/2022 15:00	0.3	13.8	1,754.9	0.3	1.0	1	1	1
10/03/2022 16:00	0.6	12.5	2,060.1	0.3	1.9	1	1	1
10/03/2022 17:00	0.4	12.0	2,170.1	0.3	1.3	1	1	1
10/03/2022 18:00	0.3	11.8	2,202.2	0.3	1.0	1	1	1
10/03/2022 19:00	0.3	12.0	2,175.9	0.2	1.0	1	1	1
10/03/2022 20:00	0.3	11.9	2,186.8	0.2	1.0	1	1	1
10/03/2022 21:00	0.3	12.0	2,178.8	0.2	1.0	1	1	1
10/03/2022 22:00	0.3	12.2	2,156.6	0.2	1.0	1	1	1
10/03/2022 23:00	0.3	12.1	2,174.0	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.3	1,851.2	0.3	22.5 #	24 #	24 #	9 #
Minimum:	0.2	11.8	1,546.4	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,202.2	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2022 00:00	0.3	12.2	2,156.2	0.2	1.0	1	1	1
10/04/2022 01:00	0.3	12.2	2,159.9	0.2	1.0	1	1	1
10/04/2022 02:00	0.3	12.2	2,158.6	0.2	1.0	1	1	1
10/04/2022 03:00	0.3	12.1	2,168.6	0.2	1.0	1	1	1
10/04/2022 04:00	0.3	12.1	2,182.7	0.2	1.0	1	1	1
10/04/2022 05:00	0.2	12.0	2,216.4	0.2	0.7	1	1	1
10/04/2022 06:00	0.3	12.3	2,179.8	0.2	1.0	1	1	1
10/04/2022 07:00	0.3	12.7	2,043.5	0.2	1.0	1	1	1
10/04/2022 08:00	0.2	13.8	1,586.2	0.2	0.6	1	1	0
10/04/2022 09:00	0.2	13.9	1,548.5	0.2	0.6	1	1	0
10/04/2022 10:00	0.0	0.0	1,554.2	0.0	0.0	1	1	0
10/04/2022 11:00	0.3	13.9	1,562.4	0.0	0.9	1	1	0
10/04/2022 12:00	0.3	13.9	1,707.0	0.0	1.0	1	1	0
10/04/2022 13:00	0.5	13.8	1,733.0	0.3	1.6	1	1	1
10/04/2022 14:00	0.6	12.7	2,019.5	0.4	2.0	1	1	1
10/04/2022 15:00	0.4	12.1	2,136.1	0.4	1.3	1	1	1
10/04/2022 16:00	0.4	12.1	2,128.5	0.3	1.3	1	1	1
10/04/2022 17:00	0.3	12.1	2,140.4	0.3	1.0	1	1	1
10/04/2022 18:00	0.3	12.0	2,169.9	0.2	1.0	1	1	1
10/04/2022 19:00	0.3	11.9	2,188.2	0.2	1.0	1	1	1
10/04/2022 20:00	0.2	11.7	2,242.8	0.2	0.6	1	1	1
10/04/2022 21:00	0.2	11.9	2,190.4	0.1	0.6	1	1	1
10/04/2022 22:00	0.3	12.0	2,179.1	0.1	1.0	1	1	1
10/04/2022 23:00	0.3	12.2	2,143.7	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,020.7	0.2	23.2 #	24 #	24 #	19 #
Minimum:	0.2	11.7	1,548.5	0.1	0.6	1	1	0
Maximum:	0.6	13.9	2,242.8	0.4	2.0	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2022 00:00	0.3	12.2	2,136.6	0.2	1.0	1	1	1
10/05/2022 01:00	0.4	12.8	1,995.6	0.2	1.3	1	1	1
10/05/2022 02:00	0.5	13.0	1,971.2	0.3	1.6	1	1	1
10/05/2022 03:00	0.4	12.5	2,088.5	0.3	1.3	1	1	1
10/05/2022 04:00	0.3	12.3	2,117.7	0.3	1.0	1	1	1
10/05/2022 05:00	0.2	12.0	2,204.8	0.2	0.7	1	1	1
10/05/2022 06:00	0.2	12.1	2,206.4	0.1	0.7	1	1	1
10/05/2022 07:00	0.4	12.9	1,980.3	0.2	1.3	1	1	1
10/05/2022 08:00	0.1	13.9	1,702.3	0.2	0.3	1	1	0
10/05/2022 09:00	0.2	13.9	1,667.6	0.2	0.6	1	1	0
10/05/2022 10:00	0.3	13.9	1,693.9	0.2	1.0	1	1	0
10/05/2022 11:00	0.3	13.9	1,706.3	0.3	1.0	1	1	0
10/05/2022 12:00	0.3	13.8	1,723.0	0.3	1.0	1	1	1
10/05/2022 13:00	0.5	12.5	2,064.2	0.3	1.6	1	1	1
10/05/2022 14:00	0.3	11.9	2,181.4	0.3	1.0	1	1	1
10/05/2022 15:00	0.3	12.1	2,135.0	0.3	1.0	1	1	1
10/05/2022 16:00	0.3	12.0	2,157.2	0.2	1.0	1	1	1
10/05/2022 17:00	0.3	11.8	2,196.1	0.2	1.0	1	1	1
10/05/2022 18:00	0.2	11.7	2,231.0	0.2	0.6	1	1	1
10/05/2022 19:00	0.2	11.7	2,237.6	0.1	0.6	1	1	1
10/05/2022 20:00	0.3	11.9	2,188.3	0.1	1.0	1	1	1
10/05/2022 21:00	0.2	11.7	2,234.5	0.1	0.6	1	1	1
10/05/2022 22:00	0.3	12.1	2,163.4	0.2	1.0	1	1	1
10/05/2022 23:00	0.3	12.1	2,172.8	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,048.2	0.2	23.2 #	24 #	24 #	20 #
Minimum:	0.1	11.7	1,667.6	0.1	0.3	1	1	0
Maximum:	0.5	13.9	2,237.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2022 00:00	0.3	12.2	2,162.3	0.2	1.0	1	1	1
10/06/2022 01:00	0.3	12.1	2,166.4	0.2	1.0	1	1	1
10/06/2022 02:00	0.3	12.1	2,164.4	0.2	1.0	1	1	1
10/06/2022 03:00	0.3	12.2	2,142.9	0.2	1.0	1	1	1
10/06/2022 04:00	0.2	12.0	2,184.4	0.2	0.6	1	1	1
10/06/2022 05:00	0.2	11.8	2,246.2	0.1	0.7	1	1	1
10/06/2022 06:00	0.2	11.9	2,233.3	0.1	0.7	1	1	1
10/06/2022 07:00	0.3	12.3	2,131.1	0.1	1.0	1	1	1
10/06/2022 08:00	0.4	12.5	2,082.8	0.2	1.3	1	1	1
10/06/2022 09:00	0.4	12.6	2,065.4	0.3	1.3	1	1	1
10/06/2022 10:00	0.4	12.5	2,076.7	0.3	1.3	1	1	1
10/06/2022 11:00	0.4	12.3	2,113.6	0.3	1.3	1	1	1
10/06/2022 12:00	0.3	12.1	2,142.5	0.3	1.0	1	1	1
10/06/2022 13:00	0.2	11.9	2,198.7	0.2	0.6	1	1	1
10/06/2022 14:00	0.2	11.8	2,207.0	0.1	0.6	1	1	1
10/06/2022 15:00	0.3	12.0	2,158.9	0.1	1.0	1	1	1
10/06/2022 16:00	0.3	11.9	2,197.5	0.2	1.0	1	1	1
10/06/2022 17:00	0.2	11.7	2,245.6	0.2	0.6	1	1	1
10/06/2022 18:00	0.2	11.7	2,241.8	0.1	0.6	1	1	1
10/06/2022 19:00	0.2	11.7	2,251.9	0.1	0.6	1	1	1
10/06/2022 20:00	0.2	11.7	2,253.7	0.1	0.6	1	1	1
10/06/2022 21:00	0.2	11.8	2,243.5	0.1	0.7	1	1	1
10/06/2022 22:00	0.2	12.0	2,189.6	0.1	0.6	1	1	1
10/06/2022 23:00	0.3	12.1	2,168.9	0.1	1.0	1	1	1
Average/Sum#:	0.3	12.0	2,177.9	0.2	21.1 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,065.4	0.1	0.6	1	1	1
Maximum:	0.4	12.6	2,253.7	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2022 00:00	0.3	12.3	2,144.9	0.2	1.0	1	1	1
10/07/2022 01:00	0.3	12.2	2,158.5	0.2	1.0	1	1	1
10/07/2022 02:00	0.3	12.3	2,141.1	0.2	1.0	1	1	1
10/07/2022 03:00	0.3	12.4	2,115.0	0.2	1.0	1	1	1
10/07/2022 04:00	0.3	12.2	2,155.3	0.2	1.0	1	1	1
10/07/2022 05:00	0.3	12.1	2,191.5	0.2	1.0	1	1	1
10/07/2022 06:00	0.2	12.1	2,204.8	0.2	0.7	1	1	1
10/07/2022 07:00	0.3	12.4	2,111.6	0.2	1.0	1	1	1
10/07/2022 08:00	0.4	12.7	2,031.6	0.2	1.3	1	1	1
10/07/2022 09:00	0.3	12.3	2,132.5	0.2	1.0	1	1	1
10/07/2022 10:00	0.3	12.3	2,127.2	0.2	1.0	1	1	1
10/07/2022 11:00	0.3	12.3	2,117.0	0.2	1.0	1	1	1
10/07/2022 12:00	0.3	12.0	2,174.6	0.2	1.0	1	1	1
10/07/2022 13:00	0.3	12.1	2,147.2	0.2	1.0	1	1	1
10/07/2022 14:00	0.3	11.9	2,194.6	0.2	1.0	1	1	1
10/07/2022 15:00	0.2	11.8	2,203.8	0.2	0.6	1	1	1
10/07/2022 16:00	0.3	11.9	2,188.4	0.2	1.0	1	1	1
10/07/2022 17:00	0.2	11.7	2,238.4	0.1	0.6	1	1	1
10/07/2022 18:00	0.2	11.7	2,248.1	0.1	0.6	1	1	1
10/07/2022 19:00	0.2	11.7	2,254.3	0.1	0.6	1	1	1
10/07/2022 20:00	0.2	11.7	2,259.1	0.1	0.6	1	1	1
10/07/2022 21:00	0.2	11.7	2,262.1	0.1	0.6	1	1	1
10/07/2022 22:00	0.2	11.7	2,256.4	0.1	0.6	1	1	1
10/07/2022 23:00	0.2	12.0	2,191.4	0.1	0.7	1	1	1
Average/Sum#:	0.3	12.1	2,177.1	0.2	20.9 #	24 #	24 #	24 #
Minimum:	0.2	11.7	2,031.6	0.1	0.6	1	1	1
Maximum:	0.4	12.7	2,262.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2022 00:00	0.3	12.1	2,179.0	0.1	1.0	1	1	1
10/08/2022 01:00	0.3	12.1	2,173.7	0.2	1.0	1	1	1
10/08/2022 02:00	0.3	12.2	2,165.8	0.2	1.0	1	1	1
10/08/2022 03:00	0.3	12.1	2,178.8	0.2	1.0	1	1	1
10/08/2022 04:00	0.3	12.1	2,186.4	0.2	1.0	1	1	1
10/08/2022 05:00	0.3	12.2	2,175.0	0.2	1.0	1	1	1
10/08/2022 06:00	0.4	12.6	2,114.0	0.2	1.3	1	1	1
10/08/2022 07:00	0.3	13.7	1,700.8	0.2	0.9	1	1	1
10/08/2022 08:00	0.2	14.0	1,358.1	0.2	0.5	1	1	0
10/08/2022 09:00	0.1	14.1	1,309.6	0.2	0.3	1	1	0
10/08/2022 10:00	0.1	14.1	1,309.0	0.1	0.3	1	1	0
10/08/2022 11:00	0.1	14.1	1,314.2	0.1	0.3	1	1	0
10/08/2022 12:00	0.3	13.9	1,559.1	0.2	0.9	1	1	0
10/08/2022 13:00	0.3	13.9	1,711.4	0.2	1.0	1	1	0
10/08/2022 14:00	0.3	13.8	1,728.5	0.3	1.0	1	1	1
10/08/2022 15:00	0.5	12.3	2,093.4	0.3	1.6	1	1	1
10/08/2022 16:00	0.3	11.8	2,196.4	0.2	1.0	1	1	1
10/08/2022 17:00	0.3	11.8	2,200.9	0.2	1.0	1	1	1
10/08/2022 18:00	0.3	12.0	2,169.3	0.2	1.0	1	1	1
10/08/2022 19:00	0.3	12.0	2,176.3	0.2	1.0	1	1	1
10/08/2022 20:00	0.3	12.0	2,183.4	0.2	1.0	1	1	1
10/08/2022 21:00	0.3	12.0	2,182.8	0.2	1.0	1	1	1
10/08/2022 22:00	0.3	12.1	2,179.0	0.2	1.0	1	1	1
10/08/2022 23:00	0.3	12.2	2,177.1	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.7	1,946.8	0.2	22.1 #	24 #	24 #	18 #
Minimum:	0.1	11.8	1,309.0	0.1	0.3	1	1	0
Maximum:	0.5	14.1	2,200.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2022 00:00	0.3	12.1	2,173.7	0.2	1.0	1	1	1
10/09/2022 01:00	0.3	12.2	2,176.5	0.2	1.0	1	1	1
10/09/2022 02:00	0.3	12.3	2,147.0	0.2	1.0	1	1	1
10/09/2022 03:00	0.3	12.3	2,158.6	0.2	1.0	1	1	1
10/09/2022 04:00	0.3	12.2	2,165.0	0.2	1.0	1	1	1
10/09/2022 05:00	0.3	12.2	2,156.0	0.2	1.0	1	1	1
10/09/2022 06:00	6.8	13.7	1,682.6	0.0	21.0	1	0	1
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2022 14:00	20.9	17.6	384.2	0.0	23.1	1	0	0
10/09/2022 15:00	12.9	14.5	1,309.2	0.0	34.9	1	0	0
10/09/2022 16:00	0.3	13.9	1,714.4	0.0	1.0	1	1	0
10/09/2022 17:00	0.3	13.7	1,764.8	0.0	1.0	1	1	1
10/09/2022 18:00	0.5	12.4	2,079.4	0.3	1.6	1	1	1
10/09/2022 19:00	0.2	11.8	2,207.7	0.2	0.6	1	1	1
10/09/2022 20:00	0.2	12.0	2,185.0	0.2	0.6	1	1	1
10/09/2022 21:00	0.3	12.1	2,173.4	0.1	1.0	1	1	1
10/09/2022 22:00	0.3	12.2	2,156.8	0.2	1.0	1	1	1
10/09/2022 23:00	0.3	12.2	2,148.5	0.2	1.0	1	1	1
Average/Sum#:	2.6	12.9	1,928.4	0.2	92.8 #	17 #	14 #	14 #
Minimum:	0.2	11.8	384.2	0.1	0.6	0	0	0
Maximum:	20.9	17.6	2,207.7	0.3	34.9	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2022 00:00	0.3	12.3	2,123.4	0.2	1.0	1	1	1
10/10/2022 01:00	0.3	12.5	2,095.3	0.2	1.0	1	1	1
10/10/2022 02:00	0.5	13.0	1,981.4	0.3	1.7	1	1	1
10/10/2022 03:00	0.4	12.5	2,093.7	0.3	1.3	1	1	1
10/10/2022 04:00	0.3	12.4	2,139.2	0.3	1.0	1	1	1
10/10/2022 05:00	0.2	12.0	2,225.5	0.2	0.7	1	1	1
10/10/2022 06:00	0.2	12.1	2,215.7	0.1	0.7	1	1	1
10/10/2022 07:00	0.3	13.4	1,803.1	0.1	1.0	1	1	1
10/10/2022 08:00	0.2	13.9	1,542.0	0.2	0.6	1	1	0
10/10/2022 09:00	0.2	14.0	1,535.7	0.2	0.6	1	1	0
10/10/2022 10:00	0.1	14.1	1,390.1	0.2	0.3	1	1	0
10/10/2022 11:00	0.2	14.0	1,562.7	0.2	0.6	1	1	0
10/10/2022 12:00	0.2	14.1	1,576.8	0.2	0.6	1	1	0
10/10/2022 13:00	0.2	13.9	1,704.6	0.2	0.6	1	1	0
10/10/2022 14:00	0.2	13.9	1,711.9	0.2	0.6	1	1	0
10/10/2022 15:00	0.3	13.9	1,584.5	0.2	0.9	1	1	0
10/10/2022 16:00	0.5	12.8	1,953.3	0.3	1.6	1	1	1
10/10/2022 17:00	0.3	12.0	2,159.8	0.3	1.0	1	1	1
10/10/2022 18:00	0.3	11.9	2,194.5	0.3	1.0	1	1	1
10/10/2022 19:00	0.3	12.0	2,171.3	0.2	1.0	1	1	1
10/10/2022 20:00	0.3	12.1	2,163.2	0.2	1.0	1	1	1
10/10/2022 21:00	0.4	12.3	2,109.3	0.2	1.3	1	1	1
10/10/2022 22:00	0.4	12.5	2,091.9	0.3	1.3	1	1	1
10/10/2022 23:00	0.5	13.0	1,947.6	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,919.9	0.2	23.0 #	24 #	24 #	16 #
Minimum:	0.1	11.9	1,390.1	0.1	0.3	1	1	0
Maximum:	0.5	14.1	2,225.5	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2022 00:00	0.2	14.0	1,368.8	0.3	0.5	1	1	0
10/11/2022 01:00	0.2	14.0	1,294.0	0.3	0.5	1	1	0
10/11/2022 02:00	0.1	14.0	1,293.9	0.2	0.2	1	1	0
10/11/2022 03:00	0.2	14.0	1,345.8	0.2	0.5	1	1	0
10/11/2022 04:00	0.2	14.0	1,489.9	0.2	0.6	1	1	0
10/11/2022 05:00	0.2	14.0	1,314.3	0.2	0.5	1	1	0
10/11/2022 06:00	0.2	14.0	1,303.1	0.2	0.5	1	1	0
10/11/2022 07:00	0.2	14.0	1,318.9	0.2	0.5	1	1	0
10/11/2022 08:00	0.2	13.9	1,748.2	0.2	0.7	1	1	0
10/11/2022 09:00	0.2	14.0	1,592.2	0.2	0.6	1	1	0
10/11/2022 10:00	0.3	13.8	1,729.7	0.2	1.0	1	1	0
10/11/2022 11:00	0.3	13.8	1,747.4	0.2	1.0	1	1	0
10/11/2022 12:00	0.3	13.9	1,748.6	0.2	1.0	1	1	0
10/11/2022 13:00	0.3	13.9	1,740.2	0.3	1.0	1	1	0
10/11/2022 14:00	0.3	13.9	1,733.2	0.3	1.0	1	1	0
10/11/2022 15:00	0.3	13.9	1,737.7	0.3	1.0	1	1	0
10/11/2022 16:00	0.3	13.8	1,760.7	0.3	1.0	1	1	0
10/11/2022 17:00	0.3	13.7	1,770.9	0.2	1.0	1	1	0
10/11/2022 18:00	0.3	13.7	1,775.7	0.2	1.0	1	1	1
10/11/2022 19:00	0.6	12.5	2,057.5	0.3	1.9	1	1	1
10/11/2022 20:00	0.4	12.3	2,104.9	0.3	1.3	1	1	1
10/11/2022 21:00	0.4	12.1	2,159.4	0.3	1.3	1	1	1
10/11/2022 22:00	0.4	12.4	2,094.6	0.3	1.3	1	1	1
10/11/2022 23:00	0.5	13.0	1,961.3	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.6	1,674.6	0.2	21.5 #	24 #	24 #	6 #
Minimum:	0.1	12.1	1,293.9	0.2	0.2	1	1	0
Maximum:	0.6	14.0	2,159.4	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2022 00:00	0.7	13.1	1,948.6	0.4	2.3	1	1	1
10/12/2022 01:00	0.7	13.1	1,928.9	0.5	2.3	1	1	1
10/12/2022 02:00	0.2	13.9	1,512.2	0.4	0.6	1	1	0
10/12/2022 03:00	0.2	13.9	1,624.7	0.3	0.6	1	1	0
10/12/2022 04:00	0.2	13.8	1,746.5	0.2	0.6	1	1	0
10/12/2022 05:00	0.5	12.4	2,122.6	0.2	1.6	1	1	1
10/12/2022 06:00	0.3	11.9	2,254.3	0.2	1.0	1	1	1
10/12/2022 07:00	0.2	11.9	2,245.2	0.2	0.7	1	1	1
10/12/2022 08:00	0.2	11.9	2,243.2	0.1	0.7	1	1	1
10/12/2022 09:00	0.2	11.9	2,238.0	0.1	0.7	1	1	1
10/12/2022 10:00	0.2	11.9	2,234.1	0.1	0.7	1	1	1
10/12/2022 11:00	0.2	11.9	2,233.9	0.1	0.7	1	1	1
10/12/2022 12:00	0.2	11.9	2,231.6	0.1	0.7	1	1	1
10/12/2022 13:00	0.2	11.9	2,228.9	0.1	0.7	1	1	1
10/12/2022 14:00	0.2	11.9	2,229.7	0.1	0.7	1	1	1
10/12/2022 15:00	0.2	11.8	2,235.6	0.1	0.6	1	1	1
10/12/2022 16:00	0.2	11.6	2,251.1	0.1	0.6	1	1	1
10/12/2022 17:00	0.2	11.6	2,260.5	0.1	0.6	1	1	1
10/12/2022 18:00	0.2	11.8	2,224.2	0.1	0.6	1	1	1
10/12/2022 19:00	0.3	12.2	2,135.6	0.1	1.0	1	1	1
10/12/2022 20:00	0.3	12.2	2,150.7	0.2	1.0	1	1	1
10/12/2022 21:00	0.4	12.3	2,115.2	0.2	1.3	1	1	1
10/12/2022 22:00	0.4	12.5	2,084.9	0.3	1.3	1	1	1
10/12/2022 23:00	0.6	13.0	1,959.2	0.3	2.0	1	1	1
Average/Sum#:	0.3	12.3	2,101.6	0.2	23.6 #	24 #	24 #	21 #
Minimum:	0.2	11.6	1,512.2	0.1	0.6	1	1	0
Maximum:	0.7	13.9	2,260.5	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2022 00:00	0.6	13.0	1,956.6	0.4	2.0	1	1	1
10/13/2022 01:00	0.6	12.8	2,000.9	0.4	2.0	1	1	1
10/13/2022 02:00	0.8	13.1	1,947.1	0.5	2.6	1	1	1
10/13/2022 03:00	0.7	13.1	1,959.2	0.5	2.3	1	1	1
10/13/2022 04:00	0.8	13.1	1,939.6	0.6	2.6	1	1	1
10/13/2022 05:00	0.2	13.9	1,307.9	0.4	0.5	1	1	0
10/13/2022 06:00	0.2	13.9	1,308.4	0.3	0.5	1	1	0
10/13/2022 07:00	0.2	14.0	1,308.7	0.2	0.5	1	1	0
10/13/2022 08:00	0.2	13.9	1,486.8	0.2	0.6	1	1	0
10/13/2022 09:00	0.2	13.9	1,537.2	0.2	0.6	1	1	0
10/13/2022 10:00	0.3	13.8	1,712.7	0.2	1.0	1	1	0
10/13/2022 11:00	0.3	13.7	1,794.6	0.2	1.0	1	1	0
10/13/2022 12:00	0.3	13.7	1,790.4	0.2	1.0	1	1	0
10/13/2022 13:00	0.3	13.7	1,784.6	0.2	1.0	1	1	0
10/13/2022 14:00	0.3	13.7	1,779.9	0.2	1.0	1	1	0
10/13/2022 15:00	0.3	13.7	1,777.3	0.2	1.0	1	1	0
10/13/2022 16:00	0.3	13.7	1,779.0	0.2	1.0	1	1	0
10/13/2022 17:00	0.3	13.7	1,779.7	0.2	1.0	1	1	0
10/13/2022 18:00	0.3	13.7	1,784.4	0.2	1.0	1	1	0
10/13/2022 19:00	0.3	13.7	1,788.0	0.2	1.0	1	1	1
10/13/2022 20:00	0.6	12.6	2,057.0	0.3	2.0	1	1	1
10/13/2022 21:00	0.4	12.2	2,156.4	0.3	1.3	1	1	1
10/13/2022 22:00	0.4	12.5	2,080.5	0.3	1.3	1	1	1
10/13/2022 23:00	0.4	12.6	2,070.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.4	1,787.0	0.3	30.1 #	24 #	24 #	10 #
Minimum:	0.2	12.2	1,307.9	0.2	0.5	1	1	0
Maximum:	0.8	14.0	2,156.4	0.6	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	0.4	12.7	2,061.1	0.3	1.3	1	1	1
10/14/2022 01:00	0.4	12.6	2,074.7	0.3	1.3	1	1	1
10/14/2022 02:00	0.4	12.6	2,074.6	0.3	1.3	1	1	1
10/14/2022 03:00	0.4	12.6	2,071.6	0.3	1.3	1	1	1
10/14/2022 04:00	0.3	12.4	2,112.7	0.3	1.0	1	1	1
10/14/2022 05:00	0.2	11.8	2,260.2	0.2	0.7	1	1	1
10/14/2022 06:00	0.2	11.8	2,253.5	0.1	0.7	1	1	1
10/14/2022 07:00	0.2	11.9	2,225.2	0.1	0.7	1	1	1
10/14/2022 08:00	0.3	12.7	2,025.4	0.1	1.0	1	1	1
10/14/2022 09:00	0.4	13.0	1,963.8	0.2	1.3	1	1	1
10/14/2022 10:00	0.4	12.9	1,974.2	0.3	1.3	1	1	1
10/14/2022 11:00	0.4	12.8	1,981.1	0.3	1.3	1	1	1
10/14/2022 12:00	0.5	12.8	1,989.4	0.3	1.6	1	1	1
10/14/2022 13:00	0.4	12.7	1,999.2	0.3	1.3	1	1	1
10/14/2022 14:00	0.4	12.3	2,098.0	0.3	1.3	1	1	1
10/14/2022 15:00	0.3	12.2	2,127.4	0.3	1.0	1	1	1
10/14/2022 16:00	0.3	12.2	2,119.3	0.2	1.0	1	1	1
10/14/2022 17:00	0.2	11.8	2,207.4	0.2	0.6	1	1	1
10/14/2022 18:00	0.3	12.1	2,149.5	0.2	1.0	1	1	1
10/14/2022 19:00	0.3	12.2	2,120.7	0.2	1.0	1	1	1
10/14/2022 20:00	0.3	12.2	2,129.6	0.2	1.0	1	1	1
10/14/2022 21:00	0.3	12.3	2,120.9	0.2	1.0	1	1	1
10/14/2022 22:00	0.3	12.4	2,093.7	0.2	1.0	1	1	1
10/14/2022 23:00	6.4	14.0	1,326.6	0.0	9.0	1	0	1
Average/Sum#:	0.6	12.5	2,065.0	0.2	34.0 #	24 #	23 #	24 #
Minimum:	0.2	11.8	1,326.6	0.1	0.6	1	0	1
Maximum:	6.4	14.0	2,260.2	0.3	9.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2022 17:00	75.4	17.7	328.5	0.0	74.6	1	0	0
10/16/2022 18:00	35.0	16.5	574.4	0.0	60.3	1	0	0
10/16/2022 19:00	36.7	15.1	965.7	0.0	80.7	1	0	0
10/16/2022 20:00	0.2	13.8	1,770.5	0.0	0.7	1	1	0
10/16/2022 21:00	0.2	13.8	1,686.0	0.0	0.6	1	1	0
10/16/2022 22:00	0.2	13.9	1,594.4	0.2	0.6	1	1	0
10/16/2022 23:00	0.2	13.8	1,803.8	0.2	0.7	1	1	0
Average/Sum#:	21.1	14.9	1,246.2	0.2	218.2 #	7 #	4 #	0 #
Minimum:	0.2	13.8	328.5	0.2	0.6	0	0	0
Maximum:	75.4	17.7	1,803.8	0.2	80.7	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2022 00:00	0.2	13.9	1,642.9	0.2	0.6	1	1	0
10/17/2022 01:00	0.2	13.9	1,698.6	0.2	0.6	1	1	0
10/17/2022 02:00	0.2	13.9	1,702.5	0.2	0.6	1	1	0
10/17/2022 03:00	0.2	13.8	1,794.9	0.2	0.7	1	1	1
10/17/2022 04:00	0.4	12.7	2,058.2	0.2	1.3	1	1	1
10/17/2022 05:00	0.2	12.2	2,160.0	0.2	0.7	1	1	1
10/17/2022 06:00	0.2	12.3	2,145.3	0.2	0.7	1	1	1
10/17/2022 07:00	0.3	12.5	2,099.6	0.1	1.0	1	1	1
10/17/2022 08:00	0.2	13.8	1,683.3	0.2	0.6	1	1	1
10/17/2022 09:00	0.1	13.9	1,632.3	0.2	0.3	1	1	0
10/17/2022 10:00	0.2	14.0	1,522.6	0.2	0.6	1	1	0
10/17/2022 11:00	0.2	14.0	1,609.1	0.2	0.6	1	1	0
10/17/2022 12:00	0.2	14.0	1,506.6	0.2	0.6	1	1	0
10/17/2022 13:00	0.2	14.0	1,501.4	0.2	0.6	1	1	0
10/17/2022 14:00	0.2	14.0	1,657.9	0.2	0.6	1	1	0
10/17/2022 15:00	0.3	13.8	1,696.8	0.2	0.9	1	1	1
10/17/2022 16:00	0.5	12.5	2,079.8	0.3	1.6	1	1	1
10/17/2022 17:00	0.3	11.8	2,230.9	0.3	1.0	1	1	1
10/17/2022 18:00	0.2	11.8	2,246.4	0.2	0.7	1	1	1
10/17/2022 19:00	0.2	11.9	2,223.6	0.1	0.7	1	1	1
10/17/2022 20:00	0.2	11.9	2,229.9	0.1	0.7	1	1	1
10/17/2022 21:00	0.2	11.8	2,239.7	0.1	0.7	1	1	1
10/17/2022 22:00	0.3	12.2	2,177.2	0.1	1.0	1	1	1
10/17/2022 23:00	0.3	12.2	2,183.6	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.0	1,905.1	0.2	18.4 #	24 #	24 #	15 #
Minimum:	0.1	11.8	1,501.4	0.1	0.3	1	1	0
Maximum:	0.5	14.0	2,246.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2022 00:00	0.3	12.2	2,179.1	0.2	1.0	1	1	1
10/18/2022 01:00	0.2	12.3	2,170.9	0.2	0.7	1	1	1
10/18/2022 02:00	0.2	12.2	2,170.7	0.1	0.7	1	1	1
10/18/2022 03:00	0.2	12.1	2,176.9	0.1	0.7	1	1	1
10/18/2022 04:00	0.2	12.1	2,177.4	0.1	0.7	1	1	1
10/18/2022 05:00	0.3	12.2	2,182.6	0.1	1.0	1	1	1
10/18/2022 06:00	0.3	12.3	2,168.2	0.2	1.0	1	1	1
10/18/2022 07:00	0.3	12.3	2,166.7	0.2	1.0	1	1	1
10/18/2022 08:00	0.3	12.3	2,171.0	0.2	1.0	1	1	1
10/18/2022 09:00	0.3	12.4	2,155.8	0.2	1.0	1	1	1
10/18/2022 10:00	0.4	12.4	2,119.5	0.2	1.3	1	1	1
10/18/2022 11:00	0.4	12.5	2,098.2	0.3	1.3	1	1	1
10/18/2022 12:00	0.4	12.5	2,098.2	0.3	1.3	1	1	1
10/18/2022 13:00	0.4	12.5	2,102.8	0.3	1.3	1	1	1
10/18/2022 14:00	0.4	12.4	2,107.4	0.3	1.3	1	1	1
10/18/2022 15:00	0.4	12.3	2,134.7	0.3	1.3	1	1	1
10/18/2022 16:00	0.3	11.9	2,216.3	0.3	1.0	1	1	1
10/18/2022 17:00	0.3	12.1	2,188.4	0.2	1.0	1	1	1
10/18/2022 18:00	0.3	11.9	2,231.8	0.2	1.0	1	1	1
10/18/2022 19:00	0.2	11.8	2,253.5	0.2	0.7	1	1	1
10/18/2022 20:00	0.2	11.8	2,259.4	0.1	0.7	1	1	1
10/18/2022 21:00	0.2	11.8	2,259.3	0.1	0.7	1	1	1
10/18/2022 22:00	0.3	12.1	2,195.6	0.1	1.0	1	1	1
10/18/2022 23:00	0.3	12.1	2,192.8	0.2	1.0	1	1	1
Average/Sum#:	0.3	12.2	2,174.1	0.2	23.7 #	24 #	24 #	24 #
Minimum:	0.2	11.8	2,098.2	0.1	0.7	1	1	1
Maximum:	0.4	12.5	2,259.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2022 00:00	0.3	12.2	2,182.0	0.2	1.0	1	1	1
10/19/2022 01:00	0.4	12.5	2,136.3	0.2	1.3	1	1	1
10/19/2022 02:00	0.4	12.6	2,103.7	0.3	1.3	1	1	1
10/19/2022 03:00	0.4	12.5	2,144.5	0.3	1.3	1	1	1
10/19/2022 04:00	0.3	12.3	2,188.0	0.3	1.0	1	1	1
10/19/2022 05:00	0.3	12.0	2,237.9	0.2	1.0	1	1	1
10/19/2022 06:00	0.3	12.2	2,213.4	0.2	1.0	1	1	1
10/19/2022 07:00	0.4	12.4	2,148.6	0.2	1.3	1	1	1
10/19/2022 08:00	0.4	12.5	2,138.1	0.3	1.3	1	1	1
10/19/2022 09:00	0.4	12.6	2,094.9	0.3	1.3	1	1	1
10/19/2022 10:00	0.4	12.6	2,079.5	0.3	1.3	1	1	1
10/19/2022 11:00	0.4	12.4	2,110.0	0.3	1.3	1	1	1
10/19/2022 12:00	0.4	12.3	2,130.2	0.3	1.3	1	1	1
10/19/2022 13:00	0.4	12.2	2,149.0	0.3	1.3	1	1	1
10/19/2022 14:00	0.4	12.2	2,141.4	0.3	1.3	1	1	1
10/19/2022 15:00	0.3	12.0	2,178.1	0.3	1.0	1	1	1
10/19/2022 16:00	0.3	12.0	2,194.2	0.2	1.0	1	1	1
10/19/2022 17:00	0.4	12.3	2,123.6	0.2	1.3	1	1	1
10/19/2022 18:00	0.4	12.4	2,099.3	0.3	1.3	1	1	1
10/19/2022 19:00	0.4	12.4	2,108.5	0.3	1.3	1	1	1
10/19/2022 20:00	0.4	12.3	2,147.1	0.3	1.3	1	1	1
10/19/2022 21:00	0.4	12.5	2,114.2	0.3	1.3	1	1	1
10/19/2022 22:00	0.4	12.6	2,087.5	0.3	1.3	1	1	1
10/19/2022 23:00	0.4	12.5	2,105.2	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,139.8	0.3	29.4 #	24 #	24 #	24 #
Minimum:	0.3	12.0	2,079.5	0.2	1.0	1	1	1
Maximum:	0.4	12.6	2,237.9	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2022 00:00	0.4	12.5	2,124.0	0.3	1.3	1	1	1
10/20/2022 01:00	0.4	12.6	2,087.9	0.3	1.3	1	1	1
10/20/2022 02:00	0.4	12.6	2,078.6	0.3	1.3	1	1	1
10/20/2022 03:00	0.5	12.6	2,089.3	0.3	1.7	1	1	1
10/20/2022 04:00	0.4	12.5	2,135.5	0.3	1.3	1	1	1
10/20/2022 05:00	0.3	12.1	2,217.9	0.3	1.0	1	1	1
10/20/2022 06:00	0.3	12.3	2,191.7	0.2	1.0	1	1	1
10/20/2022 07:00	0.4	12.8	2,069.5	0.2	1.3	1	1	1
10/20/2022 08:00	0.4	12.8	2,056.4	0.3	1.3	1	1	1
10/20/2022 09:00	0.5	12.7	2,066.1	0.3	1.7	1	1	1
10/20/2022 10:00	0.4	12.7	2,060.8	0.3	1.3	1	1	1
10/20/2022 11:00	0.4	12.5	2,079.4	0.3	1.3	1	1	1
10/20/2022 12:00	0.4	12.5	2,079.4	0.3	1.3	1	1	1
10/20/2022 13:00	0.4	12.4	2,099.7	0.3	1.3	1	1	1
10/20/2022 14:00	0.4	12.3	2,121.0	0.3	1.3	1	1	1
10/20/2022 15:00	0.4	12.2	2,147.2	0.3	1.3	1	1	1
10/20/2022 16:00	0.3	11.7	2,241.0	0.3	1.0	1	1	1
10/20/2022 17:00	0.3	12.0	2,178.6	0.2	1.0	1	1	1
10/20/2022 18:00	0.3	11.9	2,212.5	0.2	1.0	1	1	1
10/20/2022 19:00	0.4	12.3	2,107.9	0.2	1.3	1	1	1
10/20/2022 20:00	0.4	12.4	2,104.9	0.3	1.3	1	1	1
10/20/2022 21:00	0.4	12.6	2,083.3	0.3	1.3	1	1	1
10/20/2022 22:00	0.4	12.6	2,083.3	0.3	1.3	1	1	1
10/20/2022 23:00	0.4	12.4	2,136.7	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.4	2,118.9	0.3	30.5 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,056.4	0.2	1.0	1	1	1
Maximum:	0.5	12.8	2,241.0	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2022 00:00	0.5	12.9	1,988.0	0.3	1.6	1	1	1
10/21/2022 01:00	0.2	14.0	1,577.0	0.3	0.6	1	1	0
10/21/2022 02:00	0.3	13.9	1,586.8	0.3	0.9	1	1	0
10/21/2022 03:00	0.3	13.9	1,543.4	0.3	0.9	1	1	0
10/21/2022 04:00	0.2	14.0	1,696.1	0.3	0.6	1	1	0
10/21/2022 05:00	0.2	14.0	1,698.2	0.2	0.7	1	1	0
10/21/2022 06:00	0.2	14.0	1,598.5	0.2	0.6	1	1	0
10/21/2022 07:00	0.2	14.0	1,668.5	0.2	0.6	1	1	0
10/21/2022 08:00	0.2	14.0	1,704.9	0.2	0.7	1	1	0
10/21/2022 09:00	0.2	14.0	1,708.4	0.2	0.7	1	1	0
10/21/2022 10:00	0.2	14.0	1,706.9	0.2	0.7	1	1	0
10/21/2022 11:00	0.2	14.0	1,671.9	0.2	0.6	1	1	0
10/21/2022 12:00	0.3	14.0	1,648.8	0.2	0.9	1	1	0
10/21/2022 13:00	0.3	14.0	1,624.1	0.3	0.9	1	1	0
10/21/2022 14:00	0.3	13.9	1,681.0	0.3	1.0	1	1	0
10/21/2022 15:00	0.3	13.9	1,556.4	0.3	0.9	1	1	1
10/21/2022 16:00	0.5	12.4	2,095.8	0.3	1.6	1	1	1
10/21/2022 17:00	0.3	12.0	2,180.2	0.3	1.0	1	1	1
10/21/2022 18:00	0.4	12.2	2,136.5	0.3	1.3	1	1	1
10/21/2022 19:00	0.4	12.4	2,098.4	0.3	1.3	1	1	1
10/21/2022 20:00	0.4	12.3	2,116.7	0.3	1.3	1	1	1
10/21/2022 21:00	0.3	12.0	2,176.0	0.3	1.0	1	1	1
10/21/2022 22:00	7.8	14.3	1,201.6	0.0	9.8	1	0	1
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.5	1,768.0	0.3	30.2 #	23 #	22 #	9 #
Minimum:	0.2	12.0	1,201.6	0.2	0.6	0	0	0
Maximum:	7.8	14.3	2,180.2	0.3	9.8	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2022 20:00	68.5	17.8	297.2	0.0	62.4	1	0	0
10/23/2022 21:00	15.2	17.3	370.7	0.0	20.7	1	0	0
10/23/2022 22:00	20.3	15.9	787.1	0.0	42.2	1	0	0
10/23/2022 23:00	0.1	14.1	1,353.7	0.0	0.3	1	1	0
Average/Sum#:	26.0	16.3	702.2	0.0	125.6 #	4 #	1 #	0 #
Minimum:	0.1	14.1	297.2	0.0	0.3	0	0	0
Maximum:	68.5	17.8	1,353.7	0.0	62.4	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2022 00:00	0.1	14.1	1,368.5	0.0	0.3	1	1	0
10/24/2022 01:00	0.1	14.1	1,359.7	0.1	0.3	1	1	0
10/24/2022 02:00	0.1	14.1	1,359.6	0.1	0.3	1	1	0
10/24/2022 03:00	0.1	14.1	1,359.6	0.1	0.3	1	1	0
10/24/2022 04:00	0.1	13.9	1,649.1	0.1	0.3	1	1	0
10/24/2022 05:00	0.1	13.8	1,820.4	0.1	0.3	1	1	0
10/24/2022 06:00	0.1	13.8	1,821.7	0.1	0.3	1	1	0
10/24/2022 07:00	0.1	13.8	1,819.3	0.1	0.3	1	1	0
10/24/2022 08:00	0.1	13.9	1,816.0	0.1	0.3	1	1	0
10/24/2022 09:00	0.2	13.9	1,793.7	0.1	0.7	1	1	0
10/24/2022 10:00	0.2	13.8	1,841.1	0.2	0.7	1	1	0
10/24/2022 11:00	0.2	13.8	1,831.5	0.2	0.7	1	1	0
10/24/2022 12:00	0.2	13.9	1,769.6	0.2	0.7	1	1	0
10/24/2022 13:00	0.2	13.9	1,746.6	0.2	0.7	1	1	0
10/24/2022 14:00	8.8	15.1	1,013.9	0.0	8.5	1	0	0
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.7	14.0	1,624.7	0.1	14.7 #	15 #	14 #	0 #
Minimum:	0.1	13.8	1,013.9	0.1	0.3	0	0	0
Maximum:	8.8	15.1	1,841.1	0.2	8.5	1	1	0
%SI	37.50	37.50	37.50	45.83	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/30/2022 19:00	119.2	18.9	164.5	0.0	25.9	1	0	0
10/30/2022 20:00	36.5	17.3	372.9	0.0	49.9	1	0	0
10/30/2022 21:00	29.3	16.8	562.7	0.0	53.1	1	0	0
10/30/2022 22:00	37.6	16.0	878.4	0.0	89.0	1	0	0
10/30/2022 23:00	0.2	13.8	1,773.4	0.0	0.7	1	1	0
Average/Sum#:	44.6	16.6	750.4	0.0	218.6 #	5 #	1 #	0 #
Minimum:	0.2	13.8	164.5	0.0	0.7	0	0	0
Maximum:	119.2	18.9	1,773.4	0.0	89.0	1	1	0
%SI	79.17	79.17	79.17	100.00	79.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2022 00:00	0.2	14.0	1,565.8	0.0	0.6	1	1	0
10/31/2022 01:00	0.2	13.9	1,787.0	0.2	0.7	1	1	0
10/31/2022 02:00	0.2	14.0	1,671.4	0.2	0.6	1	1	0
10/31/2022 03:00	0.2	14.0	1,708.8	0.2	0.7	1	1	0
10/31/2022 04:00	0.2	14.0	1,723.8	0.2	0.7	1	1	0
10/31/2022 05:00	0.2	14.0	1,708.1	0.2	0.7	1	1	0
10/31/2022 06:00	0.2	14.0	1,699.3	0.2	0.7	1	1	0
10/31/2022 07:00	0.2	14.0	1,700.7	0.2	0.7	1	1	0
10/31/2022 08:00	0.2	14.0	1,704.0	0.2	0.7	1	1	0
10/31/2022 09:00	0.2	14.0	1,705.2	0.2	0.7	1	1	0
10/31/2022 10:00	0.2	14.0	1,708.1	0.2	0.7	1	1	0
10/31/2022 11:00	0.2	14.0	1,687.1	0.2	0.6	1	1	0
10/31/2022 12:00	0.2	14.0	1,677.9	0.2	0.6	1	1	0
10/31/2022 13:00	0.2	14.0	1,691.9	0.2	0.6	1	1	0
10/31/2022 14:00	0.3	13.9	1,760.4	0.2	1.0	1	1	1
10/31/2022 15:00	0.6	12.6	2,079.3	0.3	2.0	1	1	1
10/31/2022 16:00	0.5	12.5	2,105.8	0.4	1.7	1	1	1
10/31/2022 17:00	0.5	12.6	2,078.5	0.4	1.7	1	1	1
10/31/2022 18:00	0.5	12.6	2,081.3	0.4	1.7	1	1	1
10/31/2022 19:00	0.4	12.5	2,104.0	0.4	1.3	1	1	1
10/31/2022 20:00	0.4	12.5	2,108.1	0.3	1.3	1	1	1
10/31/2022 21:00	0.4	12.3	2,163.0	0.3	1.3	1	1	1
10/31/2022 22:00	0.3	12.5	2,119.3	0.3	1.0	1	1	1
10/31/2022 23:00	0.3	12.3	2,146.3	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.4	1,853.5	0.3	23.3 #	24 #	24 #	10 #
Minimum:	0.2	12.3	1,565.8	0.2	0.6	1	1	0
Maximum:	0.6	14.0	2,163.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2022 00:00	0.3	12.4	2,163.8	0.2	1.0	1	1	1
11/01/2022 01:00	0.3	12.4	2,153.2	0.2	1.0	1	1	1
11/01/2022 02:00	0.3	12.4	2,162.1	0.2	1.0	1	1	1
11/01/2022 03:00	0.3	12.4	2,163.5	0.2	1.0	1	1	1
11/01/2022 04:00	0.3	12.4	2,167.9	0.2	1.0	1	1	1
11/01/2022 05:00	0.3	12.4	2,167.4	0.2	1.0	1	1	1
11/01/2022 06:00	0.2	12.1	2,232.9	0.2	0.7	1	1	1
11/01/2022 07:00	0.2	12.3	2,179.4	0.1	0.7	1	1	1
11/01/2022 08:00	0.2	12.0	2,231.6	0.1	0.7	1	1	1
11/01/2022 09:00	0.2	12.4	2,116.2	0.1	0.7	1	1	1
11/01/2022 10:00	0.3	12.5	2,121.2	0.1	1.0	1	1	1
11/01/2022 11:00	0.2	12.2	2,178.7	0.1	0.7	1	1	1
11/01/2022 12:00	0.2	12.2	2,182.8	0.1	0.7	1	1	1
11/01/2022 13:00	0.2	12.3	2,169.2	0.1	0.7	1	1	1
11/01/2022 14:00	0.2	12.6	2,083.1	0.1	0.7	1	1	1
11/01/2022 15:00	0.4	12.7	2,094.6	0.2	1.3	1	1	1
11/01/2022 16:00	0.3	12.2	2,225.8	0.2	1.0	1	1	1
11/01/2022 17:00	0.1	11.9	2,292.1	0.2	0.3	1	1	1
11/01/2022 18:00	0.2	12.3	2,192.0	0.1	0.7	1	1	1
11/01/2022 19:00	0.2	12.5	2,163.6	0.1	0.7	1	1	1
11/01/2022 20:00	0.2	12.3	2,201.7	0.1	0.7	1	1	1
11/01/2022 21:00	0.3	12.8	2,080.8	0.1	1.0	1	1	1
11/01/2022 22:00	0.3	12.9	2,070.4	0.2	1.0	1	1	1
11/01/2022 23:00	0.2	13.4	1,845.9	0.2	0.7	1	1	1
Average/Sum#:	0.2	12.4	2,151.7	0.2	20.0 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,845.9	0.1	0.3	1	1	1
Maximum:	0.4	13.4	2,292.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2022 00:00	0.1	14.1	1,347.9	0.2	0.3	1	1	0
11/02/2022 01:00	0.1	14.0	1,630.5	0.1	0.3	1	1	0
11/02/2022 02:00	0.2	14.0	1,698.9	0.1	0.7	1	1	0
11/02/2022 03:00	0.2	14.0	1,348.8	0.2	0.5	1	1	0
11/02/2022 04:00	0.2	14.0	1,665.7	0.2	0.6	1	1	0
11/02/2022 05:00	0.3	13.5	1,907.9	0.2	1.0	1	1	1
11/02/2022 06:00	0.4	12.7	2,175.1	0.2	1.4	1	1	1
11/02/2022 07:00	0.3	12.8	2,135.9	0.2	1.0	1	1	1
11/02/2022 08:00	0.4	13.1	2,040.3	0.3	1.4	1	1	1
11/02/2022 09:00	0.1	14.0	1,710.1	0.2	0.3	1	1	0
11/02/2022 10:00	0.1	14.0	1,543.3	0.2	0.3	1	1	0
11/02/2022 11:00	0.1	14.0	1,672.4	0.1	0.3	1	1	0
11/02/2022 12:00	0.1	14.0	1,549.7	0.1	0.3	1	1	0
11/02/2022 13:00	0.1	14.0	1,552.9	0.1	0.3	1	1	0
11/02/2022 14:00	0.2	14.0	1,535.2	0.1	0.6	1	1	0
11/02/2022 15:00	0.2	14.0	1,604.0	0.2	0.6	1	1	1
11/02/2022 16:00	0.4	12.8	2,092.6	0.2	1.4	1	1	1
11/02/2022 17:00	0.3	12.5	2,182.8	0.2	1.0	1	1	1
11/02/2022 18:00	0.3	12.5	2,177.3	0.2	1.0	1	1	1
11/02/2022 19:00	0.3	12.5	2,175.0	0.2	1.0	1	1	1
11/02/2022 20:00	0.3	12.6	2,175.1	0.2	1.0	1	1	1
11/02/2022 21:00	0.3	12.6	2,157.6	0.2	1.0	1	1	1
11/02/2022 22:00	0.3	12.6	2,164.2	0.2	1.0	1	1	1
11/02/2022 23:00	0.3	12.6	2,177.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.4	1,850.9	0.2	18.3 #	24 #	24 #	13 #
Minimum:	0.1	12.5	1,347.9	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,182.8	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	0.3	12.6	2,169.0	0.2	1.0	1	1	1
11/03/2022 01:00	0.3	12.7	2,153.0	0.2	1.0	1	1	1
11/03/2022 02:00	0.3	12.5	2,194.3	0.2	1.0	1	1	1
11/03/2022 03:00	0.2	12.3	2,234.1	0.2	0.7	1	1	1
11/03/2022 04:00	0.3	12.6	2,163.9	0.2	1.0	1	1	1
11/03/2022 05:00	0.3	12.6	2,166.0	0.2	1.0	1	1	1
11/03/2022 06:00	0.2	12.4	2,231.2	0.2	0.7	1	1	1
11/03/2022 07:00	0.3	12.8	2,110.9	0.2	1.0	1	1	1
11/03/2022 08:00	0.1	14.1	1,456.2	0.1	0.3	1	1	0
11/03/2022 09:00	0.1	14.0	1,559.4	0.1	0.3	1	1	0
11/03/2022 10:00	0.1	14.0	1,574.2	0.1	0.3	1	1	0
11/03/2022 11:00	0.1	14.0	1,570.2	0.1	0.3	1	1	0
11/03/2022 12:00	0.1	14.0	1,579.0	0.1	0.3	1	1	0
11/03/2022 13:00	0.1	14.1	1,487.4	0.1	0.3	1	1	0
11/03/2022 14:00	0.2	14.1	1,553.3	0.1	0.6	1	1	0
11/03/2022 15:00	0.2	14.0	1,771.8	0.2	0.7	1	1	1
11/03/2022 16:00	0.4	12.8	2,084.1	0.2	1.4	1	1	1
11/03/2022 17:00	0.3	12.5	2,162.5	0.2	1.0	1	1	1
11/03/2022 18:00	0.2	12.5	2,175.5	0.2	0.7	1	1	1
11/03/2022 19:00	0.2	12.5	2,174.2	0.1	0.7	1	1	1
11/03/2022 20:00	0.2	12.5	2,163.4	0.1	0.7	1	1	1
11/03/2022 21:00	0.2	12.5	2,161.9	0.1	0.7	1	1	1
11/03/2022 22:00	0.2	12.5	2,161.6	0.1	0.7	1	1	1
11/03/2022 23:00	0.2	12.4	2,201.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	13.0	1,969.1	0.2	17.1 #	24 #	24 #	17 #
Minimum:	0.1	12.3	1,456.2	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,234.1	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2022 00:00	0.3	12.7	2,139.4	0.1	1.0	1	1	1
11/04/2022 01:00	0.3	12.7	2,120.0	0.2	1.0	1	1	1
11/04/2022 02:00	0.3	12.9	2,069.1	0.2	1.0	1	1	1
11/04/2022 03:00	0.3	12.9	2,071.1	0.2	1.0	1	1	1
11/04/2022 04:00	0.3	12.7	2,149.6	0.2	1.0	1	1	1
11/04/2022 05:00	0.2	12.3	2,242.1	0.2	0.7	1	1	1
11/04/2022 06:00	0.3	12.6	2,177.1	0.2	1.0	1	1	1
11/04/2022 07:00	0.3	13.0	2,059.9	0.2	1.0	1	1	1
11/04/2022 08:00	0.1	14.0	1,718.3	0.2	0.3	1	1	1
11/04/2022 09:00	0.1	14.0	1,552.2	0.1	0.3	1	1	0
11/04/2022 10:00	0.1	14.1	1,390.6	0.1	0.3	1	1	0
11/04/2022 11:00	0.1	14.1	1,319.4	0.1	0.3	1	1	0
11/04/2022 12:00	0.1	14.1	1,316.8	0.1	0.3	1	1	0
11/04/2022 13:00	0.1	14.1	1,317.6	0.1	0.3	1	1	0
11/04/2022 14:00	0.2	14.1	1,398.3	0.1	0.5	1	1	0
11/04/2022 15:00	0.3	13.9	1,629.0	0.2	0.9	1	1	1
11/04/2022 16:00	0.4	12.7	2,105.1	0.3	1.4	1	1	1
11/04/2022 17:00	0.3	12.5	2,145.5	0.3	1.0	1	1	1
11/04/2022 18:00	0.3	12.8	2,089.4	0.2	1.0	1	1	1
11/04/2022 19:00	0.3	12.8	2,086.7	0.2	1.0	1	1	1
11/04/2022 20:00	0.3	12.8	2,076.1	0.2	1.0	1	1	1
11/04/2022 21:00	0.3	12.8	2,074.7	0.2	1.0	1	1	1
11/04/2022 22:00	0.3	12.8	2,082.6	0.2	1.0	1	1	1
11/04/2022 23:00	0.3	13.3	1,970.2	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.2	1,887.5	0.2	19.3 #	24 #	24 #	18 #
Minimum:	0.1	12.3	1,316.8	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,242.1	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2022 00:00	0.4	13.3	1,965.0	0.2	1.4	1	1	1
11/05/2022 01:00	0.3	13.3	1,965.4	0.2	1.0	1	1	1
11/05/2022 02:00	0.4	13.3	1,965.9	0.3	1.4	1	1	1
11/05/2022 03:00	0.4	13.3	1,965.1	0.3	1.4	1	1	1
11/05/2022 04:00	0.4	13.3	1,973.7	0.3	1.4	1	1	1
11/05/2022 05:00	0.4	13.3	1,978.5	0.3	1.4	1	1	1
11/05/2022 06:00	0.4	13.3	1,948.0	0.3	1.4	1	1	1
11/05/2022 07:00	15.9	15.9	568.2	0.0	5.5	1	0	0
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.3	13.6	1,791.2	0.3	14.9 #	8 #	7 #	7 #
Minimum:	0.3	13.3	568.2	0.2	1.0	0	0	0
Maximum:	15.9	15.9	1,978.5	0.3	5.5	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 09:00	92.3	18.2	259.0	0.0	40.9	1	0	0
11/06/2022 10:00	18.7	17.4	380.5	0.0	26.8	1	0	0
11/06/2022 11:00	34.4	15.7	828.7	0.0	72.4	1	0	0
11/06/2022 12:00	0.2	14.0	1,401.7	0.0	0.5	1	1	0
11/06/2022 13:00	0.2	14.0	1,533.1	0.0	0.6	1	1	0
11/06/2022 14:00	0.2	13.9	1,606.7	0.2	0.6	1	1	0
11/06/2022 15:00	0.4	12.9	1,957.5	0.2	1.3	1	1	1
11/06/2022 16:00	0.3	11.8	2,286.9	0.2	1.0	1	1	1
11/06/2022 17:00	0.2	11.7	2,303.5	0.2	0.7	1	1	1
11/06/2022 18:00	0.4	12.9	2,010.4	0.2	1.3	1	1	1
11/06/2022 19:00	0.5	13.2	1,964.3	0.3	1.7	1	1	1
11/06/2022 20:00	0.5	13.1	1,989.1	0.4	1.7	1	1	1
11/06/2022 21:00	4.4	13.3	1,677.6	0.0	12.4	1	0	1
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	11.7	14.0	1,553.8	0.2	161.9 #	13 #	9 #	7 #
Minimum:	0.2	11.7	259.0	0.2	0.5	0	0	0
Maximum:	92.3	18.2	2,303.5	0.4	72.4	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2022 00:00	14.2	18.1	314.8	0.0	9.5	1	0	0
11/07/2022 01:00	32.2	15.3	1,013.6	0.0	77.0	1	0	0
11/07/2022 02:00	0.2	14.0	1,566.8	0.0	0.6	1	1	0
11/07/2022 03:00	0.2	14.0	1,619.9	0.0	0.6	1	1	0
11/07/2022 04:00	0.2	14.0	1,676.5	0.2	0.6	1	1	0
11/07/2022 05:00	0.2	13.9	1,708.4	0.2	0.6	1	1	0
11/07/2022 06:00	0.4	12.9	2,008.4	0.2	1.3	1	1	1
11/07/2022 07:00	0.3	12.2	2,239.0	0.2	1.0	1	1	1
11/07/2022 08:00	0.4	13.2	1,992.4	0.3	1.4	1	1	1
11/07/2022 09:00	0.4	13.2	1,975.3	0.3	1.4	1	1	1
11/07/2022 10:00	0.4	13.2	1,964.7	0.3	1.3	1	1	1
11/07/2022 11:00	0.4	13.2	1,962.6	0.3	1.3	1	1	1
11/07/2022 12:00	0.4	13.2	1,963.8	0.3	1.3	1	1	1
11/07/2022 13:00	0.4	13.2	1,962.7	0.3	1.3	1	1	1
11/07/2022 14:00	0.4	12.8	2,060.4	0.3	1.3	1	1	1
11/07/2022 15:00	0.3	12.3	2,192.5	0.3	1.0	1	1	1
11/07/2022 16:00	0.2	12.0	2,250.1	0.2	0.7	1	1	1
11/07/2022 17:00	0.1	11.9	2,290.9	0.1	0.3	1	1	1
11/07/2022 18:00	0.1	11.9	2,297.0	0.1	0.3	1	1	1
11/07/2022 19:00	0.1	11.9	2,293.7	0.1	0.3	1	1	1
11/07/2022 20:00	0.1	11.9	2,289.5	0.1	0.3	1	1	1
11/07/2022 21:00	0.1	11.9	2,293.4	0.1	0.3	1	1	1
11/07/2022 22:00	0.2	12.1	2,257.7	0.1	0.7	1	1	1
11/07/2022 23:00	0.3	12.4	2,181.0	0.1	1.0	1	1	1
Average/Sum#:	2.2	13.1	1,932.3	0.2	105.4 #	24 #	22 #	18 #
Minimum:	0.1	11.9	314.8	0.1	0.3	1	0	0
Maximum:	32.2	18.1	2,297.0	0.3	77.0	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2022 00:00	0.3	12.4	2,172.6	0.2	1.0	1	1	1
11/08/2022 01:00	0.3	12.5	2,167.5	0.2	1.0	1	1	1
11/08/2022 02:00	0.3	12.6	2,112.2	0.2	1.0	1	1	1
11/08/2022 03:00	0.3	12.5	2,160.9	0.2	1.0	1	1	1
11/08/2022 04:00	0.2	12.3	2,200.1	0.2	0.7	1	1	1
11/08/2022 05:00	0.2	12.2	2,219.7	0.1	0.7	1	1	1
11/08/2022 06:00	0.1	11.8	2,300.5	0.1	0.3	1	1	1
11/08/2022 07:00	0.2	12.2	2,213.6	0.1	0.7	1	1	1
11/08/2022 08:00	0.2	12.2	2,202.3	0.1	0.7	1	1	1
11/08/2022 09:00	0.2	12.2	2,200.4	0.1	0.7	1	1	1
11/08/2022 10:00	0.2	12.3	2,185.6	0.1	0.7	1	1	1
11/08/2022 11:00	0.3	13.0	2,032.7	0.1	1.0	1	1	1
11/08/2022 12:00	0.4	13.2	1,987.2	0.2	1.4	1	1	1
11/08/2022 13:00	0.4	13.2	1,985.1	0.3	1.4	1	1	1
11/08/2022 14:00	0.4	12.9	2,056.2	0.3	1.4	1	1	1
11/08/2022 15:00	0.4	12.9	2,056.3	0.3	1.4	1	1	1
11/08/2022 16:00	0.3	12.3	2,217.1	0.3	1.0	1	1	1
11/08/2022 17:00	0.2	12.3	2,201.6	0.2	0.7	1	1	1
11/08/2022 18:00	0.3	12.4	2,173.9	0.2	1.0	1	1	1
11/08/2022 19:00	0.2	12.3	2,206.4	0.1	0.7	1	1	1
11/08/2022 20:00	0.2	12.3	2,206.2	0.1	0.7	1	1	1
11/08/2022 21:00	0.2	12.3	2,204.5	0.1	0.7	1	1	1
11/08/2022 22:00	0.2	12.3	2,190.4	0.1	0.7	1	1	1
11/08/2022 23:00	0.3	12.5	2,146.3	0.1	1.0	1	1	1
Average/Sum#:	0.3	12.5	2,158.3	0.2	21.6 #	24 #	24 #	24 #
Minimum:	0.1	11.8	1,985.1	0.1	0.3	1	1	1
Maximum:	0.4	13.2	2,300.5	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	0.3	12.5	2,155.3	0.2	1.0	1	1	1
11/09/2022 01:00	0.3	12.5	2,154.5	0.2	1.0	1	1	1
11/09/2022 02:00	0.2	12.4	2,194.0	0.2	0.7	1	1	1
11/09/2022 03:00	0.2	12.4	2,195.1	0.1	0.7	1	1	1
11/09/2022 04:00	0.3	12.5	2,162.1	0.1	1.0	1	1	1
11/09/2022 05:00	0.2	12.2	2,258.0	0.1	0.7	1	1	1
11/09/2022 06:00	0.2	12.0	2,298.8	0.1	0.7	1	1	1
11/09/2022 07:00	0.2	12.4	2,203.8	0.1	0.7	1	1	1
11/09/2022 08:00	0.2	12.5	2,162.6	0.1	0.7	1	1	1
11/09/2022 09:00	0.2	13.8	1,742.9	0.1	0.6	1	1	1
11/09/2022 10:00	0.1	13.9	1,701.0	0.1	0.3	1	1	0
11/09/2022 11:00	0.1	13.9	1,628.8	0.1	0.3	1	1	0
11/09/2022 12:00	0.1	13.9	1,704.5	0.1	0.3	1	1	0
11/09/2022 13:00	0.1	14.0	1,617.1	0.1	0.3	1	1	0
11/09/2022 14:00	0.1	13.9	1,688.5	0.1	0.3	1	1	0
11/09/2022 15:00	0.1	13.9	1,636.8	0.1	0.3	1	1	1
11/09/2022 16:00	0.4	12.8	2,083.4	0.2	1.4	1	1	1
11/09/2022 17:00	0.3	12.5	2,158.5	0.2	1.0	1	1	1
11/09/2022 18:00	0.3	13.1	2,013.7	0.2	1.0	1	1	1
11/09/2022 19:00	0.3	13.3	1,976.3	0.2	1.0	1	1	1
11/09/2022 20:00	0.3	13.3	1,979.9	0.2	1.0	1	1	1
11/09/2022 21:00	0.3	13.3	2,004.2	0.2	1.0	1	1	1
11/09/2022 22:00	0.3	13.3	1,996.1	0.2	1.0	1	1	1
11/09/2022 23:00	0.3	13.3	1,995.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.1	1,988.0	0.1	18.0 #	24 #	24 #	19 #
Minimum:	0.1	12.0	1,617.1	0.1	0.3	1	1	0
Maximum:	0.4	14.0	2,298.8	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2022 00:00	0.3	13.3	1,995.0	0.2	1.0	1	1	1
11/10/2022 01:00	0.3	13.3	1,993.3	0.2	1.0	1	1	1
11/10/2022 02:00	0.3	13.3	1,991.3	0.2	1.0	1	1	1
11/10/2022 03:00	0.3	13.3	1,994.2	0.2	1.0	1	1	1
11/10/2022 04:00	0.3	13.0	2,084.2	0.2	1.0	1	1	1
11/10/2022 05:00	0.3	12.6	2,176.6	0.2	1.0	1	1	1
11/10/2022 06:00	0.2	12.0	2,294.6	0.2	0.7	1	1	1
11/10/2022 07:00	0.3	12.8	2,120.5	0.2	1.0	1	1	1
11/10/2022 08:00	0.3	13.3	1,983.8	0.2	1.0	1	1	1
11/10/2022 09:00	0.3	13.3	1,965.9	0.2	1.0	1	1	1
11/10/2022 10:00	0.1	14.0	1,725.4	0.2	0.3	1	1	0
11/10/2022 11:00	0.1	14.0	1,712.5	0.1	0.3	1	1	0
11/10/2022 12:00	0.1	14.0	1,711.2	0.1	0.3	1	1	0
11/10/2022 13:00	0.1	14.0	1,562.8	0.1	0.3	1	1	0
11/10/2022 14:00	0.1	14.0	1,712.6	0.1	0.3	1	1	0
11/10/2022 15:00	0.2	13.9	1,716.1	0.1	0.6	1	1	1
11/10/2022 16:00	0.3	12.7	2,137.8	0.2	1.0	1	1	1
11/10/2022 17:00	0.1	12.2	2,271.9	0.2	0.3	1	1	1
11/10/2022 18:00	0.1	12.2	2,274.5	0.1	0.3	1	1	1
11/10/2022 19:00	0.1	12.2	2,277.9	0.1	0.3	1	1	1
11/10/2022 20:00	0.1	12.2	2,279.9	0.1	0.3	1	1	1
11/10/2022 21:00	0.1	12.2	2,281.1	0.1	0.3	1	1	1
11/10/2022 22:00	0.1	12.2	2,281.8	0.1	0.3	1	1	1
11/10/2022 23:00	0.1	12.3	2,260.5	0.1	0.3	1	1	1
Average/Sum#:	0.2	13.0	2,033.6	0.2	14.9 #	24 #	24 #	19 #
Minimum:	0.1	12.0	1,562.8	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,294.6	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2022 00:00	0.1	12.2	2,281.0	0.1	0.3	1	1	1
11/11/2022 01:00	0.1	12.2	2,270.4	0.1	0.3	1	1	1
11/11/2022 02:00	0.2	12.7	2,154.0	0.1	0.7	1	1	1
11/11/2022 03:00	0.2	12.7	2,151.7	0.1	0.7	1	1	1
11/11/2022 04:00	0.1	12.3	2,272.4	0.1	0.3	1	1	1
11/11/2022 05:00	0.1	12.2	2,285.8	0.1	0.3	1	1	1
11/11/2022 06:00	0.1	12.3	2,289.0	0.1	0.4	1	1	1
11/11/2022 07:00	0.2	12.9	2,119.2	0.1	0.7	1	1	1
11/11/2022 08:00	0.3	13.4	1,954.8	0.1	1.0	1	1	1
11/11/2022 09:00	0.1	14.0	1,708.7	0.1	0.3	1	1	0
11/11/2022 10:00	0.1	14.0	1,712.4	0.1	0.3	1	1	0
11/11/2022 11:00	0.1	14.0	1,684.1	0.1	0.3	1	1	0
11/11/2022 12:00	0.1	14.0	1,684.6	0.1	0.3	1	1	0
11/11/2022 13:00	0.2	14.0	1,694.9	0.1	0.6	1	1	0
11/11/2022 14:00	0.2	14.0	1,573.1	0.2	0.6	1	1	0
11/11/2022 15:00	0.2	14.0	1,687.2	0.2	0.6	1	1	0
11/11/2022 16:00	0.3	13.1	1,984.8	0.2	1.0	1	1	1
11/11/2022 17:00	0.1	12.1	2,268.3	0.2	0.3	1	1	1
11/11/2022 18:00	0.1	12.1	2,263.3	0.1	0.3	1	1	1
11/11/2022 19:00	0.1	12.2	2,260.6	0.1	0.3	1	1	1
11/11/2022 20:00	0.1	12.2	2,253.7	0.1	0.3	1	1	1
11/11/2022 21:00	0.1	12.2	2,252.9	0.1	0.3	1	1	1
11/11/2022 22:00	0.1	12.3	2,246.0	0.1	0.3	1	1	1
11/11/2022 23:00	0.1	12.2	2,259.7	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.9	2,054.7	0.1	10.8 #	24 #	24 #	17 #
Minimum:	0.1	12.1	1,573.1	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,289.0	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2022 00:00	0.1	12.3	2,267.0	0.1	0.3	1	1	1
11/12/2022 01:00	0.1	12.3	2,275.6	0.1	0.3	1	1	1
11/12/2022 02:00	0.1	12.2	2,278.8	0.1	0.3	1	1	1
11/12/2022 03:00	0.1	12.2	2,280.4	0.1	0.3	1	1	1
11/12/2022 04:00	0.1	12.2	2,285.0	0.1	0.3	1	1	1
11/12/2022 05:00	0.1	12.2	2,285.3	0.1	0.3	1	1	1
11/12/2022 06:00	0.1	12.2	2,276.7	0.1	0.3	1	1	1
11/12/2022 07:00	0.3	12.8	2,103.5	0.1	1.0	1	1	1
11/12/2022 08:00	0.2	12.3	2,210.7	0.1	0.7	1	1	1
11/12/2022 09:00	0.1	13.8	1,747.7	0.1	0.3	1	1	1
11/12/2022 10:00	0.1	14.0	1,589.6	0.1	0.3	1	1	0
11/12/2022 11:00	0.1	14.0	1,554.3	0.1	0.3	1	1	0
11/12/2022 12:00	0.1	14.0	1,551.1	0.1	0.3	1	1	0
11/12/2022 13:00	0.1	14.0	1,570.2	0.1	0.3	1	1	0
11/12/2022 14:00	0.1	14.0	1,549.0	0.1	0.3	1	1	0
11/12/2022 15:00	0.2	13.9	1,791.5	0.1	0.7	1	1	1
11/12/2022 16:00	0.3	12.7	2,126.7	0.2	1.0	1	1	1
11/12/2022 17:00	0.1	12.2	2,245.9	0.2	0.3	1	1	1
11/12/2022 18:00	0.1	12.2	2,246.8	0.1	0.3	1	1	1
11/12/2022 19:00	0.1	12.2	2,251.2	0.1	0.3	1	1	1
11/12/2022 20:00	0.1	12.2	2,260.4	0.1	0.3	1	1	1
11/12/2022 21:00	0.1	12.2	2,259.8	0.1	0.3	1	1	1
11/12/2022 22:00	0.1	12.5	2,193.5	0.1	0.3	1	1	1
11/12/2022 23:00	0.1	12.5	2,190.6	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.8	2,058.0	0.1	9.4 #	24 #	24 #	19 #
Minimum:	0.1	12.2	1,549.0	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,285.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2022 00:00	0.2	12.6	2,180.8	0.1	0.7	1	1	1
11/13/2022 01:00	0.2	12.6	2,170.0	0.1	0.7	1	1	1
11/13/2022 02:00	0.2	12.7	2,165.0	0.1	0.7	1	1	1
11/13/2022 03:00	0.1	12.5	2,194.5	0.1	0.3	1	1	1
11/13/2022 04:00	0.1	12.6	2,189.7	0.1	0.3	1	1	1
11/13/2022 05:00	0.2	12.6	2,184.1	0.1	0.7	1	1	1
11/13/2022 06:00	0.1	12.5	2,195.0	0.1	0.3	1	1	1
11/13/2022 07:00	0.1	12.4	2,240.2	0.1	0.3	1	1	1
11/13/2022 08:00	0.1	13.1	1,966.4	0.1	0.3	1	1	1
11/13/2022 09:00	0.1	14.0	1,706.5	0.1	0.3	1	1	0
11/13/2022 10:00	0.1	14.0	1,707.9	0.1	0.3	1	1	0
11/13/2022 11:00	0.1	14.0	1,707.9	0.1	0.3	1	1	0
11/13/2022 12:00	0.1	14.0	1,706.8	0.1	0.3	1	1	0
11/13/2022 13:00	0.2	14.0	1,709.5	0.1	0.7	1	1	0
11/13/2022 14:00	0.2	14.0	1,677.7	0.2	0.6	1	1	0
11/13/2022 15:00	0.2	13.9	1,782.8	0.2	0.7	1	1	1
11/13/2022 16:00	0.3	12.5	2,138.8	0.2	1.0	1	1	1
11/13/2022 17:00	0.1	11.9	2,280.1	0.2	0.3	1	1	1
11/13/2022 18:00	0.1	11.9	2,280.5	0.1	0.3	1	1	1
11/13/2022 19:00	0.1	11.9	2,284.4	0.1	0.3	1	1	1
11/13/2022 20:00	0.1	11.9	2,288.2	0.1	0.3	1	1	1
11/13/2022 21:00	0.1	11.9	2,292.8	0.1	0.3	1	1	1
11/13/2022 22:00	0.1	11.9	2,295.1	0.1	0.3	1	1	1
11/13/2022 23:00	0.1	11.9	2,299.3	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.8	2,068.5	0.1	10.6 #	24 #	24 #	18 #
Minimum:	0.1	11.9	1,677.7	0.1	0.3	1	1	0
Maximum:	0.3	14.0	2,299.3	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2022 00:00	0.1	11.9	2,298.5	0.1	0.3	1	1	1
11/14/2022 01:00	0.1	12.0	2,289.5	0.1	0.3	1	1	1
11/14/2022 02:00	0.2	12.1	2,286.2	0.1	0.7	1	1	1
11/14/2022 03:00	0.3	12.6	2,166.7	0.1	1.0	1	1	1
11/14/2022 04:00	0.2	12.3	2,241.5	0.1	0.7	1	1	1
11/14/2022 05:00	0.2	12.0	2,303.2	0.1	0.7	1	1	1
11/14/2022 06:00	0.2	12.1	2,299.4	0.1	0.7	1	1	1
11/14/2022 07:00	0.3	12.5	2,194.7	0.1	1.0	1	1	1
11/14/2022 08:00	0.3	12.7	2,159.1	0.2	1.0	1	1	1
11/14/2022 09:00	0.3	12.6	2,167.7	0.2	1.0	1	1	1
11/14/2022 10:00	0.3	12.6	2,158.5	0.2	1.0	1	1	1
11/14/2022 11:00	0.3	12.6	2,130.2	0.2	1.0	1	1	1
11/14/2022 12:00	0.3	12.6	2,126.0	0.2	1.0	1	1	1
11/14/2022 13:00	0.2	12.5	2,154.3	0.2	0.7	1	1	1
11/14/2022 14:00	0.2	12.4	2,150.3	0.1	0.7	1	1	1
11/14/2022 15:00	0.3	12.8	2,079.7	0.1	1.0	1	1	1
11/14/2022 16:00	0.2	12.0	2,254.0	0.1	0.7	1	1	1
11/14/2022 17:00	0.2	12.3	2,198.1	0.1	0.7	1	1	1
11/14/2022 18:00	0.2	12.4	2,182.1	0.1	0.7	1	1	1
11/14/2022 19:00	0.2	12.1	2,240.9	0.1	0.7	1	1	1
11/14/2022 20:00	0.2	12.1	2,243.9	0.1	0.7	1	1	1
11/14/2022 21:00	0.1	12.0	2,288.0	0.1	0.3	1	1	1
11/14/2022 22:00	0.1	12.0	2,288.7	0.1	0.3	1	1	1
11/14/2022 23:00	0.1	12.1	2,271.0	0.1	0.3	1	1	1
Average/Sum#:	0.2	12.3	2,215.5	0.1	17.2 #	24 #	24 #	24 #
Minimum:	0.1	11.9	2,079.7	0.1	0.3	1	1	1
Maximum:	0.3	12.8	2,303.2	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2022 00:00	0.1	12.0	2,301.3	0.1	0.3	1	1	1
11/15/2022 01:00	0.1	11.9	2,300.4	0.1	0.3	1	1	1
11/15/2022 02:00	0.1	12.0	2,290.8	0.1	0.3	1	1	1
11/15/2022 03:00	0.1	12.0	2,281.4	0.1	0.3	1	1	1
11/15/2022 04:00	0.1	12.1	2,264.5	0.1	0.3	1	1	1
11/15/2022 05:00	0.2	12.2	2,243.0	0.1	0.7	1	1	1
11/15/2022 06:00	0.2	12.3	2,213.0	0.1	0.7	1	1	1
11/15/2022 07:00	0.2	12.4	2,183.3	0.1	0.7	1	1	1
11/15/2022 08:00	0.2	12.6	2,133.4	0.1	0.7	1	1	1
11/15/2022 09:00	0.2	12.7	2,108.5	0.1	0.7	1	1	1
11/15/2022 10:00	0.3	12.6	2,141.8	0.1	1.0	1	1	1
11/15/2022 11:00	0.3	12.9	2,056.8	0.2	1.0	1	1	1
11/15/2022 12:00	0.4	13.3	1,977.9	0.2	1.4	1	1	1
11/15/2022 13:00	0.4	13.3	1,979.2	0.3	1.4	1	1	1
11/15/2022 14:00	0.4	13.3	1,979.2	0.3	1.4	1	1	1
11/15/2022 15:00	0.4	13.1	2,018.4	0.3	1.4	1	1	1
11/15/2022 16:00	0.3	12.6	2,149.3	0.3	1.0	1	1	1
11/15/2022 17:00	0.3	12.5	2,177.7	0.2	1.0	1	1	1
11/15/2022 18:00	0.3	12.4	2,193.7	0.2	1.0	1	1	1
11/15/2022 19:00	0.2	12.4	2,188.4	0.2	0.7	1	1	1
11/15/2022 20:00	0.2	12.3	2,196.2	0.1	0.7	1	1	1
11/15/2022 21:00	0.1	12.1	2,244.0	0.1	0.3	1	1	1
11/15/2022 22:00	0.2	12.4	2,174.7	0.1	0.7	1	1	1
11/15/2022 23:00	0.2	12.5	2,174.2	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,165.5	0.2	18.7 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,977.9	0.1	0.3	1	1	1
Maximum:	0.4	13.3	2,301.3	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	0.2	12.5	2,168.0	0.1	0.7	1	1	1
11/16/2022 01:00	0.2	12.6	2,140.8	0.1	0.7	1	1	1
11/16/2022 02:00	0.2	12.5	2,165.7	0.1	0.7	1	1	1
11/16/2022 03:00	0.2	12.5	2,167.5	0.1	0.7	1	1	1
11/16/2022 04:00	0.2	12.4	2,178.7	0.1	0.7	1	1	1
11/16/2022 05:00	0.2	12.5	2,174.9	0.1	0.7	1	1	1
11/16/2022 06:00	0.2	12.5	2,168.0	0.1	0.7	1	1	1
11/16/2022 07:00	0.1	12.2	2,241.0	0.1	0.3	1	1	1
11/16/2022 08:00	0.3	13.2	1,987.0	0.1	1.0	1	1	1
11/16/2022 09:00	0.3	13.2	2,018.8	0.2	1.0	1	1	1
11/16/2022 10:00	0.4	13.3	1,985.3	0.2	1.4	1	1	1
11/16/2022 11:00	0.0	0.0	1,986.8	0.0	0.0	1	1	1
11/16/2022 12:00	0.0	13.2	1,985.9	0.0	0.0	1	1	1
11/16/2022 13:00	0.0	13.2	1,986.9	0.0	0.0	1	1	1
11/16/2022 14:00	0.0	13.2	1,985.4	0.0	0.0	1	1	1
11/16/2022 15:00	0.0	12.6	2,113.3	0.0	0.0	1	1	1
11/16/2022 16:00	0.0	12.3	2,177.2	0.0	0.0	1	1	1
11/16/2022 17:00	0.0	12.3	2,192.8	0.0	0.0	1	1	1
11/16/2022 18:00	0.0	11.9	2,278.4	0.0	0.0	1	1	1
11/16/2022 19:00	0.0	11.9	2,286.5	0.0	0.0	1	1	1
11/16/2022 20:00	0.0	11.9	2,286.7	0.0	0.0	1	1	1
11/16/2022 21:00	0.0	12.0	2,266.9	0.0	0.0	1	1	1
11/16/2022 22:00	0.0	12.2	2,230.9	0.0	0.0	1	1	1
11/16/2022 23:00	0.0	12.0	2,257.4	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.5	2,143.0	0.1	8.6 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,985.3	0.0	0.0	1	1	1
Maximum:	0.4	13.3	2,286.7	0.2	1.4	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2022 00:00	0.0	12.4	2,177.8	0.0	0.0	1	1	1
11/17/2022 01:00	0.0	12.3	2,181.0	0.0	0.0	1	1	1
11/17/2022 02:00	0.0	12.4	2,165.8	0.0	0.0	1	1	1
11/17/2022 03:00	0.0	12.5	2,166.0	0.0	0.0	1	1	1
11/17/2022 04:00	0.0	12.5	2,169.1	0.0	0.0	1	1	1
11/17/2022 05:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
11/17/2022 06:00	0.0	11.9	2,291.5	0.0	0.0	1	1	1
11/17/2022 07:00	0.0	12.4	2,182.1	0.0	0.0	1	1	1
11/17/2022 08:00	0.0	13.1	1,994.1	0.0	0.0	1	1	1
11/17/2022 09:00	0.0	12.5	2,150.8	0.0	0.0	1	1	1
11/17/2022 10:00	0.0	12.5	2,143.2	0.0	0.0	1	1	1
11/17/2022 11:00	0.0	12.3	2,174.6	0.0	0.0	1	1	1
11/17/2022 12:00	0.0	12.1	2,198.3	0.0	0.0	1	1	1
11/17/2022 13:00	0.0	12.2	2,183.9	0.0	0.0	1	1	1
11/17/2022 14:00	0.0	12.9	2,015.7	0.0	0.0	1	1	1
11/17/2022 15:00	0.0	12.4	2,130.6	0.0	0.0	1	1	1
11/17/2022 16:00	0.0	11.9	2,243.2	0.0	0.0	1	1	1
11/17/2022 17:00	0.0	11.8	2,276.9	0.0	0.0	1	1	1
11/17/2022 18:00	0.0	11.8	2,275.4	0.0	0.0	1	1	1
11/17/2022 19:00	0.0	11.8	2,278.6	0.0	0.0	1	1	1
11/17/2022 20:00	0.0	11.8	2,280.8	0.0	0.0	1	1	1
11/17/2022 21:00	0.0	11.8	2,282.5	0.0	0.0	1	1	1
11/17/2022 22:00	0.0	11.9	2,269.7	0.0	0.0	1	1	1
11/17/2022 23:00	0.0	12.2	2,226.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,193.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,994.1	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,291.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2022 00:00	0.0	12.4	2,177.7	0.0	0.0	1	1	1
11/18/2022 01:00	0.0	12.3	2,188.2	0.0	0.0	1	1	1
11/18/2022 02:00	0.0	12.2	2,194.3	0.0	0.0	1	1	1
11/18/2022 03:00	0.0	12.3	2,188.5	0.0	0.0	1	1	1
11/18/2022 04:00	0.0	12.2	2,185.6	0.0	0.0	1	1	1
11/18/2022 05:00	0.0	12.3	2,173.7	0.0	0.0	1	1	1
11/18/2022 06:00	0.0	12.4	2,160.2	0.0	0.0	1	1	1
11/18/2022 07:00	0.0	12.0	2,255.3	0.0	0.0	1	1	1
11/18/2022 08:00	0.0	12.3	2,177.7	0.0	0.0	1	1	1
11/18/2022 09:00	0.0	12.3	2,185.0	0.0	0.0	1	1	1
11/18/2022 10:00	0.0	12.2	2,190.4	0.0	0.0	1	1	1
11/18/2022 11:00	0.0	12.5	2,120.3	0.0	0.0	1	1	1
11/18/2022 12:00	0.0	13.1	1,970.2	0.0	0.0	1	1	1
11/18/2022 13:00	0.0	13.1	1,973.1	0.0	0.0	1	1	1
11/18/2022 14:00	0.0	13.1	1,974.5	0.0	0.0	1	1	1
11/18/2022 15:00	0.0	12.8	2,058.5	0.0	0.0	1	1	1
11/18/2022 16:00	0.0	12.0	2,235.0	0.0	0.0	1	1	1
11/18/2022 17:00	0.0	11.9	2,257.9	0.0	0.0	1	1	1
11/18/2022 18:00	0.0	12.0	2,260.4	0.0	0.0	1	1	1
11/18/2022 19:00	0.0	12.0	2,263.4	0.0	0.0	1	1	1
11/18/2022 20:00	0.0	12.1	2,228.1	0.0	0.0	1	1	1
11/18/2022 21:00	0.0	12.3	2,181.4	0.0	0.0	1	1	1
11/18/2022 22:00	0.0	12.5	2,145.0	0.0	0.0	1	1	1
11/18/2022 23:00	0.0	12.1	2,239.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,166.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.2	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,263.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2022 00:00	0.0	12.3	2,194.0	0.0	0.0	1	1	1
11/19/2022 01:00	0.0	12.4	2,172.4	0.0	0.0	1	1	1
11/19/2022 02:00	0.0	12.5	2,168.7	0.0	0.0	1	1	1
11/19/2022 03:00	0.0	12.6	2,144.8	0.0	0.0	1	1	1
11/19/2022 04:00	0.0	12.2	2,238.2	0.0	0.0	1	1	1
11/19/2022 05:00	0.0	12.1	2,271.6	0.0	0.0	1	1	1
11/19/2022 06:00	0.0	12.3	2,218.2	0.0	0.0	1	1	1
11/19/2022 07:00	0.0	12.6	2,132.0	0.0	0.0	1	1	1
11/19/2022 08:00	0.0	13.2	1,978.8	0.0	0.0	1	1	1
11/19/2022 09:00	0.0	13.2	1,978.8	0.0	0.0	1	1	1
11/19/2022 10:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
11/19/2022 11:00	0.0	13.2	1,970.6	0.0	0.0	1	1	1
11/19/2022 12:00	0.0	13.1	1,971.0	0.0	0.0	1	1	1
11/19/2022 13:00	0.0	13.1	1,971.9	0.0	0.0	1	1	1
11/19/2022 14:00	0.0	13.1	1,970.2	0.0	0.0	1	1	1
11/19/2022 15:00	0.0	12.8	2,050.9	0.0	0.0	1	1	1
11/19/2022 16:00	0.0	12.2	2,184.1	0.0	0.0	1	1	1
11/19/2022 17:00	0.0	12.1	2,201.8	0.0	0.0	1	1	1
11/19/2022 18:00	0.0	12.2	2,197.4	0.0	0.0	1	1	1
11/19/2022 19:00	0.0	11.9	2,260.7	0.0	0.0	1	1	1
11/19/2022 20:00	0.0	12.1	2,219.4	0.0	0.0	1	1	1
11/19/2022 21:00	0.0	12.3	2,177.5	0.0	0.0	1	1	1
11/19/2022 22:00	0.0	12.5	2,175.6	0.0	0.0	1	1	1
11/19/2022 23:00	0.0	12.6	2,143.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,123.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.2	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,271.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2022 00:00	0.0	12.7	2,106.9	0.0	0.0	1	1	1
11/20/2022 01:00	0.0	12.8	2,078.9	0.0	0.0	1	1	1
11/20/2022 02:00	0.0	12.9	2,062.3	0.0	0.0	1	1	1
11/20/2022 03:00	0.0	12.9	2,063.5	0.0	0.0	1	1	1
11/20/2022 04:00	0.0	12.9	2,070.5	0.0	0.0	1	1	1
11/20/2022 05:00	0.0	12.5	2,183.5	0.0	0.0	1	1	1
11/20/2022 06:00	0.0	12.1	2,276.9	0.0	0.0	1	1	1
11/20/2022 07:00	0.0	12.6	2,113.0	0.0	0.0	1	1	1
11/20/2022 08:00	0.0	13.9	1,703.8	0.0	0.0	1	1	0
11/20/2022 09:00	0.0	13.9	1,708.6	0.0	0.0	1	1	0
11/20/2022 10:00	0.0	13.9	1,565.5	0.0	0.0	1	1	0
11/20/2022 11:00	0.0	13.9	1,563.6	0.0	0.0	1	1	0
11/20/2022 12:00	0.0	14.0	1,533.4	0.0	0.0	1	1	0
11/20/2022 13:00	0.0	14.0	1,523.9	0.0	0.0	1	1	0
11/20/2022 14:00	0.0	13.8	1,701.2	0.0	0.0	1	1	1
11/20/2022 15:00	0.0	13.8	1,723.3	0.0	0.0	1	1	1
11/20/2022 16:00	0.0	12.4	2,162.3	0.0	0.0	1	1	1
11/20/2022 17:00	0.0	11.9	2,276.4	0.0	0.0	1	1	1
11/20/2022 18:00	0.0	11.9	2,265.8	0.0	0.0	1	1	1
11/20/2022 19:00	0.0	11.9	2,256.8	0.0	0.0	1	1	1
11/20/2022 20:00	0.0	11.9	2,261.0	0.0	0.0	1	1	1
11/20/2022 21:00	0.0	12.2	2,204.5	0.0	0.0	1	1	1
11/20/2022 22:00	0.0	12.4	2,168.3	0.0	0.0	1	1	1
11/20/2022 23:00	0.0	12.5	2,153.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,988.6	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,523.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,276.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2022 00:00	0.0	12.5	2,160.3	0.0	0.0	1	1	1
11/21/2022 01:00	0.0	12.6	2,137.5	0.0	0.0	1	1	1
11/21/2022 02:00	0.0	12.9	2,062.0	0.0	0.0	1	1	1
11/21/2022 03:00	0.0	12.4	2,174.4	0.0	0.0	1	1	1
11/21/2022 04:00	0.0	12.1	2,256.2	0.0	0.0	1	1	1
11/21/2022 05:00	0.0	12.1	2,267.1	0.0	0.0	1	1	1
11/21/2022 06:00	0.0	12.0	2,284.1	0.0	0.0	1	1	1
11/21/2022 07:00	0.0	12.5	2,150.4	0.0	0.0	1	1	1
11/21/2022 08:00	0.0	13.3	1,968.4	0.0	0.0	1	1	1
11/21/2022 09:00	0.0	13.3	1,968.7	0.0	0.0	1	1	1
11/21/2022 10:00	0.0	13.2	1,969.1	0.0	0.0	1	1	1
11/21/2022 11:00	0.0	13.2	1,979.0	0.0	0.0	1	1	1
11/21/2022 12:00	0.0	13.1	1,980.5	0.0	0.0	1	1	1
11/21/2022 13:00	0.0	13.1	1,980.3	0.0	0.0	1	1	1
11/21/2022 14:00	0.0	12.3	2,160.9	0.0	0.0	1	1	1
11/21/2022 15:00	0.0	11.9	2,251.4	0.0	0.0	1	1	1
11/21/2022 16:00	0.0	12.1	2,226.7	0.0	0.0	1	1	1
11/21/2022 17:00	0.0	11.9	2,273.3	0.0	0.0	1	1	1
11/21/2022 18:00	0.0	12.0	2,283.4	0.0	0.0	1	1	1
11/21/2022 19:00	0.0	11.9	2,265.1	0.0	0.0	1	1	1
11/21/2022 20:00	0.0	11.9	2,265.4	0.0	0.0	1	1	1
11/21/2022 21:00	0.0	11.9	2,267.8	0.0	0.0	1	1	1
11/21/2022 22:00	0.0	11.9	2,264.5	0.0	0.0	1	1	1
11/21/2022 23:00	0.0	12.1	2,228.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,159.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,968.4	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,284.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2022 00:00	0.0	12.4	2,154.9	0.0	0.0	1	1	1
11/22/2022 01:00	0.0	12.6	2,130.2	0.0	0.0	1	1	1
11/22/2022 02:00	0.0	12.7	2,101.3	0.0	0.0	1	1	1
11/22/2022 03:00	0.0	13.1	1,980.1	0.0	0.0	1	1	1
11/22/2022 04:00	0.0	13.2	1,985.4	0.0	0.0	1	1	1
11/22/2022 05:00	0.0	12.8	2,071.1	0.0	0.0	1	1	1
11/22/2022 06:00	0.0	12.5	2,156.2	0.0	0.0	1	1	1
11/22/2022 07:00	0.0	12.8	2,097.2	0.0	0.0	1	1	1
11/22/2022 08:00	0.0	12.9	2,055.9	0.0	0.0	1	1	1
11/22/2022 09:00	0.0	13.8	1,648.0	0.0	0.0	1	1	1
11/22/2022 10:00	0.0	13.8	1,674.5	0.0	0.0	1	1	0
11/22/2022 11:00	0.0	13.9	1,795.0	0.0	0.0	1	1	0
11/22/2022 12:00	0.0	13.9	1,556.4	0.0	0.0	1	1	0
11/22/2022 13:00	0.0	13.9	1,617.1	0.0	0.0	1	1	0
11/22/2022 14:00	0.0	13.8	1,779.5	0.0	0.0	1	1	0
11/22/2022 15:00	0.0	13.8	1,781.6	0.0	0.0	1	1	0
11/22/2022 16:00	0.0	13.2	1,919.5	0.0	0.0	1	1	1
11/22/2022 17:00	0.0	12.3	2,191.5	0.0	0.0	1	1	1
11/22/2022 18:00	0.0	12.8	2,055.9	0.0	0.0	1	1	1
11/22/2022 19:00	0.0	13.1	1,999.0	0.0	0.0	1	1	1
11/22/2022 20:00	0.0	12.5	2,155.9	0.0	0.0	1	1	1
11/22/2022 21:00	0.0	12.9	2,034.0	0.0	0.0	1	1	1
11/22/2022 22:00	0.0	12.9	2,045.3	0.0	0.0	1	1	1
11/22/2022 23:00	0.0	13.2	1,973.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,956.6	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.3	1,556.4	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,191.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2022 00:00	0.0	13.2	1,974.3	0.0	0.0	1	1	1
11/23/2022 01:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
11/23/2022 02:00	0.0	13.2	1,973.8	0.0	0.0	1	1	1
11/23/2022 03:00	0.0	13.2	1,976.4	0.0	0.0	1	1	1
11/23/2022 04:00	0.0	13.2	1,982.4	0.0	0.0	1	1	1
11/23/2022 05:00	0.0	12.7	2,074.5	0.0	0.0	1	1	1
11/23/2022 06:00	0.0	12.7	2,056.8	0.0	0.0	1	1	1
11/23/2022 07:00	0.0	12.7	2,111.0	0.0	0.0	1	1	1
11/23/2022 08:00	0.0	13.0	2,004.8	0.0	0.0	1	1	1
11/23/2022 09:00	0.0	13.9	1,703.0	0.0	0.0	1	1	0
11/23/2022 10:00	0.0	13.9	1,554.3	0.0	0.0	1	1	0
11/23/2022 11:00	0.0	13.9	1,550.6	0.0	0.0	1	1	0
11/23/2022 12:00	0.0	14.0	1,422.8	0.0	0.0	1	1	0
11/23/2022 13:00	0.0	14.0	1,559.1	0.0	0.0	1	1	0
11/23/2022 14:00	0.0	14.0	1,630.2	0.0	0.0	1	1	0
11/23/2022 15:00	0.0	13.9	1,636.5	0.0	0.0	1	1	1
11/23/2022 16:00	0.1	12.6	2,110.6	0.0	0.3	1	1	1
11/23/2022 17:00	0.0	12.3	2,185.3	0.0	0.0	1	1	1
11/23/2022 18:00	0.0	12.7	2,100.4	0.0	0.0	1	1	1
11/23/2022 19:00	0.1	12.9	2,063.5	0.0	0.3	1	1	1
11/23/2022 20:00	0.0	12.3	2,182.9	0.0	0.0	1	1	1
11/23/2022 21:00	0.0	12.3	2,201.9	0.0	0.0	1	1	1
11/23/2022 22:00	0.0	12.4	2,176.3	0.0	0.0	1	1	1
11/23/2022 23:00	0.0	12.4	2,171.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,932.4	0.0	0.6 #	24 #	24 #	18 #
Minimum:	0.0	12.3	1,422.8	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,201.9	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2022 00:00	0.1	13.1	1,990.6	0.0	0.3	1	1	1
11/24/2022 01:00	0.2	13.2	1,976.9	0.1	0.7	1	1	1
11/24/2022 02:00	0.2	13.2	1,976.7	0.2	0.7	1	1	1
11/24/2022 03:00	0.0	13.1	2,019.5	0.1	0.0	1	1	1
11/24/2022 04:00	0.1	13.0	2,026.8	0.1	0.3	1	1	1
11/24/2022 05:00	0.0	12.8	2,102.0	0.0	0.0	1	1	1
11/24/2022 06:00	0.0	12.2	2,191.0	0.0	0.0	1	1	1
11/24/2022 07:00	0.0	12.5	2,097.3	0.0	0.0	1	1	1
11/24/2022 08:00	0.0	13.9	1,712.8	0.0	0.0	1	1	0
11/24/2022 09:00	0.0	13.9	1,696.5	0.0	0.0	1	1	0
11/24/2022 10:00	0.0	13.9	1,703.7	0.0	0.0	1	1	0
11/24/2022 11:00	0.0	14.0	1,549.0	0.0	0.0	1	1	0
11/24/2022 12:00	0.0	14.0	1,349.8	0.0	0.0	1	1	0
11/24/2022 13:00	0.0	14.0	1,345.2	0.0	0.0	1	1	0
11/24/2022 14:00	0.0	14.0	1,551.3	0.0	0.0	1	1	0
11/24/2022 15:00	0.0	14.0	1,440.8	0.0	0.0	1	1	0
11/24/2022 16:00	0.0	13.9	1,756.8	0.0	0.0	1	1	0
11/24/2022 17:00	0.0	13.9	1,755.3	0.0	0.0	1	1	0
11/24/2022 18:00	0.0	13.9	1,738.1	0.0	0.0	1	1	0
11/24/2022 19:00	0.0	13.9	1,735.7	0.0	0.0	1	1	0
11/24/2022 20:00	0.0	13.9	1,736.2	0.0	0.0	1	1	0
11/24/2022 21:00	0.0	13.9	1,739.4	0.0	0.0	1	1	0
11/24/2022 22:00	0.0	13.9	1,742.8	0.0	0.0	1	1	0
11/24/2022 23:00	0.0	13.9	1,744.5	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.6	1,778.3	0.0	2.0 #	24 #	24 #	8 #
Minimum:	0.0	12.2	1,345.2	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,191.0	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2022 00:00	0.0	13.9	1,746.5	0.0	0.0	1	1	0
11/25/2022 01:00	0.0	13.9	1,746.8	0.0	0.0	1	1	0
11/25/2022 02:00	0.0	13.9	1,749.6	0.0	0.0	1	1	0
11/25/2022 03:00	0.0	13.9	1,753.4	0.0	0.0	1	1	0
11/25/2022 04:00	0.0	13.9	1,763.9	0.0	0.0	1	1	0
11/25/2022 05:00	0.0	13.9	1,761.2	0.0	0.0	1	1	0
11/25/2022 06:00	0.0	13.9	1,755.3	0.0	0.0	1	1	0
11/25/2022 07:00	0.0	13.9	1,755.9	0.0	0.0	1	1	0
11/25/2022 08:00	0.0	13.5	1,878.1	0.0	0.0	1	1	1
11/25/2022 09:00	0.0	13.2	1,927.0	0.0	0.0	1	1	1
11/25/2022 10:00	0.0	13.9	1,661.2	0.0	0.0	1	1	0
11/25/2022 11:00	0.0	13.9	1,538.8	0.0	0.0	1	1	0
11/25/2022 12:00	0.0	13.9	1,565.4	0.0	0.0	1	1	0
11/25/2022 13:00	0.0	13.9	1,534.3	0.0	0.0	1	1	0
11/25/2022 14:00	0.0	13.9	1,521.7	0.0	0.0	1	1	0
11/25/2022 15:00	0.0	13.8	1,630.3	0.0	0.0	1	1	1
11/25/2022 16:00	0.1	12.6	2,098.5	0.0	0.3	1	1	1
11/25/2022 17:00	0.0	12.5	2,115.1	0.0	0.0	1	1	1
11/25/2022 18:00	0.0	13.1	1,976.4	0.0	0.0	1	1	1
11/25/2022 19:00	0.0	13.2	1,966.1	0.0	0.0	1	1	1
11/25/2022 20:00	0.0	13.2	1,974.0	0.0	0.0	1	1	1
11/25/2022 21:00	0.0	13.2	1,977.2	0.0	0.0	1	1	1
11/25/2022 22:00	0.0	12.6	2,131.7	0.0	0.0	1	1	1
11/25/2022 23:00	0.0	12.7	2,091.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,817.5	0.0	0.3 #	24 #	24 #	11 #
Minimum:	0.0	12.5	1,521.7	0.0	0.0	1	1	0
Maximum:	0.1	13.9	2,131.7	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2022 00:00	0.0	13.0	2,033.3	0.0	0.0	1	1	1
11/26/2022 01:00	0.0	12.8	2,080.1	0.0	0.0	1	1	1
11/26/2022 02:00	3.3	13.9	1,574.8	0.0	9.8	1	0	1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.1	13.2	1,896.1	0.0	9.8 #	3 #	2 #	3 #
Minimum:	0.0	12.8	1,574.8	0.0	0.0	0	0	0
Maximum:	3.3	13.9	2,080.1	0.0	9.8	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2022 21:00	59.2	17.7	330.2	0.0	56.5	1	0	0
11/27/2022 22:00	14.4	17.3	396.9	0.0	21.0	1	0	0
11/27/2022 23:00	30.9	15.5	901.6	0.0	68.1	1	0	0
Average/Sum#:	34.8	16.8	542.9	0.0	145.6 #	3 #	0 #	0 #
Minimum:	14.4	15.5	330.2	0.0	21.0	0	0	0
Maximum:	59.2	17.7	901.6	0.0	68.1	1	0	0
%SI	87.50	87.50	87.50	100.00	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	0.0	13.9	1,574.9	0.0	0.0	1	1	0
11/28/2022 01:00	0.0	13.9	1,487.8	0.0	0.0	1	1	0
11/28/2022 02:00	0.0	13.8	1,745.5	0.0	0.0	1	1	0
11/28/2022 03:00	0.0	13.9	1,530.8	0.0	0.0	1	1	0
11/28/2022 04:00	0.0	13.9	1,710.5	0.0	0.0	1	1	0
11/28/2022 05:00	0.0	13.8	1,642.2	0.0	0.0	1	1	1
11/28/2022 06:00	0.0	12.3	2,173.2	0.0	0.0	1	1	1
11/28/2022 07:00	0.0	12.0	2,270.2	0.0	0.0	1	1	1
11/28/2022 08:00	0.0	13.1	1,972.1	0.0	0.0	1	1	1
11/28/2022 09:00	0.0	13.9	1,601.7	0.0	0.0	1	1	0
11/28/2022 10:00	0.0	13.9	1,699.0	0.0	0.0	1	1	0
11/28/2022 11:00	0.0	13.9	1,519.7	0.0	0.0	1	1	0
11/28/2022 12:00	0.0	13.9	1,566.4	0.0	0.0	1	1	0
11/28/2022 13:00	0.0	13.9	1,634.0	0.0	0.0	1	1	0
11/28/2022 14:00	0.0	13.9	1,616.9	0.0	0.0	1	1	0
11/28/2022 15:00	0.0	13.8	1,620.0	0.0	0.0	1	1	1
11/28/2022 16:00	0.0	12.8	2,041.1	0.0	0.0	1	1	1
11/28/2022 17:00	0.0	12.6	2,100.3	0.0	0.0	1	1	1
11/28/2022 18:00	0.0	13.1	1,988.5	0.0	0.0	1	1	1
11/28/2022 19:00	0.0	13.2	1,967.8	0.0	0.0	1	1	1
11/28/2022 20:00	0.0	12.7	2,094.0	0.0	0.0	1	1	1
11/28/2022 21:00	0.0	12.1	2,238.4	0.0	0.0	1	1	1
11/28/2022 22:00	0.0	12.7	2,095.4	0.0	0.0	1	1	1
11/28/2022 23:00	0.0	13.1	1,996.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,828.6	0.0	0.0 #	24 #	24 #	13 #
Minimum:	0.0	12.0	1,487.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,270.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2022 00:00	0.0	12.5	2,165.2	0.0	0.0	1	1	1
11/29/2022 01:00	0.0	12.3	2,212.8	0.0	0.0	1	1	1
11/29/2022 02:00	0.0	12.4	2,192.2	0.0	0.0	1	1	1
11/29/2022 03:00	0.0	12.8	2,088.0	0.0	0.0	1	1	1
11/29/2022 04:00	0.0	12.5	2,152.8	0.0	0.0	1	1	1
11/29/2022 05:00	0.0	12.4	2,205.6	0.0	0.0	1	1	1
11/29/2022 06:00	0.0	11.9	2,296.9	0.0	0.0	1	1	1
11/29/2022 07:00	0.0	11.9	2,304.2	0.0	0.0	1	1	1
11/29/2022 08:00	0.0	12.0	2,274.9	0.0	0.0	1	1	1
11/29/2022 09:00	0.0	12.4	2,174.5	0.0	0.0	1	1	1
11/29/2022 10:00	0.0	12.4	2,167.1	0.0	0.0	1	1	1
11/29/2022 11:00	0.0	12.4	2,157.9	0.0	0.0	1	1	1
11/29/2022 12:00	0.0	12.4	2,151.2	0.0	0.0	1	1	1
11/29/2022 13:00	0.0	12.4	2,151.4	0.0	0.0	1	1	1
11/29/2022 14:00	0.0	12.4	2,156.0	0.0	0.0	1	1	1
11/29/2022 15:00	0.0	12.3	2,170.6	0.0	0.0	1	1	1
11/29/2022 16:00	0.0	11.9	2,281.5	0.0	0.0	1	1	1
11/29/2022 17:00	0.0	11.9	2,289.6	0.0	0.0	1	1	1
11/29/2022 18:00	0.0	11.9	2,292.8	0.0	0.0	1	1	1
11/29/2022 19:00	0.0	11.9	2,290.5	0.0	0.0	1	1	1
11/29/2022 20:00	0.0	12.0	2,289.3	0.0	0.0	1	1	1
11/29/2022 21:00	0.0	11.9	2,292.2	0.0	0.0	1	1	1
11/29/2022 22:00	0.0	12.0	2,297.8	0.0	0.0	1	1	1
11/29/2022 23:00	0.0	12.0	2,296.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,223.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	2,088.0	0.0	0.0	1	1	1
Maximum:	0.0	12.8	2,304.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2022 00:00	0.0	12.6	2,170.7	0.0	0.0	1	1	1
11/30/2022 01:00	0.0	12.6	2,153.2	0.0	0.0	1	1	1
11/30/2022 02:00	0.0	12.6	2,153.8	0.0	0.0	1	1	1
11/30/2022 03:00	0.0	12.6	2,151.0	0.0	0.0	1	1	1
11/30/2022 04:00	0.0	12.6	2,169.6	0.0	0.0	1	1	1
11/30/2022 05:00	0.0	12.6	2,169.3	0.0	0.0	1	1	1
11/30/2022 06:00	0.0	12.1	2,268.0	0.0	0.0	1	1	1
11/30/2022 07:00	0.0	12.6	2,158.0	0.0	0.0	1	1	1
11/30/2022 08:00	0.1	13.3	1,984.3	0.0	0.3	1	1	1
11/30/2022 09:00	0.1	13.2	1,998.7	0.1	0.3	1	1	1
11/30/2022 10:00	0.1	13.2	1,980.3	0.1	0.3	1	1	1
11/30/2022 11:00	0.1	13.2	1,984.1	0.1	0.3	1	1	1
11/30/2022 12:00	0.1	13.2	1,983.8	0.1	0.3	1	1	1
11/30/2022 13:00	0.0	13.1	1,978.8	0.1	0.0	1	1	1
11/30/2022 14:00	0.0	12.5	2,132.5	0.0	0.0	1	1	1
11/30/2022 15:00	0.0	12.4	2,140.8	0.0	0.0	1	1	1
11/30/2022 16:00	0.0	11.9	2,251.8	0.0	0.0	1	1	1
11/30/2022 17:00	0.0	11.7	2,297.3	0.0	0.0	1	1	1
11/30/2022 18:00	0.0	11.8	2,289.4	0.0	0.0	1	1	1
11/30/2022 19:00	0.0	11.8	2,289.6	0.0	0.0	1	1	1
11/30/2022 20:00	0.0	11.8	2,288.9	0.0	0.0	1	1	1
11/30/2022 21:00	0.0	12.0	2,256.6	0.0	0.0	1	1	1
11/30/2022 22:00	0.0	12.6	2,106.9	0.0	0.0	1	1	1
11/30/2022 23:00	3.5	13.8	1,590.5	0.0	10.4	1	0	1
Average/Sum#:	0.2	12.6	2,122.8	0.0	11.9 #	24 #	23 #	24 #
Minimum:	0.0	11.7	1,590.5	0.0	0.0	1	0	1
Maximum:	3.5	13.8	2,297.3	0.1	10.4	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/01/2022 02:00	12.9	17.9	301.9	0.0	8.0	1	0	0
12/01/2022 03:00	23.2	14.8	1,144.0	0.0	57.5	1	0	0
12/01/2022 04:00	0.0	13.8	1,703.6	0.0	0.0	1	1	0
12/01/2022 05:00	0.0	13.5	1,790.5	0.0	0.0	1	1	1
12/01/2022 06:00	0.0	11.7	2,291.0	0.0	0.0	1	1	1
12/01/2022 07:00	0.0	11.6	2,326.9	0.0	0.0	1	1	1
12/01/2022 08:00	0.0	12.1	2,203.6	0.0	0.0	1	1	1
12/01/2022 09:00	0.0	12.2	2,190.4	0.0	0.0	1	1	1
12/01/2022 10:00	0.0	12.2	2,195.3	0.0	0.0	1	1	1
12/01/2022 11:00	0.0	12.3	2,173.6	0.0	0.0	1	1	1
12/01/2022 12:00	0.0	12.2	2,176.8	0.0	0.0	1	1	1
12/01/2022 13:00	0.0	12.2	2,177.9	0.0	0.0	1	1	1
12/01/2022 14:00	0.0	12.1	2,192.3	0.0	0.0	1	1	1
12/01/2022 15:00	0.0	11.6	2,311.4	0.0	0.0	1	1	1
12/01/2022 16:00	0.0	11.6	2,338.6	0.0	0.0	1	1	1
12/01/2022 17:00	0.0	11.6	2,347.2	0.0	0.0	1	1	1
12/01/2022 18:00	0.0	11.6	2,335.6	0.0	0.0	1	1	1
12/01/2022 19:00	0.0	11.7	2,345.2	0.0	0.0	1	1	1
12/01/2022 20:00	0.0	11.7	2,349.1	0.0	0.0	1	1	1
12/01/2022 21:00	0.0	11.8	2,324.3	0.0	0.0	1	1	1
12/01/2022 22:00	0.0	12.4	2,184.7	0.0	0.0	1	1	1
12/01/2022 23:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
Average/Sum#:	1.6	12.5	2,072.1	0.0	65.5 #	22 #	20 #	19 #
Minimum:	0.0	11.6	301.9	0.0	0.0	0	0	0
Maximum:	23.2	17.9	2,349.1	0.0	57.5	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2022 00:00	0.0	12.4	2,181.7	0.0	0.0	1	1	1
12/02/2022 01:00	0.0	12.4	2,185.0	0.0	0.0	1	1	1
12/02/2022 02:00	0.1	12.4	2,189.6	0.0	0.3	1	1	1
12/02/2022 03:00	0.1	12.5	2,168.0	0.1	0.3	1	1	1
12/02/2022 04:00	0.1	12.5	2,177.5	0.1	0.3	1	1	1
12/02/2022 05:00	0.1	12.5	2,174.2	0.1	0.3	1	1	1
12/02/2022 06:00	0.0	12.0	2,312.0	0.1	0.0	1	1	1
12/02/2022 07:00	0.0	11.9	2,323.5	0.0	0.0	1	1	1
12/02/2022 08:00	0.0	12.0	2,321.3	0.0	0.0	1	1	1
12/02/2022 09:00	0.1	12.4	2,196.4	0.0	0.3	1	1	1
12/02/2022 10:00	0.1	12.4	2,196.5	0.1	0.3	1	1	1
12/02/2022 11:00	0.0	12.3	2,214.2	0.1	0.0	1	1	1
12/02/2022 12:00	0.0	12.3	2,217.5	0.0	0.0	1	1	1
12/02/2022 13:00	0.0	12.3	2,208.5	0.0	0.0	1	1	1
12/02/2022 14:00	0.0	12.3	2,186.0	0.0	0.0	1	1	1
12/02/2022 15:00	0.0	11.9	2,306.4	0.0	0.0	1	1	1
12/02/2022 16:00	0.0	11.7	2,337.6	0.0	0.0	1	1	1
12/02/2022 17:00	0.0	11.8	2,328.6	0.0	0.0	1	1	1
12/02/2022 18:00	0.0	11.9	2,318.8	0.0	0.0	1	1	1
12/02/2022 19:00	0.0	11.9	2,324.2	0.0	0.0	1	1	1
12/02/2022 20:00	0.0	11.9	2,321.7	0.0	0.0	1	1	1
12/02/2022 21:00	0.0	11.9	2,315.9	0.0	0.0	1	1	1
12/02/2022 22:00	0.0	11.9	2,313.3	0.0	0.0	1	1	1
12/02/2022 23:00	0.0	11.9	2,317.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,255.7	0.0	1.8 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,168.0	0.0	0.0	1	1	1
Maximum:	0.1	12.5	2,337.6	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2022 00:00	0.0	12.0	2,310.3	0.0	0.0	1	1	1
12/03/2022 01:00	0.0	12.0	2,318.6	0.0	0.0	1	1	1
12/03/2022 02:00	0.0	11.9	2,322.5	0.0	0.0	1	1	1
12/03/2022 03:00	0.0	11.9	2,322.3	0.0	0.0	1	1	1
12/03/2022 04:00	0.0	11.9	2,317.9	0.0	0.0	1	1	1
12/03/2022 05:00	0.0	11.9	2,321.6	0.0	0.0	1	1	1
12/03/2022 06:00	0.0	11.9	2,325.5	0.0	0.0	1	1	1
12/03/2022 07:00	0.0	11.8	2,334.4	0.0	0.0	1	1	1
12/03/2022 08:00	0.0	11.9	2,328.6	0.0	0.0	1	1	1
12/03/2022 09:00	0.0	11.8	2,330.7	0.0	0.0	1	1	1
12/03/2022 10:00	0.0	11.9	2,311.2	0.0	0.0	1	1	1
12/03/2022 11:00	0.0	12.0	2,279.7	0.0	0.0	1	1	1
12/03/2022 12:00	0.0	11.9	2,308.6	0.0	0.0	1	1	1
12/03/2022 13:00	0.0	12.3	2,197.2	0.0	0.0	1	1	1
12/03/2022 14:00	0.1	12.4	2,185.4	0.0	0.3	1	1	1
12/03/2022 15:00	0.0	11.9	2,313.0	0.0	0.0	1	1	1
12/03/2022 16:00	0.0	11.7	2,334.9	0.0	0.0	1	1	1
12/03/2022 17:00	0.0	11.8	2,325.1	0.0	0.0	1	1	1
12/03/2022 18:00	0.0	11.8	2,312.8	0.0	0.0	1	1	1
12/03/2022 19:00	0.0	11.8	2,316.1	0.0	0.0	1	1	1
12/03/2022 20:00	0.0	11.7	2,329.1	0.0	0.0	1	1	1
12/03/2022 21:00	0.0	11.7	2,344.0	0.0	0.0	1	1	1
12/03/2022 22:00	0.0	11.7	2,350.9	0.0	0.0	1	1	1
12/03/2022 23:00	0.0	11.7	2,342.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.9	2,311.8	0.0	0.3 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,185.4	0.0	0.0	1	1	1
Maximum:	0.1	12.4	2,350.9	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2022 00:00	0.0	12.3	2,200.3	0.0	0.0	1	1	1
12/04/2022 01:00	0.0	12.3	2,203.9	0.0	0.0	1	1	1
12/04/2022 02:00	0.0	12.3	2,208.7	0.0	0.0	1	1	1
12/04/2022 03:00	0.1	12.3	2,200.4	0.0	0.3	1	1	1
12/04/2022 04:00	0.0	12.3	2,211.5	0.0	0.0	1	1	1
12/04/2022 05:00	0.0	12.3	2,202.2	0.0	0.0	1	1	1
12/04/2022 06:00	0.0	11.8	2,326.8	0.0	0.0	1	1	1
12/04/2022 07:00	0.0	11.7	2,339.1	0.0	0.0	1	1	1
12/04/2022 08:00	0.0	12.3	2,214.8	0.0	0.0	1	1	1
12/04/2022 09:00	0.1	12.3	2,191.3	0.0	0.3	1	1	1
12/04/2022 10:00	0.0	12.2	2,206.1	0.0	0.0	1	1	1
12/04/2022 11:00	0.0	12.2	2,206.4	0.0	0.0	1	1	1
12/04/2022 12:00	0.0	12.1	2,197.7	0.0	0.0	1	1	1
12/04/2022 13:00	0.0	12.1	2,193.2	0.0	0.0	1	1	1
12/04/2022 14:00	0.0	12.1	2,207.4	0.0	0.0	1	1	1
12/04/2022 15:00	0.0	12.1	2,194.8	0.0	0.0	1	1	1
12/04/2022 16:00	0.0	11.6	2,322.7	0.0	0.0	1	1	1
12/04/2022 17:00	0.0	11.6	2,338.7	0.0	0.0	1	1	1
12/04/2022 18:00	0.0	11.6	2,323.4	0.0	0.0	1	1	1
12/04/2022 19:00	0.0	11.7	2,320.9	0.0	0.0	1	1	1
12/04/2022 20:00	0.0	11.7	2,321.9	0.0	0.0	1	1	1
12/04/2022 21:00	0.0	11.7	2,322.9	0.0	0.0	1	1	1
12/04/2022 22:00	0.0	11.8	2,311.7	0.0	0.0	1	1	1
12/04/2022 23:00	0.0	12.3	2,192.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.0	2,248.3	0.0	0.6 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,191.3	0.0	0.0	1	1	1
Maximum:	0.1	12.3	2,339.1	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2022 00:00	0.0	12.3	2,194.3	0.0	0.0	1	1	1
12/05/2022 01:00	0.0	12.3	2,191.4	0.0	0.0	1	1	1
12/05/2022 02:00	0.0	12.3	2,196.4	0.0	0.0	1	1	1
12/05/2022 03:00	0.0	12.3	2,190.0	0.0	0.0	1	1	1
12/05/2022 04:00	0.0	12.2	2,215.9	0.0	0.0	1	1	1
12/05/2022 05:00	0.0	11.8	2,320.8	0.0	0.0	1	1	1
12/05/2022 06:00	0.0	11.6	2,344.1	0.0	0.0	1	1	1
12/05/2022 07:00	0.0	11.7	2,340.6	0.0	0.0	1	1	1
12/05/2022 08:00	0.0	11.6	2,351.7	0.0	0.0	1	1	1
12/05/2022 09:00	0.0	11.5	2,366.0	0.0	0.0	1	1	1
12/05/2022 10:00	0.0	11.9	2,141.8	0.0	0.0	1	1	1
12/05/2022 11:00	0.0	13.2	1,826.8	0.0	0.0	1	1	1
12/05/2022 12:00	0.0	12.2	2,161.8	0.0	0.0	1	1	1
12/05/2022 13:00	0.0	12.8	2,027.0	0.0	0.0	1	1	1
12/05/2022 14:00	0.0	12.7	2,056.5	0.0	0.0	1	1	1
12/05/2022 15:00	0.0	12.6	2,074.4	0.0	0.0	1	1	1
12/05/2022 16:00	0.0	12.0	2,222.7	0.0	0.0	1	1	1
12/05/2022 17:00	0.0	11.7	2,298.0	0.0	0.0	1	1	1
12/05/2022 18:00	0.0	11.7	2,298.7	0.0	0.0	1	1	1
12/05/2022 19:00	0.0	11.8	2,302.3	0.0	0.0	1	1	1
12/05/2022 20:00	0.0	11.8	2,299.3	0.0	0.0	1	1	1
12/05/2022 21:00	0.0	12.1	2,221.1	0.0	0.0	1	1	1
12/05/2022 22:00	0.0	12.7	2,074.3	0.0	0.0	1	1	1
12/05/2022 23:00	0.0	12.8	2,049.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,198.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,826.8	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,366.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2022 00:00	0.0	13.2	1,968.4	0.0	0.0	1	1	1
12/06/2022 01:00	0.0	13.2	1,968.0	0.0	0.0	1	1	1
12/06/2022 02:00	0.1	13.2	1,968.0	0.0	0.3	1	1	1
12/06/2022 03:00	0.1	13.2	1,969.4	0.1	0.3	1	1	1
12/06/2022 04:00	0.0	13.1	1,984.1	0.1	0.0	1	1	1
12/06/2022 05:00	0.0	13.0	2,012.5	0.0	0.0	1	1	1
12/06/2022 06:00	0.0	13.1	1,985.5	0.0	0.0	1	1	1
12/06/2022 07:00	0.0	12.7	2,090.5	0.0	0.0	1	1	1
12/06/2022 08:00	0.0	11.9	2,283.2	0.0	0.0	1	1	1
12/06/2022 09:00	0.0	12.0	2,270.7	0.0	0.0	1	1	1
12/06/2022 10:00	0.0	12.0	2,264.3	0.0	0.0	1	1	1
12/06/2022 11:00	0.0	12.0	2,260.4	0.0	0.0	1	1	1
12/06/2022 12:00	0.0	12.0	2,241.0	0.0	0.0	1	1	1
12/06/2022 13:00	0.0	13.7	1,779.8	0.0	0.0	1	1	1
12/06/2022 14:00	0.0	14.0	1,314.5	0.0	0.0	1	1	0
12/06/2022 15:00	0.0	14.0	1,314.1	0.0	0.0	1	1	0
12/06/2022 16:00	0.0	13.9	1,512.4	0.0	0.0	1	1	0
12/06/2022 17:00	0.0	13.8	1,808.0	0.0	0.0	1	1	0
12/06/2022 18:00	0.0	13.8	1,807.8	0.0	0.0	1	1	0
12/06/2022 19:00	0.0	13.8	1,817.6	0.0	0.0	1	1	1
12/06/2022 20:00	0.0	12.5	2,137.3	0.0	0.0	1	1	1
12/06/2022 21:00	0.0	12.1	2,235.9	0.0	0.0	1	1	1
12/06/2022 22:00	0.0	12.6	2,105.7	0.0	0.0	1	1	1
12/06/2022 23:00	0.0	13.2	1,973.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,961.3	0.0	0.6 #	24 #	24 #	19 #
Minimum:	0.0	11.9	1,314.1	0.0	0.0	1	1	0
Maximum:	0.1	14.0	2,283.2	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2022 00:00	0.0	12.7	2,084.1	0.0	0.0	1	1	1
12/07/2022 01:00	0.0	13.1	1,990.9	0.0	0.0	1	1	1
12/07/2022 02:00	0.0	12.6	2,139.0	0.0	0.0	1	1	1
12/07/2022 03:00	0.0	12.5	2,147.2	0.0	0.0	1	1	1
12/07/2022 04:00	0.0	12.5	2,164.6	0.0	0.0	1	1	1
12/07/2022 05:00	0.0	12.4	2,173.1	0.0	0.0	1	1	1
12/07/2022 06:00	0.0	12.1	2,253.6	0.0	0.0	1	1	1
12/07/2022 07:00	0.0	12.1	2,265.4	0.0	0.0	1	1	1
12/07/2022 08:00	0.0	12.6	2,137.8	0.0	0.0	1	1	1
12/07/2022 09:00	0.0	12.5	2,172.2	0.0	0.0	1	1	1
12/07/2022 10:00	0.0	12.5	2,171.5	0.0	0.0	1	1	1
12/07/2022 11:00	0.0	12.5	2,169.0	0.0	0.0	1	1	1
12/07/2022 12:00	0.0	12.5	2,144.8	0.0	0.0	1	1	1
12/07/2022 13:00	0.0	12.5	2,120.6	0.0	0.0	1	1	1
12/07/2022 14:00	0.0	12.8	2,065.4	0.0	0.0	1	1	1
12/07/2022 15:00	0.0	12.7	2,088.9	0.0	0.0	1	1	1
12/07/2022 16:00	0.0	12.0	2,262.1	0.0	0.0	1	1	1
12/07/2022 17:00	0.0	11.9	2,276.0	0.0	0.0	1	1	1
12/07/2022 18:00	0.0	11.9	2,279.2	0.0	0.0	1	1	1
12/07/2022 19:00	0.0	11.9	2,277.8	0.0	0.0	1	1	1
12/07/2022 20:00	0.0	11.9	2,278.1	0.0	0.0	1	1	1
12/07/2022 21:00	0.0	12.0	2,272.8	0.0	0.0	1	1	1
12/07/2022 22:00	0.0	12.4	2,185.4	0.0	0.0	1	1	1
12/07/2022 23:00	0.0	12.4	2,181.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,179.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,990.9	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,279.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2022 00:00	0.0	12.6	2,140.3	0.0	0.0	1	1	1
12/08/2022 01:00	0.0	12.6	2,134.5	0.0	0.0	1	1	1
12/08/2022 02:00	0.0	12.6	2,131.2	0.0	0.0	1	1	1
12/08/2022 03:00	0.0	12.7	2,128.7	0.0	0.0	1	1	1
12/08/2022 04:00	0.0	12.6	2,153.6	0.0	0.0	1	1	1
12/08/2022 05:00	0.0	12.4	2,211.4	0.0	0.0	1	1	1
12/08/2022 06:00	0.0	12.0	2,286.3	0.0	0.0	1	1	1
12/08/2022 07:00	0.0	12.2	2,241.1	0.0	0.0	1	1	1
12/08/2022 08:00	0.0	13.0	2,033.7	0.0	0.0	1	1	1
12/08/2022 09:00	0.0	12.8	2,111.2	0.0	0.0	1	1	1
12/08/2022 10:00	0.0	12.7	2,119.0	0.0	0.0	1	1	1
12/08/2022 11:00	0.0	12.5	2,150.5	0.0	0.0	1	1	1
12/08/2022 12:00	0.0	12.5	2,152.8	0.0	0.0	1	1	1
12/08/2022 13:00	0.0	12.4	2,166.9	0.0	0.0	1	1	1
12/08/2022 14:00	0.0	12.3	2,177.4	0.0	0.0	1	1	1
12/08/2022 15:00	0.0	12.3	2,183.9	0.0	0.0	1	1	1
12/08/2022 16:00	0.0	11.9	2,283.7	0.0	0.0	1	1	1
12/08/2022 17:00	0.0	11.9	2,284.7	0.0	0.0	1	1	1
12/08/2022 18:00	0.0	11.9	2,287.5	0.0	0.0	1	1	1
12/08/2022 19:00	0.0	11.9	2,285.8	0.0	0.0	1	1	1
12/08/2022 20:00	0.0	11.9	2,287.4	0.0	0.0	1	1	1
12/08/2022 21:00	0.0	11.9	2,285.0	0.0	0.0	1	1	1
12/08/2022 22:00	0.0	12.3	2,194.3	0.0	0.0	1	1	1
12/08/2022 23:00	0.0	12.3	2,195.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,192.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	2,033.7	0.0	0.0	1	1	1
Maximum:	0.0	13.0	2,287.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2022 00:00	0.0	12.5	2,144.3	0.0	0.0	1	1	1
12/09/2022 01:00	0.0	12.9	2,046.2	0.0	0.0	1	1	1
12/09/2022 02:00	0.0	12.6	2,142.3	0.0	0.0	1	1	1
12/09/2022 03:00	0.0	12.6	2,144.2	0.0	0.0	1	1	1
12/09/2022 04:00	0.0	12.4	2,194.9	0.0	0.0	1	1	1
12/09/2022 05:00	0.0	12.0	2,296.2	0.0	0.0	1	1	1
12/09/2022 06:00	0.0	12.0	2,298.6	0.0	0.0	1	1	1
12/09/2022 07:00	0.0	12.0	2,286.8	0.0	0.0	1	1	1
12/09/2022 08:00	0.0	12.9	2,072.5	0.0	0.0	1	1	1
12/09/2022 09:00	0.0	13.0	2,032.9	0.0	0.0	1	1	1
12/09/2022 10:00	0.1	13.2	1,984.3	0.0	0.3	1	1	1
12/09/2022 11:00	0.0	12.8	2,074.2	0.0	0.0	1	1	1
12/09/2022 12:00	0.0	13.0	2,007.8	0.0	0.0	1	1	1
12/09/2022 13:00	0.0	12.4	2,160.2	0.0	0.0	1	1	1
12/09/2022 14:00	0.0	12.4	2,163.1	0.0	0.0	1	1	1
12/09/2022 15:00	0.0	12.9	2,055.6	0.0	0.0	1	1	1
12/09/2022 16:00	0.0	11.9	2,286.0	0.0	0.0	1	1	1
12/09/2022 17:00	0.0	11.9	2,285.5	0.0	0.0	1	1	1
12/09/2022 18:00	0.0	11.9	2,285.9	0.0	0.0	1	1	1
12/09/2022 19:00	0.0	11.9	2,287.2	0.0	0.0	1	1	1
12/09/2022 20:00	0.0	11.9	2,289.2	0.0	0.0	1	1	1
12/09/2022 21:00	0.0	11.9	2,287.9	0.0	0.0	1	1	1
12/09/2022 22:00	0.0	11.9	2,286.6	0.0	0.0	1	1	1
12/09/2022 23:00	0.0	11.9	2,280.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,183.0	0.0	0.3 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,984.3	0.0	0.0	1	1	1
Maximum:	0.1	13.2	2,298.6	0.0	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2022 00:00	0.0	13.0	2,020.4	0.0	0.0	1	1	1
12/10/2022 01:00	0.0	13.0	2,016.4	0.0	0.0	1	1	1
12/10/2022 02:00	0.0	13.1	1,980.5	0.0	0.0	1	1	1
12/10/2022 03:00	0.0	13.1	1,981.2	0.0	0.0	1	1	1
12/10/2022 04:00	0.0	13.1	1,976.3	0.0	0.0	1	1	1
12/10/2022 05:00	0.0	13.0	1,986.7	0.0	0.0	1	1	1
12/10/2022 06:00	0.0	13.1	1,973.6	0.0	0.0	1	1	1
12/10/2022 07:00	0.0	13.1	1,981.0	0.0	0.0	1	1	1
12/10/2022 08:00	0.0	12.9	2,021.2	0.0	0.0	1	1	1
12/10/2022 09:00	0.0	12.9	1,998.2	0.0	0.0	1	1	1
12/10/2022 10:00	0.0	13.0	1,974.5	0.0	0.0	1	1	1
12/10/2022 11:00	0.0	12.8	2,015.4	0.0	0.0	1	1	1
12/10/2022 12:00	0.0	12.4	2,121.1	0.0	0.0	1	1	1
12/10/2022 13:00	0.0	12.0	2,182.6	0.0	0.0	1	1	1
12/10/2022 14:00	0.0	12.7	2,018.0	0.0	0.0	1	1	1
12/10/2022 15:00	0.0	12.6	2,043.8	0.0	0.0	1	1	1
12/10/2022 16:00	0.0	12.4	2,112.6	0.0	0.0	1	1	1
12/10/2022 17:00	0.0	12.5	2,071.9	0.0	0.0	1	1	1
12/10/2022 18:00	0.0	12.6	2,072.8	0.0	0.0	1	1	1
12/10/2022 19:00	0.0	11.8	2,252.8	0.0	0.0	1	1	1
12/10/2022 20:00	0.0	12.2	2,175.1	0.0	0.0	1	1	1
12/10/2022 21:00	0.0	12.5	2,080.6	0.0	0.0	1	1	1
12/10/2022 22:00	0.0	12.9	2,016.0	0.0	0.0	1	1	1
12/10/2022 23:00	0.0	12.6	2,077.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	2,047.9	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,973.6	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,252.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2022 00:00	0.0	13.1	1,967.5	0.0	0.0	1	1	1
12/11/2022 01:00	0.0	13.1	1,965.0	0.0	0.0	1	1	1
12/11/2022 02:00	0.0	13.1	1,964.9	0.0	0.0	1	1	1
12/11/2022 03:00	0.0	13.1	1,965.4	0.0	0.0	1	1	1
12/11/2022 04:00	0.0	13.1	1,969.0	0.0	0.0	1	1	1
12/11/2022 05:00	0.0	13.1	1,967.8	0.0	0.0	1	1	1
12/11/2022 06:00	0.0	13.1	1,969.4	0.0	0.0	1	1	1
12/11/2022 07:00	0.0	13.2	1,972.0	0.0	0.0	1	1	1
12/11/2022 08:00	0.0	13.2	1,973.7	0.0	0.0	1	1	1
12/11/2022 09:00	0.0	13.1	1,971.0	0.0	0.0	1	1	1
12/11/2022 10:00	0.0	13.1	1,969.2	0.0	0.0	1	1	1
12/11/2022 11:00	0.0	13.1	1,966.9	0.0	0.0	1	1	1
12/11/2022 12:00	0.0	13.1	1,966.8	0.0	0.0	1	1	1
12/11/2022 13:00	0.0	13.1	1,968.3	0.0	0.0	1	1	1
12/11/2022 14:00	0.0	13.1	1,963.5	0.0	0.0	1	1	1
12/11/2022 15:00	0.0	12.7	2,060.7	0.0	0.0	1	1	1
12/11/2022 16:00	0.0	12.8	2,068.6	0.0	0.0	1	1	1
12/11/2022 17:00	0.0	12.5	2,141.4	0.0	0.0	1	1	1
12/11/2022 18:00	0.0	12.9	2,048.1	0.0	0.0	1	1	1
12/11/2022 19:00	0.0	12.8	2,066.7	0.0	0.0	1	1	1
12/11/2022 20:00	0.0	12.6	2,120.2	0.0	0.0	1	1	1
12/11/2022 21:00	0.0	13.1	2,003.0	0.0	0.0	1	1	1
12/11/2022 22:00	0.0	13.2	1,972.7	0.0	0.0	1	1	1
12/11/2022 23:00	0.0	13.2	1,974.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,999.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.5	1,963.5	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,141.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2022 00:00	0.0	13.2	1,981.6	0.0	0.0	1	1	1
12/12/2022 01:00	0.0	13.2	1,982.3	0.0	0.0	1	1	1
12/12/2022 02:00	0.0	13.2	1,981.4	0.0	0.0	1	1	1
12/12/2022 03:00	0.0	13.2	1,978.4	0.0	0.0	1	1	1
12/12/2022 04:00	0.0	13.2	1,977.9	0.0	0.0	1	1	1
12/12/2022 05:00	0.0	12.7	2,119.2	0.0	0.0	1	1	1
12/12/2022 06:00	0.0	12.2	2,218.1	0.0	0.0	1	1	1
12/12/2022 07:00	0.0	12.3	2,198.9	0.0	0.0	1	1	1
12/12/2022 08:00	0.0	12.8	2,076.7	0.0	0.0	1	1	1
12/12/2022 09:00	0.0	12.9	2,068.8	0.0	0.0	1	1	1
12/12/2022 10:00	0.1	13.3	1,973.0	0.0	0.3	1	1	1
12/12/2022 11:00	0.1	13.2	1,970.2	0.1	0.3	1	1	1
12/12/2022 12:00	0.1	13.2	1,970.6	0.1	0.3	1	1	1
12/12/2022 13:00	0.1	13.2	1,969.6	0.1	0.3	1	1	1
12/12/2022 14:00	0.1	13.2	1,968.0	0.1	0.3	1	1	1
12/12/2022 15:00	0.0	13.2	1,967.7	0.1	0.0	1	1	1
12/12/2022 16:00	0.0	12.5	2,153.9	0.0	0.0	1	1	1
12/12/2022 17:00	0.0	12.1	2,250.2	0.0	0.0	1	1	1
12/12/2022 18:00	0.0	11.8	2,314.5	0.0	0.0	1	1	1
12/12/2022 19:00	0.0	11.8	2,316.4	0.0	0.0	1	1	1
12/12/2022 20:00	0.0	11.8	2,320.3	0.0	0.0	1	1	1
12/12/2022 21:00	0.0	12.0	2,269.9	0.0	0.0	1	1	1
12/12/2022 22:00	0.0	12.3	2,201.9	0.0	0.0	1	1	1
12/12/2022 23:00	0.0	13.0	2,035.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	2,094.4	0.0	1.5 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,967.7	0.0	0.0	1	1	1
Maximum:	0.1	13.3	2,320.3	0.1	0.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2022 00:00	0.0	12.6	2,155.3	0.0	0.0	1	1	1
12/13/2022 01:00	0.0	12.5	2,162.4	0.0	0.0	1	1	1
12/13/2022 02:00	0.0	12.5	2,171.0	0.0	0.0	1	1	1
12/13/2022 03:00	0.0	12.5	2,161.4	0.0	0.0	1	1	1
12/13/2022 04:00	0.0	12.4	2,201.7	0.0	0.0	1	1	1
12/13/2022 05:00	0.0	12.1	2,286.6	0.0	0.0	1	1	1
12/13/2022 06:00	0.0	11.9	2,323.5	0.0	0.0	1	1	1
12/13/2022 07:00	0.0	11.9	2,314.5	0.0	0.0	1	1	1
12/13/2022 08:00	0.0	12.5	2,149.7	0.0	0.0	1	1	1
12/13/2022 09:00	0.0	13.1	2,013.4	0.0	0.0	1	1	1
12/13/2022 10:00	0.0	13.3	1,978.2	0.0	0.0	1	1	1
12/13/2022 11:00	0.0	13.2	1,972.8	0.0	0.0	1	1	1
12/13/2022 12:00	0.0	13.2	1,971.6	0.0	0.0	1	1	1
12/13/2022 13:00	0.0	13.2	1,969.9	0.0	0.0	1	1	1
12/13/2022 14:00	0.0	13.2	1,968.6	0.0	0.0	1	1	1
12/13/2022 15:00	0.0	12.8	2,076.2	0.0	0.0	1	1	1
12/13/2022 16:00	0.0	11.9	2,282.3	0.0	0.0	1	1	1
12/13/2022 17:00	0.0	11.8	2,299.2	0.0	0.0	1	1	1
12/13/2022 18:00	0.0	11.9	2,297.3	0.0	0.0	1	1	1
12/13/2022 19:00	0.0	11.9	2,296.7	0.0	0.0	1	1	1
12/13/2022 20:00	0.0	11.9	2,293.3	0.0	0.0	1	1	1
12/13/2022 21:00	0.0	12.0	2,293.3	0.0	0.0	1	1	1
12/13/2022 22:00	0.0	12.0	2,297.4	0.0	0.0	1	1	1
12/13/2022 23:00	0.0	11.9	2,293.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,176.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,968.6	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,323.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2022 00:00	0.0	12.4	2,201.0	0.0	0.0	1	1	1
12/14/2022 01:00	0.0	12.4	2,205.8	0.0	0.0	1	1	1
12/14/2022 02:00	0.0	12.4	2,207.5	0.0	0.0	1	1	1
12/14/2022 03:00	0.0	12.5	2,202.0	0.0	0.0	1	1	1
12/14/2022 04:00	0.0	12.5	2,195.8	0.0	0.0	1	1	1
12/14/2022 05:00	0.0	12.0	2,307.3	0.0	0.0	1	1	1
12/14/2022 06:00	0.0	12.0	2,311.1	0.0	0.0	1	1	1
12/14/2022 07:00	0.0	12.1	2,277.8	0.0	0.0	1	1	1
12/14/2022 08:00	0.0	12.9	2,081.0	0.0	0.0	1	1	1
12/14/2022 09:00	0.0	13.1	2,011.1	0.0	0.0	1	1	1
12/14/2022 10:00	0.0	13.0	2,028.4	0.0	0.0	1	1	1
12/14/2022 11:00	0.0	13.2	1,974.9	0.0	0.0	1	1	1
12/14/2022 12:00	0.0	13.2	1,976.5	0.0	0.0	1	1	1
12/14/2022 13:00	0.0	13.2	1,978.3	0.0	0.0	1	1	1
12/14/2022 14:00	0.0	13.2	1,975.2	0.0	0.0	1	1	1
12/14/2022 15:00	0.0	13.1	2,018.4	0.0	0.0	1	1	1
12/14/2022 16:00	0.0	12.2	2,219.4	0.0	0.0	1	1	1
12/14/2022 17:00	0.0	11.9	2,291.2	0.0	0.0	1	1	1
12/14/2022 18:00	0.0	11.9	2,288.1	0.0	0.0	1	1	1
12/14/2022 19:00	0.0	11.9	2,292.6	0.0	0.0	1	1	1
12/14/2022 20:00	0.0	12.0	2,292.9	0.0	0.0	1	1	1
12/14/2022 21:00	0.0	12.0	2,291.3	0.0	0.0	1	1	1
12/14/2022 22:00	0.0	12.1	2,265.2	0.0	0.0	1	1	1
12/14/2022 23:00	0.0	12.5	2,178.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,169.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,974.9	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,311.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0.0	12.0	2,300.0	0.0	0.0	1	1	1
12/15/2022 01:00	0.0	11.9	2,310.7	0.0	0.0	1	1	1
12/15/2022 02:00	0.0	11.9	2,310.7	0.0	0.0	1	1	1
12/15/2022 03:00	0.0	11.9	2,312.5	0.0	0.0	1	1	1
12/15/2022 04:00	0.0	11.9	2,317.5	0.0	0.0	1	1	1
12/15/2022 05:00	0.0	11.9	2,320.2	0.0	0.0	1	1	1
12/15/2022 06:00	0.0	11.9	2,319.6	0.0	0.0	1	1	1
12/15/2022 07:00	0.0	11.9	2,314.8	0.0	0.0	1	1	1
12/15/2022 08:00	0.0	12.2	2,232.9	0.0	0.0	1	1	1
12/15/2022 09:00	0.0	12.1	2,231.2	0.0	0.0	1	1	1
12/15/2022 10:00	0.0	13.1	1,978.7	0.0	0.0	1	1	1
12/15/2022 11:00	0.0	13.1	1,990.3	0.0	0.0	1	1	1
12/15/2022 12:00	0.0	12.9	2,023.1	0.0	0.0	1	1	1
12/15/2022 13:00	0.0	12.8	2,045.1	0.0	0.0	1	1	1
12/15/2022 14:00	0.0	12.6	2,102.6	0.0	0.0	1	1	1
12/15/2022 15:00	0.0	11.9	2,258.0	0.0	0.0	1	1	1
12/15/2022 16:00	0.0	11.9	2,270.0	0.0	0.0	1	1	1
12/15/2022 17:00	0.0	11.9	2,268.1	0.0	0.0	1	1	1
12/15/2022 18:00	0.0	12.0	2,258.2	0.0	0.0	1	1	1
12/15/2022 19:00	0.0	12.0	2,251.3	0.0	0.0	1	1	1
12/15/2022 20:00	0.0	12.0	2,253.0	0.0	0.0	1	1	1
12/15/2022 21:00	0.0	12.1	2,254.6	0.0	0.0	1	1	1
12/15/2022 22:00	0.0	12.1	2,260.1	0.0	0.0	1	1	1
12/15/2022 23:00	0.0	12.2	2,242.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,226.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,978.7	0.0	0.0	1	1	1
Maximum:	0.0	13.1	2,320.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2022 00:00	0.0	13.1	1,997.7	0.0	0.0	1	1	1
12/16/2022 01:00	0.0	13.2	1,975.0	0.0	0.0	1	1	1
12/16/2022 02:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
12/16/2022 03:00	0.0	13.2	1,977.9	0.0	0.0	1	1	1
12/16/2022 04:00	0.0	13.2	1,976.0	0.0	0.0	1	1	1
12/16/2022 05:00	0.0	13.2	1,986.3	0.0	0.0	1	1	1
12/16/2022 06:00	0.0	12.7	2,114.7	0.0	0.0	1	1	1
12/16/2022 07:00	0.0	12.4	2,213.4	0.0	0.0	1	1	1
12/16/2022 08:00	0.0	12.6	2,148.7	0.0	0.0	1	1	1
12/16/2022 09:00	0.0	12.8	2,073.1	0.0	0.0	1	1	1
12/16/2022 10:00	0.0	13.9	1,533.9	0.0	0.0	1	1	0
12/16/2022 11:00	0.0	14.0	1,455.0	0.0	0.0	1	1	0
12/16/2022 12:00	0.0	14.0	1,319.9	0.0	0.0	1	1	0
12/16/2022 13:00	0.0	14.0	1,322.2	0.0	0.0	1	1	0
12/16/2022 14:00	0.0	13.9	1,577.2	0.0	0.0	1	1	0
12/16/2022 15:00	0.0	13.9	1,550.0	0.0	0.0	1	1	1
12/16/2022 16:00	0.0	12.4	2,166.8	0.0	0.0	1	1	1
12/16/2022 17:00	0.0	12.1	2,236.7	0.0	0.0	1	1	1
12/16/2022 18:00	0.0	12.4	2,162.4	0.0	0.0	1	1	1
12/16/2022 19:00	0.0	12.4	2,168.7	0.0	0.0	1	1	1
12/16/2022 20:00	0.0	12.0	2,256.4	0.0	0.0	1	1	1
12/16/2022 21:00	0.0	12.2	2,198.9	0.0	0.0	1	1	1
12/16/2022 22:00	0.0	12.7	2,089.5	0.0	0.0	1	1	1
12/16/2022 23:00	0.0	13.2	1,975.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,935.4	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.0	1,319.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,256.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2022 00:00	0.0	12.5	2,148.3	0.0	0.0	1	1	1
12/17/2022 01:00	0.0	12.5	2,151.2	0.0	0.0	1	1	1
12/17/2022 02:00	0.0	12.6	2,142.6	0.0	0.0	1	1	1
12/17/2022 03:00	0.0	12.6	2,153.4	0.0	0.0	1	1	1
12/17/2022 04:00	0.0	12.5	2,154.4	0.0	0.0	1	1	1
12/17/2022 05:00	0.0	12.6	2,151.3	0.0	0.0	1	1	1
12/17/2022 06:00	0.0	12.1	2,242.2	0.0	0.0	1	1	1
12/17/2022 07:00	0.0	12.7	2,099.3	0.0	0.0	1	1	1
12/17/2022 08:00	0.0	12.5	2,165.9	0.0	0.0	1	1	1
12/17/2022 09:00	0.0	12.7	2,124.8	0.0	0.0	1	1	1
12/17/2022 10:00	0.0	13.1	2,009.5	0.0	0.0	1	1	1
12/17/2022 11:00	0.0	13.2	1,977.3	0.0	0.0	1	1	1
12/17/2022 12:00	0.0	13.2	1,970.0	0.0	0.0	1	1	1
12/17/2022 13:00	0.0	13.2	1,970.2	0.0	0.0	1	1	1
12/17/2022 14:00	0.0	13.1	1,991.1	0.0	0.0	1	1	1
12/17/2022 15:00	0.0	12.6	2,124.4	0.0	0.0	1	1	1
12/17/2022 16:00	0.0	11.9	2,279.1	0.0	0.0	1	1	1
12/17/2022 17:00	0.0	12.0	2,247.4	0.0	0.0	1	1	1
12/17/2022 18:00	0.0	12.4	2,159.7	0.0	0.0	1	1	1
12/17/2022 19:00	0.0	11.9	2,288.0	0.0	0.0	1	1	1
12/17/2022 20:00	0.0	11.9	2,291.4	0.0	0.0	1	1	1
12/17/2022 21:00	0.0	11.9	2,292.3	0.0	0.0	1	1	1
12/17/2022 22:00	0.0	11.9	2,284.2	0.0	0.0	1	1	1
12/17/2022 23:00	0.0	12.3	2,192.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,150.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.9	1,970.0	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,292.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2022 00:00	0.0	12.5	2,141.4	0.0	0.0	1	1	1
12/18/2022 01:00	0.0	12.6	2,140.8	0.0	0.0	1	1	1
12/18/2022 02:00	0.0	13.1	2,023.7	0.0	0.0	1	1	1
12/18/2022 03:00	0.0	13.3	1,985.2	0.0	0.0	1	1	1
12/18/2022 04:00	0.0	12.7	2,140.3	0.0	0.0	1	1	1
12/18/2022 05:00	0.0	12.6	2,162.0	0.0	0.0	1	1	1
12/18/2022 06:00	0.0	12.4	2,182.1	0.0	0.0	1	1	1
12/18/2022 07:00	0.0	12.3	2,219.3	0.0	0.0	1	1	1
12/18/2022 08:00	0.0	12.7	2,091.7	0.0	0.0	1	1	1
12/18/2022 09:00	0.0	13.9	1,607.9	0.0	0.0	1	1	0
12/18/2022 10:00	0.0	13.9	1,552.2	0.0	0.0	1	1	0
12/18/2022 11:00	0.0	13.9	1,544.4	0.0	0.0	1	1	0
12/18/2022 12:00	0.0	14.0	1,404.3	0.0	0.0	1	1	0
12/18/2022 13:00	0.0	14.0	1,395.8	0.0	0.0	1	1	0
12/18/2022 14:00	0.0	13.9	1,634.8	0.0	0.0	1	1	0
12/18/2022 15:00	0.0	13.9	1,645.9	0.0	0.0	1	1	1
12/18/2022 16:00	0.0	12.5	2,143.3	0.0	0.0	1	1	1
12/18/2022 17:00	0.0	12.0	2,254.0	0.0	0.0	1	1	1
12/18/2022 18:00	0.0	11.9	2,283.9	0.0	0.0	1	1	1
12/18/2022 19:00	0.0	11.9	2,288.7	0.0	0.0	1	1	1
12/18/2022 20:00	0.0	12.2	2,245.0	0.0	0.0	1	1	1
12/18/2022 21:00	0.0	12.4	2,208.9	0.0	0.0	1	1	1
12/18/2022 22:00	0.0	12.4	2,205.7	0.0	0.0	1	1	1
12/18/2022 23:00	0.0	13.0	2,049.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,981.3	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,395.8	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,288.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2022 00:00	0.0	12.7	2,141.9	0.0	0.0	1	1	1
12/19/2022 01:00	0.0	12.6	2,153.5	0.0	0.0	1	1	1
12/19/2022 02:00	0.0	12.6	2,149.7	0.0	0.0	1	1	1
12/19/2022 03:00	0.0	12.6	2,152.1	0.0	0.0	1	1	1
12/19/2022 04:00	0.0	12.5	2,185.5	0.0	0.0	1	1	1
12/19/2022 05:00	0.0	12.0	2,309.6	0.0	0.0	1	1	1
12/19/2022 06:00	0.0	12.0	2,310.1	0.0	0.0	1	1	1
12/19/2022 07:00	0.0	12.0	2,310.1	0.0	0.0	1	1	1
12/19/2022 08:00	0.0	12.2	2,262.0	0.0	0.0	1	1	1
12/19/2022 09:00	0.0	12.1	2,274.3	0.0	0.0	1	1	1
12/19/2022 10:00	0.0	12.5	2,181.5	0.0	0.0	1	1	1
12/19/2022 11:00	0.0	12.5	2,181.8	0.0	0.0	1	1	1
12/19/2022 12:00	0.0	12.6	2,174.1	0.0	0.0	1	1	1
12/19/2022 13:00	0.0	12.6	2,164.7	0.0	0.0	1	1	1
12/19/2022 14:00	0.0	12.6	2,166.8	0.0	0.0	1	1	1
12/19/2022 15:00	0.0	12.3	2,231.0	0.0	0.0	1	1	1
12/19/2022 16:00	0.0	12.1	2,274.5	0.0	0.0	1	1	1
12/19/2022 17:00	0.0	12.1	2,275.0	0.0	0.0	1	1	1
12/19/2022 18:00	0.0	12.1	2,277.1	0.0	0.0	1	1	1
12/19/2022 19:00	0.0	12.1	2,280.3	0.0	0.0	1	1	1
12/19/2022 20:00	0.0	12.2	2,277.2	0.0	0.0	1	1	1
12/19/2022 21:00	0.0	12.2	2,277.4	0.0	0.0	1	1	1
12/19/2022 22:00	0.0	12.1	2,283.3	0.0	0.0	1	1	1
12/19/2022 23:00	0.0	12.1	2,278.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,232.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,141.9	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,310.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2022 00:00	0.0	12.6	2,180.6	0.0	0.0	1	1	1
12/20/2022 01:00	0.0	12.6	2,178.9	0.0	0.0	1	1	1
12/20/2022 02:00	0.0	12.5	2,184.2	0.0	0.0	1	1	1
12/20/2022 03:00	0.0	12.5	2,189.6	0.0	0.0	1	1	1
12/20/2022 04:00	0.0	12.5	2,190.7	0.0	0.0	1	1	1
12/20/2022 05:00	0.0	12.5	2,190.8	0.0	0.0	1	1	1
12/20/2022 06:00	0.0	12.1	2,291.6	0.0	0.0	1	1	1
12/20/2022 07:00	0.0	12.1	2,284.8	0.0	0.0	1	1	1
12/20/2022 08:00	0.0	12.6	2,170.4	0.0	0.0	1	1	1
12/20/2022 09:00	0.0	12.5	2,170.0	0.0	0.0	1	1	1
12/20/2022 10:00	0.0	12.7	2,128.2	0.0	0.0	1	1	1
12/20/2022 11:00	0.0	12.8	2,095.1	0.0	0.0	1	1	1
12/20/2022 12:00	0.0	13.3	1,961.4	0.0	0.0	1	1	1
12/20/2022 13:00	0.0	13.3	1,965.5	0.0	0.0	1	1	1
12/20/2022 14:00	0.0	13.3	1,964.0	0.0	0.0	1	1	1
12/20/2022 15:00	0.0	13.0	2,038.6	0.0	0.0	1	1	1
12/20/2022 16:00	0.0	12.3	2,199.8	0.0	0.0	1	1	1
12/20/2022 17:00	0.0	12.0	2,266.0	0.0	0.0	1	1	1
12/20/2022 18:00	0.0	12.0	2,265.9	0.0	0.0	1	1	1
12/20/2022 19:00	0.0	12.0	2,259.4	0.0	0.0	1	1	1
12/20/2022 20:00	0.0	12.0	2,259.9	0.0	0.0	1	1	1
12/20/2022 21:00	0.0	12.4	2,168.4	0.0	0.0	1	1	1
12/20/2022 22:00	0.0	12.4	2,167.9	0.0	0.0	1	1	1
12/20/2022 23:00	0.0	12.2	2,226.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,166.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,961.4	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,291.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	0.0	12.0	2,286.1	0.0	0.0	1	1	1
12/21/2022 01:00	0.0	12.0	2,284.9	0.0	0.0	1	1	1
12/21/2022 02:00	0.0	12.0	2,281.3	0.0	0.0	1	1	1
12/21/2022 03:00	0.0	12.0	2,289.0	0.0	0.0	1	1	1
12/21/2022 04:00	0.0	12.0	2,282.4	0.0	0.0	1	1	1
12/21/2022 05:00	0.0	12.0	2,284.7	0.0	0.0	1	1	1
12/21/2022 06:00	0.0	12.0	2,284.5	0.0	0.0	1	1	1
12/21/2022 07:00	0.0	12.0	2,283.3	0.0	0.0	1	1	1
12/21/2022 08:00	0.0	0.0	2,268.8	0.0	0.0	1	1	1
12/21/2022 09:00	0.1	12.2	2,259.9	0.0	0.3	1	1	1
12/21/2022 10:00	0.1	12.2	2,253.9	0.0	0.3	1	1	1
12/21/2022 11:00	0.1	12.3	2,219.0	0.1	0.3	1	1	1
12/21/2022 12:00	0.1	12.2	2,236.9	0.1	0.3	1	1	1
12/21/2022 13:00	0.1	12.1	2,229.8	0.1	0.3	1	1	1
12/21/2022 14:00	0.1	12.5	2,160.3	0.1	0.3	1	1	1
12/21/2022 15:00	0.1	12.1	2,234.3	0.1	0.3	1	1	1
12/21/2022 16:00	0.0	12.0	2,257.4	0.1	0.0	1	1	1
12/21/2022 17:00	0.1	12.0	2,255.2	0.1	0.3	1	1	1
12/21/2022 18:00	0.1	12.0	2,258.5	0.1	0.3	1	1	1
12/21/2022 19:00	0.0	12.0	2,256.4	0.1	0.0	1	1	1
12/21/2022 20:00	0.1	12.1	2,252.8	0.1	0.3	1	1	1
12/21/2022 21:00	0.1	12.1	2,253.7	0.1	0.3	1	1	1
12/21/2022 22:00	0.1	12.1	2,250.9	0.1	0.3	1	1	1
12/21/2022 23:00	0.1	12.1	2,248.9	0.1	0.3	1	1	1
Average/Sum#:	0.1	12.1	2,257.2	0.1	3.9 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,160.3	0.0	0.0	1	1	1
Maximum:	0.1	12.5	2,289.0	0.1	0.3	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2022 00:00	0.2	12.4	2,185.3	0.1	0.7	1	1	1
12/22/2022 01:00	0.3	13.2	1,981.3	0.1	1.0	1	1	1
12/22/2022 02:00	0.3	13.2	1,968.8	0.2	1.0	1	1	1
12/22/2022 03:00	0.3	13.2	1,968.0	0.2	1.0	1	1	1
12/22/2022 04:00	0.3	12.8	2,091.8	0.2	1.0	1	1	1
12/22/2022 05:00	0.1	12.4	2,221.8	0.2	0.3	1	1	1
12/22/2022 06:00	0.1	12.1	2,268.5	0.1	0.3	1	1	1
12/22/2022 07:00	0.1	12.1	2,266.2	0.1	0.3	1	1	1
12/22/2022 08:00	0.1	12.2	2,248.9	0.1	0.3	1	1	1
12/22/2022 09:00	0.2	12.6	2,149.4	0.1	0.7	1	1	1
12/22/2022 10:00	0.2	12.6	2,146.2	0.1	0.7	1	1	1
12/22/2022 11:00	0.2	12.6	2,143.8	0.1	0.7	1	1	1
12/22/2022 12:00	0.2	12.6	2,141.5	0.1	0.7	1	1	1
12/22/2022 13:00	0.1	12.6	2,143.3	0.1	0.3	1	1	1
12/22/2022 14:00	0.2	12.6	2,149.6	0.1	0.7	1	1	1
12/22/2022 15:00	0.1	12.3	2,214.6	0.1	0.3	1	1	1
12/22/2022 16:00	0.1	12.3	2,209.7	0.1	0.3	1	1	1
12/22/2022 17:00	0.1	12.1	2,256.5	0.1	0.3	1	1	1
12/22/2022 18:00	0.1	12.1	2,261.1	0.1	0.3	1	1	1
12/22/2022 19:00	0.1	12.1	2,267.4	0.1	0.3	1	1	1
12/22/2022 20:00	0.1	12.1	2,262.7	0.1	0.3	1	1	1
12/22/2022 21:00	0.0	12.1	2,260.5	0.1	0.0	1	1	1
12/22/2022 22:00	0.1	12.3	2,215.3	0.1	0.3	1	1	1
12/22/2022 23:00	0.2	12.8	2,077.3	0.1	0.7	1	1	1
Average/Sum#:	0.2	12.5	2,170.8	0.1	12.5 #	24 #	24 #	24 #
Minimum:	0.0	12.1	1,968.0	0.1	0.0	1	1	1
Maximum:	0.3	13.2	2,268.5	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2022 00:00	0.1	12.3	2,228.2	0.1	0.3	1	1	1
12/23/2022 01:00	0.1	12.1	2,265.3	0.1	0.3	1	1	1
12/23/2022 02:00	0.1	12.1	2,261.5	0.1	0.3	1	1	1
12/23/2022 03:00	0.1	12.1	2,261.6	0.1	0.3	1	1	1
12/23/2022 04:00	0.1	12.1	2,262.1	0.1	0.3	1	1	1
12/23/2022 05:00	0.1	12.1	2,259.9	0.1	0.3	1	1	1
12/23/2022 06:00	0.1	12.1	2,259.7	0.1	0.3	1	1	1
12/23/2022 07:00	0.1	12.2	2,240.1	0.1	0.3	1	1	1
12/23/2022 08:00	0.1	12.4	2,187.9	0.1	0.3	1	1	1
12/23/2022 09:00	0.1	12.4	2,182.4	0.1	0.3	1	1	1
12/23/2022 10:00	0.1	12.5	2,137.6	0.1	0.3	1	1	1
12/23/2022 11:00	0.1	12.5	2,141.7	0.1	0.3	1	1	1
12/23/2022 12:00	0.2	12.9	2,027.4	0.1	0.7	1	1	1
12/23/2022 13:00	0.2	13.2	1,960.0	0.1	0.7	1	1	1
12/23/2022 14:00	0.2	13.2	1,953.8	0.2	0.7	1	1	1
12/23/2022 15:00	0.2	12.8	2,064.7	0.2	0.7	1	1	1
12/23/2022 16:00	0.0	12.0	2,253.1	0.1	0.0	1	1	1
12/23/2022 17:00	0.0	12.0	2,254.2	0.0	0.0	1	1	1
12/23/2022 18:00	0.0	12.0	2,260.1	0.0	0.0	1	1	1
12/23/2022 19:00	0.0	12.0	2,252.4	0.0	0.0	1	1	1
12/23/2022 20:00	0.0	12.0	2,248.8	0.0	0.0	1	1	1
12/23/2022 21:00	0.0	12.0	2,253.2	0.0	0.0	1	1	1
12/23/2022 22:00	0.0	12.0	2,252.2	0.0	0.0	1	1	1
12/23/2022 23:00	0.0	12.0	2,242.9	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.3	2,196.3	0.1	6.4 #	24 #	24 #	24 #
Minimum:	0.0	12.0	1,953.8	0.0	0.0	1	1	1
Maximum:	0.2	13.2	2,265.3	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2022 00:00	0.1	12.5	2,130.9	0.0	0.3	1	1	1
12/24/2022 01:00	0.1	12.6	2,124.1	0.1	0.3	1	1	1
12/24/2022 02:00	0.2	13.2	1,963.2	0.1	0.7	1	1	1
12/24/2022 03:00	0.2	13.2	1,955.6	0.2	0.7	1	1	1
12/24/2022 04:00	0.2	13.2	1,955.0	0.2	0.7	1	1	1
12/24/2022 05:00	0.2	13.2	1,953.0	0.2	0.7	1	1	1
12/24/2022 06:00	0.2	13.1	1,979.9	0.2	0.7	1	1	1
12/24/2022 07:00	0.2	13.0	2,010.1	0.2	0.7	1	1	1
12/24/2022 08:00	0.2	13.4	1,837.3	0.2	0.6	1	1	1
12/24/2022 09:00	0.0	13.9	1,316.3	0.1	0.0	1	1	0
12/24/2022 10:00	0.1	13.9	1,548.3	0.1	0.3	1	1	0
12/24/2022 11:00	0.1	13.9	1,547.9	0.1	0.3	1	1	0
12/24/2022 12:00	0.1	13.9	1,552.0	0.1	0.3	1	1	0
12/24/2022 13:00	0.0	13.9	1,554.4	0.1	0.0	1	1	0
12/24/2022 14:00	0.0	13.9	1,730.3	0.0	0.0	1	1	0
12/24/2022 15:00	0.0	13.9	1,734.3	0.0	0.0	1	1	0
12/24/2022 16:00	0.0	13.9	1,590.2	0.0	0.0	1	1	1
12/24/2022 17:00	0.3	13.1	1,969.4	0.1	1.0	1	1	1
12/24/2022 18:00	0.2	13.1	1,965.8	0.1	0.7	1	1	1
12/24/2022 19:00	0.1	13.1	1,965.9	0.2	0.3	1	1	1
12/24/2022 20:00	0.1	13.1	1,967.3	0.1	0.3	1	1	1
12/24/2022 21:00	0.1	13.1	1,962.5	0.1	0.3	1	1	1
12/24/2022 22:00	0.1	13.2	1,965.3	0.1	0.3	1	1	1
12/24/2022 23:00	0.1	13.1	1,967.2	0.1	0.3	1	1	1
Average/Sum#:	0.1	13.4	1,843.6	0.1	9.5 #	24 #	24 #	17 #
Minimum:	0.0	12.5	1,316.3	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,130.9	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2022 00:00	0.1	13.1	1,946.8	0.1	0.3	1	1	1
12/25/2022 01:00	16.2	15.6	592.2	0.0	5.3	1	0	0
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/25/2022 18:00	42.7	17.7	345.3	0.0	43.8	1	0	0
12/25/2022 19:00	16.8	17.3	411.1	0.0	25.3	1	0	0
12/25/2022 20:00	27.2	15.9	780.4	0.0	56.1	1	0	0
12/25/2022 21:00	0.1	13.9	1,417.5	0.0	0.3	1	1	0
12/25/2022 22:00	0.0	13.9	1,455.7	0.0	0.0	1	1	0
12/25/2022 23:00	0.1	13.9	1,477.4	0.1	0.3	1	1	0
Average/Sum#:	12.9	15.2	1,053.3	0.1	131.4 #	8 #	4 #	1 #
Minimum:	0.0	13.1	345.3	0.1	0.0	0	0	0
Maximum:	42.7	17.7	1,946.8	0.1	56.1	1	1	1
%SI	66.67	66.67	66.67	91.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	0.1	13.8	1,763.9	0.1	0.3	1	1	0
12/26/2022 01:00	0.1	13.8	1,543.0	0.1	0.3	1	1	0
12/26/2022 02:00	0.1	13.8	1,700.6	0.1	0.3	1	1	0
12/26/2022 03:00	0.1	13.8	1,721.9	0.1	0.3	1	1	0
12/26/2022 04:00	0.1	13.8	1,721.7	0.1	0.3	1	1	0
12/26/2022 05:00	0.1	13.8	1,737.5	0.1	0.3	1	1	0
12/26/2022 06:00	0.1	13.8	1,736.8	0.1	0.3	1	1	0
12/26/2022 07:00	0.1	13.8	1,728.0	0.1	0.3	1	1	0
12/26/2022 08:00	0.1	13.8	1,734.8	0.1	0.3	1	1	0
12/26/2022 09:00	0.1	13.9	1,548.8	0.1	0.3	1	1	0
12/26/2022 10:00	0.1	13.9	1,544.0	0.1	0.3	1	1	0
12/26/2022 11:00	0.1	13.9	1,535.6	0.1	0.3	1	1	0
12/26/2022 12:00	0.1	13.9	1,526.6	0.1	0.3	1	1	0
12/26/2022 13:00	0.1	13.9	1,547.1	0.1	0.3	1	1	0
12/26/2022 14:00	0.1	13.8	1,610.5	0.1	0.3	1	1	0
12/26/2022 15:00	0.1	13.8	1,740.0	0.1	0.3	1	1	0
12/26/2022 16:00	0.1	13.8	1,774.3	0.1	0.3	1	1	1
12/26/2022 17:00	0.3	12.6	2,122.6	0.1	1.0	1	1	1
12/26/2022 18:00	0.2	12.4	2,163.9	0.1	0.7	1	1	1
12/26/2022 19:00	0.3	13.0	2,015.8	0.2	1.0	1	1	1
12/26/2022 20:00	0.3	13.1	2,000.4	0.2	1.0	1	1	1
12/26/2022 21:00	0.3	13.2	1,969.8	0.2	1.0	1	1	1
12/26/2022 22:00	0.3	13.2	1,947.6	0.2	1.0	1	1	1
12/26/2022 23:00	13.9	15.6	609.2	0.0	4.9	1	0	0
Average/Sum#:	0.7	13.7	1,710.2	0.1	15.7 #	24 #	23 #	7 #
Minimum:	0.1	12.4	609.2	0.1	0.3	1	0	0
Maximum:	13.9	15.6	2,163.9	0.2	4.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/27/2022 01:00	6.6	18.8	198.2	0.0	1.6	1	0	0
12/27/2022 02:00	20.5	16.0	756.8	0.0	41.8	1	0	0
12/27/2022 03:00	0.0	13.8	1,538.4	0.0	0.0	1	1	0
12/27/2022 04:00	0.0	13.9	1,539.3	0.0	0.0	1	1	0
12/27/2022 05:00	0.0	13.8	1,685.4	0.0	0.0	1	1	0
12/27/2022 06:00	0.0	13.9	1,397.3	0.0	0.0	1	1	0
12/27/2022 07:00	0.0	13.8	1,731.2	0.0	0.0	1	1	0
12/27/2022 08:00	0.1	13.8	1,701.6	0.0	0.3	1	1	1
12/27/2022 09:00	0.3	12.9	1,972.8	0.1	1.0	1	1	1
12/27/2022 10:00	0.3	12.9	1,967.9	0.2	1.0	1	1	1
12/27/2022 11:00	0.2	12.9	1,970.4	0.2	0.7	1	1	1
12/27/2022 12:00	0.2	12.9	1,969.6	0.1	0.7	1	1	1
12/27/2022 13:00	0.2	12.9	1,969.2	0.1	0.7	1	1	1
12/27/2022 14:00	0.2	12.9	1,970.6	0.1	0.7	1	1	1
12/27/2022 15:00	0.2	12.9	1,970.8	0.1	0.7	1	1	1
12/27/2022 16:00	0.2	13.0	1,970.5	0.1	0.7	1	1	1
12/27/2022 17:00	0.2	13.0	1,962.5	0.1	0.7	1	1	1
12/27/2022 18:00	0.2	13.1	1,960.1	0.1	0.7	1	1	1
12/27/2022 19:00	0.2	13.1	1,959.5	0.2	0.7	1	1	1
12/27/2022 20:00	0.2	13.1	1,971.6	0.2	0.7	1	1	1
12/27/2022 21:00	0.2	13.1	1,972.6	0.2	0.7	1	1	1
12/27/2022 22:00	0.2	13.2	1,945.8	0.2	0.7	1	1	1
12/27/2022 23:00	0.0	14.0	1,392.3	0.1	0.0	1	1	0
Average/Sum#:	1.3	13.6	1,716.3	0.1	54.1 #	23 #	21 #	15 #
Minimum:	0.0	12.9	198.2	0.0	0.0	0	0	0
Maximum:	20.5	18.8	1,972.8	0.2	41.8	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2022 00:00	0.0	13.9	1,539.7	0.1	0.0	1	1	0
12/28/2022 01:00	0.0	13.9	1,465.2	0.0	0.0	1	1	0
12/28/2022 02:00	0.0	13.9	1,520.9	0.0	0.0	1	1	0
12/28/2022 03:00	0.0	13.9	1,518.1	0.0	0.0	1	1	0
12/28/2022 04:00	0.0	13.9	1,528.2	0.0	0.0	1	1	0
12/28/2022 05:00	0.1	13.8	1,718.9	0.0	0.3	1	1	0
12/28/2022 06:00	0.0	13.8	1,735.9	0.0	0.0	1	1	0
12/28/2022 07:00	0.1	13.8	1,738.4	0.1	0.3	1	1	0
12/28/2022 08:00	0.0	13.8	1,716.3	0.0	0.0	1	1	0
12/28/2022 09:00	0.1	13.8	1,707.8	0.1	0.3	1	1	0
12/28/2022 10:00	0.1	13.9	1,547.7	0.1	0.3	1	1	0
12/28/2022 11:00	0.0	13.9	1,563.0	0.1	0.0	1	1	0
12/28/2022 12:00	0.0	13.9	1,545.4	0.0	0.0	1	1	0
12/28/2022 13:00	0.0	13.9	1,525.3	0.0	0.0	1	1	0
12/28/2022 14:00	0.0	13.9	1,549.1	0.0	0.0	1	1	0
12/28/2022 15:00	0.1	13.9	1,592.4	0.0	0.3	1	1	1
12/28/2022 16:00	0.3	12.6	2,095.4	0.1	1.0	1	1	1
12/28/2022 17:00	0.3	13.1	1,976.0	0.2	1.0	1	1	1
12/28/2022 18:00	0.3	13.2	1,956.1	0.2	1.0	1	1	1
12/28/2022 19:00	0.3	13.2	1,957.5	0.2	1.0	1	1	1
12/28/2022 20:00	0.3	13.2	1,959.0	0.2	1.0	1	1	1
12/28/2022 21:00	0.3	13.1	1,970.4	0.2	1.0	1	1	1
12/28/2022 22:00	0.3	13.2	1,956.0	0.2	1.0	1	1	1
12/28/2022 23:00	0.3	13.2	1,960.9	0.2	1.0	1	1	1
Average/Sum#:	0.1	13.6	1,722.7	0.1	9.5 #	24 #	24 #	9 #
Minimum:	0.0	12.6	1,465.2	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,095.4	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2022 00:00	0.3	13.2	1,956.9	0.2	1.0	1	1	1
12/29/2022 01:00	0.3	13.2	1,961.0	0.2	1.0	1	1	1
12/29/2022 02:00	0.3	13.2	1,965.0	0.2	1.0	1	1	1
12/29/2022 03:00	0.3	13.2	1,964.8	0.2	1.0	1	1	1
12/29/2022 04:00	0.3	13.2	1,969.1	0.2	1.0	1	1	1
12/29/2022 05:00	0.3	12.9	2,038.0	0.2	1.0	1	1	1
12/29/2022 06:00	0.3	12.6	2,047.5	0.2	1.0	1	1	1
12/29/2022 07:00	0.3	12.8	2,051.3	0.2	1.0	1	1	1
12/29/2022 08:00	0.2	12.2	2,206.4	0.2	0.7	1	1	1
12/29/2022 09:00	0.1	11.9	2,259.5	0.1	0.3	1	1	1
12/29/2022 10:00	0.1	12.4	2,161.9	0.1	0.3	1	1	1
12/29/2022 11:00	0.3	12.9	2,024.3	0.1	1.0	1	1	1
12/29/2022 12:00	0.3	13.1	1,986.2	0.2	1.0	1	1	1
12/29/2022 13:00	0.3	13.2	1,975.5	0.2	1.0	1	1	1
12/29/2022 14:00	0.3	13.1	1,985.1	0.2	1.0	1	1	1
12/29/2022 15:00	0.3	13.1	1,989.5	0.2	1.0	1	1	1
12/29/2022 16:00	0.3	12.7	2,100.3	0.2	1.0	1	1	1
12/29/2022 17:00	0.1	12.3	2,176.8	0.2	0.3	1	1	1
12/29/2022 18:00	0.2	12.6	2,085.5	0.1	0.7	1	1	1
12/29/2022 19:00	0.4	13.2	1,968.4	0.2	1.4	1	1	1
12/29/2022 20:00	0.4	13.2	1,977.8	0.2	1.4	1	1	1
12/29/2022 21:00	0.3	13.1	1,989.3	0.3	1.0	1	1	1
12/29/2022 22:00	0.4	13.1	1,972.1	0.3	1.3	1	1	1
12/29/2022 23:00	0.4	13.1	1,943.3	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	2,031.5	0.2	22.7 #	24 #	24 #	24 #
Minimum:	0.1	11.9	1,943.3	0.1	0.3	1	1	1
Maximum:	0.4	13.2	2,259.5	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2022 00:00	16.1	15.9	561.7	0.0	5.5	1	0	0
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	16.1	15.9	561.7	0.0	5.5 #	1 #	0 #	0 #
Minimum:	16.1	15.9	561.7	0.0	5.5	0	0	0
Maximum:	16.1	15.9	561.7	0.0	5.5	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:24 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:24 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/01/2022 00:00	10.7	13.1	8.1	192.6	3,294,378.6	2,165.1	2.0	1.7
10/01/2022 01:00	16.4	14.7	15.6	173.5	2,438,985.1	1,211.1	2.4	1.1
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.6	13.9	11.9	183.1	2,866,681.9	1,688.1	2.2	1.4
Minimum:	10.7	13.1	8.1	173.5	2,438,985.1	1,211.1	2.0	1.1
Maximum:	16.4	14.7	15.6	192.6	3,294,378.6	2,165.1	2.4	1.7
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2022 02:00	37.1	17.5	64.4	39.0	1,353,313.5	336.0	0.0	0.0
10/03/2022 03:00	33.3	15.6	37.1	244.5	2,199,954.9	867.5	3.6	1.2
10/03/2022 04:00	10.1	13.9	8.5	145.7	3,301,470.0	1,711.7	1.5	1.0
10/03/2022 05:00	10.4	13.9	8.8	151.1	3,287,004.3	1,704.2	1.6	1.0
10/03/2022 06:00	10.6	13.9	8.9	146.4	3,281,989.5	1,701.6	1.5	1.0
10/03/2022 07:00	11.0	13.9	9.3	149.4	3,295,490.8	1,708.6	1.5	1.0
10/03/2022 08:00	10.7	13.9	9.0	148.8	3,315,164.3	1,718.8	1.5	1.0
10/03/2022 09:00	10.3	13.9	8.7	160.2	3,327,122.6	1,725.0	1.6	1.0
10/03/2022 10:00	11.3	13.7	9.3	206.3	3,380,913.2	1,728.2	2.1	1.4
10/03/2022 11:00	11.3	13.8	9.4	115.1	3,381,108.8	1,728.3	1.1	0.7
10/03/2022 12:00	11.2	13.8	9.3	123.1	3,381,304.4	1,728.4	1.2	0.9
10/03/2022 13:00	11.1	13.8	9.2	122.2	3,385,021.4	1,730.3	1.2	0.9
10/03/2022 14:00	11.1	13.8	9.2	120.8	3,373,870.4	1,724.6	1.2	0.9
10/03/2022 15:00	10.5	13.7	8.6	176.9	3,312,881.5	1,766.0	1.8	1.2
10/03/2022 16:00	11.3	13.3	8.8	192.2	3,282,000.7	2,061.1	2.0	1.6
10/03/2022 17:00	11.3	13.2	8.7	216.5	3,268,861.2	2,172.2	2.3	2.0
10/03/2022 18:00	11.3	13.1	8.5	222.5	3,249,511.5	2,206.8	2.4	2.0
10/03/2022 19:00	11.4	13.1	8.6	210.7	3,271,419.4	2,173.9	2.2	1.7
10/03/2022 20:00	11.3	13.1	8.5	222.0	3,255,657.6	2,187.2	2.4	2.0
10/03/2022 21:00	11.3	13.1	8.5	218.0	3,272,322.3	2,174.5	2.3	2.0
10/03/2022 22:00	11.1	13.2	8.5	210.0	3,311,852.9	2,152.4	2.2	1.7
10/03/2022 23:00	11.1	13.2	8.5	210.2	3,304,573.2	2,171.8	2.2	1.7
Average/Sum#:	13.2	13.8	12.7	170.5	3,172,400.4	1,780.9	1.8	1.3
Minimum:	10.1	13.1	8.5	39.0	1,353,313.5	336.0	0.0	0.0
Maximum:	37.1	17.5	64.4	244.5	3,385,021.4	2,206.8	3.6	2.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/04/2022 00:00	11.0	13.2	8.4	208.6	3,315,084.1	2,154.5	2.2	1.7
10/04/2022 01:00	11.0	13.2	8.4	214.8	3,321,238.8	2,158.5	2.3	1.9
10/04/2022 02:00	11.0	13.2	8.4	215.2	3,317,853.7	2,156.3	2.3	1.9
10/04/2022 03:00	11.0	13.2	8.4	213.0	3,333,086.6	2,166.2	2.2	1.7
10/04/2022 04:00	10.8	13.2	8.3	207.6	3,344,472.9	2,173.6	2.2	1.7
10/04/2022 05:00	10.7	13.2	8.2	238.1	3,313,104.1	2,201.6	2.5	2.2
10/04/2022 06:00	10.9	13.2	8.4	205.2	3,333,856.0	2,166.7	2.1	1.7
10/04/2022 07:00	10.6	13.3	8.2	183.2	3,358,884.5	2,035.8	1.9	1.4
10/04/2022 08:00	10.7	13.8	8.9	157.4	3,033,845.6	1,595.1	1.8	1.1
10/04/2022 09:00	11.1	13.8	9.2	142.7	2,985,538.0	1,547.9	1.6	0.9
10/04/2022 10:00	11.5	13.7	9.4	142.0	2,957,956.7	1,555.2	1.6	0.9
10/04/2022 11:00	11.5	13.7	9.4	142.9	2,974,694.1	1,564.0	1.6	0.9
10/04/2022 12:00	10.9	13.7	8.9	153.5	3,276,728.2	1,722.8	1.6	1.0
10/04/2022 13:00	10.5	13.6	8.5	154.7	3,369,748.4	1,747.1	1.5	1.0
10/04/2022 14:00	11.2	13.3	8.7	168.0	3,436,917.1	2,032.9	1.6	1.2
10/04/2022 15:00	11.3	13.2	8.7	159.1	3,308,467.8	2,150.2	1.6	1.3
10/04/2022 16:00	11.2	13.2	8.6	157.3	3,316,963.7	2,131.5	1.6	1.3
10/04/2022 17:00	11.2	13.2	8.6	161.5	3,298,466.4	2,143.7	1.7	1.5
10/04/2022 18:00	11.2	13.1	8.5	163.5	3,300,617.1	2,169.2	1.7	1.5
10/04/2022 19:00	11.2	13.1	8.5	166.1	3,324,962.4	2,185.2	1.7	1.5
10/04/2022 20:00	11.3	13.1	8.5	179.4	3,303,846.8	2,243.7	1.9	1.6
10/04/2022 21:00	11.1	13.1	8.4	164.2	3,332,874.6	2,190.4	1.7	1.5
10/04/2022 22:00	11.0	13.1	8.3	163.7	3,313,854.9	2,177.9	1.7	1.5
10/04/2022 23:00	10.8	13.2	8.3	156.5	3,376,024.6	2,144.8	1.6	1.3
Average/Sum#:	11.0	13.3	8.6	175.8	3,272,878.6	2,021.5	1.8	1.4
Minimum:	10.5	13.1	8.2	142.0	2,957,956.7	1,547.9	1.5	0.9
Maximum:	11.5	13.8	9.4	238.1	3,436,917.1	2,243.7	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/05/2022 00:00	10.8	13.2	8.3	152.8	3,363,274.8	2,136.7	1.5	1.3
10/05/2022 01:00	10.7	13.3	8.3	138.9	3,379,096.9	1,998.7	1.4	1.0
10/05/2022 02:00	10.8	13.3	8.4	137.8	3,416,800.5	1,971.1	1.3	1.0
10/05/2022 03:00	10.8	13.2	8.3	144.5	3,399,759.1	2,085.4	1.4	1.0
10/05/2022 04:00	10.8	13.2	8.3	150.2	3,361,618.4	2,111.1	1.5	1.3
10/05/2022 05:00	10.9	13.2	8.4	174.5	3,347,938.3	2,200.3	1.8	1.5
10/05/2022 06:00	11.1	13.1	8.4	163.0	3,349,612.0	2,201.4	1.7	1.5
10/05/2022 07:00	10.7	13.3	8.3	140.1	3,398,226.6	1,985.2	1.4	1.0
10/05/2022 08:00	10.6	13.7	8.7	121.3	3,361,154.3	1,718.1	1.2	0.9
10/05/2022 09:00	10.8	13.8	9.0	114.0	3,292,291.9	1,682.9	1.1	0.7
10/05/2022 10:00	11.3	13.7	9.3	128.3	3,346,677.6	1,710.7	1.3	0.9
10/05/2022 11:00	11.2	13.7	9.2	203.2	3,369,566.5	1,722.4	2.1	1.4
10/05/2022 12:00	11.2	13.7	9.2	153.0	3,353,932.5	1,738.9	1.5	1.0
10/05/2022 13:00	11.5	13.2	8.8	147.2	3,351,867.6	2,080.5	1.5	1.2
10/05/2022 14:00	11.5	13.1	8.7	171.0	3,296,249.6	2,190.4	1.8	1.5
10/05/2022 15:00	11.4	13.2	8.7	164.6	3,325,678.2	2,137.1	1.7	1.5
10/05/2022 16:00	11.4	13.2	8.7	168.8	3,285,249.1	2,159.1	1.8	1.5
10/05/2022 17:00	11.4	13.1	8.6	173.7	3,272,031.2	2,198.2	1.8	1.5
10/05/2022 18:00	11.5	13.1	8.7	180.0	3,284,998.8	2,230.9	1.9	1.6
10/05/2022 19:00	11.4	13.1	8.6	176.9	3,299,576.5	2,240.8	1.8	1.6
10/05/2022 20:00	11.3	13.1	8.5	170.2	3,333,331.1	2,190.7	1.7	1.5
10/05/2022 21:00	11.3	13.1	8.5	174.1	3,295,159.0	2,237.8	1.8	1.6
10/05/2022 22:00	11.1	13.1	8.4	163.2	3,333,394.4	2,166.4	1.7	1.5
10/05/2022 23:00	11.1	13.1	8.4	162.0	3,348,165.7	2,176.0	1.7	1.5
Average/Sum#:	11.1	13.3	8.6	157.2	3,340,235.4	2,053.0	1.6	1.3
Minimum:	10.6	13.1	8.3	114.0	3,272,031.2	1,682.9	1.1	0.7
Maximum:	11.5	13.8	9.3	203.2	3,416,800.5	2,240.8	2.1	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/06/2022 00:00	10.8	13.2	8.3	159.0	3,370,184.5	2,165.7	1.6	1.3
10/06/2022 01:00	10.9	13.2	8.4	160.4	3,373,296.9	2,167.7	1.6	1.3
10/06/2022 02:00	11.0	13.2	8.4	157.0	3,369,095.2	2,165.0	1.6	1.3
10/06/2022 03:00	11.0	13.2	8.4	157.5	3,370,987.7	2,141.6	1.6	1.3
10/06/2022 04:00	10.8	13.2	8.3	163.4	3,356,320.7	2,181.3	1.7	1.5
10/06/2022 05:00	11.1	13.1	8.4	169.4	3,314,301.5	2,250.8	1.7	1.6
10/06/2022 06:00	11.4	13.1	8.6	172.5	3,368,633.5	2,238.5	1.8	1.6
10/06/2022 07:00	11.1	13.2	8.5	152.9	3,362,015.6	2,135.9	1.5	1.3
10/06/2022 08:00	11.0	13.2	8.4	150.9	3,355,734.2	2,082.9	1.5	1.2
10/06/2022 09:00	11.0	13.2	8.4	145.9	3,376,772.3	2,071.3	1.5	1.2
10/06/2022 10:00	11.1	13.2	8.5	150.1	3,394,216.2	2,082.0	1.5	1.2
10/06/2022 11:00	11.2	13.2	8.6	155.8	3,367,032.4	2,114.5	1.6	1.3
10/06/2022 12:00	11.3	13.2	8.7	158.0	3,325,055.8	2,136.7	1.6	1.3
10/06/2022 13:00	11.3	13.1	8.5	169.6	3,299,259.4	2,192.4	1.8	1.5
10/06/2022 14:00	11.1	13.1	8.4	173.7	3,307,084.6	2,197.6	1.8	1.5
10/06/2022 15:00	11.0	13.2	8.4	162.7	3,309,391.0	2,150.8	1.7	1.5
10/06/2022 16:00	11.1	13.2	8.5	171.8	3,297,905.0	2,191.5	1.8	1.5
10/06/2022 17:00	11.1	13.1	8.4	181.9	3,298,545.8	2,240.1	1.9	1.6
10/06/2022 18:00	11.1	13.1	8.4	175.8	3,332,762.2	2,239.0	1.8	1.6
10/06/2022 19:00	11.1	13.1	8.4	181.4	3,320,633.3	2,255.1	1.9	1.6
10/06/2022 20:00	11.0	13.1	8.3	177.1	3,327,112.3	2,259.5	1.8	1.6
10/06/2022 21:00	11.0	13.1	8.3	178.6	3,342,288.6	2,245.4	1.8	1.6
10/06/2022 22:00	10.9	13.2	8.4	162.2	3,369,861.1	2,190.1	1.6	1.3
10/06/2022 23:00	10.8	13.2	8.3	160.3	3,375,008.6	2,168.8	1.6	1.3
Average/Sum#:	11.1	13.2	8.4	164.5	3,345,145.8	2,177.7	1.7	1.4
Minimum:	10.8	13.1	8.3	145.9	3,297,905.0	2,071.3	1.5	1.2
Maximum:	11.4	13.2	8.7	181.9	3,394,216.2	2,259.5	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/07/2022 00:00	10.8	13.2	8.3	155.6	3,374,608.0	2,143.9	1.6	1.3
10/07/2022 01:00	10.8	13.2	8.3	155.0	3,399,792.8	2,159.9	1.5	1.3
10/07/2022 02:00	11.0	13.2	8.4	156.3	3,370,987.7	2,141.6	1.6	1.3
10/07/2022 03:00	11.0	13.2	8.4	153.9	3,367,350.9	2,114.7	1.5	1.3
10/07/2022 04:00	11.0	13.2	8.4	155.5	3,393,024.4	2,155.6	1.6	1.3
10/07/2022 05:00	10.9	13.2	8.4	159.0	3,372,169.1	2,191.6	1.6	1.3
10/07/2022 06:00	11.3	13.1	8.5	167.1	3,392,171.9	2,204.6	1.7	1.5
10/07/2022 07:00	11.0	13.2	8.4	152.4	3,400,683.5	2,110.8	1.5	1.3
10/07/2022 08:00	11.0	13.3	8.5	144.4	3,390,160.4	2,030.0	1.4	1.0
10/07/2022 09:00	11.1	13.2	8.5	154.2	3,387,892.2	2,127.6	1.5	1.3
10/07/2022 10:00	11.1	13.2	8.5	152.8	3,387,733.0	2,127.5	1.5	1.3
10/07/2022 11:00	11.1	13.2	8.5	155.9	3,361,459.2	2,111.0	1.6	1.3
10/07/2022 12:00	11.2	13.2	8.6	167.5	3,336,779.5	2,168.6	1.7	1.5
10/07/2022 13:00	11.1	13.2	8.5	159.4	3,325,367.0	2,136.9	1.6	1.3
10/07/2022 14:00	11.3	13.2	8.7	171.6	3,320,549.8	2,182.3	1.8	1.5
10/07/2022 15:00	11.2	13.1	8.5	171.7	3,300,162.3	2,193.0	1.8	1.5
10/07/2022 16:00	11.3	13.2	8.7	170.3	3,315,832.9	2,179.2	1.8	1.5
10/07/2022 17:00	11.3	13.1	8.5	180.6	3,283,526.3	2,229.9	1.9	1.6
10/07/2022 18:00	11.2	13.1	8.5	180.7	3,303,257.8	2,243.3	1.9	1.6
10/07/2022 19:00	11.2	13.1	8.5	184.5	3,325,345.3	2,258.3	1.9	1.6
10/07/2022 20:00	11.2	13.1	8.5	180.2	3,331,529.8	2,262.5	1.9	1.6
10/07/2022 21:00	11.1	13.1	8.4	183.4	3,336,094.5	2,265.6	1.9	1.6
10/07/2022 22:00	11.0	13.1	8.3	176.7	3,360,001.8	2,257.3	1.8	1.6
10/07/2022 23:00	11.0	13.2	8.4	166.4	3,361,859.9	2,184.9	1.7	1.5
Average/Sum#:	11.1	13.2	8.5	164.8	3,354,097.5	2,174.2	1.7	1.4
Minimum:	10.8	13.1	8.3	144.4	3,283,526.3	2,030.0	1.4	1.0
Maximum:	11.3	13.3	8.7	184.5	3,400,683.5	2,265.6	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/08/2022 00:00	10.9	13.2	8.4	162.7	3,382,011.4	2,173.3	1.6	1.3
10/08/2022 01:00	11.0	13.2	8.4	159.6	3,386,524.3	2,176.2	1.6	1.3
10/08/2022 02:00	10.9	13.2	8.4	159.4	3,372,830.0	2,167.4	1.6	1.3
10/08/2022 03:00	11.0	13.2	8.4	161.5	3,389,792.2	2,178.3	1.6	1.3
10/08/2022 04:00	11.0	13.2	8.4	162.6	3,348,319.6	2,176.1	1.7	1.5
10/08/2022 05:00	11.0	13.2	8.4	158.2	3,377,498.5	2,170.4	1.6	1.3
10/08/2022 06:00	11.1	13.3	8.6	153.5	3,360,503.7	2,110.4	1.5	1.3
10/08/2022 07:00	11.2	13.7	9.2	167.4	3,301,662.9	1,711.8	1.7	1.2
10/08/2022 08:00	11.5	13.9	9.7	126.8	2,671,551.3	1,365.6	1.6	0.8
10/08/2022 09:00	11.2	14.0	9.6	127.9	2,574,126.6	1,315.8	1.7	0.9
10/08/2022 10:00	10.9	14.0	9.3	128.1	2,605,081.8	1,312.6	1.7	0.9
10/08/2022 11:00	10.9	14.0	9.3	125.5	2,617,386.8	1,318.8	1.6	0.8
10/08/2022 12:00	11.5	13.8	9.6	177.1	3,027,778.0	1,569.8	2.0	1.3
10/08/2022 13:00	10.7	13.8	8.9	182.4	3,332,908.9	1,728.0	1.9	1.2
10/08/2022 14:00	10.7	13.7	8.8	178.7	3,319,142.4	1,745.1	1.8	1.2
10/08/2022 15:00	11.4	13.2	8.7	210.1	3,257,656.0	2,069.6	2.2	1.7
10/08/2022 16:00	11.5	13.1	8.7	217.6	3,277,538.6	2,201.9	2.3	2.0
10/08/2022 17:00	11.4	13.1	8.6	224.4	3,276,794.4	2,201.4	2.4	2.0
10/08/2022 18:00	11.2	13.2	8.6	222.8	3,297,269.6	2,167.0	2.4	2.0
10/08/2022 19:00	11.2	13.2	8.6	217.9	3,313,398.4	2,177.6	2.3	2.0
10/08/2022 20:00	11.1	13.2	8.5	215.5	3,317,658.8	2,180.4	2.3	2.0
10/08/2022 21:00	11.2	13.2	8.6	219.5	3,313,854.9	2,177.9	2.3	2.0
10/08/2022 22:00	11.1	13.2	8.5	218.1	3,344,011.3	2,173.3	2.3	2.0
10/08/2022 23:00	10.9	13.2	8.4	213.8	3,377,342.9	2,170.3	2.2	1.7
Average/Sum#:	11.1	13.4	8.8	178.8	3,201,776.8	1,947.5	1.9	1.5
Minimum:	10.7	13.1	8.4	125.5	2,574,126.6	1,312.6	1.5	0.8
Maximum:	11.5	14.0	9.7	224.4	3,389,792.2	2,201.9	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/09/2022 00:00	11.0	13.2	8.4	211.0	3,334,009.8	2,166.8	2.2	1.7
10/09/2022 01:00	10.9	13.2	8.4	207.1	3,372,207.5	2,167.0	2.1	1.7
10/09/2022 02:00	10.8	13.2	8.3	210.4	3,365,950.7	2,138.4	2.2	1.7
10/09/2022 03:00	10.8	13.2	8.3	209.5	3,380,746.8	2,147.8	2.2	1.7
10/09/2022 04:00	11.0	13.2	8.4	216.2	3,359,135.8	2,158.6	2.3	1.9
10/09/2022 05:00	11.0	13.2	8.4	224.4	3,344,507.8	2,149.2	2.4	1.9
10/09/2022 06:00	14.2	13.9	12.0	203.8	2,921,034.2	1,685.1	2.4	1.5
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	22.6	18.0	46.0	167.6	1,304,688.0	209.6	0.0	0.0
10/09/2022 11:00	43.4	15.6	48.3	260.4	2,066,797.3	799.9	3.9	1.2
10/09/2022 12:00	11.0	13.9	9.3	132.0	2,713,416.6	1,387.0	1.6	0.8
10/09/2022 13:00	11.2	13.9	9.4	132.9	2,760,481.7	1,390.9	1.6	0.8
10/09/2022 14:00	11.0	13.7	9.0	199.2	3,283,575.4	1,726.4	2.1	1.4
10/09/2022 15:00	11.4	13.8	9.5	165.5	3,013,312.3	1,562.3	1.9	1.1
10/09/2022 16:00	10.9	13.8	9.1	191.9	3,336,187.8	1,729.7	2.0	1.4
10/09/2022 17:00	11.0	13.5	8.8	184.2	3,341,958.3	1,781.5	1.9	1.2
10/09/2022 18:00	11.4	13.2	8.7	196.8	3,314,803.2	2,081.7	2.1	1.7
10/09/2022 19:00	11.4	13.1	8.6	220.8	3,288,107.0	2,209.0	2.4	2.0
10/09/2022 20:00	11.2	13.2	8.6	212.4	3,293,089.4	2,188.3	2.3	2.0
10/09/2022 21:00	11.1	13.2	8.5	212.6	3,309,137.9	2,174.8	2.2	1.7
10/09/2022 22:00	11.0	13.2	8.4	210.7	3,317,546.0	2,156.1	2.2	1.7
10/09/2022 23:00	11.0	13.2	8.4	210.1	3,341,239.9	2,147.1	2.2	1.7
Average/Sum#:	13.3	13.7	12.5	199.0	3,083,901.6	1,817.0	2.1	1.5
Minimum:	10.8	13.1	8.3	132.0	1,304,688.0	209.6	0.0	0.0
Maximum:	43.4	18.0	48.3	260.4	3,380,746.8	2,209.0	3.9	2.0
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/10/2022 00:00	10.9	13.2	8.4	205.7	3,339,978.9	2,121.9	2.1	1.7
10/10/2022 01:00	10.8	13.3	8.4	195.3	3,371,361.7	2,092.6	2.0	1.7
10/10/2022 02:00	10.7	13.3	8.3	179.8	3,390,694.8	1,980.8	1.8	1.4
10/10/2022 03:00	10.8	13.2	8.3	194.6	3,356,861.9	2,083.6	2.0	1.7
10/10/2022 04:00	10.8	13.2	8.3	203.5	3,387,096.1	2,127.1	2.1	1.7
10/10/2022 05:00	11.0	13.2	8.4	217.8	3,332,065.4	2,214.2	2.3	2.0
10/10/2022 06:00	11.2	13.1	8.5	214.6	3,355,698.4	2,205.4	2.2	1.8
10/10/2022 07:00	10.8	13.5	8.6	191.5	3,273,284.7	1,816.6	2.0	1.5
10/10/2022 08:00	11.4	13.7	9.3	154.6	2,993,060.2	1,551.8	1.8	1.1
10/10/2022 09:00	11.2	13.8	9.3	147.5	3,022,710.9	1,545.1	1.6	0.9
10/10/2022 10:00	11.1	13.9	9.4	127.7	2,760,283.2	1,390.8	1.5	0.8
10/10/2022 11:00	10.8	13.9	9.1	151.0	3,053,033.8	1,560.6	1.7	1.1
10/10/2022 12:00	10.5	13.9	8.9	142.5	3,079,639.8	1,574.2	1.6	0.9
10/10/2022 13:00	10.5	13.8	8.7	177.4	3,336,573.6	1,729.9	1.8	1.2
10/10/2022 14:00	10.7	13.8	8.9	182.1	3,314,392.8	1,718.4	1.9	1.2
10/10/2022 15:00	11.3	13.8	9.4	159.6	3,091,041.6	1,602.6	1.8	1.1
10/10/2022 16:00	11.3	13.3	8.8	196.0	3,255,765.2	1,973.3	2.1	1.6
10/10/2022 17:00	11.3	13.2	8.7	212.1	3,291,183.3	2,163.0	2.2	1.7
10/10/2022 18:00	11.4	13.1	8.6	221.5	3,272,775.4	2,198.7	2.4	2.0
10/10/2022 19:00	11.4	13.1	8.6	223.9	3,264,196.1	2,169.1	2.4	2.0
10/10/2022 20:00	11.2	13.2	8.6	215.6	3,287,531.5	2,160.6	2.3	1.9
10/10/2022 21:00	11.1	13.2	8.5	202.8	3,309,914.5	2,102.8	2.1	1.7
10/10/2022 22:00	10.9	13.3	8.5	202.5	3,359,761.9	2,085.4	2.1	1.7
10/10/2022 23:00	10.7	13.4	8.4	190.9	3,343,620.8	1,953.3	2.0	1.6
Average/Sum#:	11.0	13.4	8.7	187.9	3,243,438.6	1,921.7	2.0	1.5
Minimum:	10.5	13.1	8.3	127.7	2,760,283.2	1,390.8	1.5	0.8
Maximum:	11.4	13.9	9.4	223.9	3,390,694.8	2,214.2	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/11/2022 00:00	11.2	13.9	9.4	131.0	2,692,288.3	1,376.2	1.6	0.8
10/11/2022 01:00	11.1	13.9	9.4	124.4	2,544,194.9	1,300.5	1.6	0.8
10/11/2022 02:00	11.1	13.9	9.4	128.6	2,543,608.0	1,300.2	1.7	0.9
10/11/2022 03:00	11.3	13.9	9.5	139.0	2,645,532.3	1,352.3	1.8	0.9
10/11/2022 04:00	11.1	13.8	9.2	149.0	2,926,068.6	1,495.7	1.7	1.0
10/11/2022 05:00	11.2	13.9	9.4	122.2	2,582,147.5	1,319.9	1.6	0.8
10/11/2022 06:00	11.5	13.9	9.7	129.4	2,570,213.9	1,313.8	1.7	0.9
10/11/2022 07:00	11.4	13.9	9.6	126.4	2,574,322.2	1,315.9	1.7	0.9
10/11/2022 08:00	11.3	13.9	9.5	137.4	2,576,865.4	1,317.2	1.8	0.9
10/11/2022 09:00	11.4	13.8	9.5	147.6	2,895,354.4	1,480.0	1.7	1.0
10/11/2022 10:00	11.3	13.8	9.4	152.2	3,028,579.8	1,548.1	1.7	1.1
10/11/2022 11:00	11.1	13.7	9.1	156.8	3,155,269.5	1,635.9	1.7	1.1
10/11/2022 12:00	10.8	13.5	8.6	188.2	3,381,352.7	1,802.5	1.9	1.3
10/11/2022 13:00	10.9	13.5	8.7	189.6	3,364,844.5	1,793.7	1.9	1.3
10/11/2022 14:00	10.9	13.5	8.7	185.5	3,357,716.0	1,789.9	1.9	1.3
10/11/2022 15:00	10.9	13.5	8.7	183.9	3,353,213.8	1,787.5	1.9	1.3
10/11/2022 16:00	10.9	13.5	8.7	181.4	3,354,714.6	1,788.3	1.9	1.3
10/11/2022 17:00	10.9	13.5	8.7	182.0	3,357,153.3	1,789.6	1.9	1.3
10/11/2022 18:00	10.9	13.5	8.7	184.0	3,365,782.5	1,794.2	1.9	1.3
10/11/2022 19:00	11.1	13.3	8.6	186.3	3,308,727.3	2,005.4	1.9	1.4
10/11/2022 20:00	11.1	13.2	8.5	207.6	3,316,652.5	2,131.3	2.2	1.7
10/11/2022 21:00	10.9	13.3	8.5	195.9	3,278,079.8	2,034.7	2.1	1.6
10/11/2022 22:00	11.0	13.2	8.4	199.9	3,309,599.7	2,102.6	2.1	1.7
10/11/2022 23:00	10.7	13.3	8.3	193.3	3,332,435.1	1,971.1	2.0	1.6
Average/Sum#:	11.1	13.6	9.0	163.4	3,033,946.5	1,647.8	1.8	1.2
Minimum:	10.7	13.2	8.3	122.2	2,543,608.0	1,300.2	1.6	0.8
Maximum:	11.5	13.9	9.7	207.6	3,381,352.7	2,131.3	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/12/2022 00:00	10.7	13.3	8.3	180.5	3,394,265.7	1,958.1	1.8	1.4
10/12/2022 01:00	10.5	13.4	8.3	185.5	3,354,223.0	1,935.0	1.9	1.4
10/12/2022 02:00	11.1	13.8	9.2	147.8	2,931,339.7	1,519.8	1.7	1.1
10/12/2022 03:00	10.2	13.8	8.5	147.7	3,203,279.3	1,637.4	1.6	1.0
10/12/2022 04:00	10.4	13.6	8.4	170.3	3,364,409.4	1,768.9	1.7	1.2
10/12/2022 05:00	10.9	13.3	8.5	201.1	3,279,079.0	2,131.1	2.1	1.7
10/12/2022 06:00	11.3	13.1	8.5	225.8	3,364,020.8	2,260.0	2.4	2.0
10/12/2022 07:00	11.1	13.1	8.4	225.3	3,356,727.1	2,255.1	2.4	2.0
10/12/2022 08:00	11.1	13.1	8.4	223.5	3,345,712.2	2,247.7	2.3	2.0
10/12/2022 09:00	11.0	13.1	8.3	213.3	3,344,521.4	2,246.9	2.2	1.8
10/12/2022 10:00	11.0	13.1	8.3	223.4	3,337,227.7	2,242.0	2.3	2.0
10/12/2022 11:00	11.0	13.1	8.3	226.3	3,343,032.9	2,245.9	2.4	2.0
10/12/2022 12:00	11.0	13.1	8.3	225.0	3,314,154.3	2,250.7	2.4	2.0
10/12/2022 13:00	11.1	13.1	8.4	219.9	3,310,178.5	2,248.0	2.3	2.0
10/12/2022 14:00	11.1	13.1	8.4	227.9	3,312,240.0	2,249.4	2.4	2.0
10/12/2022 15:00	11.2	13.1	8.5	231.7	3,313,712.5	2,250.4	2.5	2.3
10/12/2022 16:00	11.4	13.1	8.6	222.2	3,267,446.6	2,266.7	2.4	2.0
10/12/2022 17:00	11.4	13.1	8.6	236.8	3,279,266.9	2,274.9	2.5	2.3
10/12/2022 18:00	11.4	13.1	8.6	224.6	3,288,238.3	2,233.1	2.4	2.0
10/12/2022 19:00	11.2	13.2	8.6	209.4	3,327,390.0	2,138.2	2.2	1.7
10/12/2022 20:00	11.3	13.2	8.7	220.5	3,304,467.2	2,147.6	2.3	1.9
10/12/2022 21:00	11.3	13.2	8.7	210.7	3,335,571.5	2,119.1	2.2	1.7
10/12/2022 22:00	11.1	13.2	8.5	197.9	3,362,017.4	2,086.8	2.0	1.7
10/12/2022 23:00	11.0	13.3	8.5	198.9	3,368,441.6	1,967.8	2.1	1.6
Average/Sum#:	11.0	13.2	8.5	208.2	3,308,373.5	2,111.7	2.2	1.8
Minimum:	10.2	13.1	8.3	147.7	2,931,339.7	1,519.8	1.6	1.0
Maximum:	11.4	13.8	9.2	236.8	3,394,265.7	2,274.9	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/13/2022 00:00	11.2	13.3	8.7	185.7	3,357,315.1	1,961.3	1.9	1.4
10/13/2022 01:00	11.2	13.3	8.7	197.5	3,348,409.6	2,005.0	2.0	1.6
10/13/2022 02:00	11.1	13.3	8.6	185.5	3,385,945.1	1,953.3	1.9	1.4
10/13/2022 03:00	11.1	13.3	8.6	187.5	3,396,172.5	1,959.2	1.9	1.4
10/13/2022 04:00	10.6	13.4	8.3	173.1	3,338,622.0	1,926.0	1.8	1.3
10/13/2022 05:00	11.4	13.9	9.6	129.1	2,565,127.5	1,311.2	1.7	0.9
10/13/2022 06:00	11.5	13.9	9.7	126.7	2,565,518.8	1,311.4	1.7	0.9
10/13/2022 07:00	11.6	13.9	9.8	135.2	2,621,078.3	1,339.8	1.7	0.9
10/13/2022 08:00	11.0	13.8	9.1	155.8	3,060,952.8	1,587.0	1.7	1.1
10/13/2022 09:00	11.3	13.8	9.4	158.7	2,961,814.2	1,535.6	1.8	1.1
10/13/2022 10:00	10.8	13.5	8.6	188.8	3,384,166.6	1,804.0	1.9	1.3
10/13/2022 11:00	10.9	13.5	8.7	186.2	3,350,093.2	1,810.3	1.9	1.3
10/13/2022 12:00	10.8	13.5	8.6	185.8	3,392,233.0	1,808.3	1.9	1.3
10/13/2022 13:00	10.9	13.5	8.7	188.3	3,380,977.5	1,802.3	1.9	1.3
10/13/2022 14:00	10.9	13.5	8.7	185.0	3,364,094.2	1,793.3	1.9	1.3
10/13/2022 15:00	10.9	13.5	8.7	187.5	3,362,593.4	1,792.5	1.9	1.3
10/13/2022 16:00	10.9	13.5	8.7	188.8	3,359,216.8	1,790.7	1.9	1.3
10/13/2022 17:00	10.9	13.5	8.7	180.7	3,370,659.9	1,796.8	1.8	1.3
10/13/2022 18:00	10.8	13.5	8.6	181.4	3,338,989.8	1,804.3	1.9	1.3
10/13/2022 19:00	10.7	13.5	8.5	178.6	3,343,986.3	1,807.0	1.8	1.3
10/13/2022 20:00	11.0	13.2	8.4	175.7	3,318,195.8	2,059.6	1.8	1.4
10/13/2022 21:00	11.0	13.2	8.4	203.9	3,323,393.0	2,159.9	2.1	1.7
10/13/2022 22:00	10.7	13.3	8.3	190.3	3,357,023.0	2,083.7	2.0	1.7
10/13/2022 23:00	10.6	13.3	8.2	187.5	3,377,098.3	2,071.5	1.9	1.5
Average/Sum#:	11.0	13.5	8.8	176.8	3,234,319.9	1,803.1	1.9	1.3
Minimum:	10.6	13.2	8.2	126.7	2,565,127.5	1,311.2	1.7	0.9
Maximum:	11.6	13.9	9.8	203.9	3,396,172.5	2,159.9	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/14/2022 00:00	10.4	13.3	8.1	177.5	3,400,462.2	2,061.0	1.8	1.4
10/14/2022 01:00	10.4	13.3	8.1	182.0	3,351,014.1	2,055.5	1.9	1.4
10/14/2022 02:00	10.4	13.3	8.1	183.9	3,351,829.2	2,056.0	1.9	1.4
10/14/2022 03:00	10.3	13.3	8.0	183.0	3,347,264.5	2,053.2	1.9	1.4
10/14/2022 04:00	10.4	13.3	8.1	190.5	3,340,917.8	2,098.1	2.0	1.7
10/14/2022 05:00	10.6	13.2	8.1	217.5	3,284,287.6	2,254.4	2.3	2.0
10/14/2022 06:00	11.0	13.1	8.3	212.9	3,294,631.1	2,261.5	2.3	2.0
10/14/2022 07:00	10.8	13.1	8.2	225.1	3,301,186.9	2,266.0	2.4	2.0
10/14/2022 08:00	10.5	13.3	8.2	197.9	3,314,333.1	2,033.0	2.1	1.6
10/14/2022 09:00	10.6	13.3	8.2	176.8	3,369,639.9	1,968.5	1.8	1.4
10/14/2022 10:00	10.8	13.3	8.4	190.1	3,304,153.8	1,978.5	2.0	1.6
10/14/2022 11:00	10.8	13.3	8.4	180.5	3,320,353.1	1,988.2	1.9	1.4
10/14/2022 12:00	10.8	13.3	8.4	193.1	3,328,202.3	1,992.9	2.0	1.6
10/14/2022 13:00	10.8	13.3	8.4	181.3	3,298,002.9	1,998.9	1.9	1.4
10/14/2022 14:00	10.9	13.3	8.5	202.0	3,311,960.7	2,104.1	2.1	1.7
10/14/2022 15:00	10.8	13.2	8.3	212.1	3,302,774.7	2,146.5	2.2	1.7
10/14/2022 16:00	10.8	13.2	8.3	208.8	3,300,620.5	2,145.1	2.2	1.7
10/14/2022 17:00	11.0	13.1	8.3	216.4	3,245,535.8	2,227.8	2.3	2.0
10/14/2022 18:00	10.8	13.2	8.3	215.6	3,276,576.1	2,153.4	2.3	1.9
10/14/2022 19:00	10.8	13.2	8.3	206.7	3,310,272.2	2,127.2	2.2	1.7
10/14/2022 20:00	10.8	13.2	8.3	199.2	3,283,848.9	2,134.2	2.1	1.7
10/14/2022 21:00	10.9	13.2	8.4	200.2	3,302,958.2	2,122.5	2.1	1.7
10/14/2022 22:00	10.7	13.2	8.2	196.7	3,336,459.2	2,095.3	2.1	1.7
10/14/2022 23:00	15.7	14.5	14.5	185.2	2,608,362.2	1,333.3	2.4	1.2
Average/Sum#:	10.9	13.3	8.5	197.3	3,286,902.0	2,069.0	2.1	1.6
Minimum:	10.3	13.1	8.0	176.8	2,608,362.2	1,333.3	1.8	1.2
Maximum:	15.7	14.5	14.5	225.1	3,400,462.2	2,266.0	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 23:00	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Average/Sum#:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Minimum:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
Maximum:	32.6	17.5	56.6	8.5	1,350,870.9	305.8	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/17/2022 00:00	36.4	15.5	39.8	190.2	2,186,686.5	846.3	2.9	0.9
10/17/2022 01:00	10.6	13.8	8.8	190.1	3,286,618.5	1,704.0	2.0	1.4
10/17/2022 02:00	10.9	13.8	9.1	178.0	3,305,906.2	1,714.0	1.8	1.2
10/17/2022 03:00	10.1	13.6	8.2	166.2	3,442,961.1	1,810.2	1.7	1.3
10/17/2022 04:00	10.9	13.3	8.5	199.0	3,323,561.1	2,087.2	2.1	1.7
10/17/2022 05:00	11.0	13.2	8.4	181.5	3,320,397.7	2,182.2	1.9	1.5
10/17/2022 06:00	11.1	13.2	8.5	193.2	3,386,728.2	2,151.6	2.0	1.7
10/17/2022 07:00	10.8	13.3	8.4	199.0	3,384,250.4	2,100.6	2.0	1.7
10/17/2022 08:00	10.7	13.7	8.8	169.2	3,172,937.5	1,691.4	1.8	1.2
10/17/2022 09:00	11.2	13.8	9.3	172.3	3,171,664.0	1,644.4	1.9	1.2
10/17/2022 10:00	11.4	13.8	9.5	150.8	2,981,236.9	1,523.9	1.7	1.1
10/17/2022 11:00	11.3	13.8	9.4	168.6	3,101,842.7	1,608.2	1.9	1.1
10/17/2022 12:00	11.4	13.8	9.5	151.1	2,947,783.8	1,506.8	1.7	1.1
10/17/2022 13:00	11.4	13.8	9.5	152.8	2,960,108.6	1,513.1	1.8	1.1
10/17/2022 14:00	10.6	13.8	8.8	166.4	3,267,446.6	1,670.2	1.7	1.2
10/17/2022 15:00	11.1	13.7	9.1	187.1	3,259,420.2	1,713.7	2.0	1.4
10/17/2022 16:00	11.4	13.2	8.7	191.6	3,361,695.2	2,086.6	2.0	1.7
10/17/2022 17:00	11.4	13.1	8.6	226.8	3,302,668.8	2,242.9	2.4	2.0
10/17/2022 18:00	11.3	13.1	8.5	231.9	3,328,437.5	2,260.4	2.4	2.0
10/17/2022 19:00	11.2	13.1	8.5	218.0	3,328,296.7	2,236.0	2.3	2.0
10/17/2022 20:00	11.1	13.1	8.4	229.0	3,338,865.0	2,243.1	2.4	2.0
10/17/2022 21:00	11.1	13.1	8.4	228.3	3,322,400.3	2,256.3	2.4	2.0
10/17/2022 22:00	11.0	13.2	8.4	213.7	3,358,013.2	2,182.4	2.2	1.7
10/17/2022 23:00	11.0	13.2	8.4	218.7	3,355,243.6	2,180.6	2.3	2.0
Average/Sum#:	12.1	13.5	10.1	190.6	3,216,465.4	1,881.5	2.1	1.5
Minimum:	10.1	13.1	8.2	150.8	2,186,686.5	846.3	1.7	0.9
Maximum:	36.4	15.5	39.8	231.9	3,442,961.1	2,260.4	2.9	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/18/2022 00:00	10.8	13.2	8.3	213.5	3,347,242.5	2,175.4	2.2	1.7
10/18/2022 01:00	10.5	13.2	8.0	199.4	3,370,651.4	2,166.0	2.1	1.7
10/18/2022 02:00	10.6	13.2	8.1	204.1	3,337,241.1	2,168.9	2.1	1.7
10/18/2022 03:00	10.6	13.2	8.1	210.5	3,337,439.4	2,193.4	2.2	1.8
10/18/2022 04:00	10.5	13.2	8.0	210.9	3,336,526.4	2,192.8	2.2	1.8
10/18/2022 05:00	10.5	13.2	8.0	192.3	3,344,780.6	2,173.8	2.0	1.7
10/18/2022 06:00	10.7	13.2	8.2	201.7	3,384,052.3	2,149.9	2.1	1.7
10/18/2022 07:00	10.6	13.2	8.1	204.8	3,342,640.4	2,148.0	2.1	1.7
10/18/2022 08:00	10.8	13.2	8.3	209.1	3,373,608.1	2,167.9	2.2	1.7
10/18/2022 09:00	10.8	13.2	8.3	213.4	3,370,028.9	2,165.6	2.2	1.7
10/18/2022 10:00	10.9	13.2	8.4	214.5	3,358,237.8	2,133.5	2.2	1.7
10/18/2022 11:00	10.9	13.3	8.5	201.2	3,356,363.6	2,107.8	2.1	1.7
10/18/2022 12:00	10.9	13.3	8.5	211.4	3,352,701.2	2,105.5	2.2	1.7
10/18/2022 13:00	10.9	13.3	8.5	208.6	3,358,592.9	2,109.2	2.2	1.7
10/18/2022 14:00	11.0	13.3	8.5	203.1	3,332,580.8	2,117.2	2.1	1.7
10/18/2022 15:00	11.0	13.3	8.5	218.5	3,344,663.4	2,149.3	2.3	1.9
10/18/2022 16:00	11.1	13.2	8.5	220.0	3,333,059.9	2,239.2	2.3	2.0
10/18/2022 17:00	11.0	13.2	8.4	221.9	3,351,742.3	2,202.8	2.3	2.0
10/18/2022 18:00	11.0	13.2	8.4	233.3	3,348,093.8	2,249.3	2.5	2.2
10/18/2022 19:00	11.0	13.2	8.4	222.0	3,345,076.7	2,271.7	2.3	2.0
10/18/2022 20:00	11.0	13.1	8.3	235.4	3,353,470.0	2,277.4	2.5	2.3
10/18/2022 21:00	11.0	13.1	8.3	223.4	3,354,206.2	2,277.9	2.3	2.1
10/18/2022 22:00	10.9	13.2	8.4	225.3	3,351,894.4	2,202.9	2.4	2.0
10/18/2022 23:00	10.9	13.2	8.4	222.2	3,349,916.4	2,201.6	2.3	2.0
Average/Sum#:	10.8	13.2	8.3	213.4	3,351,450.4	2,181.1	2.2	1.8
Minimum:	10.5	13.1	8.0	192.3	3,332,580.8	2,105.5	2.0	1.7
Maximum:	11.1	13.3	8.5	235.4	3,384,052.3	2,277.9	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/19/2022 00:00	10.8	13.2	8.3	213.4	3,368,784.0	2,189.4	2.2	1.8
10/19/2022 01:00	10.5	13.3	8.2	198.2	3,411,961.1	2,117.8	2.0	1.7
10/19/2022 02:00	10.4	13.4	8.2	190.2	3,374,816.0	2,070.1	2.0	1.7
10/19/2022 03:00	10.3	13.3	8.0	195.8	3,352,701.2	2,105.5	2.0	1.7
10/19/2022 04:00	10.4	13.3	8.1	204.4	3,329,257.4	2,139.4	2.1	1.7
10/19/2022 05:00	10.5	13.3	8.2	243.7	3,276,794.4	2,201.4	2.6	2.2
10/19/2022 06:00	11.0	13.2	8.4	215.0	3,381,869.6	2,222.6	2.2	1.8
10/19/2022 07:00	10.8	13.3	8.4	215.8	3,387,200.4	2,151.9	2.2	1.7
10/19/2022 08:00	10.8	13.3	8.4	200.7	3,408,592.8	2,140.6	2.0	1.7
10/19/2022 09:00	10.9	13.3	8.5	209.8	3,385,700.4	2,101.5	2.2	1.7
10/19/2022 10:00	10.9	13.3	8.5	199.3	3,371,039.5	2,092.4	2.1	1.7
10/19/2022 11:00	11.0	13.3	8.5	210.8	3,339,821.4	2,121.8	2.2	1.7
10/19/2022 12:00	11.1	13.3	8.6	216.6	3,324,744.5	2,136.5	2.3	1.9
10/19/2022 13:00	11.1	13.3	8.6	211.7	3,314,468.6	2,154.1	2.2	1.7
10/19/2022 14:00	11.1	13.3	8.6	222.6	3,338,127.6	2,145.1	2.3	1.9
10/19/2022 15:00	11.2	13.2	8.6	221.4	3,288,123.4	2,185.0	2.4	2.0
10/19/2022 16:00	11.3	13.2	8.7	227.2	3,274,263.9	2,199.7	2.4	2.0
10/19/2022 17:00	11.1	13.2	8.5	219.5	3,306,693.0	2,124.9	2.3	1.9
10/19/2022 18:00	11.1	13.3	8.6	204.5	3,319,831.0	2,109.1	2.1	1.7
10/19/2022 19:00	11.0	13.3	8.5	216.6	3,330,219.7	2,115.7	2.3	1.9
10/19/2022 20:00	11.0	13.2	8.4	210.9	3,353,066.7	2,154.7	2.2	1.7
10/19/2022 21:00	10.8	13.3	8.4	204.6	3,376,108.8	2,120.2	2.1	1.7
10/19/2022 22:00	10.9	13.3	8.5	207.9	3,371,039.5	2,092.4	2.1	1.7
10/19/2022 23:00	10.9	13.3	8.5	204.3	3,361,777.6	2,111.2	2.1	1.7
Average/Sum#:	10.9	13.3	8.4	211.0	3,347,791.8	2,137.6	2.2	1.8
Minimum:	10.3	13.2	8.0	190.2	3,274,263.9	2,070.1	2.0	1.7
Maximum:	11.3	13.4	8.7	243.7	3,411,961.1	2,222.6	2.6	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/20/2022 00:00	10.8	13.3	8.4	204.9	3,390,440.0	2,129.2	2.1	1.7
10/20/2022 01:00	10.8	13.3	8.4	208.3	3,366,206.2	2,089.4	2.2	1.7
10/20/2022 02:00	10.9	13.3	8.5	195.6	3,396,498.5	2,083.4	2.0	1.7
10/20/2022 03:00	10.9	13.3	8.5	208.5	3,373,133.9	2,093.7	2.2	1.7
10/20/2022 04:00	10.8	13.3	8.4	205.1	3,396,490.9	2,133.0	2.1	1.7
10/20/2022 05:00	10.8	13.3	8.4	227.9	3,314,759.4	2,202.7	2.4	2.0
10/20/2022 06:00	11.2	13.2	8.6	217.2	3,379,093.1	2,196.1	2.2	1.8
10/20/2022 07:00	10.8	13.3	8.4	196.8	3,409,701.7	2,066.6	2.0	1.7
10/20/2022 08:00	10.9	13.3	8.5	197.2	3,395,512.5	2,058.0	2.0	1.6
10/20/2022 09:00	11.0	13.3	8.5	203.5	3,379,054.7	2,072.7	2.1	1.7
10/20/2022 10:00	11.0	13.3	8.5	195.4	3,372,044.5	2,068.4	2.0	1.7
10/20/2022 11:00	11.1	13.3	8.6	209.4	3,363,467.4	2,087.7	2.2	1.7
10/20/2022 12:00	11.0	13.3	8.5	199.2	3,327,701.3	2,089.8	2.1	1.7
10/20/2022 13:00	11.0	13.3	8.5	213.3	3,351,586.6	2,104.8	2.2	1.7
10/20/2022 14:00	11.0	13.3	8.5	210.6	3,333,682.6	2,117.9	2.2	1.7
10/20/2022 15:00	11.0	13.3	8.5	210.2	3,344,974.7	2,149.5	2.2	1.7
10/20/2022 16:00	11.3	13.1	8.5	237.0	3,286,181.5	2,255.7	2.5	2.3
10/20/2022 17:00	11.2	13.2	8.6	218.0	3,286,618.5	2,184.0	2.3	2.0
10/20/2022 18:00	11.1	13.2	8.5	230.4	3,321,449.5	2,231.4	2.4	2.0
10/20/2022 19:00	10.9	13.3	8.5	205.0	3,329,590.1	2,115.3	2.1	1.7
10/20/2022 20:00	10.9	13.3	8.5	207.4	3,322,349.5	2,110.7	2.2	1.7
10/20/2022 21:00	10.7	13.3	8.3	204.4	3,361,856.3	2,086.7	2.1	1.7
10/20/2022 22:00	10.8	13.3	8.4	195.8	3,364,595.2	2,088.4	2.0	1.7
10/20/2022 23:00	10.6	13.3	8.2	196.6	3,344,858.4	2,125.0	2.0	1.7
Average/Sum#:	10.9	13.3	8.5	208.2	3,354,660.3	2,122.5	2.2	1.8
Minimum:	10.6	13.1	8.2	195.4	3,286,181.5	2,058.0	2.0	1.6
Maximum:	11.3	13.3	8.6	237.0	3,409,701.7	2,255.7	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/21/2022 00:00	10.3	13.4	8.1	180.1	3,286,787.6	1,944.1	1.9	1.4
10/21/2022 01:00	10.3	13.8	8.6	144.9	3,097,442.3	1,583.3	1.6	0.9
10/21/2022 02:00	10.7	13.8	8.9	155.3	3,126,004.6	1,597.9	1.7	1.1
10/21/2022 03:00	11.0	13.8	9.1	152.2	3,027,210.4	1,547.4	1.7	1.1
10/21/2022 04:00	10.2	13.8	8.5	160.9	3,342,569.3	1,708.6	1.6	1.0
10/21/2022 05:00	10.2	13.8	8.5	163.8	3,346,481.9	1,710.6	1.7	1.2
10/21/2022 06:00	10.3	13.8	8.6	139.3	3,147,328.5	1,608.8	1.5	1.0
10/21/2022 07:00	10.5	13.8	8.7	156.8	3,280,358.3	1,676.8	1.6	1.0
10/21/2022 08:00	9.8	13.8	8.1	145.5	3,358,415.5	1,716.7	1.5	1.0
10/21/2022 09:00	9.5	13.8	7.9	146.9	3,366,436.4	1,720.8	1.5	1.0
10/21/2022 10:00	9.7	13.8	8.1	145.2	3,363,893.2	1,719.5	1.5	1.0
10/21/2022 11:00	9.8	13.9	8.3	141.1	3,293,270.0	1,683.4	1.4	0.8
10/21/2022 12:00	10.2	13.8	8.5	158.4	3,203,681.6	1,661.0	1.7	1.2
10/21/2022 13:00	10.7	13.8	8.9	169.8	3,150,833.3	1,633.6	1.8	1.1
10/21/2022 14:00	10.8	13.8	9.0	181.1	3,263,666.2	1,692.1	1.9	1.2
10/21/2022 15:00	11.3	13.7	9.3	156.8	3,025,463.5	1,568.6	1.8	1.1
10/21/2022 16:00	11.5	13.2	8.8	203.7	3,304,090.5	2,099.1	2.1	1.7
10/21/2022 17:00	11.4	13.2	8.7	219.2	3,285,113.7	2,183.0	2.3	2.0
10/21/2022 18:00	11.2	13.2	8.6	208.3	3,296,927.7	2,142.7	2.2	1.7
10/21/2022 19:00	11.1	13.2	8.5	211.6	3,340,758.6	2,098.0	2.2	1.7
10/21/2022 20:00	11.1	13.2	8.5	206.1	3,328,173.5	2,114.4	2.2	1.7
10/21/2022 21:00	11.1	13.2	8.5	211.3	3,309,898.7	2,175.3	2.2	1.7
10/21/2022 22:00	16.4	14.7	15.6	181.9	2,442,338.6	1,230.6	2.5	1.2
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.7	8.9	171.3	3,216,832.3	1,774.6	1.8	1.3
Minimum:	9.5	13.2	7.9	139.3	2,442,338.6	1,230.6	1.4	0.8
Maximum:	16.4	14.7	15.6	219.2	3,366,436.4	2,183.0	2.5	2.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 12:00	6.1	19.7	30.0	11.1	0.0	2.2	0.0	0.0
10/24/2022 13:00	48.3	17.0	73.1	88.9	1,508,824.8	429.7	0.0	0.0
10/24/2022 14:00	22.5	14.0	19.2	217.4	3,166,391.1	1,572.3	2.3	1.4
10/24/2022 15:00	10.4	13.7	8.5	176.1	3,369,735.0	1,771.7	1.8	1.2
10/24/2022 16:00	10.3	13.7	8.4	161.4	3,368,023.2	1,770.8	1.6	1.1
10/24/2022 17:00	10.3	13.7	8.4	169.1	3,384,950.8	1,779.7	1.7	1.2
10/24/2022 18:00	10.3	13.7	8.4	159.1	3,407,584.3	1,791.6	1.6	1.1
10/24/2022 19:00	10.4	13.7	8.5	167.9	3,422,990.4	1,799.7	1.7	1.3
10/24/2022 20:00	10.3	13.7	8.4	159.6	3,434,972.8	1,806.0	1.6	1.1
10/24/2022 21:00	10.2	13.7	8.4	164.8	3,449,998.5	1,813.9	1.6	1.1
10/24/2022 22:00	10.2	13.7	8.4	160.2	3,443,721.9	1,810.6	1.6	1.1
10/24/2022 23:00	10.1	13.7	8.3	159.0	3,466,735.9	1,822.7	1.6	1.1
Average/Sum#:	14.1	14.5	16.5	149.6	2,951,994.1	1,514.2	1.4	1.0
Minimum:	6.1	13.7	8.3	11.1	0.0	2.2	0.0	0.0
Maximum:	48.3	19.7	73.1	217.4	3,466,735.9	1,822.7	2.3	1.4
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/25/2022 00:00	9.6	13.7	7.9	148.0	3,441,249.4	1,809.3	1.5	1.1
10/25/2022 01:00	9.6	13.7	7.9	144.3	3,432,690.5	1,804.8	1.4	0.9
10/25/2022 02:00	9.5	13.7	7.8	144.3	3,480,266.7	1,804.4	1.4	0.9
10/25/2022 03:00	9.4	13.7	7.7	145.0	3,476,409.2	1,802.4	1.4	0.9
10/25/2022 04:00	9.4	13.7	7.7	143.6	3,481,424.0	1,805.0	1.4	0.9
10/25/2022 05:00	9.4	13.7	7.7	153.5	3,487,403.1	1,808.1	1.5	1.1
10/25/2022 06:00	9.7	13.7	7.9	144.2	3,487,596.0	1,808.2	1.4	0.9
10/25/2022 07:00	9.8	13.7	8.0	154.5	3,486,631.6	1,807.7	1.5	1.1
10/25/2022 08:00	9.9	13.7	8.1	153.4	3,446,574.9	1,812.1	1.5	1.1
10/25/2022 09:00	10.2	13.6	8.2	162.1	3,453,802.4	1,815.9	1.6	1.1
10/25/2022 10:00	10.2	13.6	8.2	160.9	3,451,710.2	1,814.8	1.6	1.1
10/25/2022 11:00	10.2	13.6	8.2	174.6	3,480,049.7	1,829.7	1.7	1.3
10/25/2022 12:00	10.3	13.6	8.3	166.6	3,484,994.9	1,832.3	1.6	1.1
10/25/2022 13:00	10.5	13.6	8.5	175.0	3,445,321.7	1,836.6	1.7	1.3
10/25/2022 14:00	10.6	13.6	8.6	178.5	3,435,942.1	1,831.6	1.8	1.3
10/25/2022 15:00	10.5	13.6	8.5	172.1	3,437,442.8	1,832.4	1.7	1.3
10/25/2022 16:00	10.5	13.6	8.5	169.9	3,434,816.5	1,831.0	1.7	1.3
10/25/2022 17:00	10.5	13.6	8.5	175.8	3,440,819.5	1,834.2	1.8	1.3
10/25/2022 18:00	10.3	13.6	8.3	162.5	3,473,202.6	1,826.1	1.6	1.1
10/25/2022 19:00	10.1	13.6	8.2	162.3	3,451,710.2	1,814.8	1.6	1.1
10/25/2022 20:00	10.2	13.6	8.2	165.7	3,438,016.0	1,807.6	1.7	1.3
10/25/2022 21:00	9.9	13.7	8.1	152.5	3,442,200.3	1,809.8	1.5	1.1
10/25/2022 22:00	9.8	13.7	8.0	149.1	3,432,119.9	1,804.5	1.5	1.1
10/25/2022 23:00	10.7	13.8	8.9	147.5	3,199,562.3	1,635.5	1.6	1.0
Average/Sum#:	10.0	13.7	8.2	158.6	3,446,748.2	1,809.1	1.6	1.1
Minimum:	9.4	13.6	7.7	143.6	3,199,562.3	1,635.5	1.4	0.9
Maximum:	10.7	13.8	8.9	178.5	3,487,596.0	1,836.6	1.8	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/26/2022 00:00	10.6	13.8	8.8	150.1	3,145,625.7	1,630.9	1.6	1.0
10/26/2022 01:00	10.5	13.8	8.7	143.7	3,192,519.5	1,631.9	1.5	1.0
10/26/2022 02:00	10.6	13.8	8.8	150.2	3,186,650.5	1,628.9	1.6	1.0
10/26/2022 03:00	10.6	13.8	8.8	149.1	3,162,196.5	1,616.4	1.6	1.0
10/26/2022 04:00	9.5	13.7	7.8	144.8	3,461,364.8	1,794.6	1.4	0.9
10/26/2022 05:00	9.8	13.8	8.1	156.9	3,391,868.6	1,733.8	1.6	1.0
10/26/2022 06:00	10.4	13.8	8.6	149.4	3,309,703.1	1,691.8	1.5	1.0
10/26/2022 07:00	9.8	13.8	8.1	138.6	3,361,261.8	1,742.7	1.4	0.9
10/26/2022 08:00	22.9	15.8	26.5	182.1	1,830,546.9	735.2	3.2	0.9
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	33.0	17.9	64.9	10.2	1,264,610.7	240.1	0.0	0.0
10/26/2022 17:00	42.6	17.3	69.8	56.4	1,625,050.3	391.6	0.0	0.0
10/26/2022 18:00	52.9	15.3	55.7	266.8	2,061,606.2	828.0	4.2	1.3
10/26/2022 19:00	10.3	13.6	8.3	193.7	3,471,300.6	1,825.1	1.9	1.3
10/26/2022 20:00	9.9	13.7	8.1	170.6	3,462,171.1	1,820.3	1.7	1.3
10/26/2022 21:00	10.2	13.7	8.4	170.5	3,442,961.1	1,810.2	1.7	1.3
10/26/2022 22:00	10.6	13.7	8.7	160.8	3,356,040.7	1,764.5	1.6	1.1
10/26/2022 23:00	15.1	14.5	13.9	135.5	2,490,640.6	1,164.0	1.8	0.8
Average/Sum#:	17.0	14.5	19.5	148.8	2,895,065.8	1,414.7	1.7	0.9
Minimum:	9.5	13.6	7.8	10.2	1,264,610.7	240.1	0.0	0.0
Maximum:	52.9	17.9	69.8	266.8	3,471,300.6	1,825.1	4.2	1.3
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/31/2022 01:00	35.5	17.5	61.6	31.7	1,280,839.7	299.3	0.0	0.0
10/31/2022 02:00	44.6	15.9	52.6	265.1	2,026,189.1	725.0	4.1	1.2
10/31/2022 03:00	10.2	13.8	8.5	169.6	3,303,205.9	1,712.6	1.8	1.2
10/31/2022 04:00	10.3	13.8	8.6	165.3	3,329,630.0	1,726.3	1.7	1.2
10/31/2022 05:00	10.6	13.8	8.8	182.2	3,300,698.5	1,711.3	1.9	1.2
10/31/2022 06:00	10.9	13.8	9.1	159.1	3,265,016.3	1,692.8	1.6	1.0
10/31/2022 07:00	10.9	13.8	9.1	164.8	3,266,559.3	1,693.6	1.7	1.2
10/31/2022 08:00	10.6	13.8	8.8	154.8	3,287,582.9	1,704.5	1.6	1.0
10/31/2022 09:00	10.3	13.8	8.6	151.7	3,339,047.9	1,706.8	1.5	1.0
10/31/2022 10:00	10.4	13.8	8.6	161.5	3,342,178.0	1,708.4	1.6	1.0
10/31/2022 11:00	10.2	13.8	8.5	144.8	3,304,225.4	1,689.0	1.5	1.0
10/31/2022 12:00	10.0	13.9	8.4	145.0	3,302,073.5	1,687.9	1.5	1.0
10/31/2022 13:00	9.8	13.9	8.3	143.4	3,331,222.6	1,702.8	1.5	1.0
10/31/2022 14:00	10.6	13.7	8.7	177.5	3,362,127.1	1,767.7	1.8	1.2
10/31/2022 15:00	11.2	13.3	8.7	191.8	3,394,868.3	2,082.4	2.0	1.7
10/31/2022 16:00	11.1	13.3	8.6	195.9	3,352,860.4	2,105.6	2.0	1.7
10/31/2022 17:00	11.0	13.3	8.5	204.1	3,345,101.0	2,076.3	2.1	1.7
10/31/2022 18:00	11.0	13.3	8.5	192.2	3,354,928.6	2,082.4	2.0	1.7
10/31/2022 19:00	11.0	13.3	8.5	209.0	3,389,083.7	2,103.6	2.1	1.7
10/31/2022 20:00	10.6	13.3	8.2	184.1	3,365,561.8	2,089.0	1.9	1.5
10/31/2022 21:00	10.6	13.3	8.2	194.4	3,353,200.9	2,130.3	2.0	1.7
10/31/2022 22:00	10.4	13.3	8.1	194.5	3,338,688.5	2,096.7	2.0	1.7
10/31/2022 23:00	10.6	13.3	8.2	203.5	3,363,589.6	2,136.9	2.1	1.7
Average/Sum#:	13.1	13.9	12.8	173.3	3,186,890.4	1,757.9	1.8	1.3
Minimum:	9.8	13.3	8.1	31.7	1,280,839.7	299.3	0.0	0.0
Maximum:	44.6	17.5	61.6	265.1	3,394,868.3	2,136.9	4.1	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/01/2022 00:00	10.5	13.3	8.2	196.6	3,390,820.7	2,154.2	2.0	1.7
11/01/2022 01:00	10.5	13.3	8.2	196.4	3,384,681.9	2,150.3	2.0	1.7
11/01/2022 02:00	10.6	13.2	8.1	204.9	3,397,589.1	2,158.5	2.1	1.7
11/01/2022 03:00	10.7	13.2	8.2	195.3	3,412,227.8	2,167.8	2.0	1.7
11/01/2022 04:00	10.6	13.2	8.1	201.4	3,424,820.2	2,175.8	2.0	1.7
11/01/2022 05:00	10.7	13.2	8.2	193.9	3,386,835.5	2,176.4	2.0	1.7
11/01/2022 06:00	11.1	13.2	8.5	212.9	3,386,240.4	2,250.2	2.2	1.8
11/01/2022 07:00	10.8	13.2	8.3	211.6	3,365,398.9	2,187.2	2.2	1.7
11/01/2022 08:00	10.9	13.1	8.2	215.3	3,334,548.4	2,240.2	2.3	2.0
11/01/2022 09:00	10.7	13.2	8.2	194.4	3,335,256.7	2,118.9	2.0	1.7
11/01/2022 10:00	10.6	13.2	8.1	196.5	3,380,567.4	2,123.0	2.0	1.7
11/01/2022 11:00	10.7	13.2	8.2	208.0	3,359,705.8	2,183.5	2.2	1.7
11/01/2022 12:00	10.7	13.2	8.2	205.2	3,331,353.1	2,189.4	2.2	1.8
11/01/2022 13:00	10.6	13.3	8.2	210.1	3,355,705.2	2,180.9	2.2	1.7
11/01/2022 14:00	10.6	13.4	8.3	202.5	3,366,850.7	2,089.8	2.1	1.7
11/01/2022 15:00	10.6	13.3	8.2	195.0	3,443,524.9	2,087.1	2.0	1.7
11/01/2022 16:00	10.7	13.3	8.3	215.2	3,430,096.8	2,204.2	2.2	1.8
11/01/2022 17:00	10.5	13.2	8.0	221.4	3,378,060.7	2,294.1	2.3	2.1
11/01/2022 18:00	10.3	13.3	8.0	204.1	3,402,708.4	2,186.6	2.1	1.7
11/01/2022 19:00	10.3	13.3	8.0	200.0	3,452,541.8	2,168.2	2.0	1.7
11/01/2022 20:00	10.4	13.3	8.1	212.0	3,437,877.7	2,209.2	2.2	1.8
11/01/2022 21:00	10.3	13.3	8.0	181.6	3,444,349.8	2,087.6	1.8	1.5
11/01/2022 22:00	10.1	13.4	7.9	179.0	3,465,478.7	2,075.1	1.8	1.5
11/01/2022 23:00	9.6	13.7	7.9	163.9	3,332,025.8	1,849.2	1.7	1.3
Average/Sum#:	10.5	13.3	8.2	200.7	3,391,636.1	2,154.5	2.1	1.7
Minimum:	9.6	13.1	7.9	163.9	3,331,353.1	1,849.2	1.7	1.3
Maximum:	11.1	13.7	8.5	221.4	3,465,478.7	2,294.1	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/02/2022 00:00	11.0	13.9	9.3	123.0	2,648,466.8	1,353.8	1.6	0.8
11/02/2022 01:00	10.8	13.8	9.0	158.0	3,207,387.5	1,639.5	1.7	1.1
11/02/2022 02:00	10.8	13.8	9.0	169.2	3,297,998.2	1,709.9	1.7	1.2
11/02/2022 03:00	11.2	13.9	9.4	122.7	2,648,466.8	1,353.8	1.6	0.8
11/02/2022 04:00	11.0	13.8	9.1	167.3	3,246,885.9	1,683.4	1.8	1.2
11/02/2022 05:00	9.9	13.7	8.1	166.4	3,367,203.9	1,917.9	1.7	1.3
11/02/2022 06:00	10.6	13.3	8.2	181.3	3,537,027.6	2,169.6	1.8	1.5
11/02/2022 07:00	10.2	13.3	7.9	186.6	3,555,994.3	2,129.3	1.8	1.5
11/02/2022 08:00	10.1	13.5	8.1	177.7	3,473,031.4	2,028.9	1.8	1.4
11/02/2022 09:00	10.4	13.8	8.6	164.2	3,316,321.5	1,719.4	1.7	1.2
11/02/2022 10:00	11.1	13.8	9.2	146.4	3,031,905.6	1,549.8	1.6	0.9
11/02/2022 11:00	10.8	13.8	9.0	164.9	3,283,879.7	1,678.6	1.7	1.2
11/02/2022 12:00	10.8	13.8	9.0	145.2	3,049,121.2	1,558.6	1.6	0.9
11/02/2022 13:00	10.6	13.8	8.8	139.8	3,056,555.2	1,562.4	1.5	0.9
11/02/2022 14:00	10.7	13.8	8.9	138.9	3,020,950.2	1,544.2	1.5	0.9
11/02/2022 15:00	10.5	13.8	8.7	154.2	3,154,958.1	1,612.7	1.7	1.1
11/02/2022 16:00	10.4	13.4	8.2	177.8	3,433,130.4	2,080.8	1.8	1.5
11/02/2022 17:00	10.4	13.3	8.1	196.5	3,459,229.7	2,172.4	2.0	1.7
11/02/2022 18:00	10.3	13.3	8.0	191.8	3,487,682.2	2,164.8	1.9	1.5
11/02/2022 19:00	10.4	13.3	8.1	190.0	3,488,326.7	2,165.2	1.9	1.5
11/02/2022 20:00	10.4	13.3	8.1	195.8	3,490,904.4	2,166.8	1.9	1.5
11/02/2022 21:00	10.4	13.3	8.1	193.3	3,509,802.1	2,152.9	1.9	1.5
11/02/2022 22:00	10.3	13.3	8.0	186.5	3,485,426.7	2,163.4	1.9	1.5
11/02/2022 23:00	10.4	13.3	8.1	194.8	3,506,209.7	2,176.3	1.9	1.5
Average/Sum#:	10.6	13.6	8.5	168.0	3,281,536.1	1,852.3	1.8	1.3
Minimum:	9.9	13.3	7.9	122.7	2,648,466.8	1,353.8	1.5	0.8
Maximum:	11.2	13.9	9.4	196.5	3,555,994.3	2,176.3	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/03/2022 00:00	10.4	13.3	8.1	195.4	3,492,354.4	2,167.7	1.9	1.5
11/03/2022 01:00	10.3	13.3	8.0	186.0	3,510,780.3	2,153.5	1.8	1.5
11/03/2022 02:00	10.2	13.3	7.9	194.0	3,502,701.0	2,199.7	1.9	1.5
11/03/2022 03:00	10.3	13.3	8.0	211.8	3,490,476.0	2,243.0	2.1	1.8
11/03/2022 04:00	10.1	13.3	7.8	191.3	3,496,543.2	2,170.3	1.9	1.5
11/03/2022 05:00	10.2	13.3	7.9	228.1	3,504,920.9	2,175.5	2.3	2.0
11/03/2022 06:00	10.6	13.3	8.2	208.9	3,496,389.4	2,246.8	2.1	1.8
11/03/2022 07:00	10.3	13.4	8.1	190.2	3,494,012.1	2,117.7	1.9	1.5
11/03/2022 08:00	10.6	13.9	8.9	127.9	2,858,575.6	1,461.2	1.5	0.9
11/03/2022 09:00	10.9	13.8	9.1	151.3	3,066,532.5	1,567.5	1.7	1.1
11/03/2022 10:00	10.8	13.8	9.0	150.8	3,094,312.2	1,581.7	1.7	1.1
11/03/2022 11:00	10.8	13.8	9.0	143.5	3,082,574.3	1,575.7	1.6	0.9
11/03/2022 12:00	10.8	13.8	9.0	144.3	3,105,854.5	1,587.6	1.6	1.0
11/03/2022 13:00	10.8	13.9	9.1	138.1	2,928,220.6	1,496.8	1.6	0.9
11/03/2022 14:00	10.7	13.9	9.0	143.9	3,060,076.6	1,564.2	1.6	0.9
11/03/2022 15:00	10.0	13.8	8.3	157.7	3,447,091.9	1,787.2	1.6	1.1
11/03/2022 16:00	10.6	13.4	8.3	188.2	3,476,667.9	2,081.8	1.9	1.5
11/03/2022 17:00	10.5	13.4	8.3	194.1	3,483,815.6	2,162.4	1.9	1.5
11/03/2022 18:00	10.5	13.3	8.2	208.9	3,468,465.3	2,178.2	2.1	1.7
11/03/2022 19:00	10.5	13.3	8.2	211.9	3,464,962.2	2,176.0	2.1	1.7
11/03/2022 20:00	10.4	13.3	8.1	199.9	3,446,172.4	2,164.2	2.0	1.7
11/03/2022 21:00	10.4	13.3	8.1	211.2	3,445,694.7	2,163.9	2.1	1.7
11/03/2022 22:00	10.4	13.4	8.2	210.6	3,444,739.3	2,163.3	2.1	1.7
11/03/2022 23:00	10.2	13.3	7.9	203.6	3,455,617.9	2,220.6	2.1	1.8
Average/Sum#:	10.5	13.5	8.4	183.0	3,346,564.6	1,975.3	1.9	1.4
Minimum:	10.0	13.3	7.8	127.9	2,858,575.6	1,461.2	1.5	0.9
Maximum:	10.9	13.9	9.1	228.1	3,510,780.3	2,246.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/04/2022 00:00	10.0	13.3	7.8	197.4	3,502,465.9	2,148.4	2.0	1.7
11/04/2022 01:00	10.1	13.4	7.9	190.8	3,499,291.8	2,120.9	1.9	1.5
11/04/2022 02:00	10.1	13.4	7.9	179.7	3,500,147.3	2,070.3	1.8	1.4
11/04/2022 03:00	10.0	13.4	7.9	186.0	3,506,571.7	2,074.1	1.8	1.5
11/04/2022 04:00	10.1	13.4	7.9	195.8	3,510,128.1	2,153.1	1.9	1.5
11/04/2022 05:00	10.3	13.3	8.0	211.1	3,487,723.9	2,266.7	2.1	1.8
11/04/2022 06:00	10.5	13.3	8.2	190.4	3,524,737.3	2,187.8	1.9	1.5
11/04/2022 07:00	9.9	13.4	7.8	182.2	3,487,636.5	2,062.9	1.8	1.4
11/04/2022 08:00	10.4	13.8	8.6	163.9	3,344,095.8	1,733.8	1.7	1.2
11/04/2022 09:00	10.9	13.8	9.1	139.9	3,046,578.0	1,557.3	1.5	0.9
11/04/2022 10:00	11.3	13.9	9.5	132.3	2,731,023.5	1,396.0	1.6	0.8
11/04/2022 11:00	11.0	14.0	9.4	127.6	2,629,294.8	1,324.8	1.6	0.8
11/04/2022 12:00	10.9	14.0	9.3	128.9	2,625,325.5	1,322.8	1.7	0.9
11/04/2022 13:00	11.0	14.0	9.4	127.3	2,627,707.1	1,324.0	1.6	0.8
11/04/2022 14:00	11.3	13.9	9.5	135.4	2,748,043.5	1,404.7	1.7	1.0
11/04/2022 15:00	10.7	13.8	8.9	166.1	3,157,005.4	1,636.8	1.8	1.1
11/04/2022 16:00	10.7	13.4	8.4	182.3	3,433,460.4	2,081.0	1.8	1.5
11/04/2022 17:00	10.6	13.3	8.2	203.0	3,414,700.0	2,119.5	2.1	1.7
11/04/2022 18:00	10.5	13.4	8.3	183.9	3,436,086.2	2,057.5	1.8	1.4
11/04/2022 19:00	10.3	13.4	8.1	185.4	3,434,917.2	2,056.8	1.9	1.4
11/04/2022 20:00	10.3	13.4	8.1	189.9	3,470,561.0	2,052.8	1.9	1.4
11/04/2022 21:00	10.3	13.4	8.1	180.4	3,473,266.0	2,054.4	1.8	1.4
11/04/2022 22:00	10.3	13.4	8.1	186.7	3,474,111.3	2,054.9	1.9	1.4
11/04/2022 23:00	9.5	13.6	7.7	162.6	3,518,159.4	1,952.5	1.6	1.2
Average/Sum#:	10.5	13.6	8.4	172.0	3,274,293.2	1,883.9	1.8	1.3
Minimum:	9.5	13.3	7.7	127.3	2,625,325.5	1,322.8	1.5	0.8
Maximum:	11.3	14.0	9.5	211.1	3,524,737.3	2,266.7	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/05/2022 00:00	9.4	13.6	7.6	155.9	3,514,555.6	1,950.5	1.5	1.2
11/05/2022 01:00	9.5	13.6	7.7	162.6	3,514,375.4	1,950.4	1.6	1.2
11/05/2022 02:00	9.6	13.6	7.8	161.2	3,513,834.9	1,950.1	1.6	1.2
11/05/2022 03:00	9.5	13.6	7.7	157.1	3,515,276.4	1,950.9	1.5	1.2
11/05/2022 04:00	9.4	13.6	7.6	157.5	3,521,402.7	1,954.3	1.5	1.2
11/05/2022 05:00	9.4	13.6	7.6	169.6	3,525,547.0	1,956.6	1.7	1.4
11/05/2022 06:00	9.8	13.6	7.9	157.6	3,473,292.7	1,927.6	1.5	1.2
11/05/2022 07:00	24.6	16.2	30.9	171.4	1,523,283.2	567.3	3.6	0.8
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	23.7	18.0	48.2	0.1	1,274,868.9	195.5	0.0	0.0
11/05/2022 14:00	40.6	16.0	48.9	123.6	2,029,886.4	711.5	0.0	0.0
11/05/2022 15:00	11.4	13.8	9.5	149.1	2,810,645.7	1,436.7	1.8	1.0
11/05/2022 16:00	11.1	13.6	9.0	170.5	3,117,175.1	1,707.2	1.9	1.2
11/05/2022 17:00	10.9	13.4	8.6	196.0	3,435,521.8	1,981.9	2.0	1.6
11/05/2022 18:00	10.9	13.4	8.6	193.3	3,418,187.3	1,971.9	2.0	1.6
11/05/2022 19:00	10.9	13.4	8.6	192.3	3,418,534.0	1,972.1	1.9	1.4
11/05/2022 20:00	10.9	13.4	8.6	187.1	3,423,907.6	1,975.2	1.9	1.4
11/05/2022 21:00	11.2	13.6	9.1	154.5	3,048,819.8	1,647.5	1.7	1.2
11/05/2022 22:00	11.6	13.8	9.6	134.0	2,758,020.7	1,409.8	1.6	0.8
11/05/2022 23:00	10.8	13.7	8.9	159.0	3,189,022.9	1,653.4	1.7	1.2
Average/Sum#:	13.4	14.1	13.8	155.4	3,054,008.3	1,624.8	1.6	1.1
Minimum:	9.4	13.4	7.6	0.1	1,274,868.9	195.5	0.0	0.0
Maximum:	40.6	18.0	48.9	196.0	3,525,547.0	1,981.9	3.6	1.6
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/06/2022 00:00	11.2	13.8	9.3	150.2	3,016,784.1	1,564.1	1.7	1.1
11/06/2022 01:00	11.5	13.8	9.6	143.1	2,822,943.0	1,463.6	1.7	1.0
11/06/2022 02:00	26.9	16.9	39.7	190.9	1,124,118.8	377.6	5.6	0.8
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.5	14.8	19.5	161.4	2,321,282.0	1,135.1	3.0	1.0
Minimum:	11.2	13.8	9.3	143.1	1,124,118.8	377.6	1.7	0.8
Maximum:	26.9	16.9	39.7	190.9	3,016,784.1	1,564.1	5.6	1.1
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2022 03:00	34.1	17.7	62.9	0.0	1,374,315.2	281.0	0.0	0.0
11/07/2022 04:00	49.4	16.5	66.2	190.8	1,748,723.1	549.1	3.4	0.7
11/07/2022 05:00	10.3	13.7	8.4	188.6	3,278,059.6	1,723.5	2.0	1.4
11/07/2022 06:00	10.1	13.6	8.2	174.7	3,424,588.0	2,000.6	1.8	1.4
11/07/2022 07:00	10.3	13.5	8.2	216.0	3,439,589.4	2,210.3	2.2	1.8
11/07/2022 08:00	10.2	13.6	8.2	156.3	3,433,441.6	1,980.7	1.6	1.2
11/07/2022 09:00	10.0	13.5	8.0	172.7	3,404,839.7	1,964.2	1.7	1.4
11/07/2022 10:00	10.2	13.6	8.2	168.6	3,391,492.2	1,956.5	1.7	1.4
11/07/2022 11:00	10.4	13.6	8.4	181.3	3,436,904.1	1,957.6	1.8	1.4
11/07/2022 12:00	10.3	13.6	8.3	171.2	3,436,201.8	1,957.2	1.7	1.4
11/07/2022 13:00	10.0	13.7	8.2	173.8	3,442,346.7	1,960.7	1.7	1.4
11/07/2022 14:00	10.1	13.6	8.2	179.5	3,474,787.6	2,055.3	1.8	1.4
11/07/2022 15:00	10.2	13.6	8.2	203.7	3,441,032.9	2,186.1	2.1	1.7
11/07/2022 16:00	10.0	13.6	8.1	221.7	3,410,779.7	2,241.6	2.3	2.0
11/07/2022 17:00	10.1	13.5	8.1	223.3	3,426,269.7	2,276.8	2.3	2.0
11/07/2022 18:00	10.1	13.5	8.1	221.3	3,430,934.8	2,279.9	2.3	2.1
11/07/2022 19:00	10.1	13.5	8.1	228.5	3,430,182.4	2,279.4	2.3	2.1
11/07/2022 20:00	10.1	13.5	8.1	221.5	3,425,968.7	2,276.6	2.3	2.0
11/07/2022 21:00	10.1	13.5	8.1	219.3	3,420,400.7	2,272.9	2.2	1.8
11/07/2022 22:00	10.0	13.5	8.0	217.0	3,434,793.3	2,232.3	2.2	1.8
11/07/2022 23:00	10.1	13.5	8.1	203.8	3,479,143.5	2,159.5	2.0	1.7
Average/Sum#:	13.2	13.9	13.5	187.3	3,246,895.0	1,942.9	2.0	1.5
Minimum:	10.0	13.5	8.0	0.0	1,374,315.2	281.0	0.0	0.0
Maximum:	49.4	17.7	66.2	228.5	3,479,143.5	2,279.9	3.4	2.1
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/08/2022 00:00	10.1	13.5	8.1	193.6	3,466,738.1	2,151.8	1.9	1.5
11/08/2022 01:00	10.2	13.5	8.1	199.1	3,463,515.9	2,149.8	2.0	1.7
11/08/2022 02:00	10.2	13.5	8.1	196.1	3,459,034.0	2,096.5	2.0	1.7
11/08/2022 03:00	10.1	13.5	8.1	190.8	3,452,882.8	2,143.2	1.9	1.5
11/08/2022 04:00	10.1	13.5	8.1	207.7	3,432,060.8	2,180.4	2.1	1.7
11/08/2022 05:00	10.0	13.5	8.0	188.9	3,419,670.5	2,197.5	1.9	1.5
11/08/2022 06:00	10.3	13.5	8.2	216.6	3,395,279.4	2,281.0	2.2	1.8
11/08/2022 07:00	10.1	13.5	8.1	208.3	3,413,757.1	2,193.7	2.1	1.8
11/08/2022 08:00	10.1	13.5	8.1	198.5	3,400,374.1	2,185.1	2.0	1.7
11/08/2022 09:00	10.0	13.5	8.0	206.0	3,434,107.1	2,181.7	2.1	1.7
11/08/2022 10:00	10.1	13.5	8.1	203.3	3,447,764.7	2,165.2	2.1	1.7
11/08/2022 11:00	9.9	13.6	8.0	172.3	3,451,634.2	2,016.4	1.7	1.4
11/08/2022 12:00	9.9	13.6	8.0	174.4	3,462,712.5	1,972.3	1.7	1.4
11/08/2022 13:00	9.8	13.6	7.9	162.7	3,507,327.0	1,972.1	1.6	1.2
11/08/2022 14:00	10.1	13.6	8.2	184.3	3,503,672.3	2,046.8	1.8	1.4
11/08/2022 15:00	10.1	13.6	8.2	173.0	3,498,536.9	2,043.8	1.7	1.4
11/08/2022 16:00	10.2	13.5	8.1	212.0	3,466,532.6	2,202.3	2.1	1.8
11/08/2022 17:00	10.1	13.5	8.1	201.4	3,433,792.3	2,181.5	2.0	1.7
11/08/2022 18:00	10.1	13.5	8.1	192.7	3,466,577.0	2,151.7	1.9	1.5
11/08/2022 19:00	10.0	13.5	8.0	209.1	3,441,032.9	2,186.1	2.1	1.7
11/08/2022 20:00	10.1	13.5	8.1	205.1	3,454,255.0	2,194.5	2.1	1.8
11/08/2022 21:00	10.1	13.5	8.1	202.6	3,456,458.6	2,195.9	2.0	1.8
11/08/2022 22:00	10.1	13.5	8.1	209.0	3,431,588.6	2,180.1	2.1	1.7
11/08/2022 23:00	10.1	13.5	8.1	194.2	3,443,216.2	2,137.2	2.0	1.7
Average/Sum#:	10.1	13.5	8.1	195.9	3,450,105.0	2,141.9	2.0	1.6
Minimum:	9.8	13.5	7.9	162.7	3,395,279.4	1,972.1	1.6	1.2
Maximum:	10.3	13.6	8.2	216.6	3,507,327.0	2,281.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/09/2022 00:00	10.0	13.5	8.0	194.5	3,459,166.0	2,147.1	2.0	1.7
11/09/2022 01:00	9.9	13.5	7.9	200.1	3,459,004.9	2,147.0	2.0	1.7
11/09/2022 02:00	9.9	13.5	7.9	197.1	3,479,134.1	2,184.9	2.0	1.7
11/09/2022 03:00	9.9	13.5	7.9	201.1	3,482,478.1	2,187.0	2.0	1.7
11/09/2022 04:00	10.0	13.5	8.0	199.9	3,512,084.5	2,154.3	2.0	1.7
11/09/2022 05:00	10.0	13.5	8.0	188.4	3,417,778.9	2,246.2	1.9	1.6
11/09/2022 06:00	10.3	13.5	8.2	212.2	3,475,751.2	2,284.3	2.1	1.8
11/09/2022 07:00	10.1	13.5	8.1	205.2	3,519,904.0	2,184.8	2.0	1.7
11/09/2022 08:00	10.0	13.5	8.0	194.7	3,501,161.7	2,147.6	1.9	1.5
11/09/2022 09:00	10.6	13.8	8.8	183.3	3,349,003.4	1,760.8	1.9	1.2
11/09/2022 10:00	11.0	13.8	9.1	179.6	3,375,044.2	1,725.2	1.8	1.2
11/09/2022 11:00	11.1	13.8	9.2	166.6	3,210,322.0	1,641.0	1.8	1.1
11/09/2022 12:00	10.9	13.8	9.1	176.5	3,357,633.0	1,716.3	1.8	1.2
11/09/2022 13:00	11.1	13.8	9.2	163.8	3,179,020.9	1,625.0	1.8	1.1
11/09/2022 14:00	11.0	13.8	9.1	172.9	3,321,832.3	1,698.0	1.8	1.2
11/09/2022 15:00	10.4	13.8	8.6	149.1	3,218,929.8	1,645.4	1.6	1.0
11/09/2022 16:00	10.4	13.4	8.2	182.6	3,506,740.8	2,074.2	1.8	1.5
11/09/2022 17:00	10.6	13.3	8.2	192.3	3,510,780.3	2,153.5	1.9	1.5
11/09/2022 18:00	10.0	13.5	8.0	180.0	3,528,725.7	2,009.9	1.8	1.4
11/09/2022 19:00	9.9	13.6	8.0	166.9	3,555,097.8	1,973.0	1.6	1.2
11/09/2022 20:00	9.9	13.6	8.0	175.1	3,561,764.7	1,976.7	1.7	1.4
11/09/2022 21:00	10.0	13.6	8.1	167.7	3,582,666.5	1,988.3	1.6	1.2
11/09/2022 22:00	9.9	13.6	8.0	176.9	3,566,089.2	1,979.1	1.7	1.4
11/09/2022 23:00	9.9	13.6	8.0	165.0	3,563,206.2	1,977.5	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	183.0	3,445,555.0	1,984.5	1.8	1.4
Minimum:	9.9	13.3	7.9	149.1	3,179,020.9	1,625.0	1.6	1.0
Maximum:	11.1	13.8	9.2	212.2	3,582,666.5	2,284.3	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/10/2022 00:00	10.0	13.6	8.1	178.4	3,562,845.8	1,977.3	1.7	1.4
11/10/2022 01:00	9.9	13.6	8.0	167.1	3,559,602.5	1,975.5	1.6	1.2
11/10/2022 02:00	9.9	13.6	8.0	177.6	3,557,620.4	1,974.4	1.7	1.4
11/10/2022 03:00	9.8	13.6	7.9	165.1	3,563,026.0	1,977.4	1.6	1.2
11/10/2022 04:00	10.3	13.4	8.1	189.4	3,549,205.6	2,073.4	1.8	1.5
11/10/2022 05:00	10.5	13.4	8.3	182.6	3,463,051.3	2,174.8	1.8	1.5
11/10/2022 06:00	11.0	13.2	8.4	213.9	3,538,654.2	2,299.8	2.1	1.8
11/10/2022 07:00	10.2	13.4	8.0	192.9	3,524,597.8	2,110.5	1.9	1.5
11/10/2022 08:00	9.7	13.7	7.9	162.6	3,544,827.1	1,967.3	1.6	1.2
11/10/2022 09:00	9.6	13.6	7.8	166.8	3,510,951.9	1,948.5	1.6	1.2
11/10/2022 10:00	10.5	13.8	8.7	169.3	3,396,563.7	1,736.2	1.7	1.2
11/10/2022 11:00	10.3	13.9	8.7	161.6	3,380,717.5	1,728.1	1.6	1.0
11/10/2022 12:00	10.2	13.9	8.6	162.3	3,354,894.1	1,714.9	1.6	1.0
11/10/2022 13:00	10.7	13.9	9.0	144.5	3,117,127.4	1,570.6	1.6	0.9
11/10/2022 14:00	10.0	13.9	8.4	152.0	3,373,087.9	1,724.2	1.5	1.0
11/10/2022 15:00	10.2	13.8	8.5	156.3	3,370,935.9	1,723.1	1.6	1.0
11/10/2022 16:00	10.4	13.4	8.2	195.7	3,508,531.3	2,126.5	1.9	1.5
11/10/2022 17:00	10.6	13.3	8.2	217.4	3,456,883.6	2,271.9	2.2	1.8
11/10/2022 18:00	10.4	13.3	8.1	219.1	3,460,991.9	2,274.6	2.2	1.8
11/10/2022 19:00	10.4	13.3	8.1	225.8	3,466,926.1	2,278.5	2.3	2.1
11/10/2022 20:00	10.4	13.3	8.1	218.2	3,467,382.5	2,278.8	2.2	1.8
11/10/2022 21:00	10.4	13.3	8.1	219.0	3,471,795.1	2,281.7	2.2	1.8
11/10/2022 22:00	10.3	13.3	8.0	225.3	3,471,034.3	2,281.2	2.3	2.1
11/10/2022 23:00	10.3	13.3	8.0	209.4	3,471,875.5	2,256.4	2.1	1.8
Average/Sum#:	10.3	13.5	8.2	186.3	3,464,297.1	2,030.2	1.9	1.4
Minimum:	9.6	13.2	7.8	144.5	3,117,127.4	1,570.6	1.5	0.9
Maximum:	11.0	13.9	9.0	225.8	3,563,026.0	2,299.8	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/11/2022 00:00	10.3	13.3	8.0	223.0	3,510,957.9	2,281.8	2.2	1.8
11/11/2022 01:00	10.3	13.3	8.0	221.4	3,501,725.9	2,275.8	2.2	1.8
11/11/2022 02:00	10.2	13.4	8.0	187.4	3,539,219.6	2,145.1	1.8	1.5
11/11/2022 03:00	10.3	13.4	8.1	194.3	3,535,259.8	2,142.7	1.9	1.5
11/11/2022 04:00	10.5	13.3	8.2	218.9	3,534,982.3	2,271.6	2.2	1.8
11/11/2022 05:00	10.3	13.3	8.0	198.5	3,516,189.4	2,285.2	2.0	1.8
11/11/2022 06:00	10.6	13.3	8.2	212.4	3,514,496.9	2,284.1	2.1	1.8
11/11/2022 07:00	10.0	13.5	8.0	188.3	3,520,756.7	2,108.2	1.9	1.5
11/11/2022 08:00	9.6	13.7	7.9	162.4	3,495,996.3	1,940.2	1.6	1.2
11/11/2022 09:00	10.5	13.8	8.7	170.2	3,361,154.3	1,718.1	1.7	1.2
11/11/2022 10:00	10.5	13.8	8.7	164.3	3,372,696.6	1,724.0	1.7	1.2
11/11/2022 11:00	10.6	13.8	8.8	163.0	3,304,029.8	1,688.9	1.7	1.2
11/11/2022 12:00	10.6	13.8	8.8	167.3	3,301,290.9	1,687.5	1.7	1.2
11/11/2022 13:00	10.4	13.8	8.6	164.9	3,327,114.4	1,700.7	1.7	1.2
11/11/2022 14:00	10.8	13.9	9.1	148.5	3,095,486.0	1,582.3	1.6	0.9
11/11/2022 15:00	10.2	13.8	8.5	155.4	3,303,442.9	1,688.6	1.6	1.0
11/11/2022 16:00	10.2	13.5	8.1	171.8	3,431,881.5	1,979.8	1.7	1.4
11/11/2022 17:00	10.7	13.2	8.2	228.1	3,421,002.7	2,273.3	2.3	2.0
11/11/2022 18:00	10.6	13.2	8.1	218.7	3,448,058.4	2,266.1	2.2	1.8
11/11/2022 19:00	10.5	13.2	8.0	219.6	3,429,799.4	2,254.1	2.2	1.8
11/11/2022 20:00	10.5	13.2	8.0	225.9	3,424,778.2	2,250.8	2.3	2.0
11/11/2022 21:00	10.4	13.2	8.0	217.1	3,422,343.7	2,249.2	2.2	1.8
11/11/2022 22:00	10.3	13.3	8.0	213.5	3,490,942.9	2,243.3	2.1	1.8
11/11/2022 23:00	10.4	13.2	8.0	221.7	3,478,799.5	2,260.9	2.2	1.8
Average/Sum#:	10.4	13.5	8.3	194.0	3,428,433.6	2,054.3	2.0	1.5
Minimum:	9.6	13.2	7.9	148.5	3,095,486.0	1,582.3	1.6	0.9
Maximum:	10.8	13.9	9.1	228.1	3,539,219.6	2,285.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/12/2022 00:00	10.3	13.2	7.9	216.7	3,485,415.9	2,265.2	2.2	1.8
11/12/2022 01:00	10.3	13.2	7.9	208.8	3,490,955.1	2,268.8	2.1	1.8
11/12/2022 02:00	10.3	13.2	7.9	218.5	3,500,956.5	2,275.3	2.2	1.8
11/12/2022 03:00	10.4	13.2	8.0	221.1	3,506,341.9	2,278.8	2.2	1.8
11/12/2022 04:00	10.4	13.2	8.0	212.3	3,516,343.3	2,285.3	2.1	1.8
11/12/2022 05:00	10.5	13.2	8.0	227.9	3,518,343.6	2,286.6	2.3	2.1
11/12/2022 06:00	10.8	13.2	8.3	212.8	3,503,726.1	2,277.1	2.1	1.8
11/12/2022 07:00	10.4	13.3	8.1	197.3	3,539,628.0	2,119.5	1.9	1.5
11/12/2022 08:00	10.5	13.3	8.2	206.7	3,456,930.8	2,196.2	2.1	1.8
11/12/2022 09:00	10.0	13.8	8.3	168.8	3,339,493.5	1,755.8	1.7	1.2
11/12/2022 10:00	10.8	13.8	9.0	152.1	3,123,852.7	1,596.8	1.6	1.0
11/12/2022 11:00	10.8	13.8	9.0	144.6	3,047,751.8	1,557.9	1.6	0.9
11/12/2022 12:00	10.9	13.8	9.1	151.8	3,046,382.4	1,557.2	1.7	1.1
11/12/2022 13:00	10.8	13.9	9.1	152.3	3,092,747.2	1,580.9	1.7	1.1
11/12/2022 14:00	10.8	13.9	9.1	144.2	3,047,556.2	1,557.8	1.6	0.9
11/12/2022 15:00	9.8	13.8	8.1	160.0	3,458,471.6	1,793.1	1.6	1.1
11/12/2022 16:00	10.4	13.4	8.2	195.8	3,482,576.6	2,136.2	1.9	1.5
11/12/2022 17:00	10.6	13.2	8.1	219.3	3,445,531.9	2,289.6	2.2	1.8
11/12/2022 18:00	10.5	13.2	8.0	223.2	3,443,726.1	2,288.4	2.3	2.1
11/12/2022 19:00	10.5	13.2	8.0	227.9	3,452,454.3	2,294.2	2.3	2.1
11/12/2022 20:00	10.5	13.2	8.0	218.0	3,468,405.8	2,304.8	2.2	1.8
11/12/2022 21:00	10.5	13.2	8.0	228.5	3,462,085.4	2,300.6	2.3	2.1
11/12/2022 22:00	10.3	13.3	8.0	205.4	3,498,560.8	2,197.1	2.0	1.8
11/12/2022 23:00	10.3	13.3	8.0	202.5	3,491,554.5	2,192.7	2.0	1.8
Average/Sum#:	10.5	13.4	8.3	196.5	3,392,491.3	2,069.0	2.0	1.6
Minimum:	9.8	13.2	7.9	144.2	3,046,382.4	1,557.2	1.6	0.9
Maximum:	10.9	13.9	9.1	228.5	3,539,628.0	2,304.8	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/13/2022 00:00	10.4	13.3	8.1	204.8	3,517,004.0	2,183.0	2.0	1.7
11/13/2022 01:00	10.4	13.3	8.1	200.2	3,495,093.2	2,169.4	2.0	1.7
11/13/2022 02:00	10.4	13.3	8.1	195.4	3,524,963.6	2,162.2	1.9	1.5
11/13/2022 03:00	10.5	13.3	8.2	211.3	3,500,471.7	2,198.3	2.1	1.8
11/13/2022 04:00	10.4	13.3	8.1	204.9	3,532,309.4	2,192.5	2.0	1.8
11/13/2022 05:00	10.4	13.3	8.1	227.8	3,520,387.3	2,185.1	2.3	2.0
11/13/2022 06:00	10.8	13.3	8.4	209.5	3,505,567.2	2,201.5	2.1	1.8
11/13/2022 07:00	10.7	13.3	8.3	214.9	3,491,416.7	2,269.1	2.1	1.8
11/13/2022 08:00	10.1	13.5	8.1	187.4	3,377,000.5	1,972.8	1.9	1.4
11/13/2022 09:00	10.5	13.8	8.7	166.9	3,352,350.9	1,713.6	1.7	1.2
11/13/2022 10:00	10.5	13.8	8.7	168.7	3,354,111.6	1,714.5	1.7	1.2
11/13/2022 11:00	10.4	13.9	8.8	160.7	3,353,720.3	1,714.3	1.6	1.0
11/13/2022 12:00	10.3	13.9	8.7	156.6	3,349,807.7	1,712.3	1.6	1.0
11/13/2022 13:00	10.1	13.9	8.5	153.9	3,401,531.1	1,713.9	1.5	1.0
11/13/2022 14:00	10.2	13.9	8.6	156.5	3,347,944.9	1,686.9	1.6	1.0
11/13/2022 15:00	9.9	13.8	8.2	160.4	3,466,958.2	1,797.5	1.6	1.1
11/13/2022 16:00	10.7	13.4	8.4	189.5	3,518,100.7	2,132.3	1.9	1.5
11/13/2022 17:00	10.7	13.2	8.2	213.4	3,498,648.5	2,273.8	2.1	1.8
11/13/2022 18:00	10.6	13.2	8.1	224.1	3,498,186.9	2,273.5	2.2	1.8
11/13/2022 19:00	10.6	13.2	8.1	215.0	3,504,033.9	2,277.3	2.1	1.8
11/13/2022 20:00	10.5	13.2	8.0	222.1	3,508,188.3	2,280.0	2.2	1.8
11/13/2022 21:00	10.5	13.2	8.0	218.6	3,515,727.8	2,284.9	2.2	1.8
11/13/2022 22:00	10.5	13.2	8.0	221.0	3,519,266.8	2,287.2	2.2	1.8
11/13/2022 23:00	10.8	13.2	8.3	224.6	3,529,729.8	2,294.0	2.2	1.8
Average/Sum#:	10.5	13.4	8.3	196.2	3,465,938.4	2,070.4	2.0	1.5
Minimum:	9.9	13.2	8.0	153.9	3,347,944.9	1,686.9	1.5	1.0
Maximum:	10.8	13.9	8.8	227.8	3,532,309.4	2,294.0	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/14/2022 00:00	10.4	13.2	8.0	219.4	3,561,125.9	2,288.4	2.2	1.8
11/14/2022 01:00	10.3	13.2	7.9	211.9	3,544,319.3	2,277.6	2.1	1.8
11/14/2022 02:00	10.3	13.2	7.9	208.5	3,566,170.0	2,265.6	2.0	1.8
11/14/2022 03:00	10.1	13.3	7.8	192.4	3,589,728.9	2,149.5	1.9	1.5
11/14/2022 04:00	10.3	13.2	7.9	205.0	3,593,691.8	2,230.6	2.0	1.8
11/14/2022 05:00	10.6	13.2	8.1	228.5	3,607,410.1	2,291.8	2.2	1.8
11/14/2022 06:00	10.7	13.2	8.2	214.2	3,599,067.6	2,286.5	2.1	1.8
11/14/2022 07:00	10.3	13.3	8.0	193.1	3,603,566.0	2,184.1	1.9	1.5
11/14/2022 08:00	10.3	13.3	8.0	184.7	3,579,207.7	2,143.2	1.8	1.5
11/14/2022 09:00	10.3	13.3	8.0	198.4	3,546,479.2	2,149.5	1.9	1.5
11/14/2022 10:00	10.4	13.3	8.1	192.5	3,533,114.9	2,141.4	1.9	1.5
11/14/2022 11:00	10.4	13.3	8.1	188.0	3,535,118.9	2,116.8	1.8	1.5
11/14/2022 12:00	10.4	13.4	8.2	195.0	3,517,249.6	2,106.1	1.9	1.5
11/14/2022 13:00	10.4	13.4	8.2	196.8	3,484,043.9	2,137.1	2.0	1.7
11/14/2022 14:00	10.4	13.4	8.2	196.4	3,484,533.0	2,137.4	2.0	1.7
11/14/2022 15:00	10.3	13.4	8.1	192.3	3,487,298.4	2,062.7	1.9	1.4
11/14/2022 16:00	10.6	13.3	8.2	209.6	3,469,934.6	2,229.8	2.1	1.8
11/14/2022 17:00	10.4	13.3	8.1	208.9	3,466,713.8	2,177.1	2.1	1.7
11/14/2022 18:00	10.4	13.3	8.1	201.1	3,519,909.7	2,159.1	2.0	1.7
11/14/2022 19:00	10.6	13.2	8.1	215.3	3,525,178.5	2,265.3	2.1	1.8
11/14/2022 20:00	10.5	13.2	8.0	224.5	3,510,188.6	2,281.3	2.2	1.8
11/14/2022 21:00	10.4	13.2	8.0	216.6	3,510,861.8	2,256.1	2.2	1.8
11/14/2022 22:00	10.4	13.2	8.0	210.2	3,516,464.0	2,259.7	2.1	1.8
11/14/2022 23:00	10.4	13.2	8.0	213.7	3,525,087.3	2,239.5	2.1	1.8
Average/Sum#:	10.4	13.3	8.1	204.9	3,536,519.3	2,201.5	2.0	1.7
Minimum:	10.1	13.2	7.8	184.7	3,466,713.8	2,062.7	1.8	1.4
Maximum:	10.7	13.4	8.2	228.5	3,607,410.1	2,291.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/15/2022 00:00	10.5	13.2	8.0	222.8	3,524,711.6	2,265.0	2.2	1.8
11/15/2022 01:00	10.5	13.2	8.0	212.4	3,529,380.1	2,268.0	2.1	1.8
11/15/2022 02:00	10.5	13.2	8.0	225.5	3,518,343.6	2,286.6	2.2	1.8
11/15/2022 03:00	10.5	13.2	8.0	223.2	3,532,807.2	2,296.0	2.2	1.8
11/15/2022 04:00	10.5	13.2	8.0	222.4	3,538,654.2	2,299.8	2.2	1.8
11/15/2022 05:00	10.6	13.2	8.1	214.1	3,471,937.4	2,332.5	2.2	1.9
11/15/2022 06:00	10.7	13.3	8.3	210.1	3,467,004.8	2,202.6	2.1	1.8
11/15/2022 07:00	10.7	13.2	8.2	221.5	3,496,095.3	2,323.2	2.2	1.9
11/15/2022 08:00	10.6	13.3	8.2	219.3	3,438,486.1	2,234.7	2.2	1.8
11/15/2022 09:00	10.4	13.4	8.2	198.9	3,487,907.4	2,114.0	2.0	1.7
11/15/2022 10:00	10.5	13.4	8.3	214.0	3,481,761.5	2,135.7	2.1	1.7
11/15/2022 11:00	10.1	13.5	8.1	184.5	3,487,410.4	2,037.3	1.8	1.4
11/15/2022 12:00	9.8	13.6	7.9	169.3	3,533,655.5	1,961.1	1.6	1.2
11/15/2022 13:00	9.9	13.6	8.0	257.6	3,544,827.1	1,967.3	2.6	2.0
11/15/2022 14:00	0.0	0.0	0.0	215.4	1,293,287.0	1,973.8	6.3	4.7
11/15/2022 15:00	10.5	13.4	8.3	145.1	1,315,040.5	2,007.0	4.0	3.0
11/15/2022 16:00	10.5	13.3	8.2	204.6	3,456,329.3	2,120.1	2.1	1.7
11/15/2022 17:00	10.4	13.3	8.1	199.3	3,437,738.5	2,133.8	2.0	1.7
11/15/2022 18:00	10.6	13.4	8.3	201.8	3,420,338.8	2,123.0	2.1	1.7
11/15/2022 19:00	10.7	13.4	8.4	208.4	3,403,019.6	2,137.1	2.1	1.7
11/15/2022 20:00	10.6	13.4	8.3	214.0	3,423,875.8	2,175.2	2.2	1.7
11/15/2022 21:00	10.5	13.3	8.2	222.1	3,404,389.0	2,237.4	2.3	2.0
11/15/2022 22:00	10.4	13.4	8.2	210.5	3,422,127.8	2,149.1	2.2	1.7
11/15/2022 23:00	10.4	13.4	8.2	208.9	3,420,535.5	2,148.1	2.1	1.7
Average/Sum#:	10.5	13.3	8.2	209.4	3,474,606.2	2,163.7	2.1	1.7
Minimum:	9.8	13.2	7.9	145.1	3,403,019.6	1,961.1	1.6	1.2
Maximum:	10.7	13.6	8.4	257.6	3,544,827.1	2,332.5	2.6	2.0
%SI	4.17	4.17	4.17	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/16/2022 00:00	10.4	13.4	8.2	202.0	3,411,459.1	2,142.4	2.1	1.7
11/16/2022 01:00	10.4	13.4	8.2	202.6	3,449,645.2	2,116.0	2.0	1.7
11/16/2022 02:00	10.4	13.4	8.2	208.3	3,447,405.1	2,139.8	2.1	1.7
11/16/2022 03:00	10.4	13.4	8.2	209.8	3,454,816.1	2,144.4	2.1	1.7
11/16/2022 04:00	10.7	13.3	8.3	219.1	3,460,991.9	2,274.6	2.2	1.8
11/16/2022 05:00	10.8	13.2	8.3	256.8	3,408,992.6	2,340.0	2.7	2.3
11/16/2022 06:00	11.1	13.2	8.5	228.3	3,418,462.0	2,346.5	2.3	2.1
11/16/2022 07:00	10.7	13.3	8.3	224.9	3,430,103.8	2,254.3	2.3	2.0
11/16/2022 08:00	5.4	13.7	4.4	154.5	3,543,926.2	1,966.8	1.5	1.2
11/16/2022 09:00	2.2	13.9	1.9	150.7	3,746,219.9	1,997.0	1.5	1.2
11/16/2022 10:00	10.3	13.6	8.3	163.3	3,494,344.2	1,964.8	1.6	1.2
11/16/2022 11:00	10.2	13.6	8.2	175.1	3,502,169.5	1,969.2	1.7	1.4
11/16/2022 12:00	10.1	13.6	8.2	174.6	3,472,719.8	1,978.0	1.7	1.4
11/16/2022 13:00	10.1	13.6	8.2	172.7	3,477,109.0	1,980.5	1.7	1.4
11/16/2022 14:00	10.1	13.6	8.2	179.5	3,478,337.9	1,981.2	1.8	1.4
11/16/2022 15:00	10.5	13.4	8.3	192.3	3,467,943.5	2,101.9	1.9	1.5
11/16/2022 16:00	10.6	13.3	8.2	204.0	3,442,032.3	2,161.6	2.1	1.7
11/16/2022 17:00	10.6	13.3	8.2	206.4	3,448,720.2	2,165.8	2.1	1.7
11/16/2022 18:00	10.6	13.3	8.2	219.8	3,418,329.5	2,221.6	2.3	2.0
11/16/2022 19:00	10.6	13.3	8.2	221.9	3,390,694.8	2,228.4	2.3	2.0
11/16/2022 20:00	10.5	13.3	8.2	219.8	3,392,672.8	2,229.7	2.3	2.0
11/16/2022 21:00	10.4	13.3	8.1	216.3	3,453,719.1	2,244.6	2.2	1.8
11/16/2022 22:00	10.3	13.3	8.0	210.2	3,488,569.3	2,216.3	2.1	1.8
11/16/2022 23:00	10.4	13.3	8.1	215.2	3,452,642.0	2,243.9	2.2	1.8
Average/Sum#:	9.9	13.4	7.8	201.2	3,464,667.7	2,142.1	2.0	1.7
Minimum:	2.2	13.2	1.9	150.7	3,390,694.8	1,964.8	1.5	1.2
Maximum:	11.1	13.9	8.5	256.8	3,746,219.9	2,346.5	2.7	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/17/2022 00:00	10.3	13.4	8.1	202.0	3,478,499.0	2,159.1	2.0	1.7
11/17/2022 01:00	10.4	13.4	8.2	203.7	3,478,982.4	2,159.4	2.0	1.7
11/17/2022 02:00	10.3	13.4	8.1	199.0	3,498,716.3	2,146.1	2.0	1.7
11/17/2022 03:00	10.2	13.4	8.0	197.1	3,504,422.2	2,149.6	2.0	1.7
11/17/2022 04:00	10.4	13.3	8.1	209.2	3,511,707.8	2,231.0	2.1	1.8
11/17/2022 05:00	10.7	13.2	8.2	231.9	3,470,680.9	2,357.0	2.3	2.1
11/17/2022 06:00	10.8	13.3	8.4	221.7	3,463,578.6	2,276.3	2.2	1.8
11/17/2022 07:00	10.4	13.4	8.2	203.7	3,484,299.0	2,162.7	2.0	1.7
11/17/2022 08:00	9.6	13.6	7.8	164.4	3,485,711.8	1,985.4	1.6	1.2
11/17/2022 09:00	10.4	13.4	8.2	196.8	3,470,838.7	2,129.0	2.0	1.7
11/17/2022 10:00	10.4	13.4	8.2	197.3	3,441,167.8	2,110.8	2.0	1.7
11/17/2022 11:00	10.5	13.4	8.3	203.3	3,397,924.1	2,133.9	2.1	1.7
11/17/2022 12:00	10.5	13.4	8.3	212.4	3,379,210.3	2,171.5	2.2	1.7
11/17/2022 13:00	10.5	13.4	8.3	211.5	3,415,375.9	2,169.8	2.2	1.7
11/17/2022 14:00	10.3	13.5	8.2	185.0	3,432,119.9	2,005.0	1.9	1.4
11/17/2022 15:00	10.6	13.4	8.3	198.9	3,413,411.1	2,118.7	2.0	1.7
11/17/2022 16:00	10.6	13.3	8.2	218.7	3,400,585.1	2,234.9	2.3	2.0
11/17/2022 17:00	10.6	13.3	8.2	226.8	3,413,327.9	2,268.2	2.3	2.0
11/17/2022 18:00	10.4	13.3	8.1	224.8	3,394,517.1	2,255.7	2.3	2.0
11/17/2022 19:00	10.5	13.3	8.2	225.8	3,399,182.2	2,258.8	2.3	2.0
11/17/2022 20:00	10.4	13.3	8.1	224.6	3,401,289.0	2,260.2	2.3	2.0
11/17/2022 21:00	10.4	13.3	8.1	223.7	3,404,599.7	2,262.4	2.3	2.0
11/17/2022 22:00	10.4	13.3	8.1	218.4	3,418,083.3	2,246.4	2.2	1.8
11/17/2022 23:00	10.2	13.3	7.9	205.4	3,473,301.0	2,206.6	2.1	1.8
Average/Sum#:	10.4	13.4	8.2	208.6	3,442,980.5	2,185.8	2.1	1.8
Minimum:	9.6	13.2	7.8	164.4	3,379,210.3	1,985.4	1.6	1.2
Maximum:	10.8	13.6	8.4	231.9	3,511,707.8	2,357.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/18/2022 00:00	10.3	13.4	8.1	199.9	3,475,276.9	2,157.1	2.0	1.7
11/18/2022 01:00	10.4	13.4	8.2	206.2	3,446,490.9	2,164.4	2.1	1.7
11/18/2022 02:00	10.4	13.4	8.2	208.0	3,410,496.3	2,166.7	2.1	1.7
11/18/2022 03:00	10.3	13.4	8.1	203.8	3,449,038.6	2,166.0	2.1	1.7
11/18/2022 04:00	10.7	13.3	8.3	226.2	3,398,675.7	2,308.1	2.3	2.1
11/18/2022 05:00	10.8	13.2	8.3	256.3	3,388,596.9	2,326.0	2.7	2.3
11/18/2022 06:00	11.3	13.2	8.7	225.2	3,398,940.5	2,333.1	2.3	2.1
11/18/2022 07:00	10.8	13.3	8.4	227.5	3,411,522.1	2,267.0	2.3	2.0
11/18/2022 08:00	10.6	13.4	8.3	209.8	3,416,713.8	2,145.7	2.1	1.7
11/18/2022 09:00	10.7	13.4	8.4	210.2	3,429,452.7	2,153.7	2.1	1.7
11/18/2022 10:00	10.8	13.4	8.5	211.7	3,404,357.5	2,162.8	2.2	1.7
11/18/2022 11:00	10.7	13.4	8.4	204.8	3,384,572.6	2,100.8	2.1	1.7
11/18/2022 12:00	10.5	13.5	8.4	188.1	3,438,308.6	1,958.4	1.9	1.4
11/18/2022 13:00	10.7	13.5	8.5	182.9	3,441,293.2	1,960.1	1.8	1.4
11/18/2022 14:00	10.7	13.5	8.5	184.5	3,405,359.7	1,964.5	1.9	1.4
11/18/2022 15:00	10.8	13.5	8.6	199.0	3,407,027.7	2,040.1	2.0	1.6
11/18/2022 16:00	10.9	13.3	8.5	220.9	3,416,636.9	2,220.5	2.3	2.0
11/18/2022 17:00	10.8	13.3	8.4	220.4	3,415,800.9	2,244.9	2.3	2.0
11/18/2022 18:00	10.7	13.3	8.3	225.6	3,413,366.4	2,243.3	2.3	2.0
11/18/2022 19:00	10.7	13.3	8.3	225.3	3,416,561.7	2,245.4	2.3	2.0
11/18/2022 20:00	10.7	13.3	8.3	229.7	3,425,517.3	2,276.3	2.4	2.0
11/18/2022 21:00	10.8	13.3	8.4	225.1	3,428,862.0	2,328.6	2.3	2.1
11/18/2022 22:00	10.9	13.2	8.4	238.5	3,447,120.9	2,341.0	2.4	2.1
11/18/2022 23:00	10.8	13.3	8.4	221.1	3,463,439.8	2,301.5	2.2	1.8
Average/Sum#:	10.7	13.4	8.4	214.6	3,422,226.2	2,190.7	2.2	1.8
Minimum:	10.3	13.2	8.1	182.9	3,384,572.6	1,958.4	1.8	1.4
Maximum:	11.3	13.5	8.7	256.3	3,475,276.9	2,341.0	2.7	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/19/2022 00:00	10.5	13.4	8.3	205.7	3,445,217.0	2,163.6	2.1	1.7
11/19/2022 01:00	10.5	13.4	8.3	205.1	3,492,521.3	2,142.3	2.0	1.7
11/19/2022 02:00	10.5	13.4	8.3	204.0	3,487,304.4	2,139.1	2.0	1.7
11/19/2022 03:00	10.5	13.4	8.3	198.6	3,495,002.0	2,118.3	2.0	1.7
11/19/2022 04:00	10.7	13.3	8.3	211.7	3,472,580.1	2,231.5	2.1	1.8
11/19/2022 05:00	10.7	13.3	8.3	242.6	3,434,668.5	2,257.3	2.5	2.3
11/19/2022 06:00	10.9	13.4	8.6	206.9	3,489,802.9	2,191.6	2.1	1.8
11/19/2022 07:00	10.5	13.4	8.3	196.7	3,461,057.1	2,123.0	2.0	1.7
11/19/2022 08:00	9.8	13.6	7.9	168.0	3,492,210.0	1,963.6	1.7	1.4
11/19/2022 09:00	10.0	13.6	8.1	168.3	3,488,830.9	1,961.7	1.7	1.4
11/19/2022 10:00	10.2	13.6	8.2	174.4	3,479,760.7	1,956.6	1.7	1.4
11/19/2022 11:00	10.4	13.6	8.4	184.6	3,429,354.7	1,953.3	1.9	1.4
11/19/2022 12:00	10.7	13.5	8.5	179.7	3,429,354.7	1,953.3	1.8	1.4
11/19/2022 13:00	10.7	13.5	8.5	192.2	3,430,759.2	1,954.1	1.9	1.4
11/19/2022 14:00	10.7	13.5	8.5	179.7	3,442,697.8	1,960.9	1.8	1.4
11/19/2022 15:00	10.8	13.5	8.6	196.2	3,417,305.6	2,021.3	2.0	1.6
11/19/2022 16:00	10.9	13.4	8.6	216.1	3,394,598.4	2,156.6	2.2	1.7
11/19/2022 17:00	10.8	13.4	8.5	214.2	3,387,302.3	2,176.7	2.2	1.7
11/19/2022 18:00	10.7	13.4	8.4	210.8	3,414,274.1	2,169.1	2.2	1.7
11/19/2022 19:00	10.8	13.3	8.4	227.1	3,420,701.7	2,273.1	2.3	2.0
11/19/2022 20:00	10.8	13.3	8.4	234.0	3,395,141.7	2,305.7	2.4	2.1
11/19/2022 21:00	10.8	13.3	8.4	229.5	3,405,596.5	2,312.8	2.4	2.1
11/19/2022 22:00	10.5	13.2	8.0	229.2	3,484,143.1	2,340.7	2.3	2.1
11/19/2022 23:00	10.7	13.2	8.2	236.9	3,472,889.7	2,358.5	2.4	2.1
Average/Sum#:	10.6	13.4	8.3	204.7	3,448,461.4	2,132.7	2.1	1.7
Minimum:	9.8	13.2	7.9	168.0	3,387,302.3	1,953.3	1.7	1.4
Maximum:	10.9	13.6	8.6	242.6	3,495,002.0	2,358.5	2.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/20/2022 00:00	10.5	13.3	8.2	213.9	3,469,413.6	2,254.8	2.2	1.8
11/20/2022 01:00	10.6	13.3	8.2	226.4	3,458,557.4	2,273.0	2.3	2.0
11/20/2022 02:00	10.7	13.3	8.3	234.5	3,463,138.8	2,301.3	2.4	2.1
11/20/2022 03:00	10.6	13.3	8.2	225.4	3,501,466.0	2,301.2	2.3	2.1
11/20/2022 04:00	10.4	13.3	8.1	223.5	3,509,378.2	2,306.4	2.2	1.8
11/20/2022 05:00	10.5	13.2	8.0	213.2	3,497,986.2	2,350.0	2.1	1.9
11/20/2022 06:00	10.7	13.3	8.3	212.8	3,508,371.9	2,254.5	2.1	1.8
11/20/2022 07:00	10.1	13.5	8.1	188.7	3,458,704.0	2,096.3	1.9	1.5
11/20/2022 08:00	10.3	13.9	8.7	169.6	3,321,915.0	1,722.3	1.7	1.2
11/20/2022 09:00	10.4	13.9	8.8	162.0	3,327,894.1	1,725.4	1.7	1.2
11/20/2022 10:00	10.8	13.9	9.1	149.8	3,031,056.9	1,571.5	1.7	1.1
11/20/2022 11:00	10.8	13.9	9.1	146.4	3,078,466.0	1,573.6	1.6	0.9
11/20/2022 12:00	10.8	13.9	9.1	143.5	3,024,275.9	1,545.9	1.6	0.9
11/20/2022 13:00	10.8	13.9	9.1	142.1	3,005,886.5	1,536.5	1.6	0.9
11/20/2022 14:00	9.9	13.9	8.3	143.6	3,269,259.6	1,695.0	1.5	1.0
11/20/2022 15:00	10.2	13.8	8.5	159.9	3,341,009.7	1,732.2	1.6	1.0
11/20/2022 16:00	11.0	13.4	8.7	200.6	3,419,102.4	2,147.2	2.0	1.7
11/20/2022 17:00	10.9	13.3	8.5	231.0	3,409,264.8	2,265.5	2.4	2.0
11/20/2022 18:00	10.7	13.3	8.3	228.1	3,389,250.1	2,252.2	2.4	2.0
11/20/2022 19:00	10.6	13.3	8.2	223.0	3,391,206.4	2,253.5	2.3	2.0
11/20/2022 20:00	10.5	13.3	8.2	220.7	3,397,075.4	2,257.4	2.3	2.0
11/20/2022 21:00	10.4	13.4	8.2	211.5	3,412,045.3	2,192.6	2.2	1.8
11/20/2022 22:00	10.2	13.4	8.0	200.6	3,475,760.2	2,157.4	2.0	1.7
11/20/2022 23:00	10.2	13.4	8.0	195.9	3,500,998.6	2,147.5	1.9	1.5
Average/Sum#:	10.5	13.5	8.4	194.4	3,360,895.1	2,038.1	2.0	1.6
Minimum:	9.9	13.2	8.0	142.1	3,005,886.5	1,536.5	1.5	0.9
Maximum:	11.0	13.9	9.1	234.5	3,509,378.2	2,350.0	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/21/2022 00:00	10.2	13.4	8.0	201.0	3,474,793.5	2,156.8	2.0	1.7
11/21/2022 01:00	10.1	13.4	7.9	191.5	3,515,130.9	2,130.5	1.9	1.5
11/21/2022 02:00	9.9	13.5	7.9	175.2	3,522,844.2	2,058.0	1.7	1.4
11/21/2022 03:00	10.4	13.4	8.2	196.8	3,499,604.3	2,172.2	2.0	1.7
11/21/2022 04:00	10.4	13.3	8.1	218.6	3,476,183.8	2,259.2	2.2	1.8
11/21/2022 05:00	10.4	13.3	8.1	186.4	3,488,954.8	2,267.5	1.8	1.6
11/21/2022 06:00	10.7	13.3	8.3	213.2	3,514,958.5	2,284.4	2.1	1.8
11/21/2022 07:00	10.2	13.4	8.0	196.3	3,500,346.5	2,147.1	1.9	1.5
11/21/2022 08:00	9.5	13.7	7.8	167.9	3,494,877.7	1,965.1	1.7	1.4
11/21/2022 09:00	9.6	13.7	7.9	164.0	3,495,055.6	1,965.2	1.6	1.2
11/21/2022 10:00	9.9	13.6	8.0	168.1	3,488,830.9	1,961.7	1.7	1.4
11/21/2022 11:00	10.1	13.6	8.2	181.7	3,439,186.4	1,958.9	1.8	1.4
11/21/2022 12:00	10.5	13.5	8.4	180.1	3,408,306.6	1,966.2	1.8	1.4
11/21/2022 13:00	10.6	13.5	8.5	182.0	3,428,241.3	1,977.7	1.8	1.4
11/21/2022 14:00	10.8	13.4	8.5	213.6	3,401,996.5	2,161.3	2.2	1.7
11/21/2022 15:00	10.9	13.3	8.5	224.6	3,419,046.4	2,272.0	2.3	2.0
11/21/2022 16:00	10.5	13.3	8.2	208.8	3,429,715.7	2,229.0	2.1	1.8
11/21/2022 17:00	10.6	13.3	8.2	222.0	3,394,498.7	2,230.9	2.3	2.0
11/21/2022 18:00	10.6	13.3	8.2	223.4	3,393,890.1	2,230.5	2.3	2.0
11/21/2022 19:00	10.5	13.3	8.2	222.7	3,398,881.2	2,258.6	2.3	2.0
11/21/2022 20:00	10.5	13.3	8.2	220.8	3,406,255.0	2,263.5	2.3	2.0
11/21/2022 21:00	10.5	13.3	8.2	223.7	3,407,308.5	2,264.2	2.3	2.0
11/21/2022 22:00	10.4	13.3	8.1	221.6	3,408,211.4	2,264.8	2.3	2.0
11/21/2022 23:00	10.3	13.3	8.0	214.5	3,425,099.6	2,226.0	2.2	1.8
Average/Sum#:	10.3	13.4	8.2	200.8	3,451,342.4	2,153.0	2.0	1.7
Minimum:	9.5	13.3	7.8	164.0	3,393,890.1	1,958.9	1.6	1.2
Maximum:	10.9	13.7	8.5	224.6	3,522,844.2	2,284.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/22/2022 00:00	10.2	13.4	8.0	197.3	3,454,010.5	2,143.9	2.0	1.7
11/22/2022 01:00	10.1	13.4	7.9	189.5	3,506,716.4	2,125.4	1.9	1.5
11/22/2022 02:00	10.2	13.4	8.0	189.7	3,455,569.2	2,094.4	1.9	1.5
11/22/2022 03:00	9.5	13.7	7.8	162.4	3,465,170.4	1,973.7	1.6	1.2
11/22/2022 04:00	9.7	13.6	7.8	164.6	3,471,315.2	1,977.2	1.6	1.2
11/22/2022 05:00	10.0	13.6	8.1	213.5	3,408,546.8	2,065.9	2.2	1.7
11/22/2022 06:00	10.6	13.4	8.3	190.8	3,503,444.0	2,149.0	1.9	1.5
11/22/2022 07:00	10.2	13.5	8.1	180.1	3,488,525.1	2,088.9	1.8	1.5
11/22/2022 08:00	10.1	13.5	8.1	185.5	3,510,861.8	2,051.0	1.8	1.4
11/22/2022 09:00	14.1	14.4	12.8	162.3	2,952,642.5	1,444.6	1.8	1.0
11/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2022 11:00	12.5	18.6	32.1	161.5	567,333.0	58.0	10.0	0.2
11/22/2022 12:00	45.0	15.9	53.1	257.1	2,031,849.9	756.7	3.9	1.1
11/22/2022 13:00	10.7	13.8	8.9	162.7	3,129,424.0	1,622.5	1.8	1.1
11/22/2022 14:00	9.5	13.9	8.0	152.9	3,453,264.0	1,790.4	1.5	1.1
11/22/2022 15:00	9.8	13.9	8.3	151.7	3,453,264.0	1,790.4	1.5	1.1
11/22/2022 16:00	10.9	13.6	8.8	185.9	3,374,830.8	1,897.6	1.9	1.3
11/22/2022 17:00	11.0	13.4	8.7	200.5	3,410,503.7	2,141.8	2.0	1.7
11/22/2022 18:00	10.6	13.5	8.5	191.1	3,399,011.5	2,035.3	1.9	1.4
11/22/2022 19:00	10.3	13.5	8.2	176.4	3,436,561.8	1,982.5	1.8	1.4
11/22/2022 20:00	10.6	13.4	8.3	200.2	3,445,632.9	2,138.7	2.0	1.7
11/22/2022 21:00	10.2	13.5	8.1	182.2	3,453,688.3	2,017.6	1.8	1.4
11/22/2022 22:00	10.2	13.5	8.1	176.1	3,429,985.4	2,028.8	1.8	1.4
11/22/2022 23:00	9.8	13.6	7.9	162.4	3,481,361.3	1,957.5	1.6	1.2
Average/Sum#:	12.0	13.9	11.4	182.5	3,229,717.9	1,840.5	2.3	1.3
Minimum:	9.5	13.4	7.8	151.7	567,333.0	58.0	1.5	0.2
Maximum:	45.0	18.6	53.1	257.1	3,510,861.8	2,149.0	10.0	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/23/2022 00:00	9.8	13.6	7.9	166.0	3,483,495.5	1,958.7	1.6	1.2
11/23/2022 01:00	9.8	13.6	7.9	165.5	3,486,874.6	1,960.6	1.6	1.2
11/23/2022 02:00	9.9	13.6	8.0	163.7	3,482,962.0	1,958.4	1.6	1.2
11/23/2022 03:00	9.6	13.7	7.9	158.7	3,490,253.7	1,962.5	1.6	1.2
11/23/2022 04:00	10.0	13.6	8.1	169.0	3,457,269.9	1,969.2	1.7	1.4
11/23/2022 05:00	10.5	13.5	8.4	168.2	3,353,622.5	2,057.1	1.7	1.4
11/23/2022 06:00	10.7	13.5	8.5	182.1	3,463,291.2	2,048.5	1.8	1.4
11/23/2022 07:00	10.8	13.4	8.5	193.0	3,471,243.3	2,103.9	1.9	1.5
11/23/2022 08:00	10.4	13.5	8.3	183.4	3,455,976.4	1,993.7	1.8	1.4
11/23/2022 09:00	10.5	13.9	8.9	157.1	3,293,755.0	1,707.7	1.6	1.0
11/23/2022 10:00	11.2	13.9	9.4	157.0	3,012,926.5	1,562.1	1.8	1.1
11/23/2022 11:00	11.2	13.9	9.4	152.7	3,044,426.0	1,556.2	1.7	1.1
11/23/2022 12:00	11.4	13.9	9.6	133.4	2,787,169.9	1,424.7	1.6	0.9
11/23/2022 13:00	10.6	14.0	9.1	146.6	3,049,316.8	1,558.7	1.6	0.9
11/23/2022 14:00	10.3	14.0	8.8	148.1	3,186,259.3	1,628.7	1.6	1.0
11/23/2022 15:00	10.8	13.9	9.1	166.4	3,181,500.7	1,649.5	1.8	1.2
11/23/2022 16:00	11.0	13.4	8.7	198.3	3,418,833.2	2,097.1	2.0	1.7
11/23/2022 17:00	10.8	13.3	8.4	208.7	3,438,847.6	2,159.6	2.1	1.7
11/23/2022 18:00	10.5	13.4	8.3	189.4	3,429,500.6	2,078.6	1.9	1.5
11/23/2022 19:00	10.5	13.4	8.3	186.4	3,457,712.0	2,045.2	1.9	1.4
11/23/2022 20:00	10.8	13.3	8.4	208.5	3,431,522.7	2,155.0	2.1	1.7
11/23/2022 21:00	10.8	13.3	8.4	207.1	3,413,487.0	2,168.6	2.1	1.7
11/23/2022 22:00	10.7	13.3	8.3	198.4	3,453,527.2	2,143.6	2.0	1.7
11/23/2022 23:00	10.6	13.3	8.2	200.4	3,448,693.9	2,140.6	2.0	1.7
Average/Sum#:	10.6	13.6	8.5	175.3	3,341,352.8	1,920.4	1.8	1.3
Minimum:	9.6	13.3	7.9	133.4	2,787,169.9	1,424.7	1.6	0.9
Maximum:	11.4	14.0	9.6	208.7	3,490,253.7	2,168.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/24/2022 00:00	10.0	13.6	8.1	174.8	3,468,155.0	1,975.4	1.7	1.4
11/24/2022 01:00	9.9	13.6	8.0	169.8	3,490,253.7	1,962.5	1.7	1.4
11/24/2022 02:00	9.9	13.6	8.0	164.7	3,492,210.0	1,963.6	1.6	1.2
11/24/2022 03:00	10.7	13.5	8.5	188.3	3,423,561.0	1,975.0	1.9	1.4
11/24/2022 04:00	10.5	13.5	8.4	186.3	3,398,740.1	1,985.5	1.9	1.4
11/24/2022 05:00	10.6	13.5	8.5	202.4	3,346,775.4	2,052.9	2.1	1.6
11/24/2022 06:00	11.1	13.4	8.7	207.0	3,408,764.9	2,165.6	2.1	1.7
11/24/2022 07:00	10.7	13.5	8.5	202.8	3,389,977.5	2,079.4	2.1	1.7
11/24/2022 08:00	10.3	13.9	8.7	163.9	3,302,048.7	1,712.0	1.7	1.2
11/24/2022 09:00	10.4	13.9	8.8	159.0	3,296,262.4	1,709.0	1.6	1.0
11/24/2022 10:00	10.3	13.9	8.7	157.3	3,310,535.2	1,716.4	1.6	1.0
11/24/2022 11:00	11.0	13.9	9.3	151.5	3,052,055.7	1,560.1	1.7	1.1
11/24/2022 12:00	11.3	14.0	9.7	125.0	2,644,749.7	1,351.9	1.6	0.8
11/24/2022 13:00	11.2	14.0	9.6	134.4	2,642,793.4	1,350.9	1.7	0.9
11/24/2022 14:00	10.9	13.9	9.2	152.4	3,056,164.0	1,562.2	1.7	1.1
11/24/2022 15:00	11.0	13.9	9.3	143.9	2,837,056.1	1,450.2	1.7	1.0
11/24/2022 16:00	9.8	13.9	8.3	151.4	3,412,952.7	1,769.5	1.5	1.1
11/24/2022 17:00	9.4	13.9	7.9	147.7	3,411,216.9	1,768.6	1.5	1.1
11/24/2022 18:00	9.6	13.9	8.1	144.0	3,366,469.5	1,745.4	1.4	0.9
11/24/2022 19:00	9.6	13.9	8.1	145.6	3,350,460.7	1,737.1	1.5	1.0
11/24/2022 20:00	10.4	13.9	8.8	167.6	3,368,591.1	1,746.5	1.7	1.2
11/24/2022 21:00	10.5	13.9	8.9	165.9	3,369,748.4	1,747.1	1.7	1.2
11/24/2022 22:00	10.5	13.9	8.9	168.2	3,377,849.2	1,751.3	1.7	1.2
11/24/2022 23:00	10.5	13.9	8.9	172.8	3,381,513.8	1,753.2	1.7	1.2
Average/Sum#:	10.4	13.8	8.7	164.4	3,274,954.4	1,774.6	1.7	1.2
Minimum:	9.4	13.4	7.9	125.0	2,642,793.4	1,350.9	1.4	0.8
Maximum:	11.3	14.0	9.7	207.0	3,492,210.0	2,165.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/25/2022 00:00	10.2	13.9	8.6	160.5	3,389,228.9	1,757.2	1.6	1.1
11/25/2022 01:00	10.1	13.9	8.5	159.6	3,391,543.4	1,758.4	1.6	1.1
11/25/2022 02:00	10.0	13.9	8.4	163.1	3,396,558.2	1,761.0	1.6	1.1
11/25/2022 03:00	10.1	13.9	8.5	157.3	3,402,923.2	1,764.3	1.6	1.1
11/25/2022 04:00	10.1	13.9	8.5	163.3	3,423,753.8	1,775.1	1.6	1.1
11/25/2022 05:00	10.2	13.8	8.5	174.6	3,416,231.6	1,771.2	1.8	1.2
11/25/2022 06:00	10.3	13.9	8.7	160.5	3,407,745.1	1,766.8	1.6	1.1
11/25/2022 07:00	10.0	13.9	8.4	155.6	3,407,745.1	1,766.8	1.5	1.1
11/25/2022 08:00	9.8	13.7	8.0	153.3	3,436,524.8	1,882.1	1.5	1.1
11/25/2022 09:00	10.4	13.6	8.4	185.1	3,370,364.1	1,919.7	1.9	1.3
11/25/2022 10:00	10.5	13.9	8.9	157.2	3,217,182.9	1,668.0	1.7	1.2
11/25/2022 11:00	10.9	13.9	9.2	146.5	2,987,659.7	1,549.0	1.7	1.1
11/25/2022 12:00	10.8	13.9	9.1	145.9	3,037,229.0	1,574.7	1.6	0.9
11/25/2022 13:00	11.2	13.9	9.4	148.1	2,976,665.7	1,543.3	1.7	1.1
11/25/2022 14:00	11.2	13.9	9.4	152.1	2,954,099.1	1,531.6	1.7	1.1
11/25/2022 15:00	10.9	13.8	9.1	163.2	3,127,422.9	1,644.3	1.8	1.2
11/25/2022 16:00	10.9	13.4	8.6	182.8	3,435,275.3	2,082.1	1.8	1.5
11/25/2022 17:00	10.7	13.4	8.4	195.2	3,418,181.1	2,096.7	2.0	1.7
11/25/2022 18:00	10.2	13.5	8.1	176.1	3,415,240.4	1,970.2	1.8	1.4
11/25/2022 19:00	10.1	13.6	8.2	170.5	3,433,392.7	1,955.6	1.7	1.4
11/25/2022 20:00	10.1	13.6	8.2	164.9	3,432,339.3	1,955.0	1.6	1.2
11/25/2022 21:00	9.9	13.6	8.0	167.3	3,452,178.4	1,966.3	1.7	1.4
11/25/2022 22:00	10.7	13.4	8.4	197.3	3,453,883.9	2,118.6	2.0	1.7
11/25/2022 23:00	10.6	13.4	8.3	190.8	3,431,810.5	2,080.0	1.9	1.5
Average/Sum#:	10.4	13.7	8.6	166.3	3,325,632.5	1,819.1	1.7	1.2
Minimum:	9.8	13.4	8.0	145.9	2,954,099.1	1,531.6	1.5	0.9
Maximum:	11.2	13.9	9.4	197.3	3,453,883.9	2,118.6	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/26/2022 00:00	10.3	13.5	8.2	179.2	3,452,318.9	2,016.8	1.8	1.4
11/26/2022 01:00	10.3	13.4	8.1	187.0	3,443,601.3	2,062.0	1.9	1.4
11/26/2022 02:00	13.4	14.3	12.0	168.6	3,038,579.1	1,575.4	1.9	1.1
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.3	13.7	9.4	178.3	3,311,499.8	1,884.7	1.9	1.3
Minimum:	10.3	13.4	8.1	168.6	3,038,579.1	1,575.4	1.8	1.1
Maximum:	13.4	14.3	12.0	187.0	3,452,318.9	2,062.0	1.9	1.4
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2022 02:00	40.4	17.4	68.1	40.6	1,346,731.1	344.2	0.0	0.0
11/28/2022 03:00	35.2	15.3	37.1	229.8	2,281,413.0	949.6	3.2	1.1
11/28/2022 04:00	10.5	13.8	8.7	182.0	3,280,151.8	1,724.6	1.9	1.2
11/28/2022 05:00	10.7	13.8	8.9	156.2	3,146,823.1	1,654.5	1.7	1.2
11/28/2022 06:00	10.9	13.3	8.5	191.5	3,529,039.2	2,164.7	1.9	1.5
11/28/2022 07:00	11.1	13.2	8.5	211.2	3,478,030.2	2,260.4	2.1	1.8
11/28/2022 08:00	10.0	13.6	8.1	168.8	3,416,453.8	1,970.9	1.7	1.4
11/28/2022 09:00	10.9	13.8	9.1	155.3	3,112,643.8	1,613.8	1.7	1.1
11/28/2022 10:00	10.8	13.8	9.0	175.9	3,315,550.0	1,719.0	1.8	1.2
11/28/2022 11:00	11.3	13.9	9.5	148.2	2,944,069.5	1,526.4	1.7	1.1
11/28/2022 12:00	11.1	13.9	9.4	149.7	3,030,092.5	1,571.0	1.7	1.1
11/28/2022 13:00	10.8	13.9	9.1	159.2	3,170,892.5	1,644.0	1.7	1.2
11/28/2022 14:00	10.9	13.9	9.2	156.2	3,138,682.1	1,627.3	1.7	1.1
11/28/2022 15:00	10.7	13.8	8.9	154.7	3,088,242.2	1,623.7	1.7	1.1
11/28/2022 16:00	10.7	13.5	8.5	176.7	3,420,855.9	2,023.4	1.8	1.4
11/28/2022 17:00	10.7	13.4	8.4	188.8	3,407,258.3	2,090.0	1.9	1.5
11/28/2022 18:00	10.1	13.5	8.1	172.0	3,432,921.6	1,980.4	1.7	1.4
11/28/2022 19:00	10.0	13.6	8.1	172.2	3,438,484.2	1,958.5	1.7	1.4
11/28/2022 20:00	10.5	13.4	8.3	189.1	3,474,162.9	2,080.3	1.9	1.5
11/28/2022 21:00	10.7	13.3	8.3	208.0	3,442,857.4	2,212.4	2.1	1.8
11/28/2022 22:00	10.3	13.4	8.1	184.9	3,480,676.0	2,084.2	1.8	1.5
11/28/2022 23:00	9.9	13.6	8.0	165.6	3,479,215.8	1,981.7	1.6	1.2
Average/Sum#:	13.1	13.9	12.6	169.8	3,175,238.5	1,763.9	1.8	1.3
Minimum:	9.9	13.2	8.0	40.6	1,346,731.1	344.2	0.0	0.0
Maximum:	40.4	17.4	68.1	229.8	3,529,039.2	2,260.4	3.2	1.8
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/29/2022 00:00	10.6	13.3	8.2	197.6	3,450,627.2	2,141.8	2.0	1.7
11/29/2022 01:00	10.6	13.3	8.2	202.9	3,482,318.8	2,186.9	2.0	1.7
11/29/2022 02:00	10.4	13.3	8.1	198.6	3,464,006.7	2,175.4	2.0	1.7
11/29/2022 03:00	10.3	13.4	8.1	183.7	3,485,519.1	2,087.1	1.8	1.5
11/29/2022 04:00	10.5	13.3	8.2	193.2	3,503,444.0	2,149.0	1.9	1.5
11/29/2022 05:00	10.6	13.3	8.2	209.5	3,497,923.9	2,196.7	2.1	1.8
11/29/2022 06:00	11.0	13.2	8.4	222.9	3,471,795.1	2,281.7	2.2	1.8
11/29/2022 07:00	10.8	13.2	8.3	226.2	3,471,338.7	2,281.4	2.3	2.1
11/29/2022 08:00	10.7	13.3	8.3	222.9	3,414,583.6	2,244.1	2.3	2.0
11/29/2022 09:00	10.6	13.4	8.3	204.2	3,424,675.6	2,150.7	2.1	1.7
11/29/2022 10:00	10.6	13.4	8.3	205.9	3,415,599.2	2,145.0	2.1	1.7
11/29/2022 11:00	10.7	13.4	8.4	207.2	3,402,701.1	2,136.9	2.1	1.7
11/29/2022 12:00	10.7	13.4	8.4	211.4	3,386,299.9	2,126.6	2.2	1.7
11/29/2022 13:00	10.7	13.4	8.4	207.5	3,383,911.3	2,125.1	2.1	1.7
11/29/2022 14:00	10.7	13.4	8.4	207.6	3,389,166.1	2,128.4	2.1	1.7
11/29/2022 15:00	10.5	13.4	8.3	204.8	3,417,987.7	2,146.5	2.1	1.7
11/29/2022 16:00	10.8	13.3	8.4	224.3	3,391,657.9	2,253.8	2.3	2.0
11/29/2022 17:00	10.7	13.3	8.3	225.0	3,405,051.2	2,262.7	2.3	2.0
11/29/2022 18:00	10.6	13.3	8.2	228.0	3,415,585.2	2,269.7	2.3	2.0
11/29/2022 19:00	10.6	13.3	8.2	226.8	3,416,638.6	2,270.4	2.3	2.0
11/29/2022 20:00	10.5	13.3	8.2	224.6	3,461,600.5	2,275.0	2.3	2.0
11/29/2022 21:00	10.5	13.3	8.2	221.3	3,468,295.5	2,279.4	2.2	1.8
11/29/2022 22:00	10.4	13.3	8.1	220.1	3,470,730.0	2,281.0	2.2	1.8
11/29/2022 23:00	10.4	13.3	8.1	217.5	3,467,991.2	2,279.2	2.2	1.8
Average/Sum#:	10.6	13.3	8.3	212.2	3,439,977.0	2,203.1	2.1	1.8
Minimum:	10.3	13.2	8.1	183.7	3,383,911.3	2,087.1	1.8	1.5
Maximum:	11.0	13.4	8.4	228.0	3,503,444.0	2,281.7	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/30/2022 00:00	10.2	13.3	7.9	196.1	3,542,081.4	2,172.7	1.9	1.5
11/30/2022 01:00	10.4	13.4	8.2	195.8	3,511,921.4	2,154.2	1.9	1.5
11/30/2022 02:00	10.3	13.4	8.1	197.6	3,506,215.5	2,150.7	2.0	1.7
11/30/2022 03:00	10.2	13.4	8.0	195.6	3,507,845.8	2,151.7	1.9	1.5
11/30/2022 04:00	10.2	13.4	8.0	196.4	3,534,419.1	2,168.0	1.9	1.5
11/30/2022 05:00	10.2	13.4	8.0	192.3	3,529,691.3	2,165.1	1.9	1.5
11/30/2022 06:00	10.7	13.3	8.3	208.1	3,513,974.1	2,258.1	2.1	1.8
11/30/2022 07:00	10.2	13.4	8.0	193.5	3,498,716.3	2,146.1	1.9	1.5
11/30/2022 08:00	9.8	13.6	7.9	175.0	3,522,621.9	1,980.7	1.7	1.4
11/30/2022 09:00	9.9	13.5	7.9	171.7	3,501,688.4	1,994.5	1.7	1.4
11/30/2022 10:00	9.5	13.6	7.7	160.8	3,505,904.3	1,971.3	1.6	1.2
11/30/2022 11:00	9.8	13.6	7.9	171.2	3,451,476.1	1,965.9	1.7	1.4
11/30/2022 12:00	10.1	13.5	8.1	174.6	3,452,002.9	1,966.2	1.7	1.4
11/30/2022 13:00	10.4	13.5	8.3	172.0	3,405,186.4	1,964.4	1.7	1.4
11/30/2022 14:00	10.7	13.4	8.4	198.6	3,390,372.6	2,104.4	2.0	1.7
11/30/2022 15:00	10.7	13.3	8.3	202.7	3,364,962.3	2,113.2	2.1	1.7
11/30/2022 16:00	10.8	13.3	8.4	218.6	3,373,957.4	2,217.4	2.3	2.0
11/30/2022 17:00	10.8	13.2	8.3	223.4	3,372,505.2	2,265.7	2.3	2.0
11/30/2022 18:00	10.8	13.2	8.3	221.2	3,370,272.5	2,264.2	2.3	2.0
11/30/2022 19:00	10.7	13.2	8.2	225.1	3,369,677.1	2,263.8	2.3	2.0
11/30/2022 20:00	10.7	13.2	8.2	225.2	3,398,881.2	2,258.6	2.3	2.0
11/30/2022 21:00	10.6	13.2	8.1	220.2	3,385,217.1	2,224.8	2.3	2.0
11/30/2022 22:00	10.4	13.4	8.2	191.8	3,401,715.4	2,086.6	2.0	1.7
11/30/2022 23:00	13.5	14.1	11.7	171.8	3,014,445.4	1,584.9	1.9	1.1
Average/Sum#:	10.5	13.4	8.3	195.8	3,434,406.3	2,108.1	2.0	1.6
Minimum:	9.5	13.2	7.7	160.8	3,014,445.4	1,584.9	1.6	1.1
Maximum:	13.5	14.1	11.7	225.2	3,542,081.4	2,265.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2022 09:00	7.7	19.1	25.2	10.1	37,170.1	1.9	0.0	0.0
12/05/2022 10:00	44.9	16.7	63.1	84.6	1,497,449.6	470.2	0.0	0.0
12/05/2022 11:00	13.9	13.5	11.1	212.1	3,190,403.1	1,793.9	2.3	1.6
12/05/2022 12:00	11.1	13.3	8.6	221.9	3,369,571.0	2,140.7	2.3	1.9
12/05/2022 13:00	10.8	13.4	8.5	192.1	3,360,266.8	2,012.1	2.0	1.6
12/05/2022 14:00	10.9	13.4	8.6	202.1	3,394,001.4	2,032.3	2.1	1.6
12/05/2022 15:00	10.9	13.4	8.6	195.6	3,384,788.1	2,051.5	2.0	1.6
12/05/2022 16:00	11.0	13.3	8.5	214.4	3,375,246.4	2,193.6	2.2	1.8
12/05/2022 17:00	11.0	13.2	8.4	231.5	3,378,161.6	2,269.5	2.4	2.0
12/05/2022 18:00	10.9	13.2	8.4	229.6	3,381,138.6	2,271.5	2.4	2.0
12/05/2022 19:00	10.9	13.2	8.4	225.0	3,380,543.2	2,271.1	2.3	2.0
12/05/2022 20:00	10.8	13.2	8.3	220.4	3,419,196.9	2,272.1	2.3	2.0
12/05/2022 21:00	10.5	13.3	8.2	210.5	3,425,895.2	2,201.5	2.1	1.8
12/05/2022 22:00	10.3	13.4	8.1	195.0	3,451,951.5	2,067.0	2.0	1.7
12/05/2022 23:00	10.3	13.4	8.1	184.6	3,458,895.5	2,045.9	1.8	1.4
Average/Sum#:	13.1	13.9	13.3	188.6	3,033,645.3	1,873.0	1.9	1.5
Minimum:	7.7	13.2	8.1	10.1	37,170.1	1.9	0.0	0.0
Maximum:	44.9	19.1	63.1	231.5	3,458,895.5	2,272.1	2.4	2.0
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/06/2022 00:00	9.9	13.6	8.0	167.3	3,498,612.5	1,967.2	1.6	1.2
12/06/2022 01:00	9.9	13.6	8.0	172.9	3,496,656.2	1,966.1	1.7	1.4
12/06/2022 02:00	9.9	13.6	8.0	164.1	3,495,944.8	1,965.7	1.6	1.2
12/06/2022 03:00	9.8	13.6	7.9	167.3	3,498,256.8	1,967.0	1.6	1.2
12/06/2022 04:00	10.1	13.5	8.1	179.3	3,480,093.6	1,982.2	1.8	1.4
12/06/2022 05:00	10.2	13.6	8.2	180.3	3,439,480.5	2,009.3	1.8	1.4
12/06/2022 06:00	10.3	13.6	8.3	166.9	3,479,742.5	1,982.0	1.6	1.2
12/06/2022 07:00	10.7	13.4	8.4	196.6	3,481,344.0	2,084.6	2.0	1.7
12/06/2022 08:00	10.9	13.2	8.4	219.5	3,437,559.5	2,259.2	2.2	1.8
12/06/2022 09:00	10.7	13.3	8.3	215.3	3,446,795.0	2,240.1	2.2	1.8
12/06/2022 10:00	10.5	13.3	8.2	215.2	3,438,640.0	2,234.8	2.2	1.8
12/06/2022 11:00	10.6	13.3	8.2	220.4	3,432,177.6	2,230.6	2.2	1.8
12/06/2022 12:00	10.5	13.3	8.2	218.2	3,412,636.3	2,217.9	2.2	1.8
12/06/2022 13:00	9.6	13.7	7.9	161.8	3,355,652.5	1,788.8	1.7	1.3
12/06/2022 14:00	11.1	14.0	9.5	129.7	2,579,995.5	1,318.8	1.7	0.9
12/06/2022 15:00	11.2	14.0	9.6	127.2	2,579,604.3	1,318.6	1.7	0.9
12/06/2022 16:00	10.8	13.9	9.1	158.9	2,933,268.5	1,520.8	1.9	1.1
12/06/2022 17:00	9.7	13.8	8.1	158.3	3,468,257.5	1,823.5	1.6	1.1
12/06/2022 18:00	9.7	13.8	8.1	162.1	3,471,300.6	1,825.1	1.6	1.1
12/06/2022 19:00	9.9	13.7	8.1	157.5	3,479,288.9	1,829.3	1.5	1.1
12/06/2022 20:00	10.8	13.4	8.5	198.6	3,461,709.2	2,123.4	2.0	1.7
12/06/2022 21:00	10.8	13.2	8.3	219.0	3,417,252.4	2,220.9	2.2	1.8
12/06/2022 22:00	10.5	13.4	8.3	195.4	3,418,018.1	2,096.6	2.0	1.7
12/06/2022 23:00	9.9	13.6	8.0	166.7	3,501,280.2	1,968.7	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	179.9	3,362,648.6	1,955.9	1.8	1.4
Minimum:	9.6	13.2	7.9	127.2	2,579,604.3	1,318.6	1.5	0.9
Maximum:	11.2	14.0	9.6	220.4	3,501,280.2	2,259.2	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/07/2022 00:00	10.4	13.4	8.2	194.2	3,474,329.9	2,080.4	1.9	1.5
12/07/2022 01:00	9.8	13.5	7.8	175.2	3,482,376.0	1,983.5	1.7	1.4
12/07/2022 02:00	10.4	13.3	8.1	187.1	3,477,522.8	2,133.1	1.9	1.5
12/07/2022 03:00	10.4	13.3	8.1	193.6	3,489,749.8	2,140.6	1.9	1.5
12/07/2022 04:00	10.5	13.3	8.2	200.6	3,459,327.1	2,147.2	2.0	1.7
12/07/2022 05:00	10.6	13.3	8.2	186.7	3,441,395.3	2,161.2	1.9	1.5
12/07/2022 06:00	10.9	13.3	8.5	202.6	3,485,807.5	2,240.0	2.0	1.8
12/07/2022 07:00	10.5	13.3	8.2	213.7	3,447,410.5	2,240.5	2.2	1.8
12/07/2022 08:00	10.2	13.4	8.0	198.3	3,503,746.5	2,123.6	2.0	1.7
12/07/2022 09:00	10.3	13.3	8.0	200.8	3,522,192.1	2,160.5	2.0	1.7
12/07/2022 10:00	10.4	13.3	8.1	197.3	3,471,410.3	2,154.7	2.0	1.7
12/07/2022 11:00	10.4	13.3	8.1	200.9	3,467,060.3	2,152.0	2.0	1.7
12/07/2022 12:00	10.4	13.4	8.2	200.6	3,464,969.7	2,125.4	2.0	1.7
12/07/2022 13:00	10.4	13.4	8.2	202.0	3,431,875.3	2,105.1	2.0	1.7
12/07/2022 14:00	10.2	13.4	8.0	188.2	3,415,544.8	2,045.2	1.9	1.4
12/07/2022 15:00	10.3	13.4	8.1	189.4	3,420,096.2	2,072.9	1.9	1.5
12/07/2022 16:00	10.6	13.3	8.2	217.8	3,411,844.8	2,242.3	2.2	1.8
12/07/2022 17:00	10.5	13.2	8.0	223.4	3,405,653.1	2,263.1	2.3	2.0
12/07/2022 18:00	10.5	13.2	8.0	223.5	3,442,732.9	2,262.6	2.3	2.0
12/07/2022 19:00	10.4	13.2	8.0	221.9	3,438,016.0	2,259.5	2.3	2.0
12/07/2022 20:00	10.4	13.3	8.1	218.6	3,439,385.4	2,260.4	2.2	1.8
12/07/2022 21:00	10.3	13.3	8.0	213.2	3,469,567.5	2,254.9	2.1	1.8
12/07/2022 22:00	10.2	13.3	7.9	196.3	3,498,959.9	2,171.8	2.0	1.7
12/07/2022 23:00	10.3	13.3	8.0	197.8	3,497,993.2	2,171.2	2.0	1.7
Average/Sum#:	10.4	13.3	8.1	201.8	3,460,790.3	2,164.7	2.0	1.7
Minimum:	9.8	13.2	7.8	175.2	3,405,653.1	1,983.5	1.7	1.4
Maximum:	10.9	13.5	8.5	223.5	3,522,192.1	2,263.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/08/2022 00:00	10.3	13.3	8.0	198.2	3,511,501.1	2,128.3	2.0	1.7
12/08/2022 01:00	10.3	13.3	8.0	194.6	3,504,406.5	2,124.0	1.9	1.5
12/08/2022 02:00	10.3	13.3	8.0	190.1	3,506,716.4	2,125.4	1.9	1.5
12/08/2022 03:00	10.3	13.3	8.0	194.1	3,508,696.3	2,126.6	1.9	1.5
12/08/2022 04:00	10.5	13.3	8.2	201.5	3,508,008.8	2,151.8	2.0	1.7
12/08/2022 05:00	10.6	13.3	8.2	196.2	3,433,364.8	2,206.3	2.0	1.8
12/08/2022 06:00	11.0	13.2	8.4	215.3	3,503,110.7	2,276.7	2.1	1.8
12/08/2022 07:00	10.6	13.2	8.1	210.4	3,519,420.7	2,235.9	2.1	1.8
12/08/2022 08:00	10.3	13.5	8.2	195.0	3,524,621.0	2,033.3	1.9	1.4
12/08/2022 09:00	10.4	13.3	8.1	185.3	3,540,129.0	2,119.8	1.8	1.5
12/08/2022 10:00	10.5	13.3	8.2	196.8	3,506,386.4	2,125.2	1.9	1.5
12/08/2022 11:00	10.6	13.3	8.2	200.0	3,508,987.0	2,152.4	2.0	1.7
12/08/2022 12:00	10.6	13.3	8.2	195.5	3,457,877.1	2,146.3	2.0	1.7
12/08/2022 13:00	10.6	13.3	8.2	202.2	3,426,108.7	2,151.6	2.1	1.7
12/08/2022 14:00	10.7	13.3	8.3	206.0	3,430,089.6	2,154.1	2.1	1.7
12/08/2022 15:00	10.6	13.3	8.2	205.4	3,441,076.9	2,161.0	2.1	1.7
12/08/2022 16:00	10.6	13.2	8.1	217.2	3,389,701.6	2,252.5	2.2	1.8
12/08/2022 17:00	10.5	13.2	8.0	216.2	3,429,190.8	2,253.7	2.2	1.8
12/08/2022 18:00	10.6	13.2	8.1	222.0	3,402,342.4	2,260.9	2.3	2.0
12/08/2022 19:00	10.5	13.2	8.0	222.4	3,399,332.7	2,258.9	2.3	2.0
12/08/2022 20:00	10.5	13.2	8.0	222.0	3,401,740.5	2,260.5	2.3	2.0
12/08/2022 21:00	10.5	13.2	8.0	221.0	3,404,449.2	2,262.3	2.3	2.0
12/08/2022 22:00	10.5	13.3	8.2	201.7	3,424,033.2	2,175.3	2.1	1.7
12/08/2022 23:00	10.5	13.3	8.2	204.5	3,464,484.5	2,175.7	2.1	1.7
Average/Sum#:	10.5	13.3	8.1	204.7	3,464,407.3	2,179.9	2.1	1.7
Minimum:	10.3	13.2	8.0	185.3	3,389,701.6	2,033.3	1.8	1.4
Maximum:	11.0	13.5	8.4	222.4	3,540,129.0	2,276.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/09/2022 00:00	10.5	13.3	8.2	200.0	3,437,094.1	2,133.4	2.0	1.7
12/09/2022 01:00	10.3	13.4	8.1	189.3	3,507,951.7	2,049.3	1.9	1.4
12/09/2022 02:00	10.5	13.3	8.2	193.0	3,497,901.1	2,145.6	1.9	1.5
12/09/2022 03:00	10.5	13.3	8.2	194.7	3,491,706.1	2,141.8	1.9	1.5
12/09/2022 04:00	10.3	13.3	8.0	201.5	3,484,388.9	2,188.2	2.0	1.8
12/09/2022 05:00	10.5	13.2	8.0	194.5	3,467,686.9	2,279.0	2.0	1.8
12/09/2022 06:00	10.8	13.2	8.3	214.6	3,476,207.7	2,284.6	2.2	1.8
12/09/2022 07:00	10.5	13.2	8.0	211.9	3,498,340.8	2,273.6	2.1	1.8
12/09/2022 08:00	10.0	13.4	7.9	183.9	3,499,132.9	2,069.7	1.8	1.4
12/09/2022 09:00	10.0	13.5	8.0	183.6	3,508,499.9	2,024.0	1.8	1.4
12/09/2022 10:00	10.1	13.6	8.2	178.2	3,514,085.2	1,975.9	1.7	1.4
12/09/2022 11:00	10.4	13.4	8.2	193.1	3,502,007.0	2,071.4	1.9	1.4
12/09/2022 12:00	10.2	13.5	8.1	177.9	3,472,790.9	2,003.4	1.8	1.4
12/09/2022 13:00	10.6	13.3	8.2	201.2	3,459,166.0	2,147.1	2.0	1.7
12/09/2022 14:00	10.6	13.3	8.2	202.3	3,443,860.7	2,137.6	2.0	1.7
12/09/2022 15:00	10.3	13.4	8.1	178.2	3,442,158.1	2,036.0	1.8	1.4
12/09/2022 16:00	10.8	13.2	8.3	218.7	3,425,843.3	2,251.5	2.2	1.8
12/09/2022 17:00	10.7	13.2	8.2	219.8	3,425,234.7	2,251.1	2.2	1.8
12/09/2022 18:00	10.6	13.2	8.1	221.0	3,426,147.7	2,251.7	2.3	2.0
12/09/2022 19:00	10.6	13.2	8.1	222.9	3,429,038.7	2,253.6	2.3	2.0
12/09/2022 20:00	10.6	13.2	8.1	222.6	3,436,037.9	2,258.2	2.3	2.0
12/09/2022 21:00	10.6	13.2	8.1	218.6	3,434,668.5	2,257.3	2.2	1.8
12/09/2022 22:00	10.6	13.2	8.1	217.9	3,432,081.8	2,255.6	2.2	1.8
12/09/2022 23:00	10.6	13.2	8.1	217.3	3,422,191.5	2,249.1	2.2	1.8
Average/Sum#:	10.5	13.3	8.1	202.4	3,463,925.9	2,166.2	2.0	1.7
Minimum:	10.0	13.2	7.9	177.9	3,422,191.5	1,975.9	1.7	1.4
Maximum:	10.8	13.6	8.3	222.9	3,514,085.2	2,284.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/10/2022 00:00	10.0	13.5	8.0	180.5	3,434,516.4	2,006.4	1.8	1.4
12/10/2022 01:00	10.1	13.4	7.9	179.4	3,422,876.2	1,999.6	1.8	1.4
12/10/2022 02:00	10.0	13.5	8.0	165.1	3,447,087.0	1,963.4	1.6	1.2
12/10/2022 03:00	10.2	13.5	8.1	176.4	3,404,839.7	1,964.2	1.8	1.4
12/10/2022 04:00	10.2	13.5	8.1	167.7	3,395,825.8	1,959.0	1.7	1.4
12/10/2022 05:00	10.2	13.5	8.1	188.0	3,373,405.8	1,970.7	1.9	1.4
12/10/2022 06:00	10.6	13.5	8.5	166.1	3,394,612.4	1,958.3	1.7	1.4
12/10/2022 07:00	10.5	13.4	8.3	174.3	3,406,746.5	1,965.3	1.8	1.4
12/10/2022 08:00	10.6	13.4	8.3	175.7	3,390,593.3	2,005.5	1.8	1.4
12/10/2022 09:00	10.6	13.4	8.3	177.3	3,392,235.4	1,981.7	1.8	1.4
12/10/2022 10:00	10.5	13.4	8.3	170.0	3,394,439.0	1,958.2	1.7	1.4
12/10/2022 11:00	10.7	13.4	8.4	181.3	3,341,729.5	2,001.0	1.9	1.4
12/10/2022 12:00	10.7	13.3	8.3	196.3	3,340,280.8	2,097.7	2.0	1.7
12/10/2022 13:00	10.7	13.2	8.2	202.2	3,317,238.2	2,155.9	2.1	1.7
12/10/2022 14:00	10.5	13.4	8.3	183.6	3,303,777.6	2,002.4	1.9	1.4
12/10/2022 15:00	10.6	13.4	8.3	192.8	3,340,405.6	2,024.6	2.0	1.6
12/10/2022 16:00	10.6	13.3	8.2	195.2	3,334,707.6	2,094.2	2.0	1.7
12/10/2022 17:00	10.5	13.4	8.3	188.0	3,353,622.5	2,057.1	1.9	1.4
12/10/2022 18:00	10.5	13.3	8.2	193.3	3,355,252.8	2,058.1	2.0	1.6
12/10/2022 19:00	10.7	13.2	8.2	218.9	3,355,691.7	2,229.9	2.3	2.0
12/10/2022 20:00	10.5	13.3	8.2	201.9	3,351,666.2	2,153.8	2.1	1.7
12/10/2022 21:00	10.3	13.4	8.1	188.8	3,372,696.6	2,068.8	1.9	1.4
12/10/2022 22:00	10.2	13.4	8.0	186.2	3,397,017.8	2,009.3	1.9	1.4
12/10/2022 23:00	10.4	13.4	8.2	186.2	3,364,056.2	2,063.5	1.9	1.4
Average/Sum#:	10.4	13.4	8.2	184.8	3,374,388.4	2,031.2	1.9	1.5
Minimum:	10.0	13.2	7.9	165.1	3,303,777.6	1,958.2	1.6	1.2
Maximum:	10.7	13.5	8.5	218.9	3,447,087.0	2,229.9	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/11/2022 00:00	10.0	13.5	8.0	169.1	3,391,492.2	1,956.5	1.7	1.4
12/11/2022 01:00	10.0	13.5	8.0	172.5	3,431,461.5	1,954.5	1.7	1.4
12/11/2022 02:00	10.0	13.5	8.0	164.6	3,431,461.5	1,954.5	1.6	1.2
12/11/2022 03:00	10.0	13.5	8.0	170.5	3,428,828.0	1,953.0	1.7	1.4
12/11/2022 04:00	9.9	13.5	7.9	168.1	3,433,041.6	1,955.4	1.7	1.4
12/11/2022 05:00	9.9	13.5	7.9	186.3	3,434,095.0	1,956.0	1.9	1.4
12/11/2022 06:00	10.1	13.6	8.2	165.0	3,438,484.2	1,958.5	1.6	1.2
12/11/2022 07:00	9.9	13.6	8.0	160.2	3,441,995.5	1,960.5	1.6	1.2
12/11/2022 08:00	9.8	13.6	7.9	164.4	3,443,751.2	1,961.5	1.6	1.2
12/11/2022 09:00	9.8	13.5	7.8	170.9	3,449,018.2	1,964.5	1.7	1.4
12/11/2022 10:00	9.9	13.5	7.9	167.5	3,447,613.7	1,963.7	1.7	1.4
12/11/2022 11:00	10.0	13.5	8.0	174.7	3,440,766.5	1,959.8	1.7	1.4
12/11/2022 12:00	10.1	13.5	8.1	169.9	3,438,308.6	1,958.4	1.7	1.4
12/11/2022 13:00	10.2	13.5	8.1	170.3	3,398,599.3	1,960.6	1.7	1.4
12/11/2022 14:00	10.3	13.5	8.2	179.8	3,394,439.0	1,958.2	1.8	1.4
12/11/2022 15:00	10.6	13.4	8.3	185.1	3,423,728.0	2,050.1	1.9	1.4
12/11/2022 16:00	10.4	13.4	8.2	183.6	3,429,907.1	2,053.8	1.8	1.4
12/11/2022 17:00	10.5	13.3	8.2	201.2	3,421,627.7	2,123.8	2.0	1.7
12/11/2022 18:00	10.3	13.4	8.1	181.2	3,492,716.9	2,040.4	1.8	1.4
12/11/2022 19:00	10.4	13.4	8.2	185.4	3,496,935.1	2,068.4	1.8	1.4
12/11/2022 20:00	10.4	13.3	8.1	193.1	3,496,321.9	2,119.1	1.9	1.5
12/11/2022 21:00	10.2	13.5	8.1	178.6	3,516,084.9	2,002.7	1.7	1.4
12/11/2022 22:00	10.3	13.6	8.3	181.9	3,500,213.2	1,968.1	1.8	1.4
12/11/2022 23:00	10.3	13.6	8.3	185.1	3,496,300.5	1,965.9	1.8	1.4
Average/Sum#:	10.1	13.5	8.1	176.2	3,446,549.6	1,990.3	1.7	1.4
Minimum:	9.8	13.3	7.8	160.2	3,391,492.2	1,953.0	1.6	1.2
Maximum:	10.6	13.6	8.3	201.2	3,516,084.9	2,123.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/12/2022 00:00	10.2	13.6	8.2	174.6	3,511,773.2	1,974.6	1.7	1.4
12/12/2022 01:00	10.1	13.6	8.2	176.5	3,511,951.1	1,974.7	1.7	1.4
12/12/2022 02:00	10.0	13.6	8.1	169.4	3,511,773.2	1,974.6	1.7	1.4
12/12/2022 03:00	10.1	13.6	8.2	178.3	3,507,860.6	1,972.4	1.7	1.4
12/12/2022 04:00	9.8	13.6	7.9	171.9	3,513,018.2	1,975.3	1.7	1.4
12/12/2022 05:00	10.2	13.4	8.0	199.4	3,401,328.0	2,111.2	2.0	1.7
12/12/2022 06:00	10.7	13.3	8.3	204.5	3,511,777.4	2,205.4	2.0	1.8
12/12/2022 07:00	10.4	13.3	8.1	199.3	3,483,751.9	2,187.8	2.0	1.8
12/12/2022 08:00	10.1	13.4	7.9	178.0	3,506,571.7	2,074.1	1.8	1.5
12/12/2022 09:00	10.1	13.4	7.9	187.6	3,493,215.6	2,066.2	1.9	1.4
12/12/2022 10:00	9.6	13.6	7.8	162.5	3,509,639.1	1,973.4	1.6	1.2
12/12/2022 11:00	9.7	13.6	7.8	165.6	3,500,213.2	1,968.1	1.6	1.2
12/12/2022 12:00	9.8	13.6	7.9	169.4	3,492,921.4	1,964.0	1.7	1.4
12/12/2022 13:00	9.9	13.6	8.0	165.3	3,442,873.4	1,961.0	1.6	1.2
12/12/2022 14:00	9.9	13.6	8.0	167.6	3,430,056.9	1,953.7	1.7	1.4
12/12/2022 15:00	10.0	13.6	8.1	172.0	3,434,972.8	1,956.5	1.7	1.4
12/12/2022 16:00	10.5	13.4	8.3	194.4	3,434,677.5	2,131.9	2.0	1.7
12/12/2022 17:00	10.5	13.3	8.2	213.6	3,410,174.5	2,216.3	2.2	1.8
12/12/2022 18:00	10.5	13.3	8.2	224.4	3,424,012.4	2,275.3	2.3	2.0
12/12/2022 19:00	10.4	13.3	8.1	224.3	3,426,570.7	2,277.0	2.3	2.0
12/12/2022 20:00	10.4	13.3	8.1	225.6	3,432,590.1	2,281.0	2.3	2.1
12/12/2022 21:00	10.3	13.3	8.0	216.2	3,456,796.4	2,246.6	2.2	1.8
12/12/2022 22:00	10.3	13.3	8.0	201.4	3,485,344.3	2,188.8	2.0	1.8
12/12/2022 23:00	10.0	13.5	8.0	174.0	3,510,406.7	2,025.1	1.7	1.4
Average/Sum#:	10.1	13.5	8.1	188.2	3,472,677.9	2,080.6	1.9	1.6
Minimum:	9.6	13.3	7.8	162.5	3,401,328.0	1,953.7	1.6	1.2
Maximum:	10.7	13.6	8.3	225.6	3,513,018.2	2,281.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/13/2022 00:00	10.3	13.3	8.0	194.9	3,548,954.0	2,151.0	1.9	1.5
12/13/2022 01:00	10.3	13.3	8.0	199.0	3,517,138.3	2,157.4	2.0	1.7
12/13/2022 02:00	10.3	13.4	8.1	198.4	3,482,204.5	2,161.4	2.0	1.7
12/13/2022 03:00	10.4	13.4	8.2	192.2	3,499,205.4	2,146.4	1.9	1.5
12/13/2022 04:00	10.3	13.3	8.0	197.7	3,526,831.7	2,189.1	1.9	1.5
12/13/2022 05:00	10.4	13.3	8.1	219.1	3,498,648.5	2,273.8	2.2	1.8
12/13/2022 06:00	10.8	13.3	8.4	221.7	3,515,160.2	2,310.2	2.2	1.8
12/13/2022 07:00	10.5	13.3	8.2	223.6	3,481,076.8	2,287.8	2.3	2.1
12/13/2022 08:00	10.1	13.4	7.9	193.0	3,478,990.0	2,134.0	1.9	1.5
12/13/2022 09:00	9.9	13.5	7.9	176.7	3,484,751.7	2,010.3	1.8	1.4
12/13/2022 10:00	9.6	13.6	7.8	165.9	3,492,032.2	1,963.5	1.6	1.2
12/13/2022 11:00	9.8	13.6	7.9	173.3	3,496,834.1	1,966.2	1.7	1.4
12/13/2022 12:00	9.9	13.6	8.0	167.0	3,447,964.8	1,963.9	1.7	1.4
12/13/2022 13:00	9.9	13.6	8.0	166.8	3,439,010.9	1,958.8	1.7	1.4
12/13/2022 14:00	9.9	13.6	8.0	174.7	3,420,751.9	1,948.4	1.8	1.4
12/13/2022 15:00	10.3	13.5	8.2	185.1	3,433,414.1	2,055.9	1.9	1.4
12/13/2022 16:00	10.7	13.3	8.3	220.3	3,425,691.2	2,251.4	2.3	2.0
12/13/2022 17:00	10.5	13.3	8.2	224.6	3,417,842.5	2,271.2	2.3	2.0
12/13/2022 18:00	10.4	13.3	8.1	223.4	3,420,701.7	2,273.1	2.3	2.0
12/13/2022 19:00	10.3	13.3	8.0	223.6	3,455,057.7	2,270.7	2.3	2.0
12/13/2022 20:00	10.2	13.3	7.9	221.2	3,452,927.5	2,269.3	2.3	2.0
12/13/2022 21:00	10.2	13.3	7.9	219.9	3,498,956.2	2,274.0	2.2	1.8
12/13/2022 22:00	10.3	13.3	8.0	218.2	3,496,186.6	2,272.2	2.2	1.8
12/13/2022 23:00	10.3	13.3	8.0	215.6	3,450,949.4	2,268.0	2.2	1.8
Average/Sum#:	10.2	13.4	8.0	200.7	3,474,220.1	2,159.5	2.0	1.7
Minimum:	9.6	13.3	7.8	165.9	3,417,842.5	1,948.4	1.6	1.2
Maximum:	10.8	13.6	8.4	224.6	3,548,954.0	2,310.2	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/14/2022 00:00	10.1	13.3	7.8	198.1	3,482,159.6	2,186.8	2.0	1.7
12/14/2022 01:00	10.1	13.3	7.8	197.8	3,524,253.9	2,187.5	2.0	1.8
12/14/2022 02:00	10.1	13.3	7.8	200.8	3,525,703.9	2,188.4	2.0	1.8
12/14/2022 03:00	10.1	13.3	7.8	199.8	3,527,798.3	2,189.7	2.0	1.8
12/14/2022 04:00	10.1	13.3	7.8	198.9	3,522,481.7	2,186.4	2.0	1.7
12/14/2022 05:00	10.3	13.3	8.0	209.6	3,526,344.7	2,291.8	2.1	1.8
12/14/2022 06:00	10.6	13.3	8.2	207.6	3,534,499.7	2,297.1	2.0	1.8
12/14/2022 07:00	10.3	13.3	8.0	214.0	3,509,305.6	2,255.1	2.1	1.8
12/14/2022 08:00	9.9	13.4	7.8	182.7	3,542,700.9	2,069.6	1.8	1.4
12/14/2022 09:00	9.8	13.6	7.9	173.1	3,525,214.4	2,007.9	1.7	1.4
12/14/2022 10:00	9.9	13.5	7.9	175.8	3,508,326.6	2,023.9	1.7	1.4
12/14/2022 11:00	9.7	13.7	7.9	177.3	3,498,968.2	1,967.4	1.7	1.4
12/14/2022 12:00	9.6	13.7	7.9	161.3	3,499,501.8	1,967.7	1.6	1.2
12/14/2022 13:00	9.7	13.6	7.8	167.3	3,497,189.8	1,966.4	1.6	1.2
12/14/2022 14:00	9.6	13.6	7.8	168.5	3,489,186.6	1,961.9	1.7	1.4
12/14/2022 15:00	9.9	13.5	7.9	170.4	3,473,657.6	2,003.9	1.7	1.4
12/14/2022 16:00	10.4	13.3	8.1	205.3	3,457,717.9	2,196.7	2.1	1.8
12/14/2022 17:00	10.5	13.3	8.2	221.2	3,454,296.9	2,270.2	2.2	1.8
12/14/2022 18:00	10.5	13.3	8.2	222.4	3,444,406.6	2,263.7	2.3	2.0
12/14/2022 19:00	10.5	13.3	8.2	222.6	3,453,992.6	2,270.0	2.3	2.0
12/14/2022 20:00	10.4	13.3	8.1	218.7	3,453,688.3	2,269.8	2.2	1.8
12/14/2022 21:00	10.4	13.3	8.1	216.7	3,494,186.3	2,270.9	2.2	1.8
12/14/2022 22:00	10.3	13.3	8.0	211.7	3,501,524.8	2,250.1	2.1	1.8
12/14/2022 23:00	10.2	13.4	8.0	201.5	3,500,248.7	2,172.6	2.0	1.7
Average/Sum#:	10.1	13.4	8.0	196.8	3,497,806.5	2,154.8	2.0	1.7
Minimum:	9.6	13.3	7.8	161.3	3,444,406.6	1,961.9	1.6	1.2
Maximum:	10.6	13.7	8.2	222.6	3,542,700.9	2,297.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/15/2022 00:00	10.3	13.3	8.0	221.6	3,477,120.7	2,285.2	2.2	1.8
12/15/2022 01:00	10.3	13.3	8.0	222.3	3,490,814.9	2,294.2	2.2	1.8
12/15/2022 02:00	10.3	13.3	8.0	218.8	3,492,184.3	2,295.1	2.2	1.8
12/15/2022 03:00	10.3	13.3	8.0	217.7	3,494,771.0	2,296.8	2.2	1.8
12/15/2022 04:00	10.4	13.3	8.1	222.7	3,503,291.9	2,302.4	2.2	1.8
12/15/2022 05:00	10.5	13.3	8.2	240.5	3,469,609.7	2,305.6	2.4	2.1
12/15/2022 06:00	10.9	13.3	8.5	225.8	3,467,051.5	2,303.9	2.3	2.1
12/15/2022 07:00	10.6	13.3	8.2	226.8	3,496,140.5	2,297.7	2.3	2.1
12/15/2022 08:00	10.4	13.3	8.1	212.6	3,489,513.7	2,216.9	2.1	1.8
12/15/2022 09:00	10.5	13.3	8.2	211.8	3,439,900.7	2,210.5	2.2	1.8
12/15/2022 10:00	9.9	13.6	8.0	171.7	3,468,506.2	1,975.6	1.7	1.4
12/15/2022 11:00	10.1	13.5	8.1	182.9	3,439,162.0	1,984.0	1.8	1.4
12/15/2022 12:00	10.2	13.5	8.1	186.8	3,399,046.6	2,010.5	1.9	1.4
12/15/2022 13:00	10.5	13.5	8.4	186.2	3,427,449.4	2,027.3	1.9	1.4
12/15/2022 14:00	10.6	13.4	8.3	203.9	3,385,738.8	2,076.8	2.1	1.7
12/15/2022 15:00	10.6	13.3	8.2	225.9	3,384,456.3	2,224.3	2.3	2.0
12/15/2022 16:00	10.4	13.3	8.1	224.0	3,412,301.2	2,242.6	2.3	2.0
12/15/2022 17:00	10.4	13.3	8.1	222.0	3,408,953.8	2,240.4	2.3	2.0
12/15/2022 18:00	10.3	13.3	8.0	215.4	3,436,024.3	2,233.1	2.2	1.8
12/15/2022 19:00	10.4	13.3	8.1	213.6	3,431,716.0	2,230.3	2.2	1.8
12/15/2022 20:00	10.3	13.3	8.0	216.2	3,435,408.8	2,232.7	2.2	1.8
12/15/2022 21:00	10.2	13.3	7.9	216.2	3,483,317.7	2,238.4	2.2	1.8
12/15/2022 22:00	10.2	13.3	7.9	215.9	3,490,009.2	2,242.7	2.2	1.8
12/15/2022 23:00	10.2	13.3	7.9	212.1	3,510,606.0	2,230.3	2.1	1.8
Average/Sum#:	10.4	13.3	8.1	213.1	3,455,545.6	2,208.2	2.2	1.8
Minimum:	9.9	13.3	7.9	171.7	3,384,456.3	1,975.6	1.7	1.4
Maximum:	10.9	13.6	8.5	240.5	3,510,606.0	2,305.6	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/16/2022 00:00	10.0	13.6	8.1	176.3	3,500,283.8	1,993.7	1.7	1.4
12/16/2022 01:00	10.1	13.6	8.2	183.9	3,499,323.9	1,967.6	1.8	1.4
12/16/2022 02:00	10.1	13.6	8.2	175.3	3,498,079.0	1,966.9	1.7	1.4
12/16/2022 03:00	10.0	13.7	8.2	177.6	3,503,058.7	1,969.7	1.7	1.4
12/16/2022 04:00	10.0	13.7	8.2	175.0	3,501,102.4	1,968.6	1.7	1.4
12/16/2022 05:00	9.9	13.7	8.1	195.8	3,526,534.6	1,982.9	1.9	1.4
12/16/2022 06:00	10.6	13.5	8.5	193.4	3,530,609.9	2,114.1	1.9	1.5
12/16/2022 07:00	10.5	13.3	8.2	200.3	3,516,076.7	2,208.1	2.0	1.8
12/16/2022 08:00	10.3	13.4	8.1	193.6	3,535,259.8	2,142.7	1.9	1.5
12/16/2022 09:00	10.1	13.5	8.1	194.3	3,450,448.4	2,066.1	2.0	1.7
12/16/2022 10:00	10.9	13.9	9.2	154.3	2,975,894.2	1,542.9	1.8	1.1
12/16/2022 11:00	11.4	13.9	9.6	144.8	2,858,966.8	1,461.4	1.7	1.0
12/16/2022 12:00	11.1	14.0	9.5	134.0	2,590,950.9	1,324.4	1.8	0.9
12/16/2022 13:00	11.1	14.0	9.5	129.9	2,594,667.9	1,326.3	1.7	0.9
12/16/2022 14:00	11.0	13.9	9.3	160.3	3,062,688.7	1,587.9	1.8	1.1
12/16/2022 15:00	11.1	13.9	9.4	148.0	3,000,775.3	1,555.8	1.7	1.1
12/16/2022 16:00	10.7	13.4	8.4	200.3	3,459,004.9	2,147.0	2.0	1.7
12/16/2022 17:00	10.6	13.3	8.2	217.7	3,419,252.7	2,222.2	2.2	1.8
12/16/2022 18:00	10.4	13.4	8.2	200.7	3,463,838.1	2,150.0	2.0	1.7
12/16/2022 19:00	10.4	13.4	8.2	199.8	3,479,626.8	2,159.8	2.0	1.7
12/16/2022 20:00	10.6	13.3	8.2	223.4	3,413,975.0	2,243.7	2.3	2.0
12/16/2022 21:00	10.6	13.4	8.3	216.8	3,443,394.0	2,187.6	2.2	1.8
12/16/2022 22:00	9.9	13.5	7.9	185.1	3,486,020.1	2,087.4	1.8	1.5
12/16/2022 23:00	9.5	13.7	7.8	163.6	3,515,330.2	1,976.6	1.6	1.2
Average/Sum#:	10.5	13.6	8.5	181.0	3,326,048.5	1,931.4	1.9	1.4
Minimum:	9.5	13.3	7.8	129.9	2,590,950.9	1,324.4	1.6	0.9
Maximum:	11.4	14.0	9.6	223.4	3,535,259.8	2,243.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/17/2022 00:00	10.4	13.4	8.2	200.7	3,498,879.3	2,146.2	2.0	1.7
12/17/2022 01:00	10.4	13.4	8.2	200.4	3,503,118.0	2,148.8	2.0	1.7
12/17/2022 02:00	10.3	13.4	8.1	196.6	3,489,749.8	2,140.6	2.0	1.7
12/17/2022 03:00	10.3	13.4	8.1	193.2	3,510,291.2	2,153.2	1.9	1.5
12/17/2022 04:00	10.3	13.4	8.1	196.8	3,510,943.3	2,153.6	1.9	1.5
12/17/2022 05:00	10.4	13.4	8.2	202.5	3,507,356.7	2,151.4	2.0	1.7
12/17/2022 06:00	10.8	13.3	8.4	213.7	3,516,115.2	2,233.8	2.1	1.8
12/17/2022 07:00	10.2	13.4	8.0	186.0	3,505,726.4	2,099.2	1.8	1.5
12/17/2022 08:00	10.4	13.4	8.2	196.0	3,520,072.8	2,159.2	1.9	1.5
12/17/2022 09:00	10.2	13.4	8.0	192.9	3,493,187.1	2,117.2	1.9	1.5
12/17/2022 10:00	9.8	13.6	7.9	174.7	3,507,131.0	1,997.6	1.7	1.4
12/17/2022 11:00	9.6	13.6	7.8	169.4	3,493,632.8	1,964.4	1.7	1.4
12/17/2022 12:00	9.7	13.6	7.8	162.4	3,487,408.1	1,960.9	1.6	1.2
12/17/2022 13:00	9.8	13.6	7.9	169.3	3,435,148.4	1,956.6	1.7	1.4
12/17/2022 14:00	9.9	13.6	8.0	176.5	3,414,893.7	1,970.0	1.8	1.4
12/17/2022 15:00	10.3	13.4	8.1	190.6	3,424,050.0	2,100.3	1.9	1.5
12/17/2022 16:00	10.5	13.3	8.2	220.7	3,420,670.0	2,248.1	2.3	2.0
12/17/2022 17:00	10.3	13.3	8.0	214.2	3,412,482.5	2,217.8	2.2	1.8
12/17/2022 18:00	10.2	13.4	8.0	201.0	3,443,860.7	2,137.6	2.0	1.7
12/17/2022 19:00	10.3	13.3	8.0	223.1	3,400,988.0	2,260.0	2.3	2.0
12/17/2022 20:00	10.3	13.3	8.0	224.3	3,405,803.6	2,263.2	2.3	2.0
12/17/2022 21:00	10.3	13.3	8.0	222.0	3,408,060.9	2,264.7	2.3	2.0
12/17/2022 22:00	10.2	13.3	7.9	216.0	3,441,211.3	2,261.6	2.2	1.8
12/17/2022 23:00	10.0	13.4	7.9	200.4	3,471,650.0	2,180.2	2.0	1.7
Average/Sum#:	10.2	13.4	8.0	197.6	3,467,601.3	2,136.9	2.0	1.6
Minimum:	9.6	13.3	7.8	162.4	3,400,988.0	1,956.6	1.6	1.2
Maximum:	10.8	13.6	8.4	224.3	3,520,072.8	2,264.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/18/2022 00:00	10.0	13.4	7.9	193.8	3,476,544.6	2,132.5	1.9	1.5
12/18/2022 01:00	9.9	13.4	7.8	192.9	3,523,380.4	2,135.5	1.9	1.5
12/18/2022 02:00	9.7	13.5	7.7	169.2	3,504,339.7	2,021.6	1.7	1.4
12/18/2022 03:00	9.4	13.7	7.7	160.7	3,514,085.2	1,975.9	1.6	1.2
12/18/2022 04:00	10.2	13.4	8.0	193.2	3,523,380.4	2,135.5	1.9	1.5
12/18/2022 05:00	10.2	13.4	8.0	176.6	3,515,182.0	2,156.2	1.7	1.5
12/18/2022 06:00	10.5	13.3	8.2	189.4	3,497,832.1	2,171.1	1.9	1.5
12/18/2022 07:00	10.3	13.3	8.0	201.3	3,516,236.0	2,208.2	2.0	1.8
12/18/2022 08:00	10.1	13.4	7.9	196.3	3,440,390.0	2,085.2	2.0	1.7
12/18/2022 09:00	10.7	13.8	8.9	155.8	3,122,094.7	1,618.7	1.7	1.1
12/18/2022 10:00	11.0	13.8	9.1	155.6	3,011,383.5	1,561.3	1.8	1.1
12/18/2022 11:00	11.1	13.8	9.2	157.1	3,006,947.3	1,559.0	1.8	1.1
12/18/2022 12:00	11.4	13.9	9.6	137.4	2,717,439.5	1,408.9	1.7	1.0
12/18/2022 13:00	11.4	13.9	9.6	137.7	2,698,730.4	1,399.2	1.7	1.0
12/18/2022 14:00	11.0	13.8	9.1	172.2	3,169,735.3	1,643.4	1.9	1.2
12/18/2022 15:00	10.5	13.8	8.7	153.2	3,185,744.0	1,651.7	1.6	1.0
12/18/2022 16:00	10.6	13.4	8.3	198.4	3,432,421.9	2,130.5	2.0	1.7
12/18/2022 17:00	10.6	13.3	8.2	219.0	3,449,718.5	2,242.0	2.2	1.8
12/18/2022 18:00	10.5	13.3	8.2	222.7	3,453,079.7	2,269.4	2.3	2.0
12/18/2022 19:00	10.4	13.3	8.1	219.3	3,454,601.2	2,270.4	2.2	1.8
12/18/2022 20:00	10.2	13.3	7.9	207.4	3,480,049.7	2,236.3	2.1	1.8
12/18/2022 21:00	10.2	13.3	7.9	203.7	3,519,420.7	2,210.2	2.0	1.8
12/18/2022 22:00	10.2	13.3	7.9	203.1	3,541,331.5	2,198.1	2.0	1.8
12/18/2022 23:00	9.9	13.5	7.9	177.3	3,507,438.2	2,049.0	1.7	1.4
Average/Sum#:	10.4	13.5	8.3	183.1	3,344,229.4	1,977.9	1.9	1.5
Minimum:	9.4	13.3	7.7	137.4	2,698,730.4	1,399.2	1.6	1.0
Maximum:	11.4	13.9	9.6	222.7	3,541,331.5	2,270.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/19/2022 00:00	10.2	13.3	7.9	185.6	3,536,249.7	2,143.3	1.8	1.5
12/19/2022 01:00	10.2	13.3	7.9	192.8	3,510,943.3	2,153.6	1.9	1.5
12/19/2022 02:00	10.2	13.3	7.9	193.1	3,547,799.1	2,150.3	1.9	1.5
12/19/2022 03:00	10.2	13.3	7.9	186.8	3,549,779.0	2,151.5	1.8	1.5
12/19/2022 04:00	10.3	13.3	8.0	191.1	3,556,590.8	2,181.6	1.9	1.5
12/19/2022 05:00	10.4	13.2	8.0	222.3	3,533,422.6	2,296.4	2.2	1.8
12/19/2022 06:00	10.7	13.2	8.2	217.5	3,533,114.9	2,296.2	2.1	1.8
12/19/2022 07:00	10.4	13.2	8.0	216.5	3,532,037.8	2,295.5	2.1	1.8
12/19/2022 08:00	10.2	13.3	7.9	207.3	3,498,256.8	2,248.0	2.1	1.8
12/19/2022 09:00	10.2	13.3	7.9	208.4	3,512,729.2	2,257.3	2.1	1.8
12/19/2022 10:00	10.1	13.3	7.8	190.2	3,537,190.6	2,169.7	1.9	1.5
12/19/2022 11:00	10.1	13.3	7.8	188.4	3,542,244.4	2,172.8	1.8	1.5
12/19/2022 12:00	10.1	13.3	7.8	189.8	3,526,430.8	2,163.1	1.9	1.5
12/19/2022 13:00	10.1	13.3	7.8	193.6	3,512,736.6	2,154.7	1.9	1.5
12/19/2022 14:00	10.2	13.3	7.9	194.9	3,516,486.2	2,157.0	1.9	1.5
12/19/2022 15:00	10.3	13.3	8.0	200.9	3,532,955.7	2,218.7	2.0	1.8
12/19/2022 16:00	10.3	13.3	8.0	206.6	3,516,152.7	2,259.5	2.0	1.8
12/19/2022 17:00	10.2	13.3	7.9	209.0	3,524,244.8	2,264.7	2.1	1.8
12/19/2022 18:00	10.2	13.3	7.9	213.3	3,525,645.3	2,265.6	2.1	1.8
12/19/2022 19:00	10.2	13.3	7.9	214.4	3,523,466.7	2,264.2	2.1	1.8
12/19/2022 20:00	10.2	13.3	7.9	208.7	3,516,152.7	2,259.5	2.1	1.8
12/19/2022 21:00	10.2	13.3	7.9	206.1	3,516,464.0	2,259.7	2.0	1.8
12/19/2022 22:00	10.2	13.3	7.9	208.5	3,523,622.3	2,264.3	2.1	1.8
12/19/2022 23:00	10.2	13.3	7.9	212.1	3,522,533.0	2,263.6	2.1	1.8
Average/Sum#:	10.2	13.3	7.9	202.4	3,526,968.7	2,221.3	2.0	1.7
Minimum:	10.1	13.2	7.8	185.6	3,498,256.8	2,143.3	1.8	1.5
Maximum:	10.7	13.3	8.2	222.3	3,556,590.8	2,296.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/20/2022 00:00	10.1	13.3	7.8	195.8	3,541,755.3	2,172.5	1.9	1.5
12/20/2022 01:00	10.1	13.3	7.8	192.1	3,536,538.5	2,169.3	1.9	1.5
12/20/2022 02:00	10.2	13.3	7.9	189.3	3,542,896.5	2,173.2	1.9	1.5
12/20/2022 03:00	10.2	13.3	7.9	194.7	3,552,678.1	2,179.2	1.9	1.5
12/20/2022 04:00	10.2	13.3	7.9	196.7	3,561,807.6	2,184.8	1.9	1.5
12/20/2022 05:00	10.2	13.3	7.9	186.8	3,565,231.2	2,186.9	1.8	1.5
12/20/2022 06:00	10.7	13.3	8.3	204.2	3,547,898.5	2,279.9	2.0	1.8
12/20/2022 07:00	10.4	13.3	8.1	211.4	3,537,939.0	2,273.5	2.1	1.8
12/20/2022 08:00	10.2	13.3	7.9	195.2	3,527,409.0	2,163.7	1.9	1.5
12/20/2022 09:00	10.4	13.3	8.1	194.4	3,523,659.4	2,161.4	1.9	1.5
12/20/2022 10:00	10.4	13.3	8.1	189.5	3,498,631.8	2,120.5	1.9	1.5
12/20/2022 11:00	10.1	13.4	7.9	188.9	3,487,523.1	2,088.3	1.9	1.5
12/20/2022 12:00	9.3	13.7	7.6	163.0	3,487,763.8	1,961.1	1.6	1.2
12/20/2022 13:00	9.4	13.7	7.7	160.9	3,491,854.3	1,963.4	1.6	1.2
12/20/2022 14:00	9.5	13.6	7.7	161.5	3,482,250.6	1,958.0	1.6	1.2
12/20/2022 15:00	10.0	13.5	8.0	181.3	3,475,770.3	2,030.5	1.8	1.4
12/20/2022 16:00	10.4	13.3	8.1	208.4	3,477,701.0	2,184.0	2.1	1.7
12/20/2022 17:00	10.4	13.3	8.1	214.3	3,459,104.4	2,248.1	2.2	1.8
12/20/2022 18:00	10.3	13.3	8.0	214.1	3,456,796.4	2,246.6	2.2	1.8
12/20/2022 19:00	10.3	13.3	8.0	212.5	3,446,179.5	2,239.7	2.2	1.8
12/20/2022 20:00	10.3	13.3	8.0	214.3	3,449,410.8	2,241.8	2.2	1.8
12/20/2022 21:00	10.2	13.4	8.0	197.6	3,471,410.3	2,154.7	2.0	1.7
12/20/2022 22:00	10.2	13.4	8.0	198.1	3,473,988.0	2,156.3	2.0	1.7
12/20/2022 23:00	10.2	13.3	7.9	206.0	3,477,550.9	2,209.3	2.1	1.8
Average/Sum#:	10.2	13.4	7.9	194.6	3,503,072.8	2,156.1	1.9	1.6
Minimum:	9.3	13.3	7.6	160.9	3,446,179.5	1,958.0	1.6	1.2
Maximum:	10.7	13.7	8.3	214.3	3,565,231.2	2,279.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/21/2022 00:00	10.3	13.3	8.0	219.2	3,447,602.0	2,265.8	2.2	1.8
12/21/2022 01:00	10.2	13.3	7.9	218.5	3,443,645.9	2,263.2	2.2	1.8
12/21/2022 02:00	10.2	13.3	7.9	215.1	3,479,415.0	2,261.3	2.2	1.8
12/21/2022 03:00	10.2	13.3	7.9	215.5	3,488,339.3	2,267.1	2.2	1.8
12/21/2022 04:00	10.2	13.3	7.9	210.7	3,488,954.8	2,267.5	2.1	1.8
12/21/2022 05:00	10.3	13.3	8.0	236.9	3,481,876.9	2,262.9	2.4	2.0
12/21/2022 06:00	10.6	13.3	8.2	214.9	3,481,415.3	2,262.6	2.2	1.8
12/21/2022 07:00	10.4	13.3	8.1	214.7	3,478,030.2	2,260.4	2.2	1.8
12/21/2022 08:00	10.2	13.3	7.9	210.9	3,500,902.3	2,249.7	2.1	1.8
12/21/2022 09:00	10.3	13.3	8.0	208.9	3,478,804.8	2,235.5	2.1	1.8
12/21/2022 10:00	10.3	13.3	8.0	206.9	3,466,822.3	2,227.8	2.1	1.8
12/21/2022 11:00	10.3	13.3	8.0	202.6	3,455,042.0	2,195.0	2.0	1.8
12/21/2022 12:00	10.3	13.3	8.0	210.7	3,443,946.7	2,213.1	2.1	1.8
12/21/2022 13:00	10.3	13.3	8.0	212.9	3,436,632.7	2,208.4	2.2	1.8
12/21/2022 14:00	10.3	13.4	8.1	201.6	3,437,255.2	2,133.5	2.0	1.7
12/21/2022 15:00	10.4	13.3	8.1	211.5	3,431,341.8	2,205.0	2.2	1.8
12/21/2022 16:00	10.4	13.3	8.1	213.2	3,427,099.9	2,227.3	2.2	1.8
12/21/2022 17:00	10.5	13.3	8.2	214.9	3,437,562.9	2,234.1	2.2	1.8
12/21/2022 18:00	10.4	13.3	8.1	216.6	3,446,487.3	2,239.9	2.2	1.8
12/21/2022 19:00	10.4	13.3	8.1	219.6	3,448,641.4	2,241.3	2.2	1.8
12/21/2022 20:00	10.4	13.3	8.1	217.5	3,444,487.0	2,238.6	2.2	1.8
12/21/2022 21:00	10.4	13.3	8.1	215.6	3,444,487.0	2,238.6	2.2	1.8
12/21/2022 22:00	10.4	13.3	8.1	210.5	3,484,407.0	2,239.1	2.1	1.8
12/21/2022 23:00	10.4	13.3	8.1	208.8	3,485,340.7	2,239.7	2.1	1.8
Average/Sum#:	10.3	13.3	8.0	213.7	3,460,772.5	2,236.6	2.2	1.8
Minimum:	10.2	13.3	7.9	201.6	3,427,099.9	2,133.5	2.0	1.7
Maximum:	10.6	13.4	8.2	236.9	3,500,902.3	2,267.5	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/22/2022 00:00	10.3	13.3	8.0	202.7	3,470,535.4	2,179.5	2.0	1.7
12/22/2022 01:00	10.0	13.6	8.1	182.1	3,476,231.1	1,980.0	1.8	1.4
12/22/2022 02:00	10.3	13.6	8.3	178.7	3,488,297.4	1,961.4	1.8	1.4
12/22/2022 03:00	10.3	13.6	8.3	186.3	3,494,166.3	1,964.7	1.8	1.4
12/22/2022 04:00	10.4	13.4	8.2	185.1	3,541,568.1	2,094.8	1.8	1.5
12/22/2022 05:00	10.4	13.3	8.1	215.0	3,458,263.4	2,222.3	2.2	1.8
12/22/2022 06:00	10.7	13.2	8.2	209.5	3,519,109.4	2,261.4	2.1	1.8
12/22/2022 07:00	10.5	13.2	8.0	208.9	3,516,464.0	2,259.7	2.1	1.8
12/22/2022 08:00	10.3	13.3	8.0	203.4	3,483,628.9	2,238.6	2.0	1.8
12/22/2022 09:00	10.2	13.3	7.9	191.3	3,505,400.4	2,150.2	1.9	1.5
12/22/2022 10:00	10.2	13.3	7.9	193.2	3,539,219.6	2,145.1	1.9	1.5
12/22/2022 11:00	10.2	13.3	7.9	191.5	3,489,260.7	2,140.3	1.9	1.5
12/22/2022 12:00	10.3	13.3	8.0	187.6	3,484,859.0	2,137.6	1.9	1.5
12/22/2022 13:00	10.4	13.3	8.1	193.9	3,484,206.9	2,137.2	1.9	1.5
12/22/2022 14:00	10.4	13.3	8.1	196.7	3,496,433.9	2,144.7	2.0	1.7
12/22/2022 15:00	10.5	13.3	8.2	206.4	3,468,106.6	2,203.3	2.1	1.8
12/22/2022 16:00	10.5	13.3	8.2	202.1	3,460,393.8	2,198.4	2.0	1.8
12/22/2022 17:00	10.5	13.2	8.0	210.1	3,444,794.7	2,238.8	2.1	1.8
12/22/2022 18:00	10.5	13.2	8.0	213.8	3,450,026.2	2,242.2	2.2	1.8
12/22/2022 19:00	10.4	13.2	8.0	214.8	3,456,796.4	2,246.6	2.2	1.8
12/22/2022 20:00	10.3	13.3	8.0	213.1	3,452,026.5	2,243.5	2.2	1.8
12/22/2022 21:00	10.3	13.3	8.0	212.5	3,448,795.3	2,241.4	2.2	1.8
12/22/2022 22:00	10.3	13.3	8.0	203.3	3,463,227.0	2,200.2	2.0	1.8
12/22/2022 23:00	10.1	13.4	7.9	179.8	3,497,611.3	2,068.8	1.8	1.4
Average/Sum#:	10.3	13.3	8.1	199.2	3,482,892.6	2,162.5	2.0	1.7
Minimum:	10.0	13.2	7.9	178.7	3,444,794.7	1,961.4	1.8	1.4
Maximum:	10.7	13.6	8.3	215.0	3,541,568.1	2,261.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/23/2022 00:00	10.4	13.3	8.1	208.8	3,487,310.0	2,215.5	2.1	1.8
12/23/2022 01:00	10.4	13.2	8.0	216.4	3,465,413.0	2,252.2	2.2	1.8
12/23/2022 02:00	10.3	13.2	7.9	212.3	3,462,489.5	2,250.3	2.1	1.8
12/23/2022 03:00	10.3	13.2	7.9	212.0	3,455,257.7	2,245.6	2.1	1.8
12/23/2022 04:00	10.3	13.2	7.9	208.6	3,459,258.3	2,248.2	2.1	1.8
12/23/2022 05:00	10.4	13.3	8.1	228.3	3,448,487.6	2,241.2	2.3	2.0
12/23/2022 06:00	10.8	13.2	8.3	216.4	3,463,105.0	2,250.7	2.2	1.8
12/23/2022 07:00	10.6	13.2	8.1	213.8	3,474,758.8	2,232.9	2.2	1.8
12/23/2022 08:00	10.5	13.3	8.2	201.9	3,459,548.2	2,172.6	2.0	1.7
12/23/2022 09:00	10.5	13.3	8.2	202.3	3,444,898.5	2,163.4	2.0	1.7
12/23/2022 10:00	10.5	13.3	8.2	204.2	3,460,894.1	2,122.9	2.1	1.7
12/23/2022 11:00	10.6	13.3	8.2	205.3	3,422,272.1	2,124.2	2.1	1.7
12/23/2022 12:00	10.1	13.5	8.1	179.0	3,410,712.0	2,017.4	1.8	1.4
12/23/2022 13:00	9.9	13.6	8.0	174.5	3,423,561.0	1,950.0	1.8	1.4
12/23/2022 14:00	9.9	13.6	8.0	172.4	3,408,462.2	1,941.4	1.7	1.4
12/23/2022 15:00	10.5	13.4	8.3	188.0	3,423,060.0	2,049.7	1.9	1.4
12/23/2022 16:00	10.8	13.3	8.4	222.8	3,390,390.5	2,228.2	2.3	2.0
12/23/2022 17:00	10.6	13.3	8.2	222.1	3,394,346.6	2,230.8	2.3	2.0
12/23/2022 18:00	10.6	13.3	8.2	218.8	3,394,650.9	2,231.0	2.3	2.0
12/23/2022 19:00	10.6	13.3	8.2	215.7	3,430,177.3	2,229.3	2.2	1.8
12/23/2022 20:00	10.6	13.3	8.2	216.3	3,432,331.4	2,230.7	2.2	1.8
12/23/2022 21:00	10.6	13.3	8.2	220.6	3,399,672.1	2,234.3	2.3	2.0
12/23/2022 22:00	10.6	13.3	8.2	222.0	3,398,454.8	2,233.5	2.3	2.0
12/23/2022 23:00	10.5	13.3	8.2	218.2	3,424,484.2	2,225.6	2.2	1.8
Average/Sum#:	10.5	13.3	8.1	208.4	3,434,749.8	2,180.1	2.1	1.8
Minimum:	9.9	13.2	7.9	172.4	3,390,390.5	1,941.4	1.7	1.4
Maximum:	10.8	13.6	8.4	228.3	3,487,310.0	2,252.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/24/2022 00:00	10.4	13.3	8.1	197.1	3,413,894.4	2,119.0	2.0	1.7
12/24/2022 01:00	10.4	13.3	8.1	194.3	3,446,221.7	2,113.9	2.0	1.7
12/24/2022 02:00	9.9	13.6	8.0	183.6	3,443,575.6	1,961.4	1.8	1.4
12/24/2022 03:00	10.0	13.6	8.1	171.4	3,477,448.7	1,955.3	1.7	1.4
12/24/2022 04:00	10.0	13.6	8.1	178.1	3,473,358.2	1,953.0	1.8	1.4
12/24/2022 05:00	9.9	13.6	8.0	164.4	3,469,979.1	1,951.1	1.6	1.2
12/24/2022 06:00	10.2	13.5	8.1	167.3	3,467,101.6	1,974.8	1.7	1.4
12/24/2022 07:00	10.3	13.5	8.2	187.7	3,464,990.4	1,998.9	1.9	1.4
12/24/2022 08:00	10.4	13.7	8.5	168.8	3,304,457.1	1,833.9	1.7	1.3
12/24/2022 09:00	11.4	13.9	9.6	137.2	2,547,322.2	1,320.7	1.8	0.9
12/24/2022 10:00	11.3	13.8	9.4	163.6	3,008,297.5	1,559.7	1.9	1.1
12/24/2022 11:00	11.0	13.8	9.1	154.1	3,000,389.5	1,555.6	1.7	1.1
12/24/2022 12:00	10.9	13.8	9.1	156.2	2,999,039.4	1,554.9	1.8	1.1
12/24/2022 13:00	11.0	13.8	9.1	158.1	3,006,561.6	1,558.8	1.8	1.1
12/24/2022 14:00	9.9	13.8	8.2	162.4	3,338,502.3	1,730.9	1.7	1.2
12/24/2022 15:00	9.6	13.8	8.0	154.2	3,355,089.7	1,739.5	1.6	1.0
12/24/2022 16:00	10.7	13.8	8.9	160.1	3,074,647.1	1,594.1	1.8	1.1
12/24/2022 17:00	10.1	13.6	8.2	166.0	3,414,607.0	1,944.9	1.7	1.4
12/24/2022 18:00	9.9	13.6	8.0	172.4	3,412,500.2	1,943.7	1.7	1.4
12/24/2022 19:00	9.9	13.6	8.0	164.2	3,413,202.5	1,944.1	1.6	1.2
12/24/2022 20:00	9.9	13.6	8.0	172.7	3,419,522.9	1,947.7	1.7	1.4
12/24/2022 21:00	9.9	13.6	8.0	169.2	3,413,378.1	1,944.2	1.7	1.4
12/24/2022 22:00	9.6	13.6	7.8	162.4	3,462,509.5	1,946.9	1.6	1.2
12/24/2022 23:00	9.5	13.6	7.7	168.5	3,467,311.4	1,949.6	1.7	1.4
Average/Sum#:	10.3	13.6	8.3	168.1	3,303,912.8	1,837.4	1.8	1.3
Minimum:	9.5	13.3	7.7	137.2	2,547,322.2	1,320.7	1.6	0.9
Maximum:	11.4	13.9	9.6	197.1	3,477,448.7	2,119.0	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/25/2022 00:00	9.9	13.6	8.0	164.4	3,432,453.3	1,930.0	1.6	1.2
12/25/2022 01:00	25.6	16.1	31.5	196.1	1,528,070.9	591.4	4.2	0.9
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	17.8	14.9	19.8	180.3	2,480,262.1	1,260.7	2.9	1.1
Minimum:	9.9	13.6	8.0	164.4	1,528,070.9	591.4	1.6	0.9
Maximum:	25.6	16.1	31.5	196.1	3,432,453.3	1,930.0	4.2	1.2
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/26/2022 00:00	37.6	17.5	65.2	1.7	1,378,138.9	332.1	0.0	0.0
12/26/2022 01:00	37.1	15.1	37.7	217.7	2,289,772.0	969.8	3.1	1.2
12/26/2022 02:00	10.8	13.8	9.0	184.6	3,263,414.4	1,715.8	1.9	1.2
12/26/2022 03:00	11.0	13.8	9.1	179.2	3,301,834.3	1,736.0	1.9	1.2
12/26/2022 04:00	11.0	13.8	9.1	180.3	3,301,263.8	1,735.7	1.9	1.2
12/26/2022 05:00	10.9	13.8	9.1	173.5	3,329,983.6	1,750.8	1.8	1.2
12/26/2022 06:00	11.1	13.8	9.2	173.2	3,329,603.2	1,750.6	1.8	1.2
12/26/2022 07:00	11.0	13.8	9.1	174.4	3,313,816.8	1,742.3	1.8	1.2
12/26/2022 08:00	10.8	13.8	9.0	177.4	3,325,418.9	1,748.4	1.8	1.2
12/26/2022 09:00	11.5	13.8	9.6	151.6	3,016,205.4	1,563.8	1.7	1.1
12/26/2022 10:00	11.5	13.8	9.6	149.7	3,007,718.9	1,559.4	1.7	1.1
12/26/2022 11:00	11.5	13.8	9.6	149.5	2,989,974.2	1,550.2	1.7	1.1
12/26/2022 12:00	11.5	13.8	9.6	153.4	2,972,229.5	1,541.0	1.7	1.1
12/26/2022 13:00	11.3	13.8	9.4	153.2	3,012,347.9	1,561.8	1.7	1.1
12/26/2022 14:00	11.3	13.8	9.4	162.0	3,087,671.6	1,623.4	1.8	1.1
12/26/2022 15:00	10.6	13.8	8.8	173.2	3,330,554.2	1,751.1	1.8	1.2
12/26/2022 16:00	10.4	13.7	8.5	170.6	3,391,037.1	1,782.9	1.7	1.2
12/26/2022 17:00	10.6	13.4	8.3	179.1	3,429,919.0	2,103.9	1.8	1.5
12/26/2022 18:00	10.6	13.3	8.2	195.7	3,416,076.9	2,145.3	2.0	1.7
12/26/2022 19:00	9.9	13.5	7.9	174.0	3,430,579.3	2,004.1	1.8	1.4
12/26/2022 20:00	9.9	13.5	7.9	161.9	3,450,776.1	1,990.7	1.6	1.2
12/26/2022 21:00	9.8	13.6	7.9	165.3	3,441,293.2	1,960.1	1.6	1.2
12/26/2022 22:00	9.9	13.5	7.9	161.4	3,398,981.5	1,936.0	1.6	1.2
12/26/2022 23:00	23.8	16.1	29.3	179.7	1,555,717.8	602.1	3.8	0.9
Average/Sum#:	13.6	14.0	13.3	164.3	3,073,513.7	1,631.6	1.8	1.2
Minimum:	9.8	13.3	7.9	1.7	1,378,138.9	332.1	0.0	0.0
Maximum:	37.6	17.5	65.2	217.7	3,450,776.1	2,145.3	3.8	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 05:00	36.1	17.0	54.6	167.3	1,693,170.4	482.2	0.0	0.0
12/27/2022 06:00	24.0	14.3	21.5	195.0	2,459,984.2	1,185.6	2.6	1.2
12/27/2022 07:00	10.1	13.8	8.4	166.3	3,305,448.1	1,737.9	1.7	1.2
12/27/2022 08:00	10.7	13.7	8.8	166.1	3,216,459.0	1,714.6	1.8	1.2
12/27/2022 09:00	10.7	13.4	8.4	167.5	3,338,485.5	1,950.3	1.7	1.4
12/27/2022 10:00	11.0	13.4	8.7	196.7	3,334,034.8	1,947.7	2.0	1.6
12/27/2022 11:00	10.8	13.4	8.5	182.7	3,339,170.2	1,950.7	1.9	1.4
12/27/2022 12:00	10.7	13.4	8.4	172.9	3,336,260.2	1,949.0	1.8	1.4
12/27/2022 13:00	10.6	13.5	8.5	184.3	3,333,692.5	1,947.5	1.9	1.4
12/27/2022 14:00	10.5	13.5	8.4	174.5	3,334,548.4	1,948.0	1.8	1.4
12/27/2022 15:00	10.5	13.5	8.4	183.7	3,336,431.3	1,949.1	1.9	1.4
12/27/2022 16:00	10.5	13.5	8.4	176.8	3,339,512.5	1,950.9	1.8	1.4
12/27/2022 17:00	10.4	13.5	8.3	174.1	3,365,837.1	1,941.7	1.8	1.4
12/27/2022 18:00	10.3	13.5	8.2	175.3	3,403,019.6	1,938.3	1.8	1.4
12/27/2022 19:00	10.3	13.5	8.2	165.1	3,408,637.7	1,941.5	1.7	1.4
12/27/2022 20:00	10.2	13.5	8.1	175.5	3,423,912.1	1,950.2	1.8	1.4
12/27/2022 21:00	10.2	13.5	8.1	166.8	3,417,065.0	1,946.3	1.7	1.4
12/27/2022 22:00	10.0	13.6	8.1	168.8	3,383,356.1	1,927.1	1.7	1.3
12/27/2022 23:00	11.1	13.9	9.4	133.1	2,736,109.9	1,398.6	1.6	0.8
Average/Sum#:	12.6	13.8	11.5	173.3	3,184,480.8	1,776.7	1.7	1.3
Minimum:	10.0	13.4	8.1	133.1	1,693,170.4	482.2	0.0	0.0
Maximum:	36.1	17.0	54.6	196.7	3,423,912.1	1,950.9	2.6	1.6
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/28/2022 00:00	11.3	13.8	9.4	157.6	2,991,710.1	1,551.1	1.8	1.1
12/28/2022 01:00	11.5	13.8	9.6	147.6	2,842,616.4	1,473.8	1.8	1.0
12/28/2022 02:00	11.4	13.8	9.5	151.6	2,967,021.9	1,538.3	1.7	1.1
12/28/2022 03:00	11.3	13.8	9.4	147.3	2,965,478.9	1,537.5	1.7	1.1
12/28/2022 04:00	11.3	13.8	9.4	149.9	2,976,087.1	1,543.0	1.7	1.1
12/28/2022 05:00	10.8	13.8	9.0	186.3	3,301,073.6	1,735.6	1.9	1.2
12/28/2022 06:00	10.9	13.8	9.1	171.8	3,335,499.4	1,753.7	1.8	1.2
12/28/2022 07:00	10.7	13.8	8.9	173.2	3,340,824.9	1,756.5	1.8	1.2
12/28/2022 08:00	10.8	13.8	9.0	175.9	3,295,367.6	1,732.6	1.8	1.2
12/28/2022 09:00	10.8	13.8	9.0	177.1	3,278,630.2	1,723.8	1.8	1.2
12/28/2022 10:00	11.3	13.8	9.4	151.1	3,012,733.6	1,562.0	1.7	1.1
12/28/2022 11:00	11.3	13.8	9.4	153.7	3,043,401.0	1,577.9	1.7	1.1
12/28/2022 12:00	11.3	13.8	9.4	155.8	3,010,226.2	1,560.7	1.8	1.1
12/28/2022 13:00	11.2	13.8	9.3	153.4	2,961,235.6	1,535.3	1.8	1.1
12/28/2022 14:00	11.2	13.8	9.3	153.2	2,997,303.5	1,554.0	1.7	1.1
12/28/2022 15:00	10.7	13.8	8.9	153.0	3,045,637.9	1,601.3	1.7	1.1
12/28/2022 16:00	10.7	13.4	8.4	188.8	3,402,530.5	2,087.1	1.9	1.5
12/28/2022 17:00	10.0	13.5	8.0	166.6	3,423,214.3	1,974.8	1.7	1.4
12/28/2022 18:00	9.7	13.6	7.8	164.6	3,432,163.8	1,954.9	1.6	1.2
12/28/2022 19:00	9.6	13.6	7.8	164.2	3,434,621.7	1,956.3	1.6	1.2
12/28/2022 20:00	9.7	13.6	7.8	159.5	3,433,743.9	1,955.8	1.6	1.2
12/28/2022 21:00	9.8	13.5	7.8	171.5	3,411,253.5	1,967.9	1.7	1.4
12/28/2022 22:00	9.7	13.6	7.8	161.2	3,428,652.4	1,952.9	1.6	1.2
12/28/2022 23:00	9.7	13.6	7.8	159.5	3,436,904.1	1,957.6	1.6	1.2
Average/Sum#:	10.7	13.7	8.8	162.3	3,198,663.8	1,731.0	1.7	1.2
Minimum:	9.6	13.4	7.8	147.3	2,842,616.4	1,473.8	1.6	1.0
Maximum:	11.5	13.8	9.6	188.8	3,436,904.1	2,087.1	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/29/2022 00:00	9.6	13.6	7.8	165.2	3,429,003.5	1,953.1	1.7	1.4
12/29/2022 01:00	9.6	13.6	7.8	158.3	3,429,179.1	1,953.2	1.6	1.2
12/29/2022 02:00	9.6	13.6	7.8	162.2	3,430,056.9	1,953.7	1.6	1.2
12/29/2022 03:00	9.7	13.6	7.8	163.0	3,432,339.3	1,955.0	1.6	1.2
12/29/2022 04:00	9.7	13.6	7.8	159.0	3,436,728.5	1,957.5	1.6	1.2
12/29/2022 05:00	10.1	13.5	8.1	187.3	3,389,659.4	2,029.7	1.9	1.4
12/29/2022 06:00	10.5	13.4	8.3	177.6	3,447,230.0	2,039.0	1.8	1.4
12/29/2022 07:00	10.3	13.4	8.1	174.4	3,453,485.4	2,042.7	1.7	1.4
12/29/2022 08:00	10.6	13.3	8.2	201.4	3,440,088.5	2,185.5	2.0	1.7
12/29/2022 09:00	10.6	13.2	8.1	216.8	3,399,367.8	2,234.1	2.2	1.8
12/29/2022 10:00	10.4	13.3	8.1	193.3	3,411,140.6	2,142.2	2.0	1.7
12/29/2022 11:00	9.9	13.5	7.9	169.6	3,445,471.7	2,012.8	1.7	1.4
12/29/2022 12:00	9.8	13.5	7.8	171.2	3,424,601.0	1,975.6	1.7	1.4
12/29/2022 13:00	9.8	13.5	7.8	160.5	3,444,629.0	1,962.0	1.6	1.2
12/29/2022 14:00	10.0	13.5	8.0	173.1	3,416,800.5	1,971.1	1.7	1.4
12/29/2022 15:00	10.0	13.5	8.0	169.1	3,427,894.6	1,977.5	1.7	1.4
12/29/2022 16:00	10.5	13.3	8.2	187.6	3,435,605.3	2,082.3	1.9	1.5
12/29/2022 17:00	10.6	13.3	8.2	193.2	3,422,446.3	2,149.3	2.0	1.7
12/29/2022 18:00	10.2	13.4	8.0	187.2	3,403,102.1	2,062.6	1.9	1.4
12/29/2022 19:00	9.8	13.5	7.8	161.6	3,434,972.8	1,956.5	1.6	1.2
12/29/2022 20:00	10.0	13.5	8.0	168.4	3,447,262.5	1,963.5	1.7	1.4
12/29/2022 21:00	10.0	13.5	8.0	167.1	3,421,654.2	1,973.9	1.7	1.4
12/29/2022 22:00	10.1	13.5	8.1	166.4	3,394,265.7	1,958.1	1.7	1.4
12/29/2022 23:00	10.1	13.5	8.1	166.2	3,388,974.2	1,930.3	1.7	1.4
Average/Sum#:	10.1	13.5	8.0	175.0	3,425,248.3	2,017.6	1.8	1.4
Minimum:	9.6	13.2	7.8	158.3	3,388,974.2	1,930.3	1.6	1.2
Maximum:	10.6	13.6	8.3	216.8	3,453,485.4	2,234.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/30/2022 00:00	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
Minimum:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
Maximum:	23.0	16.1	28.3	172.4	1,620,571.6	627.2	3.4	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/01/2022 00:00	8.6	13.0	6.4	131.1	3,371,118.2	2,166.3	1.3	1.1
10/01/2022 01:00	13.4	14.6	12.5	135.7	2,456,788.2	1,202.0	1.7	0.8
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	34.9	17.4	58.8	45.2	1,318,071.0	308.0	1.0	0.1
10/01/2022 13:00	36.8	17.1	57.1	253.8	1,393,111.7	376.4	5.6	0.8
10/01/2022 14:00	34.8	15.2	36.0	225.1	2,221,003.5	875.8	3.2	1.1
10/01/2022 15:00	7.1	13.8	5.9	87.1	2,848,604.1	1,414.5	1.0	0.6
10/01/2022 16:00	8.3	13.4	6.5	105.7	3,222,461.9	1,717.8	1.0	0.7
10/01/2022 17:00	9.4	12.8	6.8	157.8	3,324,903.5	2,258.0	1.5	1.4
10/01/2022 18:00	9.3	12.9	6.9	142.5	3,329,679.3	2,188.3	1.4	1.1
10/01/2022 19:00	8.9	13.1	6.7	120.5	3,343,870.4	2,026.7	1.2	1.0
10/01/2022 20:00	9.3	12.9	6.9	144.3	3,363,914.9	2,210.8	1.4	1.1
10/01/2022 21:00	8.9	13.1	6.7	131.0	3,150,165.2	1,932.3	1.3	1.0
10/01/2022 22:00	7.9	13.6	6.4	97.7	3,027,778.0	1,569.8	1.0	0.6
10/01/2022 23:00	19.9	15.8	23.0	152.8	1,630,131.8	630.9	2.9	0.7
Average/Sum#:	15.5	14.2	17.6	137.9	2,714,400.1	1,491.3	1.8	0.9
Minimum:	7.1	12.8	5.9	45.2	1,318,071.0	308.0	1.0	0.1
Maximum:	36.8	17.4	58.8	253.8	3,371,118.2	2,258.0	5.6	1.4
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	30.0	17.4	50.6	24.0	1,332,621.1	311.4	0.5	0.1
10/02/2022 12:00	34.7	17.1	53.9	246.1	1,496,743.8	404.4	4.9	0.8
10/02/2022 13:00	29.9	15.4	32.1	224.5	2,275,569.9	880.7	3.0	1.1
10/02/2022 14:00	8.3	13.5	6.6	108.4	3,338,116.6	1,730.7	1.0	0.7
10/02/2022 15:00	8.3	13.4	6.5	106.2	3,058,618.3	1,719.8	1.1	0.7
10/02/2022 16:00	9.3	12.9	6.9	136.3	3,360,782.9	2,184.2	1.3	1.1
10/02/2022 17:00	9.5	12.8	6.9	157.6	3,335,211.0	2,265.0	1.5	1.4
10/02/2022 18:00	9.6	12.8	7.0	154.5	3,343,457.0	2,270.6	1.5	1.4
10/02/2022 19:00	9.5	12.8	6.9	154.7	3,346,843.7	2,272.9	1.5	1.4
10/02/2022 20:00	9.4	12.8	6.8	153.4	3,348,905.2	2,274.3	1.5	1.4
10/02/2022 21:00	9.0	13.0	6.7	128.7	3,381,189.4	2,098.7	1.2	1.0
10/02/2022 22:00	8.7	13.2	6.7	123.9	3,193,096.9	1,912.0	1.2	1.0
10/02/2022 23:00	7.7	13.6	6.2	95.9	3,033,470.6	1,550.6	1.0	0.6
Average/Sum#:	14.1	13.9	15.7	139.6	2,911,125.1	1,682.7	1.6	1.0
Minimum:	7.7	12.8	6.2	24.0	1,332,621.1	311.4	0.5	0.1
Maximum:	34.7	17.4	53.9	246.1	3,381,189.4	2,274.3	4.9	1.4
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/03/2022 00:00	7.8	13.6	6.3	95.3	3,025,254.1	1,546.4	1.0	0.6
10/03/2022 01:00	7.9	13.6	6.4	95.9	3,032,883.7	1,550.3	1.0	0.6
10/03/2022 02:00	8.1	13.5	6.5	108.3	3,441,305.6	1,784.2	1.0	0.7
10/03/2022 03:00	7.8	13.6	6.3	98.6	3,096,659.8	1,582.9	1.0	0.6
10/03/2022 04:00	7.4	13.6	6.0	102.2	3,356,459.2	1,715.7	1.0	0.7
10/03/2022 05:00	7.4	13.6	6.0	102.1	3,352,350.9	1,713.6	1.0	0.7
10/03/2022 06:00	7.3	13.6	5.9	101.0	3,346,677.6	1,710.7	0.9	0.5
10/03/2022 07:00	7.7	13.6	6.2	103.1	3,347,460.1	1,711.1	1.0	0.7
10/03/2022 08:00	7.6	13.6	6.1	103.5	3,359,589.3	1,717.3	1.0	0.7
10/03/2022 09:00	7.6	13.7	6.2	103.4	3,368,979.6	1,722.1	1.0	0.7
10/03/2022 10:00	7.7	13.6	6.2	103.9	3,373,674.8	1,724.5	1.0	0.7
10/03/2022 11:00	7.7	13.6	6.2	104.1	3,374,066.0	1,724.7	1.0	0.7
10/03/2022 12:00	7.9	13.6	6.4	104.7	3,373,870.4	1,724.6	1.0	0.7
10/03/2022 13:00	8.0	13.6	6.5	105.1	3,375,239.8	1,725.3	1.0	0.7
10/03/2022 14:00	7.9	13.6	6.4	104.6	3,358,219.9	1,716.6	1.0	0.7
10/03/2022 15:00	8.1	13.5	6.5	106.9	3,384,792.7	1,754.9	1.0	0.7
10/03/2022 16:00	8.9	13.0	6.6	121.5	3,358,513.3	2,060.1	1.2	1.0
10/03/2022 17:00	8.9	12.9	6.6	131.6	3,339,087.5	2,170.1	1.3	1.1
10/03/2022 18:00	8.9	12.9	6.6	134.7	3,314,007.0	2,202.2	1.3	1.1
10/03/2022 19:00	8.8	12.9	6.5	131.7	3,348,011.8	2,175.9	1.3	1.1
10/03/2022 20:00	8.8	12.9	6.5	133.1	3,327,396.9	2,186.8	1.3	1.1
10/03/2022 21:00	8.7	12.9	6.4	131.5	3,352,474.0	2,178.8	1.3	1.1
10/03/2022 22:00	8.5	13.0	6.3	128.7	3,394,598.4	2,156.6	1.2	1.1
10/03/2022 23:00	8.5	13.0	6.3	130.4	3,383,100.7	2,174.0	1.2	1.1
Average/Sum#:	8.1	13.4	6.3	111.9	3,324,361.4	1,851.2	1.1	0.8
Minimum:	7.3	12.9	5.9	95.3	3,025,254.1	1,546.4	0.9	0.5
Maximum:	8.9	13.7	6.6	134.7	3,441,305.6	2,202.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/04/2022 00:00	8.4	13.0	6.3	128.6	3,393,968.8	2,156.2	1.2	1.1
10/04/2022 01:00	8.5	13.0	6.3	129.1	3,399,792.8	2,159.9	1.2	1.1
10/04/2022 02:00	8.5	13.0	6.3	128.9	3,397,746.5	2,158.6	1.2	1.1
10/04/2022 03:00	8.4	13.0	6.3	129.5	3,374,697.4	2,168.6	1.2	1.1
10/04/2022 04:00	8.5	13.0	6.3	130.8	3,396,639.3	2,182.7	1.2	1.1
10/04/2022 05:00	8.4	12.9	6.2	133.9	3,410,328.3	2,216.4	1.3	1.1
10/04/2022 06:00	8.4	12.9	6.2	131.3	3,471,013.1	2,179.8	1.2	1.1
10/04/2022 07:00	8.6	13.1	6.5	119.8	3,412,705.8	2,043.5	1.1	0.8
10/04/2022 08:00	7.5	13.6	6.1	97.1	3,059,409.8	1,586.2	1.0	0.6
10/04/2022 09:00	7.6	13.7	6.2	94.0	3,029,362.4	1,548.5	1.0	0.6
10/04/2022 10:00	7.9	13.6	6.4	95.2	1,018,353.8	1,554.2	3.2	1.9
10/04/2022 11:00	7.9	13.6	6.4	96.1	3,056,555.2	1,562.4	1.0	0.6
10/04/2022 12:00	7.9	13.6	6.4	104.2	3,339,439.2	1,707.0	1.0	0.7
10/04/2022 13:00	8.0	13.5	6.4	107.0	3,342,552.8	1,733.0	1.0	0.7
10/04/2022 14:00	8.8	13.1	6.7	117.9	3,372,625.1	2,019.5	1.1	0.8
10/04/2022 15:00	8.8	13.0	6.6	128.3	3,324,122.1	2,136.1	1.2	1.1
10/04/2022 16:00	8.7	12.9	6.4	127.7	3,312,295.2	2,128.5	1.2	1.1
10/04/2022 17:00	8.7	12.9	6.4	128.6	3,330,813.6	2,140.4	1.2	1.1
10/04/2022 18:00	8.7	12.9	6.4	131.1	3,338,779.7	2,169.9	1.3	1.1
10/04/2022 19:00	8.7	12.9	6.4	132.7	3,329,527.2	2,188.2	1.3	1.1
10/04/2022 20:00	8.7	12.8	6.3	139.2	3,338,418.5	2,242.8	1.4	1.1
10/04/2022 21:00	8.7	12.9	6.4	133.8	3,332,874.6	2,190.4	1.3	1.1
10/04/2022 22:00	8.6	12.9	6.3	131.1	3,352,935.6	2,179.1	1.3	1.1
10/04/2022 23:00	8.3	13.0	6.2	127.1	3,374,293.2	2,143.7	1.2	1.1
Average/Sum#:	8.4	13.1	6.4	121.8	3,325,691.1	2,020.7	1.2	1.0
Minimum:	7.5	12.8	6.1	94.0	3,029,362.4	1,548.5	1.0	0.6
Maximum:	8.8	13.7	6.7	139.2	3,471,013.1	2,242.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/05/2022 00:00	8.4	13.0	6.3	126.6	3,363,117.4	2,136.6	1.2	1.1
10/05/2022 01:00	8.2	13.1	6.2	114.8	3,373,855.9	1,995.6	1.1	0.8
10/05/2022 02:00	8.2	13.2	6.3	112.1	3,416,973.9	1,971.2	1.0	0.8
10/05/2022 03:00	8.4	13.0	6.3	121.9	3,404,812.9	2,088.5	1.1	0.8
10/05/2022 04:00	8.4	13.0	6.3	124.5	3,372,127.9	2,117.7	1.2	1.1
10/05/2022 05:00	8.5	12.9	6.3	133.1	3,392,479.6	2,204.8	1.3	1.1
10/05/2022 06:00	8.4	12.9	6.2	134.1	3,433,520.4	2,206.4	1.3	1.1
10/05/2022 07:00	8.4	13.2	6.4	115.8	3,389,838.9	1,980.3	1.1	0.8
10/05/2022 08:00	7.4	13.6	6.0	102.2	3,330,244.5	1,702.3	1.0	0.7
10/05/2022 09:00	7.4	13.7	6.1	100.4	3,262,360.1	1,667.6	1.0	0.7
10/05/2022 10:00	7.6	13.6	6.1	102.2	3,313,811.4	1,693.9	1.0	0.7
10/05/2022 11:00	7.8	13.6	6.3	103.3	3,338,069.8	1,706.3	1.0	0.7
10/05/2022 12:00	8.0	13.6	6.5	105.1	3,323,265.1	1,723.0	1.0	0.7
10/05/2022 13:00	8.8	13.0	6.6	121.7	3,365,197.4	2,064.2	1.2	1.0
10/05/2022 14:00	8.9	12.9	6.6	132.4	3,319,180.4	2,181.4	1.3	1.1
10/05/2022 15:00	8.7	12.9	6.4	128.1	3,322,410.3	2,135.0	1.2	1.1
10/05/2022 16:00	8.8	12.9	6.5	130.1	3,319,238.5	2,157.2	1.3	1.1
10/05/2022 17:00	8.8	12.8	6.4	134.5	3,304,827.4	2,196.1	1.3	1.1
10/05/2022 18:00	8.9	12.8	6.5	138.3	3,320,854.1	2,231.0	1.4	1.1
10/05/2022 19:00	8.8	12.8	6.4	140.0	3,330,678.3	2,237.6	1.4	1.1
10/05/2022 20:00	8.6	12.9	6.3	132.5	3,329,679.3	2,188.3	1.3	1.1
10/05/2022 21:00	8.7	12.8	6.3	138.6	3,326,063.9	2,234.5	1.4	1.1
10/05/2022 22:00	8.5	12.9	6.3	129.8	3,366,605.4	2,163.4	1.2	1.1
10/05/2022 23:00	8.5	12.9	6.3	130.0	3,381,233.3	2,172.8	1.2	1.1
Average/Sum#:	8.4	13.1	6.3	123.0	3,350,018.6	2,048.2	1.2	1.0
Minimum:	7.4	12.8	6.0	100.4	3,262,360.1	1,667.6	1.0	0.7
Maximum:	8.9	13.7	6.6	140.0	3,433,520.4	2,237.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/06/2022 00:00	8.4	13.0	6.3	128.8	3,403,570.5	2,162.3	1.2	1.1
10/06/2022 01:00	8.4	12.9	6.2	129.1	3,371,273.8	2,166.4	1.2	1.1
10/06/2022 02:00	8.5	12.9	6.3	129.2	3,368,161.5	2,164.4	1.2	1.1
10/06/2022 03:00	8.4	13.0	6.3	126.8	3,373,033.9	2,142.9	1.2	1.1
10/06/2022 04:00	8.3	12.9	6.1	131.5	3,361,090.6	2,184.4	1.3	1.1
10/06/2022 05:00	8.5	12.9	6.3	137.7	3,380,220.9	2,246.2	1.3	1.1
10/06/2022 06:00	8.5	12.9	6.3	140.2	3,398,150.5	2,233.3	1.3	1.1
10/06/2022 07:00	8.7	13.0	6.5	127.7	3,393,465.5	2,131.1	1.2	1.1
10/06/2022 08:00	8.4	13.0	6.3	122.1	3,395,520.4	2,082.8	1.2	1.0
10/06/2022 09:00	8.4	13.1	6.4	120.8	3,407,721.8	2,065.4	1.1	0.8
10/06/2022 10:00	8.5	13.0	6.3	122.3	3,385,575.7	2,076.7	1.2	1.0
10/06/2022 11:00	8.6	13.0	6.4	125.7	3,365,599.3	2,113.6	1.2	1.1
10/06/2022 12:00	8.7	12.9	6.4	128.4	3,334,081.5	2,142.5	1.2	1.1
10/06/2022 13:00	8.8	12.9	6.5	134.1	3,345,503.8	2,198.7	1.3	1.1
10/06/2022 14:00	8.8	12.9	6.5	135.6	3,321,230.3	2,207.0	1.3	1.1
10/06/2022 15:00	8.7	12.9	6.4	130.5	3,321,854.3	2,158.9	1.3	1.1
10/06/2022 16:00	8.8	12.9	6.5	135.2	3,343,677.9	2,197.5	1.3	1.1
10/06/2022 17:00	8.8	12.8	6.4	143.2	3,342,586.3	2,245.6	1.4	1.1
10/06/2022 18:00	8.8	12.8	6.4	141.7	3,336,930.0	2,241.8	1.4	1.1
10/06/2022 19:00	8.8	12.8	6.4	142.8	3,351,963.9	2,251.9	1.4	1.1
10/06/2022 20:00	8.8	12.8	6.4	144.5	3,354,643.2	2,253.7	1.4	1.1
10/06/2022 21:00	8.7	12.9	6.4	142.0	3,376,157.8	2,243.5	1.4	1.1
10/06/2022 22:00	8.6	12.9	6.3	133.8	3,369,091.7	2,189.6	1.3	1.1
10/06/2022 23:00	8.6	13.0	6.4	130.4	3,375,164.3	2,168.9	1.2	1.1
Average/Sum#:	8.6	12.9	6.4	132.7	3,365,677.9	2,177.9	1.3	1.1
Minimum:	8.3	12.8	6.1	120.8	3,321,230.3	2,065.4	1.1	0.8
Maximum:	8.8	13.1	6.5	144.5	3,407,721.8	2,253.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/07/2022 00:00	8.4	13.0	6.3	127.6	3,415,440.0	2,144.9	1.2	1.1
10/07/2022 01:00	8.5	13.0	6.3	128.8	3,397,589.1	2,158.5	1.2	1.1
10/07/2022 02:00	8.5	13.0	6.3	127.9	3,409,389.0	2,141.1	1.2	1.1
10/07/2022 03:00	8.5	13.0	6.3	125.3	3,407,450.1	2,115.0	1.2	1.1
10/07/2022 04:00	8.5	13.0	6.3	128.7	3,392,552.2	2,155.3	1.2	1.1
10/07/2022 05:00	8.4	13.0	6.3	131.4	3,410,333.6	2,191.5	1.2	1.1
10/07/2022 06:00	8.4	12.9	6.2	133.4	3,431,030.5	2,204.8	1.3	1.1
10/07/2022 07:00	8.8	13.1	6.7	126.1	3,401,972.4	2,111.6	1.2	1.1
10/07/2022 08:00	8.5	13.1	6.4	117.9	3,392,832.4	2,031.6	1.1	0.8
10/07/2022 09:00	8.5	13.0	6.3	126.7	3,395,694.8	2,132.5	1.2	1.1
10/07/2022 10:00	8.6	13.0	6.4	126.8	3,387,255.3	2,127.2	1.2	1.1
10/07/2022 11:00	8.6	13.0	6.4	126.2	3,371,013.3	2,117.0	1.2	1.1
10/07/2022 12:00	8.7	12.9	6.4	131.9	3,346,011.5	2,174.6	1.3	1.1
10/07/2022 13:00	8.7	13.0	6.5	130.3	3,341,395.5	2,147.2	1.3	1.1
10/07/2022 14:00	8.8	12.9	6.5	134.9	3,339,265.3	2,194.6	1.3	1.1
10/07/2022 15:00	8.8	12.9	6.5	136.7	3,316,414.8	2,203.8	1.3	1.1
10/07/2022 16:00	8.8	12.9	6.5	134.2	3,329,831.5	2,188.4	1.3	1.1
10/07/2022 17:00	8.8	12.8	6.4	142.8	3,331,869.1	2,238.4	1.4	1.1
10/07/2022 18:00	8.8	12.9	6.5	144.3	3,346,307.6	2,248.1	1.4	1.1
10/07/2022 19:00	8.8	12.9	6.5	144.6	3,355,536.3	2,254.3	1.4	1.1
10/07/2022 20:00	8.7	12.9	6.4	145.0	3,362,681.1	2,259.1	1.4	1.1
10/07/2022 21:00	8.7	12.9	6.4	144.6	3,367,146.6	2,262.1	1.4	1.1
10/07/2022 22:00	8.6	12.9	6.3	143.6	3,358,662.2	2,256.4	1.4	1.1
10/07/2022 23:00	8.5	13.0	6.3	132.3	3,371,861.3	2,191.4	1.3	1.1
Average/Sum#:	8.6	13.0	6.4	133.0	3,374,147.3	2,177.1	1.3	1.1
Minimum:	8.4	12.8	6.2	117.9	3,316,414.8	2,031.6	1.1	0.8
Maximum:	8.8	13.1	6.7	145.0	3,431,030.5	2,262.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/08/2022 00:00	8.5	13.0	6.3	130.2	3,390,881.5	2,179.0	1.2	1.1
10/08/2022 01:00	8.5	13.0	6.3	130.3	3,382,633.8	2,173.7	1.2	1.1
10/08/2022 02:00	8.5	13.0	6.3	129.9	3,409,079.7	2,165.8	1.2	1.1
10/08/2022 03:00	8.5	13.0	6.3	130.9	3,390,570.3	2,178.8	1.2	1.1
10/08/2022 04:00	8.6	13.0	6.4	131.4	3,402,397.1	2,186.4	1.2	1.1
10/08/2022 05:00	8.5	13.0	6.3	130.1	3,423,561.0	2,175.0	1.2	1.1
10/08/2022 06:00	8.4	13.0	6.3	128.9	3,487,907.4	2,114.0	1.2	1.1
10/08/2022 07:00	7.7	13.6	6.2	104.0	3,234,884.7	1,700.8	1.0	0.7
10/08/2022 08:00	7.7	13.7	6.3	86.9	2,695,384.4	1,358.1	1.0	0.5
10/08/2022 09:00	7.4	13.8	6.1	82.9	2,637,350.3	1,309.6	1.0	0.5
10/08/2022 10:00	7.2	13.8	6.0	84.1	2,636,141.9	1,309.0	1.0	0.5
10/08/2022 11:00	7.3	13.8	6.1	84.0	2,646,614.0	1,314.2	1.0	0.5
10/08/2022 12:00	7.7	13.7	6.3	95.1	3,050,099.4	1,559.1	1.0	0.6
10/08/2022 13:00	7.9	13.6	6.4	104.4	3,348,047.0	1,711.4	1.0	0.7
10/08/2022 14:00	8.0	13.5	6.4	105.6	3,333,873.3	1,728.5	1.0	0.7
10/08/2022 15:00	8.9	13.0	6.6	124.9	3,333,433.7	2,093.4	1.2	1.0
10/08/2022 16:00	8.9	12.9	6.6	135.9	3,305,278.8	2,196.4	1.3	1.1
10/08/2022 17:00	8.8	12.9	6.5	136.4	3,312,050.7	2,200.9	1.3	1.1
10/08/2022 18:00	8.7	12.9	6.4	132.8	3,337,856.5	2,169.3	1.3	1.1
10/08/2022 19:00	8.7	12.9	6.4	132.5	3,348,627.3	2,176.3	1.3	1.1
10/08/2022 20:00	8.6	12.9	6.3	132.2	3,359,551.9	2,183.4	1.3	1.1
10/08/2022 21:00	8.7	12.9	6.4	132.6	3,358,628.7	2,182.8	1.3	1.1
10/08/2022 22:00	8.6	13.0	6.4	131.8	3,390,881.5	2,179.0	1.3	1.1
10/08/2022 23:00	8.4	13.0	6.3	129.9	3,426,866.5	2,177.1	1.2	1.1
Average/Sum#:	8.3	13.2	6.3	118.7	3,235,108.4	1,946.8	1.2	0.9
Minimum:	7.2	12.9	6.0	82.9	2,636,141.9	1,309.0	1.0	0.5
Maximum:	8.9	13.8	6.6	136.4	3,487,907.4	2,200.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/09/2022 00:00	8.5	13.0	6.3	129.8	3,382,633.8	2,173.7	1.2	1.1
10/09/2022 01:00	8.5	13.0	6.3	130.0	3,425,922.0	2,176.5	1.2	1.1
10/09/2022 02:00	8.3	13.0	6.2	127.2	3,418,783.9	2,147.0	1.2	1.1
10/09/2022 03:00	8.3	13.0	6.2	127.5	3,437,255.2	2,158.6	1.2	1.1
10/09/2022 04:00	8.4	13.0	6.3	128.8	3,407,820.4	2,165.0	1.2	1.1
10/09/2022 05:00	8.4	13.0	6.3	128.2	3,393,654.0	2,156.0	1.2	1.1
10/09/2022 06:00	8.1	13.1	6.1	140.1	3,200,268.7	1,682.6	1.5	1.0
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2022 14:00	34.3	17.2	54.7	100.7	1,594,342.0	384.2	1.8	0.3
10/09/2022 15:00	22.4	14.2	19.7	173.8	2,801,328.8	1,309.2	2.0	1.0
10/09/2022 16:00	7.7	13.6	6.2	103.9	3,353,915.9	1,714.4	1.0	0.7
10/09/2022 17:00	8.3	13.4	6.5	107.9	3,356,611.3	1,764.8	1.0	0.7
10/09/2022 18:00	8.8	13.0	6.6	123.1	3,350,095.4	2,079.4	1.2	1.0
10/09/2022 19:00	8.9	12.9	6.6	135.0	3,322,283.7	2,207.7	1.3	1.1
10/09/2022 20:00	8.7	12.9	6.4	133.0	3,362,013.8	2,185.0	1.3	1.1
10/09/2022 21:00	8.7	13.0	6.5	131.4	3,382,167.0	2,173.4	1.3	1.1
10/09/2022 22:00	8.5	13.0	6.3	128.9	3,394,913.2	2,156.8	1.2	1.1
10/09/2022 23:00	8.5	13.0	6.3	127.9	3,381,848.6	2,148.5	1.2	1.1
Average/Sum#:	10.8	13.4	10.0	128.1	3,233,285.7	1,928.4	1.3	1.0
Minimum:	7.7	12.9	6.1	100.7	1,594,342.0	384.2	1.0	0.3
Maximum:	34.3	17.2	54.7	173.8	3,437,255.2	2,207.7	2.0	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/10/2022 00:00	8.3	13.0	6.2	125.2	3,381,204.3	2,123.4	1.2	1.1
10/10/2022 01:00	8.1	13.1	6.1	121.5	3,415,898.7	2,095.3	1.1	0.8
10/10/2022 02:00	8.0	13.2	6.1	111.8	3,434,655.0	1,981.4	1.0	0.8
10/10/2022 03:00	8.2	13.1	6.2	120.8	3,413,290.3	2,093.7	1.1	0.8
10/10/2022 04:00	8.2	13.0	6.1	124.3	3,446,438.4	2,139.2	1.2	1.1
10/10/2022 05:00	8.3	12.9	6.1	132.5	3,424,330.3	2,225.5	1.3	1.1
10/10/2022 06:00	8.2	12.9	6.0	134.4	3,447,992.7	2,215.7	1.3	1.1
10/10/2022 07:00	7.8	13.4	6.1	110.4	3,292,278.8	1,803.1	1.1	0.7
10/10/2022 08:00	7.5	13.7	6.1	93.7	3,016,646.3	1,542.0	1.0	0.6
10/10/2022 09:00	7.5	13.7	6.1	92.8	3,047,862.4	1,535.7	1.0	0.6
10/10/2022 10:00	7.1	13.8	5.9	83.1	2,799,465.9	1,390.1	0.9	0.4
10/10/2022 11:00	7.3	13.8	6.1	92.4	3,101,448.5	1,562.7	0.9	0.5
10/10/2022 12:00	7.3	13.8	6.1	93.6	3,175,453.5	1,576.8	0.9	0.5
10/10/2022 13:00	8.1	13.7	6.6	103.4	3,334,744.0	1,704.6	1.0	0.7
10/10/2022 14:00	7.7	13.6	6.2	102.9	3,349,025.1	1,711.9	1.0	0.7
10/10/2022 15:00	8.6	13.6	7.0	99.6	3,099,789.9	1,584.5	1.0	0.6
10/10/2022 16:00	8.7	13.2	6.7	117.4	3,302,341.5	1,953.3	1.1	0.8
10/10/2022 17:00	8.8	13.0	6.6	130.6	3,323,239.1	2,159.8	1.3	1.1
10/10/2022 18:00	8.8	12.9	6.5	134.2	3,339,113.1	2,194.5	1.3	1.1
10/10/2022 19:00	8.8	12.9	6.5	131.9	3,340,933.9	2,171.3	1.3	1.1
10/10/2022 20:00	8.8	12.9	6.5	131.1	3,366,294.1	2,163.2	1.3	1.1
10/10/2022 21:00	8.7	13.0	6.5	125.9	3,358,752.2	2,109.3	1.2	1.1
10/10/2022 22:00	8.5	13.1	6.4	123.7	3,410,355.8	2,091.9	1.2	1.0
10/10/2022 23:00	8.3	13.2	6.4	113.0	3,376,064.5	1,947.6	1.1	0.8
Average/Sum#:	8.2	13.3	6.3	114.6	3,291,567.4	1,919.9	1.1	0.8
Minimum:	7.1	12.9	5.9	83.1	2,799,465.9	1,390.1	0.9	0.4
Maximum:	8.8	13.8	7.0	134.4	3,447,992.7	2,225.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/11/2022 00:00	7.5	13.7	6.1	87.3	2,716,620.4	1,368.8	1.0	0.5
10/11/2022 01:00	7.5	13.8	6.2	82.4	2,568,166.9	1,294.0	1.0	0.5
10/11/2022 02:00	7.5	13.8	6.2	82.4	2,567,968.4	1,293.9	1.0	0.5
10/11/2022 03:00	7.5	13.8	6.2	84.2	2,670,973.0	1,345.8	1.0	0.5
10/11/2022 04:00	7.3	13.7	6.0	90.1	2,956,964.3	1,489.9	1.0	0.6
10/11/2022 05:00	7.5	13.8	6.2	83.3	2,608,455.8	1,314.3	1.0	0.5
10/11/2022 06:00	7.6	13.8	6.3	82.6	2,586,227.4	1,303.1	1.0	0.5
10/11/2022 07:00	7.9	13.8	6.6	83.7	2,617,585.2	1,318.9	1.0	0.5
10/11/2022 08:00	7.7	13.7	6.3	103.7	3,420,039.6	1,748.2	0.9	0.5
10/11/2022 09:00	7.5	13.7	6.1	96.5	3,159,996.4	1,592.2	1.0	0.6
10/11/2022 10:00	8.4	13.6	6.8	105.9	3,336,187.8	1,729.7	1.0	0.7
10/11/2022 11:00	8.0	13.5	6.4	105.9	3,370,327.0	1,747.4	1.0	0.7
10/11/2022 12:00	7.8	13.6	6.3	105.5	3,420,822.1	1,748.6	1.0	0.7
10/11/2022 13:00	7.9	13.6	6.4	105.4	3,404,389.0	1,740.2	1.0	0.7
10/11/2022 14:00	7.8	13.6	6.3	105.0	3,390,694.8	1,733.2	1.0	0.7
10/11/2022 15:00	7.9	13.6	6.4	105.4	3,399,498.2	1,737.7	1.0	0.7
10/11/2022 16:00	8.1	13.5	6.5	107.2	3,395,979.6	1,760.7	1.0	0.7
10/11/2022 17:00	8.4	13.4	6.6	108.8	3,368,213.4	1,770.9	1.0	0.7
10/11/2022 18:00	8.4	13.4	6.6	109.3	3,377,342.9	1,775.7	1.0	0.7
10/11/2022 19:00	8.7	13.2	6.7	122.3	3,354,274.6	2,057.5	1.2	1.0
10/11/2022 20:00	8.7	13.1	6.6	125.7	3,351,745.8	2,104.9	1.2	1.1
10/11/2022 21:00	8.8	13.0	6.6	134.8	3,360,380.7	2,159.4	1.3	1.1
10/11/2022 22:00	8.6	13.0	6.4	124.6	3,374,583.9	2,094.6	1.2	1.0
10/11/2022 23:00	8.3	13.2	6.4	112.7	3,399,812.7	1,961.3	1.1	0.8
Average/Sum#:	8.0	13.5	6.4	102.3	3,132,385.4	1,674.6	1.0	0.7
Minimum:	7.3	13.0	6.0	82.4	2,567,968.4	1,293.9	0.9	0.5
Maximum:	8.8	13.8	6.8	134.8	3,420,822.1	2,159.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/12/2022 00:00	8.3	13.2	6.4	111.3	3,421,103.0	1,948.6	1.0	0.8
10/12/2022 01:00	8.2	13.2	6.3	110.4	3,386,516.3	1,928.9	1.0	0.8
10/12/2022 02:00	7.3	13.7	6.0	92.8	2,958,347.9	1,512.2	1.0	0.6
10/12/2022 03:00	7.3	13.7	6.0	97.1	3,178,434.0	1,624.7	1.0	0.6
10/12/2022 04:00	7.9	13.5	6.3	105.7	3,368,591.1	1,746.5	1.0	0.7
10/12/2022 05:00	8.7	13.1	6.6	125.4	3,419,694.3	2,122.6	1.2	1.1
10/12/2022 06:00	8.7	12.9	6.4	138.5	3,430,103.8	2,254.3	1.3	1.1
10/12/2022 07:00	8.9	12.9	6.6	138.1	3,416,257.4	2,245.2	1.3	1.1
10/12/2022 08:00	8.6	12.9	6.3	136.6	3,413,214.2	2,243.2	1.3	1.1
10/12/2022 09:00	8.5	12.9	6.3	136.2	3,405,302.0	2,238.0	1.3	1.1
10/12/2022 10:00	8.5	12.9	6.3	135.7	3,399,367.8	2,234.1	1.3	1.1
10/12/2022 11:00	8.6	12.9	6.3	136.5	3,399,063.5	2,233.9	1.3	1.1
10/12/2022 12:00	8.6	12.9	6.3	136.0	3,395,563.8	2,231.6	1.3	1.1
10/12/2022 13:00	8.7	12.9	6.4	135.9	3,391,455.6	2,228.9	1.3	1.1
10/12/2022 14:00	8.7	12.9	6.4	135.8	3,392,672.8	2,229.7	1.3	1.1
10/12/2022 15:00	8.8	12.9	6.5	138.3	3,364,269.4	2,235.6	1.3	1.1
10/12/2022 16:00	9.0	12.8	6.6	142.9	3,314,743.3	2,251.1	1.4	1.1
10/12/2022 17:00	9.0	12.8	6.6	146.0	3,328,584.8	2,260.5	1.4	1.1
10/12/2022 18:00	8.9	12.9	6.6	139.8	3,347,114.0	2,224.2	1.4	1.1
10/12/2022 19:00	8.7	13.0	6.5	128.0	3,361,543.3	2,135.6	1.2	1.1
10/12/2022 20:00	8.7	13.0	6.5	129.0	3,385,311.5	2,150.7	1.2	1.1
10/12/2022 21:00	8.7	13.0	6.5	125.9	3,368,147.0	2,115.2	1.2	1.1
10/12/2022 22:00	8.6	13.1	6.5	123.0	3,398,943.9	2,084.9	1.2	1.0
10/12/2022 23:00	8.4	13.2	6.4	112.6	3,396,172.5	1,959.2	1.1	0.8
Average/Sum#:	8.5	13.1	6.4	127.4	3,360,021.6	2,101.6	1.2	1.0
Minimum:	7.3	12.8	6.0	92.8	2,958,347.9	1,512.2	1.0	0.6
Maximum:	9.0	13.7	6.6	146.0	3,430,103.8	2,260.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/13/2022 00:00	8.5	13.2	6.5	112.3	3,391,665.5	1,956.6	1.0	0.8
10/13/2022 01:00	8.6	13.1	6.5	115.9	3,382,816.4	2,000.9	1.1	0.8
10/13/2022 02:00	8.5	13.2	6.5	111.2	3,418,469.5	1,947.1	1.0	0.8
10/13/2022 03:00	8.5	13.2	6.5	112.0	3,439,713.1	1,959.2	1.0	0.8
10/13/2022 04:00	8.3	13.2	6.4	110.8	3,405,302.0	1,939.6	1.0	0.8
10/13/2022 05:00	7.7	13.7	6.3	84.8	2,558,671.6	1,307.9	1.0	0.5
10/13/2022 06:00	7.6	13.7	6.2	83.0	2,559,649.8	1,308.4	1.0	0.5
10/13/2022 07:00	7.9	13.7	6.5	84.0	2,597,341.6	1,308.7	1.0	0.5
10/13/2022 08:00	7.7	13.7	6.3	91.2	2,908,657.4	1,486.8	1.0	0.6
10/13/2022 09:00	7.6	13.7	6.2	93.8	3,007,255.9	1,537.2	1.0	0.6
10/13/2022 10:00	8.1	13.5	6.5	103.9	3,303,398.8	1,712.7	1.0	0.7
10/13/2022 11:00	8.4	13.4	6.6	110.0	3,413,290.3	1,794.6	1.0	0.7
10/13/2022 12:00	8.4	13.4	6.6	109.8	3,405,302.0	1,790.4	1.0	0.7
10/13/2022 13:00	8.4	13.4	6.6	110.4	3,394,270.5	1,784.6	1.0	0.7
10/13/2022 14:00	8.4	13.4	6.6	108.9	3,385,331.2	1,779.9	1.0	0.7
10/13/2022 15:00	8.4	13.4	6.6	108.9	3,380,386.1	1,777.3	1.0	0.7
10/13/2022 16:00	8.4	13.4	6.6	108.9	3,383,619.4	1,779.0	1.0	0.7
10/13/2022 17:00	8.3	13.4	6.5	108.8	3,384,950.8	1,779.7	1.0	0.7
10/13/2022 18:00	8.2	13.4	6.5	108.8	3,393,890.1	1,784.4	1.0	0.7
10/13/2022 19:00	8.2	13.4	6.5	108.9	3,400,737.2	1,788.0	1.0	0.7
10/13/2022 20:00	8.4	13.1	6.4	118.8	3,393,862.6	2,057.0	1.1	0.8
10/13/2022 21:00	8.4	13.0	6.3	128.5	3,394,283.6	2,156.4	1.2	1.1
10/13/2022 22:00	8.1	13.1	6.1	120.1	3,391,770.8	2,080.5	1.1	0.8
10/13/2022 23:00	8.0	13.1	6.1	118.9	3,415,311.4	2,070.0	1.1	0.8
Average/Sum#:	8.2	13.4	6.4	107.2	3,254,581.2	1,787.0	1.0	0.7
Minimum:	7.6	13.0	6.1	83.0	2,558,671.6	1,307.9	1.0	0.5
Maximum:	8.6	13.7	6.6	128.5	3,439,713.1	2,156.4	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/14/2022 00:00	7.9	13.1	6.0	117.4	3,442,098.3	2,061.1	1.1	0.8
10/14/2022 01:00	7.9	13.1	6.0	118.9	3,423,066.0	2,074.7	1.1	0.8
10/14/2022 02:00	8.1	13.1	6.1	121.3	3,422,901.0	2,074.6	1.1	0.8
10/14/2022 03:00	8.1	13.1	6.1	121.2	3,417,951.3	2,071.6	1.1	0.8
10/14/2022 04:00	8.2	13.0	6.1	125.0	3,403,744.6	2,112.7	1.2	1.1
10/14/2022 05:00	8.4	12.9	6.2	150.9	3,401,289.0	2,260.2	1.5	1.4
10/14/2022 06:00	8.4	12.9	6.2	155.8	3,391,206.4	2,253.5	1.5	1.4
10/14/2022 07:00	8.9	12.8	6.5	148.2	3,385,825.7	2,225.2	1.4	1.1
10/14/2022 08:00	8.2	13.1	6.2	120.5	3,382,478.2	2,025.4	1.1	0.8
10/14/2022 09:00	8.3	13.1	6.3	114.7	3,404,146.3	1,963.8	1.1	0.8
10/14/2022 10:00	8.3	13.1	6.3	115.5	3,379,397.0	1,974.2	1.1	0.8
10/14/2022 11:00	8.3	13.1	6.3	116.1	3,349,341.5	1,981.1	1.1	0.8
10/14/2022 12:00	8.3	13.1	6.3	117.7	3,363,373.9	1,989.4	1.1	0.8
10/14/2022 13:00	8.3	13.1	6.3	117.2	3,338,723.4	1,999.2	1.1	0.8
10/14/2022 14:00	8.5	13.0	6.3	130.4	3,340,758.6	2,098.0	1.3	1.0
10/14/2022 15:00	8.6	12.9	6.3	137.2	3,348,636.1	2,127.4	1.3	1.1
10/14/2022 16:00	8.5	12.9	6.3	135.0	3,335,886.3	2,119.3	1.3	1.1
10/14/2022 17:00	8.6	12.9	6.3	147.0	3,321,832.3	2,207.4	1.4	1.1
10/14/2022 18:00	8.3	13.0	6.2	134.4	3,344,974.7	2,149.5	1.3	1.1
10/14/2022 19:00	8.3	13.0	6.2	129.6	3,338,090.0	2,120.7	1.3	1.1
10/14/2022 20:00	8.2	13.0	6.1	130.0	3,352,099.0	2,129.6	1.3	1.1
10/14/2022 21:00	8.2	13.0	6.1	128.7	3,377,223.5	2,120.9	1.2	1.1
10/14/2022 22:00	8.1	13.0	6.0	124.2	3,373,133.9	2,093.7	1.2	1.0
10/14/2022 23:00	12.7	14.3	11.4	132.1	2,632,867.2	1,326.6	1.6	0.8
Average/Sum#:	8.5	13.1	6.4	128.7	3,344,626.8	2,065.0	1.2	1.0
Minimum:	7.9	12.8	6.0	114.7	2,632,867.2	1,326.6	1.1	0.8
Maximum:	12.7	14.3	11.4	155.8	3,442,098.3	2,260.2	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	28.3	17.3	46.4	0.0	1,405,799.7	328.5	0.1	0.0
10/16/2022 18:00	38.5	16.2	48.3	207.0	1,787,721.3	574.4	3.5	0.7
10/16/2022 19:00	29.4	14.8	28.4	215.2	2,280,091.6	965.7	3.0	1.2
10/16/2022 20:00	8.0	13.5	6.4	107.6	3,414,881.5	1,770.5	1.0	0.7
10/16/2022 21:00	8.0	13.5	6.4	103.0	3,251,900.7	1,686.0	1.0	0.7
10/16/2022 22:00	7.9	13.6	6.4	94.6	3,119,157.5	1,594.4	1.0	0.6
10/16/2022 23:00	8.3	13.5	6.6	109.6	3,479,109.4	1,803.8	1.0	0.7
Average/Sum#:	18.3	14.6	21.3	119.6	2,676,951.7	1,246.2	1.5	0.7
Minimum:	7.9	13.5	6.4	0.0	1,405,799.7	328.5	0.1	0.0
Maximum:	38.5	17.3	48.3	215.2	3,479,109.4	1,803.8	3.5	1.2
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/17/2022 00:00	7.8	13.6	6.3	100.9	3,214,039.0	1,642.9	1.0	0.7
10/17/2022 01:00	7.7	13.6	6.2	103.1	3,323,006.1	1,698.6	1.0	0.7
10/17/2022 02:00	7.5	13.6	6.1	103.0	3,330,635.7	1,702.5	1.0	0.7
10/17/2022 03:00	7.9	13.5	6.3	108.4	3,461,943.4	1,794.9	1.0	0.7
10/17/2022 04:00	8.8	13.1	6.7	124.8	3,437,255.2	2,058.2	1.2	1.0
10/17/2022 05:00	8.9	13.0	6.6	144.6	3,399,950.2	2,160.0	1.4	1.1
10/17/2022 06:00	8.7	13.0	6.5	139.1	3,416,076.9	2,145.3	1.3	1.1
10/17/2022 07:00	8.9	13.1	6.7	132.3	3,422,908.9	2,099.6	1.2	1.0
10/17/2022 08:00	7.4	13.6	6.0	102.7	3,246,693.0	1,683.3	1.0	0.7
10/17/2022 09:00	7.4	13.7	6.1	99.2	3,193,302.0	1,632.3	1.0	0.7
10/17/2022 10:00	7.4	13.7	6.1	92.1	3,021,863.1	1,522.6	1.0	0.6
10/17/2022 11:00	7.6	13.7	6.2	97.3	3,193,537.4	1,609.1	1.0	0.6
10/17/2022 12:00	7.5	13.7	6.1	91.6	2,990,108.4	1,506.6	1.0	0.6
10/17/2022 13:00	7.5	13.7	6.1	90.8	2,979,788.1	1,501.4	1.0	0.6
10/17/2022 14:00	7.6	13.7	6.2	100.5	3,290,389.4	1,657.9	1.0	0.7
10/17/2022 15:00	8.0	13.6	6.5	103.4	3,272,731.4	1,696.8	1.0	0.7
10/17/2022 16:00	8.9	13.1	6.7	124.9	3,390,629.6	2,079.8	1.2	1.0
10/17/2022 17:00	9.0	12.9	6.6	151.6	3,357,196.5	2,230.9	1.5	1.3
10/17/2022 18:00	8.8	12.9	6.5	154.4	3,380,521.9	2,246.4	1.5	1.3
10/17/2022 19:00	8.7	12.9	6.4	152.7	3,383,391.2	2,223.6	1.5	1.3
10/17/2022 20:00	8.7	12.9	6.4	153.2	3,392,977.1	2,229.9	1.5	1.3
10/17/2022 21:00	8.7	12.9	6.4	155.0	3,370,439.3	2,239.7	1.5	1.3
10/17/2022 22:00	8.5	13.0	6.3	140.8	3,427,023.9	2,177.2	1.3	1.1
10/17/2022 23:00	8.6	13.0	6.4	142.1	3,437,097.8	2,183.6	1.3	1.1
Average/Sum#:	8.2	13.3	6.4	121.2	3,305,562.7	1,905.1	1.2	0.9
Minimum:	7.4	12.9	6.0	90.8	2,979,788.1	1,501.4	1.0	0.6
Maximum:	9.0	13.7	6.7	155.0	3,461,943.4	2,246.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/18/2022 00:00	8.5	13.0	6.3	139.6	3,430,014.6	2,179.1	1.3	1.1
10/18/2022 01:00	8.3	13.0	6.2	136.1	3,456,841.2	2,170.9	1.3	1.1
10/18/2022 02:00	8.4	13.0	6.3	143.8	3,416,792.5	2,170.7	1.4	1.1
10/18/2022 03:00	8.5	13.0	6.3	147.6	3,387,613.6	2,176.9	1.4	1.1
10/18/2022 04:00	8.4	13.0	6.3	146.5	3,388,391.7	2,177.4	1.4	1.1
10/18/2022 05:00	8.5	13.0	6.3	143.4	3,435,523.7	2,182.6	1.4	1.1
10/18/2022 06:00	8.2	13.0	6.1	133.5	3,452,541.8	2,168.2	1.3	1.1
10/18/2022 07:00	8.8	13.1	6.7	138.3	3,450,153.3	2,166.7	1.3	1.1
10/18/2022 08:00	8.7	13.0	6.5	139.3	3,457,000.4	2,171.0	1.3	1.1
10/18/2022 09:00	8.6	13.0	6.4	138.7	3,473,182.5	2,155.8	1.3	1.1
10/18/2022 10:00	8.6	13.0	6.4	134.6	3,414,700.0	2,119.5	1.3	1.1
10/18/2022 11:00	8.6	13.1	6.5	131.8	3,420,626.5	2,098.2	1.2	1.0
10/18/2022 12:00	8.6	13.1	6.5	132.3	3,420,626.5	2,098.2	1.2	1.0
10/18/2022 13:00	8.7	13.1	6.6	133.1	3,428,125.7	2,102.8	1.3	1.1
10/18/2022 14:00	8.7	13.0	6.5	134.3	3,395,205.8	2,107.4	1.3	1.1
10/18/2022 15:00	8.8	13.0	6.6	139.0	3,399,197.9	2,134.7	1.3	1.1
10/18/2022 16:00	9.0	12.9	6.6	154.3	3,372,283.6	2,216.3	1.5	1.3
10/18/2022 17:00	8.9	13.0	6.6	150.0	3,405,509.5	2,188.4	1.4	1.1
10/18/2022 18:00	9.0	12.9	6.6	156.6	3,395,868.2	2,231.8	1.5	1.3
10/18/2022 19:00	9.0	12.9	6.6	163.5	3,391,206.4	2,253.5	1.6	1.4
10/18/2022 20:00	8.9	12.9	6.6	162.9	3,400,085.1	2,259.4	1.6	1.4
10/18/2022 21:00	8.9	12.9	6.6	164.1	3,399,934.6	2,259.3	1.6	1.4
10/18/2022 22:00	8.8	13.0	6.6	150.4	3,416,713.8	2,195.6	1.4	1.1
10/18/2022 23:00	8.8	13.0	6.6	149.8	3,412,356.6	2,192.8	1.4	1.1
Average/Sum#:	8.7	13.0	6.5	144.3	3,417,520.6	2,174.1	1.4	1.1
Minimum:	8.2	12.9	6.1	131.8	3,372,283.6	2,098.2	1.2	1.0
Maximum:	9.0	13.1	6.7	164.1	3,473,182.5	2,259.4	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/19/2022 00:00	8.8	13.0	6.6	147.7	3,434,579.3	2,182.0	1.4	1.1
10/19/2022 01:00	8.4	13.1	6.4	132.2	3,482,739.7	2,136.3	1.2	1.1
10/19/2022 02:00	8.5	13.1	6.4	131.0	3,470,913.3	2,103.7	1.2	1.1
10/19/2022 03:00	8.6	13.1	6.5	136.5	3,496,107.8	2,144.5	1.3	1.1
10/19/2022 04:00	8.7	13.0	6.5	143.5	3,484,070.4	2,188.0	1.3	1.1
10/19/2022 05:00	8.8	13.0	6.6	154.5	3,443,409.9	2,237.9	1.5	1.3
10/19/2022 06:00	8.7	13.0	6.5	151.0	3,484,004.5	2,213.4	1.4	1.1
10/19/2022 07:00	9.1	13.1	6.9	140.0	3,461,582.6	2,148.6	1.3	1.1
10/19/2022 08:00	8.7	13.1	6.6	134.9	3,485,674.1	2,138.1	1.2	1.1
10/19/2022 09:00	8.6	13.1	6.5	132.5	3,456,394.1	2,094.9	1.2	1.0
10/19/2022 10:00	8.7	13.1	6.6	131.1	3,430,985.5	2,079.5	1.2	1.0
10/19/2022 11:00	8.9	13.0	6.6	136.7	3,399,394.6	2,110.0	1.3	1.1
10/19/2022 12:00	8.9	13.0	6.6	141.8	3,392,032.4	2,130.2	1.4	1.1
10/19/2022 13:00	8.9	13.0	6.6	146.5	3,382,635.6	2,149.0	1.4	1.1
10/19/2022 14:00	8.9	13.0	6.6	141.9	3,370,672.8	2,141.4	1.4	1.1
10/19/2022 15:00	9.0	12.9	6.6	148.4	3,351,396.9	2,178.1	1.4	1.1
10/19/2022 16:00	9.1	12.9	6.7	151.8	3,376,169.6	2,194.2	1.5	1.3
10/19/2022 17:00	8.9	13.0	6.6	141.6	3,381,522.8	2,123.6	1.4	1.1
10/19/2022 18:00	8.8	13.0	6.6	134.7	3,382,156.0	2,099.3	1.3	1.0
10/19/2022 19:00	8.8	13.0	6.6	137.1	3,396,978.0	2,108.5	1.3	1.1
10/19/2022 20:00	8.8	13.0	6.6	140.4	3,418,943.1	2,147.1	1.3	1.1
10/19/2022 21:00	8.6	13.1	6.5	134.3	3,446,710.8	2,114.2	1.3	1.1
10/19/2022 22:00	8.6	13.1	6.5	131.0	3,444,184.8	2,087.5	1.2	1.0
10/19/2022 23:00	8.7	13.1	6.6	132.4	3,432,038.3	2,105.2	1.2	1.1
Average/Sum#:	8.8	13.0	6.6	139.7	3,429,387.4	2,139.8	1.3	1.1
Minimum:	8.4	12.9	6.4	131.0	3,351,396.9	2,079.5	1.2	1.0
Maximum:	9.1	13.1	6.9	154.5	3,496,107.8	2,237.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/20/2022 00:00	8.6	13.1	6.5	134.0	3,462,687.4	2,124.0	1.2	1.1
10/20/2022 01:00	8.6	13.1	6.5	130.5	3,444,844.8	2,087.9	1.2	1.0
10/20/2022 02:00	8.5	13.1	6.4	128.2	3,429,500.6	2,078.6	1.2	1.0
10/20/2022 03:00	8.5	13.1	6.4	129.3	3,447,154.7	2,089.3	1.2	1.0
10/20/2022 04:00	8.6	13.1	6.5	134.4	3,481,435.4	2,135.5	1.2	1.1
10/20/2022 05:00	8.7	13.0	6.5	148.1	3,451,416.3	2,217.9	1.4	1.1
10/20/2022 06:00	8.7	13.0	6.5	148.4	3,489,962.1	2,191.7	1.4	1.1
10/20/2022 07:00	8.7	13.2	6.7	126.1	3,498,794.8	2,069.5	1.2	1.0
10/20/2022 08:00	8.6	13.1	6.5	125.8	3,476,647.3	2,056.4	1.2	1.0
10/20/2022 09:00	8.6	13.1	6.5	128.6	3,450,448.4	2,066.1	1.2	1.0
10/20/2022 10:00	8.6	13.1	6.5	127.9	3,441,597.3	2,060.8	1.2	1.0
10/20/2022 11:00	8.6	13.1	6.5	130.7	3,389,977.5	2,079.4	1.2	1.0
10/20/2022 12:00	8.7	13.1	6.6	131.5	3,389,977.5	2,079.4	1.2	1.0
10/20/2022 13:00	8.8	13.0	6.6	135.0	3,382,800.4	2,099.7	1.3	1.0
10/20/2022 14:00	8.8	13.0	6.6	138.3	3,377,382.7	2,121.0	1.3	1.1
10/20/2022 15:00	8.9	13.0	6.6	143.7	3,379,802.3	2,147.2	1.4	1.1
10/20/2022 16:00	9.0	12.9	6.6	161.3	3,335,739.2	2,241.0	1.6	1.3
10/20/2022 17:00	8.9	13.0	6.6	149.9	3,352,166.3	2,178.6	1.5	1.3
10/20/2022 18:00	8.9	12.9	6.6	155.2	3,366,501.6	2,212.5	1.5	1.3
10/20/2022 19:00	8.7	13.0	6.5	136.2	3,356,522.9	2,107.9	1.3	1.1
10/20/2022 20:00	8.8	13.0	6.6	136.2	3,391,178.1	2,104.9	1.3	1.1
10/20/2022 21:00	8.5	13.1	6.4	129.7	3,437,255.2	2,083.3	1.2	1.0
10/20/2022 22:00	8.6	13.1	6.5	130.4	3,437,255.2	2,083.3	1.2	1.0
10/20/2022 23:00	8.5	13.0	6.3	134.9	3,442,410.7	2,136.7	1.3	1.1
Average/Sum#:	8.7	13.1	6.5	136.4	3,421,394.1	2,118.9	1.3	1.1
Minimum:	8.5	12.9	6.3	125.8	3,335,739.2	2,056.4	1.2	1.0
Maximum:	9.0	13.2	6.7	161.3	3,498,794.8	2,241.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/21/2022 00:00	8.4	13.2	6.4	120.9	3,403,019.6	1,988.0	1.1	0.8
10/21/2022 01:00	7.5	13.7	6.1	96.6	3,129,829.4	1,577.0	1.0	0.6
10/21/2022 02:00	7.7	13.7	6.3	96.8	3,104,289.4	1,586.8	1.0	0.6
10/21/2022 03:00	7.7	13.7	6.3	94.0	3,019,385.1	1,543.4	1.0	0.6
10/21/2022 04:00	7.4	13.7	6.1	101.5	3,366,203.9	1,696.1	1.0	0.7
10/21/2022 05:00	7.2	13.7	5.9	100.8	3,370,371.7	1,698.2	0.9	0.5
10/21/2022 06:00	7.1	13.7	5.8	96.5	3,172,499.8	1,598.5	1.0	0.6
10/21/2022 07:00	7.5	13.7	6.1	99.3	3,311,426.9	1,668.5	0.9	0.5
10/21/2022 08:00	7.3	13.7	6.0	101.8	3,383,669.0	1,704.9	1.0	0.7
10/21/2022 09:00	7.3	13.7	6.0	101.5	3,390,615.4	1,708.4	0.9	0.5
10/21/2022 10:00	7.4	13.7	6.1	101.7	3,387,638.4	1,706.9	0.9	0.5
10/21/2022 11:00	7.4	13.7	6.1	100.4	3,318,174.8	1,671.9	1.0	0.7
10/21/2022 12:00	8.0	13.7	6.6	101.0	3,272,328.9	1,648.8	1.0	0.7
10/21/2022 13:00	7.7	13.7	6.3	98.4	3,223,307.5	1,624.1	1.0	0.6
10/21/2022 14:00	7.8	13.6	6.3	102.6	3,288,574.8	1,681.0	1.0	0.7
10/21/2022 15:00	8.2	13.6	6.6	96.4	3,044,817.3	1,556.4	1.0	0.6
10/21/2022 16:00	8.9	13.0	6.6	125.9	3,376,517.2	2,095.8	1.2	1.0
10/21/2022 17:00	8.9	12.9	6.6	141.1	3,354,628.1	2,180.2	1.4	1.1
10/21/2022 18:00	8.8	13.0	6.6	138.7	3,362,960.0	2,136.5	1.3	1.1
10/21/2022 19:00	8.6	13.0	6.4	132.0	3,380,706.0	2,098.4	1.3	1.0
10/21/2022 20:00	8.7	13.0	6.5	133.5	3,370,535.6	2,116.7	1.3	1.1
10/21/2022 21:00	8.7	12.9	6.4	141.7	3,348,165.7	2,176.0	1.4	1.1
10/21/2022 22:00	13.3	14.5	12.3	134.2	2,493,182.3	1,201.6	1.7	0.8
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.2	13.5	6.5	111.2	3,255,341.2	1,768.0	1.1	0.7
Minimum:	7.1	12.9	5.8	94.0	2,493,182.3	1,201.6	0.9	0.5
Maximum:	13.3	14.5	12.3	141.7	3,403,019.6	2,180.2	1.7	1.1
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	33.8	17.4	57.0	0.0	1,312,880.4	297.2	0.0	0.0
10/23/2022 21:00	35.3	17.2	56.3	206.6	1,410,126.7	370.7	4.5	0.6
10/23/2022 22:00	33.3	15.7	37.8	220.0	2,155,747.9	787.1	3.1	0.9
10/23/2022 23:00	7.2	13.8	6.0	88.4	2,726,161.5	1,353.7	1.0	0.5
Average/Sum#:	27.4	16.0	39.3	128.8	1,901,229.1	702.2	2.2	0.5
Minimum:	7.2	13.8	6.0	0.0	1,312,880.4	297.2	0.0	0.0
Maximum:	35.3	17.4	57.0	220.0	2,726,161.5	1,353.7	4.5	0.9
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/24/2022 00:00	7.1	13.8	5.9	83.5	2,755,966.6	1,368.5	1.0	0.5
10/24/2022 01:00	7.3	13.8	6.1	83.9	2,738,244.6	1,359.7	1.0	0.5
10/24/2022 02:00	7.3	13.8	6.1	84.2	2,738,043.2	1,359.6	1.0	0.5
10/24/2022 03:00	7.3	13.8	6.1	84.3	2,738,043.2	1,359.6	1.0	0.5
10/24/2022 04:00	8.0	13.6	6.5	101.4	3,226,168.2	1,649.1	1.0	0.7
10/24/2022 05:00	8.3	13.6	6.7	113.5	3,511,127.0	1,820.4	1.0	0.7
10/24/2022 06:00	8.2	13.5	6.5	113.2	3,513,634.4	1,821.7	1.0	0.7
10/24/2022 07:00	8.6	13.5	6.9	115.2	3,509,005.3	1,819.3	1.0	0.7
10/24/2022 08:00	8.6	13.6	7.0	114.5	3,552,678.1	1,816.0	1.0	0.7
10/24/2022 09:00	7.9	13.6	6.4	111.5	3,509,052.2	1,793.7	1.0	0.7
10/24/2022 10:00	8.1	13.5	6.5	113.7	3,551,052.4	1,841.1	1.0	0.7
10/24/2022 11:00	8.1	13.5	6.5	113.7	3,532,536.3	1,831.5	1.0	0.7
10/24/2022 12:00	7.6	13.6	6.1	108.5	3,461,904.8	1,769.6	1.0	0.7
10/24/2022 13:00	7.6	13.6	6.1	107.5	3,416,909.5	1,746.6	1.0	0.7
10/24/2022 14:00	15.1	15.0	15.1	129.0	2,393,895.5	1,013.9	1.6	0.6
10/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.3	13.7	7.0	105.2	3,209,884.1	1,624.7	1.0	0.6
Minimum:	7.1	13.5	5.9	83.5	2,393,895.5	1,013.9	1.0	0.5
Maximum:	15.1	15.0	15.1	129.0	3,552,678.1	1,841.1	1.6	0.7
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	19.8	18.0	40.3	0.1	1,126,351.6	164.5	-0.2	0.0
10/30/2022 20:00	36.0	17.1	55.9	64.2	1,418,495.4	372.9	1.4	0.2
10/30/2022 21:00	39.5	16.6	54.2	238.7	1,879,451.5	562.7	3.7	0.8
10/30/2022 22:00	36.8	15.7	41.8	227.8	2,454,902.8	878.4	2.8	1.0
10/30/2022 23:00	7.9	13.5	6.3	113.3	3,420,474.9	1,773.4	1.1	0.7
Average/Sum#:	28.0	16.2	39.7	128.8	2,059,935.2	750.4	1.8	0.5
Minimum:	7.9	13.5	6.3	0.1	1,126,351.6	164.5	-0.2	0.0
Maximum:	39.5	18.0	55.9	238.7	3,420,474.9	1,773.4	3.7	1.0
%SI	79.17	79.17	79.17	79.17	79.17	79.17	79.17	79.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/31/2022 00:00	7.4	13.7	6.1	97.9	3,107,601.0	1,565.8	1.0	0.6
10/31/2022 01:00	7.9	13.6	6.4	109.7	3,495,944.8	1,787.0	1.0	0.7
10/31/2022 02:00	7.7	13.7	6.3	104.6	3,317,182.5	1,671.4	1.0	0.7
10/31/2022 03:00	7.5	13.7	6.1	104.6	3,391,409.3	1,708.8	1.0	0.7
10/31/2022 04:00	7.4	13.7	6.1	105.5	3,421,179.4	1,723.8	1.0	0.7
10/31/2022 05:00	7.4	13.7	6.1	104.8	3,390,020.0	1,708.1	1.0	0.7
10/31/2022 06:00	7.3	13.7	6.0	103.9	3,372,554.9	1,699.3	1.0	0.7
10/31/2022 07:00	7.6	13.7	6.2	104.9	3,375,333.4	1,700.7	1.0	0.7
10/31/2022 08:00	7.5	13.7	6.1	105.1	3,381,882.8	1,704.0	1.0	0.7
10/31/2022 09:00	7.5	13.7	6.1	104.9	3,384,264.4	1,705.2	1.0	0.7
10/31/2022 10:00	7.5	13.7	6.1	105.0	3,390,020.0	1,708.1	1.0	0.7
10/31/2022 11:00	7.4	13.7	6.1	103.5	3,348,341.9	1,687.1	1.0	0.7
10/31/2022 12:00	7.4	13.7	6.1	103.3	3,330,082.9	1,677.9	1.0	0.7
10/31/2022 13:00	7.4	13.7	6.1	104.0	3,357,868.3	1,691.9	1.0	0.7
10/31/2022 14:00	8.3	13.5	6.6	110.1	3,443,906.7	1,760.4	1.0	0.7
10/31/2022 15:00	9.0	13.1	6.8	125.4	3,430,655.6	2,079.3	1.2	1.0
10/31/2022 16:00	8.9	13.1	6.7	132.3	3,433,016.5	2,105.8	1.2	1.1
10/31/2022 17:00	8.8	13.1	6.7	127.5	3,429,335.6	2,078.5	1.2	1.0
10/31/2022 18:00	8.7	13.1	6.6	128.2	3,433,955.4	2,081.3	1.2	1.0
10/31/2022 19:00	8.7	13.1	6.6	130.6	3,430,082.0	2,104.0	1.2	1.1
10/31/2022 20:00	8.7	13.1	6.6	131.4	3,436,766.1	2,108.1	1.2	1.1
10/31/2022 21:00	8.7	13.0	6.5	138.0	3,444,261.6	2,163.0	1.3	1.1
10/31/2022 22:00	8.3	13.1	6.3	129.8	3,455,025.1	2,119.3	1.2	1.1
10/31/2022 23:00	8.4	13.1	6.4	137.5	3,417,669.3	2,146.3	1.3	1.1
Average/Sum#:	8.0	13.5	6.3	114.7	3,392,431.6	1,853.5	1.1	0.8
Minimum:	7.3	13.0	6.0	97.9	3,107,601.0	1,565.8	1.0	0.6
Maximum:	9.0	13.7	6.8	138.0	3,495,944.8	2,163.0	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/01/2022 00:00	8.4	13.1	6.4	136.6	3,486,071.2	2,163.8	1.3	1.1
11/01/2022 01:00	8.3	13.1	6.3	134.4	3,468,993.6	2,153.2	1.3	1.1
11/01/2022 02:00	8.3	13.1	6.3	133.3	3,483,332.3	2,162.1	1.2	1.1
11/01/2022 03:00	8.3	13.0	6.2	132.2	3,485,587.8	2,163.5	1.2	1.1
11/01/2022 04:00	8.3	13.0	6.2	134.5	3,492,676.6	2,167.9	1.2	1.1
11/01/2022 05:00	8.3	13.0	6.2	134.0	3,491,871.1	2,167.4	1.2	1.1
11/01/2022 06:00	8.4	13.0	6.3	147.8	3,474,758.8	2,232.9	1.4	1.1
11/01/2022 07:00	8.9	13.0	6.6	138.8	3,470,376.2	2,179.4	1.3	1.1
11/01/2022 08:00	8.7	12.9	6.4	148.7	3,433,716.2	2,231.6	1.4	1.1
11/01/2022 09:00	8.3	13.0	6.2	132.5	3,409,383.4	2,116.2	1.3	1.1
11/01/2022 10:00	8.3	13.1	6.3	129.2	3,458,122.6	2,121.2	1.2	1.1
11/01/2022 11:00	8.5	13.0	6.3	140.9	3,429,384.9	2,178.7	1.3	1.1
11/01/2022 12:00	8.6	13.0	6.4	147.0	3,435,838.6	2,182.8	1.4	1.1
11/01/2022 13:00	8.6	13.1	6.5	148.7	3,454,134.2	2,169.2	1.4	1.1
11/01/2022 14:00	8.6	13.2	6.6	138.9	3,436,925.2	2,083.1	1.3	1.0
11/01/2022 15:00	8.5	13.2	6.5	132.0	3,498,044.3	2,094.6	1.2	1.0
11/01/2022 16:00	8.6	13.0	6.4	147.7	3,503,522.8	2,225.8	1.4	1.1
11/01/2022 17:00	8.7	13.0	6.5	168.5	3,487,619.6	2,292.1	1.6	1.4
11/01/2022 18:00	8.3	13.1	6.3	145.6	3,490,439.8	2,192.0	1.4	1.1
11/01/2022 19:00	8.3	13.1	6.3	138.1	3,527,245.9	2,163.6	1.3	1.1
11/01/2022 20:00	8.4	13.1	6.4	145.5	3,505,885.7	2,201.7	1.3	1.1
11/01/2022 21:00	8.1	13.2	6.2	125.7	3,517,899.1	2,080.8	1.2	1.0
11/01/2022 22:00	7.8	13.2	6.0	124.0	3,544,070.3	2,070.4	1.1	0.8
11/01/2022 23:00	7.0	13.5	5.6	106.4	3,370,427.3	1,845.9	1.0	0.7
Average/Sum#:	8.4	13.1	6.3	138.0	3,473,180.3	2,151.7	1.3	1.1
Minimum:	7.0	12.9	5.6	106.4	3,370,427.3	1,845.9	1.0	0.7
Maximum:	8.9	13.5	6.6	168.5	3,544,070.3	2,292.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/02/2022 00:00	7.3	13.8	6.1	86.5	2,714,481.1	1,347.9	1.0	0.5
11/02/2022 01:00	7.2	13.7	5.9	99.4	3,236,009.4	1,630.5	1.0	0.7
11/02/2022 02:00	7.2	13.7	5.9	104.0	3,371,761.0	1,698.9	1.0	0.7
11/02/2022 03:00	7.5	13.8	6.2	87.0	2,676,927.0	1,348.8	1.0	0.5
11/02/2022 04:00	7.4	13.7	6.1	100.6	3,305,869.8	1,665.7	1.0	0.7
11/02/2022 05:00	7.7	13.4	6.1	110.7	3,530,709.2	1,907.9	1.0	0.8
11/02/2022 06:00	8.1	13.1	6.1	128.8	3,632,481.7	2,175.1	1.1	0.9
11/02/2022 07:00	8.3	13.2	6.4	121.6	3,611,053.8	2,135.9	1.1	0.9
11/02/2022 08:00	7.7	13.3	6.0	114.9	3,582,098.2	2,040.3	1.0	0.8
11/02/2022 09:00	7.0	13.6	5.7	100.7	3,393,989.3	1,710.1	0.9	0.5
11/02/2022 10:00	7.3	13.7	6.0	93.3	3,062,945.9	1,543.3	1.0	0.6
11/02/2022 11:00	7.2	13.7	5.9	98.7	3,319,167.2	1,672.4	0.9	0.5
11/02/2022 12:00	7.3	13.7	6.0	93.0	3,075,647.8	1,549.7	1.0	0.6
11/02/2022 13:00	7.3	13.7	6.0	93.0	3,081,998.7	1,552.9	1.0	0.6
11/02/2022 14:00	7.3	13.7	6.0	92.3	3,046,870.0	1,535.2	1.0	0.6
11/02/2022 15:00	7.8	13.7	6.4	96.3	3,183,415.5	1,604.0	0.9	0.5
11/02/2022 16:00	8.6	13.2	6.6	127.4	3,537,848.7	2,092.6	1.2	1.0
11/02/2022 17:00	8.4	13.1	6.4	132.8	3,558,547.1	2,182.8	1.2	1.1
11/02/2022 18:00	8.2	13.1	6.2	132.3	3,549,580.6	2,177.3	1.2	1.1
11/02/2022 19:00	8.1	13.1	6.1	131.3	3,545,831.0	2,175.0	1.2	1.1
11/02/2022 20:00	8.1	13.1	6.1	131.8	3,588,716.8	2,175.1	1.2	1.1
11/02/2022 21:00	8.0	13.1	6.1	129.2	3,559,843.4	2,157.6	1.2	1.1
11/02/2022 22:00	8.0	13.1	6.1	128.6	3,570,732.8	2,164.2	1.2	1.1
11/02/2022 23:00	8.0	13.1	6.1	130.7	3,592,676.6	2,177.5	1.2	1.1
Average/Sum#:	7.7	13.4	6.1	111.0	3,347,050.1	1,850.9	1.1	0.8
Minimum:	7.0	13.1	5.7	86.5	2,676,927.0	1,347.9	0.9	0.5
Maximum:	8.6	13.8	6.6	132.8	3,632,481.7	2,182.8	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/03/2022 00:00	8.1	13.1	6.1	130.2	3,578,652.4	2,169.0	1.2	1.1
11/03/2022 01:00	8.0	13.2	6.1	128.6	3,595,574.0	2,153.0	1.2	1.1
11/03/2022 02:00	8.1	13.1	6.1	136.6	3,577,295.1	2,194.3	1.2	1.1
11/03/2022 03:00	8.2	13.1	6.2	144.9	3,557,477.9	2,234.1	1.3	1.1
11/03/2022 04:00	8.1	13.2	6.2	131.7	3,570,237.9	2,163.9	1.2	1.1
11/03/2022 05:00	8.1	13.2	6.2	131.9	3,573,702.7	2,166.0	1.2	1.1
11/03/2022 06:00	8.2	13.1	6.2	149.6	3,594,658.5	2,231.2	1.4	1.1
11/03/2022 07:00	8.5	13.2	6.5	126.2	3,568,787.6	2,110.9	1.1	0.8
11/03/2022 08:00	7.1	13.8	5.9	88.6	2,932,582.0	1,456.2	1.0	0.6
11/03/2022 09:00	7.2	13.7	5.9	92.4	3,094,899.1	1,559.4	0.9	0.5
11/03/2022 10:00	7.3	13.7	6.0	94.0	3,124,272.3	1,574.2	0.9	0.5
11/03/2022 11:00	7.3	13.7	6.0	94.0	3,116,333.6	1,570.2	1.0	0.6
11/03/2022 12:00	7.3	13.7	6.0	94.4	3,133,798.7	1,579.0	0.9	0.5
11/03/2022 13:00	7.3	13.8	6.1	89.7	2,995,414.5	1,487.4	0.9	0.4
11/03/2022 14:00	7.2	13.8	6.0	92.3	3,128,127.8	1,553.3	0.9	0.5
11/03/2022 15:00	7.7	13.7	6.3	105.1	3,516,443.7	1,771.8	0.9	0.5
11/03/2022 16:00	8.9	13.2	6.8	131.7	3,523,478.2	2,084.1	1.2	1.0
11/03/2022 17:00	8.6	13.1	6.5	142.2	3,525,452.7	2,162.5	1.3	1.1
11/03/2022 18:00	8.5	13.1	6.4	146.9	3,546,646.1	2,175.5	1.3	1.1
11/03/2022 19:00	8.5	13.1	6.4	146.7	3,544,526.8	2,174.2	1.3	1.1
11/03/2022 20:00	8.5	13.1	6.4	147.3	3,526,919.9	2,163.4	1.4	1.1
11/03/2022 21:00	8.6	13.1	6.5	151.2	3,524,474.5	2,161.9	1.4	1.1
11/03/2022 22:00	8.6	13.1	6.5	147.4	3,523,985.4	2,161.6	1.4	1.1
11/03/2022 23:00	8.5	13.1	6.4	149.3	3,546,325.8	2,201.2	1.4	1.1
Average/Sum#:	8.0	13.3	6.2	124.7	3,413,336.1	1,969.1	1.2	0.9
Minimum:	7.1	13.1	5.9	88.6	2,932,582.0	1,456.2	0.9	0.4
Maximum:	8.9	13.8	6.8	151.2	3,595,574.0	2,234.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/04/2022 00:00	8.1	13.1	6.1	136.2	3,572,861.6	2,139.4	1.2	1.1
11/04/2022 01:00	8.2	13.1	6.2	133.0	3,540,463.0	2,120.0	1.2	1.1
11/04/2022 02:00	8.1	13.2	6.2	127.4	3,541,845.0	2,069.1	1.2	1.0
11/04/2022 03:00	8.1	13.2	6.2	128.3	3,545,268.6	2,071.1	1.2	1.0
11/04/2022 04:00	8.2	13.1	6.2	136.9	3,589,895.9	2,149.6	1.2	1.1
11/04/2022 05:00	8.4	13.0	6.3	152.7	3,570,216.8	2,242.1	1.4	1.1
11/04/2022 06:00	8.2	13.1	6.2	141.7	3,592,016.7	2,177.1	1.3	1.1
11/04/2022 07:00	8.0	13.3	6.2	125.9	3,570,730.7	2,059.9	1.1	0.8
11/04/2022 08:00	6.9	13.7	5.7	100.9	3,410,263.7	1,718.3	0.9	0.5
11/04/2022 09:00	7.1	13.7	5.8	93.1	3,080,609.5	1,552.2	1.0	0.6
11/04/2022 10:00	7.1	13.8	5.9	82.7	2,800,472.9	1,390.6	0.9	0.4
11/04/2022 11:00	7.5	13.8	6.2	83.1	2,657,086.1	1,319.4	1.0	0.5
11/04/2022 12:00	7.6	13.8	6.3	83.3	2,651,850.0	1,316.8	1.0	0.5
11/04/2022 13:00	7.6	13.8	6.3	83.3	2,653,461.1	1,317.6	1.0	0.5
11/04/2022 14:00	7.5	13.8	6.2	85.3	2,815,979.6	1,398.3	1.0	0.6
11/04/2022 15:00	8.1	13.6	6.5	99.3	3,186,846.2	1,629.0	1.0	0.7
11/04/2022 16:00	8.9	13.2	6.8	132.1	3,515,579.6	2,105.1	1.2	1.1
11/04/2022 17:00	8.7	13.1	6.6	142.7	3,497,738.1	2,145.5	1.3	1.1
11/04/2022 18:00	8.4	13.2	6.4	134.7	3,532,438.7	2,089.4	1.2	1.0
11/04/2022 19:00	8.3	13.2	6.4	130.7	3,527,873.9	2,086.7	1.2	1.0
11/04/2022 20:00	8.3	13.2	6.4	131.6	3,509,953.0	2,076.1	1.2	1.0
11/04/2022 21:00	8.3	13.2	6.4	130.0	3,507,586.1	2,074.7	1.2	1.0
11/04/2022 22:00	8.3	13.2	6.4	129.6	3,520,942.2	2,082.6	1.2	1.0
11/04/2022 23:00	7.2	13.4	5.7	108.0	3,550,052.5	1,970.2	1.0	0.8
Average/Sum#:	8.0	13.4	6.2	118.0	3,330,918.0	1,887.5	1.1	0.9
Minimum:	6.9	13.0	5.7	82.7	2,651,850.0	1,316.8	0.9	0.4
Maximum:	8.9	13.8	6.8	152.7	3,592,016.7	2,242.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/05/2022 00:00	7.2	13.4	5.7	106.4	3,540,682.8	1,965.0	1.0	0.8
11/05/2022 01:00	7.3	13.4	5.7	106.8	3,541,403.5	1,965.4	1.0	0.8
11/05/2022 02:00	7.3	13.4	5.7	112.2	3,542,304.5	1,965.9	1.0	0.8
11/05/2022 03:00	7.3	13.4	5.7	107.2	3,540,863.0	1,965.1	1.0	0.8
11/05/2022 04:00	7.3	13.4	5.7	107.1	3,556,359.1	1,973.7	1.0	0.8
11/05/2022 05:00	7.4	13.4	5.8	107.8	3,565,008.1	1,978.5	1.0	0.8
11/05/2022 06:00	7.5	13.4	5.9	107.9	3,510,050.9	1,948.0	1.0	0.8
11/05/2022 07:00	12.5	17.8	23.8	157.0	1,556,213.9	568.2	3.2	0.7
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.0	14.0	8.0	114.1	3,294,110.7	1,791.2	1.3	0.8
Minimum:	7.2	13.4	5.7	106.4	1,556,213.9	568.2	1.0	0.7
Maximum:	12.5	17.8	23.8	157.0	3,565,008.1	1,978.5	3.2	0.8
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	28.2	17.6	50.4	0.0	1,313,633.0	259.0	-0.1	0.0
11/06/2022 10:00	34.8	17.1	54.0	159.9	1,488,759.9	380.5	3.3	0.5
11/06/2022 11:00	34.8	15.4	37.3	229.0	2,182,388.4	828.7	3.2	1.0
11/06/2022 12:00	7.3	13.7	6.0	89.1	2,781,916.2	1,401.7	1.0	0.6
11/06/2022 13:00	7.5	13.7	6.1	93.5	3,042,702.2	1,533.1	1.0	0.6
11/06/2022 14:00	8.3	13.6	6.7	106.7	3,143,220.2	1,606.7	1.1	0.6
11/06/2022 15:00	9.4	13.2	7.2	140.1	3,350,810.3	1,957.5	1.3	1.0
11/06/2022 16:00	9.7	12.9	7.2	188.0	3,441,468.8	2,286.9	1.8	1.6
11/06/2022 17:00	9.6	12.9	7.1	191.9	3,428,770.7	2,303.5	1.8	1.6
11/06/2022 18:00	8.8	13.2	6.7	124.3	3,441,363.5	2,010.4	1.2	1.0
11/06/2022 19:00	8.6	13.3	6.7	118.2	3,493,455.0	1,964.3	1.1	0.8
11/06/2022 20:00	8.7	13.2	6.7	123.2	3,492,207.7	1,989.1	1.1	0.8
11/06/2022 21:00	11.9	13.8	9.9	146.0	3,022,824.1	1,677.6	1.5	1.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.4	14.1	16.3	131.5	2,894,116.9	1,553.8	1.5	0.9
Minimum:	7.3	12.9	6.0	0.0	1,313,633.0	259.0	-0.1	0.0
Maximum:	34.8	17.6	54.0	229.0	3,493,455.0	2,303.5	3.3	1.6
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/07/2022 00:00	31.0	17.6	55.4	200.0	1,539,624.3	314.8	3.5	0.4
11/07/2022 01:00	31.0	14.9	30.5	205.6	2,478,658.1	1,013.6	2.5	1.0
11/07/2022 02:00	7.4	13.7	6.1	96.6	3,109,585.7	1,566.8	1.0	0.6
11/07/2022 03:00	7.5	13.7	6.1	97.4	3,214,971.8	1,619.9	1.0	0.6
11/07/2022 04:00	7.4	13.7	6.1	101.1	3,327,304.3	1,676.5	1.0	0.7
11/07/2022 05:00	7.9	13.6	6.4	101.9	3,342,178.0	1,708.4	1.0	0.7
11/07/2022 06:00	8.3	13.3	6.4	117.9	3,437,939.9	2,008.4	1.1	0.8
11/07/2022 07:00	9.1	13.0	6.8	147.2	3,524,300.2	2,239.0	1.4	1.1
11/07/2022 08:00	8.1	13.3	6.3	113.5	3,543,430.1	1,992.4	1.0	0.8
11/07/2022 09:00	8.0	13.3	6.2	111.7	3,513,018.2	1,975.3	1.0	0.8
11/07/2022 10:00	8.4	13.3	6.5	115.3	3,494,166.3	1,964.7	1.0	0.8
11/07/2022 11:00	8.4	13.3	6.5	115.0	3,490,431.6	1,962.6	1.0	0.8
11/07/2022 12:00	8.4	13.3	6.5	115.0	3,492,565.7	1,963.8	1.0	0.8
11/07/2022 13:00	7.9	13.3	6.1	110.8	3,490,609.4	1,962.7	1.0	0.8
11/07/2022 14:00	8.3	13.1	6.3	121.1	3,483,409.9	2,060.4	1.1	0.8
11/07/2022 15:00	8.6	13.0	6.4	145.1	3,491,236.0	2,192.5	1.4	1.1
11/07/2022 16:00	8.8	12.9	6.5	156.0	3,462,181.8	2,250.1	1.5	1.4
11/07/2022 17:00	8.7	12.8	6.3	161.4	3,485,793.7	2,290.9	1.5	1.4
11/07/2022 18:00	8.7	12.8	6.3	161.3	3,495,075.3	2,297.0	1.5	1.4
11/07/2022 19:00	8.6	12.8	6.3	159.4	3,490,054.1	2,293.7	1.5	1.4
11/07/2022 20:00	8.6	12.8	6.3	154.9	3,483,663.5	2,289.5	1.5	1.4
11/07/2022 21:00	8.6	12.8	6.3	157.5	3,489,597.6	2,293.4	1.5	1.4
11/07/2022 22:00	8.4	12.9	6.2	147.6	3,513,351.6	2,257.7	1.4	1.1
11/07/2022 23:00	8.3	13.0	6.2	134.5	3,513,781.9	2,181.0	1.2	1.1
Average/Sum#:	10.2	13.4	9.4	135.3	3,329,455.4	1,932.3	1.4	1.0
Minimum:	7.4	12.8	6.1	96.6	1,539,624.3	314.8	1.0	0.4
Maximum:	31.0	17.6	55.4	205.6	3,543,430.1	2,297.0	3.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/08/2022 00:00	8.3	13.0	6.2	133.1	3,500,248.7	2,172.6	1.2	1.1
11/08/2022 01:00	8.3	13.0	6.2	131.4	3,533,604.0	2,167.5	1.2	1.1
11/08/2022 02:00	8.1	13.1	6.1	124.9	3,484,937.6	2,112.2	1.2	1.1
11/08/2022 03:00	8.3	13.0	6.2	130.0	3,522,844.2	2,160.9	1.2	1.1
11/08/2022 04:00	8.4	12.9	6.2	136.8	3,503,337.9	2,200.1	1.3	1.1
11/08/2022 05:00	8.4	12.9	6.2	140.9	3,493,921.0	2,219.7	1.3	1.1
11/08/2022 06:00	8.6	12.8	6.3	161.0	3,461,934.9	2,300.5	1.5	1.4
11/08/2022 07:00	8.8	12.9	6.5	140.5	3,484,319.3	2,213.6	1.3	1.1
11/08/2022 08:00	8.5	12.9	6.3	138.8	3,466,532.6	2,202.3	1.3	1.1
11/08/2022 09:00	8.4	12.9	6.2	139.5	3,463,541.9	2,200.4	1.3	1.1
11/08/2022 10:00	8.3	13.0	6.2	134.7	3,480,248.8	2,185.6	1.3	1.1
11/08/2022 11:00	7.7	13.2	5.9	115.0	3,523,580.9	2,032.7	1.0	0.8
11/08/2022 12:00	7.7	13.3	6.0	109.1	3,534,182.0	1,987.2	1.0	0.8
11/08/2022 13:00	7.5	13.3	5.8	108.3	3,530,447.2	1,985.1	1.0	0.8
11/08/2022 14:00	7.9	13.2	6.1	117.5	3,519,763.0	2,056.2	1.1	0.8
11/08/2022 15:00	7.9	13.2	6.1	117.3	3,519,934.2	2,056.3	1.1	0.8
11/08/2022 16:00	8.4	12.9	6.2	143.9	3,530,407.9	2,217.1	1.3	1.1
11/08/2022 17:00	8.2	13.0	6.1	136.3	3,505,726.4	2,201.6	1.3	1.1
11/08/2022 18:00	8.2	13.0	6.1	131.5	3,502,343.1	2,173.9	1.2	1.1
11/08/2022 19:00	8.3	13.0	6.2	139.3	3,513,369.7	2,206.4	1.3	1.1
11/08/2022 20:00	8.3	12.9	6.1	140.3	3,513,051.3	2,206.2	1.3	1.1
11/08/2022 21:00	8.3	12.9	6.1	140.7	3,510,344.2	2,204.5	1.3	1.1
11/08/2022 22:00	8.2	13.0	6.1	137.8	3,487,892.1	2,190.4	1.3	1.1
11/08/2022 23:00	8.1	13.0	6.0	130.0	3,499,042.3	2,146.3	1.2	1.1
Average/Sum#:	8.2	13.0	6.1	132.4	3,503,564.8	2,158.3	1.2	1.1
Minimum:	7.5	12.8	5.8	108.3	3,461,934.9	1,985.1	1.0	0.8
Maximum:	8.8	13.3	6.5	161.0	3,534,182.0	2,300.5	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/09/2022 00:00	8.1	13.0	6.0	131.2	3,513,714.7	2,155.3	1.2	1.1
11/09/2022 01:00	8.1	13.0	6.0	131.0	3,512,410.5	2,154.5	1.2	1.1
11/09/2022 02:00	8.2	13.0	6.1	136.7	3,534,726.0	2,194.0	1.3	1.1
11/09/2022 03:00	8.1	13.0	6.0	137.4	3,536,498.2	2,195.1	1.3	1.1
11/09/2022 04:00	8.1	13.0	6.0	130.4	3,524,800.5	2,162.1	1.2	1.1
11/09/2022 05:00	8.3	12.9	6.1	149.6	3,554,207.2	2,258.0	1.4	1.1
11/09/2022 06:00	8.4	12.9	6.2	167.2	3,537,115.5	2,298.8	1.6	1.4
11/09/2022 07:00	8.6	13.0	6.4	140.7	3,550,514.7	2,203.8	1.3	1.1
11/09/2022 08:00	8.2	13.1	6.2	135.3	3,525,615.7	2,162.6	1.2	1.1
11/09/2022 09:00	7.0	13.6	5.7	102.7	3,361,647.5	1,742.9	1.0	0.7
11/09/2022 10:00	7.1	13.7	5.8	101.1	3,327,701.3	1,701.0	1.0	0.7
11/09/2022 11:00	7.3	13.7	6.0	97.8	3,186,454.9	1,628.8	1.0	0.7
11/09/2022 12:00	7.2	13.7	5.9	101.7	3,334,548.4	1,704.5	1.0	0.7
11/09/2022 13:00	7.3	13.7	6.0	97.3	3,209,414.7	1,617.1	1.0	0.6
11/09/2022 14:00	7.2	13.7	5.9	100.7	3,303,247.2	1,688.5	1.0	0.7
11/09/2022 15:00	7.4	13.7	6.1	97.9	3,202,105.5	1,636.8	1.0	0.7
11/09/2022 16:00	8.4	13.2	6.4	124.7	3,522,294.8	2,083.4	1.1	0.8
11/09/2022 17:00	8.5	13.0	6.3	134.8	3,518,931.6	2,158.5	1.2	1.1
11/09/2022 18:00	7.5	13.3	5.8	114.5	3,535,397.3	2,013.7	1.0	0.8
11/09/2022 19:00	7.2	13.4	5.7	106.9	3,561,044.0	1,976.3	1.0	0.8
11/09/2022 20:00	7.3	13.4	5.7	107.4	3,567,530.7	1,979.9	1.0	0.8
11/09/2022 21:00	7.4	13.4	5.8	110.6	3,611,316.3	2,004.2	1.0	0.8
11/09/2022 22:00	7.3	13.4	5.7	107.4	3,596,721.1	1,996.1	1.0	0.8
11/09/2022 23:00	7.3	13.4	5.7	107.6	3,595,639.9	1,995.5	1.0	0.8
Average/Sum#:	7.7	13.3	6.0	119.7	3,467,649.9	1,988.0	1.1	0.9
Minimum:	7.0	12.9	5.7	97.3	3,186,454.9	1,617.1	1.0	0.6
Maximum:	8.6	13.7	6.4	167.2	3,611,316.3	2,298.8	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/10/2022 00:00	7.3	13.4	5.7	107.7	3,594,739.0	1,995.0	1.0	0.8
11/10/2022 01:00	7.3	13.4	5.7	107.7	3,591,675.8	1,993.3	1.0	0.8
11/10/2022 02:00	7.3	13.4	5.7	107.6	3,588,072.1	1,991.3	1.0	0.8
11/10/2022 03:00	7.3	13.4	5.7	107.6	3,593,297.5	1,994.2	1.0	0.8
11/10/2022 04:00	8.0	13.2	6.1	120.4	3,612,853.5	2,084.2	1.1	0.8
11/10/2022 05:00	8.3	13.1	6.3	137.7	3,591,191.7	2,176.6	1.2	1.1
11/10/2022 06:00	8.6	12.9	6.3	157.4	3,530,653.0	2,294.6	1.5	1.4
11/10/2022 07:00	8.3	13.2	6.4	134.2	3,585,017.8	2,120.5	1.2	1.1
11/10/2022 08:00	7.3	13.4	5.7	107.4	3,574,558.0	1,983.8	1.0	0.8
11/10/2022 09:00	7.3	13.4	5.7	107.0	3,542,304.5	1,965.9	1.0	0.8
11/10/2022 10:00	7.0	13.7	5.7	101.4	3,424,354.8	1,725.4	0.9	0.5
11/10/2022 11:00	7.2	13.7	5.9	101.7	3,398,752.5	1,712.5	0.9	0.5
11/10/2022 12:00	7.2	13.7	5.9	101.7	3,396,172.5	1,711.2	0.9	0.5
11/10/2022 13:00	7.2	13.7	5.9	94.1	3,101,647.0	1,562.8	1.0	0.6
11/10/2022 14:00	7.3	13.7	6.0	101.6	3,398,951.0	1,712.6	0.9	0.5
11/10/2022 15:00	7.5	13.6	6.1	102.3	3,357,241.7	1,716.1	1.0	0.7
11/10/2022 16:00	8.7	13.1	6.6	129.7	3,570,189.6	2,137.8	1.2	1.1
11/10/2022 17:00	8.8	12.9	6.5	155.4	3,576,086.5	2,271.9	1.4	1.1
11/10/2022 18:00	8.7	12.9	6.4	159.1	3,580,179.0	2,274.5	1.5	1.4
11/10/2022 19:00	8.6	12.9	6.3	160.0	3,585,530.8	2,277.9	1.5	1.4
11/10/2022 20:00	8.6	12.9	6.3	157.9	3,588,678.9	2,279.9	1.4	1.1
11/10/2022 21:00	8.6	12.9	6.3	156.9	3,590,567.8	2,281.1	1.4	1.1
11/10/2022 22:00	8.6	13.0	6.4	157.7	3,591,669.6	2,281.8	1.4	1.1
11/10/2022 23:00	8.6	13.0	6.4	155.0	3,599,516.1	2,260.5	1.4	1.1
Average/Sum#:	7.9	13.3	6.1	126.2	3,523,495.9	2,033.6	1.2	0.9
Minimum:	7.0	12.9	5.7	94.1	3,101,647.0	1,562.8	0.9	0.5
Maximum:	8.8	13.7	6.6	160.0	3,612,853.5	2,294.6	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/11/2022 00:00	8.6	13.0	6.4	158.9	3,590,410.4	2,281.0	1.4	1.1
11/11/2022 01:00	8.5	13.0	6.3	152.8	3,573,725.4	2,270.4	1.4	1.1
11/11/2022 02:00	8.2	13.1	6.2	132.1	3,597,244.1	2,154.0	1.2	1.1
11/11/2022 03:00	8.2	13.1	6.2	129.5	3,593,403.0	2,151.7	1.2	1.1
11/11/2022 04:00	8.5	13.0	6.3	152.9	3,618,465.1	2,272.4	1.4	1.1
11/11/2022 05:00	8.4	13.0	6.3	152.6	3,597,965.8	2,285.8	1.4	1.1
11/11/2022 06:00	8.3	13.0	6.2	151.7	3,644,898.2	2,289.0	1.4	1.1
11/11/2022 07:00	8.2	13.2	6.3	127.7	3,627,605.2	2,119.2	1.1	0.8
11/11/2022 08:00	7.2	13.4	5.7	106.6	3,569,267.7	1,954.8	1.0	0.8
11/11/2022 09:00	7.0	13.7	5.7	100.7	3,391,210.8	1,708.7	0.9	0.5
11/11/2022 10:00	7.1	13.7	5.8	101.5	3,398,554.1	1,712.4	0.9	0.5
11/11/2022 11:00	7.2	13.7	5.9	100.6	3,342,387.8	1,684.1	1.0	0.7
11/11/2022 12:00	7.3	13.7	6.0	100.9	3,343,380.2	1,684.6	1.0	0.7
11/11/2022 13:00	7.3	13.7	6.0	101.5	3,363,822.3	1,694.9	1.0	0.7
11/11/2022 14:00	7.3	13.7	6.0	95.2	3,122,089.1	1,573.1	1.0	0.6
11/11/2022 15:00	7.6	13.7	6.2	100.7	3,348,540.3	1,687.2	0.9	0.5
11/11/2022 16:00	8.5	13.3	6.6	119.8	3,484,658.4	1,984.8	1.1	0.8
11/11/2022 17:00	8.9	12.9	6.6	155.8	3,529,847.0	2,268.3	1.4	1.1
11/11/2022 18:00	8.7	12.9	6.4	157.5	3,522,066.1	2,263.3	1.5	1.4
11/11/2022 19:00	8.6	12.9	6.3	157.2	3,558,299.7	2,260.6	1.4	1.1
11/11/2022 20:00	8.5	13.0	6.3	157.0	3,547,438.8	2,253.7	1.4	1.1
11/11/2022 21:00	8.5	13.0	6.3	156.0	3,546,179.5	2,252.9	1.4	1.1
11/11/2022 22:00	8.5	13.0	6.3	151.4	3,576,426.9	2,246.0	1.4	1.1
11/11/2022 23:00	8.5	13.0	6.3	152.6	3,556,883.1	2,259.7	1.4	1.1
Average/Sum#:	8.1	13.2	6.2	132.2	3,501,865.4	2,054.7	1.2	0.9
Minimum:	7.0	12.9	5.7	95.2	3,122,089.1	1,573.1	0.9	0.5
Maximum:	8.9	13.7	6.6	158.9	3,644,898.2	2,289.0	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/12/2022 00:00	8.3	13.0	6.2	146.6	3,609,866.4	2,267.0	1.3	1.1
11/12/2022 01:00	8.3	12.9	6.1	147.4	3,623,560.6	2,275.6	1.3	1.1
11/12/2022 02:00	8.3	12.9	6.1	148.3	3,586,947.5	2,278.8	1.3	1.1
11/12/2022 03:00	8.3	12.9	6.1	149.1	3,589,465.9	2,280.4	1.4	1.1
11/12/2022 04:00	8.4	12.9	6.2	150.7	3,596,706.6	2,285.0	1.4	1.1
11/12/2022 05:00	8.4	12.9	6.2	149.4	3,597,178.8	2,285.3	1.4	1.1
11/12/2022 06:00	8.4	12.9	6.2	151.9	3,583,641.9	2,276.7	1.4	1.1
11/12/2022 07:00	8.6	13.2	6.6	130.8	3,556,276.8	2,103.5	1.2	1.1
11/12/2022 08:00	8.7	13.0	6.5	146.8	3,520,216.8	2,210.7	1.4	1.1
11/12/2022 09:00	6.9	13.6	5.6	102.9	3,370,905.6	1,747.7	1.0	0.7
11/12/2022 10:00	7.2	13.7	5.9	95.4	3,154,836.2	1,589.6	1.0	0.6
11/12/2022 11:00	7.3	13.7	6.0	93.5	3,084,777.3	1,554.3	1.0	0.6
11/12/2022 12:00	7.3	13.7	6.0	93.2	3,078,426.3	1,551.1	1.0	0.6
11/12/2022 13:00	7.4	13.7	6.1	94.5	3,116,333.6	1,570.2	1.0	0.6
11/12/2022 14:00	7.3	13.7	6.0	93.1	3,074,258.5	1,549.0	1.0	0.6
11/12/2022 15:00	7.7	13.6	6.2	106.3	3,504,748.3	1,791.5	1.0	0.7
11/12/2022 16:00	8.8	13.1	6.7	131.0	3,551,652.2	2,126.7	1.2	1.1
11/12/2022 17:00	8.9	12.9	6.6	152.2	3,535,161.2	2,245.9	1.4	1.1
11/12/2022 18:00	8.8	12.9	6.5	153.8	3,536,577.8	2,246.8	1.4	1.1
11/12/2022 19:00	8.7	12.9	6.4	155.5	3,543,503.6	2,251.2	1.4	1.1
11/12/2022 20:00	8.7	12.9	6.4	153.8	3,557,984.9	2,260.4	1.4	1.1
11/12/2022 21:00	8.8	12.9	6.5	156.6	3,557,040.5	2,259.8	1.4	1.1
11/12/2022 22:00	8.6	13.0	6.4	141.5	3,575,990.9	2,193.5	1.3	1.1
11/12/2022 23:00	8.6	13.0	6.4	141.8	3,571,263.2	2,190.6	1.3	1.1
Average/Sum#:	8.2	13.2	6.2	132.8	3,461,555.1	2,058.0	1.2	1.0
Minimum:	6.9	12.9	5.6	93.1	3,074,258.5	1,549.0	1.0	0.6
Maximum:	8.9	13.7	6.7	156.6	3,623,560.6	2,285.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/13/2022 00:00	8.4	13.0	6.3	136.4	3,598,121.3	2,180.8	1.2	1.1
11/13/2022 01:00	8.4	13.0	6.3	134.5	3,580,302.3	2,170.0	1.2	1.1
11/13/2022 02:00	8.4	13.0	6.3	135.3	3,615,614.4	2,165.0	1.2	1.1
11/13/2022 03:00	8.6	13.0	6.4	141.0	3,577,621.2	2,194.5	1.3	1.1
11/13/2022 04:00	8.5	13.0	6.3	139.8	3,612,805.5	2,189.7	1.3	1.1
11/13/2022 05:00	8.4	13.0	6.3	136.9	3,603,566.0	2,184.1	1.2	1.1
11/13/2022 06:00	8.6	13.0	6.4	141.4	3,578,436.3	2,195.0	1.3	1.1
11/13/2022 07:00	9.2	12.9	6.8	154.4	3,609,158.2	2,240.2	1.4	1.1
11/13/2022 08:00	8.0	13.3	6.2	125.1	3,452,354.0	1,966.4	1.2	1.0
11/13/2022 09:00	7.0	13.7	5.7	100.8	3,386,844.5	1,706.5	0.9	0.5
11/13/2022 10:00	7.1	13.7	5.8	101.3	3,389,623.1	1,707.9	0.9	0.5
11/13/2022 11:00	7.1	13.7	5.8	101.6	3,389,623.1	1,707.9	0.9	0.5
11/13/2022 12:00	7.2	13.7	5.9	101.5	3,387,439.9	1,706.8	0.9	0.5
11/13/2022 13:00	7.2	13.7	5.9	101.6	3,392,798.5	1,709.5	0.9	0.5
11/13/2022 14:00	7.2	13.7	5.9	99.9	3,329,685.9	1,677.7	0.9	0.5
11/13/2022 15:00	7.9	13.6	6.4	107.4	3,487,728.3	1,782.8	1.0	0.7
11/13/2022 16:00	9.0	13.1	6.8	140.4	3,486,815.3	2,138.8	1.3	1.1
11/13/2022 17:00	8.9	12.9	6.6	174.9	3,469,360.6	2,280.1	1.7	1.6
11/13/2022 18:00	8.8	12.9	6.5	176.0	3,469,969.2	2,280.5	1.7	1.6
11/13/2022 19:00	8.8	12.9	6.5	175.2	3,475,903.4	2,284.4	1.7	1.6
11/13/2022 20:00	8.8	12.9	6.5	177.3	3,481,685.4	2,288.2	1.7	1.6
11/13/2022 21:00	8.8	12.9	6.5	177.6	3,488,684.7	2,292.8	1.7	1.6
11/13/2022 22:00	8.8	12.9	6.5	179.1	3,492,184.3	2,295.1	1.7	1.6
11/13/2022 23:00	8.8	12.9	6.5	179.0	3,498,575.0	2,299.3	1.7	1.6
Average/Sum#:	8.2	13.2	6.3	139.1	3,493,954.2	2,068.5	1.3	1.1
Minimum:	7.0	12.9	5.7	99.9	3,329,685.9	1,677.7	0.9	0.5
Maximum:	9.2	13.7	6.8	179.1	3,615,614.4	2,299.3	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/14/2022 00:00	8.7	12.9	6.4	171.6	3,497,357.7	2,298.5	1.6	1.4
11/14/2022 01:00	8.6	12.9	6.3	162.9	3,522,805.8	2,289.5	1.5	1.4
11/14/2022 02:00	8.5	12.9	6.3	160.1	3,557,702.3	2,286.2	1.5	1.4
11/14/2022 03:00	8.2	13.1	6.2	135.5	3,574,857.6	2,166.7	1.2	1.1
11/14/2022 04:00	8.4	13.0	6.3	150.2	3,569,261.3	2,241.5	1.4	1.1
11/14/2022 05:00	8.5	12.9	6.3	161.7	3,543,885.7	2,303.2	1.5	1.4
11/14/2022 06:00	8.4	12.9	6.2	162.2	3,578,243.7	2,299.4	1.5	1.4
11/14/2022 07:00	8.6	13.1	6.5	138.7	3,577,947.3	2,194.7	1.3	1.1
11/14/2022 08:00	8.3	13.1	6.3	132.1	3,605,761.2	2,159.1	1.2	1.1
11/14/2022 09:00	8.3	13.1	6.3	136.0	3,576,507.5	2,167.7	1.2	1.1
11/14/2022 10:00	8.4	13.1	6.4	136.6	3,561,328.4	2,158.5	1.2	1.1
11/14/2022 11:00	8.4	13.1	6.4	137.0	3,514,635.9	2,130.2	1.3	1.1
11/14/2022 12:00	8.4	13.1	6.4	138.1	3,507,706.3	2,126.0	1.3	1.1
11/14/2022 13:00	8.5	13.1	6.4	145.4	3,512,084.5	2,154.3	1.3	1.1
11/14/2022 14:00	8.6	13.1	6.5	145.3	3,464,321.5	2,150.3	1.4	1.1
11/14/2022 15:00	8.3	13.2	6.4	134.2	3,516,039.4	2,079.7	1.2	1.0
11/14/2022 16:00	8.8	12.9	6.5	166.4	3,468,182.7	2,254.0	1.6	1.4
11/14/2022 17:00	8.5	13.0	6.3	152.7	3,500,153.2	2,198.1	1.4	1.1
11/14/2022 18:00	8.4	13.0	6.3	146.6	3,515,554.1	2,182.1	1.4	1.1
11/14/2022 19:00	8.6	13.0	6.4	158.8	3,487,208.1	2,240.9	1.5	1.3
11/14/2022 20:00	8.5	13.0	6.3	159.8	3,491,876.6	2,243.9	1.5	1.3
11/14/2022 21:00	8.6	12.9	6.3	171.2	3,520,497.7	2,288.0	1.6	1.4
11/14/2022 22:00	8.6	12.9	6.3	168.9	3,521,574.8	2,288.7	1.6	1.4
11/14/2022 23:00	8.5	12.9	6.3	165.9	3,534,048.6	2,271.0	1.5	1.4
Average/Sum#:	8.5	13.0	6.3	151.6	3,529,980.9	2,215.5	1.4	1.2
Minimum:	8.2	12.9	6.2	132.1	3,464,321.5	2,079.7	1.2	1.0
Maximum:	8.8	13.2	6.5	171.6	3,605,761.2	2,303.2	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/15/2022 00:00	8.7	12.9	6.4	175.6	3,540,962.2	2,301.3	1.6	1.4
11/15/2022 01:00	8.7	12.9	6.4	173.4	3,500,248.7	2,300.4	1.6	1.4
11/15/2022 02:00	8.7	12.9	6.4	170.5	3,524,806.0	2,290.8	1.6	1.4
11/15/2022 03:00	8.6	13.0	6.4	164.6	3,510,342.5	2,281.4	1.5	1.4
11/15/2022 04:00	8.6	13.0	6.4	160.0	3,523,933.5	2,264.5	1.5	1.4
11/15/2022 05:00	8.6	13.0	6.4	155.7	3,530,596.4	2,243.0	1.4	1.1
11/15/2022 06:00	8.5	13.0	6.3	162.3	3,523,879.3	2,213.0	1.5	1.3
11/15/2022 07:00	9.0	13.1	6.8	143.7	3,517,487.4	2,183.3	1.3	1.1
11/15/2022 08:00	8.6	13.1	6.5	140.9	3,519,915.6	2,133.4	1.3	1.1
11/15/2022 09:00	8.7	13.2	6.7	144.4	3,521,257.7	2,108.5	1.3	1.1
11/15/2022 10:00	8.7	13.1	6.6	143.9	3,533,774.9	2,141.8	1.3	1.1
11/15/2022 11:00	7.9	13.2	6.1	121.2	3,520,790.1	2,056.8	1.1	0.8
11/15/2022 12:00	7.5	13.4	5.9	107.8	3,563,927.0	1,977.9	1.0	0.8
11/15/2022 13:00	7.5	13.3	5.8	106.4	3,566,269.4	1,979.2	1.0	0.8
11/15/2022 14:00	7.6	13.3	5.9	109.8	3,566,269.4	1,979.2	1.0	0.8
11/15/2022 15:00	7.9	13.2	6.1	113.6	3,543,648.9	2,018.4	1.0	0.8
11/15/2022 16:00	8.5	13.0	6.3	132.5	3,546,149.2	2,149.3	1.2	1.1
11/15/2022 17:00	8.4	13.0	6.3	136.7	3,550,232.7	2,177.7	1.2	1.1
11/15/2022 18:00	8.4	13.0	6.3	137.5	3,534,242.7	2,193.7	1.3	1.1
11/15/2022 19:00	8.5	13.0	6.3	147.1	3,525,703.9	2,188.4	1.4	1.1
11/15/2022 20:00	8.9	13.1	6.7	164.3	3,497,127.7	2,196.2	1.5	1.3
11/15/2022 21:00	8.8	13.0	6.6	170.5	3,492,032.2	2,244.0	1.6	1.3
11/15/2022 22:00	8.6	13.1	6.5	156.3	3,503,632.0	2,174.7	1.5	1.3
11/15/2022 23:00	8.6	13.1	6.5	151.3	3,544,526.8	2,174.2	1.4	1.1
Average/Sum#:	8.4	13.1	6.4	145.4	3,529,239.8	2,165.5	1.3	1.1
Minimum:	7.5	12.9	5.8	106.4	3,492,032.2	1,977.9	1.0	0.8
Maximum:	9.0	13.4	6.8	175.6	3,566,269.4	2,301.3	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/16/2022 00:00	8.6	13.1	6.5	153.7	3,534,419.1	2,168.0	1.4	1.1
11/16/2022 01:00	8.5	13.1	6.4	146.8	3,532,125.0	2,140.8	1.4	1.1
11/16/2022 02:00	8.6	13.1	6.5	149.8	3,530,669.5	2,165.7	1.4	1.1
11/16/2022 03:00	8.6	13.1	6.5	149.1	3,533,604.0	2,167.5	1.4	1.1
11/16/2022 04:00	8.6	13.1	6.5	149.5	3,510,076.4	2,178.7	1.4	1.1
11/16/2022 05:00	8.5	13.1	6.4	147.4	3,545,668.0	2,174.9	1.4	1.1
11/16/2022 06:00	8.4	13.1	6.4	147.6	3,534,419.1	2,168.0	1.4	1.1
11/16/2022 07:00	9.3	13.0	6.9	169.3	3,527,448.3	2,241.0	1.6	1.3
11/16/2022 08:00	7.7	13.4	6.1	115.4	3,533,826.3	1,987.0	1.0	0.8
11/16/2022 09:00	7.9	13.3	6.1	117.4	3,590,381.7	2,018.8	1.0	0.8
11/16/2022 10:00	7.5	13.4	5.9	108.5	3,577,260.8	1,985.3	1.0	0.8
11/16/2022 11:00	7.7	13.4	6.1	110.7	1,301,805.0	1,986.8	2.9	2.2
11/16/2022 12:00	7.9	13.4	6.2	113.9	3,531,870.0	1,985.9	1.0	0.8
11/16/2022 13:00	7.6	13.4	6.0	108.5	3,533,648.5	1,986.9	1.0	0.8
11/16/2022 14:00	7.4	13.3	5.7	107.7	3,530,980.7	1,985.4	1.0	0.8
11/16/2022 15:00	8.1	13.1	6.1	122.0	3,486,752.5	2,113.3	1.1	0.8
11/16/2022 16:00	8.3	13.0	6.2	127.0	3,466,873.0	2,177.2	1.2	1.1
11/16/2022 17:00	8.2	13.0	6.1	129.3	3,491,713.7	2,192.8	1.2	1.1
11/16/2022 18:00	8.4	12.9	6.2	145.0	3,466,773.9	2,278.4	1.4	1.1
11/16/2022 19:00	8.3	12.9	6.1	144.5	3,479,098.7	2,286.5	1.4	1.1
11/16/2022 20:00	8.2	12.9	6.0	142.5	3,479,403.0	2,286.7	1.3	1.1
11/16/2022 21:00	8.2	13.0	6.1	148.0	3,488,031.6	2,266.9	1.4	1.1
11/16/2022 22:00	8.1	13.0	6.0	139.4	3,511,550.4	2,230.9	1.3	1.1
11/16/2022 23:00	8.3	13.0	6.2	149.4	3,473,414.2	2,257.4	1.4	1.1
Average/Sum#:	8.2	13.1	6.2	135.1	3,516,956.9	2,143.0	1.3	1.0
Minimum:	7.4	12.9	5.7	107.7	3,466,773.9	1,985.3	1.0	0.8
Maximum:	9.3	13.4	6.9	169.3	3,590,381.7	2,286.7	1.6	1.3
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/17/2022 00:00	8.0	13.1	6.1	131.4	3,508,626.4	2,177.8	1.2	1.1
11/17/2022 01:00	8.1	13.1	6.1	133.6	3,472,923.9	2,181.0	1.2	1.1
11/17/2022 02:00	8.0	13.1	6.1	129.6	3,489,293.3	2,165.8	1.2	1.1
11/17/2022 03:00	8.0	13.1	6.1	128.4	3,531,158.6	2,166.0	1.2	1.1
11/17/2022 04:00	8.0	13.1	6.1	131.6	3,536,212.4	2,169.1	1.2	1.1
11/17/2022 05:00	8.0	13.1	6.1	146.4	3,515,070.7	2,181.8	1.4	1.1
11/17/2022 06:00	8.3	12.9	6.1	149.7	3,486,706.6	2,291.5	1.4	1.1
11/17/2022 07:00	8.5	13.1	6.4	134.6	3,515,554.1	2,182.1	1.2	1.1
11/17/2022 08:00	7.1	13.4	5.6	107.7	3,500,986.1	1,994.1	1.0	0.8
11/17/2022 09:00	8.2	13.1	6.2	129.6	3,506,378.5	2,150.8	1.2	1.1
11/17/2022 10:00	8.1	13.1	6.1	128.3	3,493,988.5	2,143.2	1.2	1.1
11/17/2022 11:00	8.2	13.1	6.2	135.9	3,462,732.9	2,174.6	1.3	1.1
11/17/2022 12:00	8.3	13.0	6.2	146.5	3,420,915.5	2,198.3	1.4	1.1
11/17/2022 13:00	8.4	13.0	6.3	145.8	3,437,570.0	2,183.9	1.4	1.1
11/17/2022 14:00	8.0	13.2	6.1	120.2	3,450,435.9	2,015.7	1.1	0.8
11/17/2022 15:00	8.5	13.1	6.4	140.6	3,432,583.0	2,130.6	1.3	1.1
11/17/2022 16:00	8.6	13.0	6.4	161.2	3,413,214.2	2,243.2	1.5	1.3
11/17/2022 17:00	8.5	12.9	6.3	164.1	3,426,420.2	2,276.9	1.6	1.4
11/17/2022 18:00	8.3	12.9	6.1	159.1	3,424,162.9	2,275.4	1.5	1.4
11/17/2022 19:00	8.3	12.9	6.1	156.8	3,428,978.5	2,278.6	1.5	1.4
11/17/2022 20:00	8.3	12.9	6.1	158.5	3,432,289.2	2,280.8	1.5	1.4
11/17/2022 21:00	8.3	12.9	6.1	159.7	3,434,847.4	2,282.5	1.5	1.4
11/17/2022 22:00	8.3	12.9	6.1	155.7	3,453,536.1	2,269.7	1.5	1.4
11/17/2022 23:00	8.0	13.0	6.0	140.4	3,505,254.2	2,226.9	1.3	1.1
Average/Sum#:	8.2	13.0	6.1	141.5	3,469,993.3	2,193.3	1.3	1.2
Minimum:	7.1	12.9	5.6	107.7	3,413,214.2	1,994.1	1.0	0.8
Maximum:	8.6	13.4	6.4	164.1	3,536,212.4	2,291.5	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/18/2022 00:00	8.0	13.1	6.1	130.9	3,508,465.3	2,177.7	1.2	1.1
11/18/2022 01:00	8.2	13.0	6.1	138.9	3,484,388.9	2,188.2	1.3	1.1
11/18/2022 02:00	8.2	13.0	6.1	141.1	3,453,940.1	2,194.3	1.3	1.1
11/18/2022 03:00	8.1	13.0	6.0	135.1	3,484,866.6	2,188.5	1.3	1.1
11/18/2022 04:00	8.2	13.0	6.1	140.0	3,440,245.9	2,185.6	1.3	1.1
11/18/2022 05:00	8.1	13.1	6.1	138.6	3,461,299.7	2,173.7	1.3	1.1
11/18/2022 06:00	8.0	13.1	6.1	138.7	3,480,271.2	2,160.2	1.3	1.1
11/18/2022 07:00	8.9	13.0	6.6	156.3	3,470,182.9	2,255.3	1.5	1.4
11/18/2022 08:00	8.4	13.1	6.4	139.6	3,467,669.2	2,177.7	1.3	1.1
11/18/2022 09:00	8.4	13.0	6.3	142.2	3,479,293.3	2,185.0	1.3	1.1
11/18/2022 10:00	8.5	13.0	6.3	149.2	3,447,801.3	2,190.4	1.4	1.1
11/18/2022 11:00	8.4	13.1	6.4	140.7	3,456,655.4	2,120.3	1.3	1.1
11/18/2022 12:00	8.2	13.3	6.4	117.0	3,459,025.5	1,970.2	1.1	0.8
11/18/2022 13:00	8.4	13.3	6.5	119.7	3,464,117.0	1,973.1	1.1	0.8
11/18/2022 14:00	8.4	13.3	6.5	121.4	3,466,574.9	1,974.5	1.1	0.8
11/18/2022 15:00	8.6	13.2	6.6	133.9	3,480,197.6	2,058.5	1.2	1.0
11/18/2022 16:00	8.7	13.0	6.5	156.6	3,438,947.8	2,235.0	1.5	1.3
11/18/2022 17:00	8.5	13.0	6.3	159.2	3,435,581.5	2,257.9	1.5	1.4
11/18/2022 18:00	8.4	13.0	6.3	160.3	3,478,030.2	2,260.4	1.5	1.4
11/18/2022 19:00	8.4	13.0	6.3	157.0	3,482,646.2	2,263.4	1.5	1.4
11/18/2022 20:00	8.3	13.0	6.2	144.4	3,467,289.2	2,228.1	1.4	1.1
11/18/2022 21:00	8.2	13.1	6.2	138.9	3,473,560.9	2,181.4	1.3	1.1
11/18/2022 22:00	8.0	13.1	6.1	138.8	3,496,923.0	2,145.0	1.3	1.1
11/18/2022 23:00	8.3	13.0	6.2	149.8	3,484,251.4	2,239.0	1.4	1.1
Average/Sum#:	8.3	13.1	6.3	141.2	3,469,259.4	2,166.0	1.3	1.1
Minimum:	8.0	13.0	6.0	117.0	3,435,581.5	1,970.2	1.1	0.8
Maximum:	8.9	13.3	6.6	160.3	3,508,465.3	2,263.4	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/19/2022 00:00	8.2	13.1	6.2	138.3	3,493,624.5	2,194.0	1.3	1.1
11/19/2022 01:00	8.1	13.1	6.1	134.5	3,499,926.5	2,172.4	1.2	1.1
11/19/2022 02:00	8.1	13.1	6.1	131.6	3,535,560.3	2,168.7	1.2	1.1
11/19/2022 03:00	8.1	13.1	6.1	128.6	3,538,724.6	2,144.8	1.2	1.1
11/19/2022 04:00	8.3	13.0	6.2	149.2	3,523,041.0	2,238.2	1.4	1.1
11/19/2022 05:00	8.3	13.0	6.2	152.3	3,534,982.3	2,271.6	1.4	1.1
11/19/2022 06:00	8.2	13.0	6.1	140.8	3,532,159.5	2,218.2	1.3	1.1
11/19/2022 07:00	8.2	13.2	6.3	129.7	3,517,605.8	2,132.0	1.2	1.1
11/19/2022 08:00	7.2	13.4	5.7	106.0	3,519,242.8	1,978.8	1.0	0.8
11/19/2022 09:00	7.5	13.4	5.9	107.7	3,519,242.8	1,978.8	1.0	0.8
11/19/2022 10:00	7.8	13.4	6.1	108.8	3,512,662.5	1,975.1	1.0	0.8
11/19/2022 11:00	8.0	13.4	6.3	110.9	3,504,659.3	1,970.6	1.0	0.8
11/19/2022 12:00	8.3	13.3	6.4	117.0	3,460,430.1	1,971.0	1.1	0.8
11/19/2022 13:00	8.4	13.3	6.5	120.9	3,462,010.2	1,971.9	1.1	0.8
11/19/2022 14:00	8.4	13.3	6.5	121.8	3,459,025.5	1,970.2	1.1	0.8
11/19/2022 15:00	8.7	13.2	6.7	136.7	3,467,348.7	2,050.9	1.3	1.0
11/19/2022 16:00	8.7	13.1	6.6	150.8	3,437,884.8	2,184.1	1.4	1.1
11/19/2022 17:00	8.6	13.0	6.4	152.5	3,426,362.1	2,201.8	1.5	1.3
11/19/2022 18:00	8.5	13.1	6.4	149.8	3,458,819.7	2,197.4	1.4	1.1
11/19/2022 19:00	8.6	13.0	6.4	163.2	3,439,841.9	2,260.7	1.6	1.4
11/19/2022 20:00	8.4	13.0	6.3	150.0	3,453,750.5	2,219.4	1.4	1.1
11/19/2022 21:00	8.1	13.1	6.1	138.9	3,467,350.7	2,177.5	1.3	1.1
11/19/2022 22:00	7.8	13.1	5.9	137.4	3,546,809.2	2,175.6	1.3	1.1
11/19/2022 23:00	7.8	13.1	5.9	137.9	3,537,074.7	2,143.8	1.3	1.1
Average/Sum#:	8.2	13.2	6.2	134.0	3,493,672.5	2,123.6	1.3	1.0
Minimum:	7.2	13.0	5.7	106.0	3,426,362.1	1,970.2	1.0	0.8
Maximum:	8.7	13.4	6.7	163.2	3,546,809.2	2,271.6	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/20/2022 00:00	7.7	13.2	5.9	131.0	3,518,585.7	2,106.9	1.2	1.1
11/20/2022 01:00	7.7	13.2	5.9	132.1	3,514,686.9	2,078.9	1.2	1.0
11/20/2022 02:00	7.7	13.2	5.9	135.3	3,530,204.9	2,062.3	1.2	1.0
11/20/2022 03:00	7.6	13.3	5.9	134.1	3,532,259.0	2,063.5	1.2	1.0
11/20/2022 04:00	7.6	13.3	5.9	134.2	3,544,241.5	2,070.5	1.2	1.0
11/20/2022 05:00	7.9	13.1	6.0	145.7	3,559,688.3	2,183.5	1.3	1.1
11/20/2022 06:00	8.1	13.0	6.0	142.1	3,543,230.0	2,276.9	1.3	1.1
11/20/2022 07:00	8.0	13.2	6.1	131.2	3,486,257.5	2,113.0	1.2	1.1
11/20/2022 08:00	6.5	13.7	5.3	97.9	3,333,179.0	1,703.8	0.9	0.5
11/20/2022 09:00	6.8	13.7	5.6	99.3	3,342,569.3	1,708.6	0.9	0.5
11/20/2022 10:00	6.8	13.8	5.7	92.3	3,062,619.8	1,565.5	0.9	0.5
11/20/2022 11:00	6.9	13.8	5.7	92.0	3,058,902.8	1,563.6	0.9	0.5
11/20/2022 12:00	6.9	13.8	5.7	90.2	3,043,297.6	1,533.4	0.9	0.5
11/20/2022 13:00	6.9	13.8	5.7	89.4	3,024,443.2	1,523.9	0.9	0.5
11/20/2022 14:00	6.9	13.7	5.7	98.7	3,281,218.0	1,701.2	0.9	0.5
11/20/2022 15:00	7.6	13.7	6.2	102.1	3,323,843.7	1,723.3	1.0	0.7
11/20/2022 16:00	9.0	13.1	6.8	143.0	3,483,654.5	2,162.3	1.3	1.1
11/20/2022 17:00	8.8	13.0	6.6	165.8	3,463,730.7	2,276.4	1.6	1.4
11/20/2022 18:00	8.5	13.0	6.3	158.4	3,447,602.0	2,265.8	1.5	1.4
11/20/2022 19:00	8.4	13.0	6.3	159.9	3,433,907.7	2,256.8	1.5	1.4
11/20/2022 20:00	8.3	13.0	6.2	156.2	3,440,298.4	2,261.0	1.5	1.4
11/20/2022 21:00	8.1	13.0	6.0	144.9	3,469,995.5	2,204.5	1.4	1.1
11/20/2022 22:00	8.0	13.1	6.1	132.3	3,493,321.0	2,168.3	1.2	1.1
11/20/2022 23:00	7.9	13.1	6.0	128.8	3,510,454.2	2,153.3	1.2	1.1
Average/Sum#:	7.7	13.3	6.0	126.5	3,393,424.6	1,988.6	1.2	0.9
Minimum:	6.5	13.0	5.3	89.4	3,024,443.2	1,523.9	0.9	0.5
Maximum:	9.0	13.8	6.8	165.8	3,559,688.3	2,276.9	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/21/2022 00:00	7.8	13.1	5.9	128.4	3,521,866.1	2,160.3	1.2	1.1
11/21/2022 01:00	7.7	13.1	5.8	120.3	3,526,680.3	2,137.5	1.1	0.9
11/21/2022 02:00	7.4	13.3	5.7	113.6	3,529,691.3	2,062.0	1.0	0.8
11/21/2022 03:00	8.1	13.1	6.1	132.9	3,503,148.7	2,174.4	1.2	1.1
11/21/2022 04:00	8.2	13.0	6.1	145.3	3,511,017.4	2,256.2	1.4	1.1
11/21/2022 05:00	8.0	13.0	6.0	143.8	3,527,979.6	2,267.1	1.3	1.1
11/21/2022 06:00	8.0	13.0	6.0	145.0	3,514,496.9	2,284.1	1.3	1.1
11/21/2022 07:00	8.1	13.2	6.2	131.8	3,505,726.4	2,150.4	1.2	1.1
11/21/2022 08:00	6.8	13.4	5.3	104.4	3,546,809.2	1,968.4	0.9	0.6
11/21/2022 09:00	6.9	13.4	5.4	104.9	3,547,349.7	1,968.7	0.9	0.6
11/21/2022 10:00	7.5	13.4	5.9	107.5	3,501,991.6	1,969.1	1.0	0.8
11/21/2022 11:00	7.8	13.4	6.1	109.4	3,519,598.5	1,979.0	1.0	0.8
11/21/2022 12:00	8.2	13.3	6.4	117.7	3,477,109.0	1,980.5	1.1	0.8
11/21/2022 13:00	8.3	13.3	6.4	118.6	3,476,757.8	1,980.3	1.1	0.8
11/21/2022 14:00	8.8	13.1	6.7	149.7	3,440,917.6	2,160.9	1.4	1.1
11/21/2022 15:00	8.9	12.9	6.6	170.7	3,425,691.2	2,251.4	1.6	1.4
11/21/2022 16:00	8.1	12.9	6.0	135.2	3,465,110.5	2,226.7	1.3	1.1
11/21/2022 17:00	8.2	12.9	6.0	141.2	3,459,013.8	2,273.3	1.3	1.1
11/21/2022 18:00	8.2	12.9	6.0	142.3	3,513,419.8	2,283.4	1.3	1.1
11/21/2022 19:00	8.4	13.0	6.3	154.3	3,446,536.9	2,265.1	1.5	1.4
11/21/2022 20:00	8.3	13.0	6.2	154.9	3,446,993.3	2,265.4	1.5	1.4
11/21/2022 21:00	8.3	13.0	6.2	153.9	3,450,645.1	2,267.8	1.5	1.4
11/21/2022 22:00	8.3	13.0	6.2	154.2	3,445,623.9	2,264.5	1.5	1.4
11/21/2022 23:00	8.1	13.0	6.0	144.5	3,468,378.5	2,228.8	1.4	1.1
Average/Sum#:	8.0	13.1	6.1	134.4	3,490,523.0	2,159.4	1.3	1.1
Minimum:	6.8	12.9	5.3	104.4	3,425,691.2	1,968.4	0.9	0.6
Maximum:	8.9	13.4	6.7	170.7	3,547,349.7	2,284.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/22/2022 00:00	7.9	13.1	6.0	127.7	3,471,732.5	2,154.9	1.2	1.1
11/22/2022 01:00	7.8	13.1	5.9	122.0	3,514,635.9	2,130.2	1.1	0.9
11/22/2022 02:00	7.9	13.2	6.1	120.9	3,509,233.5	2,101.3	1.1	0.8
11/22/2022 03:00	6.9	13.4	5.4	106.3	3,476,406.7	1,980.1	1.0	0.8
11/22/2022 04:00	7.0	13.4	5.5	106.1	3,530,980.7	1,985.4	1.0	0.8
11/22/2022 05:00	7.6	13.2	5.8	116.5	3,501,499.8	2,071.1	1.1	0.8
11/22/2022 06:00	7.9	13.1	6.0	121.8	3,515,182.0	2,156.2	1.1	0.9
11/22/2022 07:00	7.7	13.2	5.9	125.7	3,545,625.7	2,097.2	1.1	0.8
11/22/2022 08:00	7.6	13.3	5.9	112.8	3,519,249.5	2,055.9	1.0	0.8
11/22/2022 09:00	6.7	13.7	5.5	96.6	3,178,607.6	1,648.0	1.0	0.7
11/22/2022 10:00	7.3	13.6	5.9	98.2	3,229,719.9	1,674.5	1.0	0.7
11/22/2022 11:00	6.8	13.7	5.6	103.6	3,511,595.4	1,795.0	0.9	0.5
11/22/2022 12:00	6.8	13.7	5.6	92.6	3,044,817.3	1,556.4	1.0	0.6
11/22/2022 13:00	7.3	13.7	6.0	95.4	3,163,566.0	1,617.1	0.9	0.5
11/22/2022 14:00	7.1	13.6	5.7	103.9	3,432,240.4	1,779.5	1.0	0.7
11/22/2022 15:00	7.1	13.6	5.7	103.8	3,436,290.8	1,781.6	1.0	0.7
11/22/2022 16:00	7.7	13.4	6.1	111.3	3,413,779.4	1,919.5	1.0	0.8
11/22/2022 17:00	8.2	13.0	6.1	126.3	3,489,643.6	2,191.5	1.2	1.1
11/22/2022 18:00	7.9	13.2	6.1	118.0	3,475,802.0	2,055.9	1.1	0.8
11/22/2022 19:00	7.5	13.3	5.8	109.1	3,509,588.9	1,999.0	1.0	0.8
11/22/2022 20:00	8.1	13.1	6.1	128.1	3,514,692.9	2,155.9	1.2	1.1
11/22/2022 21:00	7.5	13.3	5.8	113.4	3,481,761.5	2,034.0	1.0	0.8
11/22/2022 22:00	7.5	13.3	5.8	115.1	3,501,104.6	2,045.3	1.1	0.8
11/22/2022 23:00	6.9	13.4	5.4	104.9	3,508,927.7	1,973.0	1.0	0.8
Average/Sum#:	7.4	13.4	5.8	111.7	3,436,528.5	1,956.6	1.0	0.8
Minimum:	6.7	13.0	5.4	92.6	3,044,817.3	1,556.4	0.9	0.5
Maximum:	8.2	13.7	6.1	128.1	3,545,625.7	2,191.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/23/2022 00:00	7.0	13.4	5.5	105.2	3,511,239.7	1,974.3	1.0	0.8
11/23/2022 01:00	6.9	13.4	5.4	105.1	3,512,662.5	1,975.1	1.0	0.8
11/23/2022 02:00	7.1	13.4	5.6	105.9	3,510,350.5	1,973.8	1.0	0.8
11/23/2022 03:00	6.8	13.4	5.3	104.6	3,514,974.5	1,976.4	1.0	0.8
11/23/2022 04:00	7.4	13.4	5.8	107.5	3,525,645.3	1,982.4	1.0	0.8
11/23/2022 05:00	8.1	13.2	6.2	118.9	3,464,476.7	2,074.5	1.1	0.8
11/23/2022 06:00	7.5	13.3	5.8	116.2	3,434,917.2	2,056.8	1.1	0.8
11/23/2022 07:00	8.2	13.2	6.3	119.0	3,525,432.8	2,111.0	1.1	0.8
11/23/2022 08:00	7.6	13.3	5.9	111.4	3,475,217.7	2,004.8	1.0	0.8
11/23/2022 09:00	6.8	13.7	5.6	99.4	3,331,613.9	1,703.0	0.9	0.5
11/23/2022 10:00	6.9	13.8	5.7	91.9	3,040,709.0	1,554.3	1.0	0.6
11/23/2022 11:00	6.9	13.8	5.7	91.6	3,033,470.6	1,550.6	1.0	0.6
11/23/2022 12:00	6.9	13.8	5.7	84.4	2,823,792.8	1,422.8	0.9	0.4
11/23/2022 13:00	6.9	13.8	5.7	91.2	3,094,303.7	1,559.1	0.9	0.5
11/23/2022 14:00	7.0	13.8	5.8	95.1	3,235,414.0	1,630.2	0.9	0.5
11/23/2022 15:00	8.1	13.7	6.6	99.8	3,201,518.6	1,636.5	1.0	0.7
11/23/2022 16:00	8.5	13.2	6.5	120.9	3,482,297.7	2,110.6	1.1	0.8
11/23/2022 17:00	8.1	13.1	6.1	124.9	3,479,771.1	2,185.3	1.2	1.1
11/23/2022 18:00	7.7	13.2	5.9	117.8	3,507,730.5	2,100.4	1.1	0.8
11/23/2022 19:00	7.7	13.3	6.0	113.7	3,532,259.0	2,063.5	1.0	0.8
11/23/2022 20:00	8.1	13.1	6.1	125.1	3,475,949.4	2,182.9	1.2	1.1
11/23/2022 21:00	8.1	13.1	6.1	127.4	3,506,204.1	2,201.9	1.2	1.1
11/23/2022 22:00	8.0	13.1	6.1	124.3	3,506,209.7	2,176.3	1.1	0.9
11/23/2022 23:00	7.9	13.1	6.0	123.4	3,498,476.5	2,171.5	1.1	0.9
Average/Sum#:	7.5	13.4	5.9	109.4	3,384,359.9	1,932.4	1.0	0.8
Minimum:	6.8	13.1	5.3	84.4	2,823,792.8	1,422.8	0.9	0.4
Maximum:	8.5	13.8	6.6	127.4	3,532,259.0	2,201.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/24/2022 00:00	7.2	13.4	5.7	107.8	3,494,841.3	1,990.6	1.0	0.8
11/24/2022 01:00	7.1	13.4	5.6	105.9	3,515,863.7	1,976.9	1.0	0.8
11/24/2022 02:00	7.1	13.4	5.6	106.3	3,515,508.0	1,976.7	1.0	0.8
11/24/2022 03:00	7.9	13.3	6.1	112.9	3,545,580.2	2,019.5	1.0	0.8
11/24/2022 04:00	7.5	13.3	5.8	111.8	3,513,353.6	2,026.8	1.0	0.8
11/24/2022 05:00	7.8	13.2	6.0	117.2	3,553,740.8	2,102.0	1.1	0.8
11/24/2022 06:00	8.5	13.1	6.4	161.3	3,448,745.8	2,191.0	1.5	1.3
11/24/2022 07:00	8.5	13.2	6.5	135.9	3,419,159.2	2,097.3	1.3	1.0
11/24/2022 08:00	6.5	13.7	5.3	98.8	3,350,785.8	1,712.8	0.9	0.5
11/24/2022 09:00	6.7	13.7	5.5	98.7	3,318,897.8	1,696.5	0.9	0.5
11/24/2022 10:00	6.8	13.7	5.6	99.4	3,332,983.3	1,703.7	0.9	0.5
11/24/2022 11:00	6.8	13.8	5.7	91.7	3,074,258.5	1,549.0	0.9	0.5
11/24/2022 12:00	7.0	13.8	5.8	82.5	2,678,911.6	1,349.8	1.0	0.5
11/24/2022 13:00	7.1	13.8	5.9	81.8	2,669,782.1	1,345.2	1.0	0.5
11/24/2022 14:00	6.9	13.8	5.7	91.0	3,078,823.3	1,551.3	0.9	0.5
11/24/2022 15:00	7.3	13.8	6.1	87.6	2,859,516.9	1,440.8	1.0	0.6
11/24/2022 16:00	7.2	13.7	5.9	103.2	3,436,863.9	1,756.8	0.9	0.5
11/24/2022 17:00	6.9	13.7	5.7	101.7	3,433,929.5	1,755.3	0.9	0.5
11/24/2022 18:00	6.9	13.7	5.7	101.2	3,400,280.7	1,738.1	0.9	0.5
11/24/2022 19:00	6.9	13.7	5.7	101.1	3,395,585.6	1,735.7	0.9	0.5
11/24/2022 20:00	6.9	13.7	5.7	101.3	3,396,563.7	1,736.2	0.9	0.5
11/24/2022 21:00	6.9	13.7	5.7	101.5	3,402,824.0	1,739.4	0.9	0.5
11/24/2022 22:00	6.9	13.7	5.7	101.6	3,409,475.5	1,742.8	0.9	0.5
11/24/2022 23:00	6.9	13.7	5.7	101.7	3,412,801.2	1,744.5	0.9	0.5
Average/Sum#:	7.2	13.6	5.8	104.3	3,319,128.2	1,778.3	1.0	0.6
Minimum:	6.5	13.1	5.3	81.8	2,669,782.1	1,345.2	0.9	0.5
Maximum:	8.5	13.8	6.5	161.3	3,553,740.8	2,191.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/25/2022 00:00	6.9	13.7	5.7	101.8	3,416,713.8	1,746.5	0.9	0.5
11/25/2022 01:00	6.9	13.7	5.7	101.9	3,417,300.7	1,746.8	0.9	0.5
11/25/2022 02:00	6.8	13.7	5.6	101.9	3,422,778.4	1,749.6	0.9	0.5
11/25/2022 03:00	6.8	13.7	5.6	102.1	3,430,212.4	1,753.4	0.9	0.5
11/25/2022 04:00	6.8	13.7	5.6	102.4	3,450,753.8	1,763.9	0.9	0.5
11/25/2022 05:00	6.9	13.7	5.7	102.5	3,445,471.7	1,761.2	0.9	0.5
11/25/2022 06:00	6.9	13.7	5.7	102.4	3,433,929.5	1,755.3	0.9	0.5
11/25/2022 07:00	7.1	13.7	5.8	103.4	3,435,103.3	1,755.9	0.9	0.5
11/25/2022 08:00	7.3	13.5	5.8	107.2	3,475,562.1	1,878.1	1.0	0.8
11/25/2022 09:00	7.6	13.4	6.0	108.6	3,427,117.9	1,927.0	1.0	0.8
11/25/2022 10:00	6.8	13.7	5.6	96.9	3,249,839.7	1,661.2	0.9	0.5
11/25/2022 11:00	6.9	13.7	5.7	90.7	3,010,386.1	1,538.8	0.9	0.5
11/25/2022 12:00	6.9	13.7	5.7	91.9	3,062,424.2	1,565.4	0.9	0.5
11/25/2022 13:00	6.9	13.7	5.7	90.4	3,001,582.6	1,534.3	0.9	0.5
11/25/2022 14:00	7.0	13.7	5.7	89.5	2,976,933.0	1,521.7	0.9	0.5
11/25/2022 15:00	7.8	13.6	6.3	98.0	3,144,468.4	1,630.3	1.0	0.7
11/25/2022 16:00	8.5	13.2	6.5	123.2	3,462,333.8	2,098.5	1.1	0.8
11/25/2022 17:00	8.0	13.2	6.1	121.8	3,448,178.0	2,115.1	1.1	0.8
11/25/2022 18:00	7.5	13.4	5.9	108.8	3,469,910.7	1,976.4	1.0	0.8
11/25/2022 19:00	7.4	13.4	5.8	106.9	3,496,656.2	1,966.1	1.0	0.8
11/25/2022 20:00	7.5	13.4	5.9	107.3	3,510,706.1	1,974.0	1.0	0.8
11/25/2022 21:00	7.1	13.4	5.6	105.9	3,516,397.3	1,977.2	1.0	0.8
11/25/2022 22:00	8.0	13.2	6.1	121.0	3,517,110.8	2,131.7	1.1	0.9
11/25/2022 23:00	7.9	13.2	6.1	118.9	3,492,199.2	2,091.1	1.1	0.8
Average/Sum#:	7.3	13.5	5.8	104.4	3,363,086.2	1,817.5	1.0	0.6
Minimum:	6.8	13.2	5.6	89.5	2,976,933.0	1,521.7	0.9	0.5
Maximum:	8.5	13.7	6.5	123.2	3,517,110.8	2,131.7	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/26/2022 00:00	7.5	13.3	5.8	111.9	3,524,621.0	2,033.3	1.0	0.8
11/26/2022 01:00	7.6	13.2	5.8	117.4	3,516,715.6	2,080.1	1.1	0.8
11/26/2022 02:00	10.1	14.1	8.8	114.8	3,080,813.6	1,574.8	1.2	0.8
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.4	13.5	6.8	114.7	3,374,050.1	1,896.1	1.1	0.8
Minimum:	7.5	13.2	5.8	111.9	3,080,813.6	1,574.8	1.0	0.8
Maximum:	10.1	14.1	8.8	117.4	3,524,621.0	2,080.1	1.2	0.8
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	33.3	17.5	57.8	0.0	1,413,074.8	330.2	0.0	0.0
11/27/2022 22:00	33.7	17.2	53.7	202.1	1,509,790.4	396.9	4.1	0.6
11/27/2022 23:00	33.8	15.3	35.6	217.8	2,286,431.5	901.6	2.9	1.0
Average/Sum#:	33.6	16.7	49.0	140.0	1,736,432.2	542.9	2.3	0.5
Minimum:	33.3	15.3	35.6	0.0	1,413,074.8	330.2	0.0	0.0
Maximum:	33.8	17.5	57.8	217.8	2,286,431.5	901.6	4.1	1.0
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/28/2022 00:00	6.9	13.7	5.7	96.1	3,081,009.2	1,574.9	1.0	0.6
11/28/2022 01:00	7.1	13.7	5.8	88.2	2,910,613.7	1,487.8	1.0	0.6
11/28/2022 02:00	7.1	13.7	5.8	98.0	3,366,662.3	1,745.5	0.9	0.5
11/28/2022 03:00	7.2	13.7	5.9	92.9	2,994,735.5	1,530.8	1.0	0.6
11/28/2022 04:00	7.0	13.7	5.7	100.0	3,346,286.3	1,710.5	0.9	0.5
11/28/2022 05:00	7.3	13.7	6.0	97.2	3,167,420.7	1,642.2	1.0	0.7
11/28/2022 06:00	8.2	13.1	6.2	127.8	3,460,503.6	2,173.2	1.2	1.1
11/28/2022 07:00	8.6	13.0	6.4	141.4	3,493,109.3	2,270.2	1.3	1.1
11/28/2022 08:00	7.3	13.4	5.7	109.7	3,462,361.3	1,972.1	1.0	0.8
11/28/2022 09:00	6.9	13.7	5.7	95.2	3,133,438.6	1,601.7	1.0	0.6
11/28/2022 10:00	7.0	13.7	5.7	100.2	3,323,788.6	1,699.0	1.0	0.7
11/28/2022 11:00	7.1	13.7	5.8	91.1	2,973,020.3	1,519.7	1.0	0.6
11/28/2022 12:00	7.1	13.7	5.8	93.9	3,064,380.5	1,566.4	1.0	0.6
11/28/2022 13:00	7.0	13.7	5.7	96.8	3,196,627.8	1,634.0	1.0	0.7
11/28/2022 14:00	7.1	13.7	5.8	96.0	3,163,174.7	1,616.9	1.0	0.6
11/28/2022 15:00	7.6	13.7	6.2	97.7	3,124,602.1	1,620.0	1.0	0.6
11/28/2022 16:00	8.2	13.3	6.4	115.0	3,450,780.4	2,041.1	1.1	0.8
11/28/2022 17:00	8.2	13.2	6.3	122.4	3,465,303.7	2,100.3	1.1	0.8
11/28/2022 18:00	7.6	13.3	5.9	110.3	3,491,154.3	1,988.5	1.0	0.8
11/28/2022 19:00	7.5	13.4	5.9	107.5	3,499,679.6	1,967.8	1.0	0.8
11/28/2022 20:00	8.0	13.2	6.1	119.7	3,497,042.3	2,094.0	1.1	0.8
11/28/2022 21:00	8.2	13.0	6.1	138.2	3,483,317.7	2,238.4	1.3	1.1
11/28/2022 22:00	7.7	13.2	5.9	119.3	3,499,380.3	2,095.4	1.1	0.8
11/28/2022 23:00	7.2	13.4	5.7	107.0	3,504,497.5	1,996.1	1.0	0.8
Average/Sum#:	7.5	13.5	5.9	106.7	3,298,037.1	1,828.6	1.0	0.7
Minimum:	6.9	13.0	5.7	88.2	2,910,613.7	1,487.8	0.9	0.5
Maximum:	8.6	13.7	6.4	141.4	3,504,497.5	2,270.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/29/2022 00:00	8.0	13.1	6.1	124.4	3,529,854.4	2,165.2	1.1	0.9
11/29/2022 01:00	8.1	13.1	6.1	132.0	3,523,560.8	2,212.8	1.2	1.1
11/29/2022 02:00	7.9	13.1	6.0	129.2	3,531,826.0	2,192.2	1.2	1.1
11/29/2022 03:00	7.7	13.2	5.9	117.5	3,530,071.7	2,088.0	1.1	0.8
11/29/2022 04:00	8.0	13.2	6.1	126.4	3,509,639.1	2,152.8	1.2	1.1
11/29/2022 05:00	8.0	13.1	6.1	131.4	3,553,414.6	2,205.6	1.2	1.1
11/29/2022 06:00	8.3	13.0	6.2	146.9	3,494,923.2	2,296.9	1.4	1.1
11/29/2022 07:00	8.7	13.0	6.5	154.5	3,506,030.7	2,304.2	1.4	1.2
11/29/2022 08:00	8.4	13.0	6.3	151.9	3,500,341.0	2,274.9	1.4	1.1
11/29/2022 09:00	8.1	13.1	6.1	132.7	3,503,309.8	2,174.5	1.2	1.1
11/29/2022 10:00	8.2	13.1	6.2	135.5	3,491,387.7	2,167.1	1.3	1.1
11/29/2022 11:00	8.2	13.1	6.2	134.3	3,476,565.7	2,157.9	1.3	1.1
11/29/2022 12:00	8.2	13.1	6.2	135.1	3,465,771.5	2,151.2	1.3	1.1
11/29/2022 13:00	8.2	13.1	6.2	135.1	3,466,093.7	2,151.4	1.3	1.1
11/29/2022 14:00	8.3	13.1	6.3	135.4	3,473,504.7	2,156.0	1.3	1.1
11/29/2022 15:00	8.3	13.1	6.3	138.1	3,456,363.5	2,170.6	1.3	1.1
11/29/2022 16:00	8.5	13.0	6.3	160.2	3,471,490.8	2,281.5	1.5	1.4
11/29/2022 17:00	8.3	13.0	6.2	157.5	3,483,815.6	2,289.6	1.5	1.4
11/29/2022 18:00	8.3	13.0	6.2	157.6	3,488,684.7	2,292.8	1.5	1.4
11/29/2022 19:00	8.3	13.0	6.2	154.3	3,485,185.1	2,290.5	1.4	1.1
11/29/2022 20:00	8.1	13.0	6.0	150.2	3,522,498.0	2,289.3	1.4	1.1
11/29/2022 21:00	8.1	13.0	6.0	150.7	3,487,771.7	2,292.2	1.4	1.1
11/29/2022 22:00	8.1	13.0	6.0	146.4	3,535,576.8	2,297.8	1.4	1.1
11/29/2022 23:00	8.1	13.0	6.0	150.5	3,533,884.3	2,296.7	1.4	1.1
Average/Sum#:	8.2	13.1	6.2	141.2	3,500,898.5	2,223.0	1.3	1.1
Minimum:	7.7	13.0	5.9	117.5	3,456,363.5	2,088.0	1.1	0.8
Maximum:	8.7	13.2	6.5	160.2	3,553,414.6	2,304.2	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/30/2022 00:00	7.6	13.2	5.8	121.6	3,581,457.2	2,170.7	1.1	0.9
11/30/2022 01:00	7.7	13.2	5.9	120.3	3,552,583.8	2,153.2	1.1	0.9
11/30/2022 02:00	7.8	13.2	6.0	120.4	3,553,573.8	2,153.8	1.1	0.9
11/30/2022 03:00	7.7	13.2	5.9	119.4	3,548,954.0	2,151.0	1.1	0.9
11/30/2022 04:00	7.7	13.2	5.9	121.3	3,579,642.3	2,169.6	1.1	0.9
11/30/2022 05:00	7.7	13.2	5.9	121.9	3,579,147.4	2,169.3	1.1	0.9
11/30/2022 06:00	7.9	13.1	6.0	142.7	3,529,380.1	2,268.0	1.3	1.1
11/30/2022 07:00	7.9	13.2	6.1	124.1	3,560,503.4	2,158.0	1.1	0.9
11/30/2022 08:00	7.0	13.4	5.5	105.9	3,575,459.0	1,984.3	0.9	0.6
11/30/2022 09:00	7.3	13.3	5.7	108.0	3,554,634.4	1,998.7	1.0	0.8
11/30/2022 10:00	7.0	13.4	5.5	105.5	3,521,910.5	1,980.3	1.0	0.8
11/30/2022 11:00	7.2	13.4	5.7	106.7	3,528,668.7	1,984.1	1.0	0.8
11/30/2022 12:00	7.7	13.3	6.0	108.9	3,528,135.2	1,983.8	1.0	0.8
11/30/2022 13:00	7.8	13.3	6.1	109.5	3,474,124.3	1,978.8	1.0	0.8
11/30/2022 14:00	8.2	13.1	6.2	127.0	3,476,544.6	2,132.5	1.2	1.1
11/30/2022 15:00	8.2	13.1	6.2	129.7	3,449,016.1	2,140.8	1.2	1.1
11/30/2022 16:00	8.4	13.0	6.3	148.9	3,426,299.8	2,251.8	1.4	1.1
11/30/2022 17:00	8.4	12.9	6.2	158.7	3,419,542.0	2,297.3	1.5	1.4
11/30/2022 18:00	8.3	12.9	6.1	156.8	3,445,231.0	2,289.4	1.5	1.4
11/30/2022 19:00	8.3	12.9	6.1	154.5	3,445,531.9	2,289.6	1.5	1.4
11/30/2022 20:00	8.2	12.9	6.0	150.2	3,444,478.5	2,288.9	1.4	1.1
11/30/2022 21:00	8.1	12.9	6.0	143.1	3,472,183.2	2,256.6	1.3	1.1
11/30/2022 22:00	7.7	13.1	5.8	121.8	3,476,193.1	2,106.9	1.1	0.8
11/30/2022 23:00	10.4	13.9	8.8	117.0	3,067,703.5	1,590.5	1.2	0.8
Average/Sum#:	7.9	13.2	6.1	126.8	3,491,287.4	2,122.8	1.2	1.0
Minimum:	7.0	12.9	5.5	105.5	3,067,703.5	1,590.5	0.9	0.6
Maximum:	10.4	13.9	8.8	158.7	3,581,457.2	2,297.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	30.2	17.5	52.4	206.6	1,378,097.4	301.9	4.3	0.5
12/01/2022 03:00	22.5	14.6	21.1	183.9	2,568,232.0	1,144.0	2.2	0.9
12/01/2022 04:00	7.1	13.6	5.7	101.8	3,285,847.0	1,703.6	1.0	0.7
12/01/2022 05:00	7.5	13.5	6.0	106.7	3,313,451.8	1,790.5	1.0	0.7
12/01/2022 06:00	8.9	12.9	6.6	162.2	3,410,164.4	2,291.0	1.6	1.4
12/01/2022 07:00	9.2	12.9	6.8	179.8	3,426,358.7	2,326.9	1.7	1.6
12/01/2022 08:00	8.6	13.0	6.4	135.0	3,429,163.2	2,203.6	1.3	1.1
12/01/2022 09:00	8.5	13.0	6.3	132.6	3,447,801.3	2,190.4	1.2	1.1
12/01/2022 10:00	8.5	13.0	6.3	133.8	3,455,514.2	2,195.3	1.3	1.1
12/01/2022 11:00	8.5	13.0	6.3	132.3	3,461,140.5	2,173.6	1.2	1.1
12/01/2022 12:00	8.6	13.0	6.4	135.0	3,426,394.3	2,176.8	1.3	1.1
12/01/2022 13:00	8.5	13.0	6.3	135.7	3,428,125.7	2,177.9	1.3	1.1
12/01/2022 14:00	8.6	13.0	6.4	140.5	3,411,578.5	2,192.3	1.3	1.1
12/01/2022 15:00	8.9	12.9	6.6	172.8	3,403,535.0	2,311.4	1.7	1.6
12/01/2022 16:00	9.0	12.9	6.6	176.2	3,443,587.0	2,338.6	1.7	1.6
12/01/2022 17:00	9.0	12.9	6.6	182.0	3,456,250.4	2,347.2	1.7	1.6
12/01/2022 18:00	8.9	12.9	6.6	171.5	3,439,169.5	2,335.6	1.6	1.4
12/01/2022 19:00	8.9	12.9	6.6	173.7	3,490,841.4	2,345.2	1.6	1.4
12/01/2022 20:00	8.9	12.9	6.6	171.9	3,496,646.5	2,349.1	1.6	1.4
12/01/2022 21:00	8.8	13.0	6.6	162.2	3,497,750.7	2,324.3	1.5	1.4
12/01/2022 22:00	8.4	13.1	6.4	132.0	3,519,742.9	2,184.7	1.2	1.1
12/01/2022 23:00	8.4	13.1	6.4	134.4	3,515,070.7	2,181.8	1.2	1.1
Average/Sum#:	10.2	13.3	9.2	152.8	3,304,748.3	2,072.1	1.6	1.2
Minimum:	7.1	12.9	5.7	101.8	1,378,097.4	301.9	1.0	0.5
Maximum:	30.2	17.5	52.4	206.6	3,519,742.9	2,349.1	4.3	1.6
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/02/2022 00:00	8.4	13.1	6.4	132.8	3,514,909.6	2,181.7	1.2	1.1
12/02/2022 01:00	8.4	13.1	6.4	133.7	3,520,226.2	2,185.0	1.2	1.1
12/02/2022 02:00	8.3	13.1	6.3	136.7	3,527,637.2	2,189.6	1.3	1.1
12/02/2022 03:00	8.3	13.1	6.3	128.6	3,534,419.1	2,168.0	1.2	1.1
12/02/2022 04:00	8.3	13.1	6.3	130.9	3,549,906.7	2,177.5	1.2	1.1
12/02/2022 05:00	8.2	13.1	6.2	130.2	3,544,526.8	2,174.2	1.2	1.1
12/02/2022 06:00	8.5	13.0	6.3	159.9	3,557,426.0	2,312.0	1.5	1.4
12/02/2022 07:00	8.9	13.0	6.6	159.8	3,535,397.3	2,323.5	1.5	1.4
12/02/2022 08:00	8.6	13.0	6.4	151.0	3,571,735.8	2,321.3	1.4	1.2
12/02/2022 09:00	8.3	13.1	6.3	131.8	3,538,592.6	2,196.4	1.2	1.1
12/02/2022 10:00	8.4	13.1	6.4	134.0	3,538,753.7	2,196.5	1.2	1.1
12/02/2022 11:00	8.5	13.1	6.4	138.5	3,525,790.1	2,214.2	1.3	1.1
12/02/2022 12:00	8.5	13.1	6.4	138.1	3,531,044.9	2,217.5	1.3	1.1
12/02/2022 13:00	8.5	13.1	6.4	138.6	3,516,713.7	2,208.5	1.3	1.1
12/02/2022 14:00	8.4	13.1	6.4	135.7	3,480,885.7	2,186.0	1.3	1.1
12/02/2022 15:00	8.8	13.0	6.6	162.1	3,509,378.2	2,306.4	1.5	1.4
12/02/2022 16:00	8.8	12.9	6.5	167.6	3,479,528.7	2,337.6	1.6	1.4
12/02/2022 17:00	8.6	13.0	6.4	162.7	3,504,221.6	2,328.6	1.5	1.4
12/02/2022 18:00	8.6	13.0	6.4	158.4	3,528,245.8	2,318.8	1.5	1.4
12/02/2022 19:00	8.6	13.0	6.4	158.8	3,536,462.4	2,324.2	1.5	1.4
12/02/2022 20:00	8.6	13.0	6.4	158.4	3,532,658.4	2,321.7	1.5	1.4
12/02/2022 21:00	8.6	13.0	6.4	158.5	3,523,833.3	2,315.9	1.5	1.4
12/02/2022 22:00	8.6	13.0	6.4	154.6	3,519,877.1	2,313.3	1.4	1.2
12/02/2022 23:00	8.6	13.0	6.4	157.3	3,526,572.1	2,317.7	1.5	1.4
Average/Sum#:	8.5	13.0	6.4	146.6	3,527,031.0	2,255.7	1.4	1.2
Minimum:	8.2	12.9	6.2	128.6	3,479,528.7	2,168.0	1.2	1.1
Maximum:	8.9	13.1	6.6	167.6	3,571,735.8	2,337.6	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/03/2022 00:00	8.5	13.0	6.3	152.6	3,554,810.3	2,310.3	1.4	1.2
12/03/2022 01:00	8.5	13.0	6.3	153.5	3,567,581.3	2,318.6	1.4	1.2
12/03/2022 02:00	8.4	13.0	6.3	150.5	3,533,875.7	2,322.5	1.4	1.2
12/03/2022 03:00	8.4	13.0	6.3	153.3	3,533,571.4	2,322.3	1.4	1.2
12/03/2022 04:00	8.5	13.0	6.3	154.7	3,526,876.4	2,317.9	1.4	1.2
12/03/2022 05:00	8.5	13.0	6.3	154.1	3,532,506.3	2,321.6	1.4	1.2
12/03/2022 06:00	8.5	13.0	6.3	157.5	3,538,440.4	2,325.5	1.5	1.4
12/03/2022 07:00	8.8	13.0	6.6	158.2	3,512,949.8	2,334.4	1.5	1.4
12/03/2022 08:00	8.6	13.0	6.4	158.9	3,543,157.4	2,328.6	1.5	1.4
12/03/2022 09:00	8.6	13.0	6.4	153.6	3,507,381.8	2,330.7	1.4	1.2
12/03/2022 10:00	8.4	13.0	6.3	149.8	3,516,681.8	2,311.2	1.4	1.2
12/03/2022 11:00	8.4	13.0	6.3	143.3	3,507,726.7	2,279.7	1.3	1.1
12/03/2022 12:00	8.4	12.9	6.2	150.2	3,512,725.7	2,308.6	1.4	1.2
12/03/2022 13:00	8.1	13.1	6.1	128.0	3,498,720.1	2,197.2	1.2	1.1
12/03/2022 14:00	8.1	13.1	6.1	127.0	3,520,870.6	2,185.4	1.2	1.1
12/03/2022 15:00	8.5	12.9	6.3	152.9	3,519,420.7	2,313.0	1.4	1.2
12/03/2022 16:00	8.5	12.9	6.3	158.2	3,475,509.8	2,334.9	1.5	1.4
12/03/2022 17:00	8.5	12.9	6.3	156.3	3,498,954.5	2,325.1	1.5	1.4
12/03/2022 18:00	8.5	12.9	6.3	153.9	3,480,444.7	2,312.8	1.4	1.2
12/03/2022 19:00	8.5	12.9	6.3	153.0	3,485,410.8	2,316.1	1.4	1.2
12/03/2022 20:00	8.6	12.9	6.3	158.2	3,466,876.4	2,329.1	1.5	1.4
12/03/2022 21:00	8.6	12.9	6.3	161.5	3,489,055.2	2,344.0	1.5	1.4
12/03/2022 22:00	8.6	12.9	6.3	162.2	3,499,325.9	2,350.9	1.5	1.4
12/03/2022 23:00	8.5	12.9	6.3	158.4	3,486,227.0	2,342.1	1.5	1.4
Average/Sum#:	8.5	13.0	6.3	152.5	3,512,879.2	2,311.8	1.4	1.3
Minimum:	8.1	12.9	6.1	127.0	3,466,876.4	2,185.4	1.2	1.1
Maximum:	8.8	13.1	6.6	162.2	3,567,581.3	2,350.9	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/04/2022 00:00	8.2	13.1	6.2	129.5	3,503,656.4	2,200.3	1.2	1.1
12/04/2022 01:00	8.2	13.1	6.2	129.9	3,509,388.8	2,203.9	1.2	1.1
12/04/2022 02:00	8.2	13.0	6.1	130.4	3,517,032.1	2,208.7	1.2	1.1
12/04/2022 03:00	8.2	13.1	6.2	129.4	3,503,815.6	2,200.4	1.2	1.1
12/04/2022 04:00	8.2	13.0	6.1	131.1	3,521,490.7	2,211.5	1.2	1.1
12/04/2022 05:00	8.2	13.0	6.1	128.4	3,506,681.8	2,202.2	1.2	1.1
12/04/2022 06:00	8.5	12.9	6.3	164.1	3,501,512.8	2,326.8	1.5	1.4
12/04/2022 07:00	8.8	12.9	6.5	155.8	3,481,761.5	2,339.1	1.5	1.4
12/04/2022 08:00	8.3	13.0	6.2	130.3	3,526,745.5	2,214.8	1.2	1.1
12/04/2022 09:00	8.3	13.0	6.2	128.1	3,489,325.2	2,191.3	1.2	1.1
12/04/2022 10:00	8.3	13.0	6.2	130.6	3,472,513.9	2,206.1	1.2	1.1
12/04/2022 11:00	8.4	13.0	6.3	133.5	3,472,986.2	2,206.4	1.2	1.1
12/04/2022 12:00	8.6	13.0	6.4	138.4	3,419,981.8	2,197.7	1.3	1.1
12/04/2022 13:00	8.7	13.0	6.5	143.4	3,412,979.0	2,193.2	1.4	1.1
12/04/2022 14:00	8.6	13.0	6.4	138.3	3,435,076.6	2,207.4	1.3	1.1
12/04/2022 15:00	8.5	13.0	6.3	136.0	3,415,468.9	2,194.8	1.3	1.1
12/04/2022 16:00	8.8	12.9	6.5	165.3	3,420,174.2	2,322.7	1.6	1.4
12/04/2022 17:00	8.8	12.9	6.5	166.6	3,443,734.2	2,338.7	1.6	1.4
12/04/2022 18:00	8.8	12.9	6.5	162.6	3,421,205.0	2,323.4	1.6	1.4
12/04/2022 19:00	8.7	12.9	6.4	161.7	3,454,670.7	2,320.9	1.5	1.4
12/04/2022 20:00	8.7	12.9	6.4	156.0	3,456,159.2	2,321.9	1.5	1.4
12/04/2022 21:00	8.6	12.9	6.3	157.2	3,457,647.7	2,322.9	1.5	1.4
12/04/2022 22:00	8.6	12.9	6.3	155.5	3,478,789.4	2,311.7	1.5	1.4
12/04/2022 23:00	8.3	13.0	6.2	129.9	3,491,554.5	2,192.7	1.2	1.1
Average/Sum#:	8.5	13.0	6.3	143.0	3,471,431.3	2,248.3	1.3	1.2
Minimum:	8.2	12.9	6.1	128.1	3,412,979.0	2,191.3	1.2	1.1
Maximum:	8.8	13.1	6.5	166.6	3,526,745.5	2,339.1	1.6	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/05/2022 00:00	8.3	13.0	6.2	130.7	3,494,102.2	2,194.3	1.2	1.1
12/05/2022 01:00	8.3	13.0	6.2	129.3	3,489,484.4	2,191.4	1.2	1.1
12/05/2022 02:00	8.3	13.0	6.2	131.5	3,497,446.2	2,196.4	1.2	1.1
12/05/2022 03:00	8.4	13.0	6.3	131.0	3,487,255.1	2,190.0	1.2	1.1
12/05/2022 04:00	8.4	13.0	6.3	135.5	3,487,939.6	2,215.9	1.3	1.1
12/05/2022 05:00	8.7	12.9	6.4	160.6	3,492,483.6	2,320.8	1.5	1.4
12/05/2022 06:00	8.7	12.9	6.4	175.6	3,451,685.7	2,344.1	1.7	1.6
12/05/2022 07:00	9.0	12.9	6.6	161.7	3,483,994.3	2,340.6	1.5	1.4
12/05/2022 08:00	8.8	12.9	6.5	161.8	3,462,876.7	2,351.7	1.5	1.4
12/05/2022 09:00	8.8	12.8	6.4	170.4	3,446,870.3	2,366.0	1.6	1.4
12/05/2022 10:00	8.6	13.0	6.4	154.7	3,258,925.7	2,141.8	1.6	1.3
12/05/2022 11:00	7.6	13.5	6.1	106.0	3,248,914.9	1,826.8	1.0	0.7
12/05/2022 12:00	8.3	13.0	6.2	127.3	3,402,783.5	2,161.8	1.2	1.1
12/05/2022 13:00	8.1	13.2	6.2	117.3	3,426,942.3	2,027.0	1.1	0.8
12/05/2022 14:00	8.2	13.2	6.3	120.5	3,434,416.2	2,056.5	1.1	0.8
12/05/2022 15:00	8.2	13.2	6.3	121.8	3,422,571.0	2,074.4	1.1	0.8
12/05/2022 16:00	8.4	13.0	6.3	144.4	3,420,022.0	2,222.7	1.4	1.1
12/05/2022 17:00	8.4	12.9	6.2	154.3	3,420,584.0	2,298.0	1.5	1.4
12/05/2022 18:00	8.3	12.9	6.1	151.3	3,421,625.9	2,298.7	1.5	1.4
12/05/2022 19:00	8.3	12.9	6.1	151.2	3,464,643.7	2,302.3	1.4	1.2
12/05/2022 20:00	8.2	12.9	6.0	146.4	3,460,129.1	2,299.3	1.4	1.1
12/05/2022 21:00	8.0	13.0	6.0	133.7	3,456,396.0	2,221.1	1.3	1.1
12/05/2022 22:00	7.6	13.2	5.8	116.1	3,464,142.7	2,074.3	1.1	0.8
12/05/2022 23:00	7.6	13.2	5.8	113.6	3,465,658.1	2,049.9	1.1	0.8
Average/Sum#:	8.3	13.0	6.2	139.4	3,440,078.9	2,198.6	1.3	1.1
Minimum:	7.6	12.8	5.8	106.0	3,248,914.9	1,826.8	1.0	0.7
Maximum:	9.0	13.5	6.6	175.6	3,497,446.2	2,366.0	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/06/2022 00:00	7.1	13.4	5.6	106.0	3,500,746.7	1,968.4	1.0	0.8
12/06/2022 01:00	7.1	13.4	5.6	106.0	3,500,035.3	1,968.0	1.0	0.8
12/06/2022 02:00	7.1	13.4	5.6	106.1	3,500,035.3	1,968.0	1.0	0.8
12/06/2022 03:00	7.1	13.4	5.6	106.2	3,502,525.2	1,969.4	1.0	0.8
12/06/2022 04:00	7.4	13.4	5.8	108.0	3,483,429.4	1,984.1	1.0	0.8
12/06/2022 05:00	7.5	13.3	5.8	110.3	3,488,565.3	2,012.5	1.0	0.8
12/06/2022 06:00	7.2	13.4	5.7	106.5	3,485,887.3	1,985.5	1.0	0.8
12/06/2022 07:00	8.1	13.2	6.2	120.6	3,491,197.2	2,090.5	1.1	0.8
12/06/2022 08:00	8.4	13.0	6.3	142.7	3,474,077.5	2,283.2	1.3	1.1
12/06/2022 09:00	8.1	13.0	6.0	140.8	3,493,878.6	2,270.7	1.3	1.1
12/06/2022 10:00	8.1	13.0	6.0	139.9	3,484,031.0	2,264.3	1.3	1.1
12/06/2022 11:00	8.1	13.0	6.0	141.6	3,478,030.2	2,260.4	1.3	1.1
12/06/2022 12:00	8.2	13.0	6.1	147.0	3,448,179.8	2,241.0	1.4	1.1
12/06/2022 13:00	6.8	13.6	5.5	104.5	3,385,141.0	1,779.8	1.0	0.7
12/06/2022 14:00	7.1	13.8	5.9	82.6	2,608,852.7	1,314.5	1.0	0.5
12/06/2022 15:00	7.2	13.8	6.0	81.7	2,608,058.8	1,314.1	1.0	0.5
12/06/2022 16:00	7.3	13.7	6.0	91.2	2,958,739.2	1,512.4	1.0	0.6
12/06/2022 17:00	7.1	13.6	5.7	105.9	3,487,210.3	1,808.0	1.0	0.7
12/06/2022 18:00	7.0	13.6	5.7	105.4	3,486,824.5	1,807.8	1.0	0.7
12/06/2022 19:00	7.2	13.6	5.8	106.6	3,505,726.4	1,817.6	1.0	0.7
12/06/2022 20:00	8.2	13.1	6.2	122.8	3,484,369.9	2,137.3	1.1	0.9
12/06/2022 21:00	8.3	13.0	6.2	139.1	3,479,427.3	2,235.9	1.3	1.1
12/06/2022 22:00	7.8	13.2	6.0	125.5	3,474,213.2	2,105.7	1.2	1.1
12/06/2022 23:00	7.2	13.4	5.7	106.3	3,509,283.4	1,973.2	1.0	0.8
Average/Sum#:	7.5	13.3	5.9	114.7	3,388,269.4	1,961.3	1.1	0.8
Minimum:	6.8	13.0	5.5	81.7	2,608,058.8	1,314.1	1.0	0.5
Maximum:	8.4	13.8	6.3	147.0	3,509,283.4	2,283.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/07/2022 00:00	7.9	13.2	6.1	117.4	3,480,509.0	2,084.1	1.1	0.8
12/07/2022 01:00	7.3	13.4	5.7	108.0	3,495,368.0	1,990.9	1.0	0.8
12/07/2022 02:00	7.9	13.1	6.0	119.7	3,529,155.1	2,139.0	1.1	0.9
12/07/2022 03:00	7.8	13.1	5.9	120.5	3,500,509.6	2,147.2	1.1	0.9
12/07/2022 04:00	7.9	13.1	6.0	123.4	3,528,876.2	2,164.6	1.1	0.9
12/07/2022 05:00	7.9	13.1	6.0	123.8	3,501,054.3	2,173.1	1.1	0.9
12/07/2022 06:00	8.0	13.0	6.0	141.7	3,506,971.4	2,253.6	1.3	1.1
12/07/2022 07:00	8.5	13.0	6.3	139.3	3,525,334.1	2,265.4	1.3	1.1
12/07/2022 08:00	7.9	13.1	6.0	120.8	3,527,175.2	2,137.8	1.1	0.9
12/07/2022 09:00	7.8	13.1	5.9	121.0	3,541,266.2	2,172.2	1.1	0.9
12/07/2022 10:00	7.9	13.1	6.0	123.0	3,540,125.1	2,171.5	1.1	0.9
12/07/2022 11:00	7.9	13.1	6.0	125.2	3,536,049.4	2,169.0	1.1	0.9
12/07/2022 12:00	7.9	13.1	6.0	122.2	3,496,596.9	2,144.8	1.1	0.9
12/07/2022 13:00	7.9	13.1	6.0	121.9	3,457,144.5	2,120.6	1.1	0.8
12/07/2022 14:00	7.7	13.2	5.9	116.9	3,491,863.1	2,065.4	1.1	0.8
12/07/2022 15:00	7.8	13.2	6.0	119.0	3,488,525.1	2,088.9	1.1	0.8
12/07/2022 16:00	8.2	13.0	6.1	146.1	3,480,646.0	2,262.1	1.4	1.1
12/07/2022 17:00	8.2	13.0	6.1	145.9	3,463,122.1	2,276.0	1.4	1.1
12/07/2022 18:00	8.1	13.0	6.0	146.5	3,467,991.2	2,279.2	1.4	1.1
12/07/2022 19:00	8.1	13.0	6.0	145.9	3,465,861.0	2,277.8	1.4	1.1
12/07/2022 20:00	8.1	13.0	6.0	144.1	3,466,317.4	2,278.1	1.4	1.1
12/07/2022 21:00	8.0	13.0	6.0	139.3	3,497,109.8	2,272.8	1.3	1.1
12/07/2022 22:00	7.7	13.1	5.8	123.7	3,520,870.6	2,185.4	1.1	0.9
12/07/2022 23:00	7.8	13.1	5.9	123.2	3,515,070.7	2,181.8	1.1	0.9
Average/Sum#:	7.9	13.1	6.0	128.3	3,500,979.7	2,179.2	1.2	0.9
Minimum:	7.3	13.0	5.7	108.0	3,457,144.5	1,990.9	1.0	0.8
Maximum:	8.5	13.4	6.3	146.5	3,541,266.2	2,279.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/08/2022 00:00	7.7	13.2	5.9	119.2	3,531,300.0	2,140.3	1.1	0.9
12/08/2022 01:00	7.7	13.2	5.9	118.7	3,521,730.5	2,134.5	1.1	0.9
12/08/2022 02:00	7.8	13.2	6.0	118.7	3,516,285.8	2,131.2	1.1	0.9
12/08/2022 03:00	7.8	13.2	6.0	118.2	3,554,992.3	2,128.7	1.1	0.9
12/08/2022 04:00	7.8	13.1	5.9	120.9	3,553,243.8	2,153.6	1.1	0.9
12/08/2022 05:00	7.9	13.1	6.0	128.8	3,562,758.9	2,211.4	1.2	1.1
12/08/2022 06:00	8.0	13.0	6.0	140.2	3,517,882.0	2,286.3	1.3	1.1
12/08/2022 07:00	8.3	13.0	6.2	134.7	3,527,605.7	2,241.1	1.2	1.1
12/08/2022 08:00	7.3	13.3	5.7	110.6	3,525,314.4	2,033.7	1.0	0.8
12/08/2022 09:00	7.7	13.2	5.9	115.7	3,569,294.8	2,111.2	1.0	0.8
12/08/2022 10:00	7.7	13.2	5.9	116.8	3,538,793.0	2,119.0	1.1	0.8
12/08/2022 11:00	7.8	13.1	5.9	120.1	3,505,889.4	2,150.5	1.1	0.9
12/08/2022 12:00	7.8	13.1	5.9	121.1	3,509,639.1	2,152.8	1.1	0.9
12/08/2022 13:00	7.9	13.1	6.0	123.3	3,491,065.5	2,166.9	1.1	0.9
12/08/2022 14:00	7.9	13.1	6.0	124.5	3,467,191.5	2,177.4	1.2	1.1
12/08/2022 15:00	7.9	13.1	6.0	126.1	3,477,541.8	2,183.9	1.2	1.1
12/08/2022 16:00	8.2	12.9	6.0	144.4	3,474,838.3	2,283.7	1.4	1.1
12/08/2022 17:00	8.1	12.9	6.0	142.8	3,476,359.9	2,284.7	1.3	1.1
12/08/2022 18:00	8.2	12.9	6.0	144.4	3,480,620.3	2,287.5	1.4	1.1
12/08/2022 19:00	8.1	12.9	6.0	145.1	3,478,033.6	2,285.8	1.4	1.1
12/08/2022 20:00	8.1	12.9	6.0	141.5	3,480,468.2	2,287.4	1.3	1.1
12/08/2022 21:00	8.1	12.9	6.0	142.3	3,476,816.4	2,285.0	1.3	1.1
12/08/2022 22:00	7.9	13.0	5.9	126.2	3,494,102.2	2,194.3	1.2	1.1
12/08/2022 23:00	7.9	13.1	6.0	126.0	3,496,331.5	2,195.7	1.2	1.1
Average/Sum#:	7.9	13.1	6.0	127.9	3,509,504.1	2,192.8	1.2	1.0
Minimum:	7.3	12.9	5.7	110.6	3,467,191.5	2,033.7	1.0	0.8
Maximum:	8.3	13.3	6.2	145.1	3,569,294.8	2,287.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/09/2022 00:00	7.7	13.1	5.8	120.7	3,495,781.8	2,144.3	1.1	0.9
12/09/2022 01:00	7.4	13.2	5.7	112.0	3,502,645.2	2,046.2	1.0	0.8
12/09/2022 02:00	7.8	13.1	5.9	120.1	3,534,599.8	2,142.3	1.1	0.9
12/09/2022 03:00	7.8	13.1	5.9	120.2	3,537,734.7	2,144.2	1.1	0.9
12/09/2022 04:00	7.8	13.1	5.9	123.7	3,536,176.0	2,194.9	1.1	0.9
12/09/2022 05:00	8.0	13.0	6.0	140.1	3,533,114.9	2,296.2	1.3	1.1
12/09/2022 06:00	7.9	13.0	5.9	138.3	3,536,807.7	2,298.6	1.3	1.1
12/09/2022 07:00	8.3	13.0	6.2	138.5	3,518,651.3	2,286.8	1.3	1.1
12/09/2022 08:00	7.4	13.2	5.7	113.4	3,547,665.0	2,072.5	1.0	0.8
12/09/2022 09:00	7.3	13.3	5.7	110.2	3,523,927.6	2,032.9	1.0	0.8
12/09/2022 10:00	7.0	13.4	5.5	106.0	3,529,024.4	1,984.3	1.0	0.8
12/09/2022 11:00	7.7	13.2	5.9	115.2	3,506,740.8	2,074.2	1.1	0.8
12/09/2022 12:00	7.3	13.3	5.7	109.4	3,480,418.1	2,007.8	1.0	0.8
12/09/2022 13:00	7.9	13.1	6.0	122.8	3,480,271.2	2,160.2	1.1	0.9
12/09/2022 14:00	7.9	13.1	6.0	123.2	3,484,943.4	2,163.1	1.1	0.9
12/09/2022 15:00	7.5	13.2	5.7	112.9	3,518,736.0	2,055.6	1.0	0.8
12/09/2022 16:00	8.2	12.9	6.0	142.0	3,478,337.9	2,286.0	1.3	1.1
12/09/2022 17:00	8.1	13.0	6.0	140.9	3,477,577.1	2,285.5	1.3	1.1
12/09/2022 18:00	8.0	12.9	5.9	141.9	3,478,185.8	2,285.9	1.3	1.1
12/09/2022 19:00	8.0	12.9	5.9	141.2	3,480,163.8	2,287.2	1.3	1.1
12/09/2022 20:00	8.0	12.9	5.9	142.2	3,483,207.0	2,289.2	1.3	1.1
12/09/2022 21:00	8.0	13.0	6.0	143.6	3,481,228.9	2,287.9	1.3	1.1
12/09/2022 22:00	8.0	12.9	5.9	140.8	3,479,250.9	2,286.6	1.3	1.1
12/09/2022 23:00	8.0	13.0	6.0	141.0	3,469,817.1	2,280.4	1.3	1.1
Average/Sum#:	7.8	13.1	5.9	127.5	3,503,958.6	2,183.0	1.2	1.0
Minimum:	7.0	12.9	5.5	106.0	3,469,817.1	1,984.3	1.0	0.8
Maximum:	8.3	13.4	6.2	143.6	3,547,665.0	2,298.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/10/2022 00:00	7.3	13.3	5.7	110.5	3,502,259.5	2,020.4	1.0	0.8
12/10/2022 01:00	7.3	13.3	5.7	109.6	3,495,325.7	2,016.4	1.0	0.8
12/10/2022 02:00	7.2	13.3	5.6	106.4	3,477,109.0	1,980.5	1.0	0.8
12/10/2022 03:00	7.5	13.3	5.8	108.4	3,478,337.9	1,981.2	1.0	0.8
12/10/2022 04:00	7.3	13.3	5.7	107.2	3,469,735.1	1,976.3	1.0	0.8
12/10/2022 05:00	7.4	13.3	5.7	108.2	3,443,842.3	1,986.7	1.0	0.8
12/10/2022 06:00	7.4	13.3	5.7	107.2	3,464,994.8	1,973.6	1.0	0.8
12/10/2022 07:00	7.8	13.3	6.1	109.3	3,477,986.8	1,981.0	1.0	0.8
12/10/2022 08:00	7.8	13.2	6.0	112.6	3,459,850.7	2,021.2	1.0	0.8
12/10/2022 09:00	7.7	13.2	5.9	110.7	3,420,479.8	1,998.2	1.0	0.8
12/10/2022 10:00	7.7	13.2	5.9	108.9	3,422,694.2	1,974.5	1.0	0.8
12/10/2022 11:00	7.8	13.2	6.0	112.3	3,407,330.7	2,015.4	1.1	0.8
12/10/2022 12:00	8.0	13.0	6.0	121.1	3,417,277.7	2,121.1	1.1	0.8
12/10/2022 13:00	8.1	13.0	6.0	129.0	3,358,321.0	2,182.6	1.2	1.1
12/10/2022 14:00	7.8	13.1	5.9	114.5	3,370,120.0	2,018.0	1.1	0.8
12/10/2022 15:00	8.0	13.1	6.1	117.9	3,372,083.8	2,043.8	1.1	0.8
12/10/2022 16:00	8.1	13.1	6.1	125.5	3,403,583.5	2,112.6	1.2	1.1
12/10/2022 17:00	7.9	13.1	6.0	119.8	3,377,750.5	2,071.9	1.1	0.8
12/10/2022 18:00	8.0	13.1	6.1	118.1	3,419,931.2	2,072.8	1.1	0.8
12/10/2022 19:00	8.3	12.9	6.1	146.0	3,390,153.0	2,252.8	1.4	1.1
12/10/2022 20:00	8.1	13.0	6.0	130.3	3,423,718.4	2,175.1	1.2	1.1
12/10/2022 21:00	7.8	13.1	5.9	119.7	3,391,933.8	2,080.6	1.1	0.8
12/10/2022 22:00	7.8	13.2	6.0	112.5	3,450,949.4	2,016.0	1.0	0.8
12/10/2022 23:00	7.9	13.1	6.0	119.3	3,427,520.7	2,077.4	1.1	0.8
Average/Sum#:	7.8	13.2	5.9	116.0	3,430,137.1	2,047.9	1.1	0.9
Minimum:	7.2	12.9	5.6	106.4	3,358,321.0	1,973.6	1.0	0.8
Maximum:	8.3	13.3	6.1	146.0	3,502,259.5	2,252.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/11/2022 00:00	7.5	13.3	5.8	108.1	3,454,285.2	1,967.5	1.0	0.8
12/11/2022 01:00	7.4	13.3	5.7	107.6	3,449,896.0	1,965.0	1.0	0.8
12/11/2022 02:00	7.5	13.3	5.8	107.7	3,449,720.5	1,964.9	1.0	0.8
12/11/2022 03:00	7.4	13.3	5.7	107.3	3,450,598.3	1,965.4	1.0	0.8
12/11/2022 04:00	7.2	13.3	5.6	106.6	3,456,918.7	1,969.0	1.0	0.8
12/11/2022 05:00	7.1	13.3	5.5	106.1	3,454,811.9	1,967.8	1.0	0.8
12/11/2022 06:00	7.1	13.3	5.5	106.2	3,457,621.0	1,969.4	1.0	0.8
12/11/2022 07:00	7.4	13.4	5.8	107.3	3,507,149.2	1,972.0	1.0	0.8
12/11/2022 08:00	7.2	13.4	5.7	106.6	3,510,172.6	1,973.7	1.0	0.8
12/11/2022 09:00	7.2	13.3	5.6	107.0	3,460,430.1	1,971.0	1.0	0.8
12/11/2022 10:00	7.5	13.3	5.8	108.3	3,457,269.9	1,969.2	1.0	0.8
12/11/2022 11:00	7.6	13.3	5.9	108.6	3,453,231.8	1,966.9	1.0	0.8
12/11/2022 12:00	7.7	13.3	6.0	108.6	3,453,056.3	1,966.8	1.0	0.8
12/11/2022 13:00	7.8	13.3	6.1	109.3	3,455,689.8	1,968.3	1.0	0.8
12/11/2022 14:00	7.8	13.3	6.1	109.0	3,447,262.5	1,963.5	1.0	0.8
12/11/2022 15:00	8.0	13.2	6.1	117.7	3,441,430.3	2,060.7	1.1	0.8
12/11/2022 16:00	7.7	13.2	5.9	115.6	3,497,273.2	2,068.6	1.1	0.8
12/11/2022 17:00	7.8	13.1	5.9	121.3	3,491,054.0	2,141.4	1.1	0.9
12/11/2022 18:00	7.4	13.2	5.7	112.2	3,505,897.6	2,048.1	1.0	0.8
12/11/2022 19:00	7.6	13.2	5.8	113.9	3,494,061.0	2,066.7	1.0	0.8
12/11/2022 20:00	7.7	13.1	5.8	118.4	3,498,136.8	2,120.2	1.1	0.8
12/11/2022 21:00	7.1	13.3	5.5	108.2	3,516,611.6	2,003.0	1.0	0.8
12/11/2022 22:00	7.0	13.4	5.5	105.8	3,508,394.1	1,972.7	1.0	0.8
12/11/2022 23:00	7.1	13.4	5.6	106.1	3,511,239.7	1,974.3	1.0	0.8
Average/Sum#:	7.5	13.3	5.8	109.7	3,474,258.8	1,999.0	1.0	0.8
Minimum:	7.0	13.1	5.5	105.8	3,441,430.3	1,963.5	1.0	0.8
Maximum:	8.0	13.4	6.1	121.3	3,516,611.6	2,141.4	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/12/2022 00:00	7.0	13.4	5.5	106.2	3,524,222.5	1,981.6	1.0	0.8
12/12/2022 01:00	7.0	13.4	5.5	106.1	3,525,467.5	1,982.3	1.0	0.8
12/12/2022 02:00	7.0	13.4	5.5	106.1	3,523,866.8	1,981.4	1.0	0.8
12/12/2022 03:00	6.9	13.4	5.4	105.8	3,518,531.4	1,978.4	1.0	0.8
12/12/2022 04:00	6.9	13.4	5.4	105.7	3,517,642.2	1,977.9	1.0	0.8
12/12/2022 05:00	7.6	13.2	5.8	117.4	3,539,127.0	2,119.2	1.1	0.8
12/12/2022 06:00	7.8	13.1	5.9	129.3	3,491,402.6	2,218.1	1.2	1.1
12/12/2022 07:00	8.1	13.1	6.1	126.9	3,501,427.1	2,198.9	1.2	1.1
12/12/2022 08:00	7.4	13.2	5.7	114.6	3,510,967.4	2,076.7	1.0	0.8
12/12/2022 09:00	7.5	13.2	5.7	114.0	3,541,331.5	2,068.8	1.0	0.8
12/12/2022 10:00	6.9	13.4	5.4	105.1	3,555,097.8	1,973.0	0.9	0.6
12/12/2022 11:00	6.9	13.4	5.4	105.1	3,503,947.9	1,970.2	1.0	0.8
12/12/2022 12:00	7.1	13.4	5.6	105.7	3,504,659.3	1,970.6	1.0	0.8
12/12/2022 13:00	7.1	13.4	5.6	105.8	3,502,880.9	1,969.6	1.0	0.8
12/12/2022 14:00	7.2	13.4	5.7	106.3	3,500,035.3	1,968.0	1.0	0.8
12/12/2022 15:00	7.4	13.4	5.8	106.9	3,499,501.8	1,967.7	1.0	0.8
12/12/2022 16:00	8.1	13.1	6.1	130.7	3,511,432.4	2,153.9	1.2	1.1
12/12/2022 17:00	8.2	13.0	6.1	143.6	3,501,680.4	2,250.2	1.3	1.1
12/12/2022 18:00	8.2	13.0	6.1	152.5	3,483,003.0	2,314.5	1.4	1.2
12/12/2022 19:00	8.2	13.0	6.1	154.7	3,485,862.2	2,316.4	1.5	1.4
12/12/2022 20:00	8.2	13.0	6.1	156.3	3,491,731.2	2,320.3	1.5	1.4
12/12/2022 21:00	8.0	13.0	6.0	140.8	3,492,647.7	2,269.9	1.3	1.1
12/12/2022 22:00	7.9	13.1	6.0	131.1	3,506,204.1	2,201.9	1.2	1.1
12/12/2022 23:00	7.3	13.3	5.7	110.7	3,527,741.2	2,035.1	1.0	0.8
Average/Sum#:	7.5	13.2	5.8	120.3	3,510,850.5	2,094.4	1.1	0.9
Minimum:	6.9	13.0	5.4	105.1	3,483,003.0	1,967.7	0.9	0.6
Maximum:	8.2	13.4	6.1	156.3	3,555,097.8	2,320.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/13/2022 00:00	7.7	13.1	5.8	119.3	3,556,048.6	2,155.3	1.1	0.9
12/13/2022 01:00	7.8	13.1	5.9	122.0	3,525,289.6	2,162.4	1.1	0.9
12/13/2022 02:00	7.9	13.1	6.0	125.9	3,539,309.9	2,171.0	1.1	0.9
12/13/2022 03:00	7.8	13.1	5.9	125.0	3,523,659.4	2,161.4	1.1	0.9
12/13/2022 04:00	7.8	13.1	5.9	126.2	3,547,131.4	2,201.7	1.2	1.1
12/13/2022 05:00	7.8	13.0	5.8	138.3	3,558,324.8	2,286.6	1.3	1.1
12/13/2022 06:00	8.0	13.0	6.0	146.8	3,535,397.3	2,323.5	1.4	1.2
12/13/2022 07:00	8.5	13.0	6.3	148.9	3,521,703.0	2,314.5	1.4	1.2
12/13/2022 08:00	7.7	13.2	5.9	128.5	3,504,585.2	2,149.7	1.2	1.1
12/13/2022 09:00	7.3	13.3	5.7	108.9	3,534,870.6	2,013.4	1.0	0.8
12/13/2022 10:00	6.9	13.4	5.4	104.9	3,564,467.5	1,978.2	0.9	0.6
12/13/2022 11:00	7.3	13.4	5.7	106.7	3,508,572.0	1,972.8	1.0	0.8
12/13/2022 12:00	7.5	13.4	5.9	107.6	3,506,437.8	1,971.6	1.0	0.8
12/13/2022 13:00	7.5	13.4	5.9	107.7	3,503,414.4	1,969.9	1.0	0.8
12/13/2022 14:00	7.5	13.4	5.9	107.6	3,501,102.4	1,968.6	1.0	0.8
12/13/2022 15:00	7.9	13.2	6.1	121.1	3,510,122.1	2,076.2	1.1	0.8
12/13/2022 16:00	8.4	13.0	6.3	152.5	3,472,708.1	2,282.3	1.4	1.1
12/13/2022 17:00	8.2	13.0	6.1	154.0	3,459,978.6	2,299.2	1.5	1.4
12/13/2022 18:00	8.2	13.0	6.1	153.9	3,495,531.8	2,297.3	1.4	1.1
12/13/2022 19:00	8.1	13.0	6.0	152.2	3,494,618.9	2,296.7	1.4	1.1
12/13/2022 20:00	8.0	13.0	6.0	146.3	3,489,445.5	2,293.3	1.4	1.1
12/13/2022 21:00	8.0	13.0	6.0	143.5	3,528,652.7	2,293.3	1.3	1.1
12/13/2022 22:00	8.0	13.0	6.0	148.1	3,534,961.3	2,297.4	1.4	1.1
12/13/2022 23:00	8.0	13.0	6.0	147.0	3,489,749.8	2,293.5	1.4	1.1
Average/Sum#:	7.8	13.1	5.9	131.0	3,516,920.1	2,176.2	1.2	1.0
Minimum:	6.9	13.0	5.4	104.9	3,459,978.6	1,968.6	0.9	0.6
Maximum:	8.5	13.4	6.3	154.0	3,564,467.5	2,323.5	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/14/2022 00:00	7.8	13.1	5.9	127.7	3,546,003.6	2,201.0	1.2	1.1
12/14/2022 01:00	7.7	13.1	5.8	125.9	3,553,736.8	2,205.8	1.1	0.9
12/14/2022 02:00	7.8	13.1	5.9	127.9	3,556,475.7	2,207.5	1.2	1.1
12/14/2022 03:00	7.7	13.1	5.8	124.7	3,589,848.2	2,202.0	1.1	0.9
12/14/2022 04:00	7.7	13.1	5.8	123.7	3,579,740.6	2,195.8	1.1	0.9
12/14/2022 05:00	7.9	13.0	5.9	144.8	3,550,194.2	2,307.3	1.3	1.2
12/14/2022 06:00	7.9	13.0	5.9	143.9	3,556,041.2	2,311.1	1.3	1.2
12/14/2022 07:00	8.3	13.0	6.2	142.3	3,544,630.5	2,277.8	1.3	1.1
12/14/2022 08:00	7.5	13.3	5.8	113.4	3,562,215.2	2,081.0	1.0	0.8
12/14/2022 09:00	7.2	13.3	5.6	108.4	3,530,832.5	2,011.1	1.0	0.8
12/14/2022 10:00	7.4	13.3	5.7	110.2	3,516,127.1	2,028.4	1.0	0.8
12/14/2022 11:00	6.9	13.4	5.4	105.2	3,512,306.8	1,974.9	1.0	0.8
12/14/2022 12:00	6.9	13.4	5.4	105.3	3,515,152.3	1,976.5	1.0	0.8
12/14/2022 13:00	6.9	13.4	5.4	105.3	3,518,353.6	1,978.3	1.0	0.8
12/14/2022 14:00	6.9	13.4	5.4	105.1	3,512,840.3	1,975.2	1.0	0.8
12/14/2022 15:00	7.3	13.3	5.7	109.2	3,543,648.9	2,018.4	1.0	0.8
12/14/2022 16:00	8.2	13.1	6.2	135.8	3,493,448.8	2,219.4	1.3	1.1
12/14/2022 17:00	8.1	13.0	6.0	146.5	3,486,250.2	2,291.2	1.4	1.1
12/14/2022 18:00	8.1	13.0	6.0	148.1	3,481,533.3	2,288.1	1.4	1.1
12/14/2022 19:00	8.1	13.0	6.0	147.4	3,488,380.4	2,292.6	1.4	1.1
12/14/2022 20:00	8.1	13.0	6.0	146.0	3,528,037.3	2,292.9	1.4	1.1
12/14/2022 21:00	8.0	13.0	6.0	146.3	3,525,575.4	2,291.3	1.4	1.1
12/14/2022 22:00	7.9	13.0	5.9	140.1	3,525,022.9	2,265.2	1.3	1.1
12/14/2022 23:00	7.8	13.1	5.9	126.6	3,551,700.0	2,178.6	1.2	1.1
Average/Sum#:	7.7	13.1	5.8	127.5	3,532,004.0	2,169.6	1.2	1.0
Minimum:	6.9	13.0	5.4	105.1	3,481,533.3	1,974.9	1.0	0.8
Maximum:	8.3	13.4	6.2	148.1	3,589,848.2	2,311.1	1.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/15/2022 00:00	8.1	13.0	6.0	147.1	3,538,961.9	2,300.0	1.4	1.2
12/15/2022 01:00	8.1	13.0	6.0	148.2	3,515,921.0	2,310.7	1.4	1.2
12/15/2022 02:00	8.1	13.0	6.0	150.4	3,515,921.0	2,310.7	1.4	1.2
12/15/2022 03:00	8.1	13.0	6.0	151.6	3,518,659.9	2,312.5	1.4	1.2
12/15/2022 04:00	8.1	13.0	6.0	151.2	3,526,267.8	2,317.5	1.4	1.2
12/15/2022 05:00	8.1	13.0	6.0	154.3	3,530,376.1	2,320.2	1.4	1.2
12/15/2022 06:00	8.1	13.0	6.0	176.5	3,529,463.1	2,319.6	1.7	1.6
12/15/2022 07:00	8.7	13.0	6.5	154.4	3,522,159.5	2,314.8	1.4	1.2
12/15/2022 08:00	8.1	13.1	6.1	138.6	3,514,698.5	2,232.9	1.3	1.1
12/15/2022 09:00	8.2	13.1	6.2	143.1	3,472,113.3	2,231.2	1.3	1.1
12/15/2022 10:00	7.4	13.4	5.8	108.7	3,473,948.8	1,978.7	1.0	0.8
12/15/2022 11:00	7.7	13.3	6.0	110.8	3,494,314.6	1,990.3	1.0	0.8
12/15/2022 12:00	7.9	13.3	6.1	116.4	3,463,103.1	2,023.1	1.1	0.8
12/15/2022 13:00	8.2	13.2	6.3	125.2	3,457,543.0	2,045.1	1.2	1.0
12/15/2022 14:00	8.3	13.2	6.4	135.0	3,469,098.4	2,102.6	1.3	1.1
12/15/2022 15:00	8.6	13.0	6.4	160.1	3,435,733.6	2,258.0	1.5	1.4
12/15/2022 16:00	8.3	13.0	6.2	154.6	3,453,992.6	2,270.0	1.5	1.4
12/15/2022 17:00	8.3	13.0	6.2	156.1	3,451,101.6	2,268.1	1.5	1.4
12/15/2022 18:00	8.1	13.0	6.0	145.5	3,474,645.1	2,258.2	1.4	1.1
12/15/2022 19:00	8.1	13.0	6.0	141.7	3,464,028.2	2,251.3	1.3	1.1
12/15/2022 20:00	8.2	13.0	6.1	148.1	3,466,644.0	2,253.0	1.4	1.1
12/15/2022 21:00	8.1	13.0	6.0	144.7	3,508,527.5	2,254.6	1.3	1.1
12/15/2022 22:00	8.1	13.0	6.0	143.0	3,517,086.4	2,260.1	1.3	1.1
12/15/2022 23:00	7.9	13.1	6.0	135.0	3,529,809.4	2,242.5	1.2	1.1
Average/Sum#:	8.1	13.1	6.1	143.3	3,493,504.9	2,226.1	1.3	1.1
Minimum:	7.4	13.0	5.8	108.7	3,435,733.6	1,978.7	1.0	0.8
Maximum:	8.7	13.4	6.5	176.5	3,538,961.9	2,320.2	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/16/2022 00:00	6.9	13.4	5.4	107.0	3,507,306.5	1,997.7	1.0	0.8
12/16/2022 01:00	6.9	13.4	5.4	105.2	3,512,484.6	1,975.0	1.0	0.8
12/16/2022 02:00	6.9	13.4	5.4	105.5	3,512,662.5	1,975.1	1.0	0.8
12/16/2022 03:00	6.9	13.4	5.4	105.4	3,517,642.2	1,977.9	1.0	0.8
12/16/2022 04:00	6.8	13.4	5.3	105.1	3,514,263.1	1,976.0	1.0	0.8
12/16/2022 05:00	7.0	13.4	5.5	106.1	3,532,581.4	1,986.3	1.0	0.8
12/16/2022 06:00	7.7	13.3	6.0	125.9	3,531,611.9	2,114.7	1.1	0.8
12/16/2022 07:00	8.4	13.1	6.4	135.2	3,565,981.1	2,213.4	1.2	1.1
12/16/2022 08:00	7.9	13.2	6.1	122.3	3,545,159.2	2,148.7	1.1	0.9
12/16/2022 09:00	7.5	13.3	5.8	120.3	3,504,881.1	2,073.1	1.1	0.8
12/16/2022 10:00	6.7	13.7	5.5	90.9	3,000,800.1	1,533.9	1.0	0.6
12/16/2022 11:00	6.9	13.8	5.7	86.0	2,887,699.2	1,455.0	0.9	0.4
12/16/2022 12:00	7.3	13.8	6.1	82.3	2,619,569.9	1,319.9	1.0	0.5
12/16/2022 13:00	7.3	13.8	6.1	82.4	2,624,134.7	1,322.2	1.0	0.5
12/16/2022 14:00	7.1	13.7	5.8	93.7	3,085,508.8	1,577.2	1.0	0.6
12/16/2022 15:00	7.2	13.8	6.0	91.8	3,032,296.9	1,550.0	1.0	0.6
12/16/2022 16:00	8.4	13.1	6.4	129.7	3,490,904.4	2,166.8	1.2	1.1
12/16/2022 17:00	8.3	13.0	6.2	143.2	3,480,672.2	2,236.7	1.3	1.1
12/16/2022 18:00	8.0	13.1	6.1	129.3	3,483,815.6	2,162.4	1.2	1.1
12/16/2022 19:00	8.1	13.1	6.1	133.6	3,493,965.5	2,168.7	1.2	1.1
12/16/2022 20:00	8.3	13.0	6.2	151.6	3,471,875.5	2,256.4	1.4	1.1
12/16/2022 21:00	8.1	13.1	6.1	140.1	3,461,180.8	2,198.9	1.3	1.1
12/16/2022 22:00	7.4	13.3	5.7	124.4	3,489,527.1	2,089.5	1.2	1.0
12/16/2022 23:00	6.9	13.4	5.4	105.1	3,512,662.5	1,975.1	1.0	0.8
Average/Sum#:	7.5	13.4	5.8	113.4	3,349,132.8	1,935.4	1.1	0.8
Minimum:	6.7	13.0	5.3	82.3	2,619,569.9	1,319.9	0.9	0.4
Maximum:	8.4	13.8	6.4	151.6	3,565,981.1	2,256.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/17/2022 00:00	8.0	13.2	6.1	124.8	3,502,302.9	2,148.3	1.1	0.9
12/17/2022 01:00	7.9	13.2	6.1	125.0	3,507,030.6	2,151.2	1.1	0.9
12/17/2022 02:00	7.8	13.2	6.0	123.1	3,535,094.8	2,142.6	1.1	0.9
12/17/2022 03:00	7.8	13.2	6.0	125.4	3,552,913.8	2,153.4	1.1	0.9
12/17/2022 04:00	7.8	13.2	6.0	124.7	3,512,247.5	2,154.4	1.1	0.9
12/17/2022 05:00	7.8	13.2	6.0	124.1	3,549,449.0	2,151.3	1.1	0.9
12/17/2022 06:00	8.0	13.1	6.1	140.8	3,489,231.1	2,242.2	1.3	1.1
12/17/2022 07:00	8.0	13.3	6.2	121.6	3,505,893.4	2,099.3	1.1	0.8
12/17/2022 08:00	8.0	13.2	6.1	125.4	3,530,995.6	2,165.9	1.1	0.9
12/17/2022 09:00	7.7	13.2	5.9	119.0	3,548,479.2	2,124.8	1.1	0.8
12/17/2022 10:00	7.1	13.4	5.6	108.0	3,528,023.5	2,009.5	1.0	0.8
12/17/2022 11:00	6.9	13.4	5.4	105.1	3,516,575.1	1,977.3	1.0	0.8
12/17/2022 12:00	7.1	13.4	5.6	106.1	3,503,592.3	1,970.0	1.0	0.8
12/17/2022 13:00	7.4	13.4	5.8	107.2	3,503,947.9	1,970.2	1.0	0.8
12/17/2022 14:00	7.6	13.4	6.0	109.5	3,495,719.1	1,991.1	1.0	0.8
12/17/2022 15:00	8.0	13.2	6.1	126.2	3,505,066.5	2,124.4	1.2	1.1
12/17/2022 16:00	8.3	13.0	6.2	155.1	3,467,839.0	2,279.1	1.5	1.4
12/17/2022 17:00	8.1	13.0	6.0	144.2	3,458,027.4	2,247.4	1.4	1.1
12/17/2022 18:00	7.8	13.1	5.9	127.9	3,479,465.7	2,159.7	1.2	1.1
12/17/2022 19:00	8.1	13.0	6.0	154.2	3,481,381.1	2,288.0	1.5	1.4
12/17/2022 20:00	8.0	13.0	6.0	151.1	3,486,554.5	2,291.4	1.4	1.1
12/17/2022 21:00	8.0	13.0	6.0	153.5	3,487,923.9	2,292.3	1.4	1.1
12/17/2022 22:00	8.0	13.0	6.0	151.5	3,475,599.1	2,284.2	1.4	1.1
12/17/2022 23:00	7.7	13.1	5.8	133.2	3,491,236.0	2,192.5	1.2	1.1
Average/Sum#:	7.8	13.2	6.0	128.6	3,504,774.5	2,150.4	1.2	1.0
Minimum:	6.9	13.0	5.4	105.1	3,458,027.4	1,970.0	1.0	0.8
Maximum:	8.3	13.4	6.2	155.1	3,552,913.8	2,292.3	1.5	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/18/2022 00:00	7.7	13.2	5.9	122.0	3,491,054.0	2,141.4	1.1	0.9
12/18/2022 01:00	7.6	13.2	5.8	118.2	3,532,125.0	2,140.8	1.1	0.9
12/18/2022 02:00	7.2	13.3	5.6	108.9	3,552,954.0	2,023.7	1.0	0.8
12/18/2022 03:00	6.9	13.4	5.4	105.2	3,577,080.6	1,985.2	0.9	0.6
12/18/2022 04:00	7.7	13.2	5.9	117.8	3,574,364.6	2,140.3	1.1	0.9
12/18/2022 05:00	7.7	13.2	5.9	121.5	3,567,103.0	2,162.0	1.1	0.9
12/18/2022 06:00	7.7	13.2	5.9	126.6	3,515,554.1	2,182.1	1.2	1.1
12/18/2022 07:00	8.2	13.1	6.2	128.8	3,533,911.1	2,219.3	1.2	1.1
12/18/2022 08:00	7.5	13.2	5.7	121.7	3,493,201.2	2,091.7	1.1	0.8
12/18/2022 09:00	6.7	13.7	5.5	94.8	3,145,567.8	1,607.9	1.0	0.6
12/18/2022 10:00	6.9	13.7	5.7	92.3	3,036,600.8	1,552.2	1.0	0.6
12/18/2022 11:00	6.9	13.7	5.7	92.2	3,021,341.5	1,544.4	1.0	0.6
12/18/2022 12:00	6.9	13.7	5.7	83.4	2,787,076.3	1,404.3	0.9	0.4
12/18/2022 13:00	7.0	13.8	5.8	82.4	2,770,206.6	1,395.8	0.9	0.4
12/18/2022 14:00	7.0	13.7	5.7	96.8	3,198,192.8	1,634.8	1.0	0.7
12/18/2022 15:00	7.4	13.7	6.1	98.3	3,219,908.0	1,645.9	1.0	0.7
12/18/2022 16:00	8.2	13.2	6.3	127.3	3,494,151.5	2,143.3	1.2	1.1
12/18/2022 17:00	8.2	13.0	6.1	145.0	3,468,182.7	2,254.0	1.4	1.1
12/18/2022 18:00	8.1	13.0	6.0	147.6	3,475,142.6	2,283.9	1.4	1.1
12/18/2022 19:00	8.0	13.0	6.0	147.3	3,482,446.2	2,288.7	1.4	1.1
12/18/2022 20:00	7.8	13.0	5.8	133.4	3,533,744.5	2,245.0	1.2	1.1
12/18/2022 21:00	7.7	13.1	5.8	126.0	3,558,731.2	2,208.9	1.1	0.9
12/18/2022 22:00	7.6	13.1	5.7	126.0	3,553,575.7	2,205.7	1.2	1.1
12/18/2022 23:00	7.1	13.3	5.5	109.7	3,552,529.5	2,049.4	1.0	0.8
Average/Sum#:	7.5	13.3	5.8	115.6	3,380,614.4	1,981.3	1.1	0.8
Minimum:	6.7	13.0	5.4	82.4	2,770,206.6	1,395.8	0.9	0.4
Maximum:	8.2	13.8	6.3	147.6	3,577,080.6	2,288.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/19/2022 00:00	7.6	13.1	5.7	116.6	3,577,036.7	2,141.9	1.1	0.9
12/19/2022 01:00	7.6	13.1	5.7	117.9	3,553,078.8	2,153.5	1.1	0.9
12/19/2022 02:00	7.6	13.1	5.7	117.3	3,546,809.2	2,149.7	1.1	0.9
12/19/2022 03:00	7.5	13.1	5.7	117.4	3,550,768.9	2,152.1	1.1	0.9
12/19/2022 04:00	7.6	13.1	5.7	120.0	3,562,948.8	2,185.5	1.1	0.9
12/19/2022 05:00	7.8	13.0	5.8	139.8	3,553,733.2	2,309.6	1.3	1.2
12/19/2022 06:00	7.8	13.0	5.8	142.0	3,554,502.5	2,310.1	1.3	1.2
12/19/2022 07:00	8.2	13.0	6.1	138.6	3,554,502.5	2,310.1	1.3	1.2
12/19/2022 08:00	7.7	13.0	5.8	132.2	3,560,503.4	2,262.0	1.2	1.1
12/19/2022 09:00	7.8	13.0	5.8	133.8	3,539,184.0	2,274.3	1.2	1.1
12/19/2022 10:00	7.5	13.1	5.7	119.6	3,556,427.7	2,181.5	1.1	0.9
12/19/2022 11:00	7.5	13.1	5.7	119.5	3,556,916.8	2,181.8	1.1	0.9
12/19/2022 12:00	7.5	13.1	5.7	118.9	3,587,066.9	2,174.1	1.1	0.9
12/19/2022 13:00	7.6	13.1	5.7	118.3	3,571,557.8	2,164.7	1.1	0.9
12/19/2022 14:00	7.6	13.1	5.7	119.0	3,575,022.6	2,166.8	1.1	0.9
12/19/2022 15:00	7.8	13.1	5.9	129.5	3,552,541.6	2,231.0	1.2	1.1
12/19/2022 16:00	7.8	13.0	5.8	135.3	3,539,495.2	2,274.5	1.2	1.1
12/19/2022 17:00	7.8	13.0	5.8	134.6	3,540,273.3	2,275.0	1.2	1.1
12/19/2022 18:00	7.8	13.0	5.8	133.6	3,543,541.2	2,277.1	1.2	1.1
12/19/2022 19:00	7.8	13.0	5.8	135.5	3,548,520.9	2,280.3	1.2	1.1
12/19/2022 20:00	7.8	13.0	5.8	133.8	3,584,429.0	2,277.2	1.2	1.1
12/19/2022 21:00	7.8	13.0	5.8	134.0	3,584,743.8	2,277.4	1.2	1.1
12/19/2022 22:00	7.8	13.0	5.8	134.6	3,553,189.4	2,283.3	1.2	1.1
12/19/2022 23:00	7.8	13.0	5.8	134.0	3,546,186.7	2,278.8	1.2	1.1
Average/Sum#:	7.7	13.0	5.8	128.2	3,558,040.9	2,232.2	1.2	1.0
Minimum:	7.5	13.0	5.7	116.6	3,539,184.0	2,141.9	1.1	0.9
Maximum:	8.2	13.1	6.1	142.0	3,587,066.9	2,310.1	1.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/20/2022 00:00	7.6	13.1	5.7	119.5	3,597,791.3	2,180.6	1.1	0.9
12/20/2022 01:00	7.6	13.1	5.7	119.1	3,594,986.5	2,178.9	1.1	0.9
12/20/2022 02:00	7.6	13.1	5.7	119.8	3,560,829.5	2,184.2	1.1	0.9
12/20/2022 03:00	7.6	13.1	5.7	120.1	3,569,632.9	2,189.6	1.1	0.9
12/20/2022 04:00	7.6	13.1	5.7	120.3	3,571,426.2	2,190.7	1.1	0.9
12/20/2022 05:00	7.6	13.1	5.7	120.2	3,571,589.2	2,190.8	1.1	0.9
12/20/2022 06:00	7.8	13.0	5.8	139.0	3,566,105.6	2,291.6	1.3	1.1
12/20/2022 07:00	8.2	13.0	6.1	134.5	3,555,523.7	2,284.8	1.2	1.1
12/20/2022 08:00	7.7	13.1	5.8	119.9	3,580,962.3	2,170.4	1.1	0.9
12/20/2022 09:00	7.7	13.1	5.8	120.2	3,537,679.7	2,170.0	1.1	0.9
12/20/2022 10:00	7.7	13.1	5.8	118.1	3,554,157.3	2,128.2	1.1	0.9
12/20/2022 11:00	7.6	13.2	5.8	115.9	3,542,075.3	2,095.1	1.1	0.8
12/20/2022 12:00	6.8	13.4	5.3	104.3	3,534,196.0	1,961.4	0.9	0.6
12/20/2022 13:00	6.9	13.4	5.4	104.5	3,541,583.7	1,965.5	0.9	0.6
12/20/2022 14:00	6.9	13.4	5.4	104.7	3,538,880.9	1,964.0	0.9	0.6
12/20/2022 15:00	7.5	13.3	5.8	112.3	3,533,808.3	2,038.6	1.0	0.8
12/20/2022 16:00	8.1	13.1	6.1	133.3	3,502,860.2	2,199.8	1.2	1.1
12/20/2022 17:00	8.1	13.0	6.0	142.2	3,486,646.8	2,266.0	1.3	1.1
12/20/2022 18:00	8.1	13.0	6.0	143.9	3,486,492.9	2,265.9	1.3	1.1
12/20/2022 19:00	8.1	13.0	6.0	145.9	3,476,491.5	2,259.4	1.4	1.1
12/20/2022 20:00	8.1	13.0	6.0	142.3	3,477,260.9	2,259.9	1.3	1.1
12/20/2022 21:00	7.9	13.1	6.0	127.3	3,493,482.2	2,168.4	1.2	1.1
12/20/2022 22:00	7.9	13.1	6.0	126.2	3,492,676.6	2,167.9	1.2	1.1
12/20/2022 23:00	8.0	13.0	6.0	138.5	3,504,782.0	2,226.6	1.3	1.1
Average/Sum#:	7.7	13.1	5.8	124.7	3,536,330.1	2,166.6	1.1	0.9
Minimum:	6.8	13.0	5.3	104.3	3,476,491.5	1,961.4	0.9	0.6
Maximum:	8.2	13.4	6.1	145.9	3,597,791.3	2,291.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/21/2022 00:00	8.1	13.0	6.0	147.3	3,517,574.3	2,286.1	1.4	1.1
12/21/2022 01:00	8.0	13.0	6.0	145.5	3,515,727.8	2,284.9	1.4	1.1
12/21/2022 02:00	8.0	13.0	6.0	144.8	3,510,188.6	2,281.3	1.3	1.1
12/21/2022 03:00	8.0	13.0	6.0	144.1	3,522,036.4	2,289.0	1.3	1.1
12/21/2022 04:00	7.9	13.0	5.9	140.7	3,511,881.1	2,282.4	1.3	1.1
12/21/2022 05:00	7.9	13.0	5.9	141.0	3,515,420.1	2,284.7	1.3	1.1
12/21/2022 06:00	7.9	13.0	5.9	145.8	3,515,112.4	2,284.5	1.4	1.1
12/21/2022 07:00	8.4	13.0	6.3	139.5	3,513,266.0	2,283.3	1.3	1.1
12/21/2022 08:00	7.9	13.0	5.9	130.8	1,486,579.0	2,268.8	3.0	2.7
12/21/2022 09:00	7.9	13.0	5.9	132.0	3,557,197.9	2,259.9	1.2	1.1
12/21/2022 10:00	7.9	13.0	5.9	134.4	3,547,753.6	2,253.9	1.2	1.1
12/21/2022 11:00	7.8	13.0	5.8	130.5	3,533,433.4	2,219.0	1.2	1.1
12/21/2022 12:00	8.0	13.0	6.0	136.8	3,520,994.7	2,236.9	1.3	1.1
12/21/2022 13:00	8.0	13.0	6.0	136.8	3,469,934.6	2,229.8	1.3	1.1
12/21/2022 14:00	7.9	13.1	6.0	125.4	3,521,866.1	2,160.3	1.2	1.1
12/21/2022 15:00	8.1	13.0	6.0	140.3	3,476,937.4	2,234.3	1.3	1.1
12/21/2022 16:00	8.1	13.0	6.0	143.7	3,473,414.2	2,257.4	1.4	1.1
12/21/2022 17:00	8.1	13.0	6.0	144.5	3,470,029.1	2,255.2	1.4	1.1
12/21/2022 18:00	8.1	13.0	6.0	143.3	3,475,106.7	2,258.5	1.3	1.1
12/21/2022 19:00	8.1	13.0	6.0	141.6	3,471,875.5	2,256.4	1.3	1.1
12/21/2022 20:00	8.0	13.0	6.0	139.8	3,505,726.4	2,252.8	1.3	1.1
12/21/2022 21:00	8.0	13.0	6.0	137.9	3,507,127.0	2,253.7	1.3	1.1
12/21/2022 22:00	7.9	13.0	5.9	136.8	3,502,769.7	2,250.9	1.3	1.1
12/21/2022 23:00	7.8	13.0	5.8	132.6	3,499,657.4	2,248.9	1.2	1.1
Average/Sum#:	8.0	13.0	6.0	139.0	3,506,740.5	2,257.2	1.3	1.1
Minimum:	7.8	13.0	5.8	125.4	3,469,934.6	2,160.3	1.2	1.1
Maximum:	8.4	13.1	6.3	147.3	3,557,197.9	2,289.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/22/2022 00:00	7.7	13.1	5.8	122.7	3,520,709.5	2,185.3	1.1	0.9
12/22/2022 01:00	6.9	13.4	5.4	105.6	3,523,689.0	1,981.3	1.0	0.8
12/22/2022 02:00	6.9	13.4	5.4	104.9	3,501,458.1	1,968.8	1.0	0.8
12/22/2022 03:00	7.0	13.4	5.5	105.5	3,500,035.3	1,968.0	1.0	0.8
12/22/2022 04:00	7.6	13.2	5.8	114.2	3,536,496.2	2,091.8	1.0	0.8
12/22/2022 05:00	7.8	13.1	5.9	127.4	3,579,514.2	2,221.8	1.2	1.1
12/22/2022 06:00	7.9	13.0	5.9	134.9	3,530,158.2	2,268.5	1.2	1.1
12/22/2022 07:00	8.2	13.0	6.1	131.7	3,526,579.0	2,266.2	1.2	1.1
12/22/2022 08:00	7.9	13.0	5.9	130.3	3,539,883.3	2,248.9	1.2	1.1
12/22/2022 09:00	7.6	13.1	5.7	118.6	3,546,314.2	2,149.4	1.1	0.9
12/22/2022 10:00	7.6	13.1	5.7	117.8	3,541,034.5	2,146.2	1.1	0.9
12/22/2022 11:00	7.6	13.1	5.7	118.0	3,537,074.7	2,143.8	1.1	0.9
12/22/2022 12:00	7.6	13.1	5.7	118.2	3,533,279.9	2,141.5	1.1	0.9
12/22/2022 13:00	7.6	13.1	5.7	118.9	3,536,249.7	2,143.3	1.1	0.9
12/22/2022 14:00	7.6	13.1	5.7	119.4	3,546,644.2	2,149.6	1.1	0.9
12/22/2022 15:00	7.8	13.0	5.8	127.2	3,526,427.0	2,214.6	1.2	1.1
12/22/2022 16:00	7.7	13.0	5.8	127.6	3,518,624.5	2,209.7	1.2	1.1
12/22/2022 17:00	7.8	13.0	5.8	134.1	3,511,484.2	2,256.5	1.2	1.1
12/22/2022 18:00	7.9	13.0	5.9	134.1	3,518,642.6	2,261.1	1.2	1.1
12/22/2022 19:00	7.9	13.0	5.9	136.0	3,528,446.4	2,267.4	1.3	1.1
12/22/2022 20:00	7.9	13.0	5.9	134.5	3,521,132.4	2,262.7	1.2	1.1
12/22/2022 21:00	7.8	13.0	5.8	133.7	3,517,708.9	2,260.5	1.2	1.1
12/22/2022 22:00	7.7	13.0	5.8	126.7	3,527,541.7	2,215.3	1.2	1.1
12/22/2022 23:00	7.4	13.2	5.7	113.8	3,511,981.8	2,077.3	1.0	0.8
Average/Sum#:	7.6	13.1	5.8	123.2	3,528,379.6	2,170.8	1.1	1.0
Minimum:	6.9	13.0	5.4	104.9	3,500,035.3	1,968.0	1.0	0.8
Maximum:	8.2	13.4	6.1	136.0	3,579,514.2	2,268.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/23/2022 00:00	7.8	13.0	5.8	129.2	3,548,083.0	2,228.2	1.2	1.1
12/23/2022 01:00	7.8	13.0	5.8	134.9	3,525,178.5	2,265.3	1.2	1.1
12/23/2022 02:00	7.8	13.0	5.8	134.2	3,519,265.1	2,261.5	1.2	1.1
12/23/2022 03:00	7.8	13.0	5.8	134.3	3,519,420.7	2,261.6	1.2	1.1
12/23/2022 04:00	7.8	13.0	5.8	135.2	3,520,198.7	2,262.1	1.3	1.1
12/23/2022 05:00	7.8	13.0	5.8	134.0	3,516,775.2	2,259.9	1.2	1.1
12/23/2022 06:00	7.9	13.0	5.9	139.8	3,516,464.0	2,259.7	1.3	1.1
12/23/2022 07:00	8.3	13.0	6.2	132.7	3,526,031.7	2,240.1	1.2	1.1
12/23/2022 08:00	7.9	13.1	6.0	127.3	3,524,898.4	2,187.9	1.2	1.1
12/23/2022 09:00	7.9	13.1	6.0	128.2	3,516,037.4	2,182.4	1.2	1.1
12/23/2022 10:00	7.8	13.1	5.9	121.6	3,484,859.0	2,137.6	1.1	0.9
12/23/2022 11:00	7.9	13.1	6.0	122.9	3,491,543.1	2,141.7	1.1	0.9
12/23/2022 12:00	7.4	13.3	5.7	112.9	3,470,463.7	2,027.4	1.0	0.8
12/23/2022 13:00	7.1	13.4	5.6	105.8	3,485,807.5	1,960.0	1.0	0.8
12/23/2022 14:00	7.1	13.4	5.6	105.8	3,474,781.0	1,953.8	1.0	0.8
12/23/2022 15:00	7.8	13.2	6.0	117.4	3,490,679.7	2,064.7	1.1	0.8
12/23/2022 16:00	8.3	13.0	6.2	145.6	3,466,797.8	2,253.1	1.4	1.1
12/23/2022 17:00	8.2	13.0	6.1	143.2	3,468,490.4	2,254.2	1.3	1.1
12/23/2022 18:00	8.2	13.0	6.1	143.4	3,477,568.6	2,260.1	1.3	1.1
12/23/2022 19:00	8.1	13.0	6.0	141.6	3,465,720.8	2,252.4	1.3	1.1
12/23/2022 20:00	8.1	13.0	6.0	143.9	3,460,181.5	2,248.8	1.4	1.1
12/23/2022 21:00	8.1	13.0	6.0	143.9	3,466,951.7	2,253.2	1.4	1.1
12/23/2022 22:00	8.1	13.0	6.0	145.0	3,465,413.0	2,252.2	1.4	1.1
12/23/2022 23:00	8.1	13.0	6.0	142.7	3,451,103.3	2,242.9	1.4	1.1
Average/Sum#:	7.9	13.1	5.9	131.9	3,493,863.1	2,196.3	1.2	1.0
Minimum:	7.1	13.0	5.6	105.8	3,451,103.3	1,953.8	1.0	0.8
Maximum:	8.3	13.4	6.2	145.6	3,548,083.0	2,265.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/24/2022 00:00	7.8	13.1	5.9	123.3	3,473,936.2	2,130.9	1.1	0.9
12/24/2022 01:00	7.8	13.1	5.9	122.2	3,504,571.5	2,124.1	1.1	0.8
12/24/2022 02:00	6.9	13.4	5.4	105.9	3,491,498.6	1,963.2	1.0	0.8
12/24/2022 03:00	6.9	13.4	5.4	105.2	3,477,982.2	1,955.6	1.0	0.8
12/24/2022 04:00	7.0	13.4	5.5	105.6	3,476,915.2	1,955.0	1.0	0.8
12/24/2022 05:00	7.0	13.4	5.5	105.5	3,473,358.2	1,953.0	1.0	0.8
12/24/2022 06:00	7.1	13.4	5.6	107.7	3,476,055.6	1,979.9	1.0	0.8
12/24/2022 07:00	7.5	13.4	5.9	112.9	3,484,405.0	2,010.1	1.0	0.8
12/24/2022 08:00	7.0	13.5	5.6	103.7	3,354,724.6	1,837.3	1.0	0.7
12/24/2022 09:00	7.3	13.8	6.1	82.9	2,575,104.7	1,316.3	1.0	0.5
12/24/2022 10:00	7.3	13.7	6.0	93.4	3,028,971.1	1,548.3	1.0	0.6
12/24/2022 11:00	7.3	13.7	6.0	93.6	3,028,188.6	1,547.9	1.0	0.6
12/24/2022 12:00	7.2	13.7	5.9	93.8	3,036,209.5	1,552.0	1.0	0.6
12/24/2022 13:00	7.2	13.7	5.9	93.9	3,040,904.7	1,554.4	1.0	0.6
12/24/2022 14:00	7.2	13.7	5.9	102.1	3,385,021.4	1,730.3	1.0	0.7
12/24/2022 15:00	7.1	13.7	5.8	102.7	3,392,846.7	1,734.3	1.0	0.7
12/24/2022 16:00	7.3	13.7	6.0	95.3	3,110,940.9	1,590.2	1.0	0.6
12/24/2022 17:00	7.5	13.3	5.8	107.2	3,457,621.0	1,969.4	1.0	0.8
12/24/2022 18:00	7.2	13.4	5.7	105.8	3,451,300.6	1,965.8	1.0	0.8
12/24/2022 19:00	7.1	13.4	5.6	105.5	3,451,476.1	1,965.9	1.0	0.8
12/24/2022 20:00	7.1	13.4	5.6	105.5	3,453,934.1	1,967.3	1.0	0.8
12/24/2022 21:00	7.1	13.4	5.6	105.4	3,445,506.9	1,962.5	1.0	0.8
12/24/2022 22:00	7.0	13.4	5.5	105.1	3,495,233.4	1,965.3	1.0	0.8
12/24/2022 23:00	7.0	13.4	5.5	105.0	3,453,758.5	1,967.2	1.0	0.8
Average/Sum#:	7.2	13.5	5.7	103.7	3,334,186.1	1,843.6	1.0	0.7
Minimum:	6.9	13.1	5.4	82.9	2,575,104.7	1,316.3	1.0	0.5
Maximum:	7.8	13.8	6.1	123.3	3,504,571.5	2,130.9	1.1	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/25/2022 00:00	7.0	13.4	5.5	104.7	3,417,942.8	1,946.8	1.0	0.8
12/25/2022 01:00	22.0	15.9	26.0	160.3	1,530,138.0	592.2	3.3	0.8
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	32.1	17.4	54.1	19.4	1,477,694.5	345.3	0.4	0.1
12/25/2022 19:00	32.3	17.2	51.5	227.4	1,563,806.6	411.1	4.4	0.7
12/25/2022 20:00	30.3	15.7	34.4	221.5	2,137,397.6	780.4	3.2	0.9
12/25/2022 21:00	6.9	13.7	5.7	88.3	2,773,084.4	1,417.5	1.0	0.6
12/25/2022 22:00	7.1	13.7	5.8	86.8	2,847,815.8	1,455.7	1.0	0.6
12/25/2022 23:00	7.2	13.7	5.9	88.6	2,890,268.0	1,477.4	1.0	0.6
Average/Sum#:	18.1	15.1	23.6	124.6	2,329,768.5	1,053.3	1.9	0.6
Minimum:	6.9	13.4	5.5	19.4	1,477,694.5	345.3	0.4	0.1
Maximum:	32.3	17.4	54.1	227.4	3,417,942.8	1,946.8	4.4	0.9
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/26/2022 00:00	7.4	13.6	6.0	104.5	3,402,151.6	1,763.9	1.0	0.7
12/26/2022 01:00	7.2	13.7	5.9	94.7	2,976,087.1	1,543.0	1.0	0.6
12/26/2022 02:00	7.1	13.6	5.7	101.0	3,280,060.7	1,700.6	1.0	0.7
12/26/2022 03:00	7.1	13.6	5.7	102.3	3,321,143.4	1,721.9	1.0	0.7
12/26/2022 04:00	7.1	13.6	5.7	102.2	3,320,757.7	1,721.7	1.0	0.7
12/26/2022 05:00	7.0	13.6	5.7	103.0	3,351,232.2	1,737.5	1.0	0.7
12/26/2022 06:00	7.0	13.6	5.7	102.7	3,349,882.1	1,736.8	1.0	0.7
12/26/2022 07:00	7.2	13.6	5.8	103.2	3,332,908.9	1,728.0	1.0	0.7
12/26/2022 08:00	7.1	13.6	5.7	102.9	3,346,024.5	1,734.8	1.0	0.7
12/26/2022 09:00	7.1	13.7	5.8	93.9	3,029,949.3	1,548.8	1.0	0.6
12/26/2022 10:00	7.2	13.7	5.9	93.2	3,020,558.9	1,544.0	1.0	0.6
12/26/2022 11:00	7.1	13.6	5.7	92.6	3,004,125.8	1,535.6	1.0	0.6
12/26/2022 12:00	7.2	13.7	5.9	91.8	2,986,518.9	1,526.6	1.0	0.6
12/26/2022 13:00	7.2	13.6	5.8	93.4	3,026,623.5	1,547.1	1.0	0.6
12/26/2022 14:00	7.2	13.6	5.8	97.1	3,106,278.8	1,610.5	1.0	0.6
12/26/2022 15:00	7.0	13.6	5.7	102.4	3,356,054.1	1,740.0	1.0	0.7
12/26/2022 16:00	7.1	13.6	5.7	104.3	3,422,210.8	1,774.3	1.0	0.7
12/26/2022 17:00	8.0	13.1	6.1	119.0	3,502,096.6	2,122.6	1.1	0.8
12/26/2022 18:00	7.9	13.1	6.0	122.8	3,486,232.3	2,163.9	1.1	0.9
12/26/2022 19:00	7.4	13.3	5.7	110.6	3,494,285.7	2,015.8	1.0	0.8
12/26/2022 20:00	7.4	13.3	5.7	109.0	3,512,046.8	2,000.4	1.0	0.8
12/26/2022 21:00	7.2	13.4	5.7	106.6	3,503,236.6	1,969.8	1.0	0.8
12/26/2022 22:00	7.3	13.4	5.7	106.3	3,463,754.5	1,947.6	1.0	0.8
12/26/2022 23:00	19.9	15.9	23.5	147.5	1,574,062.9	609.2	2.9	0.7
Average/Sum#:	7.8	13.6	6.5	104.5	3,215,345.2	1,710.2	1.1	0.7
Minimum:	7.0	13.1	5.7	91.8	1,574,062.9	609.2	1.0	0.6
Maximum:	19.9	15.9	23.5	147.5	3,512,046.8	2,163.9	2.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	18.7	18.0	38.0	165.6	1,292,475.8	198.2	3.7	0.3
12/27/2022 02:00	30.5	15.8	35.3	212.8	2,115,062.0	756.8	3.0	0.9
12/27/2022 03:00	7.1	13.6	5.7	95.9	2,967,214.7	1,538.4	1.0	0.6
12/27/2022 04:00	7.2	13.6	5.8	93.4	3,011,364.2	1,539.3	1.0	0.6
12/27/2022 05:00	7.4	13.5	5.9	101.0	3,250,743.5	1,685.4	1.0	0.7
12/27/2022 06:00	7.3	13.7	6.0	88.3	2,733,566.7	1,397.3	1.0	0.6
12/27/2022 07:00	7.5	13.6	6.1	99.9	3,339,081.0	1,731.2	0.9	0.5
12/27/2022 08:00	7.5	13.6	6.1	103.1	3,281,989.5	1,701.6	1.0	0.7
12/27/2022 09:00	8.1	13.2	6.2	110.2	3,377,000.5	1,972.8	1.0	0.8
12/27/2022 10:00	8.0	13.2	6.1	110.0	3,368,612.8	1,967.9	1.0	0.8
12/27/2022 11:00	8.1	13.2	6.2	111.0	3,372,892.3	1,970.4	1.0	0.8
12/27/2022 12:00	8.1	13.2	6.2	111.3	3,371,522.8	1,969.6	1.1	0.8
12/27/2022 13:00	8.1	13.2	6.2	111.2	3,370,838.1	1,969.2	1.1	0.8
12/27/2022 14:00	8.1	13.3	6.3	111.1	3,373,234.6	1,970.6	1.1	0.8
12/27/2022 15:00	8.0	13.3	6.2	111.2	3,373,577.0	1,970.8	1.1	0.8
12/27/2022 16:00	8.0	13.3	6.2	110.8	3,415,760.4	1,970.5	1.0	0.8
12/27/2022 17:00	7.9	13.3	6.1	109.5	3,401,892.9	1,962.5	1.0	0.8
12/27/2022 18:00	7.9	13.3	6.1	109.0	3,441,293.2	1,960.1	1.0	0.8
12/27/2022 19:00	7.7	13.3	6.0	108.4	3,440,239.8	1,959.5	1.0	0.8
12/27/2022 20:00	7.8	13.3	6.1	108.8	3,461,483.5	1,971.6	1.0	0.8
12/27/2022 21:00	7.8	13.3	6.1	109.1	3,463,239.2	1,972.6	1.0	0.8
12/27/2022 22:00	7.2	13.4	5.7	106.1	3,460,553.2	1,945.8	1.0	0.8
12/27/2022 23:00	7.1	13.8	5.9	86.7	2,763,260.2	1,392.3	1.0	0.6
Average/Sum#:	9.2	13.7	8.7	112.4	3,149,865.1	1,716.3	1.2	0.7
Minimum:	7.1	13.2	5.7	86.7	1,292,475.8	198.2	0.9	0.3
Maximum:	30.5	18.0	38.0	212.8	3,463,239.2	1,972.8	3.7	0.9
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/28/2022 00:00	7.1	13.7	5.8	92.6	3,012,146.7	1,539.7	1.0	0.6
12/28/2022 01:00	7.1	13.7	5.8	88.1	2,866,400.9	1,465.2	1.0	0.6
12/28/2022 02:00	7.1	13.7	5.8	92.0	2,975,367.9	1,520.9	1.0	0.6
12/28/2022 03:00	7.1	13.7	5.8	91.9	2,969,890.2	1,518.1	1.0	0.6
12/28/2022 04:00	7.1	13.7	5.8	91.9	2,989,649.1	1,528.2	1.0	0.6
12/28/2022 05:00	7.1	13.6	5.7	102.0	3,315,357.1	1,718.9	1.0	0.7
12/28/2022 06:00	6.9	13.6	5.6	102.4	3,348,146.2	1,735.9	1.0	0.7
12/28/2022 07:00	7.2	13.6	5.8	103.5	3,352,968.1	1,738.4	1.0	0.7
12/28/2022 08:00	7.1	13.6	5.7	102.5	3,310,342.4	1,716.3	1.0	0.7
12/28/2022 09:00	7.1	13.6	5.7	101.9	3,293,947.8	1,707.8	1.0	0.7
12/28/2022 10:00	7.1	13.7	5.8	93.8	3,027,797.3	1,547.7	1.0	0.6
12/28/2022 11:00	7.2	13.7	5.9	94.5	3,057,729.0	1,563.0	1.0	0.6
12/28/2022 12:00	7.2	13.7	5.9	93.6	3,023,297.8	1,545.4	1.0	0.6
12/28/2022 13:00	7.1	13.7	5.8	92.1	2,983,975.7	1,525.3	1.0	0.6
12/28/2022 14:00	7.1	13.7	5.8	93.6	3,030,536.2	1,549.1	1.0	0.6
12/28/2022 15:00	7.3	13.6	5.9	95.3	3,115,244.8	1,592.4	1.0	0.6
12/28/2022 16:00	8.2	13.1	6.2	118.9	3,457,219.1	2,095.4	1.1	0.8
12/28/2022 17:00	7.3	13.3	5.7	108.5	3,469,208.4	1,976.0	1.0	0.8
12/28/2022 18:00	7.1	13.4	5.6	105.6	3,478,871.5	1,956.1	1.0	0.8
12/28/2022 19:00	7.1	13.4	5.6	105.9	3,481,361.3	1,957.5	1.0	0.8
12/28/2022 20:00	7.1	13.4	5.6	106.1	3,484,029.0	1,959.0	1.0	0.8
12/28/2022 21:00	7.3	13.3	5.7	107.6	3,459,376.7	1,970.4	1.0	0.8
12/28/2022 22:00	7.1	13.4	5.6	105.8	3,478,693.6	1,956.0	1.0	0.8
12/28/2022 23:00	7.1	13.4	5.6	105.9	3,487,408.1	1,960.9	1.0	0.8
Average/Sum#:	7.2	13.6	5.8	99.8	3,227,873.5	1,722.7	1.0	0.7
Minimum:	6.9	13.1	5.6	88.1	2,866,400.9	1,465.2	1.0	0.6
Maximum:	8.2	13.7	6.2	118.9	3,487,408.1	2,095.4	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/29/2022 00:00	7.1	13.4	5.6	105.7	3,480,294.3	1,956.9	1.0	0.8
12/29/2022 01:00	7.1	13.4	5.6	105.8	3,487,586.0	1,961.0	1.0	0.8
12/29/2022 02:00	7.1	13.4	5.6	105.8	3,494,699.9	1,965.0	1.0	0.8
12/29/2022 03:00	7.1	13.4	5.6	105.8	3,494,344.2	1,964.8	1.0	0.8
12/29/2022 04:00	7.1	13.4	5.6	106.0	3,501,991.6	1,969.1	1.0	0.8
12/29/2022 05:00	7.5	13.3	5.8	111.8	3,488,608.6	2,038.0	1.0	0.8
12/29/2022 06:00	7.5	13.2	5.7	112.8	3,378,188.5	2,047.5	1.1	0.8
12/29/2022 07:00	7.9	13.2	6.1	115.3	3,468,025.0	2,051.3	1.1	0.8
12/29/2022 08:00	8.1	13.0	6.0	131.5	3,472,986.2	2,206.4	1.2	1.1
12/29/2022 09:00	8.1	12.9	6.0	139.2	3,438,016.0	2,259.5	1.3	1.1
12/29/2022 10:00	7.8	13.1	5.9	122.7	3,483,010.1	2,161.9	1.1	0.9
12/29/2022 11:00	7.3	13.3	5.7	111.0	3,465,157.2	2,024.3	1.0	0.8
12/29/2022 12:00	7.3	13.3	5.7	107.7	3,487,116.3	1,986.2	1.0	0.8
12/29/2022 13:00	7.2	13.3	5.6	106.4	3,513,373.9	1,975.5	1.0	0.8
12/29/2022 14:00	7.4	13.3	5.7	107.8	3,485,185.1	1,985.1	1.0	0.8
12/29/2022 15:00	7.3	13.3	5.7	107.9	3,492,910.0	1,989.5	1.0	0.8
12/29/2022 16:00	7.7	13.1	5.8	118.0	3,507,563.5	2,100.3	1.1	0.8
12/29/2022 17:00	7.9	13.0	5.9	124.3	3,466,236.0	2,176.8	1.2	1.1
12/29/2022 18:00	7.5	13.1	5.7	116.4	3,440,885.0	2,085.5	1.1	0.8
12/29/2022 19:00	7.0	13.3	5.4	105.5	3,500,746.7	1,968.4	1.0	0.8
12/29/2022 20:00	7.2	13.3	5.6	106.6	3,517,464.3	1,977.8	1.0	0.8
12/29/2022 21:00	7.3	13.3	5.7	108.0	3,492,558.9	1,989.3	1.0	0.8
12/29/2022 22:00	7.1	13.3	5.5	106.1	3,462,361.3	1,972.1	1.0	0.8
12/29/2022 23:00	7.1	13.3	5.5	105.6	3,411,798.0	1,943.3	1.0	0.8
Average/Sum#:	7.4	13.2	5.7	112.2	3,476,296.1	2,031.5	1.1	0.8
Minimum:	7.0	12.9	5.4	105.5	3,378,188.5	1,943.3	1.0	0.8
Maximum:	8.1	13.4	6.1	139.2	3,517,464.3	2,259.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/30/2022 00:00	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
Minimum:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
Maximum:	19.7	16.1	24.2	147.1	1,538,411.4	561.7	3.0	0.7
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:28 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:28 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,689.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 519.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,689.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:32 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:33 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 397.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:34 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	4.0	2.5	0.5	2.7	0.0
February	2.6	2.0	0.3	1.4	0.0
March	0.0	0.0	0.0	0.0	0.0
April	2.7	1.9	0.3	1.5	0.0
May	1.7	1.3	0.1	0.5	0.0
June	2.9	2.0	0.3	1.5	0.0
July	3.3	2.1	0.4	2.0	0.4
August	5.0	1.9	0.6	3.5	0.8
September	3.8	1.2	0.5	2.8	0.6
October	3.7	1.7	0.5	2.5	0.6
November	4.8	1.4	0.7	3.6	0.8
December	4.6	1.2	0.6	3.5	0.8
Quarter 1	6.6	4.5	0.8	4.1	0.0
Quarter 2	7.3	5.2	0.7	3.5	0.0
Quarter 3	12.1	5.2	1.5	8.3	1.8
Quarter 4	13.1	4.3	1.8	9.6	2.2
YTD	39.1	19.2	4.8	25.5	4.0

Cumulative Emissions Report

CT1

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:34 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
October	7,919,842	951,375	8,871,217.7	481	180.3
November	10,950,023	1,401,925	12,351,946.6	643	190.2
December	9,790,518	1,220,911	11,011,423.9	565	190.1
Quarter 4	28,660,383	3,574,211	32,234,588.2	1,689	186.9
YTD	28,660,383	3,574,211	32,234,588.2	1,689	186.9

Cumulative Emissions Report

CT2

From: 01/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:52 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	8,823,028	399,749	9,222,775.5	568	58,712.9
February	4,322,812	308,326	4,631,136.4	280	31,470.0
March	0	0	0.0	0	0.0
April	4,450,499	355,813	4,806,312.4	304	34,611.8
May	1,677,243	100,892	1,778,134.5	130	14,773.6
June	4,174,988	509,777	4,684,764.3	280	33,418.7
July	6,134,263	839,845	6,974,107.4	405	48,218.3
August	10,360,506	1,860,538	12,221,042.8	638	82,239.5
September	8,373,899	1,461,631	9,835,527.9	520	64,542.0
October	7,800,797	1,040,185	8,840,976.9	482	59,513.8
November	11,038,432	1,481,743	12,520,172.1	651	83,151.6
December	11,660,812	1,771,525	13,432,333.9	678	85,152.5
Quarter 1	13,145,840	708,075	13,853,911.9	848	90,182.9
Quarter 2	10,302,730	966,482	11,269,211.2	714	82,804.1
Quarter 3	24,868,668	4,162,014	29,030,678.1	1,563	194,999.8
Quarter 4	30,500,041	4,293,453	34,793,482.9	1,811	227,817.9
YTD	78,817,279	10,130,024	88,947,284.1	4,936	595,804.7

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
10/01/2022	1.9	6.8	6.1	59.0
10/02/2022	0.0	0.0	6.7	65.3
10/03/2022	27.1	97.8	13.4	133.3
10/04/2022	33.7	121.4	14.7	145.4
10/05/2022	34.5	123.1	14.8	147.5
10/06/2022	36.6	130.6	15.7	156.7
10/07/2022	36.5	130.6	15.7	156.8
10/08/2022	32.3	116.6	14.5	139.9
10/09/2022	26.5	95.0	9.7	97.9
10/10/2022	32.4	115.2	13.8	138.2
10/11/2022	27.8	99.1	11.7	120.5
10/12/2022	35.9	126.5	15.4	151.4
10/13/2022	30.7	108.1	12.5	128.6
10/14/2022	34.4	122.6	14.4	147.0
10/15/2022	0.0	0.0	0.0	0.0
10/16/2022	0.1	0.4	2.6	25.9
10/17/2022	32.0	113.1	13.9	137.1
10/18/2022	36.5	130.9	16.1	156.5
10/19/2022	36.0	128.5	15.0	153.7
10/20/2022	35.9	127.3	14.9	152.4
10/21/2022	28.2	100.6	12.1	120.2
10/22/2022	0.0	0.0	0.0	0.0
10/23/2022	0.0	0.0	0.8	8.2
10/24/2022	12.8	45.3	6.8	71.4
10/25/2022	31.0	108.4	0.0	0.0
10/26/2022	16.1	57.6	0.0	0.0
10/27/2022	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0
10/30/2022	0.0	0.0	1.1	10.8
10/31/2022	28.6	101.0	12.9	133.3
Monthly Avg/Sum*:	647.5 *	2,306.5 *	275.3 *	2,757.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	36.6	130.9	16.1	156.8
Oct 2022 - Oct 2022	647.5	2,306.5	275.3	2,757.0
QTD:	647.5 *	2,306.5 *	275.3 *	2,757.0 *
YTD 2022:	4,942.8 *	17,615.6 *	1,942.4 *	19,513.8 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
11/01/2022	36.1	129.2	15.6	154.8
11/02/2022	30.9	111.1	13.6	132.9
11/03/2022	33.1	118.4	14.1	141.9
11/04/2022	31.4	113.0	13.3	136.0
11/05/2022	21.5	75.7	4.2	41.6
11/06/2022	2.2	7.8	6.0	60.0
11/07/2022	28.6	101.7	14.1	138.7
11/08/2022	35.6	128.7	16.0	155.5
11/09/2022	33.3	119.1	14.2	143.3
11/10/2022	34.3	121.5	14.7	146.3
11/11/2022	34.8	123.4	14.9	148.3
11/12/2022	34.7	124.3	15.2	148.2
11/13/2022	34.7	124.3	15.1	148.8
11/14/2022	37.1	132.2	16.1	159.7
11/15/2022	36.4	129.6	15.9	155.6
11/16/2022	36.3	128.7	15.8	154.5
11/17/2022	36.8	131.2	16.1	157.6
11/18/2022	36.8	131.6	16.1	156.1
11/19/2022	36.0	128.1	15.7	152.8
11/20/2022	34.3	122.2	14.4	143.2
11/21/2022	36.5	129.2	15.7	155.6
11/22/2022	29.5	105.2	13.8	141.0
11/23/2022	32.4	115.3	14.1	139.0
11/24/2022	29.6	106.5	12.6	127.9
11/25/2022	30.6	109.0	13.0	130.8
11/26/2022	3.9	14.1	1.7	17.0
11/27/2022	0.0	0.0	0.5	4.6
11/28/2022	27.3	97.1	13.3	131.7
11/29/2022	37.1	132.3	16.1	160.3
11/30/2022	35.7	126.6	15.3	153.2
Monthly Avg/Sum*:	907.5 *	3,237.1 *	397.2 *	3,936.9 *
Daily Min:	0.0	0.0	0.5	4.6
Daily Max:	37.1	132.3	16.1	160.3
Oct 2022 - Nov 2022	1,555.0	5,543.6	672.5	6,693.9
QTD:	1,555.0 *	5,543.6 *	672.5 *	6,693.9 *
YTD 2022:	5,850.3 *	20,852.7 *	2,339.6 *	23,450.7 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
12/01/2022	0.0	0.0	13.9	136.1
12/02/2022	0.0	0.0	16.8	162.5
12/03/2022	0.0	0.0	16.8	166.5
12/04/2022	0.0	0.0	16.8	161.9
12/05/2022	19.5	70.4	15.9	158.4
12/06/2022	33.4	117.4	14.1	141.0
12/07/2022	36.6	130.0	15.8	156.8
12/08/2022	36.7	130.8	15.8	158.3
12/09/2022	36.4	129.8	15.6	157.4
12/10/2022	34.2	121.8	14.7	147.1
12/11/2022	33.8	119.4	14.4	143.8
12/12/2022	35.2	124.7	15.2	150.6
12/13/2022	36.4	129.7	15.7	156.6
12/14/2022	36.1	129.4	16.0	156.1
12/15/2022	37.4	132.5	16.3	160.4
12/16/2022	32.5	116.1	14.1	139.3
12/17/2022	36.2	128.5	15.2	155.0
12/18/2022	33.3	118.4	14.3	142.6
12/19/2022	37.4	133.2	16.3	160.3
12/20/2022	36.2	129.3	16.2	156.2
12/21/2022	37.9	134.5	16.7	162.9
12/22/2022	36.5	129.8	15.7	156.0
12/23/2022	37.2	130.8	16.2	158.4
12/24/2022	31.3	110.5	13.5	132.8
12/25/2022	1.5	5.1	2.2	23.5
12/26/2022	26.9	96.6	12.1	121.5
12/27/2022	23.8	84.0	11.9	117.9
12/28/2022	29.3	103.7	12.7	124.1
12/29/2022	34.2	121.1	14.7	146.4
12/30/2022	0.1	0.4	0.0	0.4
12/31/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	810.0 *	2,877.9 *	425.6 *	4,210.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	37.9	134.5	16.8	166.5
Oct 2022 - Dec 2022	2,365.0	8,421.5	1,098.1	10,904.7
QTD:	2,365.0 *	8,421.5 *	1,098.1 *	10,904.7 *
YTD 2022:	6,660.3 *	23,730.6 *	2,765.2 *	27,661.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
10/01/2022	16.6	11.16	1.6	100.6	180.10	11.6
10/02/2022	0.0	0.00	0.0	125.9	161.74	13.0
10/03/2022	160.6	200.30	23.1	22.5	121.10	26.2
10/04/2022	66.5	146.10	28.9	23.2	169.20	28.9
10/05/2022	70.3	146.10	29.3	23.2	169.40	29.3
10/06/2022	71.3	154.40	31.2	21.1	205.00	31.1
10/07/2022	72.8	156.50	31.5	20.9	207.00	31.5
10/08/2022	62.5	142.80	27.8	22.1	153.30	27.9
10/09/2022	139.2	158.89	22.6	92.8	201.10	19.6
10/10/2022	65.2	149.50	27.7	23.0	146.00	27.7
10/11/2022	45.9	133.30	24.0	21.5	93.00	24.1
10/12/2022	71.6	164.30	30.6	23.6	183.80	30.2
10/13/2022	62.6	156.50	26.3	30.1	135.10	26.0
10/14/2022	83.5	155.90	29.6	34.0	199.55	29.5
10/15/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/16/2022	63.7	27.50	0.1	218.2	159.59	5.2
10/17/2022	127.4	221.40	27.1	18.4	163.10	27.2
10/18/2022	74.0	163.20	31.5	23.7	208.70	31.5
10/19/2022	79.6	162.60	31.1	29.4	205.60	31.1
10/20/2022	83.0	163.50	30.9	30.5	203.40	30.5
10/21/2022	60.3	130.90	24.2	30.2	138.72	24.1
10/22/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/23/2022	0.0	0.00	0.0	125.6	123.53	1.6
10/24/2022	117.0	185.40	11.1	14.7	75.30	14.3
10/25/2022	35.5	159.00	26.3	0.0	0.00	0.0
10/26/2022	197.5	208.44	13.8	0.0	0.00	0.0
10/27/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/28/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/29/2022	0.0	0.00	0.0	0.0	0.00	0.0
10/30/2022	0.0	0.00	0.0	218.6	174.42	2.1
10/31/2022	204.3	229.42	24.1	23.3	152.40	26.5
Monthly Avg/Sum*:	2,030.9 *	3,527.11 *	554.4 *	1,317.1 *	3,930.15 *	550.7 *
Daily Min:	16.6	11.16	0.1	14.7	75.30	1.6
Daily Max:	204.3	229.42	31.5	218.6	208.70	31.5
Oct 2022 - Oct 2022	2,030.9	3,527.11	554.4	1,317.1	3,930.15	550.7
QTD:	2,030.9 *	3,527.11 *	554.4 *	1,317.1 *	3,930.15 *	550.7 *
YTD 2022:	21,694.1 *	29,604.49 *	4,226.5 *	11,661.3 *	29,690.13 *	3,906.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
11/01/2022	72.6	159.80	31.1	20.0	204.80	30.8
11/02/2022	60.8	141.70	26.5	18.3	154.10	26.5
11/03/2022	62.1	151.00	28.2	17.1	174.30	28.2
11/04/2022	63.8	136.00	26.8	19.3	164.30	27.0
11/05/2022	147.2	192.20	18.4	14.9	57.39	8.5
11/06/2022	8.9	9.98	1.8	161.9	175.21	12.1
11/07/2022	165.6	217.78	24.5	105.4	217.24	27.9
11/08/2022	66.2	168.90	30.8	21.6	207.00	30.8
11/09/2022	61.1	153.20	28.6	18.0	179.10	28.7
11/10/2022	60.7	151.80	29.4	14.9	185.00	29.5
11/11/2022	51.9	149.90	29.8	10.8	183.60	29.9
11/12/2022	52.0	151.40	30.1	9.4	186.10	29.8
11/13/2022	47.0	157.60	29.9	10.6	186.60	29.8
11/14/2022	57.0	160.70	32.0	17.2	212.80	32.0
11/15/2022	56.5	152.40	31.4	18.7	208.00	31.2
11/16/2022	71.5	156.80	30.9	8.6	192.00	31.0
11/17/2022	59.0	167.70	31.7	0.0	206.40	31.7
11/18/2022	56.9	170.20	31.6	0.0	205.70	31.2
11/19/2022	65.4	164.00	31.0	0.0	197.60	30.6
11/20/2022	47.2	158.20	29.5	0.0	147.90	28.5
11/21/2022	67.5	165.60	31.3	0.0	201.30	31.5
11/22/2022	156.1	184.70	25.4	0.0	152.00	28.3
11/23/2022	64.1	150.40	27.7	0.6	151.80	27.8
11/24/2022	44.2	148.20	25.4	2.0	105.40	25.4
11/25/2022	48.7	144.00	26.5	0.3	115.90	26.4
11/26/2022	23.0	23.80	3.3	9.8	27.40	3.3
11/27/2022	0.0	0.00	0.0	145.6	128.98	0.8
11/28/2022	174.9	232.86	23.4	0.0	124.20	26.4
11/29/2022	64.6	175.50	32.2	0.0	213.70	32.3
11/30/2022	89.6	169.80	30.8	11.9	196.80	31.0
Monthly Avg/Sum*:	2,066.1 *	4,466.12 *	780.0 *	656.9 *	5,062.62 *	788.9 *
Daily Min:	8.9	9.98	1.8	0.0	27.40	0.8
Daily Max:	174.9	232.86	32.2	161.9	217.24	32.3
Oct 2022 - Nov 2022	4,097.0	7,993.23	1,334.4	1,974.0	8,992.77	1,339.6
QTD:	4,097.0 *	7,993.23 *	1,334.4 *	1,974.0 *	8,992.77 *	1,339.6 *
YTD 2022:	23,760.2 *	34,070.61 *	5,006.5 *	12,318.2 *	34,752.75 *	4,695.4 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
12/01/2022	0.0	0.00	0.0	65.5	200.60	27.2
12/02/2022	0.0	0.00	0.0	1.8	216.70	32.4
12/03/2022	0.0	0.00	0.0	0.3	221.90	33.4
12/04/2022	0.0	0.00	0.0	0.6	215.90	32.1
12/05/2022	129.4	171.10	16.9	0.0	207.40	31.4
12/06/2022	65.5	152.30	28.3	0.6	144.90	28.6
12/07/2022	69.8	164.20	31.3	0.0	205.20	31.8
12/08/2022	71.1	172.10	31.8	0.0	208.20	31.8
12/09/2022	73.9	164.60	31.5	0.3	203.50	31.6
12/10/2022	81.4	168.30	29.3	0.0	172.60	29.4
12/11/2022	94.5	161.40	29.0	0.0	160.40	29.0
12/12/2022	84.9	166.10	30.1	1.5	177.10	30.3
12/13/2022	73.7	161.60	31.6	0.0	198.90	31.6
12/14/2022	74.5	168.00	31.3	0.0	194.30	31.3
12/15/2022	61.8	160.90	31.5	0.0	213.70	32.4
12/16/2022	64.8	153.70	27.9	0.0	147.50	27.9
12/17/2022	69.6	162.40	31.1	0.0	198.60	31.2
12/18/2022	61.8	158.40	28.4	0.0	162.70	28.5
12/19/2022	74.6	166.60	32.4	0.0	214.00	32.5
12/20/2022	74.3	167.90	31.0	0.0	202.30	31.4
12/21/2022	65.2	163.00	32.0	3.9	207.10	33.0
12/22/2022	78.5	159.50	31.0	12.5	200.50	31.5
12/23/2022	69.6	165.60	31.1	6.4	206.90	32.0
12/24/2022	67.5	143.80	26.7	9.5	123.20	26.7
12/25/2022	11.2	8.02	1.3	131.4	123.34	4.8
12/26/2022	190.6	230.94	23.1	15.7	98.11	24.1
12/27/2022	159.1	153.60	20.4	54.1	152.64	23.7
12/28/2022	53.0	139.00	24.9	9.5	100.70	24.7
12/29/2022	95.9	161.30	29.2	22.7	165.40	29.5
12/30/2022	7.7	1.88	0.1	5.5	2.85	0.1
12/31/2022	0.0	0.00	0.0	0.0	0.00	0.0
Monthly Avg/Sum*:	2,023.9 *	3,946.24 *	693.2 *	341.8 *	5,247.14 *	845.9 *
Daily Min:	7.7	1.88	0.1	0.0	2.85	0.1
Daily Max:	190.6	230.94	32.4	131.4	221.90	33.4
Oct 2022 - Dec 2022	6,120.9	11,939.47	2,027.6	2,315.8	14,239.91	2,185.5
QTD:	6,120.9 *	11,939.47 *	2,027.6 *	2,315.8 *	14,239.91 *	2,185.5 *
YTD 2022:	25,784.1 *	38,016.85 *	5,699.7 *	12,660.0 *	39,999.89 *	5,541.3 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	1.48	22,748.8	1.18	3,659.4	26,408.2	366.1	2,746.428
10/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/03/2022	21.82	348,310.3	8.03	27,830.9	376,141.2	3,751.6	39,118.620
10/04/2022	24.00	406,146.3	18.02	60,342.2	466,488.5	4,218.2	48,514.800
10/05/2022	24.00	411,799.5	19.00	61,957.4	473,756.9	3,773.3	49,270.800
10/06/2022	24.00	417,033.0	24.00	85,505.6	502,538.6	3,947.9	52,264.200
10/07/2022	24.00	417,192.6	24.00	84,546.2	501,738.8	3,955.1	52,180.600
10/08/2022	24.00	394,261.8	16.17	55,148.8	449,410.6	4,291.1	46,739.000
10/09/2022	20.22	324,309.5	12.75	41,014.1	365,323.6	4,179.5	37,993.712
10/10/2022	24.00	399,851.7	15.30	43,629.1	443,480.8	4,510.5	46,121.800
10/11/2022	24.00	368,718.0	4.78	11,536.4	380,254.4	3,921.6	39,546.500
10/12/2022	24.00	413,581.9	20.93	73,730.4	487,312.3	4,996.0	50,680.600
10/13/2022	24.00	398,608.6	9.05	17,488.3	416,096.9	4,243.3	43,274.000
10/14/2022	23.55	404,321.1	23.27	67,363.2	471,684.4	4,735.0	49,055.115
10/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2022	0.50	1,470.4	0.00	0.0	1,470.4	8.5	152.900
10/17/2022	24.00	392,382.2	12.34	41,812.2	434,194.4	4,573.5	45,156.100
10/18/2022	24.00	419,814.3	24.00	83,523.0	503,337.3	5,120.5	52,347.000
10/19/2022	24.00	418,290.0	24.00	75,008.9	493,298.9	5,064.9	51,303.000
10/20/2022	24.00	419,015.1	24.00	70,795.0	489,810.1	4,997.7	50,940.100
10/21/2022	22.48	364,897.3	7.22	21,412.9	386,310.2	3,940.2	40,176.388
10/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/24/2022	11.08	174,700.9	0.00	0.0	174,700.9	1,794.6	18,168.876
10/25/2022	24.00	417,490.1	0.00	0.0	417,490.1	3,805.9	43,418.800
10/26/2022	14.99	221,295.1	0.00	0.0	221,295.1	2,529.4	23,014.664
10/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/31/2022	22.97	363,602.6	9.05	25,072.5	388,675.1	3,986.0	40,422.221
Monthly Avg/Sum*:	475.09 *	7,919,841.1 *	297.09 *	951,376.5 *	8,871,217.7 *	86,710.4 *	922,606.224 *
Daily Min:	0.50	1,470.4	0.00	0.0	1,470.4	8.5	152.900
Daily Max:	24.00	419,814.3	24.00	85,505.6	503,337.3	5,120.5	52,347.000
Oct 2022 - Oct 2022	475.09	7,919,841.1	297.09	951,376.5	8,871,217.7	86,710.4	922,606.224
QTD:	475.09 *	7,919,841.1 *	297.09 *	951,376.5 *	8,871,217.7 *	86,710.4 *	922,606.224 *
YTD 2022:	3,804.18 *	60,808,971.0 *	2,267.96 *	6,868,954.1 *	67,677,925.2 *	662,306.6 *	7,045,504.614 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	24.00	417,976.8	23.70	75,414.7	493,391.5	4,817.2	51,707.400
11/02/2022	24.00	395,648.6	11.55	28,535.3	424,183.9	4,032.3	44,454.400
11/03/2022	24.00	405,138.5	16.02	47,213.2	452,351.7	4,391.6	47,406.500
11/04/2022	24.00	394,996.2	16.03	36,431.5	431,427.7	4,129.0	45,213.800
11/05/2022	17.43	274,407.2	12.00	14,497.3	288,904.5	2,952.4	30,277.179
11/06/2022	2.18	29,538.7	0.00	0.0	29,538.7	484.2	3,095.668
11/07/2022	20.40	340,508.8	17.80	47,214.4	387,723.2	3,933.6	40,633.200
11/08/2022	24.00	425,520.2	24.00	65,001.5	490,521.7	4,701.7	51,406.600
11/09/2022	24.00	415,419.0	17.25	39,037.5	454,456.5	4,391.5	47,627.100
11/10/2022	24.00	416,466.8	17.98	48,474.2	464,941.0	4,472.3	48,725.600
11/11/2022	24.00	414,482.5	16.73	55,960.4	470,442.9	4,656.6	49,302.300
11/12/2022	24.00	412,508.6	17.23	61,307.3	473,815.9	4,716.5	49,655.900
11/13/2022	24.00	417,232.0	16.74	56,907.6	474,139.6	4,708.2	49,689.900
11/14/2022	24.00	427,475.3	24.00	76,687.2	504,162.5	4,917.0	52,836.200
11/15/2022	24.00	423,461.7	24.00	72,037.0	495,498.7	5,025.7	51,928.400
11/16/2022	24.00	424,352.0	24.00	66,193.3	490,545.3	4,828.1	51,409.300
11/17/2022	24.00	424,594.3	24.00	75,959.8	500,554.1	5,006.1	52,458.500
11/18/2022	24.00	421,990.9	24.00	79,686.9	501,677.8	5,150.7	52,576.000
11/19/2022	24.00	423,286.6	24.00	65,114.9	488,401.5	4,912.2	51,184.700
11/20/2022	24.00	409,466.1	16.03	57,261.9	466,728.0	4,666.7	48,913.200
11/21/2022	24.00	424,747.2	24.00	68,299.4	493,046.6	4,818.5	51,671.300
11/22/2022	21.97	368,689.3	16.80	32,684.1	401,373.4	4,196.4	42,064.070
11/23/2022	24.00	405,865.9	17.04	33,910.9	439,776.8	4,208.1	46,088.500
11/24/2022	24.00	391,815.6	7.95	14,588.7	406,404.3	3,946.7	42,591.300
11/25/2022	24.00	400,436.2	9.48	16,148.1	416,584.3	3,990.8	43,658.000
11/26/2022	3.00	49,653.7	2.68	4,299.1	53,952.8	534.8	5,654.200
11/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/28/2022	21.95	346,183.8	11.10	23,929.2	370,113.0	3,736.6	38,787.790
11/29/2022	24.00	425,556.0	24.00	78,971.3	504,527.3	5,093.7	52,874.500
11/30/2022	24.00	422,602.1	23.67	60,159.3	482,761.4	4,699.3	50,593.200
Monthly Avg/Sum*:	638.93 *	10,950,020.6 *	503.78 *	1,401,926.0 *	12,351,946.6 *	122,118.5 *	1,294,484.707 *
Daily Min:	2.18	29,538.7	0.00	0.0	29,538.7	484.2	3,095.668
Daily Max:	24.00	427,475.3	24.00	79,686.9	504,527.3	5,150.7	52,874.500
Oct 2022 - Nov 2022	1,114.02	18,869,861.7	800.87	2,353,302.5	21,223,164.3	208,828.9	2,217,090.931
QTD:	1,114.02 *	18,869,861.7 *	800.87 *	2,353,302.5 *	21,223,164.3 *	208,828.9 *	2,217,090.931 *
YTD 2022:	4,443.11 *	71,758,991.6 *	2,771.74 *	8,270,880.1 *	80,029,871.8 *	784,425.1 *	8,339,989.321 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/03/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/04/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/05/2022	14.12	231,636.4	12.70	37,199.1	268,835.5	2,829.5	28,093.128
12/06/2022	24.00	410,467.1	17.25	38,729.9	449,197.0	4,318.5	46,941.200
12/07/2022	24.00	430,228.1	24.00	66,917.8	497,145.9	4,843.7	51,951.700
12/08/2022	24.00	432,960.2	24.00	67,696.6	500,656.8	4,913.6	52,318.500
12/09/2022	24.00	430,617.6	24.00	66,881.3	497,498.9	4,856.7	51,988.700
12/10/2022	24.00	418,274.6	24.00	48,218.6	466,493.2	4,435.2	48,748.600
12/11/2022	24.00	421,857.1	24.00	35,250.4	457,107.5	4,229.0	47,767.900
12/12/2022	24.00	426,529.8	24.00	51,319.3	477,849.1	4,515.8	49,935.000
12/13/2022	24.00	429,858.5	24.00	66,103.8	495,962.3	4,815.9	51,828.000
12/14/2022	24.00	432,234.2	24.00	62,651.5	494,885.7	4,723.1	51,715.500
12/15/2022	24.00	428,227.0	24.00	78,923.3	507,150.3	5,113.4	52,997.300
12/16/2022	24.00	403,808.6	18.03	39,763.5	443,572.1	4,344.2	46,353.400
12/17/2022	24.00	427,475.5	24.00	63,298.9	490,774.4	4,743.4	51,286.200
12/18/2022	24.00	410,501.5	17.02	43,755.6	454,257.1	4,393.3	47,469.800
12/19/2022	24.00	440,899.6	24.00	69,250.9	510,150.5	4,857.9	53,310.800
12/20/2022	24.00	434,137.8	23.98	61,046.1	495,183.9	4,671.0	51,746.700
12/21/2022	24.00	432,099.5	24.00	81,559.9	513,659.4	5,128.2	53,677.400
12/22/2022	24.00	434,643.9	24.00	62,010.8	496,654.7	4,781.8	51,900.700
12/23/2022	24.00	428,687.1	24.00	71,996.7	500,683.8	5,000.7	52,321.600
12/24/2022	24.00	399,176.3	15.77	22,801.7	421,978.0	4,034.0	44,096.600
12/25/2022	1.22	18,463.7	0.98	1,249.9	19,713.6	360.5	2,060.108
12/26/2022	22.86	358,447.3	6.00	10,653.9	369,101.2	3,942.3	38,570.806
12/27/2022	18.45	300,661.4	14.02	19,836.0	320,497.4	3,292.5	33,491.990
12/28/2022	24.00	385,671.0	8.03	11,882.7	397,553.7	3,894.4	41,544.400
12/29/2022	24.00	421,451.4	23.95	41,910.0	463,361.4	4,199.7	48,421.200
12/30/2022	0.25	1,500.5	0.00	0.0	1,500.5	172.4	156.800
12/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	560.90 *	9,790,515.7 *	493.73 *	1,220,908.2 *	11,011,423.9 *	107,410.7 *	1,150,694.032 *
Daily Min:	0.25	1,500.5	0.00	0.0	1,500.5	172.4	156.800
Daily Max:	24.00	440,899.6	24.00	81,559.9	513,659.4	5,128.2	53,677.400
Oct 2022 - Dec 2022	1,674.92	28,660,377.4	1,294.60	3,574,210.7	32,234,588.2	316,239.6	3,367,784.963
QTD:	1,674.92 *	28,660,377.4 *	1,294.60 *	3,574,210.7 *	32,234,588.2 *	316,239.6 *	3,367,784.963 *
YTD 2022:	5,004.01 *	81,549,507.3 *	3,265.47 *	9,491,788.3 *	91,041,295.7 *	891,835.8 *	9,490,683.353 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	12.45	167,393.3	6.42	21,965.5	189,358.8	1,930.3	19,693.145
10/02/2022	12.67	181,518.7	7.23	27,832.8	209,351.5	1,814.2	21,772.538
10/03/2022	24.00	397,876.6	8.07	29,330.8	427,207.4	2,685.9	44,429.400
10/04/2022	24.00	403,065.7	18.07	63,237.8	466,303.5	2,923.0	48,495.600
10/05/2022	24.00	407,485.9	18.98	65,164.4	472,650.3	2,952.1	49,155.700
10/06/2022	24.00	412,343.6	24.00	90,243.8	502,587.4	3,184.1	52,269.100
10/07/2022	24.00	413,011.3	24.00	89,386.7	502,398.0	3,192.0	52,249.400
10/08/2022	24.00	390,331.2	16.24	58,920.2	449,251.4	2,847.7	46,722.000
10/09/2022	16.72	270,289.8	12.77	43,895.3	314,185.1	2,177.2	32,675.224
10/10/2022	24.00	396,466.2	15.29	46,577.2	443,043.4	2,750.2	46,076.500
10/11/2022	24.00	372,504.0	5.05	13,945.5	386,449.5	2,454.7	40,190.900
10/12/2022	24.00	409,594.7	20.93	75,399.5	484,994.2	3,057.5	50,439.400
10/13/2022	24.00	393,689.1	9.05	18,684.1	412,373.2	2,572.6	42,886.900
10/14/2022	23.55	402,242.6	23.27	68,552.6	470,795.2	3,089.0	48,962.830
10/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2022	6.73	83,025.6	0.00	0.0	83,025.6	837.0	8,634.605
10/17/2022	24.00	397,009.5	12.31	42,634.7	439,644.2	2,908.5	45,723.100
10/18/2022	24.00	416,451.3	24.00	85,251.5	501,702.8	3,463.5	52,177.200
10/19/2022	24.00	416,648.1	24.00	77,152.6	493,800.7	3,353.5	51,355.200
10/20/2022	24.00	415,714.1	24.00	73,252.6	488,966.7	3,274.3	50,852.600
10/21/2022	22.52	363,089.1	7.18	22,364.0	385,453.1	2,557.3	40,087.332
10/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2022	3.72	26,207.7	0.00	0.0	26,207.7	515.0	2,725.484
10/24/2022	14.42	228,675.9	0.00	0.0	228,675.9	1,577.6	23,782.238
10/25/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/26/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/30/2022	4.20	34,810.2	0.00	0.0	34,810.2	644.1	3,620.300
10/31/2022	24.00	401,351.0	9.05	26,390.1	427,741.1	2,752.5	44,485.100
Monthly Avg/Sum*:	476.98 *	7,800,795.2 *	309.91 *	1,040,181.7 *	8,840,976.9 *	59,513.8 *	919,461.796 *
Daily Min:	3.72	26,207.7	0.00	0.0	26,207.7	515.0	2,725.484
Daily Max:	24.00	416,648.1	24.00	90,243.8	502,587.4	3,463.5	52,269.100
Oct 2022 - Oct 2022	476.98	7,800,795.2	309.91	1,040,181.7	8,840,976.9	59,513.8	919,461.796
QTD:	476.98 *	7,800,795.2 *	309.91 *	1,040,181.7 *	8,840,976.9 *	59,513.8 *	919,461.796 *
YTD 2022:	3,519.78 *	56,118,030.9 *	2,211.67 *	6,876,742.3 *	62,994,778.1 *	427,500.6 *	6,504,334.621 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	24.00	415,783.9	23.70	76,961.4	492,745.3	3,311.0	51,639.900
11/02/2022	24.00	393,465.5	11.57	30,395.6	423,861.1	2,664.9	44,420.700
11/03/2022	24.00	403,027.7	16.02	47,911.9	450,939.6	2,992.9	47,258.300
11/04/2022	24.00	393,284.9	16.10	38,972.1	432,257.0	2,832.5	45,300.800
11/05/2022	7.23	122,390.0	6.95	10,168.9	132,558.9	912.4	13,892.286
11/06/2022	12.32	172,667.3	6.42	17,984.0	190,651.4	1,709.9	19,980.322
11/07/2022	23.45	389,545.0	17.80	51,313.8	440,858.8	3,247.8	46,201.960
11/08/2022	24.00	423,190.1	24.00	71,080.1	494,270.2	3,178.6	51,799.300
11/09/2022	24.00	412,161.3	17.25	43,101.9	455,263.2	2,872.6	47,711.400
11/10/2022	24.00	414,371.0	17.98	51,330.0	465,701.0	3,029.2	48,805.400
11/11/2022	24.00	411,878.3	16.73	58,662.8	470,541.1	3,173.2	49,312.600
11/12/2022	24.00	409,886.3	17.18	61,404.6	471,290.9	3,186.1	49,391.300
11/13/2022	24.00	413,852.6	16.80	59,848.6	473,701.2	3,338.4	49,644.000
11/14/2022	24.00	424,604.2	24.00	82,763.8	507,368.0	3,637.9	53,172.200
11/15/2022	24.00	422,662.5	24.00	73,246.0	495,908.5	3,490.0	51,971.100
11/16/2022	24.00	423,060.9	24.00	67,691.3	490,752.2	3,242.4	51,430.800
11/17/2022	24.00	421,345.4	24.00	80,945.3	502,290.7	3,395.4	52,640.300
11/18/2022	24.00	419,234.0	24.00	76,790.3	496,024.3	3,388.3	51,983.400
11/19/2022	24.00	420,953.1	24.00	65,379.5	486,332.6	3,215.3	50,967.500
11/20/2022	24.00	406,843.8	16.18	48,569.2	455,413.0	3,036.9	47,727.200
11/21/2022	24.00	422,291.5	24.00	72,225.7	494,517.2	3,224.5	51,825.300
11/22/2022	24.00	411,686.6	16.82	36,389.2	448,075.8	2,680.1	46,958.500
11/23/2022	24.00	404,523.0	17.02	38,015.3	442,538.3	2,624.7	46,378.000
11/24/2022	24.00	390,951.5	7.95	16,286.8	407,238.3	2,503.9	42,678.700
11/25/2022	24.00	397,991.5	9.48	18,223.2	416,214.7	2,505.4	43,619.500
11/26/2022	3.00	49,390.6	2.68	4,886.5	54,277.1	344.1	5,688.200
11/27/2022	2.70	14,595.3	0.00	0.0	14,595.3	419.9	1,529.640
11/28/2022	24.00	392,072.4	11.10	26,689.4	418,761.8	2,561.6	43,886.500
11/29/2022	24.00	421,604.2	24.00	87,477.9	509,082.1	3,387.8	53,351.700
11/30/2022	24.00	419,115.5	23.67	67,027.0	486,142.5	3,043.9	50,947.900
Monthly Avg/Sum*:	648.70 *	11,038,429.9 *	505.40 *	1,481,742.1 *	12,520,172.1 *	83,151.6 *	1,312,114.708 *
Daily Min:	2.70	14,595.3	0.00	0.0	14,595.3	344.1	1,529.640
Daily Max:	24.00	424,604.2	24.00	87,477.9	509,082.1	3,637.9	53,351.700
Oct 2022 - Nov 2022	1,125.68	18,839,225.1	815.31	2,521,923.8	21,361,149.0	142,665.4	2,231,576.504
QTD:	1,125.68 *	18,839,225.1 *	815.31 *	2,521,923.8 *	21,361,149.0 *	142,665.4 *	2,231,576.504 *
YTD 2022:	4,168.48 *	67,156,460.8 *	2,717.07 *	8,358,484.4 *	75,514,950.2 *	510,652.2 *	7,816,449.329 *

Monthly Summary By Day Report

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	21.47	361,587.3	18.32	73,110.2	434,697.5	3,362.6	45,425.693
12/02/2022	24.00	428,734.6	24.00	89,313.0	518,047.6	3,518.7	54,136.100
12/03/2022	24.00	429,512.6	24.00	101,421.5	530,934.1	3,659.8	55,482.500
12/04/2022	24.00	424,925.0	24.00	91,432.3	516,357.3	3,432.0	53,959.500
12/05/2022	24.00	420,268.3	23.55	84,668.6	504,936.9	3,346.7	52,765.800
12/06/2022	24.00	406,717.7	17.23	43,735.3	450,453.0	2,753.3	47,072.300
12/07/2022	24.00	425,632.9	24.00	74,857.1	500,490.0	3,078.5	52,301.300
12/08/2022	24.00	428,427.0	24.00	75,177.1	503,604.1	3,070.3	52,626.600
12/09/2022	24.00	426,489.1	24.00	74,877.8	501,366.9	3,060.3	52,392.800
12/10/2022	24.00	415,952.1	24.00	54,384.2	470,336.3	2,785.0	49,150.100
12/11/2022	24.00	418,227.9	24.00	40,873.4	459,101.3	2,633.5	47,976.100
12/12/2022	24.00	422,439.5	24.00	58,562.1	481,001.6	2,887.4	50,264.600
12/13/2022	24.00	425,404.8	24.00	74,401.6	499,806.4	3,142.9	52,229.800
12/14/2022	24.00	427,460.2	24.00	70,831.8	498,292.0	3,059.8	52,071.400
12/15/2022	24.00	423,300.8	24.00	87,949.6	511,250.4	3,440.3	53,425.700
12/16/2022	24.00	399,846.5	18.03	44,655.7	444,502.2	2,722.1	46,450.600
12/17/2022	24.00	422,958.0	24.00	70,922.3	493,880.3	3,086.7	51,610.500
12/18/2022	24.00	406,113.3	17.00	48,916.8	455,030.1	2,773.2	47,550.700
12/19/2022	24.00	434,804.2	24.00	77,849.3	512,653.5	3,075.8	53,572.300
12/20/2022	24.00	428,805.5	23.98	68,783.9	497,589.4	2,992.0	51,998.300
12/21/2022	24.00	427,368.8	24.00	91,033.3	518,402.1	3,335.9	54,172.900
12/22/2022	24.00	429,729.4	24.00	68,827.4	498,556.8	2,955.8	52,099.500
12/23/2022	24.00	424,715.6	24.00	79,695.8	504,411.4	3,165.5	52,710.800
12/24/2022	24.00	396,546.3	15.77	26,863.0	423,409.3	2,489.2	44,246.200
12/25/2022	6.94	73,742.1	0.98	1,546.7	75,288.8	997.0	7,867.800
12/26/2022	23.23	376,374.0	6.04	11,907.9	388,281.9	2,507.0	40,575.316
12/27/2022	22.20	352,314.5	14.02	23,913.1	376,227.6	2,584.4	39,315.840
12/28/2022	24.00	382,192.5	8.03	13,439.8	395,632.3	2,396.0	41,343.600
12/29/2022	24.00	418,982.7	23.95	47,573.8	466,556.5	2,693.7	48,755.500
12/30/2022	0.23	1,236.3	0.00	0.0	1,236.3	147.1	129.191
12/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	674.07 *	11,660,809.5 *	594.90 *	1,771,524.4 *	13,432,333.9 *	85,152.5 *	1,403,679.340 *
Daily Min:	0.23	1,236.3	0.00	0.0	1,236.3	147.1	129.191
Daily Max:	24.00	434,804.2	24.00	101,421.5	530,934.1	3,659.8	55,482.500
Oct 2022 - Dec 2022	1,799.75	30,500,034.6	1,410.21	4,293,448.2	34,793,482.9	227,817.9	3,635,255.844
QTD:	1,799.75 *	30,500,034.6 *	1,410.21 *	4,293,448.2 *	34,793,482.9 *	227,817.9 *	3,635,255.844 *
YTD 2022:	4,842.55 *	78,817,270.3 *	3,311.97 *	10,130,008.8 *	88,947,284.1 *	595,804.7 *	9,220,128.669 *

ATTACHMENT 10
Maximum Emissions

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
10/01/2022	191.3	117.2	8.0	65.8	13.2
10/02/2022	161.7	125.9	6.7	65.3	13.0
10/03/2022	321.4	183.1	40.5	231.1	49.3
10/04/2022	315.3	89.7	48.4	266.8	57.8
10/05/2022	315.5	93.5	49.3	270.6	58.6
10/06/2022	359.4	92.4	52.3	287.3	62.3
10/07/2022	363.5	93.7	52.2	287.4	63.0
10/08/2022	296.1	84.6	46.8	256.5	55.7
10/09/2022	360.0	232.0	36.2	192.9	42.2
10/10/2022	295.5	88.2	46.2	253.4	55.4
10/11/2022	226.3	67.4	39.5	219.6	48.1
10/12/2022	348.1	95.2	51.3	277.9	60.8
10/13/2022	291.6	92.7	43.2	236.7	52.3
10/14/2022	355.5	117.5	48.8	269.6	59.1
10/15/2022	0.0	0.0	0.0	0.0	0.0
10/16/2022	187.1	281.9	2.7	26.3	5.3
10/17/2022	384.5	145.8	45.9	250.2	54.3
10/18/2022	371.9	97.7	52.6	287.4	63.0
10/19/2022	368.2	109.0	51.0	282.2	62.2
10/20/2022	366.9	113.5	50.8	279.7	61.4
10/21/2022	269.6	90.5	40.3	220.8	48.3
10/22/2022	0.0	0.0	0.0	0.0	0.0
10/23/2022	123.5	125.6	0.8	8.2	1.6
10/24/2022	260.7	131.7	19.6	116.7	25.4
10/25/2022	159.0	35.5	31.0	108.4	26.3
10/26/2022	208.4	197.5	16.1	57.6	13.8
10/27/2022	0.0	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0	0.0
10/30/2022	174.4	218.6	1.1	10.8	2.1
10/31/2022	381.8	227.6	41.5	234.3	50.6
Monthly Avg/Sum*:	7,457.2 *	3,348.0 *	922.8 *	5,063.5 *	1,105.1 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	384.5	281.9	52.6	287.4	63.0
Oct 2022 - Oct 2022	7,457.2	3,348.0	922.8	5,063.5	1,105.1
QTD:	7,457.2 *	3,348.0 *	922.8 *	5,063.5 *	1,105.1 *
YTD 2022:	59,296.1 *	33,355.4 *	6,885.2 *	37,129.4 *	4,756.6 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
11/01/2022	364.6	92.6	51.7	284.0	61.9
11/02/2022	295.8	79.1	44.5	244.0	53.0
11/03/2022	325.3	79.2	47.2	260.3	56.4
11/04/2022	300.3	83.1	44.7	249.0	53.8
11/05/2022	249.6	162.1	25.7	117.3	26.9
11/06/2022	185.2	170.8	8.2	67.8	13.9
11/07/2022	435.0	271.0	42.7	240.4	52.4
11/08/2022	375.9	87.8	51.6	284.2	61.6
11/09/2022	332.3	79.1	47.5	262.4	57.3
11/10/2022	336.8	75.6	49.0	267.8	58.9
11/11/2022	333.5	62.7	49.7	271.7	59.7
11/12/2022	337.5	61.4	49.9	272.5	59.9
11/13/2022	344.2	57.6	49.8	273.1	59.7
11/14/2022	373.5	74.2	53.2	291.9	64.0
11/15/2022	360.4	75.2	52.3	285.2	62.6
11/16/2022	348.8	80.1	52.1	283.2	61.9
11/17/2022	374.1	59.0	52.9	288.8	63.4
11/18/2022	375.9	56.9	52.9	287.7	62.8
11/19/2022	361.6	65.4	51.7	280.9	61.6
11/20/2022	306.1	47.2	48.7	265.4	58.0
11/21/2022	366.9	67.5	52.2	284.8	62.8
11/22/2022	336.7	156.1	43.3	246.2	53.7
11/23/2022	302.2	64.7	46.5	254.3	55.5
11/24/2022	253.6	46.2	42.2	234.4	50.8
11/25/2022	259.9	49.0	43.6	239.8	52.9
11/26/2022	51.2	32.8	5.6	31.1	6.6
11/27/2022	129.0	145.6	0.5	4.6	0.8
11/28/2022	357.1	174.9	40.6	228.8	49.8
11/29/2022	389.2	64.6	53.2	292.6	64.5
11/30/2022	366.6	101.5	51.0	279.8	61.8
Monthly Avg/Sum*:	9,528.8 *	2,723.0 *	1,304.7 *	7,174.0 *	1,568.9 *
Daily Min:	51.2	32.8	0.5	4.6	0.8
Daily Max:	435.0	271.0	53.2	292.6	64.5
Oct 2022 - Nov 2022	16,986.0	6,071.0	2,227.5	12,237.5	2,674.0
QTD:	16,986.0 *	6,071.0 *	2,227.5 *	12,237.5 *	2,674.0 *
YTD 2022:	68,824.9 *	36,078.4 *	8,189.9 *	44,303.4 *	6,325.5 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:58 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
12/01/2022	200.6	65.5	13.9	136.1	27.2
12/02/2022	216.7	1.8	16.8	162.5	32.4
12/03/2022	221.9	0.3	16.8	166.5	33.4
12/04/2022	215.9	0.6	16.8	161.9	32.1
12/05/2022	378.5	129.4	35.4	228.8	48.3
12/06/2022	297.2	66.1	47.5	258.4	56.9
12/07/2022	369.4	69.8	52.4	286.8	63.1
12/08/2022	380.3	71.1	52.5	289.1	63.6
12/09/2022	368.1	74.2	52.0	287.2	63.1
12/10/2022	340.9	81.4	48.9	268.9	58.7
12/11/2022	321.8	94.5	48.2	263.2	58.0
12/12/2022	343.2	86.4	50.4	275.3	60.4
12/13/2022	360.5	73.7	52.1	286.3	63.2
12/14/2022	362.3	74.5	52.1	285.5	62.6
12/15/2022	374.6	61.8	53.7	292.9	63.9
12/16/2022	301.2	64.8	46.6	255.4	55.8
12/17/2022	361.0	69.6	51.4	283.5	62.3
12/18/2022	321.1	61.8	47.6	261.0	56.9
12/19/2022	380.6	74.6	53.7	293.5	64.9
12/20/2022	370.2	74.3	52.4	285.5	62.4
12/21/2022	370.1	69.1	54.6	297.4	65.0
12/22/2022	360.0	91.0	52.2	285.8	62.5
12/23/2022	372.5	76.0	53.4	289.2	63.1
12/24/2022	267.0	77.0	44.8	243.3	53.4
12/25/2022	131.3	142.6	3.7	28.6	6.1
12/26/2022	329.0	206.3	39.0	218.1	47.2
12/27/2022	306.2	213.2	35.7	201.9	44.1
12/28/2022	239.7	62.5	42.0	227.8	49.6
12/29/2022	326.7	118.6	48.9	267.5	58.7
12/30/2022	4.8	13.2	0.1	0.8	0.2
12/31/2022	0.0	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	9,193.3 *	2,365.7 *	1,235.6 *	7,088.7 *	1,539.1 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	380.6	213.2	54.6	297.4	65.0
Oct 2022 - Dec 2022	26,179.3	8,436.7	3,463.1	19,326.2	4,213.1
QTD:	26,179.3 *	8,436.7 *	3,463.1 *	19,326.2 *	4,213.1 *
YTD 2022:	78,018.2 *	38,444.1 *	9,425.5 *	51,392.1 *	7,864.6 *

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/01/2022 00:00	15.2	3.5	2.1	11.9	2.6
10/01/2022 01:00	10.4	23.7	0.6	3.1	0.6
10/01/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/01/2022 12:00	38.8	20.0	0.1	0.6	0.1
10/01/2022 13:00	22.6	16.4	0.1	1.1	0.2
10/01/2022 14:00	52.5	37.1	0.3	2.6	0.5
10/01/2022 15:00	1.4	0.5	0.4	4.2	0.8
10/01/2022 16:00	3.4	1.2	0.5	5.2	1.0
10/01/2022 17:00	9.0	1.3	0.7	6.8	1.4
10/01/2022 18:00	8.8	1.3	0.7	6.6	1.3
10/01/2022 19:00	8.1	1.9	0.6	6.1	1.2
10/01/2022 20:00	8.8	1.3	0.7	6.6	1.3
10/01/2022 21:00	7.7	1.2	0.6	5.8	1.2
10/01/2022 22:00	3.1	0.9	0.5	4.7	0.9
10/01/2022 23:00	1.4	6.9	0.1	0.5	0.1
Average/Sum#:	191.2 #	117.2 #	8.0 #	65.8 #	13.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.5	37.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/02/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/02/2022 11:00	34.8	39.8	0.1	0.6	0.1
10/02/2022 12:00	19.8	23.7	0.1	1.2	0.2
10/02/2022 13:00	36.1	49.4	0.3	2.6	0.5
10/02/2022 14:00	3.5	1.0	0.5	5.2	1.0
10/02/2022 15:00	5.2	1.8	0.5	5.2	1.0
10/02/2022 16:00	8.7	1.9	0.7	6.6	1.3
10/02/2022 17:00	9.1	1.3	0.7	6.8	1.4
10/02/2022 18:00	9.1	1.3	0.7	6.8	1.4
10/02/2022 19:00	9.1	1.0	0.7	6.8	1.4
10/02/2022 20:00	9.1	1.0	0.7	6.8	1.4
10/02/2022 21:00	8.4	1.6	0.6	6.3	1.3
10/02/2022 22:00	5.7	1.2	0.6	5.7	1.1
10/02/2022 23:00	3.1	0.9	0.5	4.7	0.9
Average/Sum#:	161.7 #	125.9 #	6.7 #	65.3 #	13.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	36.1	49.4	0.7	6.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/03/2022 00:00	3.1	0.9	0.5	4.6	0.9
10/03/2022 01:00	3.1	0.9	0.5	4.7	0.9
10/03/2022 02:00	55.1	65.9	0.7	6.1	1.3
10/03/2022 03:00	35.3	53.5	1.1	6.9	1.4
10/03/2022 04:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 05:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 06:00	8.5	1.9	1.7	9.4	2.0
10/03/2022 07:00	10.2	1.9	1.7	9.4	2.0
10/03/2022 08:00	8.6	1.6	1.7	9.5	2.0
10/03/2022 09:00	8.6	1.6	1.7	9.5	2.0
10/03/2022 10:00	3.4	2.6	1.7	9.5	2.0
10/03/2022 11:00	8.6	2.6	1.7	9.5	2.0
10/03/2022 12:00	8.6	2.6	1.7	9.5	2.0
10/03/2022 13:00	8.7	2.6	1.7	9.5	2.0
10/03/2022 14:00	8.6	2.6	1.7	9.4	2.0
10/03/2022 15:00	10.6	2.6	1.7	9.7	2.2
10/03/2022 16:00	12.4	5.7	2.0	11.4	2.4
10/03/2022 17:00	17.4	4.8	2.2	11.9	2.6
10/03/2022 18:00	17.6	4.1	2.2	12.1	2.6
10/03/2022 19:00	15.2	4.2	2.2	11.9	2.6
10/03/2022 20:00	15.3	4.1	2.2	12.1	2.6
10/03/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/03/2022 22:00	15.1	4.2	2.1	11.9	2.6
10/03/2022 23:00	15.2	4.2	2.2	11.9	2.6
Average/Sum#:	321.4 #	183.1 #	40.5 #	231.1 #	49.3 #
Minimum:	3.1	0.9	0.5	4.6	0.9
Maximum:	55.1	65.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/04/2022 00:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 01:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 02:00	15.1	4.2	2.1	11.9	2.6
10/04/2022 03:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 04:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 05:00	15.5	3.6	2.2	12.1	2.6
10/04/2022 06:00	15.2	3.9	2.2	11.9	2.6
10/04/2022 07:00	12.2	3.9	2.0	11.2	2.4
10/04/2022 08:00	8.0	1.8	1.6	8.8	2.0
10/04/2022 09:00	9.3	2.0	1.6	8.5	1.8
10/04/2022 10:00	6.2	1.7	1.6	8.6	1.8
10/04/2022 11:00	9.4	2.6	1.6	8.6	1.8
10/04/2022 12:00	12.0	2.6	1.7	9.4	2.0
10/04/2022 13:00	6.9	3.2	1.7	9.6	2.0
10/04/2022 14:00	8.1	6.3	2.0	11.2	2.4
10/04/2022 15:00	15.0	4.8	2.1	11.8	2.6
10/04/2022 16:00	14.9	4.5	2.1	11.7	2.6
10/04/2022 17:00	15.0	4.2	2.1	11.8	2.6
10/04/2022 18:00	15.2	4.2	2.2	11.9	2.6
10/04/2022 19:00	15.4	4.2	2.2	12.1	2.6
10/04/2022 20:00	15.7	3.5	2.3	12.3	2.6
10/04/2022 21:00	15.4	3.5	2.2	12.1	2.6
10/04/2022 22:00	15.2	3.9	2.2	11.9	2.6
10/04/2022 23:00	15.0	4.3	2.1	11.8	2.6
Average/Sum#:	309.1 #	88.0 #	48.4 #	266.8 #	57.8 #
Minimum:	6.9	1.8	1.6	8.5	1.8
Maximum:	15.7	6.3	2.3	12.3	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/05/2022 00:00	14.9	4.2	2.1	11.7	2.6
10/05/2022 01:00	12.0	4.6	2.0	11.0	2.4
10/05/2022 02:00	11.8	5.2	2.0	10.8	2.4
10/05/2022 03:00	12.6	4.9	2.1	11.5	2.6
10/05/2022 04:00	14.8	4.6	2.1	11.7	2.6
10/05/2022 05:00	15.4	3.9	2.2	12.1	2.6
10/05/2022 06:00	15.4	3.6	2.2	12.1	2.6
10/05/2022 07:00	11.9	4.9	2.0	10.9	2.4
10/05/2022 08:00	8.6	1.6	1.7	9.4	2.0
10/05/2022 09:00	8.3	1.9	1.7	9.2	2.0
10/05/2022 10:00	8.5	2.6	1.7	9.4	2.0
10/05/2022 11:00	8.6	2.6	1.7	9.4	2.0
10/05/2022 12:00	6.9	3.3	1.7	9.5	2.0
10/05/2022 13:00	12.4	5.8	2.1	11.4	2.4
10/05/2022 14:00	15.3	4.5	2.2	12.0	2.6
10/05/2022 15:00	14.9	4.5	2.1	11.7	2.6
10/05/2022 16:00	15.1	4.2	2.1	11.9	2.6
10/05/2022 17:00	15.4	3.8	2.2	12.1	2.6
10/05/2022 18:00	15.6	3.5	2.3	12.3	2.6
10/05/2022 19:00	15.7	3.5	2.3	12.3	2.6
10/05/2022 20:00	15.4	3.9	2.2	12.1	2.6
10/05/2022 21:00	15.6	3.5	2.3	12.3	2.6
10/05/2022 22:00	15.2	4.2	2.1	11.9	2.6
10/05/2022 23:00	15.2	4.2	2.2	11.9	2.6
Average/Sum#:	315.5 #	93.5 #	49.3 #	270.6 #	58.6 #
Minimum:	6.9	1.6	1.7	9.2	2.0
Maximum:	15.7	5.8	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/06/2022 00:00	15.1	4.3	2.1	11.9	2.6
10/06/2022 01:00	15.2	4.3	2.1	11.9	2.6
10/06/2022 02:00	15.2	4.2	2.1	11.9	2.6
10/06/2022 03:00	15.0	4.3	2.1	11.8	2.6
10/06/2022 04:00	15.2	3.2	2.2	12.1	2.6
10/06/2022 05:00	13.5	3.6	2.3	12.3	2.7
10/06/2022 06:00	15.6	3.3	2.3	12.3	2.6
10/06/2022 07:00	14.9	4.2	2.1	11.7	2.6
10/06/2022 08:00	12.4	4.5	2.1	11.4	2.4
10/06/2022 09:00	12.4	4.6	2.0	11.4	2.4
10/06/2022 10:00	14.5	4.6	2.1	11.4	2.4
10/06/2022 11:00	14.8	4.5	2.1	11.6	2.6
10/06/2022 12:00	15.0	4.2	2.1	11.7	2.6
10/06/2022 13:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 14:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 15:00	15.1	3.9	2.1	11.9	2.6
10/06/2022 16:00	15.4	3.9	2.2	12.1	2.6
10/06/2022 17:00	15.7	3.1	2.3	12.3	2.6
10/06/2022 18:00	15.7	3.2	2.3	12.3	2.6
10/06/2022 19:00	15.8	3.2	2.3	12.4	2.8
10/06/2022 20:00	15.8	3.2	2.3	12.4	2.8
10/06/2022 21:00	15.7	3.3	2.3	12.3	2.6
10/06/2022 22:00	15.4	3.5	2.2	12.1	2.6
10/06/2022 23:00	15.2	4.3	2.2	11.9	2.6
Average/Sum#:	359.4 #	92.4 #	52.3 #	287.3 #	62.3 #
Minimum:	12.4	3.1	2.0	11.4	2.4
Maximum:	15.8	4.6	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/07/2022 00:00	15.0	4.3	2.1	11.8	2.6
10/07/2022 01:00	15.1	4.3	2.1	11.9	2.6
10/07/2022 02:00	15.0	4.3	2.1	11.8	2.6
10/07/2022 03:00	14.8	4.2	2.1	11.6	2.6
10/07/2022 04:00	15.1	4.3	2.1	11.9	2.6
10/07/2022 05:00	15.4	4.3	2.2	12.1	2.6
10/07/2022 06:00	15.4	3.6	2.2	12.1	2.6
10/07/2022 07:00	14.7	4.3	2.1	11.6	2.6
10/07/2022 08:00	12.2	4.6	2.0	11.2	2.4
10/07/2022 09:00	14.9	4.3	2.1	11.7	2.6
10/07/2022 10:00	14.9	4.3	2.1	11.7	2.6
10/07/2022 11:00	14.8	4.2	2.1	11.7	2.6
10/07/2022 12:00	15.2	4.2	2.2	11.9	2.6
10/07/2022 13:00	15.0	4.2	2.1	11.7	2.6
10/07/2022 14:00	15.3	3.9	2.2	12.1	2.6
10/07/2022 15:00	15.4	3.5	2.2	12.1	2.6
10/07/2022 16:00	15.3	3.9	2.2	12.0	2.6
10/07/2022 17:00	15.7	3.5	2.3	12.3	2.6
10/07/2022 18:00	15.7	3.1	2.3	12.3	2.6
10/07/2022 19:00	15.8	3.2	2.3	12.4	2.8
10/07/2022 20:00	15.8	3.2	2.3	12.5	2.8
10/07/2022 21:00	15.8	3.2	2.3	12.5	2.8
10/07/2022 22:00	15.8	3.2	2.3	12.4	2.8
10/07/2022 23:00	15.4	3.6	2.2	12.1	2.6
Average/Sum#:	363.5 #	93.7 #	52.2 #	287.4 #	63.0 #
Minimum:	12.2	3.1	2.0	11.2	2.4
Maximum:	15.8	4.6	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/08/2022 00:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 01:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 02:00	15.2	4.3	2.1	11.9	2.6
10/08/2022 03:00	15.2	4.3	2.2	11.9	2.6
10/08/2022 04:00	15.2	4.2	2.2	12.0	2.6
10/08/2022 05:00	13.0	4.3	2.2	11.9	2.6
10/08/2022 06:00	12.6	4.5	2.1	11.6	2.6
10/08/2022 07:00	10.2	2.5	1.7	9.4	2.0
10/08/2022 08:00	5.5	2.0	1.4	7.5	1.6
10/08/2022 09:00	5.2	1.3	1.3	7.2	1.6
10/08/2022 10:00	5.2	1.3	1.3	7.2	1.6
10/08/2022 11:00	5.3	1.3	1.3	7.2	1.6
10/08/2022 12:00	7.8	2.4	1.6	8.6	1.8
10/08/2022 13:00	10.3	2.6	1.7	9.4	2.0
10/08/2022 14:00	10.5	2.6	1.7	9.6	2.0
10/08/2022 15:00	12.5	5.1	2.0	11.5	2.5
10/08/2022 16:00	15.4	4.2	2.2	12.1	2.6
10/08/2022 17:00	15.4	3.8	2.2	12.1	2.6
10/08/2022 18:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 19:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 20:00	15.2	4.2	2.2	12.1	2.6
10/08/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 22:00	15.2	4.2	2.2	11.9	2.6
10/08/2022 23:00	15.2	4.3	2.2	11.9	2.6
Average/Sum#:	296.1 #	84.6 #	46.8 #	256.5 #	55.7 #
Minimum:	5.2	1.3	1.3	7.2	1.6
Maximum:	15.4	5.1	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/09/2022 00:00	15.2	4.2	2.2	11.9	2.6
10/09/2022 01:00	15.2	4.3	2.2	11.9	2.6
10/09/2022 02:00	15.0	4.2	2.1	11.7	2.6
10/09/2022 03:00	15.0	4.6	2.1	11.9	2.6
10/09/2022 04:00	15.2	4.2	2.1	11.9	2.6
10/09/2022 05:00	15.0	4.2	2.1	11.9	2.6
10/09/2022 06:00	21.9	39.0	1.7	9.2	2.0
10/09/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	0.3	3.9	0.0	0.1	0.0
10/09/2022 11:00	34.4	69.0	0.6	2.0	0.5
10/09/2022 12:00	4.2	1.0	1.0	3.5	0.8
10/09/2022 13:00	4.2	1.1	1.0	3.5	0.8
10/09/2022 14:00	39.8	24.7	1.3	5.2	1.2
10/09/2022 15:00	49.2	36.4	1.5	7.8	1.7
10/09/2022 16:00	10.3	2.6	1.7	9.4	2.0
10/09/2022 17:00	12.4	2.6	1.7	9.8	2.2
10/09/2022 18:00	14.5	5.8	2.1	11.4	2.4
10/09/2022 19:00	17.6	3.8	2.2	12.1	2.6
10/09/2022 20:00	15.3	3.8	2.2	12.1	2.6
10/09/2022 21:00	15.2	4.2	2.2	11.9	2.6
10/09/2022 22:00	15.1	4.2	2.1	11.9	2.6
10/09/2022 23:00	15.0	4.2	2.1	11.8	2.6
Average/Sum#:	360.0 #	232.0 #	36.2 #	192.9 #	42.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.2	69.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/10/2022 00:00	14.9	4.2	2.1	11.7	2.6
10/10/2022 01:00	12.6	4.3	2.1	11.5	2.6
10/10/2022 02:00	13.8	5.6	2.0	10.9	2.4
10/10/2022 03:00	12.6	4.9	2.1	11.5	2.6
10/10/2022 04:00	17.1	4.3	2.1	11.7	2.6
10/10/2022 05:00	15.5	3.6	2.2	12.2	2.6
10/10/2022 06:00	15.5	3.6	2.2	12.1	2.6
10/10/2022 07:00	10.8	3.2	1.8	9.9	2.2
10/10/2022 08:00	7.8	2.3	1.6	8.5	1.8
10/10/2022 09:00	7.7	1.8	1.6	8.5	1.8
10/10/2022 10:00	5.6	1.4	1.4	7.7	1.6
10/10/2022 11:00	7.8	1.8	1.6	8.6	1.8
10/10/2022 12:00	7.9	1.8	1.6	8.6	1.8
10/10/2022 13:00	10.3	1.9	1.7	9.4	2.0
10/10/2022 14:00	10.3	2.2	1.7	9.4	2.0
10/10/2022 15:00	9.6	2.4	1.6	8.8	2.0
10/10/2022 16:00	11.8	5.4	2.0	10.8	2.4
10/10/2022 17:00	15.1	4.5	2.1	11.9	2.6
10/10/2022 18:00	15.4	4.2	2.2	12.1	2.6
10/10/2022 19:00	15.2	4.5	2.2	11.9	2.6
10/10/2022 20:00	15.2	4.5	2.1	11.9	2.6
10/10/2022 21:00	14.7	5.1	2.1	11.6	2.6
10/10/2022 22:00	14.7	5.2	2.1	11.5	2.6
10/10/2022 23:00	13.6	5.5	2.0	10.7	2.4
Average/Sum#:	295.5 #	88.2 #	46.2 #	253.4 #	55.4 #
Minimum:	5.6	1.4	1.4	7.7	1.6
Maximum:	17.1	5.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/11/2022 00:00	6.8	2.3	1.4	7.5	1.6
10/11/2022 01:00	5.2	1.7	1.3	7.2	1.6
10/11/2022 02:00	5.2	1.4	1.3	7.2	1.6
10/11/2022 03:00	5.4	2.0	1.3	7.4	1.6
10/11/2022 04:00	6.0	2.0	1.4	8.2	1.8
10/11/2022 05:00	5.3	2.2	1.3	7.2	1.6
10/11/2022 06:00	5.2	2.5	1.3	7.2	1.6
10/11/2022 07:00	5.2	2.2	1.3	7.3	1.6
10/11/2022 08:00	7.5	2.2	1.4	8.5	1.8
10/11/2022 09:00	7.6	2.0	1.5	8.5	1.9
10/11/2022 10:00	9.8	2.5	1.6	9.1	1.9
10/11/2022 11:00	8.4	2.2	1.6	9.3	2.0
10/11/2022 12:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 13:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 14:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 15:00	10.7	2.6	1.8	9.7	2.1
10/11/2022 16:00	10.7	2.6	1.8	9.8	2.2
10/11/2022 17:00	12.5	2.6	1.8	9.8	2.2
10/11/2022 18:00	12.5	2.6	1.8	9.8	2.2
10/11/2022 19:00	12.2	5.7	2.0	11.2	2.4
10/11/2022 20:00	14.8	4.8	2.1	11.6	2.6
10/11/2022 21:00	16.7	4.5	2.0	11.6	2.5
10/11/2022 22:00	14.7	4.5	2.1	11.6	2.6
10/11/2022 23:00	11.8	4.5	2.0	10.8	2.4
Average/Sum#:	226.3 #	67.4 #	39.5 #	219.6 #	48.1 #
Minimum:	5.2	1.4	1.3	7.2	1.6
Maximum:	16.7	5.7	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/12/2022 00:00	13.6	5.9	2.0	10.7	2.4
10/12/2022 01:00	11.6	5.9	2.0	10.6	2.4
10/12/2022 02:00	7.6	2.3	1.6	8.3	1.8
10/12/2022 03:00	8.1	2.1	1.6	9.0	2.0
10/12/2022 04:00	10.6	2.2	1.7	9.6	2.1
10/12/2022 05:00	12.8	5.4	2.1	11.7	2.6
10/12/2022 06:00	15.8	4.2	2.3	12.5	2.8
10/12/2022 07:00	15.8	3.6	2.3	12.3	2.7
10/12/2022 08:00	15.7	3.6	2.3	12.3	2.6
10/12/2022 09:00	15.7	3.6	2.3	12.3	2.6
10/12/2022 10:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 11:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 12:00	17.9	3.3	2.3	12.3	2.7
10/12/2022 13:00	15.6	3.3	2.3	12.3	2.6
10/12/2022 14:00	15.6	3.6	2.3	12.3	2.6
10/12/2022 15:00	17.9	3.5	2.3	12.3	2.7
10/12/2022 16:00	15.8	3.4	2.3	12.5	2.8
10/12/2022 17:00	15.8	3.4	2.3	12.5	2.8
10/12/2022 18:00	17.8	3.5	2.3	12.3	2.6
10/12/2022 19:00	14.9	4.5	2.1	11.7	2.6
10/12/2022 20:00	15.0	4.5	2.1	11.9	2.6
10/12/2022 21:00	14.9	4.8	2.1	11.6	2.6
10/12/2022 22:00	14.6	5.2	2.1	11.5	2.6
10/12/2022 23:00	13.8	6.2	2.0	10.8	2.4
Average/Sum#:	348.1 #	95.2 #	51.3 #	277.9 #	60.8 #
Minimum:	7.6	2.1	1.6	8.3	1.8
Maximum:	17.9	6.2	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/13/2022 00:00	13.7	6.5	2.0	10.8	2.4
10/13/2022 01:00	12.0	6.2	2.0	11.0	2.4
10/13/2022 02:00	11.7	7.5	2.0	10.7	2.4
10/13/2022 03:00	13.7	6.9	2.0	10.8	2.4
10/13/2022 04:00	11.6	6.8	1.9	10.6	2.4
10/13/2022 05:00	6.5	2.5	1.3	7.2	1.6
10/13/2022 06:00	5.2	2.5	1.3	7.2	1.6
10/13/2022 07:00	5.3	2.3	1.3	7.2	1.6
10/13/2022 08:00	9.3	2.1	1.5	8.5	1.9
10/13/2022 09:00	7.7	2.0	1.6	8.4	1.8
10/13/2022 10:00	10.6	2.6	1.8	9.6	2.1
10/13/2022 11:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 12:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 13:00	12.6	2.6	1.8	9.9	2.2
10/13/2022 14:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 15:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 16:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 17:00	14.3	2.6	1.8	9.8	2.2
10/13/2022 18:00	14.3	2.6	1.8	9.9	2.2
10/13/2022 19:00	14.4	2.9	1.8	9.9	2.2
10/13/2022 20:00	14.4	6.2	2.0	11.3	2.4
10/13/2022 21:00	15.1	5.1	2.1	11.9	2.6
10/13/2022 22:00	16.6	4.9	2.1	11.4	2.5
10/13/2022 23:00	14.5	4.9	2.1	11.4	2.4
Average/Sum#:	291.6 #	92.7 #	43.2 #	236.7 #	52.3 #
Minimum:	5.2	2.0	1.3	7.2	1.6
Maximum:	16.6	7.5	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/14/2022 00:00	14.4	4.6	2.0	11.4	2.4
10/14/2022 01:00	14.5	4.5	2.0	11.3	2.4
10/14/2022 02:00	14.5	4.5	2.0	11.3	2.4
10/14/2022 03:00	14.5	4.2	2.0	11.3	2.4
10/14/2022 04:00	16.9	3.9	2.1	11.5	2.6
10/14/2022 05:00	18.0	3.2	2.3	12.4	2.8
10/14/2022 06:00	15.8	2.9	2.3	12.5	2.8
10/14/2022 07:00	15.7	2.9	2.3	12.4	2.7
10/14/2022 08:00	14.2	3.9	2.0	11.2	2.4
10/14/2022 09:00	15.8	4.5	2.0	10.8	2.4
10/14/2022 10:00	13.8	4.5	2.0	10.8	2.4
10/14/2022 11:00	13.9	4.5	2.0	10.9	2.4
10/14/2022 12:00	14.0	4.8	2.0	11.0	2.4
10/14/2022 13:00	14.0	4.5	2.0	11.0	2.4
10/14/2022 14:00	14.7	4.5	2.1	11.6	2.6
10/14/2022 15:00	14.9	4.2	2.1	11.8	2.6
10/14/2022 16:00	14.9	3.9	2.1	11.8	2.6
10/14/2022 17:00	15.5	3.4	2.3	12.2	2.6
10/14/2022 18:00	15.1	4.2	2.1	11.8	2.6
10/14/2022 19:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 20:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 21:00	14.9	4.2	2.1	11.7	2.6
10/14/2022 22:00	14.7	4.2	2.1	11.5	2.6
10/14/2022 23:00	11.0	23.1	0.7	4.0	0.8
Average/Sum#:	355.5 #	117.5 #	48.8 #	269.6 #	59.1 #
Minimum:	11.0	2.9	0.7	4.0	0.8
Maximum:	18.0	23.1	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	44.1	74.6	0.1	0.7	0.1
10/16/2022 18:00	47.1	60.3	0.2	1.7	0.3
10/16/2022 19:00	44.4	80.7	0.3	2.9	0.6
10/16/2022 20:00	5.3	0.7	0.5	5.3	1.1
10/16/2022 21:00	6.7	0.6	0.5	5.1	1.0
10/16/2022 22:00	4.8	0.6	0.5	4.8	1.0
10/16/2022 23:00	34.7	64.4	0.6	5.8	1.2
Average/Sum#:	187.1 #	281.9 #	2.7 #	26.3 #	5.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	47.1	80.7	0.6	5.8	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/17/2022 00:00	70.9	74.0	1.1	7.0	1.5
10/17/2022 01:00	11.9	2.2	1.7	9.4	2.0
10/17/2022 02:00	12.0	2.2	1.7	9.4	2.0
10/17/2022 03:00	12.6	2.4	1.8	9.9	2.2
10/17/2022 04:00	16.5	4.8	2.1	11.4	2.5
10/17/2022 05:00	17.3	3.9	2.1	12.0	2.6
10/17/2022 06:00	15.1	4.0	2.1	11.8	2.6
10/17/2022 07:00	14.7	4.3	2.1	11.6	2.6
10/17/2022 08:00	11.8	2.4	1.7	9.2	2.0
10/17/2022 09:00	11.5	1.5	1.7	9.0	2.0
10/17/2022 10:00	9.2	2.0	1.6	8.4	1.8
10/17/2022 11:00	9.6	1.8	1.6	8.8	2.0
10/17/2022 12:00	9.0	2.0	1.6	8.3	1.8
10/17/2022 13:00	10.6	2.0	1.6	8.3	1.8
10/17/2022 14:00	10.0	1.9	1.7	9.2	2.0
10/17/2022 15:00	12.0	2.5	1.7	9.4	2.0
10/17/2022 16:00	16.6	5.2	2.1	11.4	2.5
10/17/2022 17:00	15.6	3.9	2.3	12.3	2.6
10/17/2022 18:00	18.0	3.6	2.3	12.4	2.7
10/17/2022 19:00	15.6	3.6	2.3	12.3	2.6
10/17/2022 20:00	15.6	3.6	2.3	12.3	2.6
10/17/2022 21:00	18.0	3.6	2.3	12.3	2.7
10/17/2022 22:00	15.2	4.2	2.2	12.0	2.6
10/17/2022 23:00	15.2	4.2	2.2	12.1	2.6
Average/Sum#:	384.5 #	145.8 #	45.9 #	250.2 #	54.3 #
Minimum:	9.0	1.5	1.1	7.0	1.5
Maximum:	70.9	74.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/18/2022 00:00	15.2	4.2	2.2	11.9	2.6
10/18/2022 01:00	15.2	3.6	2.2	11.9	2.6
10/18/2022 02:00	15.2	3.3	2.2	11.9	2.6
10/18/2022 03:00	15.3	3.3	2.2	12.0	2.6
10/18/2022 04:00	15.3	3.3	2.2	12.0	2.6
10/18/2022 05:00	15.2	3.6	2.2	11.9	2.6
10/18/2022 06:00	15.1	3.9	2.2	11.9	2.6
10/18/2022 07:00	15.1	3.9	2.2	11.9	2.6
10/18/2022 08:00	15.2	4.3	2.2	11.9	2.6
10/18/2022 09:00	15.1	4.3	2.1	11.9	2.6
10/18/2022 10:00	14.9	4.9	2.1	11.7	2.6
10/18/2022 11:00	16.8	4.9	2.1	11.6	2.6
10/18/2022 12:00	14.7	4.5	2.1	11.6	2.6
10/18/2022 13:00	16.8	4.9	2.1	11.6	2.6
10/18/2022 14:00	14.8	4.8	2.1	11.6	2.6
10/18/2022 15:00	14.9	4.8	2.1	11.8	2.6
10/18/2022 16:00	15.6	3.9	2.3	12.2	2.6
10/18/2022 17:00	15.4	4.2	2.2	12.1	2.6
10/18/2022 18:00	17.9	3.9	2.3	12.3	2.6
10/18/2022 19:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 20:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 21:00	15.8	3.6	2.3	12.5	2.8
10/18/2022 22:00	15.4	4.2	2.2	12.1	2.6
10/18/2022 23:00	15.4	4.2	2.2	12.1	2.6
Average/Sum#:	371.9 #	97.7 #	52.6 #	287.4 #	63.0 #
Minimum:	14.7	3.3	2.1	11.6	2.6
Maximum:	17.9	4.9	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/19/2022 00:00	15.3	4.6	2.2	12.0	2.6
10/19/2022 01:00	14.9	4.6	2.1	11.7	2.6
10/19/2022 02:00	14.6	4.2	2.0	11.5	2.5
10/19/2022 03:00	14.9	3.9	2.1	11.7	2.6
10/19/2022 04:00	15.2	3.6	2.2	11.9	2.6
10/19/2022 05:00	15.6	3.2	2.2	12.2	2.6
10/19/2022 06:00	15.6	4.3	2.3	12.2	2.6
10/19/2022 07:00	15.1	4.9	2.1	11.8	2.6
10/19/2022 08:00	17.2	4.9	2.1	11.8	2.6
10/19/2022 09:00	14.7	4.9	2.1	11.6	2.6
10/19/2022 10:00	16.7	4.9	2.1	11.4	2.5
10/19/2022 11:00	14.8	4.8	2.1	11.6	2.6
10/19/2022 12:00	14.9	4.8	2.1	11.7	2.6
10/19/2022 13:00	15.1	4.5	2.1	11.8	2.6
10/19/2022 14:00	15.0	4.5	2.1	11.8	2.6
10/19/2022 15:00	15.3	4.2	2.2	12.0	2.6
10/19/2022 16:00	15.4	4.2	2.2	12.1	2.6
10/19/2022 17:00	14.9	4.8	2.1	11.7	2.6
10/19/2022 18:00	14.7	4.8	2.1	11.6	2.6
10/19/2022 19:00	14.7	4.8	2.1	11.6	2.6
10/19/2022 20:00	15.1	4.9	2.1	11.8	2.6
10/19/2022 21:00	14.9	4.9	2.1	11.6	2.6
10/19/2022 22:00	16.8	4.9	2.1	11.5	2.6
10/19/2022 23:00	16.8	4.9	2.1	11.6	2.6
Average/Sum#:	368.2 #	109.0 #	51.0 #	282.2 #	62.2 #
Minimum:	14.6	3.2	2.0	11.4	2.5
Maximum:	17.2	4.9	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/20/2022 00:00	14.9	4.9	2.1	11.7	2.6
10/20/2022 01:00	16.8	4.9	2.1	11.5	2.6
10/20/2022 02:00	14.6	4.9	2.1	11.4	2.5
10/20/2022 03:00	14.7	5.6	2.1	11.5	2.6
10/20/2022 04:00	17.0	4.9	2.1	11.7	2.6
10/20/2022 05:00	15.5	3.9	2.2	12.2	2.6
10/20/2022 06:00	15.4	4.3	2.2	12.1	2.6
10/20/2022 07:00	14.5	4.9	2.0	11.4	2.4
10/20/2022 08:00	14.4	4.9	2.0	11.3	2.4
10/20/2022 09:00	14.5	5.3	2.1	11.4	2.4
10/20/2022 10:00	14.4	4.9	2.0	11.4	2.4
10/20/2022 11:00	16.7	4.9	2.1	11.4	2.5
10/20/2022 12:00	16.7	4.8	2.1	11.4	2.5
10/20/2022 13:00	14.7	4.9	2.1	11.6	2.6
10/20/2022 14:00	14.9	4.8	2.1	11.7	2.6
10/20/2022 15:00	15.0	4.5	2.1	11.8	2.6
10/20/2022 16:00	15.8	3.9	2.3	12.3	2.7
10/20/2022 17:00	15.3	4.2	2.2	12.0	2.6
10/20/2022 18:00	15.6	4.2	2.3	12.2	2.6
10/20/2022 19:00	14.7	4.8	2.1	11.6	2.6
10/20/2022 20:00	14.7	4.8	2.1	11.6	2.6
10/20/2022 21:00	16.6	4.9	2.1	11.4	2.6
10/20/2022 22:00	14.6	4.9	2.1	11.4	2.6
10/20/2022 23:00	14.9	4.5	2.1	11.7	2.6
Average/Sum#:	366.9 #	113.5 #	50.8 #	279.7 #	61.4 #
Minimum:	14.4	3.9	2.0	11.3	2.4
Maximum:	17.0	5.6	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/21/2022 00:00	13.8	4.1	2.0	10.9	2.4
10/21/2022 01:00	9.4	1.8	1.6	8.7	1.9
10/21/2022 02:00	9.6	2.1	1.6	8.8	2.0
10/21/2022 03:00	9.2	2.4	1.6	8.5	1.8
10/21/2022 04:00	10.2	1.9	1.7	9.4	2.0
10/21/2022 05:00	10.2	2.3	1.7	9.4	2.0
10/21/2022 06:00	9.6	2.1	1.6	8.8	2.0
10/21/2022 07:00	10.0	2.2	1.7	9.2	2.0
10/21/2022 08:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 09:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 10:00	10.3	2.0	1.7	9.4	2.0
10/21/2022 11:00	10.1	1.9	1.7	9.2	2.0
10/21/2022 12:00	9.9	2.4	1.7	9.1	2.0
10/21/2022 13:00	11.4	2.4	1.6	9.0	2.0
10/21/2022 14:00	11.8	2.9	1.7	9.2	2.0
10/21/2022 15:00	9.4	2.9	1.6	8.6	1.8
10/21/2022 16:00	14.7	5.4	2.1	11.5	2.6
10/21/2022 17:00	17.4	4.5	2.2	12.0	2.6
10/21/2022 18:00	14.9	4.8	2.1	11.8	2.6
10/21/2022 19:00	16.8	5.2	2.1	11.5	2.6
10/21/2022 20:00	14.8	4.8	2.1	11.7	2.6
10/21/2022 21:00	15.2	4.5	2.2	11.9	2.6
10/21/2022 22:00	10.3	23.9	0.6	3.4	0.8
10/21/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	269.6 #	90.5 #	40.3 #	220.8 #	48.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	17.4	23.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/22/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/22/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/23/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/23/2022 20:00	44.9	62.4	0.1	0.6	0.1
10/23/2022 21:00	32.6	20.7	0.1	1.1	0.2
10/23/2022 22:00	43.3	42.2	0.2	2.4	0.5
10/23/2022 23:00	2.7	0.3	0.4	4.1	0.8
Average/Sum#:	123.5 #	125.6 #	0.8 #	8.2 #	1.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	44.9	62.4	0.4	4.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/24/2022 00:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 01:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 02:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 03:00	2.7	0.3	0.4	4.1	0.8
10/24/2022 04:00	4.9	0.3	0.5	4.9	1.0
10/24/2022 05:00	5.5	0.3	0.5	5.5	1.1
10/24/2022 06:00	7.3	0.3	0.5	5.5	1.1
10/24/2022 07:00	5.5	0.3	0.5	5.5	1.1
10/24/2022 08:00	7.3	0.3	0.5	5.4	1.1
10/24/2022 09:00	5.4	0.7	0.5	5.4	1.1
10/24/2022 10:00	7.4	0.7	0.6	5.5	1.1
10/24/2022 11:00	7.3	0.7	0.5	5.5	1.1
10/24/2022 12:00	5.3	0.7	0.5	5.3	1.1
10/24/2022 13:00	90.7	75.2	0.8	6.3	1.3
10/24/2022 14:00	45.9	39.3	1.2	5.2	1.2
10/24/2022 15:00	5.3	1.3	1.2	4.4	1.1
10/24/2022 16:00	7.1	1.3	1.2	4.4	1.1
10/24/2022 17:00	7.1	1.3	1.2	4.4	1.1
10/24/2022 18:00	5.4	1.3	1.3	4.5	1.1
10/24/2022 19:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 20:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 21:00	5.4	1.3	1.3	4.5	1.1
10/24/2022 22:00	7.2	1.3	1.3	4.5	1.1
10/24/2022 23:00	5.5	1.3	1.3	4.6	1.1
Average/Sum#:	260.7 #	131.7 #	19.6 #	116.7 #	25.4 #
Minimum:	2.7	0.3	0.4	4.1	0.8
Maximum:	90.7	75.2	1.3	6.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/25/2022 00:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 01:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 02:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 03:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 04:00	7.2	1.3	1.3	4.5	1.1
10/25/2022 05:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 06:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 07:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 08:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 09:00	7.3	1.3	1.3	4.5	1.1
10/25/2022 10:00	7.3	1.3	1.3	4.5	1.1
10/25/2022 11:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 12:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 13:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 14:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 15:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 16:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 17:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 18:00	7.3	1.7	1.3	4.6	1.1
10/25/2022 19:00	7.3	1.7	1.3	4.5	1.1
10/25/2022 20:00	7.2	1.7	1.3	4.5	1.1
10/25/2022 21:00	7.2	1.7	1.3	4.5	1.1
10/25/2022 22:00	5.4	1.3	1.3	4.5	1.1
10/25/2022 23:00	4.9	1.2	1.1	4.1	1.0
Average/Sum#:	159.0 #	35.5 #	31.0 #	108.4 #	26.3 #
Minimum:	4.9	1.2	1.1	4.1	1.0
Maximum:	7.3	1.7	1.3	4.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/26/2022 00:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 01:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 02:00	4.9	1.2	1.1	4.1	1.0
10/26/2022 03:00	4.8	1.2	1.1	4.0	1.0
10/26/2022 04:00	5.4	1.3	1.3	4.5	1.1
10/26/2022 05:00	5.2	1.3	1.2	4.3	1.0
10/26/2022 06:00	5.1	1.3	1.2	4.2	1.0
10/26/2022 07:00	5.2	1.3	1.2	4.4	1.0
10/26/2022 08:00	2.6	6.7	0.1	0.5	0.1
10/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/26/2022 16:00	13.2	14.4	0.1	0.2	0.0
10/26/2022 17:00	44.8	25.5	0.2	0.5	0.1
10/26/2022 18:00	77.8	121.7	0.6	2.1	0.5
10/26/2022 19:00	5.5	1.7	1.3	4.6	1.1
10/26/2022 20:00	7.3	1.7	1.3	4.6	1.1
10/26/2022 21:00	5.4	1.7	1.3	4.5	1.1
10/26/2022 22:00	5.3	1.6	1.2	4.4	1.1
10/26/2022 23:00	6.1	12.5	0.7	2.5	0.6
Average/Sum#:	208.4 #	197.5 #	16.1 #	57.6 #	13.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	77.8	121.7	1.3	4.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/27/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/28/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/28/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/29/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 19:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 20:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 21:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 22:00	0.0	0.0	0.0	0.0	0.0
10/29/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/30/2022 00:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 01:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 02:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 03:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 04:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 05:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 06:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 07:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 14:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 15:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 16:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 17:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 18:00	0.0	0.0	0.0	0.0	0.0
10/30/2022 19:00	3.8	25.9	0.0	0.1	0.0
10/30/2022 20:00	65.6	49.9	0.1	1.1	0.2
10/30/2022 21:00	40.0	53.1	0.2	1.7	0.3
10/30/2022 22:00	59.7	89.0	0.3	2.6	0.5
10/30/2022 23:00	5.3	0.7	0.5	5.3	1.1
Average/Sum#:	174.4 #	218.6 #	1.1 #	10.8 #	2.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	65.6	89.0	0.5	5.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/31/2022 00:00	4.7	0.6	0.5	4.7	0.9
10/31/2022 01:00	62.9	77.4	0.7	6.1	1.3
10/31/2022 02:00	50.7	76.2	1.0	6.8	1.4
10/31/2022 03:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 04:00	10.4	2.3	1.7	9.5	2.0
10/31/2022 05:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 06:00	10.2	2.3	1.7	9.3	2.0
10/31/2022 07:00	10.2	2.3	1.7	9.3	2.0
10/31/2022 08:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 09:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 10:00	10.2	2.3	1.7	9.4	2.0
10/31/2022 11:00	10.2	2.2	1.7	9.3	2.0
10/31/2022 12:00	10.1	1.9	1.7	9.2	2.0
10/31/2022 13:00	10.2	1.9	1.7	9.4	2.0
10/31/2022 14:00	12.4	2.9	1.7	9.7	2.2
10/31/2022 15:00	16.6	6.3	2.1	11.4	2.4
10/31/2022 16:00	14.7	5.6	2.1	11.6	2.6
10/31/2022 17:00	16.6	5.6	2.1	11.4	2.4
10/31/2022 18:00	14.5	5.6	2.1	11.4	2.4
10/31/2022 19:00	16.8	5.2	2.1	11.6	2.6
10/31/2022 20:00	14.7	4.9	2.1	11.5	2.6
10/31/2022 21:00	15.1	4.5	2.1	11.8	2.6
10/31/2022 22:00	14.8	4.2	2.1	11.6	2.6
10/31/2022 23:00	15.0	4.2	2.1	11.7	2.6
Average/Sum#:	381.8 #	227.6 #	41.5 #	234.3 #	50.6 #
Minimum:	4.7	0.6	0.5	4.7	0.9
Maximum:	62.9	77.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/01/2022 00:00	15.2	4.3	2.1	11.9	2.6
11/01/2022 01:00	15.1	4.3	2.1	11.9	2.6
11/01/2022 02:00	15.1	4.3	2.1	11.9	2.6
11/01/2022 03:00	15.2	4.3	2.1	11.9	2.6
11/01/2022 04:00	15.2	4.3	2.2	11.9	2.6
11/01/2022 05:00	17.4	4.3	2.2	11.9	2.6
11/01/2022 06:00	15.7	3.6	2.3	12.3	2.7
11/01/2022 07:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 08:00	15.6	3.3	2.3	12.3	2.6
11/01/2022 09:00	14.9	3.6	2.1	11.6	2.6
11/01/2022 10:00	14.9	4.3	2.1	11.7	2.6
11/01/2022 11:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 12:00	15.3	3.6	2.2	12.0	2.6
11/01/2022 13:00	15.2	3.3	2.2	12.0	2.6
11/01/2022 14:00	14.6	3.6	2.1	11.4	2.5
11/01/2022 15:00	14.7	5.0	2.1	11.5	2.6
11/01/2022 16:00	15.5	4.0	2.2	12.2	2.6
11/01/2022 17:00	16.1	2.9	2.3	12.6	2.8
11/01/2022 18:00	15.4	3.7	2.2	12.1	2.6
11/01/2022 19:00	17.4	3.7	2.1	11.9	2.6
11/01/2022 20:00	15.4	3.7	2.2	12.1	2.6
11/01/2022 21:00	14.6	4.0	2.1	11.4	2.5
11/01/2022 22:00	14.5	4.0	2.1	11.4	2.4
11/01/2022 23:00	11.0	3.3	1.9	10.1	2.2
Average/Sum#:	364.6 #	92.6 #	51.7 #	284.0 #	61.9 #
Minimum:	11.0	2.9	1.9	10.1	2.2
Maximum:	17.4	5.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/02/2022 00:00	6.8	2.1	1.3	7.4	1.6
11/02/2022 01:00	9.8	1.8	1.6	9.0	2.0
11/02/2022 02:00	10.2	2.3	1.7	9.4	2.0
11/02/2022 03:00	6.8	3.1	1.3	7.4	1.6
11/02/2022 04:00	10.1	2.2	1.7	9.2	2.0
11/02/2022 05:00	13.4	4.2	1.9	10.5	2.3
11/02/2022 06:00	15.2	5.2	2.2	11.9	2.6
11/02/2022 07:00	14.9	4.4	2.1	11.7	2.6
11/02/2022 08:00	16.3	4.7	2.0	11.2	2.4
11/02/2022 09:00	10.3	1.9	1.7	9.4	2.0
11/02/2022 10:00	9.2	1.8	1.6	8.5	1.8
11/02/2022 11:00	10.0	1.9	1.7	9.2	2.0
11/02/2022 12:00	9.3	1.8	1.6	8.5	1.8
11/02/2022 13:00	9.4	1.8	1.6	8.6	1.8
11/02/2022 14:00	9.2	2.1	1.6	8.5	1.8
11/02/2022 15:00	9.6	2.1	1.6	8.8	2.0
11/02/2022 16:00	14.6	5.0	2.1	11.5	2.5
11/02/2022 17:00	17.4	4.3	2.2	11.9	2.6
11/02/2022 18:00	17.4	4.4	2.2	11.9	2.6
11/02/2022 19:00	15.2	4.4	2.2	11.9	2.6
11/02/2022 20:00	15.2	4.4	2.2	11.9	2.6
11/02/2022 21:00	15.1	4.4	2.1	11.9	2.6
11/02/2022 22:00	15.2	4.4	2.1	11.9	2.6
11/02/2022 23:00	15.2	4.4	2.2	11.9	2.6
Average/Sum#:	295.8 #	79.1 #	44.5 #	244.0 #	53.0 #
Minimum:	6.8	1.8	1.3	7.4	1.6
Maximum:	17.4	5.2	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/03/2022 00:00	17.4	4.4	2.2	11.9	2.6
11/03/2022 01:00	15.1	4.4	2.1	11.9	2.6
11/03/2022 02:00	15.4	4.4	2.2	12.1	2.6
11/03/2022 03:00	15.6	3.7	2.3	12.3	2.6
11/03/2022 04:00	17.4	4.4	2.1	11.9	2.6
11/03/2022 05:00	15.2	4.4	2.1	11.9	2.6
11/03/2022 06:00	13.4	3.7	2.3	12.3	2.6
11/03/2022 07:00	14.8	4.0	2.1	11.6	2.6
11/03/2022 08:00	8.8	1.7	1.4	8.1	1.8
11/03/2022 09:00	9.4	1.8	1.6	8.6	1.8
11/03/2022 10:00	9.4	1.8	1.6	8.7	1.8
11/03/2022 11:00	9.4	1.5	1.6	8.6	1.8
11/03/2022 12:00	9.5	1.5	1.6	8.7	1.9
11/03/2022 13:00	9.0	1.7	1.4	8.2	1.8
11/03/2022 14:00	9.4	1.8	1.6	8.6	1.8
11/03/2022 15:00	10.7	2.0	1.8	9.8	2.2
11/03/2022 16:00	14.5	5.1	2.1	11.5	2.5
11/03/2022 17:00	15.2	4.4	2.1	11.9	2.6
11/03/2022 18:00	15.2	4.0	2.2	11.9	2.6
11/03/2022 19:00	17.4	3.7	2.2	11.9	2.6
11/03/2022 20:00	15.2	3.7	2.1	11.9	2.6
11/03/2022 21:00	15.1	3.7	2.1	11.9	2.6
11/03/2022 22:00	17.3	3.7	2.1	11.9	2.6
11/03/2022 23:00	15.5	3.7	2.3	12.2	2.6
Average/Sum#:	325.3 #	79.2 #	47.2 #	260.3 #	56.4 #
Minimum:	8.8	1.5	1.4	8.1	1.8
Maximum:	17.4	5.1	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/04/2022 00:00	15.0	4.4	2.1	11.8	2.6
11/04/2022 01:00	14.9	4.4	2.1	11.7	2.6
11/04/2022 02:00	14.5	4.0	2.0	11.4	2.4
11/04/2022 03:00	14.5	4.4	2.1	11.4	2.4
11/04/2022 04:00	15.1	4.4	2.1	11.8	2.6
11/04/2022 05:00	15.8	3.7	2.3	12.4	2.7
11/04/2022 06:00	15.3	4.4	2.2	12.0	2.6
11/04/2022 07:00	14.4	4.4	2.0	11.4	2.4
11/04/2022 08:00	10.4	1.6	1.7	9.5	2.0
11/04/2022 09:00	9.4	1.8	1.6	8.6	1.8
11/04/2022 10:00	7.0	1.6	1.4	7.7	1.6
11/04/2022 11:00	6.6	1.8	1.3	7.3	1.6
11/04/2022 12:00	6.6	1.8	1.3	7.3	1.6
11/04/2022 13:00	6.6	1.6	1.3	7.3	1.6
11/04/2022 14:00	8.4	2.1	1.4	7.7	1.6
11/04/2022 15:00	9.8	2.7	1.6	9.0	2.0
11/04/2022 16:00	14.6	5.0	2.1	11.5	2.5
11/04/2022 17:00	15.0	4.3	2.1	11.7	2.6
11/04/2022 18:00	14.6	4.0	2.0	11.4	2.5
11/04/2022 19:00	14.5	4.0	2.0	11.4	2.5
11/04/2022 20:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 21:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 22:00	14.5	4.0	2.0	11.3	2.4
11/04/2022 23:00	13.8	4.7	2.0	10.8	2.4
Average/Sum#:	300.3 #	83.1 #	44.7 #	249.0 #	53.8 #
Minimum:	6.6	1.6	1.3	7.3	1.6
Maximum:	15.8	5.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/05/2022 00:00	13.8	5.5	2.0	10.8	2.4
11/05/2022 01:00	13.8	5.1	2.0	10.8	2.4
11/05/2022 02:00	11.8	5.5	2.0	10.8	2.4
11/05/2022 03:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 04:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 05:00	13.8	5.8	2.0	10.8	2.4
11/05/2022 06:00	13.6	5.8	1.9	10.6	2.4
11/05/2022 07:00	6.0	12.7	0.1	0.7	0.2
11/05/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/05/2022 13:00	2.8	4.7	0.0	0.1	0.0
11/05/2022 14:00	89.6	76.2	0.5	1.8	0.4
11/05/2022 15:00	4.3	1.4	1.0	3.6	0.9
11/05/2022 16:00	5.1	3.3	1.2	4.3	1.0
11/05/2022 17:00	7.9	4.0	1.4	5.0	1.2
11/05/2022 18:00	7.9	4.3	1.4	4.9	1.2
11/05/2022 19:00	7.9	4.6	1.4	4.9	1.2
11/05/2022 20:00	7.9	5.0	1.4	4.9	1.2
11/05/2022 21:00	6.6	3.2	1.2	4.1	1.0
11/05/2022 22:00	4.2	1.9	1.0	3.5	0.8
11/05/2022 23:00	5.0	1.5	1.2	4.1	1.0
Average/Sum#:	249.6 #	162.1 #	25.7 #	117.3 #	26.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	89.6	76.2	2.0	10.8	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/06/2022 00:00	4.7	1.5	1.1	3.9	0.9
11/06/2022 01:00	4.4	1.6	1.0	3.7	0.9
11/06/2022 02:00	0.9	5.8	0.1	0.2	0.0
11/06/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 09:00	15.5	40.9	0.0	0.3	0.1
11/06/2022 10:00	43.8	26.8	0.1	1.1	0.2
11/06/2022 11:00	43.9	72.4	0.2	2.5	0.5
11/06/2022 12:00	2.8	0.5	0.4	4.2	0.8
11/06/2022 13:00	4.6	0.6	0.5	4.6	0.9
11/06/2022 14:00	4.8	0.6	0.5	4.8	1.0
11/06/2022 15:00	7.8	1.3	0.6	5.9	1.2
11/06/2022 16:00	9.1	1.0	0.7	6.9	1.4
11/06/2022 17:00	9.2	0.7	0.7	6.9	1.4
11/06/2022 18:00	8.0	1.3	0.6	6.0	1.2
11/06/2022 19:00	7.9	1.7	0.6	5.9	1.2
11/06/2022 20:00	8.0	1.7	0.6	6.0	1.2
11/06/2022 21:00	9.8	12.4	0.5	4.9	1.0
11/06/2022 22:00	0.0	0.0	0.0	0.0	0.0
11/06/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	185.2 #	170.8 #	8.2 #	67.8 #	13.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	43.9	72.4	1.1	6.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/07/2022 00:00	2.8	9.5	0.0	0.4	0.1
11/07/2022 01:00	40.5	77.0	0.3	3.0	0.6
11/07/2022 02:00	4.7	0.6	0.5	4.7	0.9
11/07/2022 03:00	24.6	45.7	0.6	5.2	1.1
11/07/2022 04:00	71.4	69.2	0.9	6.4	1.3
11/07/2022 05:00	13.7	2.5	1.7	9.4	2.0
11/07/2022 06:00	16.0	4.6	2.0	11.0	2.4
11/07/2022 07:00	15.6	4.3	2.2	12.2	2.6
11/07/2022 08:00	15.9	4.7	2.0	11.0	2.4
11/07/2022 09:00	13.8	5.0	2.0	10.8	2.4
11/07/2022 10:00	13.8	4.6	2.0	10.8	2.4
11/07/2022 11:00	13.8	4.0	2.0	10.8	2.4
11/07/2022 12:00	13.8	3.6	2.0	10.8	2.4
11/07/2022 13:00	13.8	4.0	2.0	10.8	2.4
11/07/2022 14:00	14.4	4.3	2.0	11.3	2.4
11/07/2022 15:00	15.4	4.0	2.2	12.1	2.6
11/07/2022 16:00	15.7	3.3	2.3	12.4	2.7
11/07/2022 17:00	18.3	2.6	2.3	12.6	2.8
11/07/2022 18:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 19:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 20:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 21:00	16.0	2.6	2.3	12.6	2.8
11/07/2022 22:00	15.7	3.4	2.3	12.4	2.7
11/07/2022 23:00	17.3	3.7	2.2	11.9	2.6
Average/Sum#:	435.0 #	271.0 #	42.7 #	240.4 #	52.4 #
Minimum:	2.8	0.6	0.0	0.4	0.1
Maximum:	71.4	77.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/08/2022 00:00	17.3	4.0	2.2	11.9	2.6
11/08/2022 01:00	15.1	4.0	2.2	11.9	2.6
11/08/2022 02:00	14.7	3.7	2.1	11.5	2.6
11/08/2022 03:00	15.0	4.0	2.1	11.9	2.6
11/08/2022 04:00	15.3	3.7	2.2	12.1	2.6
11/08/2022 05:00	17.7	3.3	2.2	12.2	2.6
11/08/2022 06:00	16.0	2.6	2.3	12.6	2.8
11/08/2022 07:00	15.5	3.3	2.2	12.1	2.6
11/08/2022 08:00	15.4	3.3	2.2	12.1	2.6
11/08/2022 09:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 10:00	17.4	3.7	2.2	12.0	2.6
11/08/2022 11:00	16.2	3.7	2.0	11.1	2.4
11/08/2022 12:00	13.8	4.1	2.0	10.9	2.4
11/08/2022 13:00	13.8	4.1	2.0	10.9	2.4
11/08/2022 14:00	16.4	4.4	2.0	11.3	2.4
11/08/2022 15:00	16.4	4.1	2.0	11.3	2.4
11/08/2022 16:00	15.5	3.7	2.2	12.2	2.6
11/08/2022 17:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 18:00	15.2	4.0	2.2	11.9	2.6
11/08/2022 19:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 20:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 21:00	15.4	3.4	2.2	12.1	2.6
11/08/2022 22:00	15.3	3.3	2.2	12.1	2.6
11/08/2022 23:00	17.1	4.0	2.1	11.7	2.6
Average/Sum#:	375.9 #	87.8 #	51.6 #	284.2 #	61.6 #
Minimum:	13.8	2.6	2.0	10.9	2.4
Maximum:	17.7	4.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/09/2022 00:00	15.0	4.0	2.1	11.9	2.6
11/09/2022 01:00	15.0	4.0	2.1	11.9	2.6
11/09/2022 02:00	17.5	3.7	2.2	12.1	2.6
11/09/2022 03:00	15.4	3.7	2.2	12.1	2.6
11/09/2022 04:00	15.1	4.0	2.1	11.9	2.6
11/09/2022 05:00	18.0	3.3	2.3	12.4	2.7
11/09/2022 06:00	16.1	3.0	2.3	12.6	2.8
11/09/2022 07:00	17.5	3.4	2.2	12.1	2.6
11/09/2022 08:00	17.3	3.4	2.1	11.9	2.6
11/09/2022 09:00	12.2	1.9	1.7	9.6	2.1
11/09/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/09/2022 11:00	9.8	1.2	1.6	9.0	2.0
11/09/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/09/2022 13:00	9.8	1.2	1.6	9.0	2.0
11/09/2022 14:00	10.2	1.3	1.7	9.3	2.0
11/09/2022 15:00	9.8	1.5	1.7	9.0	2.0
11/09/2022 16:00	14.5	4.8	2.1	11.5	2.5
11/09/2022 17:00	15.1	4.0	2.1	11.9	2.6
11/09/2022 18:00	14.1	4.1	2.0	11.0	2.4
11/09/2022 19:00	13.8	4.8	2.0	10.8	2.4
11/09/2022 20:00	13.8	4.8	2.0	10.8	2.4
11/09/2022 21:00	14.0	4.8	2.0	11.0	2.4
11/09/2022 22:00	13.9	4.8	2.0	10.9	2.4
11/09/2022 23:00	13.9	4.8	2.0	10.9	2.4
Average/Sum#:	332.3 #	79.1 #	47.5 #	262.4 #	57.3 #
Minimum:	9.8	1.2	1.6	9.0	2.0
Maximum:	18.0	4.8	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/10/2022 00:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 01:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 02:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 03:00	13.9	4.8	2.0	10.9	2.4
11/10/2022 04:00	16.6	4.4	2.1	11.5	2.5
11/10/2022 05:00	17.4	3.7	2.2	11.9	2.6
11/10/2022 06:00	16.1	3.4	2.3	12.6	2.8
11/10/2022 07:00	14.8	4.1	2.1	11.7	2.6
11/10/2022 08:00	13.8	4.8	2.0	10.9	2.4
11/10/2022 09:00	13.7	4.7	2.0	10.8	2.4
11/10/2022 10:00	10.4	1.3	1.7	9.5	2.0
11/10/2022 11:00	12.0	1.3	1.7	9.4	2.0
11/10/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/10/2022 13:00	9.4	1.2	1.6	8.6	1.8
11/10/2022 14:00	10.3	1.3	1.7	9.4	2.0
11/10/2022 15:00	10.3	1.6	1.7	9.4	2.0
11/10/2022 16:00	15.0	5.1	2.1	11.7	2.6
11/10/2022 17:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 18:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 19:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 20:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 21:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 22:00	15.9	2.6	2.3	12.5	2.8
11/10/2022 23:00	15.8	2.6	2.3	12.4	2.8
Average/Sum#:	336.8 #	75.6 #	49.0 #	267.8 #	58.9 #
Minimum:	9.4	1.2	1.6	8.6	1.8
Maximum:	17.4	5.1	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/11/2022 00:00	15.9	2.7	2.3	12.5	2.8
11/11/2022 01:00	15.9	2.7	2.3	12.5	2.8
11/11/2022 02:00	15.0	3.4	2.1	11.9	2.6
11/11/2022 03:00	15.0	3.4	2.1	11.9	2.6
11/11/2022 04:00	15.9	3.0	2.3	12.5	2.8
11/11/2022 05:00	16.0	3.0	2.3	12.6	2.8
11/11/2022 06:00	16.1	2.8	2.3	12.6	2.8
11/11/2022 07:00	14.8	3.8	2.1	11.7	2.6
11/11/2022 08:00	11.7	4.7	2.0	10.8	2.4
11/11/2022 09:00	10.3	1.3	1.7	9.4	2.0
11/11/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/11/2022 11:00	10.2	1.3	1.7	9.3	2.0
11/11/2022 12:00	10.2	1.3	1.7	9.3	2.0
11/11/2022 13:00	10.2	1.6	1.7	9.4	2.0
11/11/2022 14:00	9.4	1.5	1.6	8.7	1.8
11/11/2022 15:00	10.2	1.6	1.7	9.3	2.0
11/11/2022 16:00	15.8	4.3	2.0	10.9	2.4
11/11/2022 17:00	15.9	2.6	2.3	12.5	2.8
11/11/2022 18:00	15.9	2.6	2.3	12.5	2.8
11/11/2022 19:00	15.8	2.6	2.3	12.4	2.8
11/11/2022 20:00	15.8	2.6	2.3	12.4	2.8
11/11/2022 21:00	15.7	2.6	2.3	12.4	2.7
11/11/2022 22:00	15.7	3.0	2.3	12.3	2.6
11/11/2022 23:00	15.8	3.0	2.3	12.5	2.8
Average/Sum#:	333.5 #	62.7 #	49.7 #	271.7 #	59.7 #
Minimum:	9.4	1.3	1.6	8.7	1.8
Maximum:	16.1	4.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/12/2022 00:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 01:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 02:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 03:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 04:00	16.0	3.0	2.3	12.6	2.8
11/12/2022 05:00	16.0	3.0	2.3	12.6	2.8
11/12/2022 06:00	15.9	3.0	2.3	12.5	2.8
11/12/2022 07:00	14.8	3.7	2.1	11.6	2.6
11/12/2022 08:00	15.4	3.4	2.2	12.1	2.6
11/12/2022 09:00	10.5	1.6	1.7	9.6	2.1
11/12/2022 10:00	9.6	1.2	1.6	8.8	2.0
11/12/2022 11:00	9.4	1.2	1.6	8.6	1.8
11/12/2022 12:00	9.4	1.2	1.6	8.6	1.8
11/12/2022 13:00	9.4	1.2	1.6	8.7	1.8
11/12/2022 14:00	9.3	1.2	1.6	8.5	1.8
11/12/2022 15:00	10.8	1.7	1.8	9.9	2.2
11/12/2022 16:00	14.9	5.0	2.1	11.7	2.6
11/12/2022 17:00	15.9	2.6	2.3	12.4	2.7
11/12/2022 18:00	15.9	2.6	2.3	12.4	2.7
11/12/2022 19:00	15.9	2.6	2.3	12.5	2.8
11/12/2022 20:00	15.9	2.6	2.3	12.6	2.8
11/12/2022 21:00	15.9	2.6	2.3	12.6	2.8
11/12/2022 22:00	17.6	3.0	2.2	12.1	2.6
11/12/2022 23:00	15.4	3.0	2.2	12.1	2.6
Average/Sum#:	337.5 #	61.4 #	49.9 #	272.5 #	59.9 #
Minimum:	9.3	1.2	1.6	8.5	1.8
Maximum:	17.6	5.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/13/2022 00:00	15.2	3.4	2.2	12.0	2.6
11/13/2022 01:00	17.4	3.4	2.2	11.9	2.6
11/13/2022 02:00	15.2	3.4	2.1	11.9	2.6
11/13/2022 03:00	15.4	3.0	2.2	12.1	2.6
11/13/2022 04:00	17.6	3.0	2.2	12.1	2.6
11/13/2022 05:00	15.3	3.4	2.2	12.1	2.6
11/13/2022 06:00	17.6	3.0	2.2	12.1	2.6
11/13/2022 07:00	15.8	2.7	2.3	12.4	2.7
11/13/2022 08:00	13.8	2.3	2.0	10.8	2.4
11/13/2022 09:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 10:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 11:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 12:00	10.2	1.3	1.7	9.4	2.0
11/13/2022 13:00	10.2	1.7	1.7	9.4	2.0
11/13/2022 14:00	10.1	1.6	1.7	9.2	2.0
11/13/2022 15:00	10.7	1.7	1.8	9.8	2.2
11/13/2022 16:00	17.1	3.7	2.1	11.7	2.6
11/13/2022 17:00	15.9	2.3	2.3	12.5	2.8
11/13/2022 18:00	15.9	2.3	2.3	12.5	2.8
11/13/2022 19:00	15.9	2.3	2.3	12.6	2.8
11/13/2022 20:00	16.0	2.3	2.3	12.6	2.8
11/13/2022 21:00	16.1	2.3	2.3	12.6	2.8
11/13/2022 22:00	16.1	2.3	2.3	12.6	2.8
11/13/2022 23:00	16.1	2.3	2.3	12.6	2.8
Average/Sum#:	344.2 #	57.6 #	49.8 #	273.1 #	59.7 #
Minimum:	10.1	1.3	1.7	9.2	2.0
Maximum:	17.6	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/14/2022 00:00	16.1	2.4	2.3	12.6	2.8
11/14/2022 01:00	16.0	2.7	2.3	12.6	2.8
11/14/2022 02:00	15.9	3.1	2.3	12.6	2.8
11/14/2022 03:00	15.1	3.8	2.2	11.9	2.6
11/14/2022 04:00	17.9	3.5	2.3	12.3	2.6
11/14/2022 05:00	16.1	3.1	2.3	12.6	2.8
11/14/2022 06:00	16.1	3.1	2.3	12.6	2.8
11/14/2022 07:00	15.4	3.8	2.2	12.1	2.6
11/14/2022 08:00	15.0	3.8	2.1	11.9	2.6
11/14/2022 09:00	15.1	3.7	2.2	11.9	2.6
11/14/2022 10:00	15.0	3.7	2.1	11.9	2.6
11/14/2022 11:00	14.9	3.4	2.1	11.7	2.6
11/14/2022 12:00	14.8	3.4	2.1	11.7	2.6
11/14/2022 13:00	15.0	3.1	2.1	11.8	2.6
11/14/2022 14:00	15.0	3.1	2.1	11.8	2.6
11/14/2022 15:00	14.5	3.4	2.0	11.4	2.4
11/14/2022 16:00	15.7	2.7	2.3	12.4	2.7
11/14/2022 17:00	15.3	3.0	2.2	12.0	2.6
11/14/2022 18:00	15.2	3.1	2.2	11.9	2.6
11/14/2022 19:00	15.8	2.7	2.3	12.4	2.7
11/14/2022 20:00	15.8	2.7	2.3	12.4	2.7
11/14/2022 21:00	16.0	2.3	2.3	12.5	2.8
11/14/2022 22:00	16.0	2.3	2.3	12.5	2.8
11/14/2022 23:00	15.8	2.3	2.3	12.4	2.7
Average/Sum#:	373.5 #	74.2 #	53.2 #	291.9 #	64.0 #
Minimum:	14.5	2.3	2.0	11.4	2.4
Maximum:	17.9	3.8	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/15/2022 00:00	16.0	2.3	2.3	12.6	2.8
11/15/2022 01:00	16.0	2.3	2.3	12.6	2.8
11/15/2022 02:00	16.1	2.3	2.3	12.6	2.8
11/15/2022 03:00	16.0	2.3	2.3	12.5	2.8
11/15/2022 04:00	16.0	2.3	2.3	12.5	2.8
11/15/2022 05:00	16.0	2.7	2.3	12.5	2.7
11/15/2022 06:00	15.5	3.0	2.2	12.1	2.6
11/15/2022 07:00	15.7	2.7	2.3	12.3	2.7
11/15/2022 08:00	15.2	2.7	2.2	12.0	2.6
11/15/2022 09:00	14.7	3.1	2.1	11.6	2.6
11/15/2022 10:00	15.0	3.7	2.1	11.7	2.6
11/15/2022 11:00	14.3	4.0	2.0	11.3	2.4
11/15/2022 12:00	13.8	5.8	2.0	10.8	2.4
11/15/2022 13:00	13.8	5.8	2.0	10.8	2.4
11/15/2022 14:00	7.9	1.4	2.0	10.8	2.4
11/15/2022 15:00	8.1	1.4	2.0	11.1	2.4
11/15/2022 16:00	15.0	4.0	2.1	11.7	2.6
11/15/2022 17:00	17.2	4.0	2.2	11.8	2.6
11/15/2022 18:00	17.3	3.6	2.2	11.9	2.6
11/15/2022 19:00	15.2	3.3	2.2	11.9	2.6
11/15/2022 20:00	15.3	3.3	2.2	12.0	2.6
11/15/2022 21:00	15.7	2.6	2.3	12.3	2.6
11/15/2022 22:00	17.3	3.3	2.2	11.9	2.6
11/15/2022 23:00	17.3	3.3	2.2	11.9	2.6
Average/Sum#:	344.4 #	72.4 #	52.3 #	285.2 #	62.6 #
Minimum:	13.8	2.3	2.0	10.8	2.4
Maximum:	17.3	5.8	2.3	12.6	2.8
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/16/2022 00:00	17.3	3.3	2.2	11.9	2.6
11/16/2022 01:00	14.9	3.4	2.1	11.7	2.6
11/16/2022 02:00	17.3	3.4	2.1	11.8	2.6
11/16/2022 03:00	17.3	3.4	2.2	11.9	2.6
11/16/2022 04:00	15.5	3.4	2.3	12.2	2.7
11/16/2022 05:00	15.7	3.0	2.3	12.4	2.7
11/16/2022 06:00	15.7	2.7	2.3	12.4	2.7
11/16/2022 07:00	15.8	2.6	2.3	12.3	2.7
11/16/2022 08:00	9.9	4.4	2.0	10.9	2.4
11/16/2022 09:00	8.1	5.3	2.0	11.1	2.4
11/16/2022 10:00	13.8	5.4	2.0	10.9	2.4
11/16/2022 11:00	5.9	4.1	2.0	10.9	2.4
11/16/2022 12:00	13.9	4.0	2.0	10.9	2.4
11/16/2022 13:00	11.9	4.0	2.0	11.0	2.4
11/16/2022 14:00	13.9	4.0	2.0	11.0	2.4
11/16/2022 15:00	14.8	3.3	2.1	11.6	2.6
11/16/2022 16:00	15.2	2.7	2.2	11.9	2.6
11/16/2022 17:00	17.5	2.7	2.2	12.0	2.6
11/16/2022 18:00	15.8	2.3	2.3	12.4	2.7
11/16/2022 19:00	15.8	2.3	2.3	12.5	2.7
11/16/2022 20:00	15.8	2.3	2.3	12.5	2.7
11/16/2022 21:00	15.8	2.7	2.3	12.4	2.7
11/16/2022 22:00	15.5	2.7	2.3	12.2	2.6
11/16/2022 23:00	15.7	2.7	2.3	12.4	2.7
Average/Sum#:	342.9 #	76.0 #	52.1 #	283.2 #	61.9 #
Minimum:	8.1	2.3	2.0	10.9	2.4
Maximum:	17.5	5.4	2.3	12.5	2.7
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/17/2022 00:00	15.2	2.7	2.2	11.9	2.6
11/17/2022 01:00	17.3	2.7	2.2	11.9	2.6
11/17/2022 02:00	15.1	2.7	2.1	11.9	2.6
11/17/2022 03:00	15.1	2.7	2.1	11.9	2.6
11/17/2022 04:00	15.4	2.7	2.3	12.1	2.6
11/17/2022 05:00	13.6	2.3	2.3	12.4	2.7
11/17/2022 06:00	16.0	2.3	2.3	12.6	2.8
11/17/2022 07:00	17.4	2.7	2.2	11.9	2.6
11/17/2022 08:00	13.9	3.4	2.0	11.0	2.4
11/17/2022 09:00	17.1	2.7	2.1	11.8	2.6
11/17/2022 10:00	14.9	2.7	2.1	11.7	2.6
11/17/2022 11:00	15.1	2.6	2.2	11.8	2.6
11/17/2022 12:00	15.3	2.3	2.2	12.0	2.6
11/17/2022 13:00	15.2	2.3	2.2	12.0	2.6
11/17/2022 14:00	16.1	2.3	2.0	11.0	2.4
11/17/2022 15:00	14.9	2.3	2.1	11.7	2.6
11/17/2022 16:00	15.7	2.3	2.3	12.3	2.6
11/17/2022 17:00	15.9	2.0	2.3	12.5	2.8
11/17/2022 18:00	15.9	2.0	2.3	12.4	2.8
11/17/2022 19:00	15.9	2.0	2.3	12.4	2.8
11/17/2022 20:00	15.9	2.3	2.3	12.5	2.8
11/17/2022 21:00	15.9	2.0	2.3	12.5	2.8
11/17/2022 22:00	15.8	2.3	2.3	12.4	2.7
11/17/2022 23:00	15.5	2.7	2.2	12.2	2.6
Average/Sum#:	374.1 #	59.0 #	52.9 #	288.8 #	63.4 #
Minimum:	13.6	2.0	2.0	11.0	2.4
Maximum:	17.4	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/18/2022 00:00	15.2	2.7	2.2	11.9	2.6
11/18/2022 01:00	17.5	2.7	2.2	12.0	2.6
11/18/2022 02:00	15.3	2.6	2.2	12.0	2.6
11/18/2022 03:00	17.5	2.7	2.2	12.0	2.6
11/18/2022 04:00	15.6	2.0	2.3	12.4	2.7
11/18/2022 05:00	15.7	2.0	2.3	12.3	2.7
11/18/2022 06:00	15.6	2.0	2.2	12.3	2.7
11/18/2022 07:00	15.8	2.3	2.3	12.5	2.8
11/18/2022 08:00	17.3	2.6	2.2	11.9	2.6
11/18/2022 09:00	17.3	2.6	2.2	12.0	2.6
11/18/2022 10:00	15.3	2.3	2.2	12.0	2.6
11/18/2022 11:00	14.8	2.3	2.1	11.7	2.6
11/18/2022 12:00	15.7	2.7	2.0	10.8	2.4
11/18/2022 13:00	15.7	2.7	2.0	10.8	2.4
11/18/2022 14:00	13.8	2.6	2.0	10.8	2.4
11/18/2022 15:00	14.3	2.6	2.0	11.3	2.4
11/18/2022 16:00	15.6	2.3	2.3	12.3	2.6
11/18/2022 17:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 18:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 19:00	15.8	2.3	2.3	12.4	2.7
11/18/2022 20:00	15.7	2.3	2.3	12.4	2.7
11/18/2022 21:00	15.7	2.0	2.3	12.3	2.7
11/18/2022 22:00	13.4	2.0	2.2	12.3	2.7
11/18/2022 23:00	15.9	2.0	2.3	12.5	2.7
Average/Sum#:	375.9 #	56.9 #	52.9 #	287.7 #	62.8 #
Minimum:	13.4	2.0	2.0	10.8	2.4
Maximum:	17.5	2.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/19/2022 00:00	15.3	2.7	2.2	12.0	2.6
11/19/2022 01:00	15.1	2.7	2.2	11.9	2.6
11/19/2022 02:00	15.1	2.7	2.2	11.8	2.6
11/19/2022 03:00	15.0	2.7	2.1	11.7	2.6
11/19/2022 04:00	15.7	2.7	2.3	12.3	2.6
11/19/2022 05:00	15.9	2.3	2.3	12.4	2.8
11/19/2022 06:00	17.7	2.7	2.2	12.2	2.6
11/19/2022 07:00	14.9	2.7	2.1	11.7	2.6
11/19/2022 08:00	11.8	3.7	2.0	10.8	2.4
11/19/2022 09:00	13.8	3.7	2.0	10.8	2.4
11/19/2022 10:00	13.8	3.7	2.0	10.8	2.4
11/19/2022 11:00	15.7	3.6	2.0	10.8	2.4
11/19/2022 12:00	13.8	3.3	2.0	10.8	2.4
11/19/2022 13:00	15.7	3.0	2.0	10.8	2.4
11/19/2022 14:00	15.7	3.0	2.0	10.8	2.4
11/19/2022 15:00	14.3	2.6	2.0	11.3	2.4
11/19/2022 16:00	15.2	2.3	2.2	12.0	2.6
11/19/2022 17:00	15.3	2.3	2.2	12.0	2.6
11/19/2022 18:00	15.3	2.3	2.2	12.0	2.6
11/19/2022 19:00	15.8	2.0	2.3	12.5	2.8
11/19/2022 20:00	15.8	2.0	2.3	12.5	2.7
11/19/2022 21:00	15.6	2.0	2.3	12.3	2.7
11/19/2022 22:00	13.5	2.4	2.3	12.4	2.7
11/19/2022 23:00	15.8	2.3	2.3	12.3	2.7
Average/Sum#:	361.6 #	65.4 #	51.7 #	280.9 #	61.6 #
Minimum:	11.8	2.0	2.0	10.8	2.4
Maximum:	17.7	3.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/20/2022 00:00	13.1	2.7	2.2	11.9	2.7
11/20/2022 01:00	13.0	2.3	2.2	11.9	2.6
11/20/2022 02:00	13.1	2.3	2.2	12.0	2.6
11/20/2022 03:00	13.3	2.4	2.2	12.0	2.6
11/20/2022 04:00	11.0	2.4	2.2	12.0	2.6
11/20/2022 05:00	16.0	2.4	2.3	12.5	2.7
11/20/2022 06:00	15.9	2.7	2.3	12.4	2.8
11/20/2022 07:00	14.8	2.7	2.1	11.5	2.6
11/20/2022 08:00	10.3	1.0	1.7	9.4	2.0
11/20/2022 09:00	8.6	1.0	1.7	9.4	2.0
11/20/2022 10:00	9.4	0.9	1.6	8.6	1.8
11/20/2022 11:00	7.8	0.9	1.6	8.6	1.8
11/20/2022 12:00	7.7	0.9	1.6	8.5	1.8
11/20/2022 13:00	7.6	0.9	1.6	8.4	1.8
11/20/2022 14:00	10.2	0.9	1.7	9.3	2.0
11/20/2022 15:00	10.3	1.0	1.7	9.5	2.0
11/20/2022 16:00	15.0	2.6	2.1	11.9	2.6
11/20/2022 17:00	15.9	2.3	2.3	12.5	2.8
11/20/2022 18:00	15.9	2.3	2.3	12.4	2.8
11/20/2022 19:00	15.8	2.3	2.3	12.4	2.8
11/20/2022 20:00	15.8	2.3	2.3	12.4	2.8
11/20/2022 21:00	15.4	2.3	2.2	12.1	2.6
11/20/2022 22:00	15.2	2.7	2.2	11.9	2.6
11/20/2022 23:00	15.0	3.0	2.1	11.9	2.6
Average/Sum#:	306.1 #	47.2 #	48.7 #	265.4 #	58.0 #
Minimum:	7.6	0.9	1.6	8.4	1.8
Maximum:	16.0	3.0	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/21/2022 00:00	15.1	2.7	2.1	11.9	2.6
11/21/2022 01:00	15.0	2.7	2.1	11.7	2.6
11/21/2022 02:00	16.4	3.4	2.0	11.3	2.4
11/21/2022 03:00	17.4	3.0	2.2	11.9	2.6
11/21/2022 04:00	15.8	2.7	2.3	12.4	2.8
11/21/2022 05:00	18.2	2.7	2.3	12.5	2.8
11/21/2022 06:00	16.0	2.7	2.3	12.6	2.8
11/21/2022 07:00	15.0	3.0	2.1	11.9	2.6
11/21/2022 08:00	11.8	4.0	2.0	10.8	2.4
11/21/2022 09:00	11.8	4.4	2.0	10.8	2.4
11/21/2022 10:00	11.8	4.0	2.0	10.8	2.4
11/21/2022 11:00	15.7	3.3	2.0	10.8	2.4
11/21/2022 12:00	15.8	3.0	2.0	10.8	2.4
11/21/2022 13:00	13.8	2.6	2.0	10.8	2.4
11/21/2022 14:00	15.1	2.6	2.1	11.9	2.6
11/21/2022 15:00	15.8	2.0	2.3	12.5	2.8
11/21/2022 16:00	15.6	2.6	2.3	12.3	2.6
11/21/2022 17:00	15.8	2.3	2.3	12.4	2.7
11/21/2022 18:00	15.8	2.3	2.3	12.5	2.7
11/21/2022 19:00	15.9	2.3	2.3	12.4	2.8
11/21/2022 20:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 21:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 22:00	15.9	2.3	2.3	12.5	2.8
11/21/2022 23:00	15.6	2.3	2.3	12.3	2.6
Average/Sum#:	366.9 #	67.5 #	52.2 #	284.8 #	62.8 #
Minimum:	11.8	2.0	2.0	10.8	2.4
Maximum:	18.2	4.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/22/2022 00:00	15.0	2.7	2.1	11.9	2.6
11/22/2022 01:00	14.9	3.0	2.1	11.7	2.6
11/22/2022 02:00	14.7	3.0	2.1	11.5	2.6
11/22/2022 03:00	11.8	3.3	2.0	10.8	2.4
11/22/2022 04:00	13.9	3.7	2.0	10.9	2.4
11/22/2022 05:00	12.4	3.3	2.0	11.4	2.4
11/22/2022 06:00	15.0	3.0	2.1	11.9	2.6
11/22/2022 07:00	12.6	3.4	2.1	11.5	2.6
11/22/2022 08:00	16.4	3.7	2.0	11.3	2.4
11/22/2022 09:00	10.7	15.0	1.4	8.0	1.7
11/22/2022 10:00	3.3	0.0	0.5	5.0	1.0
11/22/2022 11:00	3.6	0.1	0.5	5.4	1.1
11/22/2022 12:00	44.0	83.5	1.0	6.6	1.4
11/22/2022 13:00	8.1	1.2	1.6	9.0	2.0
11/22/2022 14:00	9.0	1.0	1.8	9.8	2.2
11/22/2022 15:00	10.8	1.0	1.8	9.8	2.2
11/22/2022 16:00	13.4	2.3	1.9	10.5	2.3
11/22/2022 17:00	17.4	3.0	2.2	12.0	2.6
11/22/2022 18:00	14.3	3.0	2.0	11.3	2.4
11/22/2022 19:00	15.9	3.3	2.0	11.0	2.4
11/22/2022 20:00	17.2	3.0	2.1	11.8	2.6
11/22/2022 21:00	16.2	3.3	2.0	11.1	2.4
11/22/2022 22:00	14.3	3.3	2.0	11.2	2.4
11/22/2022 23:00	11.8	4.0	2.0	10.8	2.4
Average/Sum#:	336.7 #	156.1 #	43.3 #	246.2 #	53.7 #
Minimum:	3.3	0.0	0.5	5.0	1.0
Maximum:	44.0	83.5	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/23/2022 00:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 01:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 02:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 03:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 04:00	11.8	4.0	2.0	10.8	2.4
11/23/2022 05:00	16.5	2.9	2.0	11.3	2.4
11/23/2022 06:00	14.3	3.3	2.0	11.3	2.4
11/23/2022 07:00	14.7	3.0	2.1	11.6	2.6
11/23/2022 08:00	16.0	3.3	2.0	11.0	2.4
11/23/2022 09:00	8.5	1.0	1.7	9.4	2.0
11/23/2022 10:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 11:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 12:00	5.7	0.8	1.4	7.9	1.8
11/23/2022 13:00	7.8	0.9	1.6	8.6	1.8
11/23/2022 14:00	8.2	0.9	1.6	9.0	2.0
11/23/2022 15:00	9.9	0.9	1.7	9.0	2.0
11/23/2022 16:00	14.7	3.6	2.1	11.5	2.6
11/23/2022 17:00	17.3	3.0	2.2	12.0	2.6
11/23/2022 18:00	14.6	3.3	2.1	11.5	2.5
11/23/2022 19:00	14.4	4.0	2.0	11.3	2.4
11/23/2022 20:00	17.3	3.0	2.2	11.9	2.6
11/23/2022 21:00	15.3	3.0	2.2	12.0	2.6
11/23/2022 22:00	17.3	3.0	2.2	11.9	2.6
11/23/2022 23:00	15.1	3.0	2.2	11.9	2.6
Average/Sum#:	302.2 #	64.7 #	46.5 #	254.3 #	55.5 #
Minimum:	5.7	0.8	1.4	7.9	1.8
Maximum:	17.3	4.0	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/24/2022 00:00	13.9	4.3	2.0	10.9	2.4
11/24/2022 01:00	13.8	5.4	2.0	10.8	2.4
11/24/2022 02:00	11.8	5.4	2.0	10.8	2.4
11/24/2022 03:00	16.0	3.3	2.0	11.0	2.4
11/24/2022 04:00	14.0	3.3	2.0	11.1	2.4
11/24/2022 05:00	14.5	2.9	2.0	11.4	2.5
11/24/2022 06:00	15.3	2.6	2.2	12.0	2.6
11/24/2022 07:00	14.6	2.6	2.1	11.5	2.5
11/24/2022 08:00	8.5	1.0	1.7	9.4	2.0
11/24/2022 09:00	8.5	1.0	1.7	9.4	2.0
11/24/2022 10:00	10.3	1.0	1.7	9.4	2.0
11/24/2022 11:00	7.8	0.9	1.6	8.5	1.8
11/24/2022 12:00	5.4	0.8	1.3	7.4	1.6
11/24/2022 13:00	5.4	0.8	1.3	7.4	1.6
11/24/2022 14:00	7.8	0.9	1.6	8.6	1.8
11/24/2022 15:00	7.3	0.8	1.4	7.9	1.8
11/24/2022 16:00	10.6	1.0	1.7	9.7	2.2
11/24/2022 17:00	10.6	1.0	1.7	9.7	2.2
11/24/2022 18:00	8.7	1.0	1.7	9.6	2.0
11/24/2022 19:00	10.4	1.0	1.7	9.5	2.0
11/24/2022 20:00	8.7	1.3	1.7	9.6	2.0
11/24/2022 21:00	8.7	1.3	1.7	9.6	2.0
11/24/2022 22:00	10.5	1.3	1.7	9.6	2.1
11/24/2022 23:00	10.5	1.3	1.7	9.6	2.1
Average/Sum#:	253.6 #	46.2 #	42.2 #	234.4 #	50.8 #
Minimum:	5.4	0.8	1.3	7.4	1.6
Maximum:	16.0	5.4	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/25/2022 00:00	8.8	1.3	1.7	9.6	2.1
11/25/2022 01:00	10.5	1.3	1.7	9.6	2.1
11/25/2022 02:00	8.8	1.3	1.7	9.6	2.1
11/25/2022 03:00	10.6	1.3	1.7	9.7	2.2
11/25/2022 04:00	10.6	1.0	1.7	9.7	2.2
11/25/2022 05:00	8.8	1.3	1.7	9.7	2.2
11/25/2022 06:00	10.6	1.3	1.7	9.7	2.2
11/25/2022 07:00	8.8	1.3	1.7	9.7	2.2
11/25/2022 08:00	9.4	2.7	1.9	10.3	2.2
11/25/2022 09:00	11.6	2.9	1.9	10.6	2.4
11/25/2022 10:00	8.3	0.9	1.7	9.2	2.0
11/25/2022 11:00	7.7	1.2	1.6	8.5	1.8
11/25/2022 12:00	7.8	0.9	1.6	8.6	1.8
11/25/2022 13:00	7.7	0.9	1.6	8.5	1.8
11/25/2022 14:00	7.6	1.1	1.6	8.4	1.8
11/25/2022 15:00	8.2	1.2	1.7	9.0	2.0
11/25/2022 16:00	16.7	3.6	2.1	11.5	2.5
11/25/2022 17:00	14.8	3.0	2.1	11.5	2.6
11/25/2022 18:00	15.8	3.3	2.0	10.8	2.4
11/25/2022 19:00	13.7	3.6	2.0	10.8	2.4
11/25/2022 20:00	11.8	3.6	2.0	10.8	2.4
11/25/2022 21:00	11.8	4.0	2.0	10.8	2.4
11/25/2022 22:00	14.9	3.0	2.1	11.7	2.6
11/25/2022 23:00	14.6	3.0	2.1	11.5	2.5
Average/Sum#:	259.9 #	49.0 #	43.6 #	239.8 #	52.9 #
Minimum:	7.6	0.9	1.6	8.4	1.8
Maximum:	16.7	4.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/26/2022 00:00	16.2	3.3	2.0	11.1	2.4
11/26/2022 01:00	14.5	3.3	2.0	11.4	2.4
11/26/2022 02:00	20.5	26.2	1.6	8.6	1.8
11/26/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 15:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 16:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 17:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 18:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 19:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 20:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 21:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 22:00	0.0	0.0	0.0	0.0	0.0
11/26/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	51.2 #	32.8 #	5.6 #	31.1 #	6.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	20.5	26.2	2.0	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
11/27/2022 21:00	47.2	56.5	0.1	0.7	0.1
11/27/2022 22:00	34.9	21.0	0.1	1.2	0.2
11/27/2022 23:00	46.9	68.1	0.3	2.7	0.5
Average/Sum#:	129.0 #	145.6 #	0.5 #	4.6 #	0.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	47.2	68.1	0.3	2.7	0.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/28/2022 00:00	1.6	0.0	0.5	4.7	0.9
11/28/2022 01:00	3.0	0.0	0.4	4.5	0.9
11/28/2022 02:00	67.0	67.6	0.7	6.1	1.2
11/28/2022 03:00	43.9	61.6	1.2	7.0	1.5
11/28/2022 04:00	10.3	1.3	1.7	9.4	2.0
11/28/2022 05:00	9.9	1.5	1.7	9.0	2.0
11/28/2022 06:00	15.2	3.7	2.2	11.9	2.6
11/28/2022 07:00	15.9	3.0	2.3	12.5	2.8
11/28/2022 08:00	13.8	3.3	2.0	10.8	2.4
11/28/2022 09:00	9.7	1.2	1.6	8.8	2.0
11/28/2022 10:00	10.3	1.3	1.7	9.4	2.0
11/28/2022 11:00	7.6	1.1	1.6	8.4	1.8
11/28/2022 12:00	7.8	0.9	1.6	8.6	1.8
11/28/2022 13:00	9.9	0.9	1.7	9.0	2.0
11/28/2022 14:00	8.1	0.9	1.6	9.0	2.0
11/28/2022 15:00	9.7	1.2	1.6	9.0	2.0
11/28/2022 16:00	12.2	3.3	2.0	11.2	2.4
11/28/2022 17:00	14.7	3.0	2.1	11.5	2.6
11/28/2022 18:00	15.9	3.0	2.0	11.0	2.4
11/28/2022 19:00	11.8	3.6	2.0	10.8	2.4
11/28/2022 20:00	14.6	3.4	2.1	11.5	2.5
11/28/2022 21:00	15.6	2.7	2.2	12.2	2.6
11/28/2022 22:00	14.7	3.0	2.1	11.5	2.6
11/28/2022 23:00	13.9	3.4	2.0	11.0	2.4
Average/Sum#:	357.1 #	174.9 #	40.6 #	228.8 #	49.8 #
Minimum:	1.6	0.0	0.4	4.5	0.9
Maximum:	67.0	67.6	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/29/2022 00:00	15.1	3.0	2.1	11.9	2.6
11/29/2022 01:00	17.6	3.0	2.2	12.1	2.6
11/29/2022 02:00	17.5	3.0	2.2	12.0	2.6
11/29/2022 03:00	14.7	3.4	2.1	11.5	2.6
11/29/2022 04:00	15.0	3.0	2.1	11.9	2.6
11/29/2022 05:00	15.4	3.0	2.2	12.1	2.6
11/29/2022 06:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 07:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 08:00	15.8	2.6	2.3	12.4	2.7
11/29/2022 09:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 10:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 11:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 12:00	15.0	2.6	2.1	11.8	2.6
11/29/2022 13:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 14:00	17.1	2.6	2.1	11.8	2.6
11/29/2022 15:00	17.3	2.6	2.2	11.9	2.6
11/29/2022 16:00	15.9	2.3	2.3	12.4	2.8
11/29/2022 17:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 18:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 19:00	16.0	2.3	2.3	12.6	2.8
11/29/2022 20:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 21:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 22:00	16.0	2.7	2.3	12.6	2.8
11/29/2022 23:00	16.0	2.7	2.3	12.6	2.8
Average/Sum#:	389.2 #	64.6 #	53.2 #	292.6 #	64.5 #
Minimum:	14.7	2.3	2.1	11.5	2.6
Maximum:	17.6	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/30/2022 00:00	15.2	3.1	2.2	11.9	2.6
11/30/2022 01:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 02:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 03:00	15.1	3.0	2.1	11.9	2.6
11/30/2022 04:00	17.4	3.1	2.2	11.9	2.6
11/30/2022 05:00	17.4	3.4	2.2	11.9	2.6
11/30/2022 06:00	13.6	3.1	2.3	12.4	2.8
11/30/2022 07:00	15.0	3.0	2.1	11.9	2.6
11/30/2022 08:00	11.9	4.7	2.0	11.0	2.4
11/30/2022 09:00	14.0	4.7	2.0	11.0	2.4
11/30/2022 10:00	11.8	4.4	2.0	10.8	2.4
11/30/2022 11:00	11.9	4.3	2.0	10.9	2.4
11/30/2022 12:00	15.8	4.3	2.0	10.9	2.4
11/30/2022 13:00	15.8	3.6	2.0	10.8	2.4
11/30/2022 14:00	16.9	2.9	2.1	11.7	2.6
11/30/2022 15:00	17.1	2.9	2.1	11.7	2.6
11/30/2022 16:00	15.7	2.6	2.3	12.3	2.7
11/30/2022 17:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 18:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 19:00	16.0	2.3	2.3	12.6	2.8
11/30/2022 20:00	16.0	2.3	2.3	12.5	2.8
11/30/2022 21:00	15.7	2.6	2.3	12.4	2.7
11/30/2022 22:00	14.7	3.0	2.1	11.5	2.6
11/30/2022 23:00	17.4	27.6	1.6	8.8	2.0
Average/Sum#:	366.6 #	101.5 #	51.0 #	279.8 #	61.8 #
Minimum:	11.8	2.3	1.6	8.8	2.0
Maximum:	17.4	27.6	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/01/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/01/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/01/2022 02:00	2.4	8.0	0.0	0.4	0.1
12/01/2022 03:00	28.6	57.5	0.3	3.4	0.7
12/01/2022 04:00	3.4	0.0	0.5	5.1	1.0
12/01/2022 05:00	3.6	0.0	0.5	5.4	1.1
12/01/2022 06:00	9.2	0.0	0.7	6.9	1.4
12/01/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 08:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 09:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 10:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 11:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 12:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 13:00	8.7	0.0	0.7	6.5	1.3
12/01/2022 14:00	8.8	0.0	0.7	6.6	1.3
12/01/2022 15:00	9.2	0.0	0.7	6.9	1.4
12/01/2022 16:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 17:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 19:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 20:00	9.4	0.0	0.7	7.0	1.4
12/01/2022 21:00	9.3	0.0	0.7	7.0	1.4
12/01/2022 22:00	8.7	0.0	0.7	6.6	1.3
12/01/2022 23:00	8.7	0.0	0.7	6.5	1.3
Average/Sum#:	200.6 #	65.5 #	13.9 #	136.1 #	27.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	28.6	57.5	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/02/2022 00:00	8.7	0.0	0.7	6.5	1.3
12/02/2022 01:00	8.7	0.0	0.7	6.6	1.3
12/02/2022 02:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 03:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 04:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 05:00	8.7	0.3	0.7	6.5	1.3
12/02/2022 06:00	9.2	0.0	0.7	6.9	1.4
12/02/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 08:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 09:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 10:00	8.8	0.3	0.7	6.6	1.3
12/02/2022 11:00	8.9	0.0	0.7	6.6	1.3
12/02/2022 12:00	8.9	0.0	0.7	6.7	1.3
12/02/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/02/2022 14:00	8.7	0.0	0.7	6.6	1.3
12/02/2022 15:00	9.2	0.0	0.7	6.9	1.4
12/02/2022 16:00	9.4	0.0	0.7	7.0	1.4
12/02/2022 17:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 19:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/02/2022 21:00	9.3	0.0	0.7	6.9	1.4
12/02/2022 22:00	9.3	0.0	0.7	6.9	1.4
12/02/2022 23:00	9.3	0.0	0.7	7.0	1.4
Average/Sum#:	216.7 #	1.8 #	16.8 #	162.5 #	32.4 #
Minimum:	8.7	0.0	0.7	6.5	1.3
Maximum:	9.4	0.3	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/03/2022 00:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 01:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 02:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 03:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 04:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 05:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 06:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 07:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 08:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 09:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 10:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 11:00	9.1	0.0	0.7	6.8	1.4
12/03/2022 12:00	9.2	0.0	0.7	6.9	1.4
12/03/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/03/2022 14:00	8.7	0.3	0.7	6.6	1.3
12/03/2022 15:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 16:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 17:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 18:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 19:00	9.3	0.0	0.7	6.9	1.4
12/03/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/03/2022 21:00	9.4	0.0	0.7	7.0	1.4
12/03/2022 22:00	9.4	0.0	0.7	7.1	1.4
12/03/2022 23:00	9.4	0.0	0.7	7.0	1.4
Average/Sum#:	221.9 #	0.3 #	16.8 #	166.5 #	33.4 #
Minimum:	8.7	0.0	0.7	6.6	1.3
Maximum:	9.4	0.3	0.7	7.1	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/04/2022 00:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 01:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 02:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 03:00	8.8	0.3	0.7	6.6	1.3
12/04/2022 04:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 05:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 06:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 07:00	9.4	0.0	0.7	7.0	1.4
12/04/2022 08:00	8.9	0.0	0.7	6.6	1.3
12/04/2022 09:00	8.8	0.3	0.7	6.6	1.3
12/04/2022 10:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 11:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 12:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 13:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 14:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 15:00	8.8	0.0	0.7	6.6	1.3
12/04/2022 16:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 17:00	9.4	0.0	0.7	7.0	1.4
12/04/2022 18:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 19:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 20:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 21:00	9.3	0.0	0.7	7.0	1.4
12/04/2022 22:00	9.2	0.0	0.7	6.9	1.4
12/04/2022 23:00	8.8	0.0	0.7	6.6	1.3
Average/Sum#:	215.9 #	0.6 #	16.8 #	161.9 #	32.1 #
Minimum:	8.8	0.0	0.7	6.6	1.3
Maximum:	9.4	0.3	0.7	7.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/05/2022 00:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 01:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 02:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 03:00	8.8	0.0	0.7	6.6	1.3
12/05/2022 04:00	8.9	0.0	0.7	6.6	1.3
12/05/2022 05:00	9.3	0.0	0.7	7.0	1.4
12/05/2022 06:00	9.4	0.0	0.7	7.0	1.4
12/05/2022 07:00	9.4	0.0	0.7	7.0	1.4
12/05/2022 08:00	9.4	0.0	0.7	7.1	1.4
12/05/2022 09:00	9.5	0.5	0.7	7.1	1.4
12/05/2022 10:00	82.4	89.5	0.9	7.6	1.6
12/05/2022 11:00	23.4	6.8	1.8	10.0	2.2
12/05/2022 12:00	15.0	2.9	2.1	11.9	2.6
12/05/2022 13:00	14.1	2.9	2.0	11.1	2.4
12/05/2022 14:00	14.3	2.9	2.0	11.3	2.4
12/05/2022 15:00	16.5	2.6	2.0	11.3	2.4
12/05/2022 16:00	15.5	2.6	2.2	12.2	2.6
12/05/2022 17:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 18:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 19:00	16.0	2.3	2.3	12.6	2.8
12/05/2022 20:00	16.0	2.6	2.3	12.6	2.8
12/05/2022 21:00	15.5	2.6	2.2	12.2	2.6
12/05/2022 22:00	14.5	3.3	2.0	11.4	2.4
12/05/2022 23:00	12.2	3.3	2.0	11.2	2.4
Average/Sum#:	378.5 #	129.4 #	35.4 #	228.8 #	48.3 #
Minimum:	8.8	0.0	0.7	6.6	1.3
Maximum:	82.4	89.5	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/06/2022 00:00	11.8	4.0	2.0	10.8	2.4
12/06/2022 01:00	11.8	4.4	2.0	10.8	2.4
12/06/2022 02:00	11.8	4.7	2.0	10.8	2.4
12/06/2022 03:00	11.8	4.7	2.0	10.8	2.4
12/06/2022 04:00	13.9	4.0	2.0	11.0	2.4
12/06/2022 05:00	14.0	3.3	2.0	11.0	2.4
12/06/2022 06:00	11.9	4.0	2.0	11.0	2.4
12/06/2022 07:00	12.6	3.4	2.1	11.5	2.6
12/06/2022 08:00	15.9	3.0	2.3	12.4	2.8
12/06/2022 09:00	15.8	2.7	2.3	12.4	2.7
12/06/2022 10:00	15.8	2.7	2.3	12.4	2.7
12/06/2022 11:00	15.7	2.6	2.3	12.4	2.7
12/06/2022 12:00	15.7	2.6	2.3	12.2	2.6
12/06/2022 13:00	10.8	1.3	1.8	9.8	2.2
12/06/2022 14:00	5.3	1.0	1.3	7.2	1.6
12/06/2022 15:00	5.3	1.0	1.3	7.2	1.6
12/06/2022 16:00	7.6	1.1	1.6	8.3	1.8
12/06/2022 17:00	10.9	1.0	1.8	10.0	2.2
12/06/2022 18:00	10.9	1.0	1.8	10.0	2.2
12/06/2022 19:00	10.9	1.3	1.8	10.1	2.2
12/06/2022 20:00	14.9	3.3	2.1	11.7	2.6
12/06/2022 21:00	15.6	2.6	2.3	12.3	2.6
12/06/2022 22:00	14.7	3.0	2.1	11.5	2.6
12/06/2022 23:00	11.8	3.4	2.0	10.8	2.4
Average/Sum#:	297.2 #	66.1 #	47.5 #	258.4 #	56.9 #
Minimum:	5.3	1.0	1.3	7.2	1.6
Maximum:	15.9	4.7	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/07/2022 00:00	14.5	3.0	2.1	11.5	2.5
12/07/2022 01:00	13.9	3.4	2.0	11.0	2.4
12/07/2022 02:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 03:00	15.0	3.0	2.1	11.8	2.6
12/07/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/07/2022 05:00	17.3	3.0	2.2	11.9	2.6
12/07/2022 06:00	13.5	3.0	2.3	12.4	2.7
12/07/2022 07:00	15.8	2.7	2.3	12.4	2.7
12/07/2022 08:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 09:00	17.3	3.1	2.2	11.9	2.6
12/07/2022 10:00	15.2	3.0	2.2	11.9	2.6
12/07/2022 11:00	15.2	3.0	2.2	11.9	2.6
12/07/2022 12:00	15.0	3.0	2.1	11.7	2.6
12/07/2022 13:00	14.8	2.6	2.1	11.7	2.6
12/07/2022 14:00	14.4	3.0	2.0	11.3	2.4
12/07/2022 15:00	14.6	3.0	2.1	11.5	2.5
12/07/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/07/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/07/2022 18:00	15.9	2.7	2.3	12.5	2.8
12/07/2022 19:00	15.9	2.7	2.3	12.4	2.8
12/07/2022 20:00	15.9	2.7	2.3	12.5	2.8
12/07/2022 21:00	15.9	2.7	2.3	12.4	2.8
12/07/2022 22:00	17.4	3.0	2.2	12.0	2.6
12/07/2022 23:00	15.2	3.0	2.2	11.9	2.6
Average/Sum#:	369.4 #	69.8 #	52.4 #	286.8 #	63.1 #
Minimum:	13.5	2.6	2.0	11.0	2.4
Maximum:	17.4	3.4	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/08/2022 00:00	15.0	3.0	2.1	11.7	2.6
12/08/2022 01:00	17.0	3.0	2.1	11.7	2.6
12/08/2022 02:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 03:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/08/2022 05:00	17.6	3.3	2.2	12.1	2.6
12/08/2022 06:00	15.9	3.0	2.3	12.6	2.8
12/08/2022 07:00	15.7	3.1	2.3	12.3	2.6
12/08/2022 08:00	14.2	3.7	2.0	11.2	2.4
12/08/2022 09:00	14.8	3.4	2.1	11.6	2.6
12/08/2022 10:00	14.9	3.0	2.1	11.7	2.6
12/08/2022 11:00	17.2	3.0	2.1	11.9	2.6
12/08/2022 12:00	15.0	3.0	2.1	11.9	2.6
12/08/2022 13:00	15.2	3.0	2.2	11.9	2.6
12/08/2022 14:00	17.3	3.0	2.2	11.9	2.6
12/08/2022 15:00	17.3	3.0	2.2	12.0	2.6
12/08/2022 16:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 18:00	16.0	2.6	2.3	12.6	2.8
12/08/2022 19:00	15.9	2.6	2.3	12.5	2.8
12/08/2022 20:00	15.9	2.6	2.3	12.6	2.8
12/08/2022 21:00	15.9	2.6	2.3	12.6	2.8
12/08/2022 22:00	15.3	3.0	2.2	12.0	2.6
12/08/2022 23:00	17.5	3.0	2.2	12.0	2.6
Average/Sum#:	380.3 #	71.1 #	52.5 #	289.1 #	63.6 #
Minimum:	14.2	2.6	2.0	11.2	2.4
Maximum:	17.6	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/09/2022 00:00	15.0	3.0	2.1	11.7	2.6
12/09/2022 01:00	16.4	3.4	2.0	11.2	2.4
12/09/2022 02:00	15.0	3.0	2.1	11.8	2.6
12/09/2022 03:00	15.0	3.0	2.1	11.8	2.6
12/09/2022 04:00	15.4	3.0	2.2	12.1	2.6
12/09/2022 05:00	18.3	3.0	2.3	12.6	2.8
12/09/2022 06:00	16.1	3.0	2.3	12.6	2.8
12/09/2022 07:00	15.9	3.0	2.3	12.6	2.8
12/09/2022 08:00	14.5	3.7	2.0	11.4	2.4
12/09/2022 09:00	14.2	3.7	2.0	11.2	2.4
12/09/2022 10:00	11.9	4.7	2.0	10.9	2.4
12/09/2022 11:00	14.5	3.4	2.0	11.4	2.4
12/09/2022 12:00	12.0	3.7	2.0	11.0	2.4
12/09/2022 13:00	15.0	3.0	2.1	11.9	2.6
12/09/2022 14:00	17.3	3.0	2.1	11.8	2.6
12/09/2022 15:00	14.3	3.7	2.0	11.3	2.4
12/09/2022 16:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 17:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 18:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 19:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 20:00	16.0	2.7	2.3	12.5	2.8
12/09/2022 21:00	16.0	2.6	2.3	12.5	2.8
12/09/2022 22:00	15.9	2.6	2.3	12.5	2.8
12/09/2022 23:00	15.8	2.6	2.3	12.4	2.7
Average/Sum#:	368.1 #	74.2 #	52.0 #	287.2 #	63.1 #
Minimum:	11.9	2.6	2.0	10.9	2.4
Maximum:	18.3	4.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/10/2022 00:00	14.1	3.6	2.0	11.1	2.4
12/10/2022 01:00	14.0	3.6	2.0	11.0	2.4
12/10/2022 02:00	11.8	4.0	2.0	10.8	2.4
12/10/2022 03:00	13.8	3.9	2.0	10.8	2.4
12/10/2022 04:00	13.7	3.9	2.0	10.8	2.4
12/10/2022 05:00	13.9	3.9	2.0	10.9	2.4
12/10/2022 06:00	13.7	4.3	2.0	10.8	2.4
12/10/2022 07:00	13.8	4.3	2.0	10.8	2.4
12/10/2022 08:00	12.1	3.6	2.0	11.1	2.4
12/10/2022 09:00	13.9	3.9	2.0	11.0	2.4
12/10/2022 10:00	13.7	4.3	2.0	10.8	2.4
12/10/2022 11:00	12.0	3.5	2.0	11.0	2.4
12/10/2022 12:00	16.9	2.9	2.1	11.6	2.6
12/10/2022 13:00	15.2	2.6	2.2	11.9	2.6
12/10/2022 14:00	14.1	2.9	2.0	11.1	2.4
12/10/2022 15:00	14.3	2.9	2.0	11.2	2.4
12/10/2022 16:00	16.9	2.9	2.1	11.5	2.6
12/10/2022 17:00	14.5	2.9	2.0	11.3	2.4
12/10/2022 18:00	14.5	3.2	2.0	11.3	2.4
12/10/2022 19:00	15.7	2.6	2.3	12.4	2.7
12/10/2022 20:00	15.2	2.6	2.2	11.9	2.6
12/10/2022 21:00	14.5	2.9	2.0	11.4	2.4
12/10/2022 22:00	14.1	3.3	2.0	11.0	2.4
12/10/2022 23:00	14.5	2.9	2.0	11.4	2.4
Average/Sum#:	340.9 #	81.4 #	48.9 #	268.9 #	58.7 #
Minimum:	11.8	2.6	2.0	10.8	2.4
Maximum:	16.9	4.3	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/11/2022 00:00	11.8	3.6	2.0	10.8	2.4
12/11/2022 01:00	13.7	4.0	2.0	10.8	2.4
12/11/2022 02:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 03:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 04:00	13.7	4.3	2.0	10.8	2.4
12/11/2022 05:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 06:00	13.7	4.3	2.0	10.8	2.4
12/11/2022 07:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 08:00	11.8	4.3	2.0	10.8	2.4
12/11/2022 09:00	13.8	4.3	2.0	10.8	2.4
12/11/2022 10:00	13.8	4.3	2.0	10.8	2.4
12/11/2022 11:00	11.8	4.0	2.0	10.8	2.4
12/11/2022 12:00	13.7	4.0	2.0	10.8	2.4
12/11/2022 13:00	13.8	3.9	2.0	10.8	2.4
12/11/2022 14:00	15.7	3.9	2.0	10.8	2.4
12/11/2022 15:00	14.4	3.3	2.0	11.3	2.4
12/11/2022 16:00	14.5	3.3	2.0	11.3	2.4
12/11/2022 17:00	15.0	3.0	2.1	11.7	2.6
12/11/2022 18:00	16.4	3.7	2.0	11.2	2.4
12/11/2022 19:00	14.5	3.4	2.0	11.4	2.4
12/11/2022 20:00	14.9	3.4	2.1	11.7	2.6
12/11/2022 21:00	12.0	4.1	2.0	11.0	2.4
12/11/2022 22:00	13.8	4.4	2.0	10.8	2.4
12/11/2022 23:00	11.8	4.4	2.0	10.8	2.4
Average/Sum#:	321.8 #	94.5 #	48.2 #	263.2 #	58.0 #
Minimum:	11.8	3.0	2.0	10.8	2.4
Maximum:	16.4	4.4	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/12/2022 00:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 01:00	11.8	4.4	2.0	10.8	2.4
12/12/2022 02:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 03:00	11.8	4.4	2.0	10.8	2.4
12/12/2022 04:00	13.8	4.4	2.0	10.8	2.4
12/12/2022 05:00	14.8	3.3	2.1	11.7	2.6
12/12/2022 06:00	17.7	3.0	2.2	12.2	2.6
12/12/2022 07:00	17.6	3.0	2.2	12.1	2.6
12/12/2022 08:00	12.4	3.7	2.1	11.4	2.4
12/12/2022 09:00	14.5	3.4	2.0	11.4	2.4
12/12/2022 10:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 11:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 12:00	11.8	4.7	2.0	10.8	2.4
12/12/2022 13:00	11.8	4.3	2.0	10.8	2.4
12/12/2022 14:00	11.8	4.3	2.0	10.8	2.4
12/12/2022 15:00	13.7	4.0	2.0	10.8	2.4
12/12/2022 16:00	15.0	3.0	2.1	11.8	2.6
12/12/2022 17:00	15.6	2.6	2.3	12.3	2.7
12/12/2022 18:00	16.1	2.3	2.3	12.6	2.8
12/12/2022 19:00	16.1	2.3	2.3	12.6	2.8
12/12/2022 20:00	16.1	2.3	2.3	12.7	2.8
12/12/2022 21:00	15.8	2.7	2.3	12.4	2.7
12/12/2022 22:00	17.6	2.7	2.2	12.1	2.6
12/12/2022 23:00	16.2	3.4	2.0	11.2	2.4
Average/Sum#:	343.2 #	86.4 #	50.4 #	275.3 #	60.4 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.7	4.7	2.3	12.7	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/13/2022 00:00	15.1	3.1	2.1	11.9	2.6
12/13/2022 01:00	15.1	3.1	2.1	11.9	2.6
12/13/2022 02:00	17.3	3.0	2.2	11.9	2.6
12/13/2022 03:00	15.0	3.0	2.1	11.9	2.6
12/13/2022 04:00	15.4	3.1	2.2	12.1	2.6
12/13/2022 05:00	15.9	3.0	2.3	12.6	2.8
12/13/2022 06:00	16.2	2.7	2.3	12.8	2.8
12/13/2022 07:00	16.2	2.7	2.3	12.6	2.8
12/13/2022 08:00	15.0	3.0	2.1	11.7	2.6
12/13/2022 09:00	14.0	3.7	2.0	11.0	2.4
12/13/2022 10:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 11:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 12:00	13.8	4.0	2.0	10.8	2.4
12/13/2022 13:00	11.8	4.0	2.0	10.8	2.4
12/13/2022 14:00	13.7	4.0	2.0	10.8	2.4
12/13/2022 15:00	14.5	3.3	2.0	11.3	2.4
12/13/2022 16:00	15.9	2.3	2.3	12.4	2.8
12/13/2022 17:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 18:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 19:00	16.0	2.3	2.3	12.6	2.8
12/13/2022 20:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 21:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 22:00	16.0	2.7	2.3	12.6	2.8
12/13/2022 23:00	16.0	2.7	2.3	12.6	2.8
Average/Sum#:	360.5 #	73.7 #	52.1 #	286.3 #	63.2 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.3	4.0	2.3	12.8	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/14/2022 00:00	17.5	2.7	2.2	12.1	2.6
12/14/2022 01:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 02:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 03:00	15.4	3.1	2.2	12.1	2.6
12/14/2022 04:00	17.5	3.1	2.2	12.1	2.6
12/14/2022 05:00	18.4	3.1	2.3	12.6	2.8
12/14/2022 06:00	16.1	2.7	2.3	12.6	2.8
12/14/2022 07:00	15.9	2.7	2.3	12.4	2.8
12/14/2022 08:00	16.6	3.4	2.0	11.4	2.4
12/14/2022 09:00	14.0	3.7	2.0	11.0	2.4
12/14/2022 10:00	12.2	3.4	2.0	11.2	2.4
12/14/2022 11:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 12:00	11.8	4.0	2.0	10.8	2.4
12/14/2022 13:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 14:00	11.8	3.7	2.0	10.8	2.4
12/14/2022 15:00	14.1	3.7	2.0	11.1	2.4
12/14/2022 16:00	15.5	2.7	2.2	12.2	2.6
12/14/2022 17:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 18:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 19:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 20:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 21:00	16.0	2.7	2.3	12.6	2.8
12/14/2022 22:00	15.9	2.7	2.3	12.4	2.8
12/14/2022 23:00	15.2	2.7	2.2	11.9	2.6
Average/Sum#:	362.3 #	74.5 #	52.1 #	285.5 #	62.6 #
Minimum:	11.8	2.7	2.0	10.8	2.4
Maximum:	18.4	4.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/15/2022 00:00	16.1	2.7	2.3	12.6	2.8
12/15/2022 01:00	16.1	2.7	2.3	12.6	2.8
12/15/2022 02:00	16.1	2.4	2.3	12.6	2.8
12/15/2022 03:00	16.2	2.7	2.3	12.6	2.8
12/15/2022 04:00	16.2	2.4	2.3	12.8	2.8
12/15/2022 05:00	16.2	2.3	2.3	12.8	2.8
12/15/2022 06:00	16.2	2.3	2.3	12.8	2.8
12/15/2022 07:00	16.2	2.4	2.3	12.6	2.8
12/15/2022 08:00	15.6	2.4	2.3	12.2	2.6
12/15/2022 09:00	15.5	2.7	2.2	12.2	2.6
12/15/2022 10:00	13.8	3.3	2.0	10.8	2.4
12/15/2022 11:00	15.9	3.3	2.0	11.0	2.4
12/15/2022 12:00	14.1	3.0	2.0	11.1	2.4
12/15/2022 13:00	14.3	3.0	2.0	11.2	2.4
12/15/2022 14:00	14.6	2.3	2.1	11.5	2.5
12/15/2022 15:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 16:00	15.8	2.0	2.3	12.4	2.7
12/15/2022 17:00	15.8	2.3	2.3	12.4	2.7
12/15/2022 18:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 19:00	15.7	2.6	2.3	12.4	2.7
12/15/2022 20:00	15.7	2.3	2.3	12.4	2.7
12/15/2022 21:00	15.7	2.7	2.3	12.4	2.7
12/15/2022 22:00	15.7	2.7	2.3	12.4	2.7
12/15/2022 23:00	15.7	2.7	2.3	12.3	2.6
Average/Sum#:	374.6 #	61.8 #	53.7 #	292.9 #	63.9 #
Minimum:	13.8	2.0	2.0	10.8	2.4
Maximum:	16.2	3.3	2.3	12.8	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/16/2022 00:00	14.0	3.7	2.0	11.0	2.4
12/16/2022 01:00	11.8	4.0	2.0	10.8	2.4
12/16/2022 02:00	13.8	4.0	2.0	10.8	2.4
12/16/2022 03:00	11.8	4.1	2.0	10.8	2.4
12/16/2022 04:00	13.8	4.1	2.0	10.8	2.4
12/16/2022 05:00	11.9	4.1	2.0	11.0	2.4
12/16/2022 06:00	12.6	3.4	2.1	11.6	2.6
12/16/2022 07:00	17.7	2.7	2.2	12.1	2.6
12/16/2022 08:00	15.0	2.7	2.1	11.8	2.6
12/16/2022 09:00	14.5	3.0	2.0	11.4	2.4
12/16/2022 10:00	7.7	0.9	1.6	8.5	1.8
12/16/2022 11:00	7.3	1.1	1.4	8.1	1.8
12/16/2022 12:00	5.3	1.2	1.3	7.3	1.6
12/16/2022 13:00	5.3	1.0	1.3	7.3	1.6
12/16/2022 14:00	8.0	0.9	1.6	8.7	1.9
12/16/2022 15:00	7.8	1.2	1.6	8.6	1.8
12/16/2022 16:00	17.3	3.0	2.2	11.9	2.6
12/16/2022 17:00	15.6	2.6	2.3	12.3	2.6
12/16/2022 18:00	17.2	2.7	2.1	11.9	2.6
12/16/2022 19:00	17.3	2.7	2.2	11.9	2.6
12/16/2022 20:00	15.7	2.3	2.3	12.4	2.7
12/16/2022 21:00	15.4	2.7	2.2	12.1	2.6
12/16/2022 22:00	12.6	3.0	2.1	11.5	2.6
12/16/2022 23:00	11.8	3.7	2.0	10.8	2.4
Average/Sum#:	301.2 #	64.8 #	46.6 #	255.4 #	55.8 #
Minimum:	5.3	0.9	1.3	7.3	1.6
Maximum:	17.7	4.1	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/17/2022 00:00	15.0	3.0	2.1	11.8	2.6
12/17/2022 01:00	15.0	3.0	2.1	11.9	2.6
12/17/2022 02:00	15.0	3.0	2.1	11.8	2.6
12/17/2022 03:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 04:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 05:00	15.1	3.0	2.1	11.9	2.6
12/17/2022 06:00	15.7	2.7	2.3	12.3	2.6
12/17/2022 07:00	14.7	3.0	2.1	11.5	2.6
12/17/2022 08:00	15.2	3.1	2.1	11.9	2.6
12/17/2022 09:00	14.9	3.0	2.1	11.7	2.6
12/17/2022 10:00	14.0	3.4	2.0	11.0	2.4
12/17/2022 11:00	11.8	3.7	2.0	10.8	2.4
12/17/2022 12:00	11.8	3.7	2.0	10.8	2.4
12/17/2022 13:00	11.8	3.3	2.0	10.8	2.4
12/17/2022 14:00	15.9	3.3	2.0	10.9	2.4
12/17/2022 15:00	14.8	2.6	2.1	11.7	2.6
12/17/2022 16:00	15.8	2.3	2.3	12.4	2.7
12/17/2022 17:00	15.7	2.6	2.3	12.2	2.6
12/17/2022 18:00	17.2	2.7	2.1	11.8	2.6
12/17/2022 19:00	16.0	2.6	2.3	12.6	2.8
12/17/2022 20:00	16.0	2.3	2.3	12.6	2.8
12/17/2022 21:00	16.0	2.3	2.3	12.6	2.8
12/17/2022 22:00	15.9	2.3	2.3	12.6	2.8
12/17/2022 23:00	17.5	2.7	2.2	12.1	2.6
Average/Sum#:	361.0 #	69.6 #	51.4 #	283.5 #	62.3 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.5	3.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/18/2022 00:00	15.0	2.7	2.1	11.7	2.6
12/18/2022 01:00	15.0	3.1	2.1	11.7	2.6
12/18/2022 02:00	14.2	3.7	2.0	11.2	2.4
12/18/2022 03:00	11.9	4.1	2.0	10.9	2.4
12/18/2022 04:00	15.0	3.1	2.1	11.7	2.6
12/18/2022 05:00	17.2	3.1	2.1	11.9	2.6
12/18/2022 06:00	15.2	3.0	2.2	11.9	2.6
12/18/2022 07:00	17.7	3.1	2.2	12.2	2.6
12/18/2022 08:00	14.7	3.0	2.1	11.5	2.6
12/18/2022 09:00	8.1	1.2	1.6	8.8	2.0
12/18/2022 10:00	9.3	1.2	1.6	8.6	1.8
12/18/2022 11:00	7.8	1.2	1.6	8.5	1.8
12/18/2022 12:00	7.0	1.3	1.4	7.7	1.6
12/18/2022 13:00	7.0	1.3	1.4	7.7	1.6
12/18/2022 14:00	9.9	1.2	1.7	9.0	2.0
12/18/2022 15:00	8.3	1.2	1.7	9.0	2.0
12/18/2022 16:00	15.0	3.3	2.1	11.7	2.6
12/18/2022 17:00	15.7	2.7	2.3	12.4	2.7
12/18/2022 18:00	15.9	2.7	2.3	12.6	2.8
12/18/2022 19:00	16.0	2.7	2.3	12.6	2.8
12/18/2022 20:00	15.7	3.0	2.3	12.3	2.6
12/18/2022 21:00	17.6	3.1	2.2	12.1	2.6
12/18/2022 22:00	17.6	3.1	2.2	12.1	2.6
12/18/2022 23:00	14.3	3.7	2.0	11.2	2.4
Average/Sum#:	321.1 #	61.8 #	47.6 #	261.0 #	56.9 #
Minimum:	7.0	1.2	1.4	7.7	1.6
Maximum:	17.7	4.1	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/19/2022 00:00	15.0	3.4	2.1	11.8	2.6
12/19/2022 01:00	15.1	3.0	2.1	11.9	2.6
12/19/2022 02:00	17.2	3.1	2.1	11.8	2.6
12/19/2022 03:00	17.2	3.1	2.1	11.9	2.6
12/19/2022 04:00	15.2	3.4	2.2	12.1	2.6
12/19/2022 05:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 06:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 07:00	16.1	3.1	2.3	12.6	2.8
12/19/2022 08:00	15.7	3.0	2.3	12.4	2.7
12/19/2022 09:00	15.9	3.0	2.3	12.4	2.8
12/19/2022 10:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 11:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 12:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 13:00	15.2	3.0	2.1	11.9	2.6
12/19/2022 14:00	15.2	3.1	2.2	11.9	2.6
12/19/2022 15:00	17.8	3.1	2.3	12.2	2.6
12/19/2022 16:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 17:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 18:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 19:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 20:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 21:00	15.9	3.1	2.3	12.4	2.8
12/19/2022 22:00	15.9	3.1	2.3	12.5	2.8
12/19/2022 23:00	15.9	3.1	2.3	12.5	2.8
Average/Sum#:	380.6 #	74.6 #	53.7 #	293.5 #	64.9 #
Minimum:	15.0	3.0	2.1	11.8	2.6
Maximum:	17.8	3.4	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/20/2022 00:00	15.2	3.1	2.2	11.9	2.6
12/20/2022 01:00	17.4	3.1	2.2	11.9	2.6
12/20/2022 02:00	15.2	3.1	2.2	12.0	2.6
12/20/2022 03:00	15.3	3.1	2.2	12.0	2.6
12/20/2022 04:00	17.5	3.1	2.2	12.1	2.6
12/20/2022 05:00	17.5	3.1	2.2	12.1	2.6
12/20/2022 06:00	16.0	3.1	2.3	12.6	2.8
12/20/2022 07:00	15.9	3.1	2.3	12.6	2.8
12/20/2022 08:00	15.2	3.1	2.2	11.9	2.6
12/20/2022 09:00	17.3	3.1	2.2	11.9	2.6
12/20/2022 10:00	14.9	3.0	2.1	11.7	2.6
12/20/2022 11:00	14.7	3.0	2.1	11.5	2.6
12/20/2022 12:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 13:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 14:00	11.8	4.0	2.0	10.8	2.4
12/20/2022 15:00	16.3	3.7	2.0	11.2	2.4
12/20/2022 16:00	17.5	2.7	2.2	12.1	2.6
12/20/2022 17:00	15.8	2.7	2.3	12.4	2.7
12/20/2022 18:00	15.8	2.7	2.3	12.4	2.7
12/20/2022 19:00	15.7	2.7	2.3	12.4	2.7
12/20/2022 20:00	15.7	2.7	2.3	12.4	2.7
12/20/2022 21:00	15.2	2.7	2.2	11.9	2.6
12/20/2022 22:00	15.2	2.7	2.2	11.9	2.6
12/20/2022 23:00	15.5	2.7	2.2	12.2	2.6
Average/Sum#:	370.2 #	74.3 #	52.4 #	285.5 #	62.4 #
Minimum:	11.8	2.7	2.0	10.8	2.4
Maximum:	17.5	4.0	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/21/2022 00:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 01:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 02:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 03:00	16.0	2.7	2.3	12.6	2.8
12/21/2022 04:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 05:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 06:00	15.9	2.7	2.3	12.6	2.8
12/21/2022 07:00	15.9	2.7	2.3	12.5	2.8
12/21/2022 08:00	6.7	2.7	2.3	12.4	2.7
12/21/2022 09:00	15.7	3.3	2.3	12.4	2.7
12/21/2022 10:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 11:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 12:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 13:00	15.5	3.0	2.2	12.2	2.6
12/21/2022 14:00	17.1	3.0	2.1	11.8	2.6
12/21/2022 15:00	15.5	2.9	2.2	12.2	2.6
12/21/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/21/2022 17:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 18:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 19:00	15.7	2.7	2.3	12.4	2.7
12/21/2022 20:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 21:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 22:00	15.7	3.0	2.3	12.4	2.7
12/21/2022 23:00	15.7	3.3	2.3	12.3	2.6
Average/Sum#:	363.4 #	66.4 #	54.6 #	297.4 #	65.0 #
Minimum:	15.5	2.6	2.1	11.8	2.6
Maximum:	17.1	3.3	2.3	12.6	2.8
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/22/2022 00:00	15.2	3.7	2.2	12.0	2.6
12/22/2022 01:00	13.8	5.0	2.0	10.9	2.4
12/22/2022 02:00	11.8	5.7	2.0	10.8	2.4
12/22/2022 03:00	13.8	5.7	2.0	10.8	2.4
12/22/2022 04:00	12.6	5.1	2.1	11.5	2.6
12/22/2022 05:00	15.6	3.6	2.3	12.3	2.6
12/22/2022 06:00	15.9	3.4	2.3	12.5	2.8
12/22/2022 07:00	15.9	3.4	2.3	12.4	2.8
12/22/2022 08:00	15.7	3.3	2.3	12.3	2.6
12/22/2022 09:00	15.1	3.7	2.1	11.8	2.6
12/22/2022 10:00	15.0	3.8	2.1	11.8	2.6
12/22/2022 11:00	15.0	3.7	2.1	11.8	2.6
12/22/2022 12:00	15.0	3.7	2.1	11.7	2.6
12/22/2022 13:00	15.0	3.3	2.1	11.7	2.6
12/22/2022 14:00	15.0	3.7	2.1	11.8	2.6
12/22/2022 15:00	15.5	3.3	2.2	12.1	2.6
12/22/2022 16:00	15.4	3.3	2.2	12.1	2.6
12/22/2022 17:00	15.7	3.3	2.3	12.4	2.7
12/22/2022 18:00	15.7	3.3	2.3	12.4	2.7
12/22/2022 19:00	15.8	3.3	2.3	12.4	2.7
12/22/2022 20:00	15.8	3.3	2.3	12.4	2.7
12/22/2022 21:00	15.7	3.0	2.3	12.4	2.7
12/22/2022 22:00	15.5	3.3	2.2	12.1	2.6
12/22/2022 23:00	14.5	4.1	2.0	11.4	2.4
Average/Sum#:	360.0 #	91.0 #	52.2 #	285.8 #	62.5 #
Minimum:	11.8	3.0	2.0	10.8	2.4
Maximum:	15.9	5.7	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/23/2022 00:00	15.5	3.3	2.3	12.2	2.6
12/23/2022 01:00	15.9	3.3	2.3	12.4	2.8
12/23/2022 02:00	15.8	3.3	2.3	12.4	2.8
12/23/2022 03:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 04:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 05:00	15.7	3.3	2.3	12.4	2.7
12/23/2022 06:00	15.8	3.3	2.3	12.4	2.8
12/23/2022 07:00	15.7	3.3	2.3	12.3	2.6
12/23/2022 08:00	17.5	3.3	2.2	12.0	2.6
12/23/2022 09:00	17.4	3.3	2.2	11.9	2.6
12/23/2022 10:00	15.0	3.3	2.1	11.7	2.6
12/23/2022 11:00	17.1	2.9	2.1	11.7	2.6
12/23/2022 12:00	14.2	4.0	2.0	11.1	2.4
12/23/2022 13:00	11.8	4.3	2.0	10.8	2.4
12/23/2022 14:00	13.7	4.6	2.0	10.8	2.4
12/23/2022 15:00	14.4	4.0	2.0	11.3	2.4
12/23/2022 16:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 17:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 18:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 19:00	15.7	2.3	2.3	12.4	2.7
12/23/2022 20:00	15.7	2.3	2.3	12.3	2.6
12/23/2022 21:00	15.7	2.3	2.3	12.4	2.7
12/23/2022 22:00	15.7	2.6	2.3	12.4	2.7
12/23/2022 23:00	15.7	2.6	2.3	12.3	2.6
Average/Sum#:	372.5 #	76.0 #	53.4 #	289.2 #	63.1 #
Minimum:	11.8	2.3	2.0	10.8	2.4
Maximum:	17.5	4.6	2.3	12.4	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/24/2022 00:00	17.0	2.9	2.1	11.7	2.6
12/24/2022 01:00	14.8	3.0	2.1	11.7	2.6
12/24/2022 02:00	11.8	4.4	2.0	10.8	2.4
12/24/2022 03:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 04:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 05:00	13.7	4.7	2.0	10.8	2.4
12/24/2022 06:00	11.8	4.7	2.0	10.8	2.4
12/24/2022 07:00	14.0	4.4	2.0	11.0	2.4
12/24/2022 08:00	11.0	3.8	1.9	10.1	2.2
12/24/2022 09:00	5.3	1.5	1.3	7.2	1.6
12/24/2022 10:00	7.8	1.5	1.6	8.5	1.8
12/24/2022 11:00	7.8	1.5	1.6	8.5	1.8
12/24/2022 12:00	7.8	1.5	1.6	8.6	1.8
12/24/2022 13:00	9.3	0.9	1.6	8.6	1.8
12/24/2022 14:00	8.7	1.0	1.7	9.5	2.0
12/24/2022 15:00	8.7	1.0	1.7	9.5	2.0
12/24/2022 16:00	8.0	1.2	1.6	8.8	2.0
12/24/2022 17:00	11.7	5.0	2.0	10.8	2.4
12/24/2022 18:00	13.7	4.3	2.0	10.8	2.4
12/24/2022 19:00	11.7	3.9	2.0	10.8	2.4
12/24/2022 20:00	11.7	3.9	2.0	10.8	2.4
12/24/2022 21:00	13.7	3.9	2.0	10.8	2.4
12/24/2022 22:00	11.7	4.3	2.0	10.8	2.4
12/24/2022 23:00	11.7	4.3	2.0	10.8	2.4
Average/Sum#:	267.0 #	77.0 #	44.8 #	243.3 #	53.4 #
Minimum:	5.3	0.9	1.3	7.2	1.6
Maximum:	17.0	5.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/25/2022 00:00	11.6	4.3	2.0	10.6	2.4
12/25/2022 01:00	5.6	12.5	0.1	0.7	0.2
12/25/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/25/2022 18:00	48.0	43.8	0.1	0.7	0.1
12/25/2022 19:00	23.8	25.3	0.1	1.2	0.2
12/25/2022 20:00	35.1	56.1	0.2	2.3	0.5
12/25/2022 21:00	1.4	0.3	0.4	4.3	0.9
12/25/2022 22:00	2.9	0.0	0.4	4.4	0.9
12/25/2022 23:00	3.0	0.3	0.4	4.4	0.9
Average/Sum#:	131.4 #	142.6 #	3.7 #	28.6 #	6.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	48.0	56.1	2.0	10.6	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/26/2022 00:00	45.0	50.6	0.6	5.8	1.2
12/26/2022 01:00	57.4	85.1	1.2	7.0	1.5
12/26/2022 02:00	10.3	1.9	1.7	9.4	2.0
12/26/2022 03:00	10.3	1.9	1.7	9.5	2.0
12/26/2022 04:00	10.3	1.9	1.7	9.5	2.0
12/26/2022 05:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 06:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 07:00	10.5	1.9	1.7	9.6	2.0
12/26/2022 08:00	10.5	1.9	1.7	9.6	2.0
12/26/2022 09:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 10:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 11:00	7.8	1.7	1.6	8.5	1.8
12/26/2022 12:00	7.7	2.0	1.6	8.5	1.8
12/26/2022 13:00	7.8	1.8	1.6	8.5	1.8
12/26/2022 14:00	8.1	1.8	1.6	8.9	2.0
12/26/2022 15:00	10.5	1.9	1.7	9.6	2.1
12/26/2022 16:00	10.6	1.9	1.7	9.8	2.2
12/26/2022 17:00	12.7	5.3	2.1	11.7	2.6
12/26/2022 18:00	15.1	4.0	2.1	11.9	2.6
12/26/2022 19:00	14.0	5.0	2.0	11.0	2.4
12/26/2022 20:00	14.0	5.0	2.0	11.0	2.4
12/26/2022 21:00	11.8	5.6	2.0	10.8	2.4
12/26/2022 22:00	13.5	5.6	2.0	10.6	2.4
12/26/2022 23:00	4.6	12.1	0.1	0.7	0.2
Average/Sum#:	329.1 #	206.3 #	39.0 #	218.1 #	47.2 #
Minimum:	4.6	1.7	0.1	0.7	0.2
Maximum:	57.4	85.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/27/2022 01:00	0.0	1.6	0.0	0.1	0.0
12/27/2022 02:00	24.2	41.8	0.2	2.3	0.5
12/27/2022 03:00	3.1	0.0	0.5	4.6	0.9
12/27/2022 04:00	3.1	0.0	0.5	4.6	0.9
12/27/2022 05:00	14.7	43.9	0.6	5.6	1.1
12/27/2022 06:00	27.7	60.7	1.2	7.2	1.5
12/27/2022 07:00	10.5	1.3	1.7	9.5	2.0
12/27/2022 08:00	10.3	1.9	1.7	9.4	2.0
12/27/2022 09:00	13.7	5.5	2.0	10.8	2.4
12/27/2022 10:00	13.7	4.9	2.0	10.8	2.4
12/27/2022 11:00	15.7	3.9	2.0	10.8	2.4
12/27/2022 12:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 13:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 14:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 15:00	15.7	3.6	2.0	10.8	2.4
12/27/2022 16:00	15.7	3.9	2.0	10.8	2.4
12/27/2022 17:00	13.7	4.6	2.0	10.8	2.4
12/27/2022 18:00	15.6	4.6	2.0	10.7	2.4
12/27/2022 19:00	13.6	4.6	2.0	10.8	2.4
12/27/2022 20:00	13.8	5.0	2.0	10.8	2.4
12/27/2022 21:00	15.7	4.7	2.0	10.8	2.4
12/27/2022 22:00	11.6	4.6	1.9	10.6	2.4
12/27/2022 23:00	7.0	1.3	1.4	7.7	1.6
Average/Sum#:	306.2 #	213.2 #	35.7 #	201.9 #	44.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	27.7	60.7	2.0	10.8	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/28/2022 00:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 01:00	7.3	1.4	1.4	8.1	1.8
12/28/2022 02:00	7.6	1.4	1.6	8.4	1.8
12/28/2022 03:00	7.6	1.4	1.6	8.4	1.8
12/28/2022 04:00	9.3	1.4	1.6	8.5	1.8
12/28/2022 05:00	8.6	1.6	1.7	9.5	2.0
12/28/2022 06:00	10.5	1.3	1.7	9.6	2.1
12/28/2022 07:00	10.5	1.6	1.7	9.6	2.1
12/28/2022 08:00	10.3	1.3	1.7	9.4	2.0
12/28/2022 09:00	8.6	1.6	1.7	9.4	2.0
12/28/2022 10:00	7.8	1.5	1.6	8.5	1.8
12/28/2022 11:00	7.8	1.2	1.6	8.6	1.8
12/28/2022 12:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 13:00	7.7	1.1	1.6	8.4	1.8
12/28/2022 14:00	7.8	1.2	1.6	8.5	1.8
12/28/2022 15:00	9.6	1.8	1.6	8.8	2.0
12/28/2022 16:00	14.7	4.9	2.1	11.5	2.6
12/28/2022 17:00	13.8	4.6	2.0	10.8	2.4
12/28/2022 18:00	11.8	5.0	2.0	10.8	2.4
12/28/2022 19:00	13.7	5.0	2.0	10.8	2.4
12/28/2022 20:00	11.8	5.3	2.0	10.8	2.4
12/28/2022 21:00	11.8	4.9	2.0	10.8	2.4
12/28/2022 22:00	13.7	5.3	2.0	10.8	2.4
12/28/2022 23:00	11.8	5.3	2.0	10.8	2.4
Average/Sum#:	239.7 #	62.5 #	42.0 #	227.8 #	49.6 #
Minimum:	7.3	1.1	1.4	8.1	1.8
Maximum:	14.7	5.3	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/29/2022 00:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 01:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 02:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 03:00	13.7	5.3	2.0	10.8	2.4
12/29/2022 04:00	11.8	5.3	2.0	10.8	2.4
12/29/2022 05:00	14.3	4.6	2.0	11.2	2.4
12/29/2022 06:00	14.3	4.7	2.0	11.2	2.4
12/29/2022 07:00	12.3	4.7	2.0	11.3	2.4
12/29/2022 08:00	15.4	4.0	2.2	12.1	2.6
12/29/2022 09:00	15.7	3.3	2.3	12.4	2.7
12/29/2022 10:00	17.2	3.3	2.1	11.9	2.6
12/29/2022 11:00	16.2	4.7	2.0	11.1	2.4
12/29/2022 12:00	13.9	5.0	2.0	10.9	2.4
12/29/2022 13:00	11.8	5.7	2.0	10.8	2.4
12/29/2022 14:00	13.9	5.3	2.0	10.9	2.4
12/29/2022 15:00	11.9	5.3	2.0	10.9	2.4
12/29/2022 16:00	14.6	5.0	2.1	11.5	2.5
12/29/2022 17:00	15.1	3.3	2.2	11.9	2.6
12/29/2022 18:00	14.5	4.0	2.0	11.5	2.5
12/29/2022 19:00	13.7	6.0	2.0	10.8	2.4
12/29/2022 20:00	11.8	6.1	2.0	10.8	2.4
12/29/2022 21:00	13.9	5.3	2.0	10.9	2.4
12/29/2022 22:00	11.8	5.9	2.0	10.8	2.4
12/29/2022 23:00	13.5	5.9	2.0	10.6	2.4
Average/Sum#:	326.7 #	118.6 #	48.9 #	267.5 #	58.7 #
Minimum:	11.8	3.3	2.0	10.6	2.4
Maximum:	17.2	6.1	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/30/2022 00:00	4.7	13.2	0.1	0.8	0.2
12/30/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	4.7 #	13.2 #	0.1 #	0.8 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	4.7	13.2	0.1	0.8	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:00 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:01 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:01 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:02 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:02 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:03 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:03 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:04 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:04 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 86.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**86.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:06 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,879.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 329.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,879.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
Linearity

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/05/2022	Scale:	High
Performance Spec:	5 %	Test No.:	116	Highest Error:	0.9
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/05/2022	1129	L	200.0	50.2	50.3		25.1 %
10/05/2022	1135	M	200.0	111.1	110.8		55.6 %
10/05/2022	1141	H	200.0	184.3	187.1		92.2 %
10/05/2022	1150	L	200.0	50.2	50.1		25.1 %
10/05/2022	1156	M	200.0	111.1	112.7		55.6 %
10/05/2022	1202	H	200.0	184.3	184.3		92.2 %
10/05/2022	1210	L	200.0	50.2	50.3		25.1 %
10/05/2022	1216	M	200.0	111.1	111.1		55.6 %
10/05/2022	1222	H	200.0	184.3	186.5		92.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.200	50.233	No	**0.1**
M	111.100	111.533	No	**0.4**
H	184.300	185.967	No	**0.9**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT1
Component ID: A12
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument
Test End Date/Time: 10/05/2022
Scale: High
Performance Spec: 5 %
Test No.: 117
Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/05/2022	0926	L	25.0	5.5	5.4		22.0 %
10/05/2022	0932	M	25.0	13.0	13.0		52.0 %
10/05/2022	0938	H	25.0	21.0	21.0		84.0 %
10/05/2022	0947	L	25.0	5.5	5.4		22.0 %
10/05/2022	0953	M	25.0	13.0	13.0		52.0 %
10/05/2022	0959	H	25.0	21.0	21.0		84.0 %
10/05/2022	1007	L	25.0	5.5	5.4		22.0 %
10/05/2022	1013	M	25.0	13.0	13.0		52.0 %
10/05/2022	1019	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	**1.8**
M	13.000	13.000	No	**0.0**
H	21.000	21.000	No	**0.0**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT2
Component ID: A21
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrume
Test End Date/Time: 10/04/2022
Scale: High
Performance Spec: 5 %
Test No.: 118
Highest Error: 3.2
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1235	L	200.0	50.3	48.6		25.2 %
10/04/2022	1241	M	200.0	111.2	111.3		55.6 %
10/04/2022	1247	H	200.0	184.2	183.6		92.1 %
10/04/2022	1256	L	200.0	50.3	48.7		25.2 %
10/04/2022	1302	M	200.0	111.2	111.4		55.6 %
10/04/2022	1308	H	200.0	184.2	183.5		92.1 %
10/04/2022	1316	L	200.0	50.3	48.8		25.2 %
10/04/2022	1322	M	200.0	111.2	111.1		55.6 %
10/04/2022	1328	H	200.0	184.2	183.8		92.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.300	48.700	No	**3.2**
M	111.200	111.267	No	**0.1**
H	184.200	183.633	No	**0.3**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT2
Component ID: A22
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument
Test End Date/Time: 10/04/2022
Scale: High
Performance Spec: 5 %
Test No.: 119
Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0951	L	25.0	5.5	5.6		22.0 %
10/04/2022	0957	M	25.0	13.0	13.1		52.0 %
10/04/2022	1003	H	25.0	21.1	21.1		84.4 %
10/04/2022	1012	L	25.0	5.5	5.6		22.0 %
10/04/2022	1018	M	25.0	13.0	13.1		52.0 %
10/04/2022	1024	H	25.0	21.1	21.1		84.4 %
10/04/2022	1032	L	25.0	5.5	5.6		22.0 %
10/04/2022	1038	M	25.0	13.0	13.1		52.0 %
10/04/2022	1044	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.600	No	**1.8**
M	13.000	13.100	No	**0.8**
H	21.100	21.100	No	**0.0**

ATTACHMENT 12
Startup/Shutdown Emissions

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.6		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	132.8		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	107.0		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	118.6		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	0.7		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	125.2		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.2		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	10.0		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	2.2		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	161.9		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.5		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	158.4		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.6		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	101.1		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.6		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	127.1		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	0.8		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	110.4		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	142.4		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.3		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	132.2		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.4		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	133.8		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.0		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	100.1		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.7		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:07 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,674.85 Hours
Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:07 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	2.9	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.9 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	64.9	0	1	0	0	0
10/03/2022 03:00	41.0	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	105.9 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.4	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	3.9	0	0	1	0	0
10/09/2022 11:00	60.0	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.3 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	2.6	0	0	0	1	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	63.7	0	1	0	0	0
Average/Sum#:	63.7 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.7	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	60.9	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.9 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	2.9	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	0.0	0	1	0	0	0
10/24/2022 13:00	74.5	0	1	0	0	0
10/24/2022 14:00	10.2	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.7 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	2.0	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	2.2	0	1	0	1	0
10/26/2022 17:00	25.5	0	1	0	0	0
10/26/2022 18:00	121.7	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	1.4	0	0	0	1	0
Average/Sum#:	152.8 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	121.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	76.7	1	0	0	0	0
10/31/2022 02:00	75.6	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	152.3 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	3.1	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	4.7	0	0	1	0	0
11/05/2022 14:00	70.1	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.9 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	3.2	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.2 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	45.1	0	1	0	0	0
11/07/2022 04:00	68.6	0	1	0	0	0
11/07/2022 05:00	0.2	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	113.9 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	1.8	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	0.1	0	0	1	0	0
11/22/2022 12:00	79.3	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	81.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	79.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.6	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	67.6	0	1	0	0	0
11/28/2022 03:00	45.0	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	112.6 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	0.5	1	0	0	0	0
12/05/2022 10:00	89.5	1	0	0	0	0
12/05/2022 11:00	1.8	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.8 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	89.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	2.6	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	50.3	0	1	0	0	0
12/26/2022 01:00	65.3	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	3.2	0	0	0	1	0
Average/Sum#:	118.8 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	43.9	0	0	1	0	0
12/27/2022 06:00	26.1	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	3.1	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	36.5	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.5 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	2,638.8	0	1	0	0	0
10/03/2022 03:00	5,327.7	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,966.5 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,327.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	23.5	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	436.6	0	0	1	0	0
10/09/2022 11:00	5,985.6	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,445.7 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,985.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	60.0	0	0	0	1	0
Average/Sum#:	60.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	1,470.4	0	1	0	0	0
Average/Sum#:	1,470.4 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,470.4	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	5,643.6	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,643.6 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,643.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	41.4	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	41.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	1.8	0	1	0	0	0
10/24/2022 13:00	4,132.2	0	1	0	0	0
10/24/2022 14:00	3,375.0	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,509.0 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,132.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	14.0	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	731.0	0	1	0	1	0
10/26/2022 17:00	2,008.0	0	1	0	0	0
10/26/2022 18:00	7,703.1	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	32.1	0	0	0	1	0
Average/Sum#:	10,488.2 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,703.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	2,781.8	1	0	0	0	0
10/31/2022 02:00	6,723.1	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,504.9 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,723.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	34.3	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	373.1	0	0	1	0	0
11/05/2022 14:00	5,690.1	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,097.5 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,690.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	37.3	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	37.3 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	1,072.5	0	1	0	0	0
11/07/2022 04:00	5,239.8	0	1	0	0	0
11/07/2022 05:00	1,312.3	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,624.6 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,239.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	49.0	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	64.5	0	0	1	0	0
11/22/2022 12:00	6,557.8	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,671.3 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,557.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	36.3	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.3 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	3,120.1	0	1	0	0	0
11/28/2022 03:00	5,426.8	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,546.9 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,426.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	16.7	0	0	0	1	0
Average/Sum#:	16.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	2.1	1	0	0	0	0
12/05/2022 10:00	4,500.1	1	0	0	0	0
12/05/2022 11:00	3,428.2	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,930.4 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,500.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	23.3	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	23.3 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	2,012.2	0	1	0	0	0
12/26/2022 01:00	6,013.2	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	58.9	0	0	0	1	0
Average/Sum#:	8,084.3 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,013.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	2,076.7	0	0	1	0	0
12/27/2022 06:00	3,928.5	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,005.2 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,928.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	42.7	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	42.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	1.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	0.0	0	0	0	0	0
10/01/2022 13:00	0.0	0	0	0	0	0
10/01/2022 14:00	0.0	0	0	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	0
10/01/2022 16:00	0.0	0	0	0	0	0
10/01/2022 17:00	0.0	0	0	0	0	0
10/01/2022 18:00	0.0	0	0	0	0	0
10/01/2022 19:00	0.0	0	0	0	0	0
10/01/2022 20:00	0.0	0	0	0	0	0
10/01/2022 21:00	0.0	0	0	0	0	0
10/01/2022 22:00	0.0	0	0	0	0	0
10/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	0.0	0	0	0	0	0
10/02/2022 12:00	0.0	0	0	0	0	0
10/02/2022 13:00	0.0	0	0	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	0
10/02/2022 15:00	0.0	0	0	0	0	0
10/02/2022 16:00	0.0	0	0	0	0	0
10/02/2022 17:00	0.0	0	0	0	0	0
10/02/2022 18:00	0.0	0	0	0	0	0
10/02/2022 19:00	0.0	0	0	0	0	0
10/02/2022 20:00	0.0	0	0	0	0	0
10/02/2022 21:00	0.0	0	0	0	0	0
10/02/2022 22:00	0.0	0	0	0	0	0
10/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	0
10/03/2022 01:00	0.0	0	0	0	0	0
10/03/2022 02:00	51.5	0	1	0	0	0
10/03/2022 03:00	25.0	0	1	0	0	0
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.5 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	0.7	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.3	0	0	1	0	0
10/09/2022 11:00	29.9	0	0	1	0	0
10/09/2022 12:00	0.0	0	0	0	0	1
10/09/2022 13:00	0.0	0	0	0	0	1
10/09/2022 14:00	0.0	0	0	0	0	1
10/09/2022 15:00	0.0	0	0	0	0	1
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	0.0	0	0	0	0	0
10/16/2022 18:00	0.0	0	0	0	0	0
10/16/2022 19:00	0.0	0	0	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	0
10/16/2022 21:00	0.0	0	0	0	0	0
10/16/2022 22:00	0.0	0	0	0	0	0
10/16/2022 23:00	27.5	0	1	0	0	0
Average/Sum#:	27.5 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.5	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	54.8	0	1	0	0	0
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.8 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.0	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	0.0	0	0	0	0	0
10/23/2022 21:00	0.0	0	0	0	0	0
10/23/2022 22:00	0.0	0	0	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	0
10/24/2022 01:00	0.0	0	0	0	0	0
10/24/2022 02:00	0.0	0	0	0	0	0
10/24/2022 03:00	0.0	0	0	0	0	0
10/24/2022 04:00	0.0	0	0	0	0	0
10/24/2022 05:00	0.0	0	0	0	0	0
10/24/2022 06:00	0.0	0	0	0	0	0
10/24/2022 07:00	0.0	0	0	0	0	0
10/24/2022 08:00	0.0	0	0	0	0	0
10/24/2022 09:00	0.0	0	0	0	0	0
10/24/2022 10:00	0.0	0	0	0	0	0
10/24/2022 11:00	0.0	0	0	0	0	0
10/24/2022 12:00	0.0	0	1	0	0	0
10/24/2022 13:00	85.5	0	1	0	0	0
10/24/2022 14:00	14.0	0	1	0	0	0
10/24/2022 15:00	0.0	0	0	0	0	1
10/24/2022 16:00	0.0	0	0	0	0	1
10/24/2022 17:00	0.0	0	0	0	0	1
10/24/2022 18:00	0.0	0	0	0	0	1
10/24/2022 19:00	0.0	0	0	0	0	1
10/24/2022 20:00	0.0	0	0	0	0	1
10/24/2022 21:00	0.0	0	0	0	0	1
10/24/2022 22:00	0.0	0	0	0	0	1
10/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	99.5 #	0 #	3 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	85.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	1
10/25/2022 01:00	0.0	0	0	0	0	1
10/25/2022 02:00	0.0	0	0	0	0	1
10/25/2022 03:00	0.0	0	0	0	0	1
10/25/2022 04:00	0.0	0	0	0	0	1
10/25/2022 05:00	0.0	0	0	0	0	1
10/25/2022 06:00	0.0	0	0	0	0	1
10/25/2022 07:00	0.0	0	0	0	0	1
10/25/2022 08:00	0.0	0	0	0	0	1
10/25/2022 09:00	0.0	0	0	0	0	1
10/25/2022 10:00	0.0	0	0	0	0	1
10/25/2022 11:00	0.0	0	0	0	0	1
10/25/2022 12:00	0.0	0	0	0	0	1
10/25/2022 13:00	0.0	0	0	0	0	1
10/25/2022 14:00	0.0	0	0	0	0	1
10/25/2022 15:00	0.0	0	0	0	0	1
10/25/2022 16:00	0.0	0	0	0	0	1
10/25/2022 17:00	0.0	0	0	0	0	1
10/25/2022 18:00	0.0	0	0	0	0	1
10/25/2022 19:00	0.0	0	0	0	0	1
10/25/2022 20:00	0.0	0	0	0	0	1
10/25/2022 21:00	0.0	0	0	0	0	1
10/25/2022 22:00	0.0	0	0	0	0	1
10/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	1
10/26/2022 01:00	0.0	0	0	0	0	1
10/26/2022 02:00	0.0	0	0	0	0	1
10/26/2022 03:00	0.0	0	0	0	0	1
10/26/2022 04:00	0.0	0	0	0	0	1
10/26/2022 05:00	0.0	0	0	0	0	1
10/26/2022 06:00	0.0	0	0	0	0	1
10/26/2022 07:00	0.0	0	0	0	0	1
10/26/2022 08:00	0.8	0	0	0	1	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	2.1	0	1	0	1	0
10/26/2022 17:00	44.8	0	1	0	0	0
10/26/2022 18:00	77.8	0	1	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	1
10/26/2022 20:00	0.0	0	0	0	0	1
10/26/2022 21:00	0.0	0	0	0	0	1
10/26/2022 22:00	0.0	0	0	0	0	1
10/26/2022 23:00	0.7	0	0	0	1	0
Average/Sum#:	126.2 #	0 #	3 #	0 #	3 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	0.0	0	0	0	0	0
10/30/2022 20:00	0.0	0	0	0	0	0
10/30/2022 21:00	0.0	0	0	0	0	0
10/30/2022 22:00	0.0	0	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	0
10/31/2022 01:00	57.5	1	0	0	0	0
10/31/2022 02:00	45.7	1	0	0	0	0
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.2 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	0.8	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	2.8	0	0	1	0	0
11/05/2022 14:00	82.4	0	0	1	0	0
11/05/2022 15:00	0.0	0	0	0	0	1
11/05/2022 16:00	0.0	0	0	0	0	1
11/05/2022 17:00	0.0	0	0	0	0	1
11/05/2022 18:00	0.0	0	0	0	0	1
11/05/2022 19:00	0.0	0	0	0	0	1
11/05/2022 20:00	0.0	0	0	0	0	1
11/05/2022 21:00	0.0	0	0	0	0	1
11/05/2022 22:00	0.0	0	0	0	0	1
11/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	86.0 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	82.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	1
11/06/2022 01:00	0.0	0	0	0	0	1
11/06/2022 02:00	0.5	0	0	0	1	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	0.0	0	0	0	0	0
11/06/2022 10:00	0.0	0	0	0	0	0
11/06/2022 11:00	0.0	0	0	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	0
11/06/2022 13:00	0.0	0	0	0	0	0
11/06/2022 14:00	0.0	0	0	0	0	0
11/06/2022 15:00	0.0	0	0	0	0	0
11/06/2022 16:00	0.0	0	0	0	0	0
11/06/2022 17:00	0.0	0	0	0	0	0
11/06/2022 18:00	0.0	0	0	0	0	0
11/06/2022 19:00	0.0	0	0	0	0	0
11/06/2022 20:00	0.0	0	0	0	0	0
11/06/2022 21:00	0.0	0	0	0	0	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	0.0	0	0	0	0	0
11/07/2022 01:00	0.0	0	0	0	0	0
11/07/2022 02:00	0.0	0	0	0	0	0
11/07/2022 03:00	19.7	0	1	0	0	0
11/07/2022 04:00	66.4	0	1	0	0	0
11/07/2022 05:00	0.9	0	1	0	0	0
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.0 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.9	0	0	0	1	0
11/22/2022 10:00	0.0	0	0	0	0	0
11/22/2022 11:00	0.0	0	0	1	0	0
11/22/2022 12:00	38.9	0	0	1	0	0
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.8 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.0	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	0.0	0	0	0	0	0
11/27/2022 22:00	0.0	0	0	0	0	0
11/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	0
11/28/2022 01:00	0.0	0	0	0	0	0
11/28/2022 02:00	63.5	0	1	0	0	0
11/28/2022 03:00	29.8	0	1	0	0	0
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.3 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.6	0	0	0	1	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	0.0	0	0	0	0	0
12/01/2022 03:00	0.0	0	0	0	0	0
12/01/2022 04:00	0.0	0	0	0	0	0
12/01/2022 05:00	0.0	0	0	0	0	0
12/01/2022 06:00	0.0	0	0	0	0	0
12/01/2022 07:00	0.0	0	0	0	0	0
12/01/2022 08:00	0.0	0	0	0	0	0
12/01/2022 09:00	0.0	0	0	0	0	0
12/01/2022 10:00	0.0	0	0	0	0	0
12/01/2022 11:00	0.0	0	0	0	0	0
12/01/2022 12:00	0.0	0	0	0	0	0
12/01/2022 13:00	0.0	0	0	0	0	0
12/01/2022 14:00	0.0	0	0	0	0	0
12/01/2022 15:00	0.0	0	0	0	0	0
12/01/2022 16:00	0.0	0	0	0	0	0
12/01/2022 17:00	0.0	0	0	0	0	0
12/01/2022 18:00	0.0	0	0	0	0	0
12/01/2022 19:00	0.0	0	0	0	0	0
12/01/2022 20:00	0.0	0	0	0	0	0
12/01/2022 21:00	0.0	0	0	0	0	0
12/01/2022 22:00	0.0	0	0	0	0	0
12/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	0
12/02/2022 01:00	0.0	0	0	0	0	0
12/02/2022 02:00	0.0	0	0	0	0	0
12/02/2022 03:00	0.0	0	0	0	0	0
12/02/2022 04:00	0.0	0	0	0	0	0
12/02/2022 05:00	0.0	0	0	0	0	0
12/02/2022 06:00	0.0	0	0	0	0	0
12/02/2022 07:00	0.0	0	0	0	0	0
12/02/2022 08:00	0.0	0	0	0	0	0
12/02/2022 09:00	0.0	0	0	0	0	0
12/02/2022 10:00	0.0	0	0	0	0	0
12/02/2022 11:00	0.0	0	0	0	0	0
12/02/2022 12:00	0.0	0	0	0	0	0
12/02/2022 13:00	0.0	0	0	0	0	0
12/02/2022 14:00	0.0	0	0	0	0	0
12/02/2022 15:00	0.0	0	0	0	0	0
12/02/2022 16:00	0.0	0	0	0	0	0
12/02/2022 17:00	0.0	0	0	0	0	0
12/02/2022 18:00	0.0	0	0	0	0	0
12/02/2022 19:00	0.0	0	0	0	0	0
12/02/2022 20:00	0.0	0	0	0	0	0
12/02/2022 21:00	0.0	0	0	0	0	0
12/02/2022 22:00	0.0	0	0	0	0	0
12/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	0
12/03/2022 01:00	0.0	0	0	0	0	0
12/03/2022 02:00	0.0	0	0	0	0	0
12/03/2022 03:00	0.0	0	0	0	0	0
12/03/2022 04:00	0.0	0	0	0	0	0
12/03/2022 05:00	0.0	0	0	0	0	0
12/03/2022 06:00	0.0	0	0	0	0	0
12/03/2022 07:00	0.0	0	0	0	0	0
12/03/2022 08:00	0.0	0	0	0	0	0
12/03/2022 09:00	0.0	0	0	0	0	0
12/03/2022 10:00	0.0	0	0	0	0	0
12/03/2022 11:00	0.0	0	0	0	0	0
12/03/2022 12:00	0.0	0	0	0	0	0
12/03/2022 13:00	0.0	0	0	0	0	0
12/03/2022 14:00	0.0	0	0	0	0	0
12/03/2022 15:00	0.0	0	0	0	0	0
12/03/2022 16:00	0.0	0	0	0	0	0
12/03/2022 17:00	0.0	0	0	0	0	0
12/03/2022 18:00	0.0	0	0	0	0	0
12/03/2022 19:00	0.0	0	0	0	0	0
12/03/2022 20:00	0.0	0	0	0	0	0
12/03/2022 21:00	0.0	0	0	0	0	0
12/03/2022 22:00	0.0	0	0	0	0	0
12/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	0
12/04/2022 01:00	0.0	0	0	0	0	0
12/04/2022 02:00	0.0	0	0	0	0	0
12/04/2022 03:00	0.0	0	0	0	0	0
12/04/2022 04:00	0.0	0	0	0	0	0
12/04/2022 05:00	0.0	0	0	0	0	0
12/04/2022 06:00	0.0	0	0	0	0	0
12/04/2022 07:00	0.0	0	0	0	0	0
12/04/2022 08:00	0.0	0	0	0	0	0
12/04/2022 09:00	0.0	0	0	0	0	0
12/04/2022 10:00	0.0	0	0	0	0	0
12/04/2022 11:00	0.0	0	0	0	0	0
12/04/2022 12:00	0.0	0	0	0	0	0
12/04/2022 13:00	0.0	0	0	0	0	0
12/04/2022 14:00	0.0	0	0	0	0	0
12/04/2022 15:00	0.0	0	0	0	0	0
12/04/2022 16:00	0.0	0	0	0	0	0
12/04/2022 17:00	0.0	0	0	0	0	0
12/04/2022 18:00	0.0	0	0	0	0	0
12/04/2022 19:00	0.0	0	0	0	0	0
12/04/2022 20:00	0.0	0	0	0	0	0
12/04/2022 21:00	0.0	0	0	0	0	0
12/04/2022 22:00	0.0	0	0	0	0	0
12/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	0
12/05/2022 01:00	0.0	0	0	0	0	0
12/05/2022 02:00	0.0	0	0	0	0	0
12/05/2022 03:00	0.0	0	0	0	0	0
12/05/2022 04:00	0.0	0	0	0	0	0
12/05/2022 05:00	0.0	0	0	0	0	0
12/05/2022 06:00	0.0	0	0	0	0	0
12/05/2022 07:00	0.0	0	0	0	0	0
12/05/2022 08:00	0.0	0	0	0	0	0
12/05/2022 09:00	0.0	1	0	0	0	0
12/05/2022 10:00	73.8	1	0	0	0	0
12/05/2022 11:00	4.8	1	0	0	0	0
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.6 #	3 #	0 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	0.8	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	0.0	0	0	0	0	0
12/25/2022 19:00	0.0	0	0	0	0	0
12/25/2022 20:00	0.0	0	0	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	0
12/25/2022 22:00	0.0	0	0	0	0	0
12/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	41.5	0	1	0	0	0
12/26/2022 01:00	41.8	0	1	0	0	0
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	84.1 #	0 #	2 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	0	0	0
12/27/2022 02:00	0.0	0	0	0	0	0
12/27/2022 03:00	0.0	0	0	0	0	0
12/27/2022 04:00	0.0	0	0	0	0	0
12/27/2022 05:00	11.3	0	0	1	0	0
12/27/2022 06:00	10.7	0	0	1	0	0
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	22.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	0.8	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.9	483.5		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	94.1	790.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.6	483.5		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	65.7	679.6		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.3	483.5		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	109.4	790.5		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	1.2	483.5		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	77.8	790.5		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.2	483.5		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	9.9	790.5		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	1.4	483.5		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	140.4	790.5		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.7	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	128.4	1,355.6		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7	483.5		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	72.6	679.6		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.8	483.5		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	103.4	790.5		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	1.1	483.5		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	76.4	679.6		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6	483.5		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	104.2	790.5		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4	483.5		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	89.2	1,355.6		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5	483.5		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	110.1	790.5		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	94.4	679.6		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.9	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:11 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:14 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours
Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.12	115.00		
10/03/2022 02:11 10/03/2022 03:46 Warm Start - Gas	96	80.91	456.20		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.06	115.00		
10/09/2022 10:47 10/09/2022 11:51 Hot Start - Gas	65	33.46	259.90		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	0.18	115.00		
10/16/2022 23:30 10/17/2022 00:49 Warm Start - Gas	80	80.84	456.20		
10/21/2022 22:23 10/21/2022 22:28 Shut Down - Gas	6	0.17	115.00		
10/24/2022 12:55 10/24/2022 14:19 Warm Start - Gas	85	109.07	456.20		
10/26/2022 08:11 10/26/2022 08:15 Shut Down - Gas	5	0.05	115.00		
10/26/2022 16:21 10/26/2022 16:36 Warm Start - Gas	16	11.10	456.20		
10/26/2022 16:37 10/26/2022 16:39 Shut Down - Gas	3	3.41	115.00		
10/26/2022 17:28 10/26/2022 18:58 Warm Start - Gas	91	119.34	456.20		
10/26/2022 23:46 10/26/2022 23:51 Shut Down - Gas	6	0.15	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/31/2022 01:02 10/31/2022 02:58 Cold Start - Gas	117	101.63	779.10		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.15	115.00		
11/05/2022 13:48 11/05/2022 14:54 Hot Start - Gas	67	78.75	259.90		
11/06/2022 02:05 11/06/2022 02:10 Shut Down - Gas	6	0.07	115.00		
11/07/2022 03:36 11/07/2022 05:05 Warm Start - Gas	90	85.84	456.20		
11/22/2022 09:45 11/22/2022 09:50 Shut Down - Gas	6	0.21	115.00		
11/22/2022 11:53 11/22/2022 12:56 Hot Start - Gas	64	39.78	259.90		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.14	115.00		
11/28/2022 02:03 11/28/2022 03:43 Warm Start - Gas	101	98.73	456.20		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.06	115.00		
12/05/2022 09:53 12/05/2022 11:15 Cold Start - Gas	83	77.86	779.10		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.08	115.00		
12/26/2022 00:22 12/26/2022 01:45 Warm Start - Gas	84	87.99	456.20		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.19	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/27/2022 05:33 12/27/2022 06:25 Hot Start - Gas	53	30.69	259.90		
12/30/2022 00:09 12/30/2022 00:14 Shut Down - Gas	6	0.12	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:14 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.6		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	193.9		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.8		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	189.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	113.1		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	233.5		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.5		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	188.2		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.6		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	273.2		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:17 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	188.4		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.3		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	119.1		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.6		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	208.2		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	105.2		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	203.1		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	1.2		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	97.2		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.6		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	2.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	20.0	0	1	0	0	0
10/01/2022 13:00	16.4	0	1	0	0	0
10/01/2022 14:00	30.4	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	71.5 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	39.8	0	1	0	0	0
10/02/2022 12:00	23.7	0	1	0	0	0
10/02/2022 13:00	39.5	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.0 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.7	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	23.1	0	0	1	0	0
10/09/2022 15:00	16.4	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.2 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	74.6	0	1	0	0	0
10/16/2022 18:00	60.3	0	1	0	0	0
10/16/2022 19:00	62.1	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	197.0 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.9	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	62.4	0	1	0	0	0
10/23/2022 21:00	20.7	0	1	0	0	0
10/23/2022 22:00	35.9	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	119.0 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	2.0	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	25.9	1	0	0	0	0
10/30/2022 20:00	49.9	1	0	0	0	0
10/30/2022 21:00	53.1	1	0	0	0	0
10/30/2022 22:00	80.1	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	209.0 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	2.4	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	40.9	0	1	0	0	0
11/06/2022 10:00	26.8	0	1	0	0	0
11/06/2022 11:00	66.6	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	1.0	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	135.3 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	9.5	0	0	1	0	0
11/07/2022 01:00	56.2	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.7 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.2	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.0	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	56.5	0	1	0	0	0
11/27/2022 22:00	21.0	0	1	0	0	0
11/27/2022 23:00	57.9	0	1	0	0	0
Average/Sum#:	135.4 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.9	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	8.0	0	0	1	0	0
12/01/2022 03:00	34.5	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.5 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	1.9	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	43.8	0	1	0	0	0
12/25/2022 19:00	25.3	0	1	0	0	0
12/25/2022 20:00	49.4	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	120.4 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	2.1	0	0	0	1	0
Average/Sum#:	2.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	1.6	0	0	1	0	0
12/27/2022 02:00	36.4	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.0 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	2.4	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	33.0	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	2,122.5	0	1	0	0	0
10/01/2022 13:00	3,619.2	0	1	0	0	0
10/01/2022 14:00	5,890.9	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	48.7	0	0	0	1	0
Average/Sum#:	11,714.3 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,890.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	1,996.4	0	1	0	0	0
10/02/2022 12:00	3,888.4	0	1	0	0	0
10/02/2022 13:00	5,484.2	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,369.0 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,484.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	24.2	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	2,647.3	0	0	1	0	0
10/09/2022 15:00	4,141.6	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,813.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,141.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	61.3	0	0	0	1	0
Average/Sum#:	61.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	2,316.6	0	1	0	0	0
10/16/2022 18:00	5,522.9	0	1	0	0	0
10/16/2022 19:00	6,173.3	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,012.8 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,173.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	31.4	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	31.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	2,048.4	0	1	0	0	0
10/23/2022 21:00	3,564.8	0	1	0	0	0
10/23/2022 22:00	5,679.3	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,292.5 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,679.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	37.4	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	37.4 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	316.2	1	0	0	0	0
10/30/2022 20:00	3,585.6	1	0	0	0	0
10/30/2022 21:00	5,409.9	1	0	0	0	0
10/30/2022 22:00	7,082.4	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,394.1 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,082.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	41.2	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	41.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	864.9	0	1	0	0	0
11/06/2022 10:00	3,630.7	0	1	0	0	0
11/06/2022 11:00	6,809.7	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	18.5	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,323.8 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,809.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	1,351.8	0	0	1	0	0
11/07/2022 01:00	5,792.9	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,144.7 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,792.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	33.4	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	33.4 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	2,205.7	0	1	0	0	0
11/27/2022 22:00	3,787.1	0	1	0	0	0
11/27/2022 23:00	6,500.0	0	1	0	0	0
Average/Sum#:	12,492.8 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,500.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	25.2	0	0	0	1	0
Average/Sum#:	25.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	1,348.3	0	0	1	0	0
12/01/2022 03:00	4,961.0	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,309.3 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,961.0	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	30.5	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	2,368.1	0	1	0	0	0
12/25/2022 19:00	3,933.6	0	1	0	0	0
12/25/2022 20:00	5,883.9	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,216.1 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,883.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	69.9	0	0	0	1	0
Average/Sum#:	69.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	379.4	0	0	1	0	0
12/27/2022 02:00	5,452.8	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,832.2 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,452.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	38.8	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	38.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2022 00:00	0.0	0	0	0	0	1
10/01/2022 01:00	1.2	0	0	0	1	0
10/01/2022 02:00	0.0	0	0	0	0	0
10/01/2022 03:00	0.0	0	0	0	0	0
10/01/2022 04:00	0.0	0	0	0	0	0
10/01/2022 05:00	0.0	0	0	0	0	0
10/01/2022 06:00	0.0	0	0	0	0	0
10/01/2022 07:00	0.0	0	0	0	0	0
10/01/2022 08:00	0.0	0	0	0	0	0
10/01/2022 09:00	0.0	0	0	0	0	0
10/01/2022 10:00	0.0	0	0	0	0	0
10/01/2022 11:00	0.0	0	0	0	0	0
10/01/2022 12:00	38.8	0	1	0	0	0
10/01/2022 13:00	22.6	0	1	0	0	0
10/01/2022 14:00	43.1	0	1	0	0	0
10/01/2022 15:00	0.0	0	0	0	0	1
10/01/2022 16:00	0.0	0	0	0	0	1
10/01/2022 17:00	0.0	0	0	0	0	1
10/01/2022 18:00	0.0	0	0	0	0	1
10/01/2022 19:00	0.0	0	0	0	0	1
10/01/2022 20:00	0.0	0	0	0	0	1
10/01/2022 21:00	0.0	0	0	0	0	1
10/01/2022 22:00	0.0	0	0	0	0	1
10/01/2022 23:00	0.6	0	0	0	1	0
Average/Sum#:	106.3 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2022 00:00	0.0	0	0	0	0	0
10/02/2022 01:00	0.0	0	0	0	0	0
10/02/2022 02:00	0.0	0	0	0	0	0
10/02/2022 03:00	0.0	0	0	0	0	0
10/02/2022 04:00	0.0	0	0	0	0	0
10/02/2022 05:00	0.0	0	0	0	0	0
10/02/2022 06:00	0.0	0	0	0	0	0
10/02/2022 07:00	0.0	0	0	0	0	0
10/02/2022 08:00	0.0	0	0	0	0	0
10/02/2022 09:00	0.0	0	0	0	0	0
10/02/2022 10:00	0.0	0	0	0	0	0
10/02/2022 11:00	34.8	0	1	0	0	0
10/02/2022 12:00	19.8	0	1	0	0	0
10/02/2022 13:00	28.9	0	1	0	0	0
10/02/2022 14:00	0.0	0	0	0	0	1
10/02/2022 15:00	0.0	0	0	0	0	1
10/02/2022 16:00	0.0	0	0	0	0	1
10/02/2022 17:00	0.0	0	0	0	0	1
10/02/2022 18:00	0.0	0	0	0	0	1
10/02/2022 19:00	0.0	0	0	0	0	1
10/02/2022 20:00	0.0	0	0	0	0	1
10/02/2022 21:00	0.0	0	0	0	0	1
10/02/2022 22:00	0.0	0	0	0	0	1
10/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	83.5 #	0 #	3 #	0 #	0 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2022 00:00	0.0	0	0	0	0	1
10/03/2022 01:00	0.0	0	0	0	0	1
10/03/2022 02:00	0.0	0	0	0	0	1
10/03/2022 03:00	0.0	0	0	0	0	1
10/03/2022 04:00	0.0	0	0	0	0	1
10/03/2022 05:00	0.0	0	0	0	0	1
10/03/2022 06:00	0.0	0	0	0	0	1
10/03/2022 07:00	0.0	0	0	0	0	1
10/03/2022 08:00	0.0	0	0	0	0	1
10/03/2022 09:00	0.0	0	0	0	0	1
10/03/2022 10:00	0.0	0	0	0	0	1
10/03/2022 11:00	0.0	0	0	0	0	1
10/03/2022 12:00	0.0	0	0	0	0	1
10/03/2022 13:00	0.0	0	0	0	0	1
10/03/2022 14:00	0.0	0	0	0	0	1
10/03/2022 15:00	0.0	0	0	0	0	1
10/03/2022 16:00	0.0	0	0	0	0	1
10/03/2022 17:00	0.0	0	0	0	0	1
10/03/2022 18:00	0.0	0	0	0	0	1
10/03/2022 19:00	0.0	0	0	0	0	1
10/03/2022 20:00	0.0	0	0	0	0	1
10/03/2022 21:00	0.0	0	0	0	0	1
10/03/2022 22:00	0.0	0	0	0	0	1
10/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2022 00:00	0.0	0	0	0	0	1
10/04/2022 01:00	0.0	0	0	0	0	1
10/04/2022 02:00	0.0	0	0	0	0	1
10/04/2022 03:00	0.0	0	0	0	0	1
10/04/2022 04:00	0.0	0	0	0	0	1
10/04/2022 05:00	0.0	0	0	0	0	1
10/04/2022 06:00	0.0	0	0	0	0	1
10/04/2022 07:00	0.0	0	0	0	0	1
10/04/2022 08:00	0.0	0	0	0	0	1
10/04/2022 09:00	0.0	0	0	0	0	1
10/04/2022 10:00	0.0	0	0	0	0	1
10/04/2022 11:00	0.0	0	0	0	0	1
10/04/2022 12:00	0.0	0	0	0	0	1
10/04/2022 13:00	0.0	0	0	0	0	1
10/04/2022 14:00	0.0	0	0	0	0	1
10/04/2022 15:00	0.0	0	0	0	0	1
10/04/2022 16:00	0.0	0	0	0	0	1
10/04/2022 17:00	0.0	0	0	0	0	1
10/04/2022 18:00	0.0	0	0	0	0	1
10/04/2022 19:00	0.0	0	0	0	0	1
10/04/2022 20:00	0.0	0	0	0	0	1
10/04/2022 21:00	0.0	0	0	0	0	1
10/04/2022 22:00	0.0	0	0	0	0	1
10/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2022 00:00	0.0	0	0	0	0	1
10/05/2022 01:00	0.0	0	0	0	0	1
10/05/2022 02:00	0.0	0	0	0	0	1
10/05/2022 03:00	0.0	0	0	0	0	1
10/05/2022 04:00	0.0	0	0	0	0	1
10/05/2022 05:00	0.0	0	0	0	0	1
10/05/2022 06:00	0.0	0	0	0	0	1
10/05/2022 07:00	0.0	0	0	0	0	1
10/05/2022 08:00	0.0	0	0	0	0	1
10/05/2022 09:00	0.0	0	0	0	0	1
10/05/2022 10:00	0.0	0	0	0	0	1
10/05/2022 11:00	0.0	0	0	0	0	1
10/05/2022 12:00	0.0	0	0	0	0	1
10/05/2022 13:00	0.0	0	0	0	0	1
10/05/2022 14:00	0.0	0	0	0	0	1
10/05/2022 15:00	0.0	0	0	0	0	1
10/05/2022 16:00	0.0	0	0	0	0	1
10/05/2022 17:00	0.0	0	0	0	0	1
10/05/2022 18:00	0.0	0	0	0	0	1
10/05/2022 19:00	0.0	0	0	0	0	1
10/05/2022 20:00	0.0	0	0	0	0	1
10/05/2022 21:00	0.0	0	0	0	0	1
10/05/2022 22:00	0.0	0	0	0	0	1
10/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2022 00:00	0.0	0	0	0	0	1
10/06/2022 01:00	0.0	0	0	0	0	1
10/06/2022 02:00	0.0	0	0	0	0	1
10/06/2022 03:00	0.0	0	0	0	0	1
10/06/2022 04:00	0.0	0	0	0	0	1
10/06/2022 05:00	0.0	0	0	0	0	1
10/06/2022 06:00	0.0	0	0	0	0	1
10/06/2022 07:00	0.0	0	0	0	0	1
10/06/2022 08:00	0.0	0	0	0	0	1
10/06/2022 09:00	0.0	0	0	0	0	1
10/06/2022 10:00	0.0	0	0	0	0	1
10/06/2022 11:00	0.0	0	0	0	0	1
10/06/2022 12:00	0.0	0	0	0	0	1
10/06/2022 13:00	0.0	0	0	0	0	1
10/06/2022 14:00	0.0	0	0	0	0	1
10/06/2022 15:00	0.0	0	0	0	0	1
10/06/2022 16:00	0.0	0	0	0	0	1
10/06/2022 17:00	0.0	0	0	0	0	1
10/06/2022 18:00	0.0	0	0	0	0	1
10/06/2022 19:00	0.0	0	0	0	0	1
10/06/2022 20:00	0.0	0	0	0	0	1
10/06/2022 21:00	0.0	0	0	0	0	1
10/06/2022 22:00	0.0	0	0	0	0	1
10/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2022 00:00	0.0	0	0	0	0	1
10/07/2022 01:00	0.0	0	0	0	0	1
10/07/2022 02:00	0.0	0	0	0	0	1
10/07/2022 03:00	0.0	0	0	0	0	1
10/07/2022 04:00	0.0	0	0	0	0	1
10/07/2022 05:00	0.0	0	0	0	0	1
10/07/2022 06:00	0.0	0	0	0	0	1
10/07/2022 07:00	0.0	0	0	0	0	1
10/07/2022 08:00	0.0	0	0	0	0	1
10/07/2022 09:00	0.0	0	0	0	0	1
10/07/2022 10:00	0.0	0	0	0	0	1
10/07/2022 11:00	0.0	0	0	0	0	1
10/07/2022 12:00	0.0	0	0	0	0	1
10/07/2022 13:00	0.0	0	0	0	0	1
10/07/2022 14:00	0.0	0	0	0	0	1
10/07/2022 15:00	0.0	0	0	0	0	1
10/07/2022 16:00	0.0	0	0	0	0	1
10/07/2022 17:00	0.0	0	0	0	0	1
10/07/2022 18:00	0.0	0	0	0	0	1
10/07/2022 19:00	0.0	0	0	0	0	1
10/07/2022 20:00	0.0	0	0	0	0	1
10/07/2022 21:00	0.0	0	0	0	0	1
10/07/2022 22:00	0.0	0	0	0	0	1
10/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2022 00:00	0.0	0	0	0	0	1
10/08/2022 01:00	0.0	0	0	0	0	1
10/08/2022 02:00	0.0	0	0	0	0	1
10/08/2022 03:00	0.0	0	0	0	0	1
10/08/2022 04:00	0.0	0	0	0	0	1
10/08/2022 05:00	0.0	0	0	0	0	1
10/08/2022 06:00	0.0	0	0	0	0	1
10/08/2022 07:00	0.0	0	0	0	0	1
10/08/2022 08:00	0.0	0	0	0	0	1
10/08/2022 09:00	0.0	0	0	0	0	1
10/08/2022 10:00	0.0	0	0	0	0	1
10/08/2022 11:00	0.0	0	0	0	0	1
10/08/2022 12:00	0.0	0	0	0	0	1
10/08/2022 13:00	0.0	0	0	0	0	1
10/08/2022 14:00	0.0	0	0	0	0	1
10/08/2022 15:00	0.0	0	0	0	0	1
10/08/2022 16:00	0.0	0	0	0	0	1
10/08/2022 17:00	0.0	0	0	0	0	1
10/08/2022 18:00	0.0	0	0	0	0	1
10/08/2022 19:00	0.0	0	0	0	0	1
10/08/2022 20:00	0.0	0	0	0	0	1
10/08/2022 21:00	0.0	0	0	0	0	1
10/08/2022 22:00	0.0	0	0	0	0	1
10/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2022 00:00	0.0	0	0	0	0	1
10/09/2022 01:00	0.0	0	0	0	0	1
10/09/2022 02:00	0.0	0	0	0	0	1
10/09/2022 03:00	0.0	0	0	0	0	1
10/09/2022 04:00	0.0	0	0	0	0	1
10/09/2022 05:00	0.0	0	0	0	0	1
10/09/2022 06:00	1.1	0	0	0	1	0
10/09/2022 07:00	0.0	0	0	0	0	0
10/09/2022 08:00	0.0	0	0	0	0	0
10/09/2022 09:00	0.0	0	0	0	0	0
10/09/2022 10:00	0.0	0	0	0	0	0
10/09/2022 11:00	0.0	0	0	0	0	0
10/09/2022 12:00	0.0	0	0	0	0	0
10/09/2022 13:00	0.0	0	0	0	0	0
10/09/2022 14:00	32.9	0	0	1	0	0
10/09/2022 15:00	20.9	0	0	1	0	0
10/09/2022 16:00	0.0	0	0	0	0	1
10/09/2022 17:00	0.0	0	0	0	0	1
10/09/2022 18:00	0.0	0	0	0	0	1
10/09/2022 19:00	0.0	0	0	0	0	1
10/09/2022 20:00	0.0	0	0	0	0	1
10/09/2022 21:00	0.0	0	0	0	0	1
10/09/2022 22:00	0.0	0	0	0	0	1
10/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.9 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2022 00:00	0.0	0	0	0	0	1
10/10/2022 01:00	0.0	0	0	0	0	1
10/10/2022 02:00	0.0	0	0	0	0	1
10/10/2022 03:00	0.0	0	0	0	0	1
10/10/2022 04:00	0.0	0	0	0	0	1
10/10/2022 05:00	0.0	0	0	0	0	1
10/10/2022 06:00	0.0	0	0	0	0	1
10/10/2022 07:00	0.0	0	0	0	0	1
10/10/2022 08:00	0.0	0	0	0	0	1
10/10/2022 09:00	0.0	0	0	0	0	1
10/10/2022 10:00	0.0	0	0	0	0	1
10/10/2022 11:00	0.0	0	0	0	0	1
10/10/2022 12:00	0.0	0	0	0	0	1
10/10/2022 13:00	0.0	0	0	0	0	1
10/10/2022 14:00	0.0	0	0	0	0	1
10/10/2022 15:00	0.0	0	0	0	0	1
10/10/2022 16:00	0.0	0	0	0	0	1
10/10/2022 17:00	0.0	0	0	0	0	1
10/10/2022 18:00	0.0	0	0	0	0	1
10/10/2022 19:00	0.0	0	0	0	0	1
10/10/2022 20:00	0.0	0	0	0	0	1
10/10/2022 21:00	0.0	0	0	0	0	1
10/10/2022 22:00	0.0	0	0	0	0	1
10/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2022 00:00	0.0	0	0	0	0	1
10/11/2022 01:00	0.0	0	0	0	0	1
10/11/2022 02:00	0.0	0	0	0	0	1
10/11/2022 03:00	0.0	0	0	0	0	1
10/11/2022 04:00	0.0	0	0	0	0	1
10/11/2022 05:00	0.0	0	0	0	0	1
10/11/2022 06:00	0.0	0	0	0	0	1
10/11/2022 07:00	0.0	0	0	0	0	1
10/11/2022 08:00	0.0	0	0	0	0	1
10/11/2022 09:00	0.0	0	0	0	0	1
10/11/2022 10:00	0.0	0	0	0	0	1
10/11/2022 11:00	0.0	0	0	0	0	1
10/11/2022 12:00	0.0	0	0	0	0	1
10/11/2022 13:00	0.0	0	0	0	0	1
10/11/2022 14:00	0.0	0	0	0	0	1
10/11/2022 15:00	0.0	0	0	0	0	1
10/11/2022 16:00	0.0	0	0	0	0	1
10/11/2022 17:00	0.0	0	0	0	0	1
10/11/2022 18:00	0.0	0	0	0	0	1
10/11/2022 19:00	0.0	0	0	0	0	1
10/11/2022 20:00	0.0	0	0	0	0	1
10/11/2022 21:00	0.0	0	0	0	0	1
10/11/2022 22:00	0.0	0	0	0	0	1
10/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2022 00:00	0.0	0	0	0	0	1
10/12/2022 01:00	0.0	0	0	0	0	1
10/12/2022 02:00	0.0	0	0	0	0	1
10/12/2022 03:00	0.0	0	0	0	0	1
10/12/2022 04:00	0.0	0	0	0	0	1
10/12/2022 05:00	0.0	0	0	0	0	1
10/12/2022 06:00	0.0	0	0	0	0	1
10/12/2022 07:00	0.0	0	0	0	0	1
10/12/2022 08:00	0.0	0	0	0	0	1
10/12/2022 09:00	0.0	0	0	0	0	1
10/12/2022 10:00	0.0	0	0	0	0	1
10/12/2022 11:00	0.0	0	0	0	0	1
10/12/2022 12:00	0.0	0	0	0	0	1
10/12/2022 13:00	0.0	0	0	0	0	1
10/12/2022 14:00	0.0	0	0	0	0	1
10/12/2022 15:00	0.0	0	0	0	0	1
10/12/2022 16:00	0.0	0	0	0	0	1
10/12/2022 17:00	0.0	0	0	0	0	1
10/12/2022 18:00	0.0	0	0	0	0	1
10/12/2022 19:00	0.0	0	0	0	0	1
10/12/2022 20:00	0.0	0	0	0	0	1
10/12/2022 21:00	0.0	0	0	0	0	1
10/12/2022 22:00	0.0	0	0	0	0	1
10/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2022 00:00	0.0	0	0	0	0	1
10/13/2022 01:00	0.0	0	0	0	0	1
10/13/2022 02:00	0.0	0	0	0	0	1
10/13/2022 03:00	0.0	0	0	0	0	1
10/13/2022 04:00	0.0	0	0	0	0	1
10/13/2022 05:00	0.0	0	0	0	0	1
10/13/2022 06:00	0.0	0	0	0	0	1
10/13/2022 07:00	0.0	0	0	0	0	1
10/13/2022 08:00	0.0	0	0	0	0	1
10/13/2022 09:00	0.0	0	0	0	0	1
10/13/2022 10:00	0.0	0	0	0	0	1
10/13/2022 11:00	0.0	0	0	0	0	1
10/13/2022 12:00	0.0	0	0	0	0	1
10/13/2022 13:00	0.0	0	0	0	0	1
10/13/2022 14:00	0.0	0	0	0	0	1
10/13/2022 15:00	0.0	0	0	0	0	1
10/13/2022 16:00	0.0	0	0	0	0	1
10/13/2022 17:00	0.0	0	0	0	0	1
10/13/2022 18:00	0.0	0	0	0	0	1
10/13/2022 19:00	0.0	0	0	0	0	1
10/13/2022 20:00	0.0	0	0	0	0	1
10/13/2022 21:00	0.0	0	0	0	0	1
10/13/2022 22:00	0.0	0	0	0	0	1
10/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2022 00:00	0.0	0	0	0	0	1
10/14/2022 01:00	0.0	0	0	0	0	1
10/14/2022 02:00	0.0	0	0	0	0	1
10/14/2022 03:00	0.0	0	0	0	0	1
10/14/2022 04:00	0.0	0	0	0	0	1
10/14/2022 05:00	0.0	0	0	0	0	1
10/14/2022 06:00	0.0	0	0	0	0	1
10/14/2022 07:00	0.0	0	0	0	0	1
10/14/2022 08:00	0.0	0	0	0	0	1
10/14/2022 09:00	0.0	0	0	0	0	1
10/14/2022 10:00	0.0	0	0	0	0	1
10/14/2022 11:00	0.0	0	0	0	0	1
10/14/2022 12:00	0.0	0	0	0	0	1
10/14/2022 13:00	0.0	0	0	0	0	1
10/14/2022 14:00	0.0	0	0	0	0	1
10/14/2022 15:00	0.0	0	0	0	0	1
10/14/2022 16:00	0.0	0	0	0	0	1
10/14/2022 17:00	0.0	0	0	0	0	1
10/14/2022 18:00	0.0	0	0	0	0	1
10/14/2022 19:00	0.0	0	0	0	0	1
10/14/2022 20:00	0.0	0	0	0	0	1
10/14/2022 21:00	0.0	0	0	0	0	1
10/14/2022 22:00	0.0	0	0	0	0	1
10/14/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2022 00:00	0.0	0	0	0	0	0
10/15/2022 01:00	0.0	0	0	0	0	0
10/15/2022 02:00	0.0	0	0	0	0	0
10/15/2022 03:00	0.0	0	0	0	0	0
10/15/2022 04:00	0.0	0	0	0	0	0
10/15/2022 05:00	0.0	0	0	0	0	0
10/15/2022 06:00	0.0	0	0	0	0	0
10/15/2022 07:00	0.0	0	0	0	0	0
10/15/2022 08:00	0.0	0	0	0	0	0
10/15/2022 09:00	0.0	0	0	0	0	0
10/15/2022 10:00	0.0	0	0	0	0	0
10/15/2022 11:00	0.0	0	0	0	0	0
10/15/2022 12:00	0.0	0	0	0	0	0
10/15/2022 13:00	0.0	0	0	0	0	0
10/15/2022 14:00	0.0	0	0	0	0	0
10/15/2022 15:00	0.0	0	0	0	0	0
10/15/2022 16:00	0.0	0	0	0	0	0
10/15/2022 17:00	0.0	0	0	0	0	0
10/15/2022 18:00	0.0	0	0	0	0	0
10/15/2022 19:00	0.0	0	0	0	0	0
10/15/2022 20:00	0.0	0	0	0	0	0
10/15/2022 21:00	0.0	0	0	0	0	0
10/15/2022 22:00	0.0	0	0	0	0	0
10/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2022 00:00	0.0	0	0	0	0	0
10/16/2022 01:00	0.0	0	0	0	0	0
10/16/2022 02:00	0.0	0	0	0	0	0
10/16/2022 03:00	0.0	0	0	0	0	0
10/16/2022 04:00	0.0	0	0	0	0	0
10/16/2022 05:00	0.0	0	0	0	0	0
10/16/2022 06:00	0.0	0	0	0	0	0
10/16/2022 07:00	0.0	0	0	0	0	0
10/16/2022 08:00	0.0	0	0	0	0	0
10/16/2022 09:00	0.0	0	0	0	0	0
10/16/2022 10:00	0.0	0	0	0	0	0
10/16/2022 11:00	0.0	0	0	0	0	0
10/16/2022 12:00	0.0	0	0	0	0	0
10/16/2022 13:00	0.0	0	0	0	0	0
10/16/2022 14:00	0.0	0	0	0	0	0
10/16/2022 15:00	0.0	0	0	0	0	0
10/16/2022 16:00	0.0	0	0	0	0	0
10/16/2022 17:00	44.1	0	1	0	0	0
10/16/2022 18:00	47.1	0	1	0	0	0
10/16/2022 19:00	34.2	0	1	0	0	0
10/16/2022 20:00	0.0	0	0	0	0	1
10/16/2022 21:00	0.0	0	0	0	0	1
10/16/2022 22:00	0.0	0	0	0	0	1
10/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.4 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2022 00:00	0.0	0	0	0	0	1
10/17/2022 01:00	0.0	0	0	0	0	1
10/17/2022 02:00	0.0	0	0	0	0	1
10/17/2022 03:00	0.0	0	0	0	0	1
10/17/2022 04:00	0.0	0	0	0	0	1
10/17/2022 05:00	0.0	0	0	0	0	1
10/17/2022 06:00	0.0	0	0	0	0	1
10/17/2022 07:00	0.0	0	0	0	0	1
10/17/2022 08:00	0.0	0	0	0	0	1
10/17/2022 09:00	0.0	0	0	0	0	1
10/17/2022 10:00	0.0	0	0	0	0	1
10/17/2022 11:00	0.0	0	0	0	0	1
10/17/2022 12:00	0.0	0	0	0	0	1
10/17/2022 13:00	0.0	0	0	0	0	1
10/17/2022 14:00	0.0	0	0	0	0	1
10/17/2022 15:00	0.0	0	0	0	0	1
10/17/2022 16:00	0.0	0	0	0	0	1
10/17/2022 17:00	0.0	0	0	0	0	1
10/17/2022 18:00	0.0	0	0	0	0	1
10/17/2022 19:00	0.0	0	0	0	0	1
10/17/2022 20:00	0.0	0	0	0	0	1
10/17/2022 21:00	0.0	0	0	0	0	1
10/17/2022 22:00	0.0	0	0	0	0	1
10/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2022 00:00	0.0	0	0	0	0	1
10/18/2022 01:00	0.0	0	0	0	0	1
10/18/2022 02:00	0.0	0	0	0	0	1
10/18/2022 03:00	0.0	0	0	0	0	1
10/18/2022 04:00	0.0	0	0	0	0	1
10/18/2022 05:00	0.0	0	0	0	0	1
10/18/2022 06:00	0.0	0	0	0	0	1
10/18/2022 07:00	0.0	0	0	0	0	1
10/18/2022 08:00	0.0	0	0	0	0	1
10/18/2022 09:00	0.0	0	0	0	0	1
10/18/2022 10:00	0.0	0	0	0	0	1
10/18/2022 11:00	0.0	0	0	0	0	1
10/18/2022 12:00	0.0	0	0	0	0	1
10/18/2022 13:00	0.0	0	0	0	0	1
10/18/2022 14:00	0.0	0	0	0	0	1
10/18/2022 15:00	0.0	0	0	0	0	1
10/18/2022 16:00	0.0	0	0	0	0	1
10/18/2022 17:00	0.0	0	0	0	0	1
10/18/2022 18:00	0.0	0	0	0	0	1
10/18/2022 19:00	0.0	0	0	0	0	1
10/18/2022 20:00	0.0	0	0	0	0	1
10/18/2022 21:00	0.0	0	0	0	0	1
10/18/2022 22:00	0.0	0	0	0	0	1
10/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2022 00:00	0.0	0	0	0	0	1
10/19/2022 01:00	0.0	0	0	0	0	1
10/19/2022 02:00	0.0	0	0	0	0	1
10/19/2022 03:00	0.0	0	0	0	0	1
10/19/2022 04:00	0.0	0	0	0	0	1
10/19/2022 05:00	0.0	0	0	0	0	1
10/19/2022 06:00	0.0	0	0	0	0	1
10/19/2022 07:00	0.0	0	0	0	0	1
10/19/2022 08:00	0.0	0	0	0	0	1
10/19/2022 09:00	0.0	0	0	0	0	1
10/19/2022 10:00	0.0	0	0	0	0	1
10/19/2022 11:00	0.0	0	0	0	0	1
10/19/2022 12:00	0.0	0	0	0	0	1
10/19/2022 13:00	0.0	0	0	0	0	1
10/19/2022 14:00	0.0	0	0	0	0	1
10/19/2022 15:00	0.0	0	0	0	0	1
10/19/2022 16:00	0.0	0	0	0	0	1
10/19/2022 17:00	0.0	0	0	0	0	1
10/19/2022 18:00	0.0	0	0	0	0	1
10/19/2022 19:00	0.0	0	0	0	0	1
10/19/2022 20:00	0.0	0	0	0	0	1
10/19/2022 21:00	0.0	0	0	0	0	1
10/19/2022 22:00	0.0	0	0	0	0	1
10/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2022 00:00	0.0	0	0	0	0	1
10/20/2022 01:00	0.0	0	0	0	0	1
10/20/2022 02:00	0.0	0	0	0	0	1
10/20/2022 03:00	0.0	0	0	0	0	1
10/20/2022 04:00	0.0	0	0	0	0	1
10/20/2022 05:00	0.0	0	0	0	0	1
10/20/2022 06:00	0.0	0	0	0	0	1
10/20/2022 07:00	0.0	0	0	0	0	1
10/20/2022 08:00	0.0	0	0	0	0	1
10/20/2022 09:00	0.0	0	0	0	0	1
10/20/2022 10:00	0.0	0	0	0	0	1
10/20/2022 11:00	0.0	0	0	0	0	1
10/20/2022 12:00	0.0	0	0	0	0	1
10/20/2022 13:00	0.0	0	0	0	0	1
10/20/2022 14:00	0.0	0	0	0	0	1
10/20/2022 15:00	0.0	0	0	0	0	1
10/20/2022 16:00	0.0	0	0	0	0	1
10/20/2022 17:00	0.0	0	0	0	0	1
10/20/2022 18:00	0.0	0	0	0	0	1
10/20/2022 19:00	0.0	0	0	0	0	1
10/20/2022 20:00	0.0	0	0	0	0	1
10/20/2022 21:00	0.0	0	0	0	0	1
10/20/2022 22:00	0.0	0	0	0	0	1
10/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2022 00:00	0.0	0	0	0	0	1
10/21/2022 01:00	0.0	0	0	0	0	1
10/21/2022 02:00	0.0	0	0	0	0	1
10/21/2022 03:00	0.0	0	0	0	0	1
10/21/2022 04:00	0.0	0	0	0	0	1
10/21/2022 05:00	0.0	0	0	0	0	1
10/21/2022 06:00	0.0	0	0	0	0	1
10/21/2022 07:00	0.0	0	0	0	0	1
10/21/2022 08:00	0.0	0	0	0	0	1
10/21/2022 09:00	0.0	0	0	0	0	1
10/21/2022 10:00	0.0	0	0	0	0	1
10/21/2022 11:00	0.0	0	0	0	0	1
10/21/2022 12:00	0.0	0	0	0	0	1
10/21/2022 13:00	0.0	0	0	0	0	1
10/21/2022 14:00	0.0	0	0	0	0	1
10/21/2022 15:00	0.0	0	0	0	0	1
10/21/2022 16:00	0.0	0	0	0	0	1
10/21/2022 17:00	0.0	0	0	0	0	1
10/21/2022 18:00	0.0	0	0	0	0	1
10/21/2022 19:00	0.0	0	0	0	0	1
10/21/2022 20:00	0.0	0	0	0	0	1
10/21/2022 21:00	0.0	0	0	0	0	1
10/21/2022 22:00	1.1	0	0	0	1	0
10/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2022 00:00	0.0	0	0	0	0	0
10/22/2022 01:00	0.0	0	0	0	0	0
10/22/2022 02:00	0.0	0	0	0	0	0
10/22/2022 03:00	0.0	0	0	0	0	0
10/22/2022 04:00	0.0	0	0	0	0	0
10/22/2022 05:00	0.0	0	0	0	0	0
10/22/2022 06:00	0.0	0	0	0	0	0
10/22/2022 07:00	0.0	0	0	0	0	0
10/22/2022 08:00	0.0	0	0	0	0	0
10/22/2022 09:00	0.0	0	0	0	0	0
10/22/2022 10:00	0.0	0	0	0	0	0
10/22/2022 11:00	0.0	0	0	0	0	0
10/22/2022 12:00	0.0	0	0	0	0	0
10/22/2022 13:00	0.0	0	0	0	0	0
10/22/2022 14:00	0.0	0	0	0	0	0
10/22/2022 15:00	0.0	0	0	0	0	0
10/22/2022 16:00	0.0	0	0	0	0	0
10/22/2022 17:00	0.0	0	0	0	0	0
10/22/2022 18:00	0.0	0	0	0	0	0
10/22/2022 19:00	0.0	0	0	0	0	0
10/22/2022 20:00	0.0	0	0	0	0	0
10/22/2022 21:00	0.0	0	0	0	0	0
10/22/2022 22:00	0.0	0	0	0	0	0
10/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2022 00:00	0.0	0	0	0	0	0
10/23/2022 01:00	0.0	0	0	0	0	0
10/23/2022 02:00	0.0	0	0	0	0	0
10/23/2022 03:00	0.0	0	0	0	0	0
10/23/2022 04:00	0.0	0	0	0	0	0
10/23/2022 05:00	0.0	0	0	0	0	0
10/23/2022 06:00	0.0	0	0	0	0	0
10/23/2022 07:00	0.0	0	0	0	0	0
10/23/2022 08:00	0.0	0	0	0	0	0
10/23/2022 09:00	0.0	0	0	0	0	0
10/23/2022 10:00	0.0	0	0	0	0	0
10/23/2022 11:00	0.0	0	0	0	0	0
10/23/2022 12:00	0.0	0	0	0	0	0
10/23/2022 13:00	0.0	0	0	0	0	0
10/23/2022 14:00	0.0	0	0	0	0	0
10/23/2022 15:00	0.0	0	0	0	0	0
10/23/2022 16:00	0.0	0	0	0	0	0
10/23/2022 17:00	0.0	0	0	0	0	0
10/23/2022 18:00	0.0	0	0	0	0	0
10/23/2022 19:00	0.0	0	0	0	0	0
10/23/2022 20:00	44.9	0	1	0	0	0
10/23/2022 21:00	32.6	0	1	0	0	0
10/23/2022 22:00	36.8	0	1	0	0	0
10/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.3 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2022 00:00	0.0	0	0	0	0	1
10/24/2022 01:00	0.0	0	0	0	0	1
10/24/2022 02:00	0.0	0	0	0	0	1
10/24/2022 03:00	0.0	0	0	0	0	1
10/24/2022 04:00	0.0	0	0	0	0	1
10/24/2022 05:00	0.0	0	0	0	0	1
10/24/2022 06:00	0.0	0	0	0	0	1
10/24/2022 07:00	0.0	0	0	0	0	1
10/24/2022 08:00	0.0	0	0	0	0	1
10/24/2022 09:00	0.0	0	0	0	0	1
10/24/2022 10:00	0.0	0	0	0	0	1
10/24/2022 11:00	0.0	0	0	0	0	1
10/24/2022 12:00	0.0	0	0	0	0	1
10/24/2022 13:00	0.0	0	0	0	0	1
10/24/2022 14:00	0.8	0	0	0	1	0
10/24/2022 15:00	0.0	0	0	0	0	0
10/24/2022 16:00	0.0	0	0	0	0	0
10/24/2022 17:00	0.0	0	0	0	0	0
10/24/2022 18:00	0.0	0	0	0	0	0
10/24/2022 19:00	0.0	0	0	0	0	0
10/24/2022 20:00	0.0	0	0	0	0	0
10/24/2022 21:00	0.0	0	0	0	0	0
10/24/2022 22:00	0.0	0	0	0	0	0
10/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2022 00:00	0.0	0	0	0	0	0
10/25/2022 01:00	0.0	0	0	0	0	0
10/25/2022 02:00	0.0	0	0	0	0	0
10/25/2022 03:00	0.0	0	0	0	0	0
10/25/2022 04:00	0.0	0	0	0	0	0
10/25/2022 05:00	0.0	0	0	0	0	0
10/25/2022 06:00	0.0	0	0	0	0	0
10/25/2022 07:00	0.0	0	0	0	0	0
10/25/2022 08:00	0.0	0	0	0	0	0
10/25/2022 09:00	0.0	0	0	0	0	0
10/25/2022 10:00	0.0	0	0	0	0	0
10/25/2022 11:00	0.0	0	0	0	0	0
10/25/2022 12:00	0.0	0	0	0	0	0
10/25/2022 13:00	0.0	0	0	0	0	0
10/25/2022 14:00	0.0	0	0	0	0	0
10/25/2022 15:00	0.0	0	0	0	0	0
10/25/2022 16:00	0.0	0	0	0	0	0
10/25/2022 17:00	0.0	0	0	0	0	0
10/25/2022 18:00	0.0	0	0	0	0	0
10/25/2022 19:00	0.0	0	0	0	0	0
10/25/2022 20:00	0.0	0	0	0	0	0
10/25/2022 21:00	0.0	0	0	0	0	0
10/25/2022 22:00	0.0	0	0	0	0	0
10/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2022 00:00	0.0	0	0	0	0	0
10/26/2022 01:00	0.0	0	0	0	0	0
10/26/2022 02:00	0.0	0	0	0	0	0
10/26/2022 03:00	0.0	0	0	0	0	0
10/26/2022 04:00	0.0	0	0	0	0	0
10/26/2022 05:00	0.0	0	0	0	0	0
10/26/2022 06:00	0.0	0	0	0	0	0
10/26/2022 07:00	0.0	0	0	0	0	0
10/26/2022 08:00	0.0	0	0	0	0	0
10/26/2022 09:00	0.0	0	0	0	0	0
10/26/2022 10:00	0.0	0	0	0	0	0
10/26/2022 11:00	0.0	0	0	0	0	0
10/26/2022 12:00	0.0	0	0	0	0	0
10/26/2022 13:00	0.0	0	0	0	0	0
10/26/2022 14:00	0.0	0	0	0	0	0
10/26/2022 15:00	0.0	0	0	0	0	0
10/26/2022 16:00	0.0	0	0	0	0	0
10/26/2022 17:00	0.0	0	0	0	0	0
10/26/2022 18:00	0.0	0	0	0	0	0
10/26/2022 19:00	0.0	0	0	0	0	0
10/26/2022 20:00	0.0	0	0	0	0	0
10/26/2022 21:00	0.0	0	0	0	0	0
10/26/2022 22:00	0.0	0	0	0	0	0
10/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2022 00:00	0.0	0	0	0	0	0
10/27/2022 01:00	0.0	0	0	0	0	0
10/27/2022 02:00	0.0	0	0	0	0	0
10/27/2022 03:00	0.0	0	0	0	0	0
10/27/2022 04:00	0.0	0	0	0	0	0
10/27/2022 05:00	0.0	0	0	0	0	0
10/27/2022 06:00	0.0	0	0	0	0	0
10/27/2022 07:00	0.0	0	0	0	0	0
10/27/2022 08:00	0.0	0	0	0	0	0
10/27/2022 09:00	0.0	0	0	0	0	0
10/27/2022 10:00	0.0	0	0	0	0	0
10/27/2022 11:00	0.0	0	0	0	0	0
10/27/2022 12:00	0.0	0	0	0	0	0
10/27/2022 13:00	0.0	0	0	0	0	0
10/27/2022 14:00	0.0	0	0	0	0	0
10/27/2022 15:00	0.0	0	0	0	0	0
10/27/2022 16:00	0.0	0	0	0	0	0
10/27/2022 17:00	0.0	0	0	0	0	0
10/27/2022 18:00	0.0	0	0	0	0	0
10/27/2022 19:00	0.0	0	0	0	0	0
10/27/2022 20:00	0.0	0	0	0	0	0
10/27/2022 21:00	0.0	0	0	0	0	0
10/27/2022 22:00	0.0	0	0	0	0	0
10/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2022 00:00	0.0	0	0	0	0	0
10/28/2022 01:00	0.0	0	0	0	0	0
10/28/2022 02:00	0.0	0	0	0	0	0
10/28/2022 03:00	0.0	0	0	0	0	0
10/28/2022 04:00	0.0	0	0	0	0	0
10/28/2022 05:00	0.0	0	0	0	0	0
10/28/2022 06:00	0.0	0	0	0	0	0
10/28/2022 07:00	0.0	0	0	0	0	0
10/28/2022 08:00	0.0	0	0	0	0	0
10/28/2022 09:00	0.0	0	0	0	0	0
10/28/2022 10:00	0.0	0	0	0	0	0
10/28/2022 11:00	0.0	0	0	0	0	0
10/28/2022 12:00	0.0	0	0	0	0	0
10/28/2022 13:00	0.0	0	0	0	0	0
10/28/2022 14:00	0.0	0	0	0	0	0
10/28/2022 15:00	0.0	0	0	0	0	0
10/28/2022 16:00	0.0	0	0	0	0	0
10/28/2022 17:00	0.0	0	0	0	0	0
10/28/2022 18:00	0.0	0	0	0	0	0
10/28/2022 19:00	0.0	0	0	0	0	0
10/28/2022 20:00	0.0	0	0	0	0	0
10/28/2022 21:00	0.0	0	0	0	0	0
10/28/2022 22:00	0.0	0	0	0	0	0
10/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2022 00:00	0.0	0	0	0	0	0
10/29/2022 01:00	0.0	0	0	0	0	0
10/29/2022 02:00	0.0	0	0	0	0	0
10/29/2022 03:00	0.0	0	0	0	0	0
10/29/2022 04:00	0.0	0	0	0	0	0
10/29/2022 05:00	0.0	0	0	0	0	0
10/29/2022 06:00	0.0	0	0	0	0	0
10/29/2022 07:00	0.0	0	0	0	0	0
10/29/2022 08:00	0.0	0	0	0	0	0
10/29/2022 09:00	0.0	0	0	0	0	0
10/29/2022 10:00	0.0	0	0	0	0	0
10/29/2022 11:00	0.0	0	0	0	0	0
10/29/2022 12:00	0.0	0	0	0	0	0
10/29/2022 13:00	0.0	0	0	0	0	0
10/29/2022 14:00	0.0	0	0	0	0	0
10/29/2022 15:00	0.0	0	0	0	0	0
10/29/2022 16:00	0.0	0	0	0	0	0
10/29/2022 17:00	0.0	0	0	0	0	0
10/29/2022 18:00	0.0	0	0	0	0	0
10/29/2022 19:00	0.0	0	0	0	0	0
10/29/2022 20:00	0.0	0	0	0	0	0
10/29/2022 21:00	0.0	0	0	0	0	0
10/29/2022 22:00	0.0	0	0	0	0	0
10/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2022 00:00	0.0	0	0	0	0	0
10/30/2022 01:00	0.0	0	0	0	0	0
10/30/2022 02:00	0.0	0	0	0	0	0
10/30/2022 03:00	0.0	0	0	0	0	0
10/30/2022 04:00	0.0	0	0	0	0	0
10/30/2022 05:00	0.0	0	0	0	0	0
10/30/2022 06:00	0.0	0	0	0	0	0
10/30/2022 07:00	0.0	0	0	0	0	0
10/30/2022 08:00	0.0	0	0	0	0	0
10/30/2022 09:00	0.0	0	0	0	0	0
10/30/2022 10:00	0.0	0	0	0	0	0
10/30/2022 11:00	0.0	0	0	0	0	0
10/30/2022 12:00	0.0	0	0	0	0	0
10/30/2022 13:00	0.0	0	0	0	0	0
10/30/2022 14:00	0.0	0	0	0	0	0
10/30/2022 15:00	0.0	0	0	0	0	0
10/30/2022 16:00	0.0	0	0	0	0	0
10/30/2022 17:00	0.0	0	0	0	0	0
10/30/2022 18:00	0.0	0	0	0	0	0
10/30/2022 19:00	3.8	1	0	0	0	0
10/30/2022 20:00	65.6	1	0	0	0	0
10/30/2022 21:00	40.0	1	0	0	0	0
10/30/2022 22:00	53.7	1	0	0	0	0
10/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	163.1 #	4 #	0 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2022 00:00	0.0	0	0	0	0	1
10/31/2022 01:00	0.0	0	0	0	0	1
10/31/2022 02:00	0.0	0	0	0	0	1
10/31/2022 03:00	0.0	0	0	0	0	1
10/31/2022 04:00	0.0	0	0	0	0	1
10/31/2022 05:00	0.0	0	0	0	0	1
10/31/2022 06:00	0.0	0	0	0	0	1
10/31/2022 07:00	0.0	0	0	0	0	1
10/31/2022 08:00	0.0	0	0	0	0	1
10/31/2022 09:00	0.0	0	0	0	0	1
10/31/2022 10:00	0.0	0	0	0	0	1
10/31/2022 11:00	0.0	0	0	0	0	1
10/31/2022 12:00	0.0	0	0	0	0	1
10/31/2022 13:00	0.0	0	0	0	0	1
10/31/2022 14:00	0.0	0	0	0	0	1
10/31/2022 15:00	0.0	0	0	0	0	1
10/31/2022 16:00	0.0	0	0	0	0	1
10/31/2022 17:00	0.0	0	0	0	0	1
10/31/2022 18:00	0.0	0	0	0	0	1
10/31/2022 19:00	0.0	0	0	0	0	1
10/31/2022 20:00	0.0	0	0	0	0	1
10/31/2022 21:00	0.0	0	0	0	0	1
10/31/2022 22:00	0.0	0	0	0	0	1
10/31/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2022 00:00	0.0	0	0	0	0	1
11/01/2022 01:00	0.0	0	0	0	0	1
11/01/2022 02:00	0.0	0	0	0	0	1
11/01/2022 03:00	0.0	0	0	0	0	1
11/01/2022 04:00	0.0	0	0	0	0	1
11/01/2022 05:00	0.0	0	0	0	0	1
11/01/2022 06:00	0.0	0	0	0	0	1
11/01/2022 07:00	0.0	0	0	0	0	1
11/01/2022 08:00	0.0	0	0	0	0	1
11/01/2022 09:00	0.0	0	0	0	0	1
11/01/2022 10:00	0.0	0	0	0	0	1
11/01/2022 11:00	0.0	0	0	0	0	1
11/01/2022 12:00	0.0	0	0	0	0	1
11/01/2022 13:00	0.0	0	0	0	0	1
11/01/2022 14:00	0.0	0	0	0	0	1
11/01/2022 15:00	0.0	0	0	0	0	1
11/01/2022 16:00	0.0	0	0	0	0	1
11/01/2022 17:00	0.0	0	0	0	0	1
11/01/2022 18:00	0.0	0	0	0	0	1
11/01/2022 19:00	0.0	0	0	0	0	1
11/01/2022 20:00	0.0	0	0	0	0	1
11/01/2022 21:00	0.0	0	0	0	0	1
11/01/2022 22:00	0.0	0	0	0	0	1
11/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2022 00:00	0.0	0	0	0	0	1
11/02/2022 01:00	0.0	0	0	0	0	1
11/02/2022 02:00	0.0	0	0	0	0	1
11/02/2022 03:00	0.0	0	0	0	0	1
11/02/2022 04:00	0.0	0	0	0	0	1
11/02/2022 05:00	0.0	0	0	0	0	1
11/02/2022 06:00	0.0	0	0	0	0	1
11/02/2022 07:00	0.0	0	0	0	0	1
11/02/2022 08:00	0.0	0	0	0	0	1
11/02/2022 09:00	0.0	0	0	0	0	1
11/02/2022 10:00	0.0	0	0	0	0	1
11/02/2022 11:00	0.0	0	0	0	0	1
11/02/2022 12:00	0.0	0	0	0	0	1
11/02/2022 13:00	0.0	0	0	0	0	1
11/02/2022 14:00	0.0	0	0	0	0	1
11/02/2022 15:00	0.0	0	0	0	0	1
11/02/2022 16:00	0.0	0	0	0	0	1
11/02/2022 17:00	0.0	0	0	0	0	1
11/02/2022 18:00	0.0	0	0	0	0	1
11/02/2022 19:00	0.0	0	0	0	0	1
11/02/2022 20:00	0.0	0	0	0	0	1
11/02/2022 21:00	0.0	0	0	0	0	1
11/02/2022 22:00	0.0	0	0	0	0	1
11/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2022 00:00	0.0	0	0	0	0	1
11/03/2022 01:00	0.0	0	0	0	0	1
11/03/2022 02:00	0.0	0	0	0	0	1
11/03/2022 03:00	0.0	0	0	0	0	1
11/03/2022 04:00	0.0	0	0	0	0	1
11/03/2022 05:00	0.0	0	0	0	0	1
11/03/2022 06:00	0.0	0	0	0	0	1
11/03/2022 07:00	0.0	0	0	0	0	1
11/03/2022 08:00	0.0	0	0	0	0	1
11/03/2022 09:00	0.0	0	0	0	0	1
11/03/2022 10:00	0.0	0	0	0	0	1
11/03/2022 11:00	0.0	0	0	0	0	1
11/03/2022 12:00	0.0	0	0	0	0	1
11/03/2022 13:00	0.0	0	0	0	0	1
11/03/2022 14:00	0.0	0	0	0	0	1
11/03/2022 15:00	0.0	0	0	0	0	1
11/03/2022 16:00	0.0	0	0	0	0	1
11/03/2022 17:00	0.0	0	0	0	0	1
11/03/2022 18:00	0.0	0	0	0	0	1
11/03/2022 19:00	0.0	0	0	0	0	1
11/03/2022 20:00	0.0	0	0	0	0	1
11/03/2022 21:00	0.0	0	0	0	0	1
11/03/2022 22:00	0.0	0	0	0	0	1
11/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2022 00:00	0.0	0	0	0	0	1
11/04/2022 01:00	0.0	0	0	0	0	1
11/04/2022 02:00	0.0	0	0	0	0	1
11/04/2022 03:00	0.0	0	0	0	0	1
11/04/2022 04:00	0.0	0	0	0	0	1
11/04/2022 05:00	0.0	0	0	0	0	1
11/04/2022 06:00	0.0	0	0	0	0	1
11/04/2022 07:00	0.0	0	0	0	0	1
11/04/2022 08:00	0.0	0	0	0	0	1
11/04/2022 09:00	0.0	0	0	0	0	1
11/04/2022 10:00	0.0	0	0	0	0	1
11/04/2022 11:00	0.0	0	0	0	0	1
11/04/2022 12:00	0.0	0	0	0	0	1
11/04/2022 13:00	0.0	0	0	0	0	1
11/04/2022 14:00	0.0	0	0	0	0	1
11/04/2022 15:00	0.0	0	0	0	0	1
11/04/2022 16:00	0.0	0	0	0	0	1
11/04/2022 17:00	0.0	0	0	0	0	1
11/04/2022 18:00	0.0	0	0	0	0	1
11/04/2022 19:00	0.0	0	0	0	0	1
11/04/2022 20:00	0.0	0	0	0	0	1
11/04/2022 21:00	0.0	0	0	0	0	1
11/04/2022 22:00	0.0	0	0	0	0	1
11/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2022 00:00	0.0	0	0	0	0	1
11/05/2022 01:00	0.0	0	0	0	0	1
11/05/2022 02:00	0.0	0	0	0	0	1
11/05/2022 03:00	0.0	0	0	0	0	1
11/05/2022 04:00	0.0	0	0	0	0	1
11/05/2022 05:00	0.0	0	0	0	0	1
11/05/2022 06:00	0.0	0	0	0	0	1
11/05/2022 07:00	1.8	0	0	0	1	0
11/05/2022 08:00	0.0	0	0	0	0	0
11/05/2022 09:00	0.0	0	0	0	0	0
11/05/2022 10:00	0.0	0	0	0	0	0
11/05/2022 11:00	0.0	0	0	0	0	0
11/05/2022 12:00	0.0	0	0	0	0	0
11/05/2022 13:00	0.0	0	0	0	0	0
11/05/2022 14:00	0.0	0	0	0	0	0
11/05/2022 15:00	0.0	0	0	0	0	0
11/05/2022 16:00	0.0	0	0	0	0	0
11/05/2022 17:00	0.0	0	0	0	0	0
11/05/2022 18:00	0.0	0	0	0	0	0
11/05/2022 19:00	0.0	0	0	0	0	0
11/05/2022 20:00	0.0	0	0	0	0	0
11/05/2022 21:00	0.0	0	0	0	0	0
11/05/2022 22:00	0.0	0	0	0	0	0
11/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2022 00:00	0.0	0	0	0	0	0
11/06/2022 01:00	0.0	0	0	0	0	0
11/06/2022 02:00	0.0	0	0	0	0	0
11/06/2022 03:00	0.0	0	0	0	0	0
11/06/2022 04:00	0.0	0	0	0	0	0
11/06/2022 05:00	0.0	0	0	0	0	0
11/06/2022 06:00	0.0	0	0	0	0	0
11/06/2022 07:00	0.0	0	0	0	0	0
11/06/2022 08:00	0.0	0	0	0	0	0
11/06/2022 09:00	15.5	0	1	0	0	0
11/06/2022 10:00	43.8	0	1	0	0	0
11/06/2022 11:00	40.4	0	1	0	0	0
11/06/2022 12:00	0.0	0	0	0	0	1
11/06/2022 13:00	0.0	0	0	0	0	1
11/06/2022 14:00	0.0	0	0	0	0	1
11/06/2022 15:00	0.0	0	0	0	0	1
11/06/2022 16:00	0.0	0	0	0	0	1
11/06/2022 17:00	0.0	0	0	0	0	1
11/06/2022 18:00	0.0	0	0	0	0	1
11/06/2022 19:00	0.0	0	0	0	0	1
11/06/2022 20:00	0.0	0	0	0	0	1
11/06/2022 21:00	0.8	0	0	0	1	0
11/06/2022 22:00	0.0	0	0	0	0	0
11/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	100.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2022 00:00	2.8	0	0	1	0	0
11/07/2022 01:00	29.6	0	0	1	0	0
11/07/2022 02:00	0.0	0	0	0	0	1
11/07/2022 03:00	0.0	0	0	0	0	1
11/07/2022 04:00	0.0	0	0	0	0	1
11/07/2022 05:00	0.0	0	0	0	0	1
11/07/2022 06:00	0.0	0	0	0	0	1
11/07/2022 07:00	0.0	0	0	0	0	1
11/07/2022 08:00	0.0	0	0	0	0	1
11/07/2022 09:00	0.0	0	0	0	0	1
11/07/2022 10:00	0.0	0	0	0	0	1
11/07/2022 11:00	0.0	0	0	0	0	1
11/07/2022 12:00	0.0	0	0	0	0	1
11/07/2022 13:00	0.0	0	0	0	0	1
11/07/2022 14:00	0.0	0	0	0	0	1
11/07/2022 15:00	0.0	0	0	0	0	1
11/07/2022 16:00	0.0	0	0	0	0	1
11/07/2022 17:00	0.0	0	0	0	0	1
11/07/2022 18:00	0.0	0	0	0	0	1
11/07/2022 19:00	0.0	0	0	0	0	1
11/07/2022 20:00	0.0	0	0	0	0	1
11/07/2022 21:00	0.0	0	0	0	0	1
11/07/2022 22:00	0.0	0	0	0	0	1
11/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.4 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2022 00:00	0.0	0	0	0	0	1
11/08/2022 01:00	0.0	0	0	0	0	1
11/08/2022 02:00	0.0	0	0	0	0	1
11/08/2022 03:00	0.0	0	0	0	0	1
11/08/2022 04:00	0.0	0	0	0	0	1
11/08/2022 05:00	0.0	0	0	0	0	1
11/08/2022 06:00	0.0	0	0	0	0	1
11/08/2022 07:00	0.0	0	0	0	0	1
11/08/2022 08:00	0.0	0	0	0	0	1
11/08/2022 09:00	0.0	0	0	0	0	1
11/08/2022 10:00	0.0	0	0	0	0	1
11/08/2022 11:00	0.0	0	0	0	0	1
11/08/2022 12:00	0.0	0	0	0	0	1
11/08/2022 13:00	0.0	0	0	0	0	1
11/08/2022 14:00	0.0	0	0	0	0	1
11/08/2022 15:00	0.0	0	0	0	0	1
11/08/2022 16:00	0.0	0	0	0	0	1
11/08/2022 17:00	0.0	0	0	0	0	1
11/08/2022 18:00	0.0	0	0	0	0	1
11/08/2022 19:00	0.0	0	0	0	0	1
11/08/2022 20:00	0.0	0	0	0	0	1
11/08/2022 21:00	0.0	0	0	0	0	1
11/08/2022 22:00	0.0	0	0	0	0	1
11/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2022 00:00	0.0	0	0	0	0	1
11/09/2022 01:00	0.0	0	0	0	0	1
11/09/2022 02:00	0.0	0	0	0	0	1
11/09/2022 03:00	0.0	0	0	0	0	1
11/09/2022 04:00	0.0	0	0	0	0	1
11/09/2022 05:00	0.0	0	0	0	0	1
11/09/2022 06:00	0.0	0	0	0	0	1
11/09/2022 07:00	0.0	0	0	0	0	1
11/09/2022 08:00	0.0	0	0	0	0	1
11/09/2022 09:00	0.0	0	0	0	0	1
11/09/2022 10:00	0.0	0	0	0	0	1
11/09/2022 11:00	0.0	0	0	0	0	1
11/09/2022 12:00	0.0	0	0	0	0	1
11/09/2022 13:00	0.0	0	0	0	0	1
11/09/2022 14:00	0.0	0	0	0	0	1
11/09/2022 15:00	0.0	0	0	0	0	1
11/09/2022 16:00	0.0	0	0	0	0	1
11/09/2022 17:00	0.0	0	0	0	0	1
11/09/2022 18:00	0.0	0	0	0	0	1
11/09/2022 19:00	0.0	0	0	0	0	1
11/09/2022 20:00	0.0	0	0	0	0	1
11/09/2022 21:00	0.0	0	0	0	0	1
11/09/2022 22:00	0.0	0	0	0	0	1
11/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2022 00:00	0.0	0	0	0	0	1
11/10/2022 01:00	0.0	0	0	0	0	1
11/10/2022 02:00	0.0	0	0	0	0	1
11/10/2022 03:00	0.0	0	0	0	0	1
11/10/2022 04:00	0.0	0	0	0	0	1
11/10/2022 05:00	0.0	0	0	0	0	1
11/10/2022 06:00	0.0	0	0	0	0	1
11/10/2022 07:00	0.0	0	0	0	0	1
11/10/2022 08:00	0.0	0	0	0	0	1
11/10/2022 09:00	0.0	0	0	0	0	1
11/10/2022 10:00	0.0	0	0	0	0	1
11/10/2022 11:00	0.0	0	0	0	0	1
11/10/2022 12:00	0.0	0	0	0	0	1
11/10/2022 13:00	0.0	0	0	0	0	1
11/10/2022 14:00	0.0	0	0	0	0	1
11/10/2022 15:00	0.0	0	0	0	0	1
11/10/2022 16:00	0.0	0	0	0	0	1
11/10/2022 17:00	0.0	0	0	0	0	1
11/10/2022 18:00	0.0	0	0	0	0	1
11/10/2022 19:00	0.0	0	0	0	0	1
11/10/2022 20:00	0.0	0	0	0	0	1
11/10/2022 21:00	0.0	0	0	0	0	1
11/10/2022 22:00	0.0	0	0	0	0	1
11/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2022 00:00	0.0	0	0	0	0	1
11/11/2022 01:00	0.0	0	0	0	0	1
11/11/2022 02:00	0.0	0	0	0	0	1
11/11/2022 03:00	0.0	0	0	0	0	1
11/11/2022 04:00	0.0	0	0	0	0	1
11/11/2022 05:00	0.0	0	0	0	0	1
11/11/2022 06:00	0.0	0	0	0	0	1
11/11/2022 07:00	0.0	0	0	0	0	1
11/11/2022 08:00	0.0	0	0	0	0	1
11/11/2022 09:00	0.0	0	0	0	0	1
11/11/2022 10:00	0.0	0	0	0	0	1
11/11/2022 11:00	0.0	0	0	0	0	1
11/11/2022 12:00	0.0	0	0	0	0	1
11/11/2022 13:00	0.0	0	0	0	0	1
11/11/2022 14:00	0.0	0	0	0	0	1
11/11/2022 15:00	0.0	0	0	0	0	1
11/11/2022 16:00	0.0	0	0	0	0	1
11/11/2022 17:00	0.0	0	0	0	0	1
11/11/2022 18:00	0.0	0	0	0	0	1
11/11/2022 19:00	0.0	0	0	0	0	1
11/11/2022 20:00	0.0	0	0	0	0	1
11/11/2022 21:00	0.0	0	0	0	0	1
11/11/2022 22:00	0.0	0	0	0	0	1
11/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2022 00:00	0.0	0	0	0	0	1
11/12/2022 01:00	0.0	0	0	0	0	1
11/12/2022 02:00	0.0	0	0	0	0	1
11/12/2022 03:00	0.0	0	0	0	0	1
11/12/2022 04:00	0.0	0	0	0	0	1
11/12/2022 05:00	0.0	0	0	0	0	1
11/12/2022 06:00	0.0	0	0	0	0	1
11/12/2022 07:00	0.0	0	0	0	0	1
11/12/2022 08:00	0.0	0	0	0	0	1
11/12/2022 09:00	0.0	0	0	0	0	1
11/12/2022 10:00	0.0	0	0	0	0	1
11/12/2022 11:00	0.0	0	0	0	0	1
11/12/2022 12:00	0.0	0	0	0	0	1
11/12/2022 13:00	0.0	0	0	0	0	1
11/12/2022 14:00	0.0	0	0	0	0	1
11/12/2022 15:00	0.0	0	0	0	0	1
11/12/2022 16:00	0.0	0	0	0	0	1
11/12/2022 17:00	0.0	0	0	0	0	1
11/12/2022 18:00	0.0	0	0	0	0	1
11/12/2022 19:00	0.0	0	0	0	0	1
11/12/2022 20:00	0.0	0	0	0	0	1
11/12/2022 21:00	0.0	0	0	0	0	1
11/12/2022 22:00	0.0	0	0	0	0	1
11/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2022 00:00	0.0	0	0	0	0	1
11/13/2022 01:00	0.0	0	0	0	0	1
11/13/2022 02:00	0.0	0	0	0	0	1
11/13/2022 03:00	0.0	0	0	0	0	1
11/13/2022 04:00	0.0	0	0	0	0	1
11/13/2022 05:00	0.0	0	0	0	0	1
11/13/2022 06:00	0.0	0	0	0	0	1
11/13/2022 07:00	0.0	0	0	0	0	1
11/13/2022 08:00	0.0	0	0	0	0	1
11/13/2022 09:00	0.0	0	0	0	0	1
11/13/2022 10:00	0.0	0	0	0	0	1
11/13/2022 11:00	0.0	0	0	0	0	1
11/13/2022 12:00	0.0	0	0	0	0	1
11/13/2022 13:00	0.0	0	0	0	0	1
11/13/2022 14:00	0.0	0	0	0	0	1
11/13/2022 15:00	0.0	0	0	0	0	1
11/13/2022 16:00	0.0	0	0	0	0	1
11/13/2022 17:00	0.0	0	0	0	0	1
11/13/2022 18:00	0.0	0	0	0	0	1
11/13/2022 19:00	0.0	0	0	0	0	1
11/13/2022 20:00	0.0	0	0	0	0	1
11/13/2022 21:00	0.0	0	0	0	0	1
11/13/2022 22:00	0.0	0	0	0	0	1
11/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2022 00:00	0.0	0	0	0	0	1
11/14/2022 01:00	0.0	0	0	0	0	1
11/14/2022 02:00	0.0	0	0	0	0	1
11/14/2022 03:00	0.0	0	0	0	0	1
11/14/2022 04:00	0.0	0	0	0	0	1
11/14/2022 05:00	0.0	0	0	0	0	1
11/14/2022 06:00	0.0	0	0	0	0	1
11/14/2022 07:00	0.0	0	0	0	0	1
11/14/2022 08:00	0.0	0	0	0	0	1
11/14/2022 09:00	0.0	0	0	0	0	1
11/14/2022 10:00	0.0	0	0	0	0	1
11/14/2022 11:00	0.0	0	0	0	0	1
11/14/2022 12:00	0.0	0	0	0	0	1
11/14/2022 13:00	0.0	0	0	0	0	1
11/14/2022 14:00	0.0	0	0	0	0	1
11/14/2022 15:00	0.0	0	0	0	0	1
11/14/2022 16:00	0.0	0	0	0	0	1
11/14/2022 17:00	0.0	0	0	0	0	1
11/14/2022 18:00	0.0	0	0	0	0	1
11/14/2022 19:00	0.0	0	0	0	0	1
11/14/2022 20:00	0.0	0	0	0	0	1
11/14/2022 21:00	0.0	0	0	0	0	1
11/14/2022 22:00	0.0	0	0	0	0	1
11/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2022 00:00	0.0	0	0	0	0	1
11/15/2022 01:00	0.0	0	0	0	0	1
11/15/2022 02:00	0.0	0	0	0	0	1
11/15/2022 03:00	0.0	0	0	0	0	1
11/15/2022 04:00	0.0	0	0	0	0	1
11/15/2022 05:00	0.0	0	0	0	0	1
11/15/2022 06:00	0.0	0	0	0	0	1
11/15/2022 07:00	0.0	0	0	0	0	1
11/15/2022 08:00	0.0	0	0	0	0	1
11/15/2022 09:00	0.0	0	0	0	0	1
11/15/2022 10:00	0.0	0	0	0	0	1
11/15/2022 11:00	0.0	0	0	0	0	1
11/15/2022 12:00	0.0	0	0	0	0	1
11/15/2022 13:00	0.0	0	0	0	0	1
11/15/2022 14:00	0.0	0	0	0	0	1
11/15/2022 15:00	0.0	0	0	0	0	1
11/15/2022 16:00	0.0	0	0	0	0	1
11/15/2022 17:00	0.0	0	0	0	0	1
11/15/2022 18:00	0.0	0	0	0	0	1
11/15/2022 19:00	0.0	0	0	0	0	1
11/15/2022 20:00	0.0	0	0	0	0	1
11/15/2022 21:00	0.0	0	0	0	0	1
11/15/2022 22:00	0.0	0	0	0	0	1
11/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2022 00:00	0.0	0	0	0	0	1
11/16/2022 01:00	0.0	0	0	0	0	1
11/16/2022 02:00	0.0	0	0	0	0	1
11/16/2022 03:00	0.0	0	0	0	0	1
11/16/2022 04:00	0.0	0	0	0	0	1
11/16/2022 05:00	0.0	0	0	0	0	1
11/16/2022 06:00	0.0	0	0	0	0	1
11/16/2022 07:00	0.0	0	0	0	0	1
11/16/2022 08:00	0.0	0	0	0	0	1
11/16/2022 09:00	0.0	0	0	0	0	1
11/16/2022 10:00	0.0	0	0	0	0	1
11/16/2022 11:00	0.0	0	0	0	0	1
11/16/2022 12:00	0.0	0	0	0	0	1
11/16/2022 13:00	0.0	0	0	0	0	1
11/16/2022 14:00	0.0	0	0	0	0	1
11/16/2022 15:00	0.0	0	0	0	0	1
11/16/2022 16:00	0.0	0	0	0	0	1
11/16/2022 17:00	0.0	0	0	0	0	1
11/16/2022 18:00	0.0	0	0	0	0	1
11/16/2022 19:00	0.0	0	0	0	0	1
11/16/2022 20:00	0.0	0	0	0	0	1
11/16/2022 21:00	0.0	0	0	0	0	1
11/16/2022 22:00	0.0	0	0	0	0	1
11/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2022 00:00	0.0	0	0	0	0	1
11/17/2022 01:00	0.0	0	0	0	0	1
11/17/2022 02:00	0.0	0	0	0	0	1
11/17/2022 03:00	0.0	0	0	0	0	1
11/17/2022 04:00	0.0	0	0	0	0	1
11/17/2022 05:00	0.0	0	0	0	0	1
11/17/2022 06:00	0.0	0	0	0	0	1
11/17/2022 07:00	0.0	0	0	0	0	1
11/17/2022 08:00	0.0	0	0	0	0	1
11/17/2022 09:00	0.0	0	0	0	0	1
11/17/2022 10:00	0.0	0	0	0	0	1
11/17/2022 11:00	0.0	0	0	0	0	1
11/17/2022 12:00	0.0	0	0	0	0	1
11/17/2022 13:00	0.0	0	0	0	0	1
11/17/2022 14:00	0.0	0	0	0	0	1
11/17/2022 15:00	0.0	0	0	0	0	1
11/17/2022 16:00	0.0	0	0	0	0	1
11/17/2022 17:00	0.0	0	0	0	0	1
11/17/2022 18:00	0.0	0	0	0	0	1
11/17/2022 19:00	0.0	0	0	0	0	1
11/17/2022 20:00	0.0	0	0	0	0	1
11/17/2022 21:00	0.0	0	0	0	0	1
11/17/2022 22:00	0.0	0	0	0	0	1
11/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2022 00:00	0.0	0	0	0	0	1
11/18/2022 01:00	0.0	0	0	0	0	1
11/18/2022 02:00	0.0	0	0	0	0	1
11/18/2022 03:00	0.0	0	0	0	0	1
11/18/2022 04:00	0.0	0	0	0	0	1
11/18/2022 05:00	0.0	0	0	0	0	1
11/18/2022 06:00	0.0	0	0	0	0	1
11/18/2022 07:00	0.0	0	0	0	0	1
11/18/2022 08:00	0.0	0	0	0	0	1
11/18/2022 09:00	0.0	0	0	0	0	1
11/18/2022 10:00	0.0	0	0	0	0	1
11/18/2022 11:00	0.0	0	0	0	0	1
11/18/2022 12:00	0.0	0	0	0	0	1
11/18/2022 13:00	0.0	0	0	0	0	1
11/18/2022 14:00	0.0	0	0	0	0	1
11/18/2022 15:00	0.0	0	0	0	0	1
11/18/2022 16:00	0.0	0	0	0	0	1
11/18/2022 17:00	0.0	0	0	0	0	1
11/18/2022 18:00	0.0	0	0	0	0	1
11/18/2022 19:00	0.0	0	0	0	0	1
11/18/2022 20:00	0.0	0	0	0	0	1
11/18/2022 21:00	0.0	0	0	0	0	1
11/18/2022 22:00	0.0	0	0	0	0	1
11/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2022 00:00	0.0	0	0	0	0	1
11/19/2022 01:00	0.0	0	0	0	0	1
11/19/2022 02:00	0.0	0	0	0	0	1
11/19/2022 03:00	0.0	0	0	0	0	1
11/19/2022 04:00	0.0	0	0	0	0	1
11/19/2022 05:00	0.0	0	0	0	0	1
11/19/2022 06:00	0.0	0	0	0	0	1
11/19/2022 07:00	0.0	0	0	0	0	1
11/19/2022 08:00	0.0	0	0	0	0	1
11/19/2022 09:00	0.0	0	0	0	0	1
11/19/2022 10:00	0.0	0	0	0	0	1
11/19/2022 11:00	0.0	0	0	0	0	1
11/19/2022 12:00	0.0	0	0	0	0	1
11/19/2022 13:00	0.0	0	0	0	0	1
11/19/2022 14:00	0.0	0	0	0	0	1
11/19/2022 15:00	0.0	0	0	0	0	1
11/19/2022 16:00	0.0	0	0	0	0	1
11/19/2022 17:00	0.0	0	0	0	0	1
11/19/2022 18:00	0.0	0	0	0	0	1
11/19/2022 19:00	0.0	0	0	0	0	1
11/19/2022 20:00	0.0	0	0	0	0	1
11/19/2022 21:00	0.0	0	0	0	0	1
11/19/2022 22:00	0.0	0	0	0	0	1
11/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2022 00:00	0.0	0	0	0	0	1
11/20/2022 01:00	0.0	0	0	0	0	1
11/20/2022 02:00	0.0	0	0	0	0	1
11/20/2022 03:00	0.0	0	0	0	0	1
11/20/2022 04:00	0.0	0	0	0	0	1
11/20/2022 05:00	0.0	0	0	0	0	1
11/20/2022 06:00	0.0	0	0	0	0	1
11/20/2022 07:00	0.0	0	0	0	0	1
11/20/2022 08:00	0.0	0	0	0	0	1
11/20/2022 09:00	0.0	0	0	0	0	1
11/20/2022 10:00	0.0	0	0	0	0	1
11/20/2022 11:00	0.0	0	0	0	0	1
11/20/2022 12:00	0.0	0	0	0	0	1
11/20/2022 13:00	0.0	0	0	0	0	1
11/20/2022 14:00	0.0	0	0	0	0	1
11/20/2022 15:00	0.0	0	0	0	0	1
11/20/2022 16:00	0.0	0	0	0	0	1
11/20/2022 17:00	0.0	0	0	0	0	1
11/20/2022 18:00	0.0	0	0	0	0	1
11/20/2022 19:00	0.0	0	0	0	0	1
11/20/2022 20:00	0.0	0	0	0	0	1
11/20/2022 21:00	0.0	0	0	0	0	1
11/20/2022 22:00	0.0	0	0	0	0	1
11/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2022 00:00	0.0	0	0	0	0	1
11/21/2022 01:00	0.0	0	0	0	0	1
11/21/2022 02:00	0.0	0	0	0	0	1
11/21/2022 03:00	0.0	0	0	0	0	1
11/21/2022 04:00	0.0	0	0	0	0	1
11/21/2022 05:00	0.0	0	0	0	0	1
11/21/2022 06:00	0.0	0	0	0	0	1
11/21/2022 07:00	0.0	0	0	0	0	1
11/21/2022 08:00	0.0	0	0	0	0	1
11/21/2022 09:00	0.0	0	0	0	0	1
11/21/2022 10:00	0.0	0	0	0	0	1
11/21/2022 11:00	0.0	0	0	0	0	1
11/21/2022 12:00	0.0	0	0	0	0	1
11/21/2022 13:00	0.0	0	0	0	0	1
11/21/2022 14:00	0.0	0	0	0	0	1
11/21/2022 15:00	0.0	0	0	0	0	1
11/21/2022 16:00	0.0	0	0	0	0	1
11/21/2022 17:00	0.0	0	0	0	0	1
11/21/2022 18:00	0.0	0	0	0	0	1
11/21/2022 19:00	0.0	0	0	0	0	1
11/21/2022 20:00	0.0	0	0	0	0	1
11/21/2022 21:00	0.0	0	0	0	0	1
11/21/2022 22:00	0.0	0	0	0	0	1
11/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2022 00:00	0.0	0	0	0	0	1
11/22/2022 01:00	0.0	0	0	0	0	1
11/22/2022 02:00	0.0	0	0	0	0	1
11/22/2022 03:00	0.0	0	0	0	0	1
11/22/2022 04:00	0.0	0	0	0	0	1
11/22/2022 05:00	0.0	0	0	0	0	1
11/22/2022 06:00	0.0	0	0	0	0	1
11/22/2022 07:00	0.0	0	0	0	0	1
11/22/2022 08:00	0.0	0	0	0	0	1
11/22/2022 09:00	0.0	0	0	0	0	1
11/22/2022 10:00	0.0	0	0	0	0	1
11/22/2022 11:00	0.0	0	0	0	0	1
11/22/2022 12:00	0.0	0	0	0	0	1
11/22/2022 13:00	0.0	0	0	0	0	1
11/22/2022 14:00	0.0	0	0	0	0	1
11/22/2022 15:00	0.0	0	0	0	0	1
11/22/2022 16:00	0.0	0	0	0	0	1
11/22/2022 17:00	0.0	0	0	0	0	1
11/22/2022 18:00	0.0	0	0	0	0	1
11/22/2022 19:00	0.0	0	0	0	0	1
11/22/2022 20:00	0.0	0	0	0	0	1
11/22/2022 21:00	0.0	0	0	0	0	1
11/22/2022 22:00	0.0	0	0	0	0	1
11/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2022 00:00	0.0	0	0	0	0	1
11/23/2022 01:00	0.0	0	0	0	0	1
11/23/2022 02:00	0.0	0	0	0	0	1
11/23/2022 03:00	0.0	0	0	0	0	1
11/23/2022 04:00	0.0	0	0	0	0	1
11/23/2022 05:00	0.0	0	0	0	0	1
11/23/2022 06:00	0.0	0	0	0	0	1
11/23/2022 07:00	0.0	0	0	0	0	1
11/23/2022 08:00	0.0	0	0	0	0	1
11/23/2022 09:00	0.0	0	0	0	0	1
11/23/2022 10:00	0.0	0	0	0	0	1
11/23/2022 11:00	0.0	0	0	0	0	1
11/23/2022 12:00	0.0	0	0	0	0	1
11/23/2022 13:00	0.0	0	0	0	0	1
11/23/2022 14:00	0.0	0	0	0	0	1
11/23/2022 15:00	0.0	0	0	0	0	1
11/23/2022 16:00	0.0	0	0	0	0	1
11/23/2022 17:00	0.0	0	0	0	0	1
11/23/2022 18:00	0.0	0	0	0	0	1
11/23/2022 19:00	0.0	0	0	0	0	1
11/23/2022 20:00	0.0	0	0	0	0	1
11/23/2022 21:00	0.0	0	0	0	0	1
11/23/2022 22:00	0.0	0	0	0	0	1
11/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2022 00:00	0.0	0	0	0	0	1
11/24/2022 01:00	0.0	0	0	0	0	1
11/24/2022 02:00	0.0	0	0	0	0	1
11/24/2022 03:00	0.0	0	0	0	0	1
11/24/2022 04:00	0.0	0	0	0	0	1
11/24/2022 05:00	0.0	0	0	0	0	1
11/24/2022 06:00	0.0	0	0	0	0	1
11/24/2022 07:00	0.0	0	0	0	0	1
11/24/2022 08:00	0.0	0	0	0	0	1
11/24/2022 09:00	0.0	0	0	0	0	1
11/24/2022 10:00	0.0	0	0	0	0	1
11/24/2022 11:00	0.0	0	0	0	0	1
11/24/2022 12:00	0.0	0	0	0	0	1
11/24/2022 13:00	0.0	0	0	0	0	1
11/24/2022 14:00	0.0	0	0	0	0	1
11/24/2022 15:00	0.0	0	0	0	0	1
11/24/2022 16:00	0.0	0	0	0	0	1
11/24/2022 17:00	0.0	0	0	0	0	1
11/24/2022 18:00	0.0	0	0	0	0	1
11/24/2022 19:00	0.0	0	0	0	0	1
11/24/2022 20:00	0.0	0	0	0	0	1
11/24/2022 21:00	0.0	0	0	0	0	1
11/24/2022 22:00	0.0	0	0	0	0	1
11/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2022 00:00	0.0	0	0	0	0	1
11/25/2022 01:00	0.0	0	0	0	0	1
11/25/2022 02:00	0.0	0	0	0	0	1
11/25/2022 03:00	0.0	0	0	0	0	1
11/25/2022 04:00	0.0	0	0	0	0	1
11/25/2022 05:00	0.0	0	0	0	0	1
11/25/2022 06:00	0.0	0	0	0	0	1
11/25/2022 07:00	0.0	0	0	0	0	1
11/25/2022 08:00	0.0	0	0	0	0	1
11/25/2022 09:00	0.0	0	0	0	0	1
11/25/2022 10:00	0.0	0	0	0	0	1
11/25/2022 11:00	0.0	0	0	0	0	1
11/25/2022 12:00	0.0	0	0	0	0	1
11/25/2022 13:00	0.0	0	0	0	0	1
11/25/2022 14:00	0.0	0	0	0	0	1
11/25/2022 15:00	0.0	0	0	0	0	1
11/25/2022 16:00	0.0	0	0	0	0	1
11/25/2022 17:00	0.0	0	0	0	0	1
11/25/2022 18:00	0.0	0	0	0	0	1
11/25/2022 19:00	0.0	0	0	0	0	1
11/25/2022 20:00	0.0	0	0	0	0	1
11/25/2022 21:00	0.0	0	0	0	0	1
11/25/2022 22:00	0.0	0	0	0	0	1
11/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2022 00:00	0.0	0	0	0	0	1
11/26/2022 01:00	0.0	0	0	0	0	1
11/26/2022 02:00	1.1	0	0	0	1	0
11/26/2022 03:00	0.0	0	0	0	0	0
11/26/2022 04:00	0.0	0	0	0	0	0
11/26/2022 05:00	0.0	0	0	0	0	0
11/26/2022 06:00	0.0	0	0	0	0	0
11/26/2022 07:00	0.0	0	0	0	0	0
11/26/2022 08:00	0.0	0	0	0	0	0
11/26/2022 09:00	0.0	0	0	0	0	0
11/26/2022 10:00	0.0	0	0	0	0	0
11/26/2022 11:00	0.0	0	0	0	0	0
11/26/2022 12:00	0.0	0	0	0	0	0
11/26/2022 13:00	0.0	0	0	0	0	0
11/26/2022 14:00	0.0	0	0	0	0	0
11/26/2022 15:00	0.0	0	0	0	0	0
11/26/2022 16:00	0.0	0	0	0	0	0
11/26/2022 17:00	0.0	0	0	0	0	0
11/26/2022 18:00	0.0	0	0	0	0	0
11/26/2022 19:00	0.0	0	0	0	0	0
11/26/2022 20:00	0.0	0	0	0	0	0
11/26/2022 21:00	0.0	0	0	0	0	0
11/26/2022 22:00	0.0	0	0	0	0	0
11/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2022 00:00	0.0	0	0	0	0	0
11/27/2022 01:00	0.0	0	0	0	0	0
11/27/2022 02:00	0.0	0	0	0	0	0
11/27/2022 03:00	0.0	0	0	0	0	0
11/27/2022 04:00	0.0	0	0	0	0	0
11/27/2022 05:00	0.0	0	0	0	0	0
11/27/2022 06:00	0.0	0	0	0	0	0
11/27/2022 07:00	0.0	0	0	0	0	0
11/27/2022 08:00	0.0	0	0	0	0	0
11/27/2022 09:00	0.0	0	0	0	0	0
11/27/2022 10:00	0.0	0	0	0	0	0
11/27/2022 11:00	0.0	0	0	0	0	0
11/27/2022 12:00	0.0	0	0	0	0	0
11/27/2022 13:00	0.0	0	0	0	0	0
11/27/2022 14:00	0.0	0	0	0	0	0
11/27/2022 15:00	0.0	0	0	0	0	0
11/27/2022 16:00	0.0	0	0	0	0	0
11/27/2022 17:00	0.0	0	0	0	0	0
11/27/2022 18:00	0.0	0	0	0	0	0
11/27/2022 19:00	0.0	0	0	0	0	0
11/27/2022 20:00	0.0	0	0	0	0	0
11/27/2022 21:00	47.2	0	1	0	0	0
11/27/2022 22:00	34.9	0	1	0	0	0
11/27/2022 23:00	39.9	0	1	0	0	0
Average/Sum#:	122.0 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.2	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2022 00:00	0.0	0	0	0	0	1
11/28/2022 01:00	0.0	0	0	0	0	1
11/28/2022 02:00	0.0	0	0	0	0	1
11/28/2022 03:00	0.0	0	0	0	0	1
11/28/2022 04:00	0.0	0	0	0	0	1
11/28/2022 05:00	0.0	0	0	0	0	1
11/28/2022 06:00	0.0	0	0	0	0	1
11/28/2022 07:00	0.0	0	0	0	0	1
11/28/2022 08:00	0.0	0	0	0	0	1
11/28/2022 09:00	0.0	0	0	0	0	1
11/28/2022 10:00	0.0	0	0	0	0	1
11/28/2022 11:00	0.0	0	0	0	0	1
11/28/2022 12:00	0.0	0	0	0	0	1
11/28/2022 13:00	0.0	0	0	0	0	1
11/28/2022 14:00	0.0	0	0	0	0	1
11/28/2022 15:00	0.0	0	0	0	0	1
11/28/2022 16:00	0.0	0	0	0	0	1
11/28/2022 17:00	0.0	0	0	0	0	1
11/28/2022 18:00	0.0	0	0	0	0	1
11/28/2022 19:00	0.0	0	0	0	0	1
11/28/2022 20:00	0.0	0	0	0	0	1
11/28/2022 21:00	0.0	0	0	0	0	1
11/28/2022 22:00	0.0	0	0	0	0	1
11/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2022 00:00	0.0	0	0	0	0	1
11/29/2022 01:00	0.0	0	0	0	0	1
11/29/2022 02:00	0.0	0	0	0	0	1
11/29/2022 03:00	0.0	0	0	0	0	1
11/29/2022 04:00	0.0	0	0	0	0	1
11/29/2022 05:00	0.0	0	0	0	0	1
11/29/2022 06:00	0.0	0	0	0	0	1
11/29/2022 07:00	0.0	0	0	0	0	1
11/29/2022 08:00	0.0	0	0	0	0	1
11/29/2022 09:00	0.0	0	0	0	0	1
11/29/2022 10:00	0.0	0	0	0	0	1
11/29/2022 11:00	0.0	0	0	0	0	1
11/29/2022 12:00	0.0	0	0	0	0	1
11/29/2022 13:00	0.0	0	0	0	0	1
11/29/2022 14:00	0.0	0	0	0	0	1
11/29/2022 15:00	0.0	0	0	0	0	1
11/29/2022 16:00	0.0	0	0	0	0	1
11/29/2022 17:00	0.0	0	0	0	0	1
11/29/2022 18:00	0.0	0	0	0	0	1
11/29/2022 19:00	0.0	0	0	0	0	1
11/29/2022 20:00	0.0	0	0	0	0	1
11/29/2022 21:00	0.0	0	0	0	0	1
11/29/2022 22:00	0.0	0	0	0	0	1
11/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2022 00:00	0.0	0	0	0	0	1
11/30/2022 01:00	0.0	0	0	0	0	1
11/30/2022 02:00	0.0	0	0	0	0	1
11/30/2022 03:00	0.0	0	0	0	0	1
11/30/2022 04:00	0.0	0	0	0	0	1
11/30/2022 05:00	0.0	0	0	0	0	1
11/30/2022 06:00	0.0	0	0	0	0	1
11/30/2022 07:00	0.0	0	0	0	0	1
11/30/2022 08:00	0.0	0	0	0	0	1
11/30/2022 09:00	0.0	0	0	0	0	1
11/30/2022 10:00	0.0	0	0	0	0	1
11/30/2022 11:00	0.0	0	0	0	0	1
11/30/2022 12:00	0.0	0	0	0	0	1
11/30/2022 13:00	0.0	0	0	0	0	1
11/30/2022 14:00	0.0	0	0	0	0	1
11/30/2022 15:00	0.0	0	0	0	0	1
11/30/2022 16:00	0.0	0	0	0	0	1
11/30/2022 17:00	0.0	0	0	0	0	1
11/30/2022 18:00	0.0	0	0	0	0	1
11/30/2022 19:00	0.0	0	0	0	0	1
11/30/2022 20:00	0.0	0	0	0	0	1
11/30/2022 21:00	0.0	0	0	0	0	1
11/30/2022 22:00	0.0	0	0	0	0	1
11/30/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2022 00:00	0.0	0	0	0	0	0
12/01/2022 01:00	0.0	0	0	0	0	0
12/01/2022 02:00	2.4	0	0	1	0	0
12/01/2022 03:00	17.2	0	0	1	0	0
12/01/2022 04:00	0.0	0	0	0	0	1
12/01/2022 05:00	0.0	0	0	0	0	1
12/01/2022 06:00	0.0	0	0	0	0	1
12/01/2022 07:00	0.0	0	0	0	0	1
12/01/2022 08:00	0.0	0	0	0	0	1
12/01/2022 09:00	0.0	0	0	0	0	1
12/01/2022 10:00	0.0	0	0	0	0	1
12/01/2022 11:00	0.0	0	0	0	0	1
12/01/2022 12:00	0.0	0	0	0	0	1
12/01/2022 13:00	0.0	0	0	0	0	1
12/01/2022 14:00	0.0	0	0	0	0	1
12/01/2022 15:00	0.0	0	0	0	0	1
12/01/2022 16:00	0.0	0	0	0	0	1
12/01/2022 17:00	0.0	0	0	0	0	1
12/01/2022 18:00	0.0	0	0	0	0	1
12/01/2022 19:00	0.0	0	0	0	0	1
12/01/2022 20:00	0.0	0	0	0	0	1
12/01/2022 21:00	0.0	0	0	0	0	1
12/01/2022 22:00	0.0	0	0	0	0	1
12/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	19.6 #	0 #	0 #	2 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.2	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2022 00:00	0.0	0	0	0	0	1
12/02/2022 01:00	0.0	0	0	0	0	1
12/02/2022 02:00	0.0	0	0	0	0	1
12/02/2022 03:00	0.0	0	0	0	0	1
12/02/2022 04:00	0.0	0	0	0	0	1
12/02/2022 05:00	0.0	0	0	0	0	1
12/02/2022 06:00	0.0	0	0	0	0	1
12/02/2022 07:00	0.0	0	0	0	0	1
12/02/2022 08:00	0.0	0	0	0	0	1
12/02/2022 09:00	0.0	0	0	0	0	1
12/02/2022 10:00	0.0	0	0	0	0	1
12/02/2022 11:00	0.0	0	0	0	0	1
12/02/2022 12:00	0.0	0	0	0	0	1
12/02/2022 13:00	0.0	0	0	0	0	1
12/02/2022 14:00	0.0	0	0	0	0	1
12/02/2022 15:00	0.0	0	0	0	0	1
12/02/2022 16:00	0.0	0	0	0	0	1
12/02/2022 17:00	0.0	0	0	0	0	1
12/02/2022 18:00	0.0	0	0	0	0	1
12/02/2022 19:00	0.0	0	0	0	0	1
12/02/2022 20:00	0.0	0	0	0	0	1
12/02/2022 21:00	0.0	0	0	0	0	1
12/02/2022 22:00	0.0	0	0	0	0	1
12/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2022 00:00	0.0	0	0	0	0	1
12/03/2022 01:00	0.0	0	0	0	0	1
12/03/2022 02:00	0.0	0	0	0	0	1
12/03/2022 03:00	0.0	0	0	0	0	1
12/03/2022 04:00	0.0	0	0	0	0	1
12/03/2022 05:00	0.0	0	0	0	0	1
12/03/2022 06:00	0.0	0	0	0	0	1
12/03/2022 07:00	0.0	0	0	0	0	1
12/03/2022 08:00	0.0	0	0	0	0	1
12/03/2022 09:00	0.0	0	0	0	0	1
12/03/2022 10:00	0.0	0	0	0	0	1
12/03/2022 11:00	0.0	0	0	0	0	1
12/03/2022 12:00	0.0	0	0	0	0	1
12/03/2022 13:00	0.0	0	0	0	0	1
12/03/2022 14:00	0.0	0	0	0	0	1
12/03/2022 15:00	0.0	0	0	0	0	1
12/03/2022 16:00	0.0	0	0	0	0	1
12/03/2022 17:00	0.0	0	0	0	0	1
12/03/2022 18:00	0.0	0	0	0	0	1
12/03/2022 19:00	0.0	0	0	0	0	1
12/03/2022 20:00	0.0	0	0	0	0	1
12/03/2022 21:00	0.0	0	0	0	0	1
12/03/2022 22:00	0.0	0	0	0	0	1
12/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2022 00:00	0.0	0	0	0	0	1
12/04/2022 01:00	0.0	0	0	0	0	1
12/04/2022 02:00	0.0	0	0	0	0	1
12/04/2022 03:00	0.0	0	0	0	0	1
12/04/2022 04:00	0.0	0	0	0	0	1
12/04/2022 05:00	0.0	0	0	0	0	1
12/04/2022 06:00	0.0	0	0	0	0	1
12/04/2022 07:00	0.0	0	0	0	0	1
12/04/2022 08:00	0.0	0	0	0	0	1
12/04/2022 09:00	0.0	0	0	0	0	1
12/04/2022 10:00	0.0	0	0	0	0	1
12/04/2022 11:00	0.0	0	0	0	0	1
12/04/2022 12:00	0.0	0	0	0	0	1
12/04/2022 13:00	0.0	0	0	0	0	1
12/04/2022 14:00	0.0	0	0	0	0	1
12/04/2022 15:00	0.0	0	0	0	0	1
12/04/2022 16:00	0.0	0	0	0	0	1
12/04/2022 17:00	0.0	0	0	0	0	1
12/04/2022 18:00	0.0	0	0	0	0	1
12/04/2022 19:00	0.0	0	0	0	0	1
12/04/2022 20:00	0.0	0	0	0	0	1
12/04/2022 21:00	0.0	0	0	0	0	1
12/04/2022 22:00	0.0	0	0	0	0	1
12/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2022 00:00	0.0	0	0	0	0	1
12/05/2022 01:00	0.0	0	0	0	0	1
12/05/2022 02:00	0.0	0	0	0	0	1
12/05/2022 03:00	0.0	0	0	0	0	1
12/05/2022 04:00	0.0	0	0	0	0	1
12/05/2022 05:00	0.0	0	0	0	0	1
12/05/2022 06:00	0.0	0	0	0	0	1
12/05/2022 07:00	0.0	0	0	0	0	1
12/05/2022 08:00	0.0	0	0	0	0	1
12/05/2022 09:00	0.0	0	0	0	0	1
12/05/2022 10:00	0.0	0	0	0	0	1
12/05/2022 11:00	0.0	0	0	0	0	1
12/05/2022 12:00	0.0	0	0	0	0	1
12/05/2022 13:00	0.0	0	0	0	0	1
12/05/2022 14:00	0.0	0	0	0	0	1
12/05/2022 15:00	0.0	0	0	0	0	1
12/05/2022 16:00	0.0	0	0	0	0	1
12/05/2022 17:00	0.0	0	0	0	0	1
12/05/2022 18:00	0.0	0	0	0	0	1
12/05/2022 19:00	0.0	0	0	0	0	1
12/05/2022 20:00	0.0	0	0	0	0	1
12/05/2022 21:00	0.0	0	0	0	0	1
12/05/2022 22:00	0.0	0	0	0	0	1
12/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2022 00:00	0.0	0	0	0	0	1
12/06/2022 01:00	0.0	0	0	0	0	1
12/06/2022 02:00	0.0	0	0	0	0	1
12/06/2022 03:00	0.0	0	0	0	0	1
12/06/2022 04:00	0.0	0	0	0	0	1
12/06/2022 05:00	0.0	0	0	0	0	1
12/06/2022 06:00	0.0	0	0	0	0	1
12/06/2022 07:00	0.0	0	0	0	0	1
12/06/2022 08:00	0.0	0	0	0	0	1
12/06/2022 09:00	0.0	0	0	0	0	1
12/06/2022 10:00	0.0	0	0	0	0	1
12/06/2022 11:00	0.0	0	0	0	0	1
12/06/2022 12:00	0.0	0	0	0	0	1
12/06/2022 13:00	0.0	0	0	0	0	1
12/06/2022 14:00	0.0	0	0	0	0	1
12/06/2022 15:00	0.0	0	0	0	0	1
12/06/2022 16:00	0.0	0	0	0	0	1
12/06/2022 17:00	0.0	0	0	0	0	1
12/06/2022 18:00	0.0	0	0	0	0	1
12/06/2022 19:00	0.0	0	0	0	0	1
12/06/2022 20:00	0.0	0	0	0	0	1
12/06/2022 21:00	0.0	0	0	0	0	1
12/06/2022 22:00	0.0	0	0	0	0	1
12/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2022 00:00	0.0	0	0	0	0	1
12/07/2022 01:00	0.0	0	0	0	0	1
12/07/2022 02:00	0.0	0	0	0	0	1
12/07/2022 03:00	0.0	0	0	0	0	1
12/07/2022 04:00	0.0	0	0	0	0	1
12/07/2022 05:00	0.0	0	0	0	0	1
12/07/2022 06:00	0.0	0	0	0	0	1
12/07/2022 07:00	0.0	0	0	0	0	1
12/07/2022 08:00	0.0	0	0	0	0	1
12/07/2022 09:00	0.0	0	0	0	0	1
12/07/2022 10:00	0.0	0	0	0	0	1
12/07/2022 11:00	0.0	0	0	0	0	1
12/07/2022 12:00	0.0	0	0	0	0	1
12/07/2022 13:00	0.0	0	0	0	0	1
12/07/2022 14:00	0.0	0	0	0	0	1
12/07/2022 15:00	0.0	0	0	0	0	1
12/07/2022 16:00	0.0	0	0	0	0	1
12/07/2022 17:00	0.0	0	0	0	0	1
12/07/2022 18:00	0.0	0	0	0	0	1
12/07/2022 19:00	0.0	0	0	0	0	1
12/07/2022 20:00	0.0	0	0	0	0	1
12/07/2022 21:00	0.0	0	0	0	0	1
12/07/2022 22:00	0.0	0	0	0	0	1
12/07/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2022 00:00	0.0	0	0	0	0	1
12/08/2022 01:00	0.0	0	0	0	0	1
12/08/2022 02:00	0.0	0	0	0	0	1
12/08/2022 03:00	0.0	0	0	0	0	1
12/08/2022 04:00	0.0	0	0	0	0	1
12/08/2022 05:00	0.0	0	0	0	0	1
12/08/2022 06:00	0.0	0	0	0	0	1
12/08/2022 07:00	0.0	0	0	0	0	1
12/08/2022 08:00	0.0	0	0	0	0	1
12/08/2022 09:00	0.0	0	0	0	0	1
12/08/2022 10:00	0.0	0	0	0	0	1
12/08/2022 11:00	0.0	0	0	0	0	1
12/08/2022 12:00	0.0	0	0	0	0	1
12/08/2022 13:00	0.0	0	0	0	0	1
12/08/2022 14:00	0.0	0	0	0	0	1
12/08/2022 15:00	0.0	0	0	0	0	1
12/08/2022 16:00	0.0	0	0	0	0	1
12/08/2022 17:00	0.0	0	0	0	0	1
12/08/2022 18:00	0.0	0	0	0	0	1
12/08/2022 19:00	0.0	0	0	0	0	1
12/08/2022 20:00	0.0	0	0	0	0	1
12/08/2022 21:00	0.0	0	0	0	0	1
12/08/2022 22:00	0.0	0	0	0	0	1
12/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2022 00:00	0.0	0	0	0	0	1
12/09/2022 01:00	0.0	0	0	0	0	1
12/09/2022 02:00	0.0	0	0	0	0	1
12/09/2022 03:00	0.0	0	0	0	0	1
12/09/2022 04:00	0.0	0	0	0	0	1
12/09/2022 05:00	0.0	0	0	0	0	1
12/09/2022 06:00	0.0	0	0	0	0	1
12/09/2022 07:00	0.0	0	0	0	0	1
12/09/2022 08:00	0.0	0	0	0	0	1
12/09/2022 09:00	0.0	0	0	0	0	1
12/09/2022 10:00	0.0	0	0	0	0	1
12/09/2022 11:00	0.0	0	0	0	0	1
12/09/2022 12:00	0.0	0	0	0	0	1
12/09/2022 13:00	0.0	0	0	0	0	1
12/09/2022 14:00	0.0	0	0	0	0	1
12/09/2022 15:00	0.0	0	0	0	0	1
12/09/2022 16:00	0.0	0	0	0	0	1
12/09/2022 17:00	0.0	0	0	0	0	1
12/09/2022 18:00	0.0	0	0	0	0	1
12/09/2022 19:00	0.0	0	0	0	0	1
12/09/2022 20:00	0.0	0	0	0	0	1
12/09/2022 21:00	0.0	0	0	0	0	1
12/09/2022 22:00	0.0	0	0	0	0	1
12/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2022 00:00	0.0	0	0	0	0	1
12/10/2022 01:00	0.0	0	0	0	0	1
12/10/2022 02:00	0.0	0	0	0	0	1
12/10/2022 03:00	0.0	0	0	0	0	1
12/10/2022 04:00	0.0	0	0	0	0	1
12/10/2022 05:00	0.0	0	0	0	0	1
12/10/2022 06:00	0.0	0	0	0	0	1
12/10/2022 07:00	0.0	0	0	0	0	1
12/10/2022 08:00	0.0	0	0	0	0	1
12/10/2022 09:00	0.0	0	0	0	0	1
12/10/2022 10:00	0.0	0	0	0	0	1
12/10/2022 11:00	0.0	0	0	0	0	1
12/10/2022 12:00	0.0	0	0	0	0	1
12/10/2022 13:00	0.0	0	0	0	0	1
12/10/2022 14:00	0.0	0	0	0	0	1
12/10/2022 15:00	0.0	0	0	0	0	1
12/10/2022 16:00	0.0	0	0	0	0	1
12/10/2022 17:00	0.0	0	0	0	0	1
12/10/2022 18:00	0.0	0	0	0	0	1
12/10/2022 19:00	0.0	0	0	0	0	1
12/10/2022 20:00	0.0	0	0	0	0	1
12/10/2022 21:00	0.0	0	0	0	0	1
12/10/2022 22:00	0.0	0	0	0	0	1
12/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2022 00:00	0.0	0	0	0	0	1
12/11/2022 01:00	0.0	0	0	0	0	1
12/11/2022 02:00	0.0	0	0	0	0	1
12/11/2022 03:00	0.0	0	0	0	0	1
12/11/2022 04:00	0.0	0	0	0	0	1
12/11/2022 05:00	0.0	0	0	0	0	1
12/11/2022 06:00	0.0	0	0	0	0	1
12/11/2022 07:00	0.0	0	0	0	0	1
12/11/2022 08:00	0.0	0	0	0	0	1
12/11/2022 09:00	0.0	0	0	0	0	1
12/11/2022 10:00	0.0	0	0	0	0	1
12/11/2022 11:00	0.0	0	0	0	0	1
12/11/2022 12:00	0.0	0	0	0	0	1
12/11/2022 13:00	0.0	0	0	0	0	1
12/11/2022 14:00	0.0	0	0	0	0	1
12/11/2022 15:00	0.0	0	0	0	0	1
12/11/2022 16:00	0.0	0	0	0	0	1
12/11/2022 17:00	0.0	0	0	0	0	1
12/11/2022 18:00	0.0	0	0	0	0	1
12/11/2022 19:00	0.0	0	0	0	0	1
12/11/2022 20:00	0.0	0	0	0	0	1
12/11/2022 21:00	0.0	0	0	0	0	1
12/11/2022 22:00	0.0	0	0	0	0	1
12/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2022 00:00	0.0	0	0	0	0	1
12/12/2022 01:00	0.0	0	0	0	0	1
12/12/2022 02:00	0.0	0	0	0	0	1
12/12/2022 03:00	0.0	0	0	0	0	1
12/12/2022 04:00	0.0	0	0	0	0	1
12/12/2022 05:00	0.0	0	0	0	0	1
12/12/2022 06:00	0.0	0	0	0	0	1
12/12/2022 07:00	0.0	0	0	0	0	1
12/12/2022 08:00	0.0	0	0	0	0	1
12/12/2022 09:00	0.0	0	0	0	0	1
12/12/2022 10:00	0.0	0	0	0	0	1
12/12/2022 11:00	0.0	0	0	0	0	1
12/12/2022 12:00	0.0	0	0	0	0	1
12/12/2022 13:00	0.0	0	0	0	0	1
12/12/2022 14:00	0.0	0	0	0	0	1
12/12/2022 15:00	0.0	0	0	0	0	1
12/12/2022 16:00	0.0	0	0	0	0	1
12/12/2022 17:00	0.0	0	0	0	0	1
12/12/2022 18:00	0.0	0	0	0	0	1
12/12/2022 19:00	0.0	0	0	0	0	1
12/12/2022 20:00	0.0	0	0	0	0	1
12/12/2022 21:00	0.0	0	0	0	0	1
12/12/2022 22:00	0.0	0	0	0	0	1
12/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2022 00:00	0.0	0	0	0	0	1
12/13/2022 01:00	0.0	0	0	0	0	1
12/13/2022 02:00	0.0	0	0	0	0	1
12/13/2022 03:00	0.0	0	0	0	0	1
12/13/2022 04:00	0.0	0	0	0	0	1
12/13/2022 05:00	0.0	0	0	0	0	1
12/13/2022 06:00	0.0	0	0	0	0	1
12/13/2022 07:00	0.0	0	0	0	0	1
12/13/2022 08:00	0.0	0	0	0	0	1
12/13/2022 09:00	0.0	0	0	0	0	1
12/13/2022 10:00	0.0	0	0	0	0	1
12/13/2022 11:00	0.0	0	0	0	0	1
12/13/2022 12:00	0.0	0	0	0	0	1
12/13/2022 13:00	0.0	0	0	0	0	1
12/13/2022 14:00	0.0	0	0	0	0	1
12/13/2022 15:00	0.0	0	0	0	0	1
12/13/2022 16:00	0.0	0	0	0	0	1
12/13/2022 17:00	0.0	0	0	0	0	1
12/13/2022 18:00	0.0	0	0	0	0	1
12/13/2022 19:00	0.0	0	0	0	0	1
12/13/2022 20:00	0.0	0	0	0	0	1
12/13/2022 21:00	0.0	0	0	0	0	1
12/13/2022 22:00	0.0	0	0	0	0	1
12/13/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2022 00:00	0.0	0	0	0	0	1
12/14/2022 01:00	0.0	0	0	0	0	1
12/14/2022 02:00	0.0	0	0	0	0	1
12/14/2022 03:00	0.0	0	0	0	0	1
12/14/2022 04:00	0.0	0	0	0	0	1
12/14/2022 05:00	0.0	0	0	0	0	1
12/14/2022 06:00	0.0	0	0	0	0	1
12/14/2022 07:00	0.0	0	0	0	0	1
12/14/2022 08:00	0.0	0	0	0	0	1
12/14/2022 09:00	0.0	0	0	0	0	1
12/14/2022 10:00	0.0	0	0	0	0	1
12/14/2022 11:00	0.0	0	0	0	0	1
12/14/2022 12:00	0.0	0	0	0	0	1
12/14/2022 13:00	0.0	0	0	0	0	1
12/14/2022 14:00	0.0	0	0	0	0	1
12/14/2022 15:00	0.0	0	0	0	0	1
12/14/2022 16:00	0.0	0	0	0	0	1
12/14/2022 17:00	0.0	0	0	0	0	1
12/14/2022 18:00	0.0	0	0	0	0	1
12/14/2022 19:00	0.0	0	0	0	0	1
12/14/2022 20:00	0.0	0	0	0	0	1
12/14/2022 21:00	0.0	0	0	0	0	1
12/14/2022 22:00	0.0	0	0	0	0	1
12/14/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2022 00:00	0.0	0	0	0	0	1
12/15/2022 01:00	0.0	0	0	0	0	1
12/15/2022 02:00	0.0	0	0	0	0	1
12/15/2022 03:00	0.0	0	0	0	0	1
12/15/2022 04:00	0.0	0	0	0	0	1
12/15/2022 05:00	0.0	0	0	0	0	1
12/15/2022 06:00	0.0	0	0	0	0	1
12/15/2022 07:00	0.0	0	0	0	0	1
12/15/2022 08:00	0.0	0	0	0	0	1
12/15/2022 09:00	0.0	0	0	0	0	1
12/15/2022 10:00	0.0	0	0	0	0	1
12/15/2022 11:00	0.0	0	0	0	0	1
12/15/2022 12:00	0.0	0	0	0	0	1
12/15/2022 13:00	0.0	0	0	0	0	1
12/15/2022 14:00	0.0	0	0	0	0	1
12/15/2022 15:00	0.0	0	0	0	0	1
12/15/2022 16:00	0.0	0	0	0	0	1
12/15/2022 17:00	0.0	0	0	0	0	1
12/15/2022 18:00	0.0	0	0	0	0	1
12/15/2022 19:00	0.0	0	0	0	0	1
12/15/2022 20:00	0.0	0	0	0	0	1
12/15/2022 21:00	0.0	0	0	0	0	1
12/15/2022 22:00	0.0	0	0	0	0	1
12/15/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2022 00:00	0.0	0	0	0	0	1
12/16/2022 01:00	0.0	0	0	0	0	1
12/16/2022 02:00	0.0	0	0	0	0	1
12/16/2022 03:00	0.0	0	0	0	0	1
12/16/2022 04:00	0.0	0	0	0	0	1
12/16/2022 05:00	0.0	0	0	0	0	1
12/16/2022 06:00	0.0	0	0	0	0	1
12/16/2022 07:00	0.0	0	0	0	0	1
12/16/2022 08:00	0.0	0	0	0	0	1
12/16/2022 09:00	0.0	0	0	0	0	1
12/16/2022 10:00	0.0	0	0	0	0	1
12/16/2022 11:00	0.0	0	0	0	0	1
12/16/2022 12:00	0.0	0	0	0	0	1
12/16/2022 13:00	0.0	0	0	0	0	1
12/16/2022 14:00	0.0	0	0	0	0	1
12/16/2022 15:00	0.0	0	0	0	0	1
12/16/2022 16:00	0.0	0	0	0	0	1
12/16/2022 17:00	0.0	0	0	0	0	1
12/16/2022 18:00	0.0	0	0	0	0	1
12/16/2022 19:00	0.0	0	0	0	0	1
12/16/2022 20:00	0.0	0	0	0	0	1
12/16/2022 21:00	0.0	0	0	0	0	1
12/16/2022 22:00	0.0	0	0	0	0	1
12/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2022 00:00	0.0	0	0	0	0	1
12/17/2022 01:00	0.0	0	0	0	0	1
12/17/2022 02:00	0.0	0	0	0	0	1
12/17/2022 03:00	0.0	0	0	0	0	1
12/17/2022 04:00	0.0	0	0	0	0	1
12/17/2022 05:00	0.0	0	0	0	0	1
12/17/2022 06:00	0.0	0	0	0	0	1
12/17/2022 07:00	0.0	0	0	0	0	1
12/17/2022 08:00	0.0	0	0	0	0	1
12/17/2022 09:00	0.0	0	0	0	0	1
12/17/2022 10:00	0.0	0	0	0	0	1
12/17/2022 11:00	0.0	0	0	0	0	1
12/17/2022 12:00	0.0	0	0	0	0	1
12/17/2022 13:00	0.0	0	0	0	0	1
12/17/2022 14:00	0.0	0	0	0	0	1
12/17/2022 15:00	0.0	0	0	0	0	1
12/17/2022 16:00	0.0	0	0	0	0	1
12/17/2022 17:00	0.0	0	0	0	0	1
12/17/2022 18:00	0.0	0	0	0	0	1
12/17/2022 19:00	0.0	0	0	0	0	1
12/17/2022 20:00	0.0	0	0	0	0	1
12/17/2022 21:00	0.0	0	0	0	0	1
12/17/2022 22:00	0.0	0	0	0	0	1
12/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2022 00:00	0.0	0	0	0	0	1
12/18/2022 01:00	0.0	0	0	0	0	1
12/18/2022 02:00	0.0	0	0	0	0	1
12/18/2022 03:00	0.0	0	0	0	0	1
12/18/2022 04:00	0.0	0	0	0	0	1
12/18/2022 05:00	0.0	0	0	0	0	1
12/18/2022 06:00	0.0	0	0	0	0	1
12/18/2022 07:00	0.0	0	0	0	0	1
12/18/2022 08:00	0.0	0	0	0	0	1
12/18/2022 09:00	0.0	0	0	0	0	1
12/18/2022 10:00	0.0	0	0	0	0	1
12/18/2022 11:00	0.0	0	0	0	0	1
12/18/2022 12:00	0.0	0	0	0	0	1
12/18/2022 13:00	0.0	0	0	0	0	1
12/18/2022 14:00	0.0	0	0	0	0	1
12/18/2022 15:00	0.0	0	0	0	0	1
12/18/2022 16:00	0.0	0	0	0	0	1
12/18/2022 17:00	0.0	0	0	0	0	1
12/18/2022 18:00	0.0	0	0	0	0	1
12/18/2022 19:00	0.0	0	0	0	0	1
12/18/2022 20:00	0.0	0	0	0	0	1
12/18/2022 21:00	0.0	0	0	0	0	1
12/18/2022 22:00	0.0	0	0	0	0	1
12/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2022 00:00	0.0	0	0	0	0	1
12/19/2022 01:00	0.0	0	0	0	0	1
12/19/2022 02:00	0.0	0	0	0	0	1
12/19/2022 03:00	0.0	0	0	0	0	1
12/19/2022 04:00	0.0	0	0	0	0	1
12/19/2022 05:00	0.0	0	0	0	0	1
12/19/2022 06:00	0.0	0	0	0	0	1
12/19/2022 07:00	0.0	0	0	0	0	1
12/19/2022 08:00	0.0	0	0	0	0	1
12/19/2022 09:00	0.0	0	0	0	0	1
12/19/2022 10:00	0.0	0	0	0	0	1
12/19/2022 11:00	0.0	0	0	0	0	1
12/19/2022 12:00	0.0	0	0	0	0	1
12/19/2022 13:00	0.0	0	0	0	0	1
12/19/2022 14:00	0.0	0	0	0	0	1
12/19/2022 15:00	0.0	0	0	0	0	1
12/19/2022 16:00	0.0	0	0	0	0	1
12/19/2022 17:00	0.0	0	0	0	0	1
12/19/2022 18:00	0.0	0	0	0	0	1
12/19/2022 19:00	0.0	0	0	0	0	1
12/19/2022 20:00	0.0	0	0	0	0	1
12/19/2022 21:00	0.0	0	0	0	0	1
12/19/2022 22:00	0.0	0	0	0	0	1
12/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2022 00:00	0.0	0	0	0	0	1
12/20/2022 01:00	0.0	0	0	0	0	1
12/20/2022 02:00	0.0	0	0	0	0	1
12/20/2022 03:00	0.0	0	0	0	0	1
12/20/2022 04:00	0.0	0	0	0	0	1
12/20/2022 05:00	0.0	0	0	0	0	1
12/20/2022 06:00	0.0	0	0	0	0	1
12/20/2022 07:00	0.0	0	0	0	0	1
12/20/2022 08:00	0.0	0	0	0	0	1
12/20/2022 09:00	0.0	0	0	0	0	1
12/20/2022 10:00	0.0	0	0	0	0	1
12/20/2022 11:00	0.0	0	0	0	0	1
12/20/2022 12:00	0.0	0	0	0	0	1
12/20/2022 13:00	0.0	0	0	0	0	1
12/20/2022 14:00	0.0	0	0	0	0	1
12/20/2022 15:00	0.0	0	0	0	0	1
12/20/2022 16:00	0.0	0	0	0	0	1
12/20/2022 17:00	0.0	0	0	0	0	1
12/20/2022 18:00	0.0	0	0	0	0	1
12/20/2022 19:00	0.0	0	0	0	0	1
12/20/2022 20:00	0.0	0	0	0	0	1
12/20/2022 21:00	0.0	0	0	0	0	1
12/20/2022 22:00	0.0	0	0	0	0	1
12/20/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2022 00:00	0.0	0	0	0	0	1
12/21/2022 01:00	0.0	0	0	0	0	1
12/21/2022 02:00	0.0	0	0	0	0	1
12/21/2022 03:00	0.0	0	0	0	0	1
12/21/2022 04:00	0.0	0	0	0	0	1
12/21/2022 05:00	0.0	0	0	0	0	1
12/21/2022 06:00	0.0	0	0	0	0	1
12/21/2022 07:00	0.0	0	0	0	0	1
12/21/2022 08:00	0.0	0	0	0	0	1
12/21/2022 09:00	0.0	0	0	0	0	1
12/21/2022 10:00	0.0	0	0	0	0	1
12/21/2022 11:00	0.0	0	0	0	0	1
12/21/2022 12:00	0.0	0	0	0	0	1
12/21/2022 13:00	0.0	0	0	0	0	1
12/21/2022 14:00	0.0	0	0	0	0	1
12/21/2022 15:00	0.0	0	0	0	0	1
12/21/2022 16:00	0.0	0	0	0	0	1
12/21/2022 17:00	0.0	0	0	0	0	1
12/21/2022 18:00	0.0	0	0	0	0	1
12/21/2022 19:00	0.0	0	0	0	0	1
12/21/2022 20:00	0.0	0	0	0	0	1
12/21/2022 21:00	0.0	0	0	0	0	1
12/21/2022 22:00	0.0	0	0	0	0	1
12/21/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2022 00:00	0.0	0	0	0	0	1
12/22/2022 01:00	0.0	0	0	0	0	1
12/22/2022 02:00	0.0	0	0	0	0	1
12/22/2022 03:00	0.0	0	0	0	0	1
12/22/2022 04:00	0.0	0	0	0	0	1
12/22/2022 05:00	0.0	0	0	0	0	1
12/22/2022 06:00	0.0	0	0	0	0	1
12/22/2022 07:00	0.0	0	0	0	0	1
12/22/2022 08:00	0.0	0	0	0	0	1
12/22/2022 09:00	0.0	0	0	0	0	1
12/22/2022 10:00	0.0	0	0	0	0	1
12/22/2022 11:00	0.0	0	0	0	0	1
12/22/2022 12:00	0.0	0	0	0	0	1
12/22/2022 13:00	0.0	0	0	0	0	1
12/22/2022 14:00	0.0	0	0	0	0	1
12/22/2022 15:00	0.0	0	0	0	0	1
12/22/2022 16:00	0.0	0	0	0	0	1
12/22/2022 17:00	0.0	0	0	0	0	1
12/22/2022 18:00	0.0	0	0	0	0	1
12/22/2022 19:00	0.0	0	0	0	0	1
12/22/2022 20:00	0.0	0	0	0	0	1
12/22/2022 21:00	0.0	0	0	0	0	1
12/22/2022 22:00	0.0	0	0	0	0	1
12/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2022 00:00	0.0	0	0	0	0	1
12/23/2022 01:00	0.0	0	0	0	0	1
12/23/2022 02:00	0.0	0	0	0	0	1
12/23/2022 03:00	0.0	0	0	0	0	1
12/23/2022 04:00	0.0	0	0	0	0	1
12/23/2022 05:00	0.0	0	0	0	0	1
12/23/2022 06:00	0.0	0	0	0	0	1
12/23/2022 07:00	0.0	0	0	0	0	1
12/23/2022 08:00	0.0	0	0	0	0	1
12/23/2022 09:00	0.0	0	0	0	0	1
12/23/2022 10:00	0.0	0	0	0	0	1
12/23/2022 11:00	0.0	0	0	0	0	1
12/23/2022 12:00	0.0	0	0	0	0	1
12/23/2022 13:00	0.0	0	0	0	0	1
12/23/2022 14:00	0.0	0	0	0	0	1
12/23/2022 15:00	0.0	0	0	0	0	1
12/23/2022 16:00	0.0	0	0	0	0	1
12/23/2022 17:00	0.0	0	0	0	0	1
12/23/2022 18:00	0.0	0	0	0	0	1
12/23/2022 19:00	0.0	0	0	0	0	1
12/23/2022 20:00	0.0	0	0	0	0	1
12/23/2022 21:00	0.0	0	0	0	0	1
12/23/2022 22:00	0.0	0	0	0	0	1
12/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2022 00:00	0.0	0	0	0	0	1
12/24/2022 01:00	0.0	0	0	0	0	1
12/24/2022 02:00	0.0	0	0	0	0	1
12/24/2022 03:00	0.0	0	0	0	0	1
12/24/2022 04:00	0.0	0	0	0	0	1
12/24/2022 05:00	0.0	0	0	0	0	1
12/24/2022 06:00	0.0	0	0	0	0	1
12/24/2022 07:00	0.0	0	0	0	0	1
12/24/2022 08:00	0.0	0	0	0	0	1
12/24/2022 09:00	0.0	0	0	0	0	1
12/24/2022 10:00	0.0	0	0	0	0	1
12/24/2022 11:00	0.0	0	0	0	0	1
12/24/2022 12:00	0.0	0	0	0	0	1
12/24/2022 13:00	0.0	0	0	0	0	1
12/24/2022 14:00	0.0	0	0	0	0	1
12/24/2022 15:00	0.0	0	0	0	0	1
12/24/2022 16:00	0.0	0	0	0	0	1
12/24/2022 17:00	0.0	0	0	0	0	1
12/24/2022 18:00	0.0	0	0	0	0	1
12/24/2022 19:00	0.0	0	0	0	0	1
12/24/2022 20:00	0.0	0	0	0	0	1
12/24/2022 21:00	0.0	0	0	0	0	1
12/24/2022 22:00	0.0	0	0	0	0	1
12/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2022 00:00	0.0	0	0	0	0	1
12/25/2022 01:00	1.2	0	0	0	1	0
12/25/2022 02:00	0.0	0	0	0	0	0
12/25/2022 03:00	0.0	0	0	0	0	0
12/25/2022 04:00	0.0	0	0	0	0	0
12/25/2022 05:00	0.0	0	0	0	0	0
12/25/2022 06:00	0.0	0	0	0	0	0
12/25/2022 07:00	0.0	0	0	0	0	0
12/25/2022 08:00	0.0	0	0	0	0	0
12/25/2022 09:00	0.0	0	0	0	0	0
12/25/2022 10:00	0.0	0	0	0	0	0
12/25/2022 11:00	0.0	0	0	0	0	0
12/25/2022 12:00	0.0	0	0	0	0	0
12/25/2022 13:00	0.0	0	0	0	0	0
12/25/2022 14:00	0.0	0	0	0	0	0
12/25/2022 15:00	0.0	0	0	0	0	0
12/25/2022 16:00	0.0	0	0	0	0	0
12/25/2022 17:00	0.0	0	0	0	0	0
12/25/2022 18:00	48.0	0	1	0	0	0
12/25/2022 19:00	23.8	0	1	0	0	0
12/25/2022 20:00	30.9	0	1	0	0	0
12/25/2022 21:00	0.0	0	0	0	0	1
12/25/2022 22:00	0.0	0	0	0	0	1
12/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.9 #	0 #	3 #	0 #	1 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2022 00:00	0.0	0	0	0	0	1
12/26/2022 01:00	0.0	0	0	0	0	1
12/26/2022 02:00	0.0	0	0	0	0	1
12/26/2022 03:00	0.0	0	0	0	0	1
12/26/2022 04:00	0.0	0	0	0	0	1
12/26/2022 05:00	0.0	0	0	0	0	1
12/26/2022 06:00	0.0	0	0	0	0	1
12/26/2022 07:00	0.0	0	0	0	0	1
12/26/2022 08:00	0.0	0	0	0	0	1
12/26/2022 09:00	0.0	0	0	0	0	1
12/26/2022 10:00	0.0	0	0	0	0	1
12/26/2022 11:00	0.0	0	0	0	0	1
12/26/2022 12:00	0.0	0	0	0	0	1
12/26/2022 13:00	0.0	0	0	0	0	1
12/26/2022 14:00	0.0	0	0	0	0	1
12/26/2022 15:00	0.0	0	0	0	0	1
12/26/2022 16:00	0.0	0	0	0	0	1
12/26/2022 17:00	0.0	0	0	0	0	1
12/26/2022 18:00	0.0	0	0	0	0	1
12/26/2022 19:00	0.0	0	0	0	0	1
12/26/2022 20:00	0.0	0	0	0	0	1
12/26/2022 21:00	0.0	0	0	0	0	1
12/26/2022 22:00	0.0	0	0	0	0	1
12/26/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2022 00:00	0.0	0	0	0	0	0
12/27/2022 01:00	0.0	0	0	1	0	0
12/27/2022 02:00	21.1	0	0	1	0	0
12/27/2022 03:00	0.0	0	0	0	0	1
12/27/2022 04:00	0.0	0	0	0	0	1
12/27/2022 05:00	0.0	0	0	0	0	1
12/27/2022 06:00	0.0	0	0	0	0	1
12/27/2022 07:00	0.0	0	0	0	0	1
12/27/2022 08:00	0.0	0	0	0	0	1
12/27/2022 09:00	0.0	0	0	0	0	1
12/27/2022 10:00	0.0	0	0	0	0	1
12/27/2022 11:00	0.0	0	0	0	0	1
12/27/2022 12:00	0.0	0	0	0	0	1
12/27/2022 13:00	0.0	0	0	0	0	1
12/27/2022 14:00	0.0	0	0	0	0	1
12/27/2022 15:00	0.0	0	0	0	0	1
12/27/2022 16:00	0.0	0	0	0	0	1
12/27/2022 17:00	0.0	0	0	0	0	1
12/27/2022 18:00	0.0	0	0	0	0	1
12/27/2022 19:00	0.0	0	0	0	0	1
12/27/2022 20:00	0.0	0	0	0	0	1
12/27/2022 21:00	0.0	0	0	0	0	1
12/27/2022 22:00	0.0	0	0	0	0	1
12/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	21.1 #	0 #	0 #	2 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.1	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2022 00:00	0.0	0	0	0	0	1
12/28/2022 01:00	0.0	0	0	0	0	1
12/28/2022 02:00	0.0	0	0	0	0	1
12/28/2022 03:00	0.0	0	0	0	0	1
12/28/2022 04:00	0.0	0	0	0	0	1
12/28/2022 05:00	0.0	0	0	0	0	1
12/28/2022 06:00	0.0	0	0	0	0	1
12/28/2022 07:00	0.0	0	0	0	0	1
12/28/2022 08:00	0.0	0	0	0	0	1
12/28/2022 09:00	0.0	0	0	0	0	1
12/28/2022 10:00	0.0	0	0	0	0	1
12/28/2022 11:00	0.0	0	0	0	0	1
12/28/2022 12:00	0.0	0	0	0	0	1
12/28/2022 13:00	0.0	0	0	0	0	1
12/28/2022 14:00	0.0	0	0	0	0	1
12/28/2022 15:00	0.0	0	0	0	0	1
12/28/2022 16:00	0.0	0	0	0	0	1
12/28/2022 17:00	0.0	0	0	0	0	1
12/28/2022 18:00	0.0	0	0	0	0	1
12/28/2022 19:00	0.0	0	0	0	0	1
12/28/2022 20:00	0.0	0	0	0	0	1
12/28/2022 21:00	0.0	0	0	0	0	1
12/28/2022 22:00	0.0	0	0	0	0	1
12/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2022 00:00	0.0	0	0	0	0	1
12/29/2022 01:00	0.0	0	0	0	0	1
12/29/2022 02:00	0.0	0	0	0	0	1
12/29/2022 03:00	0.0	0	0	0	0	1
12/29/2022 04:00	0.0	0	0	0	0	1
12/29/2022 05:00	0.0	0	0	0	0	1
12/29/2022 06:00	0.0	0	0	0	0	1
12/29/2022 07:00	0.0	0	0	0	0	1
12/29/2022 08:00	0.0	0	0	0	0	1
12/29/2022 09:00	0.0	0	0	0	0	1
12/29/2022 10:00	0.0	0	0	0	0	1
12/29/2022 11:00	0.0	0	0	0	0	1
12/29/2022 12:00	0.0	0	0	0	0	1
12/29/2022 13:00	0.0	0	0	0	0	1
12/29/2022 14:00	0.0	0	0	0	0	1
12/29/2022 15:00	0.0	0	0	0	0	1
12/29/2022 16:00	0.0	0	0	0	0	1
12/29/2022 17:00	0.0	0	0	0	0	1
12/29/2022 18:00	0.0	0	0	0	0	1
12/29/2022 19:00	0.0	0	0	0	0	1
12/29/2022 20:00	0.0	0	0	0	0	1
12/29/2022 21:00	0.0	0	0	0	0	1
12/29/2022 22:00	0.0	0	0	0	0	1
12/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2022 00:00	1.2	0	0	0	1	0
12/30/2022 01:00	0.0	0	0	0	0	0
12/30/2022 02:00	0.0	0	0	0	0	0
12/30/2022 03:00	0.0	0	0	0	0	0
12/30/2022 04:00	0.0	0	0	0	0	0
12/30/2022 05:00	0.0	0	0	0	0	0
12/30/2022 06:00	0.0	0	0	0	0	0
12/30/2022 07:00	0.0	0	0	0	0	0
12/30/2022 08:00	0.0	0	0	0	0	0
12/30/2022 09:00	0.0	0	0	0	0	0
12/30/2022 10:00	0.0	0	0	0	0	0
12/30/2022 11:00	0.0	0	0	0	0	0
12/30/2022 12:00	0.0	0	0	0	0	0
12/30/2022 13:00	0.0	0	0	0	0	0
12/30/2022 14:00	0.0	0	0	0	0	0
12/30/2022 15:00	0.0	0	0	0	0	0
12/30/2022 16:00	0.0	0	0	0	0	0
12/30/2022 17:00	0.0	0	0	0	0	0
12/30/2022 18:00	0.0	0	0	0	0	0
12/30/2022 19:00	0.0	0	0	0	0	0
12/30/2022 20:00	0.0	0	0	0	0	0
12/30/2022 21:00	0.0	0	0	0	0	0
12/30/2022 22:00	0.0	0	0	0	0	0
12/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2022 00:00	0.0	0	0	0	0	0
12/31/2022 01:00	0.0	0	0	0	0	0
12/31/2022 02:00	0.0	0	0	0	0	0
12/31/2022 03:00	0.0	0	0	0	0	0
12/31/2022 04:00	0.0	0	0	0	0	0
12/31/2022 05:00	0.0	0	0	0	0	0
12/31/2022 06:00	0.0	0	0	0	0	0
12/31/2022 07:00	0.0	0	0	0	0	0
12/31/2022 08:00	0.0	0	0	0	0	0
12/31/2022 09:00	0.0	0	0	0	0	0
12/31/2022 10:00	0.0	0	0	0	0	0
12/31/2022 11:00	0.0	0	0	0	0	0
12/31/2022 12:00	0.0	0	0	0	0	0
12/31/2022 13:00	0.0	0	0	0	0	0
12/31/2022 14:00	0.0	0	0	0	0	0
12/31/2022 15:00	0.0	0	0	0	0	0
12/31/2022 16:00	0.0	0	0	0	0	0
12/31/2022 17:00	0.0	0	0	0	0	0
12/31/2022 18:00	0.0	0	0	0	0	0
12/31/2022 19:00	0.0	0	0	0	0	0
12/31/2022 20:00	0.0	0	0	0	0	0
12/31/2022 21:00	0.0	0	0	0	0	0
12/31/2022 22:00	0.0	0	0	0	0	0
12/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.7	483.5		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	66.7	790.5		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.9	483.5		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	97.2	790.5		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.4	483.5		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	46.5	679.6		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	1.0	483.5		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	189.3	790.5		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.6	483.5		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	109.4	790.5		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.6	483.5		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	199.7	1,355.6		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.7	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	120.1	790.5		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.3	483.5		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	71.8	679.6		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.4	483.5		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	123.1	790.5		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.4	483.5		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	52.1	679.6		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.5	483.5		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	108.3	790.5		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.9	483.5		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	38.3	679.6		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.7	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,674.85 Hours

Non-Operating Time: 533.15 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2022 01:23 10/01/2022 01:28 Shut Down - Gas	6	0.18	115.00		
10/01/2022 12:17 10/01/2022 14:48 Warm Start - Gas	152	108.24	456.20		
10/01/2022 23:09 10/01/2022 23:14 Shut Down - Gas	6	0.13	115.00		
10/02/2022 11:20 10/02/2022 13:47 Warm Start - Gas	148	86.43	456.20		
10/09/2022 06:54 10/09/2022 06:58 Shut Down - Gas	5	0.13	115.00		
10/09/2022 14:17 10/09/2022 15:27 Hot Start - Gas	71	64.82	259.90		
10/14/2022 23:27 10/14/2022 23:32 Shut Down - Gas	6	0.32	115.00		
10/16/2022 17:16 10/16/2022 19:45 Warm Start - Gas	150	129.10	456.20		
10/21/2022 22:25 10/21/2022 22:30 Shut Down - Gas	6	0.16	115.00		
10/23/2022 20:17 10/23/2022 22:50 Warm Start - Gas	154	117.64	456.20		
10/24/2022 14:19 10/24/2022 14:24 Shut Down - Gas	6	0.17	115.00		
10/30/2022 19:48 10/30/2022 22:53 Cold Start - Gas	186	169.89	779.10		
11/05/2022 07:08 11/05/2022 07:13 Shut Down - Gas	6	0.22	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours
Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/06/2022 09:39 11/06/2022 11:54 Warm Start - Gas	136	96.58	456.20		
11/06/2022 21:54 11/06/2022 21:58 Shut Down - Gas	5	0.05	115.00		
11/07/2022 00:33 11/07/2022 01:43 Hot Start - Gas	71	37.00	259.90		
11/26/2022 02:53 11/26/2022 02:58 Shut Down - Gas	6	0.21	115.00		
11/27/2022 21:18 11/27/2022 23:50 Warm Start - Gas	153	124.17	456.20		
11/30/2022 23:55 11/30/2022 23:59 Shut Down - Gas	5	0.16	115.00		
12/01/2022 02:32 12/01/2022 03:35 Hot Start - Gas	64	25.11	259.90		
12/25/2022 01:08 12/25/2022 01:12 Shut Down - Gas	5	0.18	115.00		
12/25/2022 18:17 12/25/2022 20:52 Warm Start - Gas	156	104.88	456.20		
12/26/2022 23:08 12/26/2022 23:13 Shut Down - Gas	6	0.41	115.00		
12/27/2022 01:48 12/27/2022 02:51 Hot Start - Gas	64	22.34	259.90		
12/30/2022 00:08 12/30/2022 00:13 Shut Down - Gas	6	0.22	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/17/2023 11:21 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,799.68 Hours

Non-Operating Time: 408.32 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/01/2022 02:00	10/03/2022 01:00	48
10/09/2022 07:00	10/09/2022 09:00	3
10/15/2022 00:00	10/16/2022 22:00	47
10/21/2022 23:00	10/24/2022 11:00	61
10/26/2022 09:00	10/26/2022 15:00	7
10/27/2022 00:00	10/31/2022 00:00	97
11/05/2022 08:00	11/05/2022 12:00	5
11/06/2022 03:00	11/07/2022 02:00	24
11/22/2022 10:00	11/22/2022 10:00	1
11/26/2022 03:00	11/28/2022 01:00	47
12/01/2022 00:00	12/05/2022 08:00	105
12/25/2022 02:00	12/25/2022 23:00	22
12/27/2022 00:00	12/27/2022 04:00	5
12/30/2022 01:00	12/31/2022 23:00	47

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	519.00 Hour(s)
Offline Percentage:	23.51 %
Total Online:	1,689.00 Hour(s)
Online Percentage:	76.49 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/03/2022 02:00	10/03/2022 03:00	Warm Startup	2
2	10/09/2022 10:00	10/09/2022 11:00	Hot Startup	2
3	10/16/2022 23:00	10/17/2022 00:00	Warm Startup	2
4	10/24/2022 12:00	10/24/2022 14:00	Warm Startup	3
5	10/26/2022 16:00	10/26/2022 18:00	Warm Startup	3
6	10/31/2022 01:00	10/31/2022 02:00	Cold Startup	2
7	11/05/2022 13:00	11/05/2022 14:00	Hot Startup	2
8	11/07/2022 03:00	11/07/2022 05:00	Warm Startup	3
9	11/22/2022 11:00	11/22/2022 12:00	Hot Startup	2
10	11/28/2022 02:00	11/28/2022 03:00	Warm Startup	2
11	12/05/2022 09:00	12/05/2022 11:00	Cold Startup	3
12	12/26/2022 00:00	12/26/2022 01:00	Warm Startup	2
13	12/27/2022 05:00	12/27/2022 06:00	Hot Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:22 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	5	0.30
Hot Startup/Startup Shutdown Event Text 02 Add	4	8	0.47
Warm Startup	7	17	1.01
Total Process Events:	13	30	1.78

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,689 Hour(s)
Total Startup Time:	30 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	30 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.78 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/01/2022 02:00	10/01/2022 11:00	10
10/02/2022 00:00	10/02/2022 10:00	11
10/09/2022 07:00	10/09/2022 13:00	7
10/15/2022 00:00	10/16/2022 16:00	41
10/21/2022 23:00	10/23/2022 19:00	45
10/24/2022 15:00	10/30/2022 18:00	148
11/05/2022 08:00	11/06/2022 08:00	25
11/06/2022 22:00	11/06/2022 23:00	2
11/26/2022 03:00	11/27/2022 20:00	42
12/01/2022 00:00	12/01/2022 01:00	2
12/25/2022 02:00	12/25/2022 17:00	16
12/27/2022 00:00	12/27/2022 00:00	1
12/30/2022 01:00	12/31/2022 23:00	47

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	397.00 Hour(s)
Offline Percentage:	17.98 %
Total Online:	1,811.00 Hour(s)
Online Percentage:	82.02 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2022 12:00	10/01/2022 14:00	Warm startup	3
2	10/02/2022 11:00	10/02/2022 13:00	Warm startup	3
3	10/09/2022 14:00	10/09/2022 15:00	Hot Startup	2
4	10/16/2022 17:00	10/16/2022 19:00	Warm startup	3
5	10/23/2022 20:00	10/23/2022 22:00	Warm startup	3
6	10/30/2022 19:00	10/30/2022 22:00	Cold Startup	4
7	11/06/2022 09:00	11/06/2022 11:00	Warm startup	3
8	11/07/2022 00:00	11/07/2022 01:00	Hot Startup	2
9	11/27/2022 21:00	11/27/2022 23:00	Warm startup	3
10	12/01/2022 02:00	12/01/2022 03:00	Hot Startup	2
11	12/25/2022 18:00	12/25/2022 20:00	Warm startup	3
12	12/27/2022 01:00	12/27/2022 02:00	Hot Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/17/2023 11:23 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	4	0.22
Hot Startup	4	8	0.44
Warm startup	7	21	1.16
Total Process Events:	12	33	1.82

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,811 Hour(s)
Total Startup Time:	33 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	33 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.82 %

ATTACHMENT 13
Water Bath Heater Operations

The Natural Gas Fired Water Bath Heater did not operate in the 4th Quarter of 2022.

ATTACHMENT 14
Toxics GHG Tracking

TOXICS TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2022

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test*	11.1	11.1	55544.40	27.772
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test*	0.022	0.022	110.09	0.055
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test*	2.6	2.6	12589.20	6.295
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test*	0.023	0.023	111.37	0.056
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	2.04	0.001
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.580	2196.93	1.098
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.080	303.08	0.152
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.056	213.28	0.107
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.076	287.04	0.144
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.097	4153.32	2.077
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.264	12363.76	6.182
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.202	766.52	0.383
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.301	1138.56	0.569
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.111	418.54	0.209
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.007	26.62	0.013
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	2.10	0.001

Total Turbines/HRSGs

Fuel Use Rate Data

NG HHV	1040	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.2338	mmscf	(for both units)
Annual Fuel Use	16036.00	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4403.15	mmbtu	(for both units)
Annual Heat Rate	16677440.0	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	5004	Hrs/Yr	
Unit #2 Annual Ops Hrs	4842	Hrs/Yr	
Total Hrs, All Units	9846	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	8155	mmscf	
CT2 Annual Fuel Use	7881	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0000	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0000	0.000	0.0000

Total FG Heater

Fuel Use Rate Data

NG HHV	1040	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00000	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	0.00	mmbtu
Annual Heat Rate	0.00	mmbtu

*Testing conducted Oct 11-14

Reporting Quarter 4

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Toxics Plan:

1. perform annual testing for ammonia per CCAPCD Permit Condition #9 (3-2-09)
2. perform annual testing for formaldehyde per CCAPCD Permit Condition #9 (3-2-09)
3. comply with all other provisions of CCAPCD Permit Condition #9 (3-2-09)
4. quantify other identified toxic pollutants via the emissions factors delineated in the AFC Appendix L (Public Health)
5. report toxic emissions to the CCAPCD annually and show compliance with CCAPCD Permit Condition #28 (3-2-09)

Data and Source References:

1. CGS plant and operational data (CEMS, DAHS, purchase records, and ops logs)
2. CCAR General Protocol, Version 3.1, January 2009.
3. CCAR Power Sector Protocol, Version 1.1, May 2009.
4. Other references as noted on the calculation tab.

Public

ATTACHMENT 15
Title V Certification Forms

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): October 1 - December 31, 2022
2. Due date for submittal of report: January 30, 2023

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)

Attachment 10: Maximum Emissions

Attachment 11: Linearity

Attachment 12: Startup / Shutdown Emissions

Attachment 13: Water Bath Heater Operations

Attachment 14: Toxic and GHG Reporting

Attachment 15: Title V Certification

If you have any questions regarding this submittal, please contact me at (530) 393-2926.

Sincerely,

TJ Gomez
Senior Environmental Field Specialist

cc: Josh Harris, PG&E
Sam Garcia, PG&E