

DOCKETED

Docket Number:	22-BSTD-01
Project Title:	2025 Energy Code Pre-Rulemaking
TN #:	248960
Document Title:	ConSol on behalf of CBIA Comments - CBIA Support for solar shade credit in compliance software
Description:	N/A
Filer:	System
Organization:	ConSol on behalf of CBIA
Submitter Role:	Public
Submission Date:	2/24/2023 3:10:45 PM
Docketed Date:	2/24/2023

Comment Received From: ConSol on behalf of CBIA
Submitted On: 2/24/2023
Docket Number: 22-BSTD-01

CBIA Support for solar shade credit in compliance software

Additional submitted attachment is included below.



1215 K Street, Suite 1200
Sacramento, CA 95814
(916) 443-7933
fax (916) 443-1960
www.cbia.org

2022 OFFICERS

Chair
MICHAEL BALSAMO
Rancho Mission Viejo

Vice Chair
JEFF SCHROEDER
Ponderosa Homes

Treasurer
CHRIS AUSTIN
DPFG

President/CEO
DAN DUNMOYER

MEMBER ASSOCIATIONS

Building Industry Association of the Bay Area

Building Industry Association of Fresno/Madera Counties

Building Industry Association of the Greater Valley

Building Industry Association of San Diego County

Building Industry Association of Southern California

Building Industry Association of Tulare & Kings Counties

Home Builders Association of the Central Coast

Home Builders Association of Kern County

North State Building Industry Association

November 29, 2022

Commissioner Andrew McAllister
California Energy Commission
715 P Street
Sacramento, CA 95814

RE: Solar Shade Credit

Dear Commissioner McAllister,

On behalf of CBIA I am writing to express our support for the addition of a compliance credit to the California Energy Commission's modeling software (CBECC and CBECC-Res) to allow proper credit to be given for the use of automated solar shades on windows.

The use of large window areas in commercial buildings increases the importance of proper shading control for both occupant comfort and energy efficiency. In residential buildings, the use of automated shades can compensate for the tendency of occupants to neglect to open and close shades.

According to the US DOE, "automated shade controls maximize the utility of natural light while preserving occupant visual comfort. Admitting more natural light enables daylight dimming controls to save lighting energy with an added benefit of saving s in cooling energy. Lighting energy in the daylit zone is significantly reduced via implementation of dimming controls". Energy savings are possible in all California Climate Zones, with "[t]he highest energy savings [...] possible in cooling-dominated climate zones due to lighting and HVAC interactive effects".

Typical dual pane windows will allow 70% of the solar heat to pass through to the interior. The use of automated shades allows building owners or tenants to use windows with a high visible transmittance to increase daylight harvesting while minimizing solar heat gain.

Studies show that energy savings upward of 20% are possible, with additional benefits of increased occupant comfort and productivity. Given that automated solar shades can be beneficial in both the new construction and the retrofit market, we request that the acceptance of this exceptional method request be treated as a priority.

Thank you in advance for your attention to this matter, and please don't hesitate o reach out if you have any questions regarding CBIA's support.

Sincerely,

Christopher E. Ochoa, Esq.
Senior Counsel
CBIA