

DOCKETED	
Docket Number:	21-SPPE-02
Project Title:	STACK Trade Zone Park
TN #:	249163
Document Title:	Santa Clara Valley Water District Comments on Draft Environmental Impact Report
Description:	N/A
Filer:	Lisa Worrall
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/15/2023 12:00:30 PM
Docketed Date:	3/15/2023

From: Shree Dharasker <sdharasker@valleywater.org>
Sent: Tuesday, March 14, 2023 6:02 PM
To: Worrall, Lisa@Energy <Lisa.Worrall@energy.ca.gov>
Cc: Michael Martin <MichaelMartin@valleywater.org>
Subject: RE: Trade Zone Boulevard Technology Park

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Lisa,

I received this comment after yesterday's deadline DEIR comment deadline. I was wondering if it can be included with Santa Clara Valley Water District (Valley Water) comments.

'Current Federal Emergency Management Agency (FEMA) Federal Insurance Rate Map (FIRM) Panel 06085C0069H, effective May 18, 2009 shows the subject site is located within a Special Flood Hazard Area (SFHA) Zone AO and would be subject to flood depths of 1 foot (usually areas of ponding). To comply with federal flood insurance regulations, the lowest floor and highest adjacent grade of any building, must be above the 1 percent water surface elevation. Valley Water recommends the lowest flood be a minimum of 2 feet above the 1 percent water surface elevation.'

Thanks,

Shree Dharasker
Associate Engineer Civil
Community Projects Review Unit
(408)630-3037