

DOCKETED

Docket Number:	22-BSTD-01
Project Title:	2025 Energy Code Pre-Rulemaking
TN #:	253250
Document Title:	Matthew Friedlander Comments - Multifamily Alterations should use ventilation systems per previous permits
Description:	N/A
Filer:	System
Organization:	Matthew Friedlander
Submitter Role:	Public
Submission Date:	11/17/2023 5:07:45 PM
Docketed Date:	11/20/2023

Comment Received From: Matthew Friedlander
Submitted On: 11/17/2023
Docket Number: 22-BSTD-01

Multifamily Alterations should use ventilation systems per previous permits

As proposed, Section 180.2(b)5Bia permits any type of ventilation system to be specified, the requirements of a previous permit. Please consider replacing the current 180.2(b)5Bia with the following:

Whole-dwelling unit ventilation strategy. The whole-dwelling unit ventilation system shall comply with the 160.2(b)2Aivb requirements for ventilation system type.
Exception to Section 180.2(b)5Bia: Dwellings that were not required by a previous building permit to have a supply ventilation system or balanced ventilation system.