

DOCKETED

Docket Number:	22-BSTD-01
Project Title:	2025 Energy Code Pre-Rulemaking
TN #:	253253
Document Title:	Matthew Friedlander Comments - Filter and HERV access via doors in walls
Description:	N/A
Filer:	System
Organization:	Matthew Friedlander
Submitter Role:	Public
Submission Date:	11/17/2023 5:01:31 PM
Docketed Date:	11/20/2023

Comment Received From: Matthew Friedlander
Submitted On: 11/17/2023
Docket Number: 22-BSTD-01

Filter and HERV access via doors in walls

When attic access is via a door in a wall rather than through a ceiling hatch, an integrated ladder is not needed. To clarify this, please consider the following insertions:

Exception to Section 150.0(o)1Civa: ...

2. ADD: "An attic access door located in a wall or, where attic access is provided through a ceiling,"

Exception to Section 160.2(b)2Axia: ...

2. ADD "An attic access door located in a wall or, where attic access is provided through a ceiling,"...