

DOCKETED	
Docket Number:	09-AFC-05C
Project Title:	Abengoa Mojave Compliance
TN #:	254874
Document Title:	Mahnaz Ghamati Comments - 2- Mojave Solar Project 2023 Annual Compliance Report (09-AFC-5C)
Description:	N/A
Filer:	System
Organization:	Mahnaz Ghamati
Submitter Role:	Applicant Representative
Submission Date:	3/6/2024 10:25:19 AM
Docketed Date:	3/6/2024

Comment Received From: Mahnaz Ghamati
Submitted On: 3/6/2024
Docket Number: 09-AFC-05C

2- Mojave Solar Project 2023 Annual Compliance Report (09-AFC-5C)


Additional submitted attachment is included below.

2023 Panel Pictures of Emergency Diesel Generator

AQ34


Alpha

E011042



Beta

E011043



Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Beda</i>					Date: <i>1-28-23</i>				
Operator: <i>Edgion</i>									
Main Generator Breaker			Comments						
Open									
Closed									
Engine			Comments						
Start Time:			<i>2244</i>						
Stop Time:			<i>2254</i>						
Total Run Time:			<i>10 min</i>						
Starting Hour Meter Reading			<i>564.5</i>		<i>564.7</i>				
Monthly Fuel Consumption(gal)									
Oil Level			<i>Good</i>						
Coolant Level			<i>Good</i>		Coolant Temp. @ Start <i>52°C</i>		Finish = <i>74°C</i>		
Belt Condition			<i>Good</i>						
Oil Pressure					Start = <i>0</i> bar		Finish = <i>7</i> bar		
Battery Condition			<i>Good</i>						
Battery Voltage			<i>26.7</i>						
Engine RPMs			<i>1800</i>						
Generator			Comments						
Generator Volts			<i>4.14</i>						
Generator Amps			<i>—</i>						
Generator "KVA"			<i>—</i>						
Reason For Use			Comments						
Testing			<i>✓</i>						
Emergency			<i>—</i>						
Maintenance			<i>—</i>						
Generator			Comments						
Fuel Delivered			<i>X</i>						
Fuel Level	<i>1/4</i>	<i>1/2</i>	<i>3/4</i>	<i>F</i>	<i>78%</i>				
Sulfur Concentrations <0.0015% (15ppm)			<i>X</i>						

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta Date: 1-23-23

Operator: Caleb Sowards

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	0220	
Stop Time:	0230	
Total Run Time:	10min	
Starting Hour Meter Reading	564.4	
Monthly Fuel Consumption(gal)		
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start 52 °c Finish=75 °c
Belt Condition	✓	
Oil Pressure	✓	Start = 8.3 bar Finish=7 bar
Battery Condition	✓	
Battery Voltage	26.7	
Engine RPMs	1800	
Generator		Comments
Generator Volts	N/A	
Generator Amps	N/A	
Generator "KVA"	N/A	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	No	
Fuel Level	1/4 1/2 3/4 F 78%	
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Beda</u>					Date: <u>1-15-23</u>				
Operator: <u>Ebrah</u>									
Main Generator Breaker			Comments						
Open									
Closed									
Engine			Comments						
Start Time:			<u>0742</u>						
Stop Time:			<u>0752</u>						
Total Run Time:			<u>10 min</u>						
Starting Hour Meter Reading			<u>564.2</u>		<u>ending 564.4</u>				
Monthly Fuel Consumption(gal)									
Oil Level			<u>Good</u>						
Coolant Level			<u>Good</u>		Coolant Temp. @ Start <u>52</u> °c		Finish = <u>74</u> °c		
Belt Condition			<u>Good</u>						
Oil Pressure					Start = <u>6</u> bar		Finish = <u>7.1</u> bar		
Battery Condition			<u>Good</u>						
Battery Voltage			<u>26.7</u>						
Engine RPMs			<u>1800</u>						
Generator			Comments						
Generator Volts			<u>4.17</u>						
Generator Amps			<u>—</u>						
Generator "KVA"			<u>—</u>						
Reason For Use			Comments						
Testing			<u>✓</u>						
Emergency			<u>—</u>						
Maintenance			<u>—</u>						
Generator			Comments						
Fuel Delivered			<u>—</u>						
Fuel Level	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>F</u>	<u>78 %</u>				
Sulfur Concentrations <0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 1/13/23

Operator: Anthony

Main Generator Breaker		Comments
Open	<u>—</u>	
Closed	<u>✓</u>	
Engine		Comments
Start Time:		
Stop Time:		<u>1622</u>
Total Run Time:		
Starting Hour Meter Reading		<u>520.5</u>
Monthly Fuel Consumption(gal)		<u>—</u>
Oil Level		<u>✓</u>
Coolant Level		Coolant Temp. @ Start °c Finish = <u>73</u> °c
Belt Condition	<u>✓</u>	
Oil Pressure		Start = bar Finish = <u>6.3</u> bar
Battery Condition	<u>✓</u>	
Battery Voltage	<u>27.5</u>	
Engine RPMs	<u>1800</u>	
Generator		Comments
Generator Volts		<u>4.18</u>
Generator Amps		<u>—</u>
Generator "KVA"		<u>—</u>
Reason For Use		Comments
Testing		<u>✓</u>
Emergency		<u>—</u>
Maintenance		<u>—</u>
Generator		Comments
Fuel Delivered		<u>—</u>
Fuel Level	1/4 1/2 <u>3/4</u> F	<u>78%</u>
Sulfur Concentrations <0.0015% (15ppm)		<u>—</u>

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Plant: A 10 km

Operator: PAT/ANTHONY

Date:	1/12/23
-------	---------

Comments: _____

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 1-9-23

Operator: Travis

Main Generator Breaker		Comments	
Open	<input checked="" type="checkbox"/>		
Closed	<input type="checkbox"/>		
Engine		Comments	
Start Time:	<u>0625</u>		
Stop Time:			
Total Run Time:			
Starting Hour Meter Reading	<u>414.0</u>		
Monthly Fuel Consumption(gal)			
Oil Level	<u>Good</u>		
Coolant Level	<u>Good</u>	Coolant Temp. @ Start <u>60</u> °C	Finish= °C
Belt Condition	<u>Good</u>		
Oil Pressure	<u>Good</u>	Start = <u>7.4</u> bar	Finish= bar
Battery Condition	<u>Good</u>		
Battery Voltage	<u>27.3</u>		
Engine RPMs	<u>1800</u>		
Generator		Comments	
Generator Volts	<u>410</u>		
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	<input type="checkbox"/>		
Emergency	<input type="checkbox"/>		
Maintenance	<input checked="" type="checkbox"/>		
Generator		Comments	
Fuel Delivered	<u>NO</u>		
Fuel Level	<u>51%</u>		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Bi-Hourly Readings

Plant: Alpha

Operator: Travis / Hinton

Date: 1-9-23

Time	Oil Psi.	Gen Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. kWh	Batt. Volts
0625	7.8	4.03	1800	60	51	414.6	37	0	27.3
0825	6.3	4.17	1799	75	48	416.6	74	962	27.5
1025	6.4	4.17	1800	76	46	418.6	74	959	27.5
1225	6.3	4.16	1800	76	43	420.6	75	979	27.5
1425	6.3	4.17	1799	76	70	422.6	75	976	27.5
1625	6.3	4.17	1800	74	67	424.6	76	951	27.5
1820	6.3	4.17	1800	76	64	426.5	75	973	27.5
2009	6.3	4.17	1800	76	59	429.2	73	858	27.5
2210	6.3	4.17	1800	76	56	431.2	74	902	27.5
0100	6.3	4.17	1800	76	53	433.2	74	880	27.5
0309	6.3	4.17	1800	75	50	435.3	73	846	27.6
0530	6.3	4.17	1799	75	48	437.6	74	855	27.6
0730	6.3	4.16	1800	75	45	439.6	73	852	27.5
0930	6.3	4.16	1800	75	41	441.6	74	834	27.5
1130	6.3	4.16	1800	75	38	443.6	73	796	27.6
1426	6.3	4.17	1800	75	67	444.6	74	827	27.4
1600	6.3	4.17	1800	75	59	451.2	73	911	27.6
1800	6.3	4.17	1800	75	56	453.3	73	890	27.6
2000	6.3	4.17	1800	75	54	455.4	73	875	27.5
2215	6.3	4.16	1800	75	52	457.4	73	882	27.5
0115	6.3	4.17	1800	74	46	460.4	73	868	27.6
0315	6.3	4.17	1800	74	46	460.4	73	868	27.6
0415	6.3	4.17	1800	74	46	460.4	73	868	27.6
0638	6.3	4.17	1799	74	40	464.8	73	838	27.5
1807	6.3	4.19	1800	74	73	474.3	73	697	27.6
2022	6.3	4.17	1800	75	69	476.5	73	817	27.6
2200	6.3	4.17	1800	75	66	478.2	73	904	27.6
2400	6.3	4.17	1800	74	63	480.2	73	890	27.6
0200	6.3	4.17	1800	74	60	482.2	73	887	27.6
0400	6.3	4.17	1800	75	58	484.5	73	865	27.6
0600	6.3	4.17	1800	75	54	486.9	73	845	27.6
0800	6.3	4.17	1800	75	51	488.6	73	847	27.6
1000	6.2	4.17	1800	75	49	490.2	73	846	27.5
1200	6.3	4.17	1800	75	45	492.9	73	806	27.5
1400	6.3	4.17	1800	74	44	494.1	73	534	27.5
1600	6.3	4.17	1800	74	41	496.6	73	521	27.5

Comments: Fuel delivered @ 1230 1-9-23

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Bedn*

Date: *1-7-23*

Operator: *E. Bary*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>2016</i>	
Stop Time:		<i>2026</i>	
Total Run Time:		<i>10 min</i>	
Starting Hour Meter Reading		<i>564.0</i> <i>Stop hrs 564.2</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>Good</i>	
Coolant Level		<i>Good</i> Coolant Temp. @ Start <i>51</i> °c Finish = <i>71</i> °c	
Belt Condition		<i>Good</i>	
Oil Pressure		Start = <i>6</i> bar Finish = <i>7.1</i> bar	
Battery Condition		<i>Good</i>	
Battery Voltage		<i>24.7</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>413</i>	
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing		<input checked="" type="checkbox"/>	
Emergency		<input type="checkbox"/>	
Maintenance		<input type="checkbox"/>	
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F	<i>78 1/2</i>	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Date: 01.05.23

Plant: Alpha Plant

Operator: TRAVIS

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:	1722		
Stop Time:	0732		
Total Run Time:	14hrs 10min		
Starting Hour Meter Reading	387.6		
Monthly Fuel Consumption(gal)			
Oil Level	Good		
Coolant Level	Good	Coolant Temp. @ Start	58°C Finish= 73°C
Belt Condition	Good		
Oil Pressure	Good	Start = 7.4 bar	Finish= 6.5 bar
Battery Condition	Good		
Battery Voltage	27.0		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.08		
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing			
Emergency			
Maintenance	✓		
Generator		Comments	
Fuel Delivered	NO		
Fuel Level	1/4 1/2 3/4 F 48%		
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 1/6/23

Operator: Anthony

Main Generator Breaker		Comments
Open	<u>—</u>	
Closed	<u>✓</u>	
Engine		Comments
Start Time:	<u>1850</u>	
Stop Time:	<u>1900</u>	
Total Run Time:	<u>10 min</u>	
Starting Hour Meter Reading	<u>402.0</u>	
Monthly Fuel Consumption(gal)	<u>—</u>	
Oil Level	<u>✓</u>	
Coolant Level		Coolant Temp. @ Start <u>63</u> °c Finish = <u>73</u> °c
Belt Condition	<u>✓</u>	
Oil Pressure		Start = <u>0.0</u> bar Finish = <u>6.6</u> bar
Battery Condition	<u>✓</u>	
Battery Voltage	<u>26.8</u>	
Engine RPMs	<u>1800</u>	
Generator		Comments
Generator Volts	<u>4.18</u>	
Generator Amps	<u>—</u>	
Generator "KVA"	<u>—</u>	
Reason For Use		Comments
Testing	<u>✓</u>	
Emergency	<u>✓</u>	
Maintenance	<u>—</u>	
Generator		Comments
Fuel Delivered	<u>—</u>	
Fuel Level	1/4 <u>(1/2)</u> 3/4 F	<u>59%</u>
Sulfur Concentrations <0.0015% (15ppm)	<u>—</u>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Alpha</i>		Date: <i>1/4/23</i>	
Operator: <i>PAT</i>			
Main Generator Breaker		Comments	
Open <input checked="" type="checkbox"/>			
Closed			
Engine		Comments	
Start Time: <i>16:39</i>			
Stop Time:			
Total Run Time:			
Starting Hour Meter Reading		<i>375</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<input checked="" type="checkbox"/>	
Coolant Level		<input checked="" type="checkbox"/>	
Coolant Temp. @ Start		<i>77</i> °C	
Coolant Temp. @ Finish		°C	
Belt Condition		<input checked="" type="checkbox"/>	
Oil Pressure		Start = <i>8.3</i> bar	
Oil Pressure		Finish = bar	
Battery Condition		<input checked="" type="checkbox"/>	
Battery Voltage		<i>26.9</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>4.16</i>	
Generator Amps		<i>102</i>	
Generator "KVA"		<i>3.97</i>	
Reason For Use		Comments	
Testing			
Emergency			
Maintenance		<input checked="" type="checkbox"/>	
Generator		Comments	
Fuel Delivered		<i>~0</i>	
Fuel Level	1/4 1/2 3/4 F	<i>65%</i>	
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha		Date: 2-26-23	
Operator: Tyronne			
Main Generator Breaker		Comments	
Open		✓	
Closed			
Engine		Comments	
Start Time:		2140	
Stop Time:		2150	
Total Run Time:		10min	
Starting Hour Meter Reading		521.3	
Monthly Fuel Consumption(gal)			
Oil Level		Normal	
Coolant Level		Coolant Temp. @ Start 63 °c Finish=73 °c	
Belt Condition		Normal	
Oil Pressure		Start = 0.0 bar Finish=6.7 bar	
Battery Condition		Normal	
Battery Voltage		26.9	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		1815	
Generator Amps		270	
Generator "KVA"		1963	
Reason For Use		Comments	
Testing		✓	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F	89%	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta

Date: 2-27-23

Operator: Caleb Sowards

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	0150		
Stop Time:	0200		
Total Run Time:	10 min		
Starting Hour Meter Reading	642.1	642.2	
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start 52 °c	Finish = 74 °c
Belt Condition	✓		
Oil Pressure	✓	Start = 8.4 bar	Finish = 6.9 bar
Battery Condition	✓		
Battery Voltage	26.7		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	Na		
Generator Amps	↓		
Generator "KVA"	↓		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	No		
Fuel Level	1/4 1/2 3/4 F	79	
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>BETA</i>					Date: <i>2-19-23</i>				
Operator: <i>ERICK</i>									
Main Generator Breaker			Comments						
Open			✓						
Closed									
Engine			Comments						
Start Time:			<i>1845</i>						
Stop Time:			<i>1855</i>						
Total Run Time:			<i>10</i>						
Starting Hour Meter Reading			<i>641.9 - 042.1</i>						
Monthly Fuel Consumption(gal)									
Oil Level			✓ <i>ADD</i>						
Coolant Level			✓ Coolant Temp. @ Start ≤ 1 °C Finish = <i>74</i> °C						
Belt Condition			✓						
Oil Pressure			Start = <i>8.3</i> bar Finish = <i>6.9</i> bar						
Battery Condition			✓						
Battery Voltage			<i>26.4</i>						
Engine RPMs			<i>1800</i>						
Generator			Comments						
Generator Volts			<i>4.17</i>						
Generator Amps			<i>168</i>						
Generator "KVA"			<i>0337</i>						
Reason For Use			Comments						
Testing			✓						
Emergency									
Maintenance									
Generator			Comments						
Fuel Delivered									
Fuel Level	1/4	1/2	3/4	F	<i>79.1</i>				
Sulfur Concentrations									
<0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Alpha</i>		Date: <i>2-10-23</i>	
Operator: <i>Erick Carrillo</i>			
Main Generator Breaker		Comments	
Open		✓	
Closed			
Engine		Comments	
Start Time:		<i>17:50</i>	
Stop Time:		<i>1800</i>	
Total Run Time:		<i>10</i>	
Starting Hour Meter Reading		<i>521.1</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>ADD</i>	
Coolant Level		✓	
Coolant Temp. @ Start		<i>53</i> °C	
Coolant Temp. @ Finish		<i>73</i> °C	
Belt Condition		✓	
Oil Pressure		Start = <i>7.7</i> bar	
Oil Pressure		Finish = <i>6.7</i> bar	
Battery Condition			
Battery Voltage		<i>27.2</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>1625</i>	
Generator Amps		<i>272</i>	
Generator "KVA"		<i>4.18</i>	
Reason For Use		Comments	
Testing		✓	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4	1/2	3/4
			(F) <i>88</i>
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Bi-Hourly Readings

Plant: <i>Beta</i>			Operator: <i>Edwin / Caleb</i>				Date: <i>2/13/23</i>		
Time	Oil Psi.	Gen Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. kWh	Batt. Volts
1421	6.8	4.13	1800	76	73%	568.4	75	635283	27.1
1622	6.7	4.16	1801	76	70%	570.5	75	635283	27.4
1800	6.7 Bay	4.14	1800	76	67	572.1	75	6941 kW	27.5
2000	6.2	4.16	1800	76	64	574.2	75	955	27.5
2200	6.17	4.14	1800	76	61	576.2	74	967	27.5
2400	6.7	4.17	1800	76	57	578.2	74	903	27.6
0000	6.7	4.13	1800	74	54	580.2	75	952	27.1
0200	6.7	4.16	1800	76	5.0	582.5	74	900	27.1
0400	6.7	4.16	1800	75	47	584.7	74	972	27.1
0638	6.7	4.16	1800	75	44	586.5	74	974	27.1
0825	6.7	4.13	1800	76	41	588.6	74	894	27.1
1032	6.6	4.16	1800	76	36	591.3	74	967	27.1
1313	6.6	4.16	1800	75	47.1	593.6	73	627	27.1
1532	6.7	4.16	1800	75	46	596.1	75	585	27.1
1800	6.6	4.13	1800	75	44	598.1	75	984	27.2
2000	6.6	4.14	1800	75	42	600.1	74	982	27.1
2200	6.6	4.14	1800	74	39	602.1	73	983	27.4
2400	6.5	4.16	1800	75	35	604.1	73	981	27.2
0000	6.6	4.16	1800	75	30	606.1	75	974	27.1
0200	6.5	4.113	1800	75	25	608.7	73	893	27.1
0400	6.6	4.12	1800	75	21%	611.0	73	822	27.2
0639	6.5	4.14	1800	75	20%	613.6	74	831	27.1
0857	6.5	4.16	1800	76	54%	615.8	74	868	27.1
1128	6.5	4.113	1800	76	50%	618.0	74	957	27.0
1342	6.5	4.15	1800	75	47%	620.4	73	789	27.1
1557	6.5	4.16	1800	75	43%	622.4	73	981	27.1
1805	6.5	4.13	1800	75	39	624.4	73	980	27.2
2005	6.5	4.13	1800	75	37	626.3	73	879	27.2
2205	6.5	4.13	1800	75	34	628.3	73	902	27.2
2400	6.5	4.14	1800	75	31	630.1	73	904	27.2
0000	6.5	4.13	1800	74	26%	632.8	73	997	27.1
0200	6.5	4.12	1800	75	90%	635.5	73	878	27.1
0400									
0643									
0923									

Comments: _____

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Bely*

Date: *2/13/23*

Operator: *E. Sre'm*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>1048</i>	
Stop Time:		<i>1548 of 2/16/23</i>	
Total Run Time:			
Starting Hour Meter Reading		<i>565.0</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>Good</i>	
Coolant Level		<i>Good</i>	
Belt Condition		<i>Good</i>	
Oil Pressure		Start = 0 bar	Finish = bar
Battery Condition		<i>Good</i>	
Battery Voltage		<i>26.7</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>4.18</i>	
Generator Amps			
Generator "KVA"		<i>1909</i>	
Reason For Use		Comments	
Testing		<i>—</i>	
Emergency		<i>—</i>	
Maintenance		<i>✓</i>	
Generator		Comments	
Fuel Delivered		<i>—</i>	
Fuel Level	1/4 1/2 3/4 F	<i>78%</i>	
Sulfur Concentrations <0.0015% (15ppm)		<i>—</i>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Bede Date: 2/10/23

Operator: E. Sain

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		2258	
Stop Time:		2308	
Total Run Time:		10 min	
Starting Hour Meter Reading		564.9	
Monthly Fuel Consumption(gal)			
Oil Level		Good	
Coolant Level		Good	
Coolant Temp. @ Start		52 °c	
Coolant Temp. @ Finish		74 °c	
Belt Condition		Good	
Oil Pressure		Start = 0 bar	
Oil Pressure		Finish = 7 bar	
Battery Condition		Good	
Battery Voltage		26.7	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		4.16	
Generator Amps		—	
Generator "KVA"		—	
Reason For Use		Comments	
Testing		✓	
Emergency		—	
Maintenance		—	
Generator		Comments	
Fuel Delivered		—	
Fuel Level	1/4 1/2 3/4 F	78%	
Sulfur Concentrations <0.0015% (15ppm)		—	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha					Date: 2-4-23				
Operator: Tyrone									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					2407				
Stop Time:					2417				
Total Run Time:					10 min				
Starting Hour Meter Reading					520.9				
Monthly Fuel Consumption(gal)									
Oil Level					normal				
Coolant Level					Coolant Temp. @ Start 36°C Finish=73°C				
Belt Condition					normal				
Oil Pressure					Start = 0.0 bar Finish=6.5 bar				
Battery Condition					normal				
Battery Voltage					26.8				
Engine RPMs					1800				
Generator					Comments				
Generator Volts					1554				
Generator Amps					240				
Generator "KVA"					1754				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					NO				
Fuel Level	1/4	1/2	3/4	F	89%				
Sulfur Concentrations <0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant:

BCH

Date:

2-4-23

Operator:

Tyone

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	1815	
Stop Time:	1825	
Total Run Time:	10 Min	
Starting Hour Meter Reading	564.7	
Monthly Fuel Consumption(gal)		
Oil Level	Normal	
Coolant Level		Coolant Temp. @ Start 50 °c Finish = 74 °c
Belt Condition	Normal	
Oil Pressure		Start = 0.0 bar Finish = 7.0 bar
Battery Condition	Normal	
Battery Voltage	26.7	
Engine RPMs	1800	
Generator		Comments
Generator Volts	1795	
Generator Amps	280	
Generator "KVA"	1980	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	No	
Fuel Level	1/4 1/2 (3/4) F	78%
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log										
Plant: <u>Alpha</u>					Date: <u>1/29/23</u>					
Operator: <u>Anthony</u>										
Main Generator Breaker			Comments							
Open										
Closed			✓							
Engine			Comments							
Start Time:			<u>0008</u>							
Stop Time:			<u>0018</u>							
Total Run Time:			<u>10 min</u>							
Starting Hour Meter Reading			<u>520.7</u>							
Monthly Fuel Consumption(gal)			—							
Oil Level			✓							
Coolant Level			Coolant Temp. @ Start				<u>64</u> °c		Finish = <u>73</u> °c	
Belt Condition			✓							
Oil Pressure			Start =				<u>0</u> bar		Finish = <u>6.4</u> bar	
Battery Condition			<u>Good</u>							
Battery Voltage			<u>26.9</u>							
Engine RPMs			<u>1800</u>							
Generator			Comments							
Generator Volts			<u>4.17</u>							
Generator Amps			—							
Generator "KVA"			—							
Reason For Use			Comments							
Testing			✓							
Emergency			—							
Maintenance			—							
Generator			Comments							
Fuel Delivered			—							
Fuel Level	1/4	1/2	<u>3/4</u>	F	<u>88%</u>					
Sulfur Concentrations <0.0015% (15ppm)			—							

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Alpha*

Date: *3/11/23*

Operator: *ETA*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>2:51</i>	
Stop Time:		<i>2:10</i>	
Total Run Time:		<i>10 min</i>	
Starting Hour Meter Reading		<i>521.6</i> <i>521.8 ending</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>Good</i>	
Coolant Level		<i>Good</i>	
Belt Condition		<i>Good</i>	
Oil Pressure		Start = <i>0</i> bar Finish = <i>7</i> bar	
Battery Condition		<i>Good</i>	
Battery Voltage		<i>26.9</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>409</i>	
Generator Amps		<i>-</i>	
Generator "KVA"		<i>-</i>	
Reason For Use		Comments	
Testing		<i>✓</i>	
Emergency		<i>-</i>	
Maintenance		<i>✓</i>	
Generator		Comments	
Fuel Delivered		<i>-</i>	
Fuel Level	1/4 1/2 3/4 F	<i>88%</i>	
Sulfur Concentrations <0.0015% (15ppm)		<i>-</i>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Beth</i>					Date: <i>3/11/23</i>				
Operator: <i>Edgar</i>									
Main Generator Breaker					Comments				
Open									
Closed									
Engine					Comments				
Start Time:					<i>2321</i>				
Stop Time:					<i>2331</i>				
Total Run Time:					<i>10 min</i>				
Starting Hour Meter Reading					<i>642.4</i> <i>642.6 ending</i>				
Monthly Fuel Consumption(gal)									
Oil Level					<i>Good</i>				
Coolant Level					<i>Good</i>				
Belt Condition					<i>Good</i>				
Oil Pressure					Start = <i>0</i> bar Finish = <i>6.9</i> bar				
Battery Condition					<i>Good</i>				
Battery Voltage					<i>26.7</i>				
Engine RPMs					<i>1800</i>				
Generator					Comments				
Generator Volts					<i>417</i>				
Generator Amps									
Generator "KVA"					<i>-</i>				
Reason For Use					Comments				
Testing					<i>✓</i>				
Emergency					<i>-</i>				
Maintenance					<i>-</i>				
Generator					Comments				
Fuel Delivered					<i>-</i>				
Fuel Level	1/4	1/2	3/4	F	<i>79%</i>				
Sulfur Concentrations <0.0015% (15ppm)					<i>-</i>				

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Alpha*

Date: *3-5-23*

Operator: *Caleb Sowards*

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	<i>1038</i>		
Stop Time:	<i>1048</i>		
Total Run Time:	<i>10min</i>		
Starting Hour Meter Reading	<i>521.4</i>	<i>521.6</i>	
Monthly Fuel Consumption(gal)			
Oil Level	<i>add</i>		
Coolant Level	✓	Coolant Temp. @ Start <i>64</i> °c	Finish = <i>73</i> °c
Belt Condition	✓		
Oil Pressure		Start = <i>6.4</i> bar	Finish = <i>6.8</i> bar
Battery Condition	<i>good</i>		
Battery Voltage	<i>26.9</i>		
Engine RPMs	<i>1800</i>		
Generator		Comments	
Generator Volts	<i>Na</i>		
Generator Amps	<i>Na</i>		
Generator "KVA"	<i>Na</i>		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<i>No</i>		
Fuel Level	<i>88</i>		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta

Date: 3-5-23

Operator: Caleb Sowards

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	9:50		
Stop Time:	1000		
Total Run Time:	10 min		
Starting Hour Meter Reading	642.2	642.4	
Monthly Fuel Consumption(gal)			
Oil Level	add		
Coolant Level	✓	Coolant Temp. @ Start 51 °c	Finish = 74 °c
Belt Condition	✓		
Oil Pressure		Start = 8.4 bar	Finish = 6.9 bar
Battery Condition	✓		
Battery Voltage	26.7		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	na		
Generator Amps	na		
Generator "KVA"	na		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	NO		
Fuel Level	1/4 1/2 3/4 F	79%	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log				
Plant: <u>Beta</u>		Date: <u>3/25/23</u>		
Operator: <u>Anthony</u>				
Main Generator Breaker		Comments		
Open		✓		
Closed				
Engine		Comments		
Start Time:		<u>2301</u>		
Stop Time:		<u>2311</u>		
Total Run Time:		<u>10 min</u>		
Starting Hour Meter Reading		<u>642.7</u>		
Monthly Fuel Consumption(gal)		<u> </u>		
Oil Level		✓		
Coolant Level		Coolant Temp. @ Start <u>52</u> °C Finish = <u>74</u> °C		
Belt Condition		✓		
Oil Pressure		Start = <u>0</u> bar Finish = <u>6.9</u> bar		
Battery Condition		✓		
Battery Voltage		<u>26.7</u>		
Engine RPMs		<u>1800</u>		
Generator		Comments		
Generator Volts		<u>41.15</u>		
Generator Amps		—		
Generator "KVA"		—		
Reason For Use		Comments		
Testing		✓		
Emergency		—		
Maintenance		—		
Generator		Comments		
Fuel Delivered		—		
Fuel Level	1/4 1/2 <u>(3/4)</u> F	<u>78%</u>		
Sulfur Concentrations <0.0015% (15ppm)		—		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>				

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Borden*

Date: *3/19/23*

Operator: *E. Sain*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>0939</i>	
Stop Time:		<i>0949</i>	
Total Run Time:		<i>10 min</i>	
Starting Hour Meter Reading		<i>642.6</i> <i>642.7</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>Good</i>	
Coolant Level		<i>Good</i>	
Belt Condition		<i>Good</i>	
Oil Pressure		Start = <i>0</i> bar Finish = <i>6.9</i> bar	
Battery Condition		<i>Good</i>	
Battery Voltage		<i>27.0</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>4.15</i>	
Generator Amps		<i>—</i>	
Generator "KVA"		<i>—</i>	
Reason For Use		Comments	
Testing		<i>✓</i>	
Emergency		<i>—</i>	
Maintenance		<i>—</i>	
Generator		Comments	
Fuel Delivered		<i>—</i>	
Fuel Level	1/4 1/2 3/4 F	<i>> 9 %</i>	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 3/25/23

Operator: Anthony

Main Generator Breaker		Comments
Open		
Closed		✓
Engine		Comments
Start Time:		2230
Stop Time:		2240
Total Run Time:		10 min
Starting Hour Meter Reading		521.9
Monthly Fuel Consumption(gal)		—
Oil Level		✓
Coolant Level		Coolant Temp. @ Start <u>60</u> °C Finish = <u>73</u> °C
Belt Condition		✓
Oil Pressure		Start = <u>0</u> bar Finish = <u>6.7</u> bar
Battery Condition		✓
Battery Voltage		26.9
Engine RPMs		1800
Generator		Comments
Generator Volts		4.17
Generator Amps		—
Generator "KVA"		—
Reason For Use		Comments
Testing		✓
Emergency		—
Maintenance		—
Generator		Comments
Fuel Delivered		—
Fuel Level	1/4 1/2 <u>3/4</u> F	88%
Sulfur Concentrations <0.0015% (15ppm)		—

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Alpha</u>					Date: <u>3/19/23</u>				
Operator: <u>Anthony</u>									
Main Generator Breaker					Comments				
Open									
Closed			<u>✓</u>						
Engine					Comments				
Start Time:			<u>2239</u>						
Stop Time:			<u>2249</u>						
Total Run Time:			<u>10 min</u>						
Starting Hour Meter Reading			<u>521.8</u>						
Monthly Fuel Consumption(gal)			<u>—</u>						
Oil Level			<u>✓</u>						
Coolant Level					Coolant Temp. @ Start <u>60</u> °c		Finish = <u>73</u> °c		
Belt Condition			<u>✓</u>						
Oil Pressure					Start = <u>0</u> bar		Finish = <u>6.7</u> bar		
Battery Condition			<u>✓</u>						
Battery Voltage			<u>27.2</u>						
Engine RPMs			<u>1800</u>						
Generator					Comments				
Generator Volts			<u>4.18</u>						
Generator Amps			<u>—</u>						
Generator "KVA"			<u>—</u>						
Reason For Use					Comments				
Testing			<u>✓</u>						
Emergency			<u>—</u>						
Maintenance			<u>—</u>						
Generator					Comments				
Fuel Delivered			<u>—</u>						
Fuel Level	1/4	1/2	<u>3/4</u>	F	<u>88%</u>				
Sulfur Concentrations <0.0015% (15ppm)			<u>—</u>						
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Alpha</u>					Date: <u>4-14-23</u>				
Operator: <u>Caleb Sowards</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>2140</u>				
Stop Time:					<u>2150</u>				
Total Run Time:					<u>10min</u>				
Starting Hour Meter Reading					<u>522.4</u> <u>522.6</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Coolant Temp. @ Start					<u>61</u> °c Finish = <u>74</u> °c				
Belt Condition					✓				
Oil Pressure					✓				
Start = <u>7.8</u> bar					Finish = <u>6.7</u> bar				
Battery Condition					✓				
Battery Voltage					<u>26.9</u>				
Engine RPMs					<u>1500</u>				
Generator					Comments				
Generator Volts					<u>N/A</u>				
Generator Amps					<u>N/A</u>				
Generator "KVA"					<u>N/A</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>88.40</u>				
Fuel Level	1/4	1/2	3/4	F	<u>NO</u>				
Sulfur Concentrations <0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <i>Alpha plant</i>					Date: <i>4-9-23</i>				
Operator: <i>Caleb Sowards</i>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<i>0330</i>				
Stop Time:					<i>0340</i>				
Total Run Time:					<i>10 min</i>				
Starting Hour Meter Reading					<i>522.3 522.4</i>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Belt Condition					✓				
Oil Pressure					✓				
Battery Condition					✓				
Battery Voltage					<i>26.8</i>				
Engine RPMs					<i>1800</i>				
Generator					Comments				
Generator Volts					<i>N/A</i>				
Generator Amps					<i>N/A</i>				
Generator "KVA"					<i>N/A</i>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<i>No</i>				
Fuel Level	1/4	1/2	3/4	F	<i>88</i>				
Sulfur Concentrations <0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta		Date: 4-23	
Operator: Erick Carrillo			
Main Generator Breaker		Comments	
Open		✓	
Closed			
Engine		Comments	
Start Time:		20:30	
Stop Time:		20:40	
Total Run Time:		10min	
Starting Hour Meter Reading		643.4 643.6	
Monthly Fuel Consumption(gal)			
Oil Level		ADD	
Coolant Level		✓	
Coolant Temp. @ Start		51 °c	
Coolant Temp. @ Finish		75 °c	
Belt Condition		✓	
Oil Pressure		✓	
Start =		7.9 bar	
Finish =		6.9 bar	
Battery Condition		✓	
Battery Voltage		27.0	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		4.15	
Generator Amps		296	
Generator "KVA"		1949.	
Reason For Use		Comments	
Testing		✓	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 (3/4) F	79%	
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log					
Plant: <u>Beta</u>				Date: <u>4/14/23</u>	
Operator: <u>Caleb Sowards</u>					
Main Generator Breaker		Comments			
Open		✓			
Closed					
Engine		Comments			
Start Time:		<u>2050</u>			
Stop Time:		<u>2100</u>			
Total Run Time:		<u>10min</u>			
Starting Hour Meter Reading		<u>643.2</u> <u>643.4</u>			
Monthly Fuel Consumption(gal)					
Oil Level		✓ Look Like turbos are going Bad			
Coolant Level		✓ Coolant Temp. @ Start <u>52</u> °c Finish = <u>75</u> °c			
Belt Condition		✓			
Oil Pressure		✓ Start = <u>8.4</u> bar Finish = <u>6.9</u> bar			
Battery Condition		✓			
Battery Voltage		<u>26.7</u>			
Engine RPMs		<u>1800</u>			
Generator		Comments			
Generator Volts		<u>N/A</u>			
Generator Amps		<u>N/A</u>			
Generator "KVA"		<u>N/A</u>			
Reason For Use		Comments			
Testing		✓			
Emergency					
Maintenance					
Generator		Comments			
Fuel Delivered		<u>7990</u>			
Fuel Level	1/4	1/2	3/4	F	
Sulfur Concentrations					
<0.0015% (15ppm)					
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>					

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Beta plant*

Date: *4/8/23*

Operator: *Caleb Sowards*

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	<i>0350</i>		
Stop Time:	<i>0400</i>		
Total Run Time:	<i>10min</i>		
Starting Hour Meter Reading	<i>643.1</i>	<i>643.2</i>	
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start <i>53</i> °c	Finish = <i>74</i> °c
Belt Condition	✓		
Oil Pressure	✓	Start = <i>8.4</i> bar	Finish = <i>6.9</i> bar
Battery Condition	✓		
Battery Voltage	<i>26.7</i>		
Engine RPMs	<i>1800</i>		
Generator		Comments	
Generator Volts	<i>N/A</i>		
Generator Amps	<i>N/A</i>		
Generator "KVA"	<i>N/A</i>		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<i>No</i>		
Fuel Level	<i>78</i>		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Beta*

Date: *4-2-23*

Operator: *Caleb Sowards*

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	<i>0420</i>		
Stop Time:	<i>0430</i>		
Total Run Time:	<i>10min</i>		
Starting Hour Meter Reading	<i>642.9 643.1</i>		
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start <i>52</i> °c	Finish = <i>74</i> °c
Belt Condition	✓		
Oil Pressure	✓	Start = <i>8.6</i> bar	Finish = <i>6.1</i> bar
Battery Condition	<i>26.7</i>		
Battery Voltage	✓		
Engine RPMs	<i>1800</i>		
Generator		Comments	
Generator Volts	<i>N/a</i>		
Generator Amps	<i>N/a</i>		
Generator "KVA"	<i>N/a</i>		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<i>NO</i>		
Fuel Level	1/4 1/2 3/4 F		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <u>Alpha</u>					Date: <u>4-2-23</u>				
Operator: <u>Caleb Sowards</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>02:27</u>				
Stop Time:					<u>02:37</u>				
Total Run Time:					<u>10 min</u>				
Starting Hour Meter Reading					<u>522.1</u> <u>522.3</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Belt Condition					✓				
Oil Pressure					✓				
Battery Condition					✓				
Battery Voltage					<u>26.9</u>				
Engine RPMs									
Generator					Comments				
Generator Volts					<u>N/A</u>				
Generator Amps					<u>N/A</u>				
Generator "KVA"					<u>N/A</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>88 No</u>				
Fuel Level	1/4	1/2	3/4	F	<u>88</u>				
Sulfur Concentrations <0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log					
Plant: <i>Beda</i>				Date: <i>5/15/23</i>	
Operator: <i>Edra</i>					
Main Generator Breaker			Comments		
Open					
Closed					
Engine			Comments		
Start Time:		<i>0026</i>			
Stop Time:		<i>0036</i>			
Total Run Time:		<i>10 min</i>			
Starting Hour Meter Reading		<i>643.9</i>			
Monthly Fuel Consumption(gal)					
Oil Level		<i>Good</i>			
Coolant Level		<i>Good</i>	Coolant Temp. @ Start <i>50</i> °c Finish <i>75</i> °c		
Belt Condition		<i>Good</i>			
Oil Pressure			Start = <i>0</i> bar Finish = <i>6.9</i> bar		
Battery Condition		<i>Good</i>			
Battery Voltage		<i>26.7</i>			
Engine RPMs		<i>1800</i>			
Generator			Comments		
Generator Volts		<i>4.15</i>			
Generator Amps		<i>—</i>			
Generator "KVA"		<i>—</i>			
Reason For Use			Comments		
Testing		<i>✓</i>			
Emergency		<i>—</i>			
Maintenance		<i>—</i>			
Generator			Comments		
Fuel Delivered		<i>—</i>			
Fuel Level	1/4	1/2	3/4	F	<i>79 %</i>
Sulfur Concentrations <0.0015% (15ppm)		<i>—</i>			
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>					

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: BETA

Date: 5.6.23

Operator: TRAVIS

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	1832	
Stop Time:	1842	
Total Run Time:	10 MIN	
Starting Hour Meter Reading	643.8	
Monthly Fuel Consumption(gal)	-	
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start 52 °c Finish = 74 °c
Belt Condition	✓	
Oil Pressure		Start = 8.0 bar Finish = 6.9 bar
Battery Condition	✓	
Battery Voltage	26.7	
Engine RPMs	1800	
Generator		Comments
Generator Volts	4.16	
Generator Amps	550	
Generator "KVA"	3880	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	NO	
Fuel Level	1/4 1/2 3/4 F 78	
Sulfur Concentrations <0.0015% (15ppm)	-	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Beta</u>					Date: <u>5.26.23</u>				
Operator: <u>Trauw</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>0141</u>				
Stop Time:					<u>0151</u>				
Total Run Time:					<u>10 MIN</u>				
Starting Hour Meter Reading					<u>644.3</u>				
Monthly Fuel Consumption(gal)					<u>N/A</u>				
Oil Level					<u>Good</u>				
Coolant Level					<u>Good</u>				
Belt Condition					<u>Good</u>				
Oil Pressure					Start = <u>80</u> bar Finish = <u>4.9</u> bar				
Battery Condition					<u>Good</u>				
Battery Voltage					<u>26.9</u>				
Engine RPMs					<u>1800</u>				
Generator					Comments				
Generator Volts					<u>4.16</u>				
Generator Amps					<u>2560</u>				
Generator "KVA"					<u>1909</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>NO</u>				
Fuel Level	1/4	1/2	3/4	F	<u>79%</u>				
Sulfur Concentrations <0.0015% (15ppm)					<u>N/A</u>				
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log				
Plant: <u>Beta</u>		Date: <u>5/21/23</u>		
Operator: <u>Anthony</u>				
Main Generator Breaker			Comments	
Open				
Closed		✓		
Engine			Comments	
Start Time:		<u>0333</u>		
Stop Time:		<u>0343</u>		
Total Run Time:		<u>10min</u>		
Starting Hour Meter Reading		<u>644.1</u>		
Monthly Fuel Consumption(gal)		<u>—</u>		
Oil Level		✓		
Coolant Level			Coolant Temp. @ Start <u>52</u> °c Finish = <u>75</u> °c	
Belt Condition		✓		
Oil Pressure			Start = <u>0</u> bar Finish = <u>6.8</u> bar	
Battery Condition		✓		
Battery Voltage		<u>26.7</u>		
Engine RPMs		<u>1800</u>		
Generator			Comments	
Generator Volts		<u>4.16</u>		
Generator Amps		<u>—</u>		
Generator "KVA"		<u>—</u>		
Reason For Use			Comments	
Testing		✓		
Emergency		<u>—</u>		
Maintenance		<u>—</u>		
Generator			Comments	
Fuel Delivered		<u>—</u>		
Fuel Level	1/4	1/2	<u>(3/4)</u>	F <u>80%</u>
Sulfur Concentrations <0.0015% (15ppm)		<u>—</u>		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>				

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha					Date: 5-25-23				
Operator: Erick Carrillo									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					23:20				
Stop Time:					23:30				
Total Run Time:					10 Min				
Starting Hour Meter Reading					523.4 523.6				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Belt Condition					✓				
Oil Pressure					Start = 7.9 bar Finish = 6.7 bar				
Battery Condition					✓				
Battery Voltage					27.4 Terminals need to be replaced & cable ends.				
Engine RPMs					1800				
Generator					Comments				
Generator Volts					4.18				
Generator Amps					320				
Generator "KVA"					2049				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance					✓				
Generator					Comments				
Fuel Delivered									
Fuel Level					1/4 1/2 3/4 F 881				
Sulfur Concentrations <0.0015% (15ppm)					Coolant Hose needs to be replaced.				

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log				
Plant: <u>Alpha</u>			Date: <u>5/20/23</u>	
Operator: <u>Anthony</u>				
Main Generator Breaker			Comments	
Open				
Closed		✓		
Engine			Comments	
Start Time:		<u>2333</u>		
Stop Time:		<u>2343</u>		
Total Run Time:		<u>10 min</u>		
Starting Hour Meter Reading		<u>523.3</u>		
Monthly Fuel Consumption(gal)		<u>—</u>		
Oil Level		✓		
Coolant Level			Coolant Temp. @ Start <u>60</u> °c Finish= <u>74</u> °c	
Belt Condition		✓		
Oil Pressure			Start = <u>0</u> bar Finish= <u>6.7</u> bar	
Battery Condition		✓		
Battery Voltage		<u>26.9</u>		
Engine RPMs		<u>1800</u>		
Generator			Comments	
Generator Volts		<u>4.17</u>		
Generator Amps		<u>—</u>		
Generator "KVA"		<u>—</u>		
Reason For Use			Comments	
Testing		✓		
Emergency		<u>—</u>		
Maintenance		<u>—</u>		
Generator			Comments	
Fuel Delivered		<u>—</u>		
Fuel Level	1/4	1/2	<u>(3/4)</u>	F <u>89%</u>
Sulfur Concentrations <0.0015% (15ppm)		<u>—</u>		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log					
Plant: <i>Alpha</i>				Date: <i>5/14/23</i>	
Operator: <i>E. Garcia</i>					
Main Generator Breaker		Comments			
Open					
Closed					
Engine		Comments			
Start Time:		<i>2002</i>			
Stop Time:		<i>2012</i>			
Total Run Time:		<i>10 min</i>			
Starting Hour Meter Reading		<i>523.7</i>			
Monthly Fuel Consumption(gal)					
Oil Level		<i>Good</i>			
Coolant Level		<i>Good</i>			
Coolant Temp. @ Start		<i>61 °C</i>			
Coolant Temp. @ Finish		<i>74 °C</i>			
Belt Condition		<i>Good</i>			
Oil Pressure		Start = <i>0</i> bar Finish = <i>67</i> bar			
Battery Condition		<i>Good</i>			
Battery Voltage		<i>26.8</i>			
Engine RPMs		<i>1800</i>			
Generator		Comments			
Generator Volts		<i>394</i>			
Generator Amps		<i>—</i>			
Generator "KVA"		<i>—</i>			
Reason For Use		Comments			
Testing		<i>✓</i>			
Emergency		<i>—</i>			
Maintenance		<i>—</i>			
Generator		Comments			
Fuel Delivered		<i>—</i>			
Fuel Level	1/4	1/2	3/4	F	<i>89 1/2</i>
Sulfur Concentrations <0.0015% (15ppm)					
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>					

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: Alpha					Date: 5.5.23				
Operator: TRAVIS									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					2218				
Stop Time:					2228				
Total Run Time:					10 Min				
Starting Hour Meter Reading					523.0				
Monthly Fuel Consumption(gal)					-				
Oil Level					✓				
Coolant Level					✓				
					Coolant Temp. @ Start 51 °c Finish=74 °c				
Belt Condition					✓				
Oil Pressure					Start = 7.8 bar Finish=4.7 bar				
Battery Condition					✓				
Battery Voltage					26.9				
Engine RPMs					1800				
Generator					Comments				
Generator Volts					4.16				
Generator Amps					296				
Generator "KVA"					3145				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					NO				
Fuel Level	1/4	1/2	3/4	F	88%				
Sulfur Concentrations <0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log					
Plant: Alpha				Date: 6.9.23	
Operator: Travis					
Main Generator Breaker			Comments		
Open		✓			
Closed					
Engine			Comments		
Start Time:		2254			
Stop Time:		2304			
Total Run Time:		10 MIN			
Starting Hour Meter Reading		523.8			
Monthly Fuel Consumption(gal)		N/A			
Oil Level		Good			
Coolant Level		Good	Coolant Temp. @ Start 62 °c Finish= 76 °c		
Belt Condition		Good			
Oil Pressure			Start = 8.1 bar Finish= 6.7 bar		
Battery Condition		Good			
Battery Voltage		26.4			
Engine RPMs		1800			
Generator			Comments		
Generator Volts		4.14			
Generator Amps		320			
Generator "KVA"		3145			
Reason For Use			Comments		
Testing		✓			
Emergency					
Maintenance					
Generator			Comments		
Fuel Delivered		NO			
Fuel Level	1/4	1/2	3/4	F	88%
Sulfur Concentrations <0.0015% (15ppm)		N/A			
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>					

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 6-4-23

Operator: Caleb S.

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	<u>1010</u>		
Stop Time:	<u>1020</u>		
Total Run Time:	<u>10min</u>		
Starting Hour Meter Reading	<u>52316</u>	<u>523.8</u>	
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start <u>63</u> °C	Finish = <u>74</u> °C
Belt Condition	✓		
Oil Pressure	✓	Start = <u>8.0</u> bar	Finish = <u>6.7</u> bar
Battery Condition	✓		
Battery Voltage	<u>27.4</u>		
Engine RPMs	<u>1800</u>		
Generator		Comments	
Generator Volts	<u>N/A</u>		
Generator Amps	<u>N/A</u>		
Generator "KVA"	<u>N/A</u>		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<u>No</u>		
Fuel Level	1/4 1/2 3/4 F <u>88</u>		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: **Beta**

Date: **6.9.23**

Operator: **Travis**

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	2121		
Stop Time:	2131		
Total Run Time:	10 min		
Starting Hour Meter Reading	644.6		
Monthly Fuel Consumption(gal)	N/A		
Oil Level	Good		
Coolant Level	Good	Coolant Temp. @ Start	50 °c
Belt Condition	Good	Finish	=75 °c
Oil Pressure		Start =	8.5 bar
Battery Condition	Good	Finish	=6.9 bar
Battery Voltage	26.0		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.15		
Generator Amps	272		
Generator "KVA"	1909		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	NO		
Fuel Level	1/4 1/2 3/4 F	78%	
Sulfur Concentrations <0.0015% (15ppm)	N/A		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log					
Plant: <u>Beta</u>				Date: <u>6-4-23</u>	
Operator: <u>Caleb S</u>					
Main Generator Breaker			Comments		
Open		✓			
Closed					
Engine			Comments		
Start Time:		<u>0045</u>			
Stop Time:		<u>0055</u>			
Total Run Time:		<u>10 min</u>			
Starting Hour Meter Reading		<u>644.4</u>	<u>644.6</u>		
Monthly Fuel Consumption(gal)					
Oil Level		✓			
Coolant Level		✓	Coolant Temp. @ Start <u>49</u> °c Finish = <u>75</u> °c		
Belt Condition		✓			
Oil Pressure		✓	Start = <u>80</u> bar Finish <u>81</u> bar		
Battery Condition		✓			
Battery Voltage		<u>26.7</u>			
Engine RPMs		<u>1800</u>			
Generator			Comments		
Generator Volts		<u>N/A</u>			
Generator Amps		<u>N/A</u>			
Generator "KVA"		<u>N/A</u>			
Reason For Use			Comments		
Testing		✓			
Emergency					
Maintenance					
Generator			Comments		
Fuel Delivered		<u>NO</u>			
Fuel Level	1/4	1/2	3/4	F	<u>79%</u>
Sulfur Concentrations <0.0015% (15ppm)					
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>					

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Beta</i>		Date: <i>7-15-23</i>	
Operator: <i>Isaiah</i>			
Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>2340</i>	
Stop Time:		<i>2350</i>	
Total Run Time:		<i>10</i>	
Starting Hour Meter Reading		<i>645.4</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>LOW</i>	
Coolant Level		<i>✓</i>	
Belt Condition		<i>✓</i>	
Oil Pressure		Start = <i>0</i> bar	
Battery Condition		Finish = <i>6.9</i> bar	
Battery Voltage		<i>26.7</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>41.4</i>	
Generator Amps		<i>—</i>	
Generator "KVA"		<i>—</i>	
Reason For Use		Comments	
Testing		<i>✓</i>	
Emergency		<i>—</i>	
Maintenance		<i>—</i>	
Generator		Comments	
Fuel Delivered		<i>—</i>	
Fuel Level	1/4 1/2 3/4 F	<i>78%</i>	
Sulfur Concentrations <0.0015% (15ppm)		<i>—</i>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Alpha</i>		Date: <i>7/29/25</i>	
Operator: <i>PAT</i>			
Main Generator Breaker			Comments
Open		✓	
Closed			
Engine			Comments
Start Time:		<i>20:22</i>	
Stop Time:		<i>20:32</i>	
Total Run Time:		<i>10 min</i>	
Starting Hour Meter Reading		<i>525</i>	
Monthly Fuel Consumption(gal)			
Oil Level		✓	
Coolant Level		✓	Coolant Temp. @ Start <i>62°C</i> Finish = <i>75°C</i>
Belt Condition		✓	
Oil Pressure			Start = <i>7.6 bar</i> Finish = <i>6.6 bar</i>
Battery Condition		✓	
Battery Voltage		<i>27.1</i>	
Engine RPMs		<i>1800</i>	
Generator			Comments
Generator Volts		<i>4.17</i>	
Generator Amps			
Generator "KVA"			
Reason For Use			Comments
Testing		✓	
Emergency			
Maintenance			
Generator			Comments
Fuel Delivered		<i>14</i>	
Fuel Level	1/4 1/2 3/4 F	<i>88%</i>	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha Date: 7/21/20

Operator: VAT

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	1:20	
Stop Time:	1:30	
Total Run Time:	10 min.	
Starting Hour Meter Reading	524.8	
Monthly Fuel Consumption(gal)		
Oil Level	✓	
Coolant Level		Coolant Temp. @ Start 63 °c Finish=75 °c
Belt Condition		good
Oil Pressure		Start = 6.0 bar Finish=6.6 bar
Battery Condition	good	
Battery Voltage	26.8	
Engine RPMs	1800	
Generator		Comments
Generator Volts	416	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	NO	
Fuel Level	1/4 1/2 3/4 F	89 %
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Notes: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <u>Beta 1</u>					Date: <u>7-29-23</u>
Operator: <u>Erick</u>					
Main Generator Breaker			Comments		
Open		<input checked="" type="checkbox"/>			
Closed					
Engine			Comments		
Start Time:		<u>20:40</u>			
Stop Time:		<u>20:50</u>			
Total Run Time:		<u>10</u>			
Starting Hour Meter Reading		<u>645.8</u>	<u>645.8</u>		
Monthly Fuel Consumption(gal)					
Oil Level		<input checked="" type="checkbox"/>	<u>inbetween Add - Full</u>		
Coolant Level		<u>A/A</u>	Coolant Temp. @ Start <u>52</u> °C	Finish = <u>75</u> °C	
Belt Condition		<u>Good</u>			
Oil Pressure			Start = <u>8.1</u> bar	Finish = <u>6.8</u> bar	
Battery Condition		<u>Good</u>			
Battery Voltage		<u>27.0</u>			
Engine RPMs		<u>1800</u>			
Generator			Comments		
Generator Volts		<u>4.16</u>			
Generator Amps		<u>360</u>			
Generator "KVA"		<u>2314</u>			
Reason For Use			Comments		
Testing		<input checked="" type="checkbox"/>			
Emergency					
Maintenance					
Generator			Comments		
Fuel Delivered					
Fuel Level	1/4	1/2	3/4	F	<u>78%</u>
Sulfur Concentrations <0.0015% (15ppm)					

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *BETA*

Date: *7/22/23*

Operator: *Diego Rodriguez*

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	<i>0348</i>	
Stop Time:	<i>0358</i>	
Total Run Time:	<i>10 mins.</i>	
Starting Hour Meter Reading	<i>645.6.</i>	<i>645.8 Finish Time</i>
Monthly Fuel Consumption(gal)	<input checked="" type="checkbox"/>	
Oil Level	<input checked="" type="checkbox"/>	
Coolant Level	<input checked="" type="checkbox"/>	Coolant Temp. @ Start <i>51</i> °c Finish = <i>74</i> °c
Belt Condition	<input checked="" type="checkbox"/>	
Oil Pressure	<input checked="" type="checkbox"/>	Start = <i>50</i> bar <i>7.8</i> Finish = <i>75</i> bar <i>6.9</i>
Battery Condition	<input checked="" type="checkbox"/>	<i>Need to be cleaned.</i>
Battery Voltage	<i>26.6.</i>	
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts	<i>416.</i>	
Generator Amps	<i>272</i>	
Generator "KVA"	<i>1621.</i>	
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered	<i>ND.</i>	
Fuel Level	1/4 1/2 <input checked="" type="checkbox"/> 3/4 F	<i>79%</i>
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha Date: 7-15-25

Operator: J. Saqah

Main Generator Breaker		Comments	
Open	-		
Closed	-		
Engine		Comments	
Start Time:	<u>0006</u>		
Stop Time:	<u>0016</u>		
Total Run Time:	<u>10</u>		
Starting Hour Meter Reading	<u>524.6</u>		
Monthly Fuel Consumption(gal)	<u>-</u>		
Oil Level	<u>LOW</u>		
Coolant Level	<u>✓</u>	Coolant Temp. @ Start <u>62c</u>	Finish = <u>75c</u>
Belt Condition	<u>✓</u>		
Oil Pressure		Start = <u>0</u> bar	Finish <u>6.6</u> bar
Battery Condition	<u>✓</u>		
Battery Voltage	<u>26.8</u>		
Engine RPMs	<u>1800</u>		
Generator		Comments	
Generator Volts	<u>41.18</u>		
Generator Amps	<u>-</u>		
Generator "KVA"	<u>-</u>		
Reason For Use		Comments	
Testing	<u>✓</u>		
Emergency	<u>-</u>		
Maintenance	<u>-</u>		
Generator		Comments	
Fuel Delivered	<u>-</u>		
Fuel Level	1/4 1/2 3/4 F <u>89%</u>		
Sulfur Concentrations <0.0015% (15ppm)	<u>-</u>		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha Date: 7-10-23

Operator: SSopal

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<u>0019</u>	
Stop Time:		<u>0029</u>	
Total Run Time:		<u>10min</u>	
Starting Hour Meter Reading		<u>524.5</u>	
Monthly Fuel Consumption(gal)		<u>/</u>	
Oil Level		<u>Low</u>	
Coolant Level		<u>✓</u>	
Coolant Temp. @ Start		<u>61</u> °C	
Coolant Temp. @ Finish		<u>74</u> °C	
Belt Condition		<u>✓</u>	
Oil Pressure		<u>0</u>	
Start =		<u>0</u> bar	
Finish =		<u>6.6</u> bar	
Battery Condition		<u>✓</u>	
Battery Voltage		<u>26.8</u>	
Engine RPMs		<u>1800</u>	
Generator		Comments	
Generator Volts		<u>3.99</u>	
Generator Amps		<u>/</u>	
Generator "KVA"		<u>/</u>	
Reason For Use		Comments	
Testing		<u>✓</u>	
Emergency		<u>/</u>	
Maintenance		<u>/</u>	
Generator		Comments	
Fuel Delivered		<u>X</u>	
Fuel Level	1/4 1/2 3/4 F	<u>88%</u>	
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha Date: 7/2/23

Operator: Anthony

Main Generator Breaker		Comments	
Open			
Closed		✓	
Engine		Comments	
Start Time:		2341	
Stop Time:		2351	
Total Run Time:		10 min	
Starting Hour Meter Reading		524.3	
Monthly Fuel Consumption(gal)		—	
Oil Level		Good	
Coolant Level		Coolant Temp. @ Start 63 °c Finish=75 °c	
Belt Condition		Good	
Oil Pressure		Start = 0 bar Finish=6.6 bar	
Battery Condition		Good	
Battery Voltage		26.8	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		4.16	
Generator Amps		—	
Generator "KVA"		—	
Reason For Use		Comments	
Testing		✓	
Emergency		—	
Maintenance		—	
Generator		Comments	
Fuel Delivered		—	
Fuel Level	1/4 1/2 <u>3/4</u> F	89%.	
Sulfur Concentrations <0.0015% (15ppm)		—	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta Date: 7-10-25

Operator: SSQAL

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<u>0147</u>	
Stop Time:		<u>0157</u>	
Total Run Time:		<u>10 mins</u>	
Starting Hour Meter Reading		<u>645.3</u>	
Monthly Fuel Consumption(gal)		<u>-</u>	
Oil Level		<u>✓</u>	
Coolant Level		<u>✓</u>	
Belt Condition		<u>✓</u>	
Oil Pressure		<u>0</u>	
Battery Condition		<u>✓</u>	
Battery Voltage		<u>26.7</u>	
Engine RPMs			
Generator		Comments	
Generator Volts		<u>416</u>	
Generator Amps		<u>-</u>	
Generator "KVA"		<u>-</u>	
Reason For Use		Comments	
Testing		<u>✓</u>	
Emergency		<u>-</u>	
Maintenance		<u>-</u>	
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F	<u>79%</u>	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta

Date: 7.2.23

Operator: Travis

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	2330	
Stop Time:	2340	
Total Run Time:	10 MIN	
Starting Hour Meter Reading	645.1	
Monthly Fuel Consumption(gal)	N/A	
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start 51 °c Finish=75 °c
Belt Condition	✓	
Oil Pressure	✓	Start = 8.3 bar Finish=6.9 bar
Battery Condition	✓	
Battery Voltage	25.8	
Engine RPMs	1800	
Generator		Comments
Generator Volts	4.16	
Generator Amps	328	
Generator "KVA"	1909	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	NO	
Fuel Level	1/4 1/2 3/4 F 78%	
Sulfur Concentrations <0.0015% (15ppm)	N/A	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Beh</i>					Date: <i>8/26/23</i>				
Operator: <i>E. Sain</i>									
Main Generator Breaker					Comments				
Open									
Closed									
Engine					Comments				
Start Time:					<i>0555</i>				
Stop Time:					<i>0605</i>				
Total Run Time:					<i>10 min</i>				
Starting Hour Meter Reading					<i>646.3</i> 646.5 <i>CAN1 communication alarm</i>				
Monthly Fuel Consumption(gal)									
Oil Level					<i>Good</i>				
Coolant Level					<i>Good</i>				
Belt Condition					<i>Good</i>				
Oil Pressure					Start = <i>0</i> bar Finish = <i>6.9</i> bar				
Battery Condition					<i>Good</i>				
Battery Voltage					<i>26.7</i>				
Engine RPMs					<i>1800</i>				
Generator					Comments				
Generator Volts					<i>4.13</i>				
Generator Amps					<i>—</i>				
Generator "KVA"					<i>—</i>				
Reason For Use					Comments				
Testing					<i>✓</i>				
Emergency					<i>—</i>				
Maintenance					<i>—</i>				
Generator					Comments				
Fuel Delivered					<i>—</i>				
Fuel Level	1/4	1/2	3/4	F	<i>78%</i>				
Sulfur Concentrations <0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Beta</i>		Date: <i>8-18-23</i>	
Operator: <i>E. Perry</i>			
Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:		<i>0154</i>	
Stop Time:		<i>0204</i>	
Total Run Time:		<i>10 min</i>	
Starting Hour Meter Reading		<i>646.3</i>	
Monthly Fuel Consumption(gal)			
Oil Level		<i>Good</i>	
Coolant Level		<i>Good</i>	
Belt Condition		<i>Good</i>	
Oil Pressure		Start = <i>0</i> bar Finish = <i>6.9</i> bar	
Battery Condition		<i>Good</i>	
Battery Voltage		<i>27.8</i>	
Engine RPMs		<i>1800</i>	
Generator		Comments	
Generator Volts		<i>4612</i>	
Generator Amps		<i>—</i>	
Generator "KVA"		<i>—</i>	
Reason For Use		Comments	
Testing		<input checked="" type="checkbox"/>	
Emergency		<input type="checkbox"/>	
Maintenance		<input type="checkbox"/>	
Generator		Comments	
Fuel Delivered		<i>—</i>	
Fuel Level	1/4 1/2 3/4 F	<i>78%</i>	
Sulfur Concentrations <0.0015% (15ppm)		<i>—</i>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <u>Beta</u>					Date: <u>8-12-23</u>				
Operator: <u>Calvin Sowards</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>0159</u>				
Stop Time:					<u>0209</u>				
Total Run Time:					<u>10min</u>				
Starting Hour Meter Reading					<u>64601 .2</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Belt Condition					✓				
Oil Pressure					✓				
Battery Condition					<u>good</u>				
Battery Voltage					<u>26.7</u>				
Engine RPMs					<u>1800</u>				
Generator					Comments				
Generator Volts					<u>N/A</u>				
Generator Amps					<u>N/A</u>				
Generator "KVA"					<u>N/A</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>NO</u>				
Fuel Level	1/4	1/2	3/4	F	<u>78%</u>				
Sulfur Concentrations <0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Bats</i>					Date: <i>8-6-23</i>				
Operator: <i>Caleb</i>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<i>0750</i>				
Stop Time:					<i>0200</i>				
Total Run Time:					<i>10.00</i>				
Starting Hour Meter Reading					<i>646.0</i>				
Monthly Fuel Consumption(gal)									
Oil Level					<i>good</i>				
Coolant Level					<i>good</i>				
Belt Condition					<i>good</i>				
Oil Pressure					Start = <i>8.4</i> bar Finish = <i>6.7</i> bar				
Battery Condition					<i>good</i>				
Battery Voltage					<i>26.7</i>				
Engine RPMs					<i>1800</i>				
Generator					Comments				
Generator Volts					<i>N/A</i>				
Generator Amps					<i>N/A</i>				
Generator "KVA"					<i>N/A</i>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<i>NO</i>				
Fuel Level	1/4	1/2	3/4	F	<i>78</i>				
Sulfur Concentrations <0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant:

Alpha

Date: 8-17-23

Operator:

Caleb

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	11:30	
Stop Time:	11:40	
Total Run Time:	10 min	
Starting Hour Meter Reading	525.5	
Monthly Fuel Consumption(gal)		
Oil Level	✓	
Coolant Level	~	Coolant Temp. @ Start 63 *c Finish=75 *c
Belt Condition	✓	
Oil Pressure	✓	Start = 7.1 bar Finish=6.7 bar
Battery Condition	✓	
Battery Voltage	26.9	
Engine RPMs	1800	
Generator		Comments
Generator Volts	N/A	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	N/A	
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 8/13/23

Operator: Diego Rodriguez

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	<u>0032</u>	
Stop Time:	<u>0042</u>	
Total Run Time:	<u>10 mins</u>	
Starting Hour Meter Reading	<u>525.3</u>	<u>525.5 End Reading</u>
Monthly Fuel Consumption(gal)		
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start <u>61</u> *c Finish= <u>74</u> *c
Belt Condition	✓	
Oil Pressure	✓	Start= <u>7.2</u> bar Finish= <u>6.7</u> bar
Battery Condition	✓	<u>Needs cleaning & Small leak BATTERY #3</u>
Battery Voltage	<u>26.8</u>	
Engine RPMs	<u>1800</u>	
Generator		Comments
Generator Volts	<u>2224</u>	
Generator Amps	<u>6344</u>	
Generator "KVA"	<u>3145</u>	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	<u>N/A</u>	
Fuel Level	1/4 1/2 <u>(3/4)</u> F <u>88%</u>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <u>Alpha</u>		Date: <u>8/6/23</u>
Operator: <u>Diego Rodriguez</u>		
Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	<u>0049</u>	
Stop Time:	<u>0059</u>	
Total Run Time:	<u>10 mins</u>	
Starting Hour Meter Reading	<u>525.1</u>	<u>Finish Hour Meter: 525.3</u>
Monthly Fuel Consumption(gal)		
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start <u>62</u> °C Finish = <u>74</u> °C
Belt Condition	✓	
Oil Pressure	✓	Start = <u>7.1</u> bar Finish = <u>6.7</u> bar
Battery Condition	✓	<u>Need To Be cleaned/leak on 3rd FROM DOOR.</u>
Battery Voltage	<u>27.3</u>	
Engine RPMs	<u>1800</u>	
Generator		Comments
Generator Volts	<u>4.18</u>	<u>KV</u>
Generator Amps	<u>0336</u>	
Generator "KVA"	<u>2385</u>	
Reason For Use		Comments
Testing	✓	<u>Weekly Test.</u>
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 <u>3/4</u> F	<u>88%</u>
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Beta*

Date: *9-30-23*

Operator: *Erick*

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	<i>18:50</i>	
Stop Time:	<i>19:00</i>	
Total Run Time:	<i>10 min</i>	
Starting Hour Meter Reading	<i>647.2</i>	
Monthly Fuel Consumption(gal)		
Oil Level	<input checked="" type="checkbox"/>	<i>In between min & max.</i>
Coolant Level		Coolant Temp. @ Start <i>51</i> °C Finish= <i>74</i> °C
Belt Condition	<input checked="" type="checkbox"/>	
Oil Pressure		Start = <i>8.3</i> bar Finish= <i>6.9</i> bar
Battery Condition	<input checked="" type="checkbox"/>	<i>Electric Die grease seems to have been</i>
Battery Voltage	<i>27.1</i>	<i>Added to terminals.</i>
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts	<i>415.</i>	
Generator Amps	<i>0264.</i>	
Generator "KVA"	<i>1661.</i>	
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F <i>76%.</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 9/30/25

Operator: PAT

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	<u>19:33</u>		
Stop Time:	<u>19:43</u>		
Total Run Time:	<u>10 minutes</u>		
Starting Hour Meter Reading	<u>526.4</u>		
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start <u>58</u> *c	Finish= <u>74</u> *c
Belt Condition	✓		
Oil Pressure		Start = <u>7.6</u> bar	Finish= <u>6.6</u> bar
Battery Condition	✓		
Battery Voltage	<u>27</u>		
Engine RPMs	<u>1800</u>		
Generator		Comments	
Generator Volts			
Generator Amps	<u>248</u>		
Generator "KVA"	<u>4.16</u>		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<u>NO</u>		
Fuel Level	1/4 1/2 3/4 F	<u>87</u> %	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: <u>A1 pln</u>					Date: <u>9/22/23</u>				
Operator: <u>RAT</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>19:22</u>				
Stop Time:					<u>19:32</u>				
Total Run Time:					<u>10 min</u>				
Starting Hour Meter Reading					<u>526.1</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Coolant Temp. @ Start					<u>60°C</u>				
Finish=					<u>*c 74</u>				
Belt Condition					✓				
Oil Pressure					Start = bar <u>7.8</u>				
Finish=					bar <u>6.6</u>				
Battery Condition					✓				
Battery Voltage					<u>27.2v</u>				
Engine RPMs					<u>1800</u>				
Generator					Comments				
Generator Volts									
Generator Amps					<u>264</u>				
Generator "KVA"					<u>4.16</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>~0</u>				
Fuel Level	1/4	1/2	3/4	F	<u>87%</u>				
Sulfur Concentrations									
<0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Alpha

Date: 9/15/23

Operator: Diego Rodriguez

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	<u>1925</u>	
Stop Time:	<u>1935</u>	
Total Run Time:	<u>10 Mins</u>	
Starting Hour Meter Reading	<u>526.0</u>	<u>End Time - 526.1</u>
Monthly Fuel Consumption(gal)	<u>N/A</u>	
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start <u>63</u> *c Finish= <u>75</u> *c
Belt Condition	✓	
Oil Pressure	✓	Start = <u>7.3</u> bar Finish = <u>6.7</u> bar
Battery Condition	✓	<u>Need To Be cleaned.</u>
Battery Voltage	<u>24.9</u>	
Engine RPMs	<u>1800</u>	
Generator		Comments
Generator Volts	<u>4.17</u>	
Generator Amps	<u>0336.</u>	
Generator "KVA"	<u>2462</u>	
Reason For Use		Comments
Testing	✓	<u>Weekly Test.</u>
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	<u>N/A</u>	
Fuel Level	1/4 1/2 <u>3/4</u> F <u>87%</u>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **Alpha**

Date: **9/10/23**

Operator: **Anthony**

Main Generator Breaker		Comments
Open		
Closed	✓	
Engine		Comments
Start Time:	2357	
Stop Time:	0007	
Total Run Time:	10 min	
Starting Hour Meter Reading	525.8	
Monthly Fuel Consumption(gal)	—	
Oil Level	✓	
Coolant Level		Coolant Temp. @ Start 62 *c Finish= 74 *c
Belt Condition	✓	
Oil Pressure		Start = 0 bar Finish= 6.6 bar
Battery Condition	✓	
Battery Voltage	27.0	
Engine RPMs	1800	
Generator		Comments
Generator Volts	417	
Generator Amps	—	
Generator "KVA"	—	
Reason For Use		Comments
Testing	✓	
Emergency	—	
Maintenance	—	
Generator		Comments
Fuel Delivered	—	
Fuel Level	1/4 1/2 3/4 F	88%
Sulfur Concentrations <0.0015% (15ppm)	—	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **Alpha**

Date: **9/3/23**

Operator: **Anthony**

Main Generator Breaker		Comments	
Open			
Closed		✓	
Engine		Comments	
Start Time:		2240	
Stop Time:		2250	
Total Run Time:		10 min.	
Starting Hour Meter Reading		525.6	
Monthly Fuel Consumption(gal)		—	
Oil Level		✓	
Coolant Level		Coolant Temp. @ Start 64 *c Finish= 74 *c	
Belt Condition		✓	
Oil Pressure		Start = 0 bar Finish= 6.6 bar	
Battery Condition		✓	
Battery Voltage		27.0	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		4.17	
Generator Amps		—	
Generator "KVA"		—	
Reason For Use		Comments	
Testing		✓	
Emergency		—	
Maintenance		—	
Generator		Comments	
Fuel Delivered		—	
Fuel Level	1/4 1/2 (3/4) F	88.1.	
Sulfur Concentrations <0.0015% (15ppm)		—	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log				
Plant: <u>Beta</u>		Date: <u>9-22-23</u>		
Operator: <u>Erick</u>				
Main Generator Breaker		Comments		
Open		✓		
Closed				
Engine		Comments		
Start Time:		<u>20:00</u>		
Stop Time:		<u>20:10</u>		
Total Run Time:		<u>10m</u>		
Starting Hour Meter Reading		<u>6470 - 647.2</u>		
Monthly Fuel Consumption(gal)				
Oil Level		✓		
Coolant Level		Coolant Temp. @ Start <u>52</u> °c Finish = <u>75</u> °c		
Belt Condition		✓		
Oil Pressure		Start = <u>8.4</u> bar Finish = <u>6.9</u> bar		
Battery Condition		✓ <u>Battery terminals</u>		
Battery Voltage		<u>27.0</u>		
Engine RPMs		<u>1800</u>		
Generator		Comments		
Generator Volts		<u>4.16</u>		
Generator Amps		<u>0280</u>		
Generator "KVA"		<u>1896</u>		
Reason For Use		Comments		
Testing		✓		
Emergency				
Maintenance				
Generator		Comments		
Fuel Delivered				
Fuel Level	1/4 1/2 3/4 <u>(F)</u>	<u>78%</u>		
Sulfur Concentrations <0.0015% (15ppm)				

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Beta</u>					Date: <u>9-17-23</u>				
Operator: <u>Caleb Sowards</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>0310</u>				
Stop Time:					<u>0320</u>				
Total Run Time:					<u>10 min</u>				
Starting Hour Meter Reading					<u>646.9 647.0</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Coolant Temp. @ Start					<u>51</u> °c				
Coolant Temp. @ Finish					<u>74</u> °c				
Belt Condition					✓				
Oil Pressure					✓				
Start =					<u>8.4</u> bar				
Finish =					<u>6.9</u> bar				
Battery Condition					✓				
Battery Voltage					<u>26.7</u>				
Engine RPMs					<u>1800</u>				
Generator					Comments				
Generator Volts					<u>N/A</u>				
Generator Amps					<u>N/A</u>				
Generator "KVA"					<u>N/A</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>No</u>				
Fuel Level	1/4	1/2	3/4	F	<u>78%</u>				
Sulfur Concentrations									
<0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta

Date: 9-11-23

Operator: Caleb

Main Generator Breaker		Comments	
Open	<input checked="" type="checkbox"/>		
Closed	<input type="checkbox"/>		
Engine		Comments	
Start Time:	<u>0125</u>		
Stop Time:	<u>0135</u>		
Total Run Time:	<u>10min</u>		
Starting Hour Meter Reading	<u>646.7</u>	<u>.9</u>	
Monthly Fuel Consumption(gal)			
Oil Level	<input checked="" type="checkbox"/>		
Coolant Level	<input checked="" type="checkbox"/>	Coolant Temp. @ Start <u>51</u> °c	Finish = <u>75</u> °c
Belt Condition	<input checked="" type="checkbox"/>		
Oil Pressure	<input checked="" type="checkbox"/>	Start = <u>8.3</u> bar	Finish = <u>6.9</u> bar
Battery Condition	<input checked="" type="checkbox"/>		
Battery Voltage	<u>26.7</u>		
Engine RPMs	<u>1800</u>		
Generator		Comments	
Generator Volts	<u>N/A</u>		
Generator Amps	<u>N/A</u>		
Generator "KVA"	<u>N/A</u>		
Reason For Use		Comments	
Testing	<input checked="" type="checkbox"/>	<u>still has can 1 alarm</u>	
Emergency	<input type="checkbox"/>		
Maintenance	<input type="checkbox"/>		
Generator		Comments	
Fuel Delivered	<u>No</u>		
Fuel Level	<u>78%</u>		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log									
Plant: <u>Beta</u>					Date: <u>9-4-23</u>				
Operator: <u>Caleb Sowards</u>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<u>0020</u> <u>Can I communications</u>				
Stop Time:					<u>0030</u>				
Total Run Time:					<u>10min</u>				
Starting Hour Meter Reading					<u>646.5</u> <u>.7</u>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Coolant Temp. @ Start					<u>52</u> °c				
Coolant Temp. @ Finish					<u>75</u> °c				
Belt Condition					✓				
Oil Pressure					✓				
Start =					<u>8.2</u> bar				
Finish =					<u>6.7</u> bar				
Battery Condition					<u>good</u>				
Battery Voltage					<u>26.7</u>				
Engine RPMs					<u>1800</u>				
Generator					Comments				
Generator Volts					<u>N/A</u>				
Generator Amps					<u>N/A</u>				
Generator "KVA"					<u>N/A</u>				
Reason For Use					Comments				
Testing					✓				
Emergency									
Maintenance									
Generator					Comments				
Fuel Delivered					<u>No</u>				
Fuel Level	1/4	1/2	3/4	F	<u>28</u>				
Sulfur Concentrations <0.0015% (15ppm)									
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.</p>									

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: <i>Befa</i>					Date: <i>10/24/23</i>				
Operator: <i>Pat</i>									
Main Generator Breaker					Comments				
Open					✓				
Closed									
Engine					Comments				
Start Time:					<i>23:20</i>				
Stop Time:					<i>23:30</i>				
Total Run Time:					<i>10 min</i>				
Starting Hour Meter Reading					<i>647.9</i>				
Monthly Fuel Consumption(gal)									
Oil Level					✓				
Coolant Level					✓				
Coolant Temp. @ Start					<i>52°C</i>				
Coolant Temp. @ Finish					<i>77°C</i>				
Belt Condition					✓				
Oil Pressure					Start = <i>8.2</i> bar				
Oil Pressure					Finish = <i>6.9</i> bar				
Battery Condition					✓				
Battery Voltage					<i>26.7</i>				
Engine RPMs					<i>1800</i>				
Generator					Comments				
Generator Volts					<i>1668</i>				
Generator Amps					<i>266</i>				
Generator "KVA"					<i>4.16</i>				
Reason For Use					Comments				
Testing									
Emergency									
Maintenance					✓				
Generator					Comments				
Fuel Delivered									
Fuel Level	1/4	1/2	3/4	F	<i>76%</i>				
Sulfur Concentrations									
<0.0015% (15ppm)									

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alpha		Date: 10/25/23	
Operator: Diego P.			
Main Generator Breaker		Comments	
Open		✓	
Closed			
Engine		Comments	
Start Time:		0534	
Stop Time:		0554	
Total Run Time:		20mins	
Starting Hour Meter Reading		528.8	
Monthly Fuel Consumption(gal)		N/A	
Oil Level		✓	
Coolant Level		✓	
Belt Condition		✓	
Oil Pressure		Start = 7.6 bar	
Battery Condition		Finish = 6.6 bar	
Battery Voltage		26.9	
Engine RPMs		1800	
Generator		Comments	
Generator Volts		1572	
Generator Amps		0264	
Generator "KVA"		4.66	
Reason For Use		Comments	
Testing		✓	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered		N/A	
Fuel Level	1/4 1/2 <u>3/4</u> F	83%	
Sulfur Concentrations		<0.0015% (15ppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Beta*

Date: *10-25-23*

Operator: *Caleb Sowards*

Main Generator Breaker		Comments	
Open	<input checked="" type="checkbox"/>		
Closed	<input type="checkbox"/>		
Engine		Comments	
Start Time:	<i>0645</i>		
Stop Time:	<i>0605</i>		
Total Run Time:	<i>20min</i>		
Starting Hour Meter Reading	<i>648.1</i>	<i>648.5</i>	
Monthly Fuel Consumption(gal)	<i>.</i>		
Oil Level	<input checked="" type="checkbox"/>		
Coolant Level	<input checked="" type="checkbox"/>	Coolant Temp. @ Start <i>52</i> °c	Finish = <i>74</i> °c
Belt Condition	<input checked="" type="checkbox"/>		
Oil Pressure	<input checked="" type="checkbox"/>	Start = <i>8.1</i> bar	Finish = <i>6.8</i> bar
Battery Condition	<input checked="" type="checkbox"/>		
Battery Voltage	<i>26.7</i>		
Engine RPMs	<i>1800</i>	<i>can't alarm</i>	
Generator		Comments	
Generator Volts	<i>N/A</i>		
Generator Amps	<i>N/A</i>		
Generator "KVA"	<i>N/A</i>		
Reason For Use		Comments	
Testing	<input checked="" type="checkbox"/>		
Emergency	<input type="checkbox"/>		
Maintenance	<input type="checkbox"/>		
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F	<i>76</i>	
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: *Alpha*

Date: *10-20-23*

Operator: *Isaiah*

Main Generator Breaker		Comments	
Open	<i>X</i>		
Closed			
Engine		Comments	
Start Time:	<i>170</i>		
Stop Time:	<i>150</i>		
Total Run Time:	<i>10</i>		
Starting Hour Meter Reading	<i>576.9</i>		
Monthly Fuel Consumption(gal)			
Oil Level	<i>LOW</i>		
Coolant Level	<i>✓</i>	Coolant Temp. @ Start <i>61</i> *c	Finish = <i>74</i> *c
Belt Condition	<i>✓</i>		
Oil Pressure		Start = <i>7.7</i> bar	Finish = <i>6.6</i> bar
Battery Condition	<i>✓</i>		
Battery Voltage	<i>26.9</i>		
Engine RPMs	<i>1800</i>		
Generator		Comments	
Generator Volts	<i>4.17</i>		
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	<i>✓</i>		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	<i>87%</i>		
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Alpha Date: 10-14-2J
Operator: Isaac

Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:		<u>0038</u>
Stop Time:		<u>0048</u>
Total Run Time:		<u>10 minutes</u>
Starting Hour Meter Reading		<u>526.7</u>
Monthly Fuel Consumption(gal)		<u>114.01</u>
Oil Level		<u>LOW</u>
Coolant Level		<u>✓</u> Coolant Temp. @ Start <u>62</u> *c Finish= <u>75</u> *c
Belt Condition		<u>✓</u>
Oil Pressure		Start= <u>8.1</u> bar <u>8</u> Finish= <u>6.7</u> bar
Battery Condition		<u>✓</u>
Battery Voltage		<u>26.9</u> Alternator excitation Alarm
Engine RPMs		<u>1800</u>
Generator		Comments
Generator Volts		<u>417</u>
Generator Amps		<u>0256</u>
Generator "KVA"		<u>1581</u>
Reason For Use		Comments
Testing		<u>✓</u>
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	<u>86%</u>
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant:

Beta

Date:

10-21-23

Operator:

Isaiah

Main Generator Breaker		Comments	
Open	X		
Closed			
Engine		Comments	
Start Time:	222		
Stop Time:	232		
Total Run Time:	10		
Starting Hour Meter Reading	647.7		
Monthly Fuel Consumption(gal)			
Oil Level	✓		
Coolant Level	✓	Coolant Temp. @ Start 51 °c	Finish=74 °c
Belt Condition	✓		
Oil Pressure		Start = 8.5 bar	Finish=6.9 bar
Battery Condition	✓		
Battery Voltage	26.6		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.14		
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F 74%		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Beta*

Date: *10-16-23*

Operator: *Caleb Sowards*

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	<i>0430</i>	
Stop Time:	<i>0440</i>	
Total Run Time:		
Starting Hour Meter Reading	<i>647.6</i>	
Monthly Fuel Consumption(gal)	<i>647.6</i>	<i>.7</i>
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start <i>52</i> °c Finish= <i>74</i> °c
Belt Condition	✓	
Oil Pressure		Start = <i>8.3</i> bar Finish= <i>68</i> bar
Battery Condition	<i>good</i>	
Battery Voltage	<i>76.6</i>	
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts	<i>NA</i>	
Generator Amps	<i>NA</i>	
Generator "KVA"	<i>NA</i>	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	<i>76% NO</i>	
Fuel Level	<i>76%</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use. This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.