

DOCKETED	
Docket Number:	24-BSTD-01
Project Title:	2025 Energy Code Rulemaking
TN #:	255598
Document Title:	Justin Yurasek Comments - Economizer Exceptions
Description:	N/A
Filer:	System
Organization:	Justin Yurasek
Submitter Role:	Public
Submission Date:	4/9/2024 1:27:24 PM
Docketed Date:	4/9/2024

Comment Received From: Justin Yurasek
Submitted On: 4/9/2024
Docket Number: 24-BSTD-01

Economizer Exceptions

Propose adding an exception to 140.4(e).1 so that economizers are NOT required for units over 33,000 Btu/hr when exclusively serving "normally unoccupied" rooms such as mechanical rooms, electrical rooms, storage rooms, etc.