

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	256062-5
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2024 - Part 6 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	4/30/2024 8:49:16 AM
Docketed Date:	4/30/2024

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/01/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/02/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 07:00	613.2	0.0	613.2	105,380.0	64.6	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 08:00	499.2	0.0	499.2	105,380.0	52.6	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 09:00	2,465.5	0.0	2,465.5	105,380.0	259.8	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 17:00	3,035.9	0.0	3,035.9	105,380.0	319.9	0.0	0.0	0.0	0.0	0.0	0.0
01/03/2024 18:00	4,773.8	0.0	4,773.8	105,380.0	503.1	0.6	0.3	1.0	0.6	0.3	1.0
01/03/2024 19:00	4,868.9	0.0	4,868.9	105,380.0	513.1	0.6	0.3	1.0	0.6	0.3	1.0
01/03/2024 20:00	4,815.5	0.0	4,815.5	105,380.0	507.5	0.6	0.3	1.0	0.6	0.3	1.0
01/03/2024 21:00	4,815.4	0.0	4,815.4	105,380.0	507.4	0.6	0.3	1.0	0.6	0.3	1.0
01/03/2024 22:00	4,384.2	0.0	4,384.2	105,380.0	462.0	0.6	0.3	0.9	0.6	0.3	0.9
01/03/2024 23:00	3,876.3	0.0	3,876.3	105,380.0	408.5	0.5	0.2	0.8	0.5	0.2	0.8
Average/Sum#:	3,414.8	0.0	3,414.8	105,380.0	359.9	0.6	0.3	1.0	0.6	0.3	1.0
Minimum:	499.2	0.0	499.2	105,380.0	52.6	0.5	0.2	0.8	0.5	0.2	0.8
Maximum:	4,868.9	0.0	4,868.9	105,380.0	513.1	0.6	0.3	1.0	0.6	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	75.00	75.00	75.00	58.33	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2024 00:00	4,476.8	0.0	4,476.8	105,380.0	471.8	0.6	0.3	0.9
01/04/2024 01:00	3,862.2	0.0	3,862.2	105,380.0	407.0	0.5	0.2	0.8
01/04/2024 02:00	3,794.3	0.0	3,794.3	105,380.0	399.8	0.5	0.2	0.8
01/04/2024 03:00	3,778.3	0.0	3,778.3	105,380.0	398.2	0.5	0.2	0.8
01/04/2024 04:00	4,257.6	0.0	4,257.6	105,380.0	448.7	0.5	0.3	0.9
01/04/2024 05:00	4,561.4	0.0	4,561.4	105,380.0	480.7	0.6	0.3	1.0
01/04/2024 06:00	4,816.1	0.0	4,816.1	105,380.0	507.5	0.6	0.3	1.0
01/04/2024 07:00	4,595.7	0.0	4,595.7	105,380.0	484.3	0.6	0.3	1.0
01/04/2024 08:00	4,032.3	0.0	4,032.3	105,380.0	424.9	0.5	0.3	0.8
01/04/2024 09:00	3,902.3	0.0	3,902.3	105,380.0	411.2	0.5	0.2	0.8
01/04/2024 10:00	3,801.3	0.0	3,801.3	105,380.0	400.6	0.5	0.2	0.8
01/04/2024 11:00	3,698.3	0.0	3,698.3	105,380.0	389.7	0.5	0.2	0.8
01/04/2024 12:00	3,673.6	0.0	3,673.6	105,380.0	387.1	0.5	0.2	0.8
01/04/2024 13:00	3,674.8	0.0	3,674.8	105,380.0	387.3	0.5	0.2	0.8
01/04/2024 14:00	3,674.8	0.0	3,674.8	105,380.0	387.3	0.5	0.2	0.8
01/04/2024 15:00	3,847.6	0.0	3,847.6	105,380.0	405.5	0.5	0.2	0.8
01/04/2024 16:00	4,511.9	0.0	4,511.9	105,380.0	475.5	0.6	0.3	1.0
01/04/2024 17:00	4,763.0	0.0	4,763.0	105,380.0	501.9	0.6	0.3	1.0
01/04/2024 18:00	4,840.2	0.0	4,840.2	105,380.0	510.1	0.6	0.3	1.0
01/04/2024 19:00	4,819.7	0.0	4,819.7	105,380.0	507.9	0.6	0.3	1.0
01/04/2024 20:00	4,723.6	0.0	4,723.6	105,380.0	497.8	0.6	0.3	1.0
01/04/2024 21:00	4,294.8	0.0	4,294.8	105,380.0	452.6	0.5	0.3	0.9
01/04/2024 22:00	4,425.8	0.0	4,425.8	105,380.0	466.4	0.6	0.3	0.9
01/04/2024 23:00	4,028.4	0.0	4,028.4	105,380.0	424.5	0.5	0.3	0.8
Average/Sum#:	4,202.3	0.0	4,202.3	105,380.0	442.8	0.5	0.3	0.9
Minimum:	3,673.6	0.0	3,673.6	105,380.0	387.1	0.5	0.2	0.8
Maximum:	4,840.2	0.0	4,840.2	105,380.0	510.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2024 00:00	3,950.5	0.0	3,950.5	105,380.0	416.3	0.5	0.2	0.2	0.8	0.8
01/05/2024 01:00	4,207.9	0.0	4,207.9	105,380.0	443.4	0.5	0.3	0.3	0.9	0.9
01/05/2024 02:00	4,134.2	0.0	4,134.2	105,380.0	435.7	0.5	0.3	0.3	0.9	0.9
01/05/2024 03:00	4,261.6	0.0	4,261.6	105,380.0	449.1	0.5	0.3	0.3	0.9	0.9
01/05/2024 04:00	4,310.0	0.0	4,310.0	105,380.0	454.2	0.5	0.3	0.3	0.9	0.9
01/05/2024 05:00	4,503.5	0.0	4,503.5	105,380.0	474.6	0.6	0.3	0.3	0.9	0.9
01/05/2024 06:00	4,695.2	0.0	4,695.2	105,380.0	494.8	0.6	0.3	0.3	1.0	1.0
01/05/2024 07:00	4,067.8	0.0	4,067.8	105,380.0	428.7	0.5	0.3	0.3	0.9	0.9
01/05/2024 08:00	4,395.2	0.0	4,395.2	105,380.0	463.2	0.6	0.3	0.3	0.9	0.9
01/05/2024 09:00	4,300.6	0.0	4,300.6	105,380.0	453.2	0.5	0.3	0.3	0.9	0.9
01/05/2024 10:00	3,768.5	0.0	3,768.5	105,380.0	397.1	0.5	0.2	0.2	0.8	0.8
01/05/2024 11:00	3,744.0	0.0	3,744.0	105,380.0	394.5	0.5	0.2	0.2	0.8	0.8
01/05/2024 12:00	3,667.1	0.0	3,667.1	105,380.0	386.4	0.5	0.2	0.2	0.8	0.8
01/05/2024 13:00	3,665.3	0.0	3,665.3	105,380.0	386.2	0.5	0.2	0.2	0.8	0.8
01/05/2024 14:00	3,657.7	0.0	3,657.7	105,380.0	385.4	0.5	0.2	0.2	0.8	0.8
01/05/2024 15:00	3,663.9	0.0	3,663.9	105,380.0	386.1	0.5	0.2	0.2	0.8	0.8
01/05/2024 16:00	3,854.4	0.0	3,854.4	105,380.0	406.2	0.5	0.2	0.2	0.8	0.8
01/05/2024 17:00	4,485.5	0.0	4,485.5	105,380.0	472.7	0.6	0.3	0.3	0.9	0.9
01/05/2024 18:00	3,995.0	0.0	3,995.0	105,380.0	421.0	0.5	0.3	0.3	0.8	0.8
01/05/2024 19:00	4,028.3	0.0	4,028.3	105,380.0	424.5	0.5	0.3	0.3	0.8	0.8
01/05/2024 20:00	4,236.8	0.0	4,236.8	105,380.0	446.5	0.5	0.3	0.3	0.9	0.9
01/05/2024 21:00	4,492.9	0.0	4,492.9	105,380.0	473.5	0.6	0.3	0.3	0.9	0.9
01/05/2024 22:00	4,154.7	0.0	4,154.7	105,380.0	437.8	0.5	0.3	0.3	0.9	0.9
01/05/2024 23:00	4,056.8	0.0	4,056.8	105,380.0	427.5	0.5	0.3	0.3	0.9	0.9
Average/Sum#:	4,095.7	0.0	4,095.7	105,380.0	431.6	0.5	0.3	0.3	0.9	0.9
Minimum:	3,657.7	0.0	3,657.7	105,380.0	385.4	0.5	0.2	0.2	0.8	0.8
Maximum:	4,695.2	0.0	4,695.2	105,380.0	494.8	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2024 00:00	4,051.7	0.0	4,051.7	105,380.0	427.0	0.5	0.3	0.9			
01/06/2024 01:00	3,889.8	0.0	3,889.8	105,380.0	409.9	0.5	0.2	0.8			
01/06/2024 02:00	3,756.9	0.0	3,756.9	105,380.0	395.9	0.5	0.2	0.8			
01/06/2024 03:00	3,760.8	0.0	3,760.8	105,380.0	396.3	0.5	0.2	0.8			
01/06/2024 04:00	3,881.4	0.0	3,881.4	105,380.0	409.0	0.5	0.2	0.8			
01/06/2024 05:00	4,234.7	0.0	4,234.7	105,380.0	446.3	0.5	0.3	0.9			
01/06/2024 06:00	4,764.8	0.0	4,764.8	105,380.0	502.1	0.6	0.3	1.0			
01/06/2024 07:00	4,051.3	0.0	4,051.3	105,380.0	426.9	0.5	0.3	0.9			
01/06/2024 08:00	3,656.1	0.0	3,656.1	105,380.0	385.3	0.5	0.2	0.8			
01/06/2024 09:00	3,761.2	0.0	3,761.2	105,380.0	396.4	0.5	0.2	0.8			
01/06/2024 10:00	3,717.0	0.0	3,717.0	105,380.0	391.7	0.5	0.2	0.8			
01/06/2024 11:00	3,660.2	0.0	3,660.2	105,380.0	385.7	0.5	0.2	0.8			
01/06/2024 12:00	3,748.4	0.0	3,748.4	105,380.0	395.0	0.5	0.2	0.8			
01/06/2024 13:00	4,209.1	0.0	4,209.1	105,380.0	443.6	0.5	0.3	0.9			
01/06/2024 14:00	4,476.4	0.0	4,476.4	105,380.0	471.7	0.6	0.3	0.9			
01/06/2024 15:00	4,252.9	0.0	4,252.9	105,380.0	448.2	0.5	0.3	0.9			
01/06/2024 16:00	4,420.0	57.4	4,436.1	105,380.0	467.5	0.6	0.3	0.9			
01/06/2024 17:00	4,878.3	241.3	5,088.2	105,380.0	536.2	0.6	0.3	1.1			
01/06/2024 18:00	4,887.7	389.4	5,277.1	105,380.0	556.1	0.7	0.3	1.1			
01/06/2024 19:00	4,895.1	391.1	5,286.2	105,380.0	557.1	0.7	0.3	1.1			
01/06/2024 20:00	4,911.0	360.4	5,271.4	105,380.0	555.5	0.7	0.3	1.1			
01/06/2024 21:00	4,835.1	142.0	4,896.2	105,380.0	516.0	0.6	0.3	1.0			
01/06/2024 22:00	3,941.4	0.0	3,941.4	105,380.0	415.3	0.5	0.2	0.8			
01/06/2024 23:00	3,786.7	0.0	3,786.7	105,380.0	399.0	0.5	0.2	0.8			
Average/Sum#:	4,184.5	65.9	4,244.0	105,380.0	447.2	0.5	0.3	0.9			
Minimum:	3,656.1	0.0	3,656.1	105,380.0	385.3	0.5	0.2	0.8			
Maximum:	4,911.0	391.1	5,286.2	105,380.0	557.1	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2024 00:00	4,184.4	0.0	4,184.4	105,380.0	441.0	0.5	0.3	0.3	0.9	0.9
01/07/2024 01:00	3,729.7	0.0	3,729.7	105,380.0	393.0	0.5	0.2	0.2	0.8	0.8
01/07/2024 02:00	3,682.1	0.0	3,682.1	105,380.0	388.0	0.5	0.2	0.2	0.8	0.8
01/07/2024 03:00	3,688.1	0.0	3,688.1	105,380.0	388.7	0.5	0.2	0.2	0.8	0.8
01/07/2024 04:00	3,685.0	0.0	3,685.0	105,380.0	388.3	0.5	0.2	0.2	0.8	0.8
01/07/2024 05:00	3,935.2	0.0	3,935.2	105,380.0	414.7	0.5	0.2	0.2	0.8	0.8
01/07/2024 06:00	3,941.9	0.0	3,941.9	105,380.0	415.4	0.5	0.2	0.2	0.8	0.8
01/07/2024 07:00	4,514.8	0.0	4,514.8	105,380.0	475.8	0.6	0.3	0.3	1.0	1.0
01/07/2024 08:00	4,667.1	0.0	4,667.1	105,380.0	491.8	0.6	0.3	0.3	1.0	1.0
01/07/2024 09:00	3,727.5	0.0	3,727.5	105,380.0	392.8	0.5	0.2	0.2	0.8	0.8
01/07/2024 10:00	3,716.9	0.0	3,716.9	105,380.0	391.7	0.5	0.2	0.2	0.8	0.8
01/07/2024 11:00	3,677.7	0.0	3,677.7	105,380.0	387.6	0.5	0.2	0.2	0.8	0.8
01/07/2024 12:00	3,672.8	0.0	3,672.8	105,380.0	387.0	0.5	0.2	0.2	0.8	0.8
01/07/2024 13:00	3,668.6	0.0	3,668.6	105,380.0	386.6	0.5	0.2	0.2	0.8	0.8
01/07/2024 14:00	3,661.3	0.0	3,661.3	105,380.0	385.8	0.5	0.2	0.2	0.8	0.8
01/07/2024 15:00	3,661.5	0.0	3,661.5	105,380.0	385.8	0.5	0.2	0.2	0.8	0.8
01/07/2024 16:00	4,389.0	49.5	4,400.4	105,380.0	463.7	0.6	0.3	0.3	0.9	0.9
01/07/2024 17:00	4,873.8	43.1	4,913.5	105,380.0	517.8	0.6	0.3	0.3	1.0	1.0
01/07/2024 18:00	4,896.1	12.3	4,908.4	105,380.0	517.2	0.6	0.3	0.3	1.0	1.0
01/07/2024 19:00	4,909.7	41.5	4,951.2	105,380.0	521.8	0.6	0.3	0.3	1.0	1.0
01/07/2024 20:00	4,914.0	858.4	5,772.4	105,380.0	608.3	0.7	0.4	0.4	1.2	1.2
01/07/2024 21:00	4,920.1	530.0	5,370.6	105,380.0	566.0	0.7	0.3	0.3	1.1	1.1
01/07/2024 22:00	4,907.7	121.2	5,028.9	105,380.0	529.9	0.6	0.3	0.3	1.1	1.1
01/07/2024 23:00	4,900.4	240.7	5,141.1	105,380.0	541.8	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,188.6	79.0	4,262.5	105,380.0	449.2	0.6	0.3	0.3	0.9	0.9
Minimum:	3,661.3	0.0	3,661.3	105,380.0	385.8	0.5	0.2	0.2	0.8	0.8
Maximum:	4,920.1	858.4	5,772.4	105,380.0	608.3	0.7	0.4	0.4	1.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2024 00:00	4,904.3	1,544.7	6,449.0	105,380.0	679.6	0.8	0.4	0.4	1.4	1.4
01/08/2024 01:00	4,918.1	1,146.5	6,064.6	105,380.0	639.1	0.8	0.4	0.4	1.3	1.3
01/08/2024 02:00	4,915.8	1,548.6	6,464.4	105,380.0	681.2	0.8	0.4	0.4	1.4	1.4
01/08/2024 03:00	4,908.5	1,375.1	6,283.6	105,380.0	662.2	0.8	0.4	0.4	1.3	1.3
01/08/2024 04:00	4,909.3	1,312.7	6,222.0	105,380.0	655.7	0.8	0.4	0.4	1.3	1.3
01/08/2024 05:00	4,922.8	1,853.6	6,776.4	105,380.0	714.1	0.9	0.4	0.4	1.4	1.4
01/08/2024 06:00	4,909.1	1,862.2	6,771.3	105,380.0	713.6	0.9	0.4	0.4	1.4	1.4
01/08/2024 07:00	4,910.2	1,473.5	6,383.7	105,380.0	672.7	0.8	0.4	0.4	1.3	1.3
01/08/2024 08:00	4,904.4	201.5	5,105.9	105,380.0	538.1	0.6	0.3	0.3	1.1	1.1
01/08/2024 09:00	4,903.3	211.5	5,114.8	105,380.0	539.0	0.6	0.3	0.3	1.1	1.1
01/08/2024 10:00	4,915.3	540.9	5,456.2	105,380.0	575.0	0.7	0.3	0.3	1.1	1.1
01/08/2024 11:00	4,919.6	335.8	5,255.4	105,380.0	553.8	0.7	0.3	0.3	1.1	1.1
01/08/2024 12:00	4,915.5	133.5	5,049.0	105,380.0	532.1	0.6	0.3	0.3	1.1	1.1
01/08/2024 13:00	4,896.9	173.4	5,070.3	105,380.0	534.3	0.6	0.3	0.3	1.1	1.1
01/08/2024 14:00	4,879.5	200.2	5,079.7	105,380.0	535.3	0.6	0.3	0.3	1.1	1.1
01/08/2024 15:00	4,868.0	223.6	5,091.6	105,380.0	536.6	0.6	0.3	0.3	1.1	1.1
01/08/2024 16:00	4,866.1	1,009.8	5,875.9	105,380.0	619.2	0.7	0.4	0.4	1.2	1.2
01/08/2024 17:00	4,897.8	1,178.1	6,075.9	105,380.0	640.3	0.8	0.4	0.4	1.3	1.3
01/08/2024 18:00	4,908.2	1,069.0	5,977.2	105,380.0	629.9	0.8	0.4	0.4	1.3	1.3
01/08/2024 19:00	4,911.1	999.7	5,910.8	105,380.0	622.9	0.7	0.4	0.4	1.2	1.2
01/08/2024 20:00	4,924.0	962.8	5,886.8	105,380.0	620.4	0.7	0.4	0.4	1.2	1.2
01/08/2024 21:00	4,923.7	692.8	5,616.5	105,380.0	591.9	0.7	0.4	0.4	1.2	1.2
01/08/2024 22:00	4,922.2	334.5	5,256.7	105,380.0	554.0	0.7	0.3	0.3	1.1	1.1
01/08/2024 23:00	4,616.4	70.7	4,653.2	105,380.0	490.4	0.6	0.3	0.3	1.0	1.0
Average/Sum#:	4,894.6	852.3	5,745.5	105,380.0	605.5	0.7	0.4	0.4	1.2	1.2
Minimum:	4,616.4	70.7	4,653.2	105,380.0	490.4	0.6	0.3	0.3	1.0	1.0
Maximum:	4,924.0	1,862.2	6,776.4	105,380.0	714.1	0.9	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2024 00:00	3,738.9	0.0	3,738.9	105,380.0	394.0	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 01:00	3,713.0	0.0	3,713.0	105,380.0	391.3	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 02:00	3,691.7	0.0	3,691.7	105,380.0	389.0	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 03:00	3,673.0	0.0	3,673.0	105,380.0	387.1	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 04:00	3,726.8	0.0	3,726.8	105,380.0	392.7	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 05:00	4,402.4	64.3	4,417.2	105,380.0	465.5	0.6	0.3	0.3	0.9	0.9	0.9
01/09/2024 06:00	4,922.6	494.3	5,416.9	105,380.0	570.8	0.7	0.3	0.3	1.1	1.1	1.1
01/09/2024 07:00	4,919.4	464.9	5,384.3	105,380.0	567.4	0.7	0.3	0.3	1.1	1.1	1.1
01/09/2024 08:00	3,931.3	0.6	3,931.3	105,380.0	414.3	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 09:00	4,033.7	0.0	4,033.7	105,380.0	425.1	0.5	0.3	0.3	0.9	0.9	0.9
01/09/2024 10:00	3,734.0	0.0	3,734.0	105,380.0	393.5	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 11:00	3,733.7	0.0	3,733.7	105,380.0	393.5	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 12:00	3,730.1	0.0	3,730.1	105,380.0	393.1	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 13:00	3,728.7	0.0	3,728.7	105,380.0	392.9	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 14:00	3,741.9	0.0	3,741.9	105,380.0	394.3	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 15:00	3,744.7	0.0	3,744.7	105,380.0	394.6	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 16:00	4,085.6	0.0	4,085.6	105,380.0	430.5	0.5	0.3	0.3	0.9	0.9	0.9
01/09/2024 17:00	3,876.9	0.0	3,876.9	105,380.0	408.5	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 18:00	3,732.4	0.0	3,732.4	105,380.0	393.3	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 19:00	3,750.6	0.0	3,750.6	105,380.0	395.2	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 20:00	3,763.3	0.0	3,763.3	105,380.0	396.6	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 21:00	3,911.3	0.0	3,911.3	105,380.0	412.2	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 22:00	3,822.4	0.0	3,822.4	105,380.0	402.8	0.5	0.2	0.2	0.8	0.8	0.8
01/09/2024 23:00	3,761.1	0.0	3,761.1	105,380.0	396.3	0.5	0.2	0.2	0.8	0.8	0.8
Average/Sum#:	3,911.2	42.7	3,951.8	105,380.0	416.4	0.5	0.2	0.2	0.8	0.8	0.8
Minimum:	3,673.0	0.0	3,673.0	105,380.0	387.1	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	4,922.6	494.3	5,416.9	105,380.0	570.8	0.7	0.3	0.3	1.1	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2024 00:00	3,766.7	0.0	3,766.7	105,380.0	396.9	0.5	0.2	0.2	0.8	0.8
01/10/2024 01:00	3,772.5	0.0	3,772.5	105,380.0	397.5	0.5	0.2	0.2	0.8	0.8
01/10/2024 02:00	3,764.9	0.0	3,764.9	105,380.0	396.7	0.5	0.2	0.2	0.8	0.8
01/10/2024 03:00	3,760.0	0.0	3,760.0	105,380.0	396.2	0.5	0.2	0.2	0.8	0.8
01/10/2024 04:00	3,754.5	0.0	3,754.5	105,380.0	395.6	0.5	0.2	0.2	0.8	0.8
01/10/2024 05:00	4,192.1	0.0	4,192.1	105,380.0	441.8	0.5	0.3	0.3	0.9	0.9
01/10/2024 06:00	4,518.6	0.0	4,518.6	105,380.0	476.2	0.6	0.3	0.3	1.0	1.0
01/10/2024 07:00	3,794.4	0.0	3,794.4	105,380.0	399.9	0.5	0.2	0.2	0.8	0.8
01/10/2024 08:00	3,734.8	0.0	3,734.8	105,380.0	393.6	0.5	0.2	0.2	0.8	0.8
01/10/2024 09:00	4,237.6	0.0	4,237.6	105,380.0	446.6	0.5	0.3	0.3	0.9	0.9
01/10/2024 10:00	4,521.1	0.0	4,521.1	105,380.0	476.4	0.6	0.3	0.3	1.0	1.0
01/10/2024 11:00	3,721.2	0.0	3,721.2	105,380.0	392.1	0.5	0.2	0.2	0.8	0.8
01/10/2024 12:00	3,722.5	0.0	3,722.5	105,380.0	392.3	0.5	0.2	0.2	0.8	0.8
01/10/2024 13:00	3,723.9	0.0	3,723.9	105,380.0	392.4	0.5	0.2	0.2	0.8	0.8
01/10/2024 14:00	3,721.8	0.0	3,721.8	105,380.0	392.2	0.5	0.2	0.2	0.8	0.8
01/10/2024 15:00	3,722.2	0.0	3,722.2	105,380.0	392.2	0.5	0.2	0.2	0.8	0.8
01/10/2024 16:00	4,247.6	0.0	4,247.6	105,380.0	447.6	0.5	0.3	0.3	0.9	0.9
01/10/2024 17:00	4,156.1	0.0	4,156.1	105,380.0	438.0	0.5	0.3	0.3	0.9	0.9
01/10/2024 18:00	4,126.2	0.0	4,126.2	105,380.0	434.8	0.5	0.3	0.3	0.9	0.9
01/10/2024 19:00	3,757.8	0.0	3,757.8	105,380.0	396.0	0.5	0.2	0.2	0.8	0.8
01/10/2024 20:00	3,930.2	0.0	3,930.2	105,380.0	414.2	0.5	0.2	0.2	0.8	0.8
01/10/2024 21:00	3,786.7	0.0	3,786.7	105,380.0	399.0	0.5	0.2	0.2	0.8	0.8
01/10/2024 22:00	3,876.0	0.0	3,876.0	105,380.0	408.5	0.5	0.2	0.2	0.8	0.8
01/10/2024 23:00	4,559.2	0.0	4,559.2	105,380.0	480.4	0.6	0.3	0.3	1.0	1.0
Average/Sum#:	3,952.9	0.0	3,952.9	105,380.0	416.5	0.5	0.2	0.2	0.8	0.8
Minimum:	3,721.2	0.0	3,721.2	105,380.0	392.1	0.5	0.2	0.2	0.8	0.8
Maximum:	4,559.2	0.0	4,559.2	105,380.0	480.4	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2024 00:00	3,878.1	0.0	3,878.1	105,380.0	408.7	0.5	0.2	0.2	0.8	0.8
01/11/2024 01:00	3,670.9	0.0	3,670.9	105,380.0	386.8	0.5	0.2	0.2	0.8	0.8
01/11/2024 02:00	3,663.9	0.0	3,663.9	105,380.0	386.1	0.5	0.2	0.2	0.8	0.8
01/11/2024 03:00	3,671.3	0.0	3,671.3	105,380.0	386.9	0.5	0.2	0.2	0.8	0.8
01/11/2024 04:00	3,728.1	0.0	3,728.1	105,380.0	392.9	0.5	0.2	0.2	0.8	0.8
01/11/2024 05:00	4,100.4	0.0	4,100.4	105,380.0	432.1	0.5	0.3	0.3	0.9	0.9
01/11/2024 06:00	4,289.7	0.0	4,289.7	105,380.0	452.0	0.5	0.3	0.3	0.9	0.9
01/11/2024 07:00	4,850.0	0.0	4,850.0	105,380.0	511.1	0.6	0.3	0.3	1.0	1.0
01/11/2024 08:00	4,855.1	0.0	4,855.1	105,380.0	511.6	0.6	0.3	0.3	1.0	1.0
01/11/2024 09:00	4,764.7	0.0	4,764.7	105,380.0	502.1	0.6	0.3	0.3	1.0	1.0
01/11/2024 10:00	3,896.6	0.0	3,896.6	105,380.0	410.6	0.5	0.2	0.2	0.8	0.8
01/11/2024 11:00	3,676.8	0.0	3,676.8	105,380.0	387.5	0.5	0.2	0.2	0.8	0.8
01/11/2024 12:00	3,661.7	0.0	3,661.7	105,380.0	385.9	0.5	0.2	0.2	0.8	0.8
01/11/2024 13:00	3,775.3	0.0	3,775.3	105,380.0	397.8	0.5	0.2	0.2	0.8	0.8
01/11/2024 14:00	4,243.0	0.0	4,243.0	105,380.0	447.1	0.5	0.3	0.3	0.9	0.9
01/11/2024 15:00	3,864.2	0.0	3,864.2	105,380.0	407.2	0.5	0.2	0.2	0.8	0.8
01/11/2024 16:00	4,300.2	0.0	4,300.2	105,380.0	453.2	0.5	0.3	0.3	0.9	0.9
01/11/2024 17:00	4,703.6	0.0	4,703.6	105,380.0	495.7	0.6	0.3	0.3	1.0	1.0
01/11/2024 18:00	4,469.1	0.0	4,469.1	105,380.0	471.0	0.6	0.3	0.3	0.9	0.9
01/11/2024 19:00	4,351.9	0.0	4,351.9	105,380.0	458.6	0.6	0.3	0.3	0.9	0.9
01/11/2024 20:00	4,319.2	0.0	4,319.2	105,380.0	455.2	0.5	0.3	0.3	0.9	0.9
01/11/2024 21:00	4,550.1	0.0	4,550.1	105,380.0	479.5	0.6	0.3	0.3	1.0	1.0
01/11/2024 22:00	4,200.9	0.0	4,200.9	105,380.0	442.7	0.5	0.3	0.3	0.9	0.9
01/11/2024 23:00	4,755.7	0.0	4,755.7	105,380.0	501.2	0.6	0.3	0.3	1.0	1.0
Average/Sum#:	4,176.7	0.0	4,176.7	105,380.0	440.1	0.5	0.3	0.3	0.9	0.9
Minimum:	3,661.7	0.0	3,661.7	105,380.0	385.9	0.5	0.2	0.2	0.8	0.8
Maximum:	4,855.1	0.0	4,855.1	105,380.0	511.6	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2024 00:00	4,909.3	202.8	5,112.1	105,380.0	538.7	0.6	0.3	1.1
01/12/2024 01:00	4,908.8	219.7	5,128.5	105,380.0	540.4	0.6	0.3	1.1
01/12/2024 02:00	4,906.0	200.1	5,106.1	105,380.0	538.1	0.6	0.3	1.1
01/12/2024 03:00	4,906.2	200.7	5,106.9	105,380.0	538.2	0.6	0.3	1.1
01/12/2024 04:00	4,914.0	201.6	5,115.6	105,380.0	539.1	0.6	0.3	1.1
01/12/2024 05:00	4,914.3	316.7	5,231.0	105,380.0	551.2	0.7	0.3	1.1
01/12/2024 06:00	4,907.8	186.3	5,094.1	105,380.0	536.8	0.6	0.3	1.1
01/12/2024 07:00	4,909.9	542.9	5,452.8	105,380.0	574.6	0.7	0.3	1.1
01/12/2024 08:00	4,901.8	374.2	5,246.1	105,380.0	552.8	0.7	0.3	1.1
01/12/2024 09:00	4,921.1	1,724.6	6,645.7	105,380.0	700.3	0.8	0.4	1.4
01/12/2024 10:00	4,925.2	1,623.9	6,549.1	105,380.0	690.1	0.8	0.4	1.4
01/12/2024 11:00	4,920.3	1,219.7	6,140.0	105,380.0	647.0	0.8	0.4	1.3
01/12/2024 12:00	4,921.1	1,679.4	6,600.5	105,380.0	695.6	0.8	0.4	1.4
01/12/2024 13:00	4,901.5	1,783.5	6,685.0	105,380.0	704.5	0.8	0.4	1.4
01/12/2024 14:00	4,888.6	1,091.6	5,980.2	105,380.0	630.2	0.8	0.4	1.3
01/12/2024 15:00	4,886.4	253.6	5,140.0	105,380.0	541.7	0.7	0.3	1.1
01/12/2024 16:00	4,886.4	596.9	5,483.3	105,380.0	577.8	0.7	0.3	1.2
01/12/2024 17:00	4,889.0	198.0	5,087.0	105,380.0	536.1	0.6	0.3	1.1
01/12/2024 18:00	4,890.1	213.9	5,104.0	105,380.0	537.9	0.6	0.3	1.1
01/12/2024 19:00	4,894.1	684.6	5,544.5	105,380.0	584.3	0.7	0.4	1.2
01/12/2024 20:00	4,896.0	347.0	5,243.0	105,380.0	552.5	0.7	0.3	1.1
01/12/2024 21:00	4,899.3	1,275.6	6,174.9	105,380.0	650.7	0.8	0.4	1.3
01/12/2024 22:00	4,896.3	1,317.2	6,213.5	105,380.0	654.8	0.8	0.4	1.3
01/12/2024 23:00	4,896.4	200.0	5,096.4	105,380.0	537.1	0.6	0.3	1.1
Average/Sum#:	4,903.7	693.9	5,595.0	105,380.0	589.6	0.7	0.3	1.2
Minimum:	4,886.4	186.3	5,087.0	105,380.0	536.1	0.6	0.3	1.1
Maximum:	4,925.2	1,783.5	6,685.0	105,380.0	704.5	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2024 00:00	4,770.3	0.7	4,770.3	105,380.0	502.7	0.6	0.3	1.0
01/13/2024 01:00	4,794.6	0.0	4,794.6	105,380.0	505.3	0.6	0.3	1.0
01/13/2024 02:00	4,793.5	0.0	4,793.5	105,380.0	505.1	0.6	0.3	1.0
01/13/2024 03:00	4,792.6	0.0	4,792.6	105,380.0	505.0	0.6	0.3	1.0
01/13/2024 04:00	4,888.7	1,290.2	6,153.1	105,380.0	648.4	0.8	0.4	1.3
01/13/2024 05:00	4,892.0	1,824.4	6,716.4	105,380.0	707.8	0.9	0.4	1.4
01/13/2024 06:00	4,902.4	1,798.5	6,700.9	105,380.0	706.1	0.8	0.4	1.4
01/13/2024 07:00	4,916.5	530.9	5,447.4	105,380.0	574.0	0.7	0.3	1.1
01/13/2024 08:00	4,565.3	69.4	4,586.1	105,380.0	483.3	0.6	0.3	1.0
01/13/2024 09:00	4,821.9	80.0	4,840.3	105,380.0	510.1	0.6	0.3	1.0
01/13/2024 10:00	4,923.7	1,473.0	6,396.7	105,380.0	674.1	0.8	0.4	1.3
01/13/2024 11:00	4,912.0	1,620.7	6,532.7	105,380.0	688.4	0.8	0.4	1.4
01/13/2024 12:00	4,893.2	679.5	5,572.7	105,380.0	587.3	0.7	0.4	1.2
01/13/2024 13:00	4,834.7	73.7	4,856.8	105,380.0	511.8	0.6	0.3	1.0
01/13/2024 14:00	4,872.7	797.9	5,654.6	105,380.0	595.9	0.7	0.4	1.2
01/13/2024 15:00	4,877.8	571.9	5,449.7	105,380.0	574.3	0.7	0.3	1.1
01/13/2024 16:00	4,871.0	381.3	5,252.3	105,380.0	553.5	0.7	0.3	1.1
01/13/2024 17:00	4,864.6	754.0	5,618.6	105,380.0	592.1	0.7	0.4	1.2
01/13/2024 18:00	4,871.4	648.2	5,519.6	105,380.0	581.7	0.7	0.3	1.2
01/13/2024 19:00	4,879.1	969.6	5,848.7	105,380.0	616.3	0.7	0.4	1.2
01/13/2024 20:00	4,880.9	656.4	5,537.3	105,380.0	583.5	0.7	0.4	1.2
01/13/2024 21:00	4,869.4	400.9	5,270.3	105,380.0	555.4	0.7	0.3	1.1
01/13/2024 22:00	4,861.1	600.8	5,461.9	105,380.0	575.6	0.7	0.3	1.2
01/13/2024 23:00	4,852.9	611.9	5,464.8	105,380.0	575.9	0.7	0.3	1.2
Average/Sum#:	4,850.1	659.7	5,501.3	105,380.0	579.7	0.7	0.3	1.2
Minimum:	4,565.3	0.0	4,586.1	105,380.0	483.3	0.6	0.3	1.0
Maximum:	4,923.7	1,824.4	6,716.4	105,380.0	707.8	0.9	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2024 00:00	4,840.4	652.4	5,492.8	105,380.0	578.8	0.7	0.3	1.2
01/14/2024 01:00	4,837.6	665.6	5,503.2	105,380.0	579.9	0.7	0.3	1.2
01/14/2024 02:00	4,834.3	676.2	5,510.5	105,380.0	580.7	0.7	0.3	1.2
01/14/2024 03:00	4,832.7	693.9	5,526.6	105,380.0	582.4	0.7	0.3	1.2
01/14/2024 04:00	4,831.9	681.3	5,513.2	105,380.0	581.0	0.7	0.3	1.2
01/14/2024 05:00	4,842.9	656.4	5,499.3	105,380.0	579.5	0.7	0.3	1.2
01/14/2024 06:00	4,842.3	320.1	5,162.4	105,380.0	544.0	0.7	0.3	1.1
01/14/2024 07:00	4,849.5	293.9	5,143.4	105,380.0	542.0	0.6	0.3	1.1
01/14/2024 08:00	4,201.6	1.2	4,201.6	105,380.0	442.8	0.5	0.3	0.9
01/14/2024 09:00	3,763.7	0.0	3,763.7	105,380.0	396.6	0.5	0.2	0.8
01/14/2024 10:00	3,717.3	0.0	3,717.3	105,380.0	391.7	0.5	0.2	0.8
01/14/2024 11:00	3,661.0	0.0	3,661.0	105,380.0	385.8	0.5	0.2	0.8
01/14/2024 12:00	3,658.8	0.0	3,658.8	105,380.0	385.6	0.5	0.2	0.8
01/14/2024 13:00	3,669.9	0.0	3,669.9	105,380.0	386.7	0.5	0.2	0.8
01/14/2024 14:00	3,850.6	0.0	3,850.6	105,380.0	405.8	0.5	0.2	0.8
01/14/2024 15:00	3,749.3	0.0	3,749.3	105,380.0	395.1	0.5	0.2	0.8
01/14/2024 16:00	4,806.1	222.2	4,968.3	105,380.0	523.6	0.6	0.3	1.1
01/14/2024 17:00	4,761.1	184.8	4,903.4	105,380.0	516.7	0.6	0.3	1.0
01/14/2024 18:00	4,325.1	44.5	4,334.0	105,380.0	456.7	0.6	0.3	0.9
01/14/2024 19:00	4,874.0	259.2	5,133.2	105,380.0	540.9	0.6	0.3	1.1
01/14/2024 20:00	4,767.6	182.7	4,908.3	105,380.0	517.2	0.6	0.3	1.0
01/14/2024 21:00	4,020.6	0.0	4,020.6	105,380.0	423.7	0.5	0.3	0.8
01/14/2024 22:00	4,390.8	0.0	4,390.8	105,380.0	462.7	0.6	0.3	0.9
01/14/2024 23:00	4,315.9	0.0	4,315.9	105,380.0	454.8	0.5	0.3	0.9
Average/Sum#:	4,385.2	230.6	4,608.3	105,380.0	485.6	0.6	0.3	1.0
Minimum:	3,658.8	0.0	3,658.8	105,380.0	385.6	0.5	0.2	0.8
Maximum:	4,874.0	693.9	5,526.6	105,380.0	582.4	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2024 00:00	4,863.6	291.7	5,149.5	105,380.0	542.7	0.7	0.3	1.1
01/15/2024 01:00	4,766.7	225.9	4,940.6	105,380.0	520.6	0.6	0.3	1.1
01/15/2024 02:00	4,231.0	0.0	4,231.0	105,380.0	445.9	0.5	0.3	0.9
01/15/2024 03:00	4,876.5	289.1	5,165.6	105,380.0	544.4	0.7	0.3	1.1
01/15/2024 04:00	4,885.0	258.4	5,143.4	105,380.0	542.0	0.7	0.3	1.1
01/15/2024 05:00	4,884.5	227.2	5,111.7	105,380.0	538.7	0.6	0.3	1.1
01/15/2024 06:00	4,885.3	456.3	5,341.6	105,380.0	562.9	0.7	0.3	1.1
01/15/2024 07:00	4,880.5	1,366.7	6,247.2	105,380.0	658.3	0.8	0.4	1.3
01/15/2024 08:00	4,883.3	1,787.4	6,670.7	105,380.0	703.0	0.8	0.4	1.4
01/15/2024 09:00	4,874.6	1,661.5	6,536.1	105,380.0	688.8	0.8	0.4	1.4
01/15/2024 10:00	4,879.0	1,673.7	6,552.7	105,380.0	690.5	0.8	0.4	1.4
01/15/2024 11:00	4,876.1	1,346.6	6,222.7	105,380.0	655.7	0.8	0.4	1.3
01/15/2024 12:00	4,851.4	220.4	5,071.8	105,380.0	534.5	0.6	0.3	1.1
01/15/2024 13:00	4,486.8	121.4	4,549.9	105,380.0	479.5	0.6	0.3	1.0
01/15/2024 14:00	3,759.9	0.0	3,759.9	105,380.0	396.2	0.5	0.2	0.8
01/15/2024 15:00	4,573.6	142.0	4,648.9	105,380.0	489.9	0.6	0.3	1.0
01/15/2024 16:00	4,820.4	906.0	5,726.4	105,380.0	603.4	0.7	0.4	1.2
01/15/2024 17:00	4,833.9	1,059.1	5,893.0	105,380.0	621.0	0.7	0.4	1.2
01/15/2024 18:00	4,840.5	983.5	5,824.0	105,380.0	613.7	0.7	0.4	1.2
01/15/2024 19:00	4,854.6	992.5	5,847.1	105,380.0	616.2	0.7	0.4	1.2
01/15/2024 20:00	4,851.8	1,098.3	5,950.1	105,380.0	627.0	0.8	0.4	1.3
01/15/2024 21:00	4,870.8	1,079.1	5,949.9	105,380.0	627.0	0.8	0.4	1.3
01/15/2024 22:00	4,878.1	1,019.7	5,897.8	105,380.0	621.5	0.7	0.4	1.2
01/15/2024 23:00	4,883.7	937.9	5,821.6	105,380.0	613.5	0.7	0.4	1.2
Average/Sum#:	4,762.2	756.0	5,510.6	105,380.0	580.7	0.7	0.4	1.2
Minimum:	3,759.9	0.0	3,759.9	105,380.0	396.2	0.5	0.2	0.8
Maximum:	4,885.3	1,787.4	6,670.7	105,380.0	703.0	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2024 00:00	4,874.1	985.2	5,859.3	105,380.0	617.5	0.7	0.4	1.2			
01/16/2024 01:00	4,865.6	1,005.6	5,871.2	105,380.0	618.7	0.7	0.4	1.2			
01/16/2024 02:00	4,848.9	1,009.0	5,857.9	105,380.0	617.3	0.7	0.4	1.2			
01/16/2024 03:00	4,848.8	1,089.9	5,938.7	105,380.0	625.8	0.8	0.4	1.3			
01/16/2024 04:00	4,859.1	1,034.0	5,893.1	105,380.0	621.0	0.7	0.4	1.2			
01/16/2024 05:00	4,858.0	1,065.3	5,923.3	105,380.0	624.2	0.7	0.4	1.2			
01/16/2024 06:00	4,872.1	1,785.6	6,657.7	105,380.0	701.6	0.8	0.4	1.4			
01/16/2024 07:00	4,867.9	1,273.7	6,141.6	105,380.0	647.2	0.8	0.4	1.3			
01/16/2024 08:00	4,882.5	1,172.9	6,055.4	105,380.0	638.1	0.8	0.4	1.3			
01/16/2024 09:00	4,880.3	1,849.5	6,729.8	105,380.0	709.2	0.9	0.4	1.4			
01/16/2024 10:00	4,853.6	1,854.4	6,708.0	105,380.0	706.9	0.8	0.4	1.4			
01/16/2024 11:00	4,842.3	1,738.8	6,581.1	105,380.0	693.5	0.8	0.4	1.4			
01/16/2024 12:00	4,828.0	1,502.0	6,330.0	105,380.0	667.1	0.8	0.4	1.3			
01/16/2024 13:00	4,823.3	1,374.1	6,197.4	105,380.0	653.1	0.8	0.4	1.3			
01/16/2024 14:00	4,823.1	1,944.1	6,767.2	105,380.0	713.1	0.9	0.4	1.4			
01/16/2024 15:00	4,813.3	1,926.2	6,739.5	105,380.0	710.2	0.9	0.4	1.4			
01/16/2024 16:00	4,807.0	1,842.2	6,649.2	105,380.0	700.7	0.8	0.4	1.4			
01/16/2024 17:00	4,817.6	1,886.9	6,704.5	105,380.0	706.5	0.8	0.4	1.4			
01/16/2024 18:00	4,820.1	1,550.3	6,370.4	105,380.0	671.3	0.8	0.4	1.3			
01/16/2024 19:00	4,818.0	1,233.3	6,051.3	105,380.0	637.7	0.8	0.4	1.3			
01/16/2024 20:00	4,813.4	1,445.7	6,259.1	105,380.0	659.6	0.8	0.4	1.3			
01/16/2024 21:00	4,808.6	1,328.0	6,136.6	105,380.0	646.7	0.8	0.4	1.3			
01/16/2024 22:00	4,757.3	469.7	5,119.0	105,380.0	539.4	0.7	0.3	1.1			
01/16/2024 23:00	4,598.5	3.2	4,598.6	105,380.0	484.6	0.6	0.3	1.0			
Average/Sum#:	4,828.4	1,348.7	6,172.5	105,380.0	650.5	0.8	0.4	1.3			
Minimum:	4,598.5	3.2	4,598.6	105,380.0	484.6	0.6	0.3	1.0			
Maximum:	4,882.5	1,944.1	6,767.2	105,380.0	713.1	0.9	0.4	1.4			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2024 00:00	4,804.9	315.4	5,120.3	105,380.0	539.6	0.6	0.3	1.1
01/17/2024 01:00	4,800.4	334.1	5,134.5	105,380.0	541.1	0.6	0.3	1.1
01/17/2024 02:00	4,801.2	331.2	5,132.4	105,380.0	540.9	0.6	0.3	1.1
01/17/2024 03:00	4,797.8	328.3	5,126.1	105,380.0	540.2	0.6	0.3	1.1
01/17/2024 04:00	4,795.6	320.1	5,115.7	105,380.0	539.1	0.6	0.3	1.1
01/17/2024 05:00	4,801.5	310.8	5,112.3	105,380.0	538.7	0.6	0.3	1.1
01/17/2024 06:00	4,815.3	300.9	5,116.2	105,380.0	539.1	0.6	0.3	1.1
01/17/2024 07:00	4,813.0	834.7	5,647.7	105,380.0	595.2	0.7	0.4	1.2
01/17/2024 08:00	4,711.9	199.1	4,815.4	105,380.0	507.4	0.6	0.3	1.0
01/17/2024 09:00	4,641.5	0.0	4,641.5	105,380.0	489.1	0.6	0.3	1.0
01/17/2024 10:00	4,123.8	0.0	4,123.8	105,380.0	434.6	0.5	0.3	0.9
01/17/2024 11:00	3,634.5	0.0	3,634.5	105,380.0	383.0	0.5	0.2	0.8
01/17/2024 12:00	3,629.8	0.0	3,629.8	105,380.0	382.5	0.5	0.2	0.8
01/17/2024 13:00	3,626.2	0.0	3,626.2	105,380.0	382.1	0.5	0.2	0.8
01/17/2024 14:00	3,629.4	0.0	3,629.4	105,380.0	382.5	0.5	0.2	0.8
01/17/2024 15:00	3,690.8	0.0	3,690.8	105,380.0	388.9	0.5	0.2	0.8
01/17/2024 16:00	4,340.9	0.0	4,340.9	105,380.0	457.4	0.5	0.3	0.9
01/17/2024 17:00	4,707.9	0.0	4,707.9	105,380.0	496.1	0.6	0.3	1.0
01/17/2024 18:00	4,344.8	0.0	4,344.8	105,380.0	457.9	0.6	0.3	0.9
01/17/2024 19:00	3,738.3	0.0	3,738.3	105,380.0	393.9	0.5	0.2	0.8
01/17/2024 20:00	3,721.3	0.0	3,721.3	105,380.0	392.2	0.5	0.2	0.8
01/17/2024 21:00	3,956.7	0.0	3,956.7	105,380.0	417.0	0.5	0.3	0.8
01/17/2024 22:00	3,710.2	0.0	3,710.2	105,380.0	391.0	0.5	0.2	0.8
01/17/2024 23:00	3,702.1	0.0	3,702.1	105,380.0	390.1	0.5	0.2	0.8
Average/Sum#:	4,264.2	136.4	4,396.6	105,380.0	463.3	0.6	0.3	0.9
Minimum:	3,626.2	0.0	3,626.2	105,380.0	382.1	0.5	0.2	0.8
Maximum:	4,815.3	834.7	5,647.7	105,380.0	595.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2024 00:00	3,664.8	0.0	3,664.8	105,380.0	386.2	0.5	0.2	0.8
01/18/2024 01:00	3,649.3	0.0	3,649.3	105,380.0	384.6	0.5	0.2	0.8
01/18/2024 02:00	3,647.1	0.0	3,647.1	105,380.0	384.3	0.5	0.2	0.8
01/18/2024 03:00	3,663.0	0.0	3,663.0	105,380.0	386.0	0.5	0.2	0.8
01/18/2024 04:00	3,683.8	0.0	3,683.8	105,380.0	388.2	0.5	0.2	0.8
01/18/2024 05:00	3,969.9	0.0	3,969.9	105,380.0	418.3	0.5	0.3	0.8
01/18/2024 06:00	4,303.7	0.0	4,303.7	105,380.0	453.5	0.5	0.3	0.9
01/18/2024 07:00	4,634.5	0.0	4,634.5	105,380.0	488.4	0.6	0.3	1.0
01/18/2024 08:00	4,668.1	0.0	4,668.1	105,380.0	491.9	0.6	0.3	1.0
01/18/2024 09:00	4,822.0	0.0	4,822.0	105,380.0	508.1	0.6	0.3	1.0
01/18/2024 10:00	4,277.4	0.0	4,277.4	105,380.0	450.8	0.5	0.3	0.9
01/18/2024 11:00	4,804.1	0.0	4,804.1	105,380.0	506.3	0.6	0.3	1.0
01/18/2024 12:00	4,580.1	0.0	4,580.1	105,380.0	482.7	0.6	0.3	1.0
01/18/2024 13:00	4,730.0	0.0	4,730.0	105,380.0	498.4	0.6	0.3	1.0
01/18/2024 14:00	3,829.9	0.0	3,829.9	105,380.0	403.6	0.5	0.2	0.8
01/18/2024 15:00	4,430.7	0.0	4,430.7	105,380.0	466.9	0.6	0.3	0.9
01/18/2024 16:00	4,532.2	0.0	4,532.2	105,380.0	477.6	0.6	0.3	1.0
01/18/2024 17:00	4,764.5	0.0	4,764.5	105,380.0	502.1	0.6	0.3	1.0
01/18/2024 18:00	4,767.3	0.0	4,767.3	105,380.0	502.4	0.6	0.3	1.0
01/18/2024 19:00	4,770.0	0.0	4,770.0	105,380.0	502.7	0.6	0.3	1.0
01/18/2024 20:00	4,779.6	0.0	4,779.6	105,380.0	503.7	0.6	0.3	1.0
01/18/2024 21:00	4,772.4	0.0	4,772.4	105,380.0	502.9	0.6	0.3	1.0
01/18/2024 22:00	4,771.8	0.0	4,771.8	105,380.0	502.9	0.6	0.3	1.0
01/18/2024 23:00	4,729.2	0.0	4,729.2	105,380.0	498.4	0.6	0.3	1.0
Average/Sum#:	4,385.2	0.0	4,385.2	105,380.0	462.1	0.6	0.3	0.9
Minimum:	3,647.1	0.0	3,647.1	105,380.0	384.3	0.5	0.2	0.8
Maximum:	4,822.0	0.0	4,822.0	105,380.0	508.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2024 00:00	4,790.8	0.0	4,790.8	105,380.0	504.9	0.6	0.3	0.3	1.0	1.0
01/19/2024 01:00	4,799.7	0.0	4,799.7	105,380.0	505.8	0.6	0.3	0.3	1.0	1.0
01/19/2024 02:00	4,798.4	0.0	4,798.4	105,380.0	505.7	0.6	0.3	0.3	1.0	1.0
01/19/2024 03:00	4,842.1	613.3	5,320.5	105,380.0	560.7	0.7	0.3	0.3	1.1	1.1
01/19/2024 04:00	4,858.5	983.9	5,842.4	105,380.0	615.7	0.7	0.4	0.4	1.2	1.2
01/19/2024 05:00	4,863.3	1,125.9	5,989.2	105,380.0	631.1	0.8	0.4	0.4	1.3	1.3
01/19/2024 06:00	4,867.3	1,375.1	6,242.4	105,380.0	657.8	0.8	0.4	0.4	1.3	1.3
01/19/2024 07:00	4,865.5	1,795.3	6,660.8	105,380.0	701.9	0.8	0.4	0.4	1.4	1.4
01/19/2024 08:00	4,857.4	1,014.4	5,871.8	105,380.0	618.8	0.7	0.4	0.4	1.2	1.2
01/19/2024 09:00	4,864.2	1,266.6	6,130.8	105,380.0	646.1	0.8	0.4	0.4	1.3	1.3
01/19/2024 10:00	4,832.9	1,373.1	6,206.0	105,380.0	654.0	0.8	0.4	0.4	1.3	1.3
01/19/2024 11:00	4,793.0	1,096.9	5,889.9	105,380.0	620.7	0.7	0.4	0.4	1.2	1.2
01/19/2024 12:00	4,741.4	492.9	5,185.0	105,380.0	546.4	0.7	0.3	0.3	1.1	1.1
01/19/2024 13:00	4,742.9	0.0	4,742.9	105,380.0	499.8	0.6	0.3	0.3	1.0	1.0
01/19/2024 14:00	4,727.2	0.0	4,727.2	105,380.0	498.2	0.6	0.3	0.3	1.0	1.0
01/19/2024 15:00	4,768.3	1,046.9	5,794.3	105,380.0	610.6	0.7	0.4	0.4	1.2	1.2
01/19/2024 16:00	4,773.0	1,092.8	5,865.8	105,380.0	618.1	0.7	0.4	0.4	1.2	1.2
01/19/2024 17:00	4,793.5	1,068.9	5,862.4	105,380.0	617.8	0.7	0.4	0.4	1.2	1.2
01/19/2024 18:00	4,793.0	1,069.3	5,862.3	105,380.0	617.8	0.7	0.4	0.4	1.2	1.2
01/19/2024 19:00	4,793.0	1,093.4	5,886.4	105,380.0	620.3	0.7	0.4	0.4	1.2	1.2
01/19/2024 20:00	4,794.2	1,249.4	6,043.6	105,380.0	636.9	0.8	0.4	0.4	1.3	1.3
01/19/2024 21:00	4,793.9	1,260.8	6,054.7	105,380.0	638.0	0.8	0.4	0.4	1.3	1.3
01/19/2024 22:00	4,772.7	1,097.5	5,870.2	105,380.0	618.6	0.7	0.4	0.4	1.2	1.2
01/19/2024 23:00	4,774.0	1,033.3	5,807.3	105,380.0	612.0	0.7	0.4	0.4	1.2	1.2
Average/Sum#:	4,804.2	881.2	5,676.9	105,380.0	598.2	0.7	0.4	0.4	1.2	1.2
Minimum:	4,727.2	0.0	4,727.2	105,380.0	498.2	0.6	0.3	0.3	1.0	1.0
Maximum:	4,867.3	1,795.3	6,660.8	105,380.0	701.9	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2024 00:00	4,760.0	1,057.2	5,817.2	105,380.0	613.0	0.7	0.4	1.2
01/20/2024 01:00	4,754.0	612.2	5,366.2	105,380.0	565.5	0.7	0.3	1.1
01/20/2024 02:00	4,758.7	606.3	5,365.0	105,380.0	565.4	0.7	0.3	1.1
01/20/2024 03:00	4,778.0	700.3	5,478.3	105,380.0	577.3	0.7	0.3	1.2
01/20/2024 04:00	4,781.4	747.7	5,529.1	105,380.0	582.7	0.7	0.3	1.2
01/20/2024 05:00	4,773.2	988.4	5,761.6	105,380.0	607.2	0.7	0.4	1.2
01/20/2024 06:00	4,771.5	859.1	5,630.6	105,380.0	593.4	0.7	0.4	1.2
01/20/2024 07:00	4,772.5	865.0	5,637.5	105,380.0	594.1	0.7	0.4	1.2
01/20/2024 08:00	4,753.6	118.2	4,816.2	105,380.0	507.5	0.6	0.3	1.0
01/20/2024 09:00	4,746.4	65.4	4,811.8	105,380.0	507.1	0.6	0.3	1.0
01/20/2024 10:00	4,669.8	27.3	4,681.5	105,380.0	493.3	0.6	0.3	1.0
01/20/2024 11:00	4,716.6	0.0	4,716.6	105,380.0	497.0	0.6	0.3	1.0
01/20/2024 12:00	4,692.7	0.0	4,692.7	105,380.0	494.5	0.6	0.3	1.0
01/20/2024 13:00	4,685.4	187.9	4,738.0	105,380.0	499.3	0.6	0.3	1.0
01/20/2024 14:00	4,695.9	1,354.5	6,050.4	105,380.0	637.6	0.8	0.4	1.3
01/20/2024 15:00	4,771.8	1,323.1	6,094.9	105,380.0	642.3	0.8	0.4	1.3
01/20/2024 16:00	4,777.1	1,081.1	5,858.2	105,380.0	617.3	0.7	0.4	1.2
01/20/2024 17:00	4,771.4	1,095.1	5,866.5	105,380.0	618.2	0.7	0.4	1.2
01/20/2024 18:00	4,776.8	698.4	5,475.2	105,380.0	577.0	0.7	0.3	1.2
01/20/2024 19:00	4,780.7	1,017.5	5,798.2	105,380.0	611.0	0.7	0.4	1.2
01/20/2024 20:00	4,774.7	1,151.6	5,926.3	105,380.0	624.5	0.8	0.4	1.2
01/20/2024 21:00	4,774.0	1,142.2	5,916.2	105,380.0	623.4	0.7	0.4	1.2
01/20/2024 22:00	4,777.5	970.4	5,747.9	105,380.0	605.7	0.7	0.4	1.2
01/20/2024 23:00	4,314.0	87.2	4,337.5	105,380.0	457.1	0.6	0.3	0.9
Average/Sum#:	4,734.5	698.2	5,421.4	105,380.0	571.3	0.7	0.4	1.1
Minimum:	4,314.0	0.0	4,337.5	105,380.0	457.1	0.6	0.3	0.9
Maximum:	4,781.4	1,354.5	6,094.9	105,380.0	642.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2024 00:00	4,229.5	0.0	4,229.5	105,380.0	445.7	0.5	0.3	0.3	0.9	0.9
01/21/2024 01:00	4,385.7	0.0	4,385.7	105,380.0	462.2	0.6	0.3	0.3	0.9	0.9
01/21/2024 02:00	3,927.5	0.0	3,927.5	105,380.0	413.9	0.5	0.2	0.2	0.8	0.8
01/21/2024 03:00	3,647.8	0.0	3,647.8	105,380.0	384.4	0.5	0.2	0.2	0.8	0.8
01/21/2024 04:00	3,645.9	0.0	3,645.9	105,380.0	384.2	0.5	0.2	0.2	0.8	0.8
01/21/2024 05:00	3,689.1	0.0	3,689.1	105,380.0	388.8	0.5	0.2	0.2	0.8	0.8
01/21/2024 06:00	3,642.9	0.0	3,642.9	105,380.0	383.9	0.5	0.2	0.2	0.8	0.8
01/21/2024 07:00	4,323.2	0.0	4,323.2	105,380.0	455.6	0.5	0.3	0.3	0.9	0.9
01/21/2024 08:00	4,549.4	0.0	4,549.4	105,380.0	479.4	0.6	0.3	0.3	1.0	1.0
01/21/2024 09:00	4,231.2	0.0	4,231.2	105,380.0	445.9	0.5	0.3	0.3	0.9	0.9
01/21/2024 10:00	3,638.1	0.0	3,638.1	105,380.0	383.4	0.5	0.2	0.2	0.8	0.8
01/21/2024 11:00	3,634.7	0.0	3,634.7	105,380.0	383.0	0.5	0.2	0.2	0.8	0.8
01/21/2024 12:00	3,631.3	0.0	3,631.3	105,380.0	382.7	0.5	0.2	0.2	0.8	0.8
01/21/2024 13:00	3,630.2	0.0	3,630.2	105,380.0	382.6	0.5	0.2	0.2	0.8	0.8
01/21/2024 14:00	3,628.8	0.0	3,628.8	105,380.0	382.4	0.5	0.2	0.2	0.8	0.8
01/21/2024 15:00	3,643.5	0.0	3,643.5	105,380.0	384.0	0.5	0.2	0.2	0.8	0.8
01/21/2024 16:00	3,937.3	0.0	3,937.3	105,380.0	414.9	0.5	0.2	0.2	0.8	0.8
01/21/2024 17:00	4,590.9	0.0	4,590.9	105,380.0	483.8	0.6	0.3	0.3	1.0	1.0
01/21/2024 18:00	4,596.9	0.0	4,596.9	105,380.0	484.4	0.6	0.3	0.3	1.0	1.0
01/21/2024 19:00	4,632.0	0.0	4,632.0	105,380.0	488.1	0.6	0.3	0.3	1.0	1.0
01/21/2024 20:00	3,953.0	0.0	3,953.0	105,380.0	416.6	0.5	0.2	0.2	0.8	0.8
01/21/2024 21:00	3,901.7	0.0	3,901.7	105,380.0	411.2	0.5	0.2	0.2	0.8	0.8
01/21/2024 22:00	3,637.8	0.0	3,637.8	105,380.0	383.4	0.5	0.2	0.2	0.8	0.8
01/21/2024 23:00	3,636.7	0.0	3,636.7	105,380.0	383.2	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,956.9	0.0	3,956.9	105,380.0	417.0	0.5	0.2	0.2	0.9	0.9
Minimum:	3,628.8	0.0	3,628.8	105,380.0	382.4	0.5	0.2	0.2	0.8	0.8
Maximum:	4,632.0	0.0	4,632.0	105,380.0	488.1	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2024 00:00	3,761.8	0.0	3,761.8	105,380.0	396.4	0.5	0.2	0.8			
01/22/2024 01:00	3,691.7	0.0	3,691.7	105,380.0	389.0	0.5	0.2	0.8			
01/22/2024 02:00	3,629.9	0.0	3,629.9	105,380.0	382.5	0.5	0.2	0.8			
01/22/2024 03:00	3,637.5	0.0	3,637.5	105,380.0	383.3	0.5	0.2	0.8			
01/22/2024 04:00	3,850.0	0.0	3,850.0	105,380.0	405.7	0.5	0.2	0.8			
01/22/2024 05:00	4,318.3	94.9	4,342.0	105,380.0	457.6	0.6	0.3	0.9			
01/22/2024 06:00	4,761.5	441.1	5,202.6	105,380.0	548.2	0.7	0.3	1.1			
01/22/2024 07:00	4,763.1	534.3	5,297.4	105,380.0	558.2	0.7	0.3	1.1			
01/22/2024 08:00	4,763.6	1,667.4	6,431.0	105,380.0	677.7	0.8	0.4	1.4			
01/22/2024 09:00	4,753.8	1,921.9	6,675.7	105,380.0	703.5	0.8	0.4	1.4			
01/22/2024 10:00	4,742.2	1,268.1	6,010.3	105,380.0	633.4	0.8	0.4	1.3			
01/22/2024 11:00	4,734.4	847.2	5,581.6	105,380.0	588.2	0.7	0.4	1.2			
01/22/2024 12:00	4,731.9	1,067.6	5,799.5	105,380.0	611.2	0.7	0.4	1.2			
01/22/2024 13:00	4,722.1	815.6	5,537.7	105,380.0	583.6	0.7	0.4	1.2			
01/22/2024 14:00	4,712.8	758.5	5,471.3	105,380.0	576.6	0.7	0.3	1.2			
01/22/2024 15:00	4,711.9	745.9	5,457.8	105,380.0	575.1	0.7	0.3	1.2			
01/22/2024 16:00	4,721.5	712.7	5,434.2	105,380.0	572.7	0.7	0.3	1.1			
01/22/2024 17:00	4,738.5	924.3	5,662.8	105,380.0	596.7	0.7	0.4	1.2			
01/22/2024 18:00	4,745.9	439.4	5,185.3	105,380.0	546.4	0.7	0.3	1.1			
01/22/2024 19:00	4,753.3	408.8	5,162.1	105,380.0	544.0	0.7	0.3	1.1			
01/22/2024 20:00	4,759.9	392.2	5,152.1	105,380.0	542.9	0.7	0.3	1.1			
01/22/2024 21:00	4,765.5	383.9	5,149.4	105,380.0	542.6	0.7	0.3	1.1			
01/22/2024 22:00	4,188.1	91.5	4,212.8	105,380.0	443.9	0.5	0.3	0.9			
01/22/2024 23:00	3,997.8	0.0	3,997.8	105,380.0	421.3	0.5	0.3	0.8			
Average/Sum#:	4,456.5	563.1	5,013.9	105,380.0	528.4	0.7	0.3	1.1			
Minimum:	3,629.9	0.0	3,629.9	105,380.0	382.5	0.5	0.2	0.8			
Maximum:	4,765.5	1,921.9	6,675.7	105,380.0	703.5	0.8	0.4	1.4			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2024 00:00	4,005.8	0.0	4,005.8	105,380.0	422.1	0.5	0.3	0.3	0.8	0.8
01/23/2024 01:00	3,765.4	0.0	3,765.4	105,380.0	396.8	0.5	0.2	0.2	0.8	0.8
01/23/2024 02:00	3,783.1	0.0	3,783.1	105,380.0	398.7	0.5	0.2	0.2	0.8	0.8
01/23/2024 03:00	3,836.9	0.0	3,836.9	105,380.0	404.3	0.5	0.2	0.2	0.8	0.8
01/23/2024 04:00	3,942.3	0.0	3,942.3	105,380.0	415.4	0.5	0.2	0.2	0.8	0.8
01/23/2024 05:00	4,469.1	128.1	4,505.0	105,380.0	474.7	0.6	0.3	0.3	1.0	1.0
01/23/2024 06:00	4,789.5	787.3	5,576.8	105,380.0	587.7	0.7	0.4	0.4	1.2	1.2
01/23/2024 07:00	4,742.0	454.9	5,092.3	105,380.0	536.6	0.7	0.3	0.3	1.1	1.1
01/23/2024 08:00	3,929.8	0.0	3,929.8	105,380.0	414.1	0.5	0.2	0.2	0.8	0.8
01/23/2024 09:00	3,804.4	0.0	3,804.4	105,380.0	400.9	0.5	0.2	0.2	0.8	0.8
01/23/2024 10:00	3,661.7	0.0	3,661.7	105,380.0	385.9	0.5	0.2	0.2	0.8	0.8
01/23/2024 11:00	3,645.4	0.0	3,645.4	105,380.0	384.2	0.5	0.2	0.2	0.8	0.8
01/23/2024 12:00	3,641.7	0.0	3,641.7	105,380.0	383.8	0.5	0.2	0.2	0.8	0.8
01/23/2024 13:00	3,641.1	0.0	3,641.1	105,380.0	383.7	0.5	0.2	0.2	0.8	0.8
01/23/2024 14:00	3,652.5	0.0	3,652.5	105,380.0	384.9	0.5	0.2	0.2	0.8	0.8
01/23/2024 15:00	3,646.2	0.0	3,646.2	105,380.0	384.2	0.5	0.2	0.2	0.8	0.8
01/23/2024 16:00	4,325.0	128.3	4,360.9	105,380.0	459.6	0.6	0.3	0.3	0.9	0.9
01/23/2024 17:00	4,758.2	719.3	5,477.5	105,380.0	577.2	0.7	0.3	0.3	1.2	1.2
01/23/2024 18:00	4,785.1	981.5	5,766.6	105,380.0	607.7	0.7	0.4	0.4	1.2	1.2
01/23/2024 19:00	4,794.8	1,061.2	5,856.0	105,380.0	617.1	0.7	0.4	0.4	1.2	1.2
01/23/2024 20:00	4,805.5	1,068.8	5,874.3	105,380.0	619.0	0.7	0.4	0.4	1.2	1.2
01/23/2024 21:00	4,811.0	1,404.4	6,215.4	105,380.0	655.0	0.8	0.4	0.4	1.3	1.3
01/23/2024 22:00	4,818.6	1,219.0	6,037.6	105,380.0	636.2	0.8	0.4	0.4	1.3	1.3
01/23/2024 23:00	4,823.4	807.9	5,631.3	105,380.0	593.4	0.7	0.4	0.4	1.2	1.2
Average/Sum#:	4,203.3	365.0	4,556.3	105,380.0	480.1	0.6	0.3	0.3	1.0	1.0
Minimum:	3,641.1	0.0	3,641.1	105,380.0	383.7	0.5	0.2	0.2	0.8	0.8
Maximum:	4,823.4	1,404.4	6,215.4	105,380.0	655.0	0.8	0.4	0.4	1.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2024 00:00	4,826.6	537.1	5,363.7	105,380.0	565.2	0.7	0.3	1.1			
01/24/2024 01:00	4,386.2	1.4	4,386.2	105,380.0	462.2	0.6	0.3	0.9			
01/24/2024 02:00	4,336.9	0.0	4,336.9	105,380.0	457.0	0.5	0.3	0.9			
01/24/2024 03:00	4,592.9	0.0	4,592.9	105,380.0	484.0	0.6	0.3	1.0			
01/24/2024 04:00	4,780.3	95.9	4,802.4	105,380.0	506.1	0.6	0.3	1.0			
01/24/2024 05:00	4,831.4	778.4	5,609.8	105,380.0	591.2	0.7	0.4	1.2			
01/24/2024 06:00	4,823.7	871.2	5,694.9	105,380.0	600.1	0.7	0.4	1.2			
01/24/2024 07:00	4,830.2	966.2	5,796.4	105,380.0	610.8	0.7	0.4	1.2			
01/24/2024 08:00	4,829.2	1,411.1	6,240.3	105,380.0	657.6	0.8	0.4	1.3			
01/24/2024 09:00	4,824.5	1,484.3	6,308.8	105,380.0	664.8	0.8	0.4	1.3			
01/24/2024 10:00	4,824.2	1,232.3	6,056.5	105,380.0	638.2	0.8	0.4	1.3			
01/24/2024 11:00	4,802.5	1,106.4	5,908.9	105,380.0	622.7	0.7	0.4	1.2			
01/24/2024 12:00	4,789.9	751.8	5,541.7	105,380.0	584.0	0.7	0.4	1.2			
01/24/2024 13:00	4,805.3	900.4	5,705.7	105,380.0	601.3	0.7	0.4	1.2			
01/24/2024 14:00	4,801.3	1,183.1	5,984.4	105,380.0	630.6	0.8	0.4	1.3			
01/24/2024 15:00	4,800.3	1,385.3	6,185.6	105,380.0	651.8	0.8	0.4	1.3			
01/24/2024 16:00	4,799.8	1,437.7	6,237.5	105,380.0	657.3	0.8	0.4	1.3			
01/24/2024 17:00	4,805.2	1,210.1	6,015.3	105,380.0	633.9	0.8	0.4	1.3			
01/24/2024 18:00	4,802.0	1,207.5	6,009.5	105,380.0	633.3	0.8	0.4	1.3			
01/24/2024 19:00	4,799.1	1,209.1	6,008.2	105,380.0	633.1	0.8	0.4	1.3			
01/24/2024 20:00	4,796.6	1,104.1	5,900.7	105,380.0	621.8	0.7	0.4	1.2			
01/24/2024 21:00	4,797.6	924.2	5,721.8	105,380.0	603.0	0.7	0.4	1.2			
01/24/2024 22:00	4,748.2	539.8	5,163.8	105,380.0	544.2	0.7	0.3	1.1			
01/24/2024 23:00	3,755.7	0.0	3,755.7	105,380.0	395.8	0.5	0.2	0.8			
Average/Sum#:	4,716.2	847.4	5,555.3	105,380.0	585.4	0.7	0.4	1.2			
Minimum:	3,755.7	0.0	3,755.7	105,380.0	395.8	0.5	0.2	0.8			
Maximum:	4,831.4	1,484.3	6,308.8	105,380.0	664.8	0.8	0.4	1.3			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2024 00:00	3,384.8	0.0	3,384.8	105,380.0	356.7	0.5	0.2	0.8
01/25/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/25/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,384.8	0.0	3,384.8	105,380.0	356.7	0.5	0.2	0.8
Minimum:	3,384.8	0.0	3,384.8	105,380.0	356.7	0.5	0.2	0.8
Maximum:	3,384.8	0.0	3,384.8	105,380.0	356.7	0.5	0.2	0.8
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 16:00	2,969.0	0.0	2,969.0	105,380.0	312.9	0.5	0.3	0.9
01/26/2024 17:00	4,798.4	242.4	4,980.2	105,380.0	524.8	0.6	0.3	1.1
01/26/2024 18:00	4,812.9	295.8	5,108.7	105,380.0	538.4	0.6	0.3	1.1
01/26/2024 19:00	4,758.0	211.7	4,927.4	105,380.0	519.2	0.6	0.3	1.0
01/26/2024 20:00	4,059.4	0.0	4,059.4	105,380.0	427.8	0.5	0.3	0.9
01/26/2024 21:00	3,441.4	0.0	3,441.4	105,380.0	362.7	0.5	0.2	0.8
01/26/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/26/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,139.9	125.0	4,247.7	105,380.0	447.6	0.6	0.3	1.0
Minimum:	2,969.0	0.0	2,969.0	105,380.0	312.9	0.5	0.2	0.8
Maximum:	4,812.9	295.8	5,108.7	105,380.0	538.4	0.6	0.3	1.1
%SI	75.00	75.00	75.00	0.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/27/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
01/28/2024 00:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 01:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 02:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 03:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 04:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 05:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 06:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 07:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 08:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 09:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 10:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 11:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 12:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 13:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 14:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 15:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 16:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 17:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 18:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 19:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 20:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 21:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 22:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
01/28/2024 23:00	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,380.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/29/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/30/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 10:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 11:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 12:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 13:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 14:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 15:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 16:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 17:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 18:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 19:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 20:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 21:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 22:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
01/31/2024 23:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2024 00:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 01:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 02:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 03:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 04:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 05:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 06:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 07:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 08:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 09:00	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
02/01/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/01/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,299.5	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,380.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/02/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/03/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/04/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
02/05/2024 00:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 01:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 02:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 03:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 04:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 05:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 06:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 07:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 08:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 09:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 10:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 11:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 12:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 13:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 14:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 15:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 16:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 17:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 18:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 19:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 20:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 21:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 22:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
02/05/2024 23:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:									
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
02/06/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/07/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/08/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/09/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/10/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/11/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/12/2024 16:00	2,703.7	0.0	2,703.7	105,242.0	284.5	0.0	0.0	0.0
02/12/2024 17:00	4,272.9	0.0	4,272.9	105,242.0	449.7	0.6	0.3	1.0
02/12/2024 18:00	4,685.7	0.0	4,685.7	105,242.0	493.1	0.6	0.3	1.0
02/12/2024 19:00	4,775.9	0.0	4,775.9	105,242.0	502.6	0.6	0.3	1.0
02/12/2024 20:00	4,766.2	0.0	4,766.2	105,242.0	501.6	0.6	0.3	1.0
02/12/2024 21:00	4,246.7	0.0	4,246.7	105,242.0	446.9	0.5	0.3	0.9
02/12/2024 22:00	3,336.7	0.0	3,336.7	105,242.0	351.2	0.5	0.2	0.8
02/12/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,112.5	0.0	4,112.5	105,242.0	432.8	0.6	0.3	1.0
Minimum:	2,703.7	0.0	2,703.7	105,242.0	284.5	0.5	0.2	0.8
Maximum:	4,775.9	0.0	4,775.9	105,242.0	502.6	0.6	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/13/2024 12:00	2,325.4	0.0	2,325.4	105,242.0	244.7	0.0	0.0	0.0
02/13/2024 13:00	3,800.7	0.0	3,800.7	105,242.0	400.0	0.5	0.2	0.8
02/13/2024 14:00	3,846.8	0.0	3,846.8	105,242.0	404.8	0.5	0.2	0.8
02/13/2024 15:00	4,684.0	0.0	4,684.0	105,242.0	493.0	0.6	0.3	1.0
02/13/2024 16:00	4,133.6	0.0	4,133.6	105,242.0	435.0	0.5	0.3	0.9
02/13/2024 17:00	4,394.4	0.0	4,394.4	105,242.0	462.5	0.6	0.3	0.9
02/13/2024 18:00	4,665.5	0.0	4,665.5	105,242.0	491.0	0.6	0.3	1.0
02/13/2024 19:00	4,677.1	0.0	4,677.1	105,242.0	492.2	0.6	0.3	1.0
02/13/2024 20:00	4,687.1	0.0	4,687.1	105,242.0	493.3	0.6	0.3	1.0
02/13/2024 21:00	4,665.9	0.0	4,665.9	105,242.0	491.0	0.6	0.3	1.0
02/13/2024 22:00	3,773.9	0.0	3,773.9	105,242.0	397.2	0.5	0.3	0.9
02/13/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,150.4	0.0	4,150.4	105,242.0	436.8	0.6	0.3	0.9
Minimum:	2,325.4	0.0	2,325.4	105,242.0	244.7	0.5	0.2	0.8
Maximum:	4,687.1	0.0	4,687.1	105,242.0	493.3	0.6	0.3	1.0
%SI	54.17	54.17	54.17	0.00	54.17	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/14/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/15/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/17/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/18/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/19/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/20/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/21/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/22/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/23/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	70.83	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/26/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	41.67	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 01:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 02:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 03:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 04:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 05:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 07:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 08:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 09:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 10:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 11:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 12:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 13:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 14:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 15:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 16:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 17:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 18:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 19:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 20:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 21:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 22:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/27/2024 23:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2024 00:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
02/28/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	95.83	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)		1 Hour(s)	1 Hour(s)
02/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
02/29/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00		100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
03/01/2024 00:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 01:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 02:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 03:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 04:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 05:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 06:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 07:00	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 08:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 09:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 10:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 11:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 12:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 13:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 14:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 15:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 16:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 17:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 18:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 19:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 20:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 21:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 22:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
03/01/2024 23:00	0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,242.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		95.83		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2024 06:00	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
03/04/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/04/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,613.2	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,242.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	25.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/05/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/06/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 08:00	0.0	7.4	16.5	105,635.0	1.7	0.0	0.0	0.0
03/07/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 14:00	0.0	418.2	142.2	105,635.0	15.0	0.1	0.1	0.2
03/07/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/07/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	212.8	79.4	105,635.0	8.4	0.1	0.1	0.2
Minimum:	0.0	7.4	16.5	105,635.0	1.7	0.1	0.1	0.2
Maximum:	0.0	418.2	142.2	105,635.0	15.0	0.1	0.1	0.2
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/08/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/09/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/10/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 06:00	2,574.9	103.9	2,574.9	105,635.0	272.0	0.0	0.0	0.0
03/11/2024 07:00	4,805.1	106.3	4,805.1	105,635.0	507.6	0.6	0.3	1.0
03/11/2024 08:00	4,836.7	98.7	4,836.7	105,635.0	510.9	0.6	0.3	1.0
03/11/2024 09:00	4,148.3	94.7	4,148.3	105,635.0	438.2	0.5	0.3	0.9
03/11/2024 10:00	3,863.6	88.6	3,863.6	105,635.0	408.1	0.5	0.3	0.8
03/11/2024 11:00	3,267.4	80.8	3,267.4	105,635.0	345.2	0.4	0.2	0.7
03/11/2024 12:00	2,999.0	75.5	2,999.0	105,635.0	316.8	0.4	0.2	0.7
03/11/2024 13:00	3,206.7	74.5	3,206.7	105,635.0	338.7	0.4	0.2	0.7
03/11/2024 14:00	1,099.6	87.9	1,099.6	105,635.0	116.2	0.0	0.0	0.0
03/11/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/11/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,422.4	90.1	3,422.4	105,635.0	361.5	0.5	0.3	0.8
Minimum:	1,099.6	74.5	1,099.6	105,635.0	116.2	0.4	0.2	0.7
Maximum:	4,836.7	106.3	4,836.7	105,635.0	510.9	0.6	0.3	1.0
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/12/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/13/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/14/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/15/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
03/16/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/17/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/18/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/19/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/20/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/21/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/22/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/23/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/24/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/25/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/26/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/27/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/28/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/29/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/30/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2024 00:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 01:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 02:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 03:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 04:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 05:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 06:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 07:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 08:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 09:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 10:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 11:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 12:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 13:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 14:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 15:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 16:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 17:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 18:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 19:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 20:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 21:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 22:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
03/31/2024 23:00	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,635.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

AQ-36 thru AQ-38, AQ-41, & AQ-117

AQ-36 thru AQ-38, AQ-41, & AQ-117: PCAPCD notifications/
corrective action: breakdowns, excess emissions, CEMS inoperable, or a
negative declaration when no excess emissions occurred.

Verification: The Project owner shall include the identification of all
breakdowns, PCAPCD notification, resulting excess emission (if any) and
corrective actions taken (if any) as part of the Quarterly Air Quality
Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 01/01/2024 00:00 **To:** 03/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/13/2024 02:06 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 47.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 44.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2024 00:00 **To:** 03/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/13/2024 02:07 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 47.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 44.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2024 00:00 **To:** 03/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/13/2024 02:07 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 47.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 44.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2024 00:00 **To:** 03/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/13/2024 02:08 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 47.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 44.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:09 Location: Roseville, CA



Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:09 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:11 Location: Roseville, CA

Tag Name: CT1_CO_SUSd_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:12 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:13 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:13 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:14 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:14 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT1



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:15 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:16 Location: Roseville, CA



Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,189.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:17 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:17 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:18 Location: Roseville, CA

Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:18 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:18 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:19 Location: Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:19 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:20 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT2

From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:20 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2024 00:00 To: 03/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/13/2024 02:21 Location: Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 550.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,634.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	550.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %



APCD USE ONLY
DATE FILED: ____/____/ REC'D
BY : _____
FEE AMOUNT: \$ _____
FEE PAID : ____/____/____
VARIANCE NO. _____-_____

VARIANCE APPLICATION/PETITION

FILING FEE:

PETITION TYPE	INITIAL FEE	STAFF TIME INCLUDED IN INITIAL FEE	CHARGE FOR ADDITIONAL STAFF TIME
Regular or Product Variance	SEE FILING FEE CHARGE SHEET		
Appeal of an Authority to Construct or Permit to Operate			
Modification of Increments of Progress or Final Compliance Date			
Short or Interim Variance			
Emergency Variance			

INSTRUCTIONS: *Please print or type all responses. If additional space is required, please attached extra pages referenced to the to the appropriate item. The completion of separate forms is required for each Variance petition (i.e. do not combine more than one petition request per form). All questions must be answered thoroughly and completely giving specific detail as requested. In accordance with Health and Safety Code Section 42350.5, the District will provide assistance in filling out this form and in developing a compliance schedule.*

1. Company/Applicant Name:
City of Roseville - Roseville Electric Utility
Roseville Energy Park

Facility Location:
5120 Phillip Road
Roseville, CA. 95747

Mailing Address:
5120 Phillip Road
Roseville, CA. 95747

2. Purpose of hearing, to consider:

- ☐ **Upset/Breakdown Emergency Variance** (*effective for up to 15 days*), pursuant to Regulation 4, Rule 404, for an upset and/or breakdown condition.
- ☐ **Emergency Variance** (*effective for up to 30 days*), pursuant to Sections 42359 et seq. of the Health and Safety Code.
- ☒ **Short Term Variance** (*effective for up to 90 days*), pursuant to Health and Safety Code, Section 40825.
- Regular Variance** (*effective for up to 1 year*) pursuant to Health and Safety Code, Section 42350.
- ☐ **Product Variance** (*effective for up to 2 years*) pursuant to Health and Safety Code, Section 42372.
- ☐ **Interim Variance** (*effective for up to 90 days*), pursuant to Health and Safety Code, Section 42351, pending a hearing on a Regular Variance or Variance Modification.
- ☐ **Interim Authorization** pending a hearing on an increments of progress modification pursuant to Health and Safety Code, Section 42351.5. Variance No. _____.
- ☐ **Modification of Increments of Progress** pursuant to Health and Safety Code, Section 40825. Variance No. _____.
- ☐ **Modification of Final Compliance** date for a previously granted *Variance* pursuant to Health and Safety Code, Section 40826. Variance Number _____.
- ☐ **Other:**

3. The Applicant is a: ☐ Individual ☐ Partnership ☐ Corporation ☒ Public Agency

4. If a Partnership or a Corporation, give names, addresses, and titles of all partners or officers.

5. Type of business or activity involved and street address at which it is conducted.

Electricity Generating Power Plant
5120 Phillip Road, Roseville, Ca. 95747

6. Detail the specific reason for seeking Variance relief.

After the A+ upgrade REP staff discovered a vibration in CT2 that was followed by extensive internal troubleshooting resulting in the creation of a root cause analysis and action plan to detect the cause.

With the scheduled outage currently in effect and 3rd party vendors available to assist REP staff, vibration monitoring has been determined as the most effective activity to identify the root cause of the vibration in the unit.

Vibration monitoring would be performed by REP staff and guided by Siemens on-site. This testing could involve multiple start-ups and shutdowns and operating the unit at various loads and ramp rates. There is a possibility that permitted operating and concentration-based emission limits may be exceeded.

Description of article, machine, equipment, or contrivance (if any) involved in the application.

Combustion Turbine Generator #2

Permit to Operate Number(s):

REPR-20-02

7. Give a detailed description of the specific process involved.

Tuning and testing activities include start-up, shutdown, and unit ramping processes.

8. Provide the Health and Safety Code Section, Rule, or order violated or complained of (*i.e. cite the requirement for which the Variance is sought*).

Tuning and testing activities could result in violating the following permit limitations or conditions:

Numbers: 18, 48, 49, 50, 51, 52, 53, 54, 55

Give the conditions, beyond the reasonable control of the applicant, that requiring compliance would result in either:

An arbitrary or unreasonable taking of property, or

X The practical closing and elimination of a lawful business.

a. Please describe the conditions and resulting effects (*supporting documentation may be attached*).

If compliance with the cited conditions is required without variance, the units may not be brought back into operation. The plant provides emergency electricity to the Bulk Electric System.

b. Explain why the taking of property or practical closing would be without a

corresponding benefit in reducing air contaminants.

Additional tuning while conducting test runs is necessary for the efficient operation of this unit. The possible emission exceedances during this time when tuning and testing is conducted are expected to be outweighed by the benefits of a more reliable unit and plant, that operates more efficiently and offers the lowest cost energy to serve its customers.

- c. Describe all options available in lieu of obtaining a *Variance* (including the curtailment of operations) and explain why each option is not considered feasible.

There are no other options available.

- d. Describe the measures to be taken to reduce excess emissions during the period the *Variance* is in effect, and explain why these measures reduce the excess emissions to the maximum extent feasible.

The work must be performed as efficiently as possible to minimize any exceedance. Emission monitoring and control equipment will be enabled while commissioning activities are proceeding.

Date by which the lesser requirement(s) can be met. Date: N/A

- e. Describe the methods, which will be employed to monitor and or quantify the emissions, and give the frequency the levels will be reported.

Emissions will be monitored using the Continuous Emissions Monitoring System. Emissions will be reported based on the hourly and daily limits as well as for startup and shut down.

9. Period of time for which *Variance* is sought. From Date: March 27, 2024
Thru Date: May 1, 2024

The reason why this period of time is required, and not a shorter period.

This period will allow for several runs to validate tuning activities and correction of any emergent issues for the unit.

10. Describe the advantages and disadvantages to residents of the District resulting from requiring compliance or resulting from granting a *Variance*.

Allowing the variance will result in validating REP's ability to integrate renewable resource use.

A disadvantage of not granting this variance could result in non-

compliant operation in the future.

11. Could granting of the *Variance* create a public or private nuisance? Yes ☒ No
If "yes", what might cause the nuisance, and what actions will be taken to prevent or mitigate the nuisance?

12. Is there any other application pending involving the same equipment? Yes ☒ No

13. If "yes", describe the pending application:

14. Specify specific negative impacts resulting from the granting of this *Variance*.

There is a possibility that emissions limits will be exceeded during tuning and/or testing but they are expected to be negligible.

15. Characterize and quantify the emission of air pollutants which may result from the granting of the requested *Variance* (i.e. *non-complying emissions versus complying emissions*) and provide the basis for the quantification.

During test runs it is not possible to estimate the quantity of excess emissions as a result of this tuning. It is expected that total hourly, daily, and quarterly emissions will be less than the permit limit due to the unit always being monitored as it operates.

16. Provide increments of progress dates by which specific actions will occur to achieve compliance with the *Variance*.

Roseville staff will maintain correspondence with the district regarding these maintenance activities. Within 30 days of the end of this variance, a full report will be submitted regarding the emissions produced and any exceedances involved.

17. General Comments (if a continuation of another paragraph, cite the paragraph).
-

"I am familiar with the Rules and Regulations of the Placer County Air Pollution Control District and I certify that the information herein and the data submitted with the application is true."

Signature of Applicants

Responsible Person: Julie Manfredi Date: 03-13-2024

Name (print or type): Julie Manfredi

Title: Electric Compliance Analyst

Telephone Number: (916) 774-5674

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

04/13/2024

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale CO / High

Test Date: 01/04/2024

Test Result: **Pass**

Instrument Name CT1_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/04/2024	09:39	L	200	49.800	46.900	24.9
01/04/2024	09:45	M	200	109.200	111.100	54.6
01/04/2024	09:57	L	200	49.800	47.100	24.9
01/04/2024	10:02	M	200	109.200	111.300	54.6
01/04/2024	10:14	L	200	49.800	47.100	24.9
01/04/2024	10:19	M	200	109.200	111.100	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	47.033	Std	5.6
M	109.200	111.167	Std	1.8

Cylinder Gas Audit

04/13/2024

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale CO / Low

Test Date: 01/04/2024

Test Result: **Pass**

Instrument Name CT1_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/04/2024	13:35	L	10	2.400	2.400	24.0
01/04/2024	13:40	M	10	5.700	5.900	57.0
01/04/2024	13:47	L	10	2.400	2.400	24.0
01/04/2024	13:52	M	10	5.700	5.900	57.0
01/04/2024	13:59	L	10	2.400	2.400	24.0
01/04/2024	14:04	M	10	5.700	5.900	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.400	Std	0.0
M	5.700		5.900	Std	3.5

Cylinder Gas Audit

04/13/2024

Page 3

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale CO / High

Test Date: 01/05/2024

Test Result: **Pass**

Instrument Name CT2_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/05/2024	09:39	L	200	49.900	50.600	25.0
01/05/2024	09:44	M	200	109.100	112.900	54.6
01/05/2024	09:56	L	200	49.900	50.700	25.0
01/05/2024	10:01	M	200	109.100	113.100	54.6
01/05/2024	10:13	L	200	49.900	50.400	25.0
01/05/2024	10:18	M	200	109.100	113.200	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	50.567	Std	1.3
M	109.100	113.067	Std	3.6

Cylinder Gas Audit

04/13/2024

Page 4

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale CO / Low

Test Date: 01/05/2024

Test Result: **Pass**

Instrument Name CT2_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/05/2024	13:38	L	10	2.400	2.300	24.0
01/05/2024	13:43	M	10	5.700	5.700	57.0
01/05/2024	13:50	L	10	2.400	2.300	24.0
01/05/2024	13:55	M	10	5.700	5.700	57.0
01/05/2024	14:02	L	10	2.400	2.300	24.0
01/05/2024	14:07	M	10	5.700	5.700	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.300	Std	4.2
M	5.700		5.700	Std	0.0

Cylinder Gas Audit

04/13/2024

Page 5

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale CO / High

Test Date: 01/23/2024

Test Result: **Pass**

Instrument Name CT1_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/23/2024	09:38	L	200	49.800	46.300	24.9
01/23/2024	09:43	M	200	109.200	107.800	54.6
01/23/2024	09:55	L	200	49.800	46.300	24.9
01/23/2024	10:00	M	200	109.200	108.100	54.6
01/23/2024	10:12	L	200	49.800	46.400	24.9
01/23/2024	10:17	M	200	109.200	108.200	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	46.333	Std	7.0
M	109.200	108.033	Std	1.1

Cylinder Gas Audit

04/13/2024

Page 6

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale CO / Low

Test Date: 01/23/2024

Test Result: **Pass**

Instrument Name CT1_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/23/2024	11:44	L	10	2.400	2.300	24.0
01/23/2024	11:49	M	10	5.700	5.700	57.0
01/23/2024	11:56	L	10	2.400	2.200	24.0
01/23/2024	12:01	M	10	5.700	5.700	57.0
01/23/2024	12:08	L	10	2.400	2.200	24.0
01/23/2024	12:13	M	10	5.700	5.700	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.233	Std	6.9
M	5.700		5.700	Std	0.0

Cylinder Gas Audit

04/13/2024

Page 7

Facility:	ROSEVILLE ENERGY	Instrument Name	CT2_CODualRg_P_Instrum
Unit/Stack:	CT2	Test Date:	01/29/2024
Parameter/Scale	CO / Low	Test Result:	Pass
		Performance Spec	15 Pct
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/29/2024	06:57	L	10	2.400	2.300	24.0
01/29/2024	07:02	M	10	5.700	5.700	57.0
01/29/2024	07:10	L	10	2.400	2.300	24.0
01/29/2024	07:15	M	10	5.700	5.700	57.0
01/29/2024	07:22	L	10	2.400	2.200	24.0
01/29/2024	07:27	M	10	5.700	5.700	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.267	Std	5.6
M	5.700		5.700	Std	0.0

Cylinder Gas Audit

04/13/2024

Page 8

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale CO / High

Test Date: 01/29/2024

Test Result: **Pass**

Instrument Name CT2_CODualRg_P_Instrum

Performance Spec 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/29/2024	07:56	L	200	49.900	50.100	25.0
01/29/2024	08:01	M	200	109.100	112.100	54.6
01/29/2024	08:13	L	200	49.900	50.000	25.0
01/29/2024	08:18	M	200	109.100	112.200	54.6
01/29/2024	08:30	L	200	49.900	50.000	25.0
01/29/2024	08:35	M	200	109.100	112.400	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	50.033	Std	0.3
M	109.100	112.233	Std	2.9

Linearity Report

04/13/2024

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A15 ReasonForTest QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum Test End Date/Time: 01/04/2024 Scale: High
Performance Spec: 5 % Test No.: 127 Highest Error 2.1
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/04/2024	0939	L	200.0	51.3	49.9		25.7
01/04/2024	0945	M	200.0	111.6	110.1		55.8
01/04/2024	0949	H	200.0	181.6	180.2		90.8
01/04/2024	0957	L	200.0	51.3	50.3		25.7
01/04/2024	1002	M	200.0	111.6	110.5		55.8
01/04/2024	1007	H	200.0	181.6	180.5		90.8
01/04/2024	1014	L	200.0	51.3	50.4		25.7
01/04/2024	1019	M	200.0	111.6	110.6		55.8
01/04/2024	1024	H	200.0	181.6	180.6		90.8

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	50.200	No	2.1
M	111.600	110.400	No	1.1
H	181.600	180.433	No	0.6

Linearity Report

04/13/2024

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A16 ReasonForTest QA
Component Type: O2D Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 01/04/2024 Scale: High
Performance Spec: 5 % Test No.: 128 Highest Error 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/04/2024	1139	L	18.0	5.5	5.4		30.6
01/04/2024	1144	M	18.0	11.2	11.2		62.2
01/04/2024	1149	H	18.0	18.0	18.1		100.0
01/04/2024	1156	L	18.0	5.5	5.4		30.6
01/04/2024	1201	M	18.0	11.2	11.2		62.2
01/04/2024	1206	H	18.0	18.0	18.1		100.0
01/04/2024	1213	L	18.0	5.5	5.4		30.6
01/04/2024	1218	M	18.0	11.2	11.2		62.2
01/04/2024	1223	H	18.0	18.0	18.1		100.0

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	1.8
M	11.200	11.200	No	0.0
H	18.000	18.100	No	0.6

Linearity Report

04/13/2024

Page 3

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A21 ReasonForTest QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 01/05/2024 Scale: High
Performance Spec: 5 % Test No.: 131 Highest Error 1.6
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/05/2024	0939	L	200.0	51.1	50.3		25.6
01/05/2024	0944	M	200.0	111.3	110.8		55.7
01/05/2024	0949	H	200.0	181.6	181.1		90.8
01/05/2024	0956	L	200.0	51.1	50.3		25.6
01/05/2024	1001	M	200.0	111.3	110.9		55.7
01/05/2024	1006	H	200.0	181.6	181.0		90.8
01/05/2024	1013	L	200.0	51.1	50.3		25.6
01/05/2024	1018	M	200.0	111.3	110.8		55.7
01/05/2024	1023	H	200.0	181.6	180.8		90.8

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.300	No	1.6
M	111.300	110.833	No	0.4
H	181.600	180.967	No	0.3

Linearity Report

04/13/2024

Page 4

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A22 ReasonForTest QA
Component Type: O2D Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 01/05/2024 Scale: High
Performance Spec: 5 % Test No.: 132 Highest Error 0.9
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/05/2024	1137	L	21.0	5.0	5.0		23.8
01/05/2024	1142	M	21.0	11.1	11.0		52.9
01/05/2024	1147	H	21.0	18.0	17.9		85.7
01/05/2024	1155	L	21.0	5.0	5.0		23.8
01/05/2024	1200	M	21.0	11.1	11.0		52.9
01/05/2024	1205	H	21.0	18.0	17.9		85.7
01/05/2024	1212	L	21.0	5.0	5.0		23.8
01/05/2024	1217	M	21.0	11.1	11.0		52.9
01/05/2024	1222	H	21.0	18.0	17.9		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.100	11.000	No	0.9
H	18.000	17.900	No	0.6