

DOCKETED	
Docket Number:	24-BSTD-01
Project Title:	2025 Energy Code Rulemaking
TN #:	256897
Document Title:	The Division of the State Architect (DSA) comments on Multilevel Lighting Controls requirements
Description:	The Division of the State Architect (DSA) supports removal of the exception to Section 130.1(b)1 for classrooms.
Filer:	Simon Lee
Organization:	California Energy Commission
Submitter Role:	Public Agency
Submission Date:	6/17/2024 1:47:25 PM
Docketed Date:	6/17/2024

June 6, 2024

Commissioner Andrew McAllister

California Energy Commission
1516 Ninth Street, MS-39
Sacramento, CA 95814

RE: Exception to California Energy Code (CEC) Section 130.1(b)1 multi-level lighting controls

Dear Commissioner McAllister,

The Division of the State Architect (DSA) appreciates the opportunity to comment on the classroom exception for multilevel lighting controls. LED luminaires account for nearly all installed luminaires in public K-12 school and community college classrooms in California. LED luminaires can easily meet the controls requirements for multi-level dimming in the California Energy Code. DSA supports removal of the exception to Section 130.1(b)1.

Sincerely,



Eric Driever

Principal Architect