

DOCKETED	
Docket Number:	24-OPT-02
Project Title:	Compass Energy Storage Project
TN #:	257630
Document Title:	Terran Baylor Comments - Different battery technology
Description:	N/A
Filer:	System
Organization:	Terran Baylor
Submitter Role:	Public
Submission Date:	7/6/2024 2:49:57 PM
Docketed Date:	7/8/2024

Comment Received From: Terran Baylor
Submitted On: 7/6/2024
Docket Number: 24-OPT-02

Different battery technology

Appears from the company own website on this project - the battery technology is lithium-iron phosphate, which is far less likely to have run-away fire risks as Otay Mesa lithium-ion battery storage project. The different type of battery changes should change perspective, and should also be known to the public.

Would request more information from the project vendor Compass Energy about the batteries used, and perhaps have them make sure this less problematic battery formulation is utilized.