



# Transportation Energy Demand Scenarios for SB 100

Quentin Gee, Ph.D.

Manager, Advanced Electrification Analysis Branch

August 7, 2024



# Acronyms and Initialisms

**ACC2** – Advanced Clean Cars II Regulation

**ACF** – Advanced Clean Fleets Regulation

**BECCS** – Bioenergy with Carbon Capture and Storage

**CAISO** – California Independent System Operator

**CARB** – California Air Resources Board

**CEC** – California Energy Commission

**H2** – Hydrogen

**IEPR** – Integrated Energy Policy Report

**MDHD** – Medium- and Heavy-Duty

**OGV** – Ocean-Going Vessel

**OOS** – Out of State (aviation)

**PA** – Planning Area

**PCM** – Production Cost Model

**SB 100** – Senate Bill 100

**TE** – Transportation Electrification

**TOU** – Time of Use

**ZE** – Zero-Emission



# Framework for Demand Scenarios in Transportation



**Existing Policies (mostly captured in the IEPR forecast)**



**Near-term policies recently or expected to be adopted**



**Goals with clear technological pathways informed by market analysis**






# Transportation Scenario Comparisons

	Policy Scenario	Policy Scenario (High Hydrogen Use)
Light-Duty Vehicles	ACC2 as modeled in the 2023 IEPR, extended to 2050	Same as Policy Scenario
Aviation	ZE fuel substitution of jet fuel for in-state aviation starting 2030, 10 percent electricity and 10 percent H2 by 2045 (5 percent for OOS Aviation)	Same as Policy Scenario
In-Use Locomotive Regulation	ZE fuel substitution starting in 2027, diffusion to 100% by 2058	Same as Policy Scenario
Freight Trucks	ACF + ZE Truck Measure (faster adoption of ZE trucks than ACF)	ZE Truck Measure, higher adoption of fuel cell trucks in lieu of BEVs
Off-Road (non-rail)	Enhanced Electrification to align with 100% ZE port operations by 2045	Same as Policy Scenario
OGVs	5% OGV energy demand replaced by hydrogen by 2045	25% OGV Energy Demand replaced by hydrogen by 2045




# Comparing Transportation Energy Demand Differences

## Transportation Electricity in SB 100 Demand Scenarios



## Transportation Hydrogen in SB 100 Demand Scenarios



Note: Does not include electricity demand from hydrogen production




# Hydrogen Production









# Options for Hydrogen Production



Base Grid-Tied



Flexible Grid-Tied



Biological Sources

Small amount of electricity demand from Biomethane and BECCS Operations



# Hydrogen Production Considerations

---

- Proportion of electrolyzer/biological sources
- Energy for electrolysis
- Other energy demand (compression, facilities, etc.)
- Geographic distribution
- Electrolyzer capacity factor
- Electrolyzer efficiencies
- Efficiency associated with electrolyzer ramping





# Hydrogen Production Framework

<b>Geographical Assignment</b>	Hydrogen production assigned to existing MDHD electricity demand
<b>Minimum Electricity Adder</b>	All production requires electricity for compression and other operations
<b>Biological Sourcing</b>	Align with CARB Scoping Plan biological/electrolysis proportions
<b>Electrolyzer Operations Parameters and Assumptions</b>	Consideration of multiple electrolyzer factors to develop a planning area assignment of load associated with electrolyzer operations, and for transportation, with seasonal fuel demand
<b>Use Parameters in PCM</b>	Use parameters to interact with the PCM



# Parameter Characterizations

	Temporal Operation Characterization	Capacity Factor Characterization	Efficiency from Ramping Characterization
Super Flex	Can drop to zero load to maximize against price signals	Lowest capacity factor to capture maximum flexibility	Consistent ramping means lowest efficiency
Flexible	Can drop to very low levels to represent high flexibility	Lower capacity factor to capture some flexibility	Regular ramping causes relatively large reductions in efficiency
TOU	Regularly drops to low levels to approximate TOU optimization schedules	Moderate capacity factor to approximate likely TOU scheduling	Some ramping causes some reductions in efficiency
Baseload	Maintains high operational capacity	Near 100 percent capacity factor to prioritize production	Baseload operation maintains ideal efficiency



# Parameters and Assumptions

	Percent Share of Electrolyzer System	Minimum Load Draw	Maximum Load Draw	Target Annual Capacity Factor	Multiplier for Ramping Efficiency
<b>Super Flex</b>	16.7%	0%	70%	40%	0.7
<b>Flexible</b>	16.7%	10%	77.5%	55%	0.8
<b>TOU</b>	16.7%	20%	87.5%	75%	0.9
<b>Baseload</b>	50%	92.5%	97.5%	95%	1.0

<b>Standard Electricity for Electrolysis</b>	52,500 MWh per 1M kg
<b>Electricity for Biological Sourcing</b>	0 MWh per 1M kg
<b>Electricity for Compression/Operations for Both System Types</b>	5,000 MWh per 1M kg

With geographical PA assignments and seasonal demand for transportation, target monthly electricity demand is assigned with the above parameters. Resulting values are used as inputs into the PCM.



**Thank You!**

