

DOCKETED

Docket Number:	03-AFC-02C
Project Title:	Los Esteros Phase II Compliance
TN #:	262102
Document Title:	Los Esteros Staff Change to Verification of AQ-45
Description:	Lost Esteros Staff Change to Verification of AQ-45
Filer:	susan fleming
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/5/2025 2:49:10 PM
Docketed Date:	3/5/2025



DATE: March 05, 2025
TO: Docket 03-AFC-02C
FROM: John Heiser, Compliance Project Manager
SUBJECT: Staff Change to Verification of AQ-45 **Los Esteros Critical Energy Facility (03-AFC-02C)**

***** Pleas note the change in AQ-45 language below marked in red.**

AQ-45 On a biennial (once every two years) basis, the project owner shall conduct a District-approved source test at exhaust point P-1, P-2, P-3, or P-4 while the Gas Turbines are at maximum allowable operating rates to demonstrate compliance with **AQ-44**. The results of the initial source test must be submitted within 165 days of initial startup. Subsequent source test results must be submitted within 60 days of the date of the source test. If three consecutive biennial source tests demonstrate that the annual emission rates for any of the compounds listed above calculated pursuant to part 5 are less than the BAAQMD Toxic Risk Management Policy trigger levels shown below, then the project owner may discontinue future testing for that pollutant.

Specified PAHs < 0.18 lb/yr
Acrolein < 15.6 lb/yr
(Basis: BAAQMD 2-1-316, Regulation 2-5)

Verification: At least 20 days prior to the intended source test date, the project owner shall submit a source testing methodology to the District and CPM for review and approval. Within **60** ~~30~~ days of the source testing date, all test results shall be submitted to the District and the Energy Commission CPM.