

**Memorandum**

Date: January 30, 2006  
 Telephone: (916) 654-4996

To: Joseph F. Desmond, Chairman  
 Jackalyne Pfannenstiel, Vice Chair  
 Arthur H. Rosenfeld, Ph.D., Commissioner  
 James D. Boyd, Commissioner  
 John L. Geesman, Commissioner

From: California Energy Commission – **B. B. Blevins**  
 1516 Ninth Street  
 Sacramento, CA 95814-5512  
 Executive Director



<b>DOCKET</b>	
<b>05-AFC-2</b>	
DATE	JAN 30 2006
RECD.	JAN 30 2006

Subject: **REVISED WALNUT CREEK ENERGY PARK DATA ADEQUACY RECOMMENDATION (05-AFC-2)**

On November 22, 2005, Walnut Creek Energy, LLC (WCE), a wholly-owned subsidiary of Edison Mission Energy, submitted an Application for Certification (AFC) for the proposed Walnut Creek Energy Park (WCEP). WCE proposes to build a 500 megawatt natural gas-fired simple-cycle power plant in the City of Industry (Los Angeles County). The proposed project would use recycled water for cooling and other plant processes and would connect to the Southern California Edison (SCE) electrical transmission grid through a 230 kilovolt connection with the SCE Walnut Substation. The project is designed as a peaking facility to meet electric generation load during periods of high demand.

Staff's initial data adequacy review of the AFC determined that it did not meet all the requirements listed in Title 20, section 1704, and Division 2, Chapter 5, Appendix B of the California Code of Regulations for the 12-month process. Specifically, the AFC was deficient in 6 of 23 areas: Air Quality, Project Overview, Socioeconomics, Transmission System Engineering, Visual Resources, and Water Resources. Subsequent to publishing our December 21, 2005 recommendation that the Commission deem the AFC data inadequate, WCE informally provided a draft AFC Supplement on January 10, 2006 that staff evaluated and determined satisfied all deficiencies except Air Quality. WCE docketed 125 copies of the supplemental material on January 13, 2006. WCE provided confidential air quality information under separate cover on January 12<sup>th</sup> and 25<sup>th</sup>. Staff's review of the supplemental information has determined that the AFC now meets the above-listed requirements in all 23 technical disciplines.

Attached is a summary table and revised data adequacy worksheets for the six technical disciplines previously determined to be data inadequate, reflecting that the supplemental information submitted by WCE makes the AFC adequate.

At the Energy Commission's Business Meeting on February 1, 2006, I will recommend that the Energy Commission accept the Walnut Creek Energy Park AFC with the supplemental information as data adequate, and request that a Committee be appointed.

If you have any questions, please call Eric Knight, staff's Project Manager, at (916) 653-1850.

Attachments

**ATTACHMENT A  
OVERVIEW OF ENERGY COMMISSION STAFF'S  
DATA ADEQUACY DETERMINATION  
WALNUT CREEK ENERGY PARK  
05-AFC-2**

<b>TECHNICAL AREA</b>	<b>ATTACHMENT B PAGE NO</b>	<b>ADEQUATE ?</b>
<b>AIR QUALITY .....</b>	<b>1</b>	<b>YES</b>
<b>PROJECT OVERVIEW.....</b>	<b>7</b>	<b>YES</b>
<b>SOCIOECONOMICS.....</b>	<b>11</b>	<b>YES</b>
<b>TRANSMISSION SYSTEM ENGINEERING.....</b>	<b>18</b>	<b>YES</b>
<b>VISUAL RESOURCES .....</b>	<b>21</b>	<b>YES</b>
<b>WATER RESOURCES .....</b>	<b>24</b>	<b>YES</b>

**ATTACHMENT B**

**ENERGY COMMISSION STAFF'S  
Data Adequacy Determination  
Revised to Reflect AFC Supplement  
and Confidential Air Quality Submittals**

**Walnut Creek Energy Park  
05-AFC-2**

**January 30, 2006**

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2005

Adequacy Issue: Adequate **X** Inadequate          Project: Walnut Creek Energy Park

Technical Staff: Gabriel D. Taylor

Technical Senior: Keith Golden

Project Manager: Eric Knight Docket: 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	\$2.1.4.2 (p. 2-10) \$2.1.16 (p. 2-19 to 20) \$8.1.1 (p. 8.1-1 to 32) \$8.1.2 (p. 8.1-32 to 70) \$8.1.2.2.2 (p. 8.1-45 to 46) \$8.1.2.4.5 (p. 8.1-63) \$8.1.2.5 (p. 8.1-63 to 65) \$8.1.4 (p. 8.1-71 to 73) Appendix 8.1E January 12 and 25, 2006 <u>Supplemental Confidential Offset Strategy</u>	No <u>Yes</u>	Along with the list of potential offsets requested under Appendix B (g) (8) (i) (ii), please provide a discussion of the "effectiveness of the proposed measures."
Appendix B (g) (8) (A)	The information necessary for the air pollution control district where the project is located to complete a Determination of Compliance.	SCAQMD completeness letter docketed 12/19/05	Yes	
Appendix B (g) (8) (B)	The heating value and chemical characteristics of the proposed fuels, the stack height and diameter, the exhaust velocity and temperature, the heat rate and the expected capacity factor of the proposed facility.	Figure 2.1-3 (p. 2-7) Table 8.1-33 (p. 8.1-62) Table 8.1-27 (p. 8.1-44) Appendix 8.1A and 8.1B Tables 8.1B-2 and 8.1B-4 Table 8.1A-2a	Yes	
Appendix B (g) (8) (C)	A description of the control technologies proposed to limit the emission of criteria pollutants.	\$2.1.11 (p. 2-14)	Yes	
Appendix B (g) (8) (D)	A description of the cooling system, the estimated cooling tower drift rate, the rate of water flow through the cooling tower, and the maximum concentrations of total dissolved solids.	\$2.1.7.4 (p. 2-12) \$2.1.8 (p. 2-12) Figure 2.1-3 (p. 2-7) Table 8.1-29 (p. 8.1-45) Appendix 8.1A Table 8.1A-4	Yes	

**DATA ADEQUACY WORKSHEET**

Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_  
 Technical Area: **Air Quality** Project: \_\_\_\_\_  
 Project Manager: Eric Knight Docket: \_\_\_\_\_

Revision No. 1 Date January 30, 2005  
 Technical Staff: Gabriel D. Taylor  
 Technical Senior: Keith Golden

Walnut Creek Energy Park  
 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (E)	The emission rates of criteria pollutants from the stack, cooling towers, fuels and materials handling processes, delivery and storage systems, and from all secondary emission sources.	§8.1.2.2.1 (p. 8.1-43 to 45) Table 8.1-31 (p. 8.1-56)	Yes	
Appendix B (g) (8) (F)	A description of typical operational modes, and start-up and shutdown modes for the proposed project, including the estimated frequency of occurrence and duration of each mode, and estimated emission rate for each criteria pollutant during each mode.	§2.1 (p. 2.1 to 2.20) Appendix 8.1A Table 8.1A-2a and 8.1A-2b	Yes	
Appendix B (g) (8) (G)	The ambient concentrations of all criteria pollutants for the previous three years as measured at the three Air Resources Board certified monitoring stations located closest to the project site, and an analysis of whether this data is representative of conditions at the project site. The applicant may substitute an explanation as to why information from one, two, or all stations is either not available or unnecessary.	§8.1.1.3 (p. 8.1-18 to 32)	Yes	
Appendix B (g) (8) (H)	One year of meteorological data collected from either the Federal Aviation Administration Class 1 station nearest to the project or from the project site, or meteorological data approved by the California Air Resources Board or the local air pollution control district.	CD-ROM (file: walnut.met)	Yes	

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2005

Adequate  Inadequate

Technical Staff: Gabriel D. Taylor

Project: Walnut Creek Energy Park

Technical Senior: Keith Golden

Docket: 05-AFC-2

Adequacy Issue:

Technical Area: **Air Quality**

Project Manager: Eric Knight

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (H) (i)	If the data is collected from the project site, the applicant shall demonstrate compliance with the requirements of the U.S. Environmental Protection Agency document entitled "On-Site Meteorological Program Guidance for Regulatory Modeling Applications" (EPA - 450/4-87-013 (August 1995), which is incorporated by reference in its entirety.)	N/A	N/A	
Appendix B (g) (8) (H) (ii)	The data shall include quarterly wind tables and wind roses, ambient temperatures, relative humidity, stability and mixing heights, upper atmospheric air data, and an analysis of whether this data is representative of conditions at the project site.	§8.1.1.2 (p. 8.1-2) Figures 8.1-3a to d (p. 8.1-7 to 15) Table 8.1-1 (p. 8.1-17 and 18) Appendix 8.1B Table 8.1B-9 CD-ROM (file: walnut.met)	Yes	
Appendix B (g) (8) (I)	An evaluation of the project's direct and cumulative air quality impacts, consisting of the following:	---	---	---
Appendix B (g) (8) (I) (l)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct inert pollutant impacts of project construction activities on ambient air quality conditions, including fugitive dust (PM <sub>10</sub> ) emissions from grading, excavation and site disturbance, as well as the combustion emissions [nitrogen oxides (NO <sub>x</sub> ), sulfur dioxide (SO <sub>2</sub> ), carbon monoxide (CO), and particulate matter less than 10 microns in diameter (PM <sub>10</sub> )] from construction-related equipment;	§8.1.2.9 (p. 8.1-70) Appendix 8.1B Table 8.1B-10	Yes	

**DATA ADEQUACY WORKSHEET**

Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_  
 Technical Area: **Air Quality** Project: Walnut Creek Energy Park

Revision No. 1 Date January 30, 2005  
 Technical Staff: Gabriel D. Taylor

Project Manager: Eric Knight Docket: 05-AFC-2

Technical Senior: Keith Golden

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (I) (ii)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct inert criteria pollutant (NO <sub>x</sub> , SO <sub>2</sub> , CO and PM <sub>10</sub> ) impacts on ambient air quality conditions of the project during typical (normal) operation, and during shutdown and startup modes of operation. Identify and include in the modeling of each operating mode the estimated maximum emissions rates and the assumed meteorological conditions; and	§8.1.2.3 (p. 8.1-48 to 55) §8.1.2.4.3 (p. 8.1-61)	Yes	
Appendix B (g) (8) (I) (iii)	A protocol for a cumulative air quality modeling impacts analysis of the project's typical operating mode in combination with other stationary emissions sources within a six mile radius which have received construction permits but are not yet operational, or are in the permitting process. The cumulative inert pollutant impact analysis should assess whether estimated emissions concentrations will cause or contribute to a violation of any ambient air quality standard.	§8.1.3 (p. 8.1-70) Appendix 8.1H	Yes	
Appendix B (g) (8) (J)	If an emission offset strategy is proposed to mitigate the project's impacts under subsection (g)(1), provide the following information: The quantity of offsets needed;	---	---	---
Appendix B (g) (8) (J) (I)	Potential offset sources, including location, and quantity of emission reductions; and	§8.1.4 (p. 8.1-71 to 73)	Yes	
Appendix B (g) (8) (J) (ii)		Appendix 8.1G January 12 and 25, 2006 Supplemental Confidential Offset Strategy	No Yes	Please provide a list of offset holders with whom you have entered into negotiations. You may submit this information to the CEC with a request for confidential status.

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2005

Technical Staff: Gabriel D. Taylor

Project: Walnut Creek Energy Park

Adequate  Inadequate   
**Air Quality**

Technical Senior: Keith Golden

Docket: 05-AFC-2

Project Manager: Eric Knight

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (J) (iii)	Method of emission reduction.	Appendix 8.1G <u>January 12 and 25, 2006 Supplemental Confidential Offset Strategy</u>	No <u>Yes</u>	Please identify the mechanism of reduction for each potential offset identified in response to Appendix B(g)(8)(j)(ii) above.
Appendix B (g) (8) (K)	A topographic map containing contour and elevation data, at a scale of 1:24,000, showing the area within 6 miles of the power plant site.	Figure 8.1-1 (p. 8.1-3) Figure 8.13-1 (p. 8.13-3)	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.1-53 (p. 8.1-93)	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.1-54 (p. 8.1-92)	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Table 8.1-53 (p. 8.1-93)	Yes	



**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2005

Technical Staff: Gabriel D. Taylor

Technical Senior: Keith Golden

Adequacy Issue: Adequate  Inadequate

Technical Area: **Air Quality**

Project: Walnut Creek Energy Park

Docket: 05-AFC-2

Project Manager: Eric Knight

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	§8.1.6 (p. 8.1-91) Table 8.1-54 (p. 8.1-92)	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	§8.1.7 (p. 8.1-92) Table 8.1-53 (p. 8.1-93) Application [to South Coast District] for a Permit to Construct for the Walnut Creek Energy Park, November 29, 2005.	Yes	

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Project Overview** Project: Walnut Creek Energy Project Technical Staff: Eric Knight  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Eileen Allen

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Cal. Code Regs., tit. 20, § 1704, (a) (3) (A)	Descriptions of all significant assumptions, methodologies, and computational methods used in arriving at conclusions in the document.		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (3) (B)	Descriptions, including methodologies and findings, of all major studies or research efforts undertaken and relied upon to provide information for the document; and a description of ongoing research of significance to the project (including expected completion dates; and		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (3) (C)	A list of all literature relied upon or referenced in the documents, along with brief discussions of the relevance of each such reference		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (4)	Each principal subject area covered in a notice or application shall be set forth in a separate chapter or section, each of which shall identify the person or persons responsible for its preparation.	Chapter 8 Chapter 9 Appendix 1D	Yes	
Appendix B (a) (1) (A)	A general description of the proposed site and related facilities, including the location of the site or transmission routes, the type, size and capacity of the generating or transmission facilities, fuel characteristics, fuel supply, water supply, pollution control systems, and other general characteristics.	§ 2.0, pp. 2-1 to 2-2 § 2.1.1, p. 2-2	Yes	
Appendix B (a) (1) (B)	Identification of the location of the proposed site and related facilities by section, township, range, county and assessors parcel numbers.	§ 2.0, p. 2-1	Yes	

Adequacy Issue: Adequate **X** Inadequate

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006

Technical Area: **Project Overview** Project: Walnut Creek Energy Project

Technical Staff: Eric Knight

Project Manager: Eric Knight Docket: 05-AFC-2

Technical Senior: Eileen Allen

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (a) (1) (C)	A description of and maps depicting the region, the vicinity, and the site and its immediate surroundings.	§ 2.0, p. 2-1 § 2.1.1, p. 2-2 Figures 1.1-2, 1.1-3, 8.2-1, 8.2-2, 8.2-3, 8.6-1, 8.15-1 Appendix 1A (Parcel Map)	Yes	
Appendix B (a) (1) (D)	A full-page color photographic reproduction depicting the visual appearance of the site prior to construction, and a full-page color simulation or artist's rendering of the site and all project components at the site, after construction.	Figure 1.1-1 (Architectural Rendering) January 2006 AFC Supplement, Section 8.13, Figures 8.13-S1 to 8.13-S5	No <u>Yes</u>	Please provide a full-page color copy of a photograph of the site prior to construction.
Appendix B (a) (1) (E)	In an appendix to the application, a list of current assessor's parcel numbers and owners' names and addresses for all parcels within 500 feet of the proposed transmission line and other linear facilities, and within 1000 feet of the proposed powerplant and related facilities.	Appendix 1B	Yes	
Appendix B (a) (2)	Project Schedule: Proposed dates of initiation and completion of construction, initial start-up, and full-scale operation of the proposed facilities.	§ 2.1.15, p. 2-18 Table 2.1-2	Yes	
Appendix B (a) (3) (A)	A list of all owners and operators of the site(s), the power plant facilities, and, if applicable, thermal host, the geothermal leasehold, the geothermal resource conveyance lines, and the geothermal re-injection system, and a description of their legal interest in these facilities.	§ 1.1, p. 1-1 § 1.2, p. 1-2 § 6.3	Yes	
Appendix B (a) (3) (B)	A list of all owners and operators of the proposed electric transmission facilities.	§ 2.1.5	Yes	
Appendix B (a) (3) (C)	A description of the legal relationship between the applicant and each of the persons or entities specified in subsections (a)(3)(A) and (B).	§ 1.1, p. 1-1 § 1.2, p. 1-2	Yes	

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Project Overview** Project: Walnut Creek Energy Project Technical Staff: Eric Knight  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Eileen Allen

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (A)	Maps at a scale of 1:24,000 (1" = 2000'), along with an identification of the dedicated leaseholds by section, township, range, county, and county assessor's parcel number, showing the proposed final locations and layout of the power plant and all related facilities;	Figure 2.1-1 Appendix 1A (Parcel Map) § 2.0, p. 2-1	Yes	
Appendix B (b) (1) (B)	Scale plan and elevation drawings depicting the relative size and location of the power plant and all related facilities;	Figures 2.1-1, 2.1-2, 5.1-1, 5.1-3	Yes	
Appendix B (b) (1) (C)	A detailed description of the design, construction and operation of the facilities, specifically including the power generation, cooling, water supply and treatment, waste handling and control, pollution control, fuel handling, and safety, emergency and auxiliary systems, and fuel types and fuel use scenarios; and	§§ 2.1.2, 2.1.3, 2.1.4, 2.1.5, 2.1.6, 2.1.7, 2.1.8, 2.1.9, 2.1.10, 2.1.11, 2.1.12, 2.1.13, 2.1.15, 2.1.16, 2.2.1, 2.2.2, 2.3.1, 2.3.2, 2.3.3, 2.3.4, 5.0, 5.3, 6.0, 7.0	Yes	
Appendix B (b) (2) (A)	Maps at a scale of 1:24,000 of each proposed transmission line route, showing the settled areas, parks, recreational areas, scenic areas, and existing transmission lines within one mile of the proposed route(s).	Figure 8.13-1 Figure 8.6-1	Yes	
Appendix B (b) (2) (B)	A full-page color photographic reproduction depicting a representative above ground section of the transmission line route prior to construction and a full-page color photographic simulation of that section of the transmission line route after construction.	Figures 8.13-2A and B	Yes	

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Project Overview** Project: Walnut Creek Energy Project Technical Staff: Eric Knight  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Eileen Allen

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (c)	In a section entitled, "Demand Conformance" provide a discussion explaining how the proposed project conforms with the requirements of Public Resources Code § 25524 or Public Resources Code § 25540.6(a)(5). If the provisions of Public Resources Code § 25523.5 are applicable, explain how the project conforms with the requirements of this section. Additional data adequacy requirements may be contained in the Electricity Report applicable pursuant to Title 20, California Code of Regulations, § 1720.5.	Section 3.0	N/A	
Appendix B (d) (1)	A copy of any study or analysis required by the terms of the Commission's Final Decision on the NOI, and a brief summary of the results of the study or analysis.		N/A	
Appendix B (d) (2)	Updates of any significant information which has changed since the Commission's Final Decision on the NOI.		N/A	
Appendix B (e) (1)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Section 4.0	Yes	

Adequacy Issue: Adequate **X** Inadequate  
 Technical Area: **Socioeconomics**  
 Project Manager: Eric Knight

Revision No. 1 Date January 30, 2006  
 Technical Staff: Joseph Diamond Ph. D.  
 Technical Senior: Dale Edwards

**DATA ADEQUACY WORKSHEET**  
 Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 8.10 Socioeconomics, page 8.10-1. Section 8.10.1.1 Population, page 8.10-1. 8.10.2.2 Construction Impacts, pages 8.10-11 to 8.10-16. Section 8.10.2.3 Operation Impacts, pages 8.10-16 to 8.10-18. Section 8.10.3 Cumulative Impacts, page 8.10-19. Section 8.10-4 Mitigation Measures, page 8.10-19.	Yes	
Appendix B (g) (7) (A)	A description of the socioeconomic circumstances of the vicinity and region affected by construction and operation of the project. Include:	—	—	
Appendix B (g) (7) (A) (i)	The economic characteristics, including the economic base, fiscal resources, and a list of the applicable local agencies with taxing powers and their most recent and projected revenues;	Section 8.10.1.4 Economy and Employment, pages 8.10-4 to 8.10-5. Section 8.10.1.5 Fiscal Resources, page 8.10-5 to 8.10-7.	Yes	

Adequacy Issue: Adequate **X** Inadequate

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006

Technical Area: **Socioeconomics**  
Project Manager: Eric Knight

Project: Walnut Creek Energy Park  
Docket: 05-AFC-2

Technical Staff: Joseph Diamond Ph. D.  
Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (A) (ii)	The social characteristics, including population and demographic and community trends;	Section 8.10.1.1 Population, pages 8.10-1 to 8.10-2. Section 8.10.1.2 Minority and Poverty Populations, pages 8.10-2 to 8.10-3.	Yes	
Appendix B (g) (7) (A) (iii)	Existing and projected unemployment rates;	Table 8.10-6 Employment Data 2004, page 8.10-5. Section 8.10.1.4 Economy and Employment, page 8.10-5.	Yes	
Appendix B (g) (7) (A) (iv)	Availability of skilled workers by craft required for construction and operation of the project;	Section 8.10.2.2.1 Construction Workforce, pages 8.10-11 to 8.10-13. Section 8.10.2.3 Operational Impacts, page 8.10-16.	Yes	
Appendix B (g) (7) (A) (v)	Availability of temporary and permanent housing; and	Section 8.10.1.3 Housing, pages 8.10-3 to 8.10-4. Section 8.10.2.2.3 Housing Impacts, pages 8.10-13 to 8.10-14.	Yes	

Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_ **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Socioeconomics** Project: Walnut Creek Energy Park Technical Staff: Joseph Diamond Ph. D.  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (A) (vi)	Capacities, existing and expected use levels, and planned expansion of utilities (gas, water and waste) and public services, including fire protection, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. For projects outside metropolitan areas with a population of 500,000 or more, information for each school district shall include current enrollment and yearly expected enrollment by grade level groupings, excluding project-related changes, for the duration of the project construction schedule.	Section 8.10.1.6 Education, pages 8.10-7 to 8.10-8. Section 8.10.1.7 Public Services and Facilities, pages 8.10-8 to 8.10-10.	Yes	
Appendix B (g) (7) (B)	A discussion of the socioeconomic impacts caused by the construction and operation of the project, including:	—	—	
Appendix B (g) (7) (B) (i)	The number of workers to be employed each month by craft during construction and operation;	Table 8.10-10, Construction Personnel by Month, pages 8.11 to 8.10-12. Section 8.10.2.3 Operational Impacts, page 8.10-16.	Yes	
Appendix B (g) (7) (B) (ii)	An estimate of the number and percentage of workers who will commute daily, commute weekly, or relocate in order to work on the project;	Section 8.12.2.2.1 Construction Impacts, Trip Generation, pages 8.12-11 to 8.12-12. Section 8.10.3 Cumulative Impacts, page 8.10-19.	Yes	



**DATA ADEQUACY WORKSHEET**

Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_ Date January 30, 2006  
 Revision No. 1  
 Technical Area: **Socioeconomics** Project: Walnut Creek Energy Park Technical Staff: Joseph Diamond Ph. D.  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (B) (iii)	An estimate of the potential population increase caused directly and indirectly by the project;	Section 8.10.2.3.2 Population Impacts, page 8.10-16.	Yes	
Appendix B (g) (7) (B) (iv)	The potential impact of population increase on housing during the construction and operations phases;	Section 8.10.2.3.3 Housing Impacts, page 8.10-16.	Yes	
Appendix B (g) (7) (B) (v)	The potential impacts, including additional costs, on utilities (gas, water and waste) and public services, including fire, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. For projects outside metropolitan areas with a population of 500,000 or more, information on schools shall include project-related enrollment changes by grade level groupings and associated facility and staffing impacts by school district during the construction and operation phases;	Section 8.10.2.2.6 Impacts on Education, page 8.10-15. Section 8.10.2.2.7 Impacts on Public Services and Facilities, page 8.10-15. Section 8.10.2.2.8 Impacts on Utilities, pages 8.10-15 to 8.10-16. Section 8.10.2.3.6 Impacts on Education, page 8.10-17. Section 8.10.2.3.7 Impacts on Public Services and Facilities, pages 8.10-17 to 8.10-18. Section 8.10.2.3.8 Impacts on Utilities, page 8.10-18.	Yes	
Appendix B (g) (7) (B) (vi)	An estimate of applicable school impact fees;	Section 8.10.2.3.6 Impacts on Education, page 8.10-17.	Yes	

Adequacy Issue: Adequate **X** Inadequate

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006

Technical Area: **Socioeconomics** Project: Walnut Creek Energy Park

Technical Staff: Joseph Diamond Ph. D.

Project Manager: Eric Knight Docket: 05-AFC-2

Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (B) (vii)	An estimate of the total construction payroll and an estimate of the total operation payroll;	Section 8.10.2.2.4 Impacts to the Local Economy and Employment, page 8.10-14. Section 8.10.2.3.4 Impacts to the Local Economy, page 8.10-16.	Yes	
Appendix B (g) (7) (B) (viii)	An estimate of the expenditures for locally purchased materials for the construction and operation phases of the project; and	Section 8.10.2.2.5 Fiscal Impacts, page 8.10-15. Section 8.10.2.3.5 Fiscal Impacts, page 8.10-17. <u>January 2006 AFC Supplement, Section 8.10 Socioeconomics, Question 1 and Response, page S-6</u>	No <u>Yes</u>	Please provide an estimate of locally (within Los Angeles County) purchased materials for the WCEP during the operations phase.
Appendix B (g) (7) (B) (ix)	An estimate of the capital cost of the project of the potential impacts on tax revenues from construction and operation of the project.	Section 8.10.2.2.6 Fiscal Impacts, page 8.10-15. Section 8.10.2.3.5 Fiscal Impacts, page 8.10-17. <u>January 2006 AFC Supplement, Section 8.10 Socioeconomics, Question 2 and Response, page S-6.</u>	No <u>Yes</u>	Please provide an estimate of: a.) the property taxes on the WCEP, and b.) the value of the lease of land for the WCEP.

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Socioeconomics** Project: Walnut Creek Energy Park Technical Staff: Joseph Diamond Ph. D.  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.10-14, Laws, Ordinances, Regulations, and Standards Applicable To WCEP Socioeconomics, page 8.10-20.	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Same as above.	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Section 8.10.4 Mitigation Measures, page 8.10-19.	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 8.10.6 Involved Agencies and Agency Contacts, page 8.10-21. Table 8.10-15 Agencies and Agency Contacts for WCEP Socioeconomics, page 8.10-21.	Yes	

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006

Technical Area: **Socioeconomics** Project: Walnut Creek Energy Park  
 Technical Staff: Joseph Diamond Ph. D.  
 Project Manager: Eric Knight Docket: 05-AFC-2  
 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.10-7 Permits and Permitting Schedule, page 8.10-21.	N/A	

Adequacy Issue: Adequate **X** Inadequate **\_\_\_\_\_** **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Transmission System Eng.** Project: Walnut Creek Energy Park Technical Staff: Sudath Arachchige  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2) (A)	A discussion of the need for the additional electric transmission lines, substations, or other equipment, the basis for selecting principal points of junction with the existing electric transmission system, and the capacity and voltage levels of the proposed lines, along with the basis for selection of the capacity and voltage levels.	Section 2.1.5 Pages 2-10 Section 5.1.5.2 System Impact Study Appendix 5A Figure 5.1-2 (Single Line Diagram), Figure 5.1-3	Yes	
Appendix B (i) (2) (B)	A discussion of the extent to which the proposed electric transmission facilities have been designed, planned, and routed to meet the transmission requirements created by additional generating facilities planned by the applicant or any other entity.	Section 2.0, 2.1.5 Section 5.1	Yes	

Adequacy Issue: Adequate **X** Inadequate **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Transmission System Eng.** Project: Walnut Creek Energy Park Technical Staff: Sudath Arachchige  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (C)	A detailed description of the design, construction, and operation of any electric transmission facilities, such as power lines, substations, switchyards, or other transmission equipment, which will be constructed or modified to transmit electrical power from the proposed power plant to the load centers to be served by the facility. Such description shall include the width of rights of way and the physical and electrical characteristics of electrical transmission facilities such as towers, conductors, and insulators. This description shall include power load flow diagrams which demonstrate conformance or nonconformance with utility reliability and planning criteria at the time the facility is expected to be placed in operation and five years thereafter; and	Section 2.0 Pages 2-1 to 2 Section 2.1.5 Pages 2-10 Interconnection System Impact Study, Appendix 5A. Figure 5.1-2 (Single Line Diagram), Figure 5.1-3 (Monopole Tower design) January 2006 AFC Supplement, Section 6.0, Power Flow Diagrams	No <u>Yes</u>	Provide power flow diagrams (MVA, % loading & P-U voltage) for all N-1 and N-2 contingencies where overheads or voltage violations appear.
Appendix B (b) (2) (D)	A description of how the route and additional transmission facilities were selected, and the consideration given to engineering constraints, environmental impacts, resource conveyance constraints, and electric transmission constraints.	Section 2.1.5 Pages 2-10 Section 5.1, 5.2, 5.2.2 Figure 5.1-2 (Single Line Diagram), Figure 5.1-3 (Monopole Tower design)	Yes	

Adequacy Issue: Adequate **X** Inadequate

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006

Technical Area: Transmission System Eng.  
 Project: Walnut Creek Energy Park  
 Project Manager: Eric Knight  
 Docket: 05-AFC-2

Technical Staff: Sudath Arachchige  
 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 5.4, Table 5.4-1 Pages 5-13 Appendix 10D	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.4.7, Table 5.4-7 Pages 5-16 Section 8.16.5, Table 8.16-10	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h) (1) (A).	Section 10D2, Appendix 10D	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 10.5, Table 10.4-2	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.16.5, Table 8.16-10	Yes	

Adequacy Issue: Adequate **X** Inadequate **\_\_\_\_\_** **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Visual Resources** Project: Walnut Creek Energy Park Technical Staff: Gary Collord  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 8.13, pages 1-29 Section 2.0, pages 2-1 to 2-2.	Yes	
Appendix B (g) (6) (A)	Descriptions of the existing visual setting of the vicinity of the project, the region that can be seen from the vicinity of the project, and the proposed project site. Include:	Section 8.13, pages 1, 11-14, 18-21.	Yes	
Appendix B (g) (6) (A) (i)	Topographic maps at a scale of 1:24,000 of the areas from which the project may be seen, identification of the view areas most sensitive to the potential visual impacts of the project, and the locations where photographs were taken for (g)(6)(E);	Figure 8.13-1, page 8.13-3.	Yes	
Appendix B (g) (6) (A) (ii)	Elevations of any existing structures on the site; and	Section 8.13, Page 2. January 2006 AFC Supplement, Section 8.13	No <u>Yes</u>	Elevations of existing warehouse not provided.  Please provide elevations of all sides of the existing warehouse facility.
Appendix B (g) (6) (A) (iii)	The visual properties of the topography, vegetation, and any modifications to the landscape as a result of human activities.	Section 8.13, Pages 2, 11-13, 18-20.	Yes	
Appendix B (g) (6) (B)	An assessment of the visual quality of those areas that will be impacted by the proposed project.	Section 8.13, Pages 11-13, 18-21.	Yes	



Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_ **DATA ADEQUACY WORKSHEET** Revision No. 1 Date January 30, 2006  
 Technical Area: **Visual Resources** Project: Walnut Creek Energy Park Technical Staff: Gary Collord  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (C)	After discussions with staff and community residents who live in close proximity to the proposed project, identify the scenic corridors and any visually sensitive areas potentially affected by the proposed project, including recreational and residential areas. Indicate the approximate number of people using each of these sensitive areas and the estimated number of residences with views of the project. For purposes of this section, a scenic corridor is that area of land with scenic natural beauty, adjacent to and visible from a linear feature, such as a road, or river.	Section 8.13, Pages 11-14, 18-19.	Yes	
Appendix B (g) (6) (D)	A description of the dimensions, color, and material of each major visible component of the project.	Section 8.13, Pages 16-17. Section 2.0, Figures 2.1-1 and 2.1-2	Yes	
Appendix B (g) (6) (E)	Full-page color photographic reproductions of the existing site, and full-page color simulations of the proposed project in the existing setting from each location representative of the view areas most sensitive to the potential visual impacts of the project.	Section 8.13, Pages 2-4	Yes	
Appendix B (g) (6) (F)	An assessment of the visual impacts of the project, including light and glare, and visible plumes.	Section 8.13, Pages 17-18 and 20.	Yes	

**DATA ADEQUACY WORKSHEET**

Adequacy Issue: Adequate **X** Inadequate \_\_\_\_\_ Date: January 30, 2006  
 Revision No. 1  
 Technical Area: **Visual Resources** Project: Walnut Creek Energy Park Technical Staff: Gary Collord  
 Project Manager: Eric Knight Docket: 05-AFC-2 Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 8.13, Pages 23-28	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.13, Pages 28-29	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Section 8.13, Page 28	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 8.13, Pages 23 and 29	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.13, Page 28	N/A	

Adequacy Issue: Adequate **X** Inadequate  
 Technical Area: **Water Resources**  
 Project Manager: Eric Knight

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006  
 Technical Staff: Richard Latteri/Brian Ellis  
 Technical Senior: Natasha Nelson

Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sections: 8.15.1 8.15.2 8.15.3 8.15.4	Yes	
Appendix B (g) (14) (A)	All information required by the Regional Water Quality Control Board in the region where the project will be located to apply for: Waste Discharge Requirements; and	—	—	
Appendix B (g) (14) (A) (i)		Sections: 7.4 – 7.4.3 8.15.2.2 – 8.15.2.2.3 8.15.5.3	Yes	
Appendix B (g) (14) (A) (ii)	a National Pollutant Discharge Elimination System Permit.	Sections: 8.15.2.2, 8.15.2.2.1 – 8.15.2.2.3 8.15.5.2 January 2006 AFC Supplement, Section 8.15, Response #1	No <u>Yes</u>	Please provide all information required by the U.S. Army Corps of Engineers for the discharge of stormwater runoff into San Jose Creek, a Section 303d impaired water body. Include all effluent limits and discharge conditions required under LACSD's (or overseeing authority's) existing NPDES permit for municipal stormwater discharge to the San Jose Creek.
Appendix B (g) (14) (B)	A description of the hydrologic setting of the project. The information shall describe, in writing and on maps at a scale of 1:24,000, the chemical and physical characteristics of the following water bodies that may be affected by the proposed project:	—	—	

Adequacy Issue: Adequate **X** Inadequate  
 Technical Area: **Water Resources**  
 Project Manager: Eric Knight

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006  
 Technical Staff: Richard Latteri/Brian Ellis  
 Technical Senior: Natasha Nelson

Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (B) (i)	Ground water bodies and related geologic structures;	Sections: 8.14.1.1.1, 8.15.1.2, Table 8.14-1, Figure 8.15-1, App. 10G, Encls. B1 -- B4b	Yes	
Appendix B (g) (14) (B) (ii)	Surface water bodies; and	Sections: 8.15.1.1 & 8.15.5.2, Figures 8.15-1 & 8.15-2, January 2006 AFC Supplement, Section 8.15, Response #2	No <u>Yes</u>	Please provide the chemical characteristics of San Jose Creek and a detailed description of those contaminants which cause it to be listed as a Section 303d impaired water body.
Appendix B (g) (14) (B) (iii)	Water inundation zones, such as the 100-year flood plain and tsunami run-up zones.	Section 8.15.1.3, Figure 8.15-2, January 2006 AFC Supplement, Section 8.15, Response #3, Figure 8.15-2	No <u>Yes</u>	On Figure 8.15-2, please provide shading or hatch marks to clarify which areas are outside the 100-year floodplain. Because the FEMA designation is "undetermined," please investigate other sources for available data which describes the inundation potential at the project site, and provide your findings as a narrative.
Appendix B (g) (14) (C)	A description of the water to be used and discharged by the project. This information shall include:	—	—	
Appendix B (g) (14) (C) (i)	Source of the water and the rationale for its selection, and if fresh water is to be used for power plant cooling purposes, a discussion of all other potential sources and an explanation why these sources were not feasible;	Sections 8.15.2.1 – 8.15.2.1.3	Yes	

Adequacy Issue: Adequate **X** Inadequate  
 Technical Area: **Water Resources**  
 Project Manager: Eric Knight

**DATA ADEQUACY WORKSHEET**

Revision No. 1 Date January 30, 2006  
 Technical Staff: Richard Latteri/Brian Ellis  
 Technical Senior: Natasha Nelson

Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (C) (ii)	The physical and chemical characteristics of the source and discharge water;	Sections 7.2 – 7.4.2 Table 7.2-2 Sections 8.15.2.2 – 8.15.2.3 Table 8.15-4	Yes	
Appendix B (g) (14) (C) (iii)	Average and maximum daily and annual water demand and waste water discharge for both the construction and operation phases of the project; and	Section 2.1.7.1 Table 2.1-1 Sections 8.15.2.1.1 – 8.15.2.2.1 Tables: 8.15-2 & 8.15-3	Yes	
Appendix B (g) (14) (C) (iv)	A description of all facilities to be used in water conveyance, treatment, and discharge. Include a water mass balance diagram.	Sections 2.1.9.1 – 2.1.9.1.2 Sections 7.1 – 7.4 Figures 7.1-1 & 7.1-2	Yes	
Appendix B (g) (14) (D)	A description of pre-, and post-construction runoff and drainage patterns, including:	—	—	
Appendix B (g) (14) (D) (i)	Precipitation and storm runoff patterns; and	Sections 8.15.1.1 & 8.15.2.3 Appendix 7B	Yes	
Appendix B (g) (14) (D) (ii)	Drainage facilities and design criteria.	Sections 8.15.1.1 & 8.15.2.3 Appendices 7B & 7C	Yes	
Appendix B (g) (14) (E)	An assessment of the effects of the proposed project on water resources. This discussion shall include:	—	—	
Appendix B (g) (14) (E) (i)	The effects of project demand on the water supply and other users of this source;	Section 7.1 Appendix 7A  January 2006 AFC Supplement, Section 8.15, Response #4	No <u>Yes</u>	Please provide an assessment of WCEP's recycled and potable water demand on other users and the ability of Rowland Water District and the San Jose Creek Water Reclamation Plant to provide an adequate and reliable supply.
Appendix B (g) (14) (E) (ii)	The effects of construction activities and plant operation on water quality; and	Sections 8.15.2.4 & 8.15.3	Yes	

Revision No. 1 Date January 30, 2006  
 Technical Staff: Richard Latteri/Brian Ellis  
 Technical Senior: Natasha Nelson

**DATA ADEQUACY WORKSHEET**

Adequacy Issue: Adequate **X** Inadequate

Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

Water Resources  
 Eric Knight

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (iii)	The effects of the project on the 100-year flood plain or other water inundation zones.	Section 8.15.1.3 January 2006 AFC Supplement, Section 8.15, Response #5	No <u>Yes</u>	Please provide an assessment of WCEP's foot print and linears on the revised 100-year floodplain area provided for compliance with Appendix B (g)(14)(B)(iii).
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed.	Section 8.15.5 Table 8.15-5	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.15.6 Table 8.15-6	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Sections 8.15.5.1 – 8.15.5.3	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 8.15.6 Table 8.15-6 January 2006 AFC Supplement, Section 8.15, Response #6	No <u>Yes</u>	Please provide the name, title, phone number, and address, if known, of an official with the Dept. of Health Services responsible for reviewing and approving the Title 22 Engineering Report.

Adequacy Issue: Adequate  Inadequate   
 Technical Area: **Water Resources**  
 Project Manager: Eric Knight

**DATA ADEQUACY WORKSHEET**  
 Project: Walnut Creek Energy Park  
 Docket: 05-AFC-2

Revision No. 1 Date January 30, 2006  
 Technical Staff: Richard Latteri/Brian Ellis  
 Technical Senior: Natasha Nelson

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Sections 8.15.5 & 8.15.6 Table 8.15-6	Yes	