

CROSSBORDER ENERGY

Comprehensive Consulting for the North American Energy Industry

August 2, 2007

DOCKET	
07-011P-1	
DATE	AUG 02 2007
RECD.	AUG 02 2007

Docket Office
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814


Re: CEC Docket # 07-OIIP-1

Dear Docket Office:

Enclosed for filing in the above-referenced proceeding is the **Response of the California Cogeneration Council to the Joint Energy Commission/Public Utilities Commission Staff Request for Information**. Copies were served yesterday via e-mail on all parties of record in this proceeding.

Thank you for your attention to this matter.

Sincerely,



R. Thomas Beach

On Behalf of
California Cogeneration Council

Enclosures

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Order Instituting Rulemaking to Implement the
Commission's Procurement Incentive Framework
and to Examine the Integration of Greenhouse Gas
Emissions Standards into Procurement Policies.

Rulemaking R.06-04-009

CEC Docket # 07-OIIP-1

**Response of the California Cogeneration Council
To the Joint Energy Commission/Public Utilities Commission
Staff Request for Information**

R. Thomas Beach
Crossborder Energy
2560 Ninth Street, Suite 213A
Berkeley, California 94710
Telephone: 510-549-6922
Facsimile: 510-649-9793
E-mail: tomb@crossborderenergy.com

On behalf of
CALIFORNIA COGENERATION COUNCIL

August 1, 2007

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Order Instituting Rulemaking to Implement the
Commission's Procurement Incentive Framework
and to Examine the Integration of Greenhouse Gas
Emissions Standards into Procurement Policies.

Rulemaking R.06-04-009

CEC Docket # 07-OIIP-1

**Response of the California Cogeneration Council
To the Joint Energy Commission/Public Utilities Commission
Staff Request for Information**

The California Cogeneration Council (CCC)¹ has reviewed the data files that are the basis for this request for information and provides the following comments.

**1. U.S. Energy Information Administration (EIA) Data Is Not Accurate for
Cogeneration Facilities.**

As a starting point for "current entity-specific" greenhouse gas (GHG) emissions, Energy Commission staff has obtained data from the U.S. EIA Form 906 and has asked for comments on the accuracy of the data. When considering entity-specific emissions for cogeneration projects, the CCC submits that this data source is flawed, particularly the data on "electric fuel consumption" for cogeneration facilities.

The EIA data on "electric fuel consumption" is supposed to represent that portion of a

¹ The CCC is an *ad hoc* association of natural gas-fired combined heat and power (CHP) facilities located throughout California, in the service territories of all three of California's major investor-owned electric utilities (IOUs) – Pacific Gas & Electric Company (PG&E), Southern California Edison Company (Edison), and San Diego Gas & Electric Company (SDG&E). CCC member facilities are certified as qualifying facilities (QFs) pursuant to the Public Utility Regulatory Policies Act of 1978 (PURPA). CCC members have sold their power to the IOUs since the early 1980s, pursuant to contract terms and avoided cost prices established by the California Public Utilities Commission (CPUC). In aggregate, CCC members' 32 different CHP projects in California generate 1,300 megawatts (MW) of power, most of which is sold to the IOUs. The CCC represents a significant share of the distributed CHP projects now operating in California.

facility's total fuel use that is used for electric generation. As can be seen by inspecting the EIA data for "total fuel consumption" and "electric fuel consumption" for cogeneration facilities, there is no consistency in how the "electric fuel consumption" is reported. Many cogeneration facilities report identical numbers for "total fuel consumption" and "electric fuel consumption"; this reflects a view that a topping-cycle cogeneration facility would have to burn the same amount of fuel to produce its power output even if it did not also produce useful thermal energy. Some cogeneration projects, however, attempt to allocate their total fuel consumption between fuel used for electric generation and fuel used for thermal energy production; in these cases, "total fuel consumption" is much greater than "electric fuel consumption." The difference between "total fuel consumption" and "electric fuel consumption" in these cases represents the fuel allocated to thermal production, and is often calculated as the fuel that would have to be used to produce the cogeneration project's useful thermal output in a stand-alone boiler.

EIA is well aware of this problem. Stan Kaplan, Team Leader of the Electric Power Division of EIA, in a presentation to the American Statistical Association in April 2006,² described the difficulties of collecting reasonable fuel allocations for CHP plants and the resultant "modifications" that EIA has applied to the data. He stated that the EIA has struggled with how to collect accurate allocations of total fuel consumed between fuel used for electricity production versus fuel used to produce useful thermal output, and concluded that there is no single standard methodology – or single theoretically "correct" methodology – for estimating the allocation of fuel between electric production and thermal output. Essentially, when the EIA analyzed the 2004 allocations of fuel for CHP plants it determined the data was not credible. Consequently, the EIA adjusted data with respect to the allocation of fuel but recognizes a continuing problem of inconsistent and questionable data reporting. The EIA admits it is reviewing other possible approaches and hopes to implement a new process for data collection by January 2008.

As a result, the CCC strongly urges the CPUC not to use the EIA data on "electric fuel consumption" in cogeneration projects.

2. The Data Source for Cogeneration Calculations Should Be Consistent Across State Agencies Involved in GHG Emissions.

The CCC is a participant in the California Air Resources Board (CARB) process to identify and develop a mandatory reporting methodology for the cogeneration sector. CARB recognizes the complexities of allocating GHG emissions between the electrical and thermal production of combined heat and power projects and has established a working group to determine a methodology for mandatory reporting, of which the CCC is an active participant.

² Kaplan, Stan. April 2006 Presentation to the American Statistical Association Committee on Energy Statistics: *Making Adjustments to Survey Data When Collected Data do not Meet Expectations*. A copy of this presentation is attached to this filing.

The CCC strongly recommends that, as the CEC and CPUC address “current entity-specific” emissions from cogeneration projects, the CEC and CPUC should use the same data source and allocation methodology for cogeneration calculations that CARB adopts. If the CEC and CPUC have views on the reporting and allocation of cogeneration emissions, the agencies should participate actively in the CARB process, rather than developing what might prove to be a different and conflicting methodology based on flawed EIA data.

3. QF Monitoring Reports Provide a More Accurate Data Source than EIA Data.


CCC recommends that existing operating data that cogeneration projects already collect and report to the utilities should be the primary source of the data used as the basis for the CARB mandatory reporting for “current entity-specific emissions”. Cogeneration plants that are also Qualifying Facilities (QFs) provide QF Monitoring Data to the Investor Owned Utility (IOU) that purchases their power. The QF Monitoring Data provides much more accurate plant data than the EIA data.³ Currently, the total useful thermal energy output provided by each QF to the IOU that purchases its power is commercially sensitive. Under CPUC order (CPUC Decision 91-05-007) the utilities are required to keep this information confidential. The CCC does not have issues with reporting the data to a regulatory agency, but asks that it remain confidential, as its publication may negatively impact important commercial interests of our members and their on-site customers.

Generally, the CCC believes that the CARB process will identify a viable and accurate method for reporting source-specific GHG emissions from cogeneration projects and then allocating those emissions to electrical and thermal production. The CCC urges the CEC and CPUC to coordinate with CARB in the development of this reporting and allocation methodology for “current entity-specific” emissions. The cogeneration sector presents a complex set of operational circumstances that requires a carefully considered reporting method. The collection and modeling of inaccurate data could lead to perverse operating and investment incentives, which could impede the continued operation and further development of efficient cogeneration projects in the state.

³ If a CHP facility is not a QF and does not provide QF Monitoring Data to a utility, then EIA data on “total fuel consumption” could be used to calculate total emissions for that project. In such cases, however, the CHP project will have to report its useful thermal output to the relevant agency in order to allocate those total emissions between electric and thermal production.

The CCC appreciates the opportunity to present these comments.

Respectfully submitted,

A handwritten signature in cursive script, reading "R. Thomas Beach", written over a horizontal line.

R. Thomas Beach
Crossborder Energy
560 Ninth Street, Suite 213A
Berkeley, California 94710
Telephone: 510-549-6922
Facsimile: 510-649-9793
E-mail: tomb@crossborderenergy.com

On behalf of
CALIFORNIA COGENERATION COUNCIL

August 1, 2007



Making Adjustments to Survey Data When Collected Data do not Meet Expectations

Stan Kaplan, Team Leader
Electric Power Division, EIA

Presentation to the ASA Committee on Energy Statistics
April 2006



Data collection for fuel consumption

- EIA collects data on fuel consumption from electric power generators. This is some of the most basic and important electric data collected and published.
- EIA collects fuel consumption (and other data) from:
 - Traditional power plants, whose only business is the production of electricity for sale on the power grid, and
 - From industrial and commercial combined heat and power (CHP) plants.



Combined Heat and Power Plants (1)


- CHP plants are typically industrial facilities whose primary business is manufacturing (e.g., paper mills, chemicals plants).
- Commercial CHP plants include universities, hospitals, other institutions, and large commercial enterprises.
- These plants produce electricity as a secondary business. The electricity they produce is largely used to meet their own needs; any excess can be sold on the grid.
- Heat for the manufacturing or commercial process is usually referred to as “process steam” or as useful thermal output (UTO).




Combined Heat and Power Plants (2)

- CHP plants achieve high efficiencies by using more of the heat produced by fuel consumption than standalone power plants and factories. Heat that is wasted in conventional power plants and factories is used to make electricity or process heat in a CHP plant.


Typical CHP Plant Configuration



Allocating fuel consumption for CHP plants



- The issue EIA has struggled with is how to collect accurate allocations of total fuel consumed between fuel used for electricity production versus fuel used to produce process heat.




Why is it difficult to collect data on fuel for electricity versus fuel for UTO?

- Collecting reasonable fuel allocations for CHP plants has been a continuing problem for two main reasons:
 - First, unlike total fuel consumption or electricity generation, most respondents are indifferent to the allocation of fuel between electricity and UTO. They do not estimate the allocation for their own purposes.
 - Second, there is no single standard methodology -- or single theoretically “correct” methodology -- for estimating the allocation of fuel.


Methods for estimating the fuel allocation at CHP plants (1)

- Compute the fuel allocation by first determining UTO: Fuel for electricity can then be calculated as Total Fuel – Fuel for UTO.
- Compute the fuel allocation by first determining fuel for electricity: Once fuel for electricity is determined, fuel for UTO can be calculated as Total Fuel – Fuel for Electricity.



Methods for estimating the fuel allocation at CHP plants (2)

- *Thermal displacement:*
estimate how much fuel would have been used to produce electricity (or UTO) in the absence of the CHP system, and subtract this value from the total fuel actually consumed to estimate fuel for UTO (or electricity).





Data collection approaches used by EIA (1)

- Prior to 2004, EIA used the “*Compute the fuel allocation by first determining UTO*” method. Respondents were asked to report only their UTO, and EIA made the rest of the calculations to estimate the fuel allocations.
- This method presumed that respondents had a estimate of how much UTO they produced, and that a standard combustor efficiency value of 80% could be applied to most respondents. Both of these presumptions were false, and consequently EIA had to spend a tremendous amount of time resolving survey responses that showed either improbably large or impossibly small amounts of fuel being used to produce electricity.



Data collection approaches used by EIA (2)

- Beginning with 2004 data collection, EIA adopted the “*Compute the fuel allocation by first determining fuel for electricity*” method. Respondents no longer reported UTO, just their estimate of fuel for electricity. This change in approach was based on an extensive series of interviews with respondents, discussions with industry and the ASA Energy Statistics Committee, assistance from EIA’s Statistics and Methods Group, and tests of a new survey instrument (the Form EIA-920, “Combined Heat and Power Plant Report”).
- The old approach asked respondents to focus on how much UTO they produced. The new approach asked respondents to focus on much fuel they used to produce electricity. The change in focus produced radically different survey results.



Measures of CHP Plant Efficiency

- *Heat rate*: Btus of fuel input required to produce a kilowatthour (kwh) of electricity.
- *Power to Steam Ratio (PS Ratio)*: the ratio of the heat content of electricity produced (computed as 3,412 Btus per kwh) to the heat content of the UTO produced.
- *Thermal efficiency*: ratio of the sum of the heat content of the power and steam produced to the total fuel input.




Respondents allocated much more fuel to electricity in 2004 than in 2003

- o The new survey form asked respondent to focus on fuel used to produce electricity instead of the amount of UTO produced.
- o Consequently, data reported for 2004 showed much more fuel allocated to electricity than in 2003 or past years. This is indicated by sharp increases in the heat rate and the power to steam ratio.
- o Thermal efficiency declines because electricity production is less efficient than production of UTO, and in 2004 respondents allocated much more fuel to electricity production.


Change in Heat Rate, 2003 vs. 2004

**Comparison of Average Heat Rate Reported,
Industrial and Commercial CHP Plants**




Change in Power to Steam Ratio, 2003 vs. 2004

**Comparison of Average Power to Steam Ratio
Reported, Industrial and Commercial CHP Plants**




Change in Thermal Efficiency, 2003 vs. 2004

**Comparison of Average Thermal Efficiency
Reported, Industrial and Commerical CHP Plants**



Many respondents allocated zero fuel to UTO in 2004

CHP Plant Using a Combustion Turbine



Out of 610 industrial and commercial CHP plants reporting in 2004, 177 (29 percent) reported zero fuel for UTO in 2004. All but 31 of these plants had reported UTO in 2003.

Many of these zero-UTO plants operated combustion turbines. The operators viewed the hot exhaust gases used to produce process heat as a “free” byproduct of power generation, or they believed they would have run the generator regardless of whether the industrial process had a demand for steam. In these cases the operator allocated no fuel to UTO.



The 2004 allocations of fuel for CHP plants were not credible

- The reported efficiencies were often comparable to operating stand-alone power generation and process steam plants. This defied logic since CHP plants capture more of the energy of each unit of fuel burned and therefore should be more efficient than combinations of stand-alone plants.
- Responses that showed zero fuel for UTO, although the plant produced UTO, were incorrect. The allocation must take into account the energy used to produce the process steam.
- Because of these problems the data had to be corrected, but the time and resources were unavailable to contact hundreds of respondents and assist them in changing their data. Therefore EIA needed to adjust the reported data.



Summary of the Adjustment Process

- The object was to bring the aggregate measures of efficiency for the CHP category into line with historical trends.
- We would change as little reported data as possible. Total fuel reported was never adjusted, just the allocation of fuel. Out of 610 plants 184 were adjusted.
- Each CHP plant was evaluated against a maximum acceptable value for the Power to Steam ratio, based on 2003 data. If the plant exceeded the maximum the allocation of fuel for the plant was adjusted to:
 - Match the 2003 PS ratio if that value was in the acceptable range; or.
 - Match the 2003 average for the plant type.
- Final checks made sure that the allocation did not result in impossibly low heat rates.



Adjustment process details (1)

- Adjustments were made only to plants with one prime mover type, either combustion turbines or steam turbines. Plants with multiple prime mover types or plants using less common prime movers (e.g., large diesel engines) were not adjusted because it was more difficult to determine whether the reported data was bad or if the plant's configuration was the cause of unusual but accurate reporting.
- Adjustments were made only to industrial and commercial CHP plants. There is also a category of “independent power producer/CHP plants” for whom power production is the main business and the manufacturing process is a sideline. In these cases the great majority of the fuel should properly be allocated to electricity production.




Adjustment Process Details (2)

- A maximum acceptable PS ratio was established for the two types of plants to be adjusted (steam turbine and combustion turbine plants). The maximum acceptable values selected were the 2003 national averages for each plant type
- If a plant's reported 2004 data yielded a PS ratio that exceeded the maximum acceptable values, the 2003 value for the PS ratio was substituted if that value was within the acceptable range. Otherwise, the industry-wide average for 2003 was substituted.
- Fuel for UTO was recomputed using the substituted PS ratio. The system then checked to make sure that 1) fuel for UTO did not exceed total fuel, and 2) the calculated fuel for electricity (computed as total fuel minus fuel for UTO) resulted in a heat rate of at least 5,000 Btus per kwh. If either of these criteria were violated, the system recalculated the fuel allocation to ensure that the heat rate was at least 5,000 Btus per kwh.


Heat Rates for Collected and Adjusted Data

Comparison of Average Heat Rate, Reported and Adjusted Data, Industrial and Commercial CHP Plants




Power to Steam Ratios for Collected and Adjusted Data

Comparison of Average Power to Steam Ratio,
Reported and Adjusted Data, Industrial and
Commerical CHP Plants



Thermal Efficiency for Collected and Adjusted Data

Comparison of Average Thermal Efficiency, Reported and Adjusted Data, Industrial and Commercial CHP Plants





Next Steps (1)

- The data collected for 2005 is showing the same over-allocation of fuel to electricity as in 2004, and will have to be adjusted before the data is finalized later this year.
- EIA is currently testing with respondents supplemental instructions for completing the EIA-920 survey. However, issuing new instructions is unlikely to solve the problem of inconsistent and questionable data reporting.



Next Steps (2)

- The basic problems are:
 - EIA is trying to collect data – the allocation of fuel between electricity and UTO production – that is not of interest to most respondents or captured in their normal course of business.
 - There is no single standard or “correct” method for estimating the allocation of fuel.
- This is a fundamentally different problem than collecting power plant data that the operator views as an important measure of its business operations and is metered using standard procedures (such as total fuel consumed or electricity generation).



Next Steps (3)

- The new approach EIA is considering is to end the ambiguities and data gaps that have plagued its efforts to collect the allocation of fuel for CHP plants by:
 - 1) Specifying the estimation method that must be used, and
 - 2) Specifying typical values for key inputs into the method (e.g., boiler efficiency) that must be used when the respondent does not have reasonable data.



Next Steps (4)

- Two means of implementing this approach are in the earliest stages of consideration:
 - Build into the EIA's Internet Data Collection system a "CHP calculator" that the respondent would use to allocate fuel.
 - EIA would make all the estimates itself. The respondent would provide only basic operating data that can be accurately reported, such as total fuel consumed. EIA would then compute the allocation of fuel using the reported information and typical industry values.



Next Steps (5)

- Considerations in implementing these approaches include:
 - Is more research is needed into the typical ranges for key parameters, such as the PS ratio and boiler efficiency?
 - Will EIA need to collect additional information on plant configurations?
 - What is the development time and cost for implementing different approaches?
- EIA currently hopes to implement a new process for data collection starting January 2008.