

CALIFORNIA ENERGY COMMISSION
REPORT OF CONVERSATION Page 1 of 1



**Systems Assessment and
 Facilities Siting Division**

PROJECT TITLE: **San Gabriel Generating Station**

<input checked="" type="checkbox"/> Telephone	877-290-1337 (Conference Call)	<input type="checkbox"/> Meeting Location:	
NAME:	Denise Heick (URS) Robert Lawhn (Reliant) Scott Galati (Galati/Blek)	DATE: 9/5/2007	TIME: 11:00 am
WITH:	URS, Galati/Blek, Reliant, and CEC		
SUBJECT:	San Gabriel Generating Station Net Output		

In attendance:
 Denise Heick
 Robert Lawhn
 Scott Galati
 Mark Hesters
 Laiping Ng
 Stanley Yeh

DOCKET 07-AFC-2
DATE SEP 05 2007
RECD. SEP 06 2007

COMMENTS:

The CEC, URS, Reliant, and Galati/Blek agree to the following:

1. The CEC will continue to finalize language for a Condition of Certification requiring:
 - a) the project owner to limit net output of the proposed facility to 696 MW (AFC) or 698 MW (System Impact Study),
 - b) if the facility exceeds output, the project owner shall appear before commission to request an amendment, and
 - c) the project owner will submit quarterly reports to the CEC indicating maximum quarterly output.

	Signed: Stanley Yeh
--	----------------------------