



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 5, 2007

Mr. Mike McCorison
State Land Manager
US Department of Agriculture Forest Service
701 N. Santa Anita
Arcadia, CA 91006-2725

DOCKET	
07-AFC-2	
DATE	SEP 05 2007
RECD.	SEP 11 2007

Subject: San Gabriel Generating Station (SGGS) 696 MW Project
Facility Location: 8996 Etiwanda Ave., Rancho Cucamonga, CA (ID: 115315)
CEC Docket No. 07-AFC-2

Dear Mr. McCorison:

Permit applications for the subject project were submitted to the South Coast Air Quality Management District (AQMD) on May 1, 2007, and were deemed complete by AQMD on May 17, 2007. As of July 25, 2007, AQMD and EPA signed an agreement whereby AQMD will assume responsibility for the PSD analysis on this project.

In accordance with AQMD's Prevention of Significant Deterioration Rule 1703(a)(3)(F), we are transmitting herewith a complete copy of the most recent application package dated August 2007 submitted by the SGGS for the proposed construction of a 696 MW combined cycle generating facility at the above location. The facility will consist of two natural gas-fired combustion gas turbines with heat recovery steam generators (HRSG), selective catalytic reduction (SCR) and carbon monoxide catalyst systems, a steam turbine generator, an auxiliary boiler, and an ammonia storage tank.

If you have any questions or need additional information, please contact Mr. Chris Perri at (909) 396-2696 or Mr. John Yee at (909) 396-2531.

Sincerely,

Michael D. Mills

Michael D. Mills, P.E.
Senior Manager
General Commercial & Energy Team
Engineering & Compliance

Cc: Joe Loyer, California Energy Commission, w/o Enclosure
Joe Araiza, Reliant Energy, w/o Enclosure

Enclosure: Application for Permit to Construct (one binder)
DVD Disk

Certified Mail
Return Receipt Requested