

Stan Yeh - Answers to CEC -- Etiwanda CCGT SIS Report

From:
To: "Laiping Ng"
Date: 10/22/2007 3:19 PM
Subject: Answers to CEC -- Etiwanda CCGT SIS Report
CC: ,

DOCKET 07-AFC-2	
DATE	OCT 22 2007
RECD	OCT 22 2007

Laiping,

Here are the answers to your questions:

Answer #1 --

The correct line ratings for the Vista-San Bernardino 230 kV line #2 is 2666 Amps (normal) and 2666 (Emergency). Therefore, there is no overload on this line.

Answer #2 --

Yes, the SIS report should read a "500 kV" double-bus double CB position to be included in the Case A cost (see page 15, Item a).

Please let me know for any other questions,

Thanks,

Ying He
Transmission and Interconnection Planning
Southern California Edison Company
(626) 302-0217 (voice) / PAX 20217 (voice)
(626) 302-9647 (fax)
ying.he@sce.com (e-mail)