



680 Andersen Drive Pittsburgh, PA 15220-2700

DOCKET	
07-BSTD-1	
DATE	DEC 10 2007
RECD.	DEC 11 2007

680 Andersen Drive Pittsburgh, PA 15220-2700 Fax: 412.922.3213

December 10, 2007

Subject: 2008 Building Energy Efficiency Standards for Residential and Nonresidential Buildings
45-Day Language Comment Provided by the Cool Metal Roofing Coalition

Mr. Chris Gekas and Mr. Mazi Shirakh
California Energy Commission
1516 Ninth Street, MS-25
Sacramento, CA 95814-5512

Dear Messrs. Gekas and Shirakh,


The Cool Metal Roofing Coalition forwards the following comment for the 2008 Building Energy Efficiency Standards for Residential and Nonresidential Buildings 45-day Language:

Page 209, Section 151 (f)11.B Roofing Products, states, "Low rise residential buildings with low-sloped roofs in climate zones 13 and 15 shall have a minimum aged reflectance of 0.55 and a minimum emittance of 0.75 or a minimum SRI of 0.65." Obviously, the SRI value is expressed incorrectly as a percent. Also, to be consistent with similar language in Section 152, the actual SRI value should be 64 rather than 65.

We hope this minor editorial comment is helpful.

Sincerely,

Gregory L. Crawford
Executive Director
Cool Metal Roofing Coalition



A COALITION OF:



WWW.COOLMETALROOFING.ORG