

# Workshop Presentations 2008 California Building Energy Efficiency Standards July 12, 2006

---

Part 1: Furnace Fan Watt Draw and Airflow  
in Cooling Mode


Part 2: Air Conditioner Airflow, Refrigerant  
Charge, and TXVs

Bruce Wilcox, P.E.

John Proctor, P.E., Proctor Engineering Group, Ltd.

Ken Nittler, P.E., Enercomp, Inc.

Rick Chitwood, Chitwood Energy Management



# Part 1: Furnace Fan Watt Draw and Airflow in Cooling Mode and Watt Draw in Air Distribution Mode

---


- Investigation and Supporting Data
- Cost Effectiveness
- New Prescriptive Standard
- ACM Changes

# Field Survey


---

- 60 furnace systems in new homes
- 55 in production homes, 5 custom
- Measured air flow and fan watts by mode (heating and cooling) (zonal control)
- Measured static pressures by mode and component


# Median Cooling Fan Watts = 632




# Median Cooling Airflow = 358 CFM/ton




# Median External Static Pressure = 0.8 IWC



# Cooling W/CFM is related to AC size



# External Static Pressure Alone is Not a Sufficient Predictor of Watts/CFM




# Lab Tests


---

- 6 furnaces, representative of survey results
- 3 ton and 4 ton airflows
- Permanent Split Capacitor and Electrically Commutated Motors
- Measured flow and watt draw over a range of external static pressures

# Furnace Lab Experimental Apparatus



# Furnace Air Handler Performance High Speed




# Manufacturers' Data


---

- Compiled by LBNL
- Data from Manufacturers' website or directly
- 841 model number and blower speed combinations that had blower power information


# Permanent Split Capacitor Watts / CFM at High Speed and 0.8 IWC



# Permanent Split Capacitor Watts / CFM at High Speed and 0.5 IWC



# Cooling W/CFM is related to AC size



## Reducing External Static

---

- Component level external static reductions for average surveyed system to achieve 0.5 IWC total external static

Component	Survey Median	Target
Supply Duct	0.18	0.18
Cooling Coil	0.27	0.20
Return Duct	0.15	0.05
Filter	0.15	0.07
Total	0.75	0.50

## Cost of Reducing External Static

---

- Cost increase for average system surveyed (3.5 ton) to achieve 0.5 IWC external static

Component	Modification	Cost increase		
	Strategy	Labor	Material	Total
Supply Duct	No Change			
Cooling Coil	5 ton coil		40.00	40
Return Duct	Increase diameter	11.76	20.75	32
Filter	25% Larger area		15.00	15
Overhead and profit	30%			37
Total				123

## Fan Watt Life Cycle Cost

---

- 100 Watt/1000 CFM reduction saves \$172 PV in Climate Zone 12
- Cost delta for improved ducts is \$123

# Prescriptive Standard

---

- Cooling Mode in CTZ 10-15
- Central forced air system fans shall simultaneously demonstrate, in every zonal control mode, a flow greater than 350 CFM/ton of nominal cooling capacity and a watt draw less than:
  - .5 W/CFM (<5 nominal tons)
  - .55 W/CFM (5 nominal tons)

# Prescriptive Standard

---

- Air Distribution Mode in all Zones
- Central forced air system fans in Air Distribution Mode, a watt draw less than :
  - .5 W/CFM (<5 nominal tons)
  - .55 W/CFM (5 nominal tons)

# ACM Modeling for Air Distribution Systems

---

- Air Distribution Schedule is 33% on every hour.
- Ventilation air inlets if not controlled
  - add ELA to proposed SLA
  - add return leak with vent CFM

# Part 2: Air Conditioner Airflow, Refrigerant Charge, and TXVs

---

- Field Experience and Data
- Changes to Prescriptive Standard
- “Housekeeping” Changes


# Field Reports

---

- Reports from HERS Raters and Evaluators
- Poor Installation Quality of TXVs Prevent Proper Operation

# Data Analysis on TXVs

## Superheat Distribution Indicates a Problem



# Changes to Prescriptive Standard for AC Charge

---

- Eliminate TXV credit
- Always verify charge
- Verify TXV performance
- Set Adequate Airflow Credit at 350 CFM per ton

# Appendix RD – Procedures for Determining Refrigerant Charge for Split System Space Cooling Systems

---

1. Remove TXV exemption
2. Add subcooling test method for TXVs and EXVs
3. Add metering device operation check for TXVs and EXVs
  - a) superheat must be within manufacturer's specified range if available
  - b) superheat must be between +4°F and +25°F if manufacturer's specification is not available

# Housekeeping

---

- Clarify *minimum* airflow for refrigerant testing
  - Temperature split cannot be used for any purpose other than establishing minimum airflow for refrigerant testing
- Temperature Split Table clarification
- Inspectors' (HERS Raters) tolerance for temperature split, subcooling, and superheat changed to 1°F greater than installers