

|                   |
|-------------------|
| DOCKET            |
| 07-BSTD-1         |
| DATE OCT 24 2005  |
| RECD. APR 29 2008 |

# CASE Update: Programmable Communicating Thermostats (PCT's)

PIER Buildings Program  
SCE Codes & Standards Program  
CEC 2008 Title 24 Workshop  
October 24, 2005



An EDISON INTERNATIONAL™ Company

Codes & Standards Enhancement Project

# Programmable Communicating Thermostats (PCT's)

## ■ Programmable

- Existing programmable schedules
- New feature – set-up based on outside signal,
  - Mandatory emergency signal or voluntary price signal

## ■ Communicating

- One-way – receive load shed or price signal
- Two-way – verify signal received, on/off status, temperature

## ■ Thermostat – limit placed on discomfort

- Control based on temperature (closed loop)
- Not duty cycling (open loop)



# PCT's – Minimum Capabilities

- Thermostat receives load shed signal and increases setpoint 4°F
- Temporary reduction in AC consumption
  - Most reduction first hour, less following hours
- Can be controlled by location
  - Useful for local capacity shortage
- Indicates status – normal vs load shed
- Emergency response vs Price Response
  - Emergency – no override of set-up
  - Price Response – voluntary set-up to save \$



# Communication infrastructure

## ■ Dispatch

- send emergency or real time price signal

## ■ Communication mode

- radio frequency, satellite, paging, powerline carrier, broadband over powerline, one –way vs two way communication

## ■ Metering & Verification

- critical peak pricing, data processing, signal verification



# PCT's additional capabilities

- Two way communication
  - Verify receipt of signal
  - Verify system status, temperature etc.
- Display of cost information savings etc.
- Internet accessible
  - Change settings remotely, more market price information
- Gateway to other devices



# Demand Savings in CA PCT Pilots

- SDG&E (CTZ 10) residential
  - 0.44 kW/home (low relative to other studies)
  - 0.11/ton (55% realization rate)
  - 10% malfunction, 17% A/C not on,
  - 9% to 42% overridden
- SCE nonresidential
  - 0.8 kW/thermostat (125% realization rate)
  - 0.27 kW/ton
    - 1<sup>st</sup> hour 0.33 kW/ton, 2<sup>nd</sup> hour 0.21kW/ton
  - 8% non-participation, 7% no signal



# Environmental impact

- Reduced energy consumption at peak
- Increased consumption immediately after peak
- Increased consumption before peak for pre-cooling if warning signal given
- Time Varying Emissions Factors used to calculate net emissions impacts
  - Related to resource mix at different times



# Non-energy impacts

- Comfort impact
- Productivity impact
  - Work output, people leaving work early
  - Less retail sales
- Reliability impacts
  - Calculated only for systems that are not participating in voluntary curtailment



# PCT Program Features

## ■ Voluntary Program

- 4 degree setup (for this example)
- User has option of overriding set-up
- Dispatch 2pm to 6pm, 20 days per year


## ■ Emergency Program

- Mandatory curtailment / no override
- Only used to prevent rotating blackouts
- Dispatch, on average 2.4 hours per year



# Example Dispatch on Top Day

## Load Impact and TDV on Top Day (Fri, Aug23)



# Results for 20 Day Program

| Ranking | Lifecycle<br>\$/ton-day | Day | Date        | Days | Cumulative<br>Value<br>(\$/ton) |
|---------|-------------------------|-----|-------------|------|---------------------------------|
| 1       | \$ 12.84                | 235 | Fri, Aug 23 | 1    | \$ 12.84                        |
| 2       | \$ 11.69                | 196 | Mon, Jul 15 | 2    | \$ 24.54                        |
| 3       | \$ 10.32                | 197 | Tue, Jul 16 | 3    | \$ 34.86                        |
| 4       | \$ 9.34                 | 234 | Thu, Aug 22 | 4    | \$ 44.20                        |
| 5       | \$ 9.21                 | 198 | Wed, Jul 17 | 5    | \$ 53.40                        |
| 6       | \$ 8.08                 | 184 | Wed, Jul 03 | 6    | \$ 61.49                        |
| 7       | \$ 7.98                 | 240 | Wed, Aug 28 | 7    | \$ 69.46                        |
| 8       | \$ 7.71                 | 239 | Tue, Aug 27 | 8    | \$ 77.17                        |
| 9       | \$ 7.62                 | 178 | Thu, Jun 27 | 9    | \$ 84.79                        |
| 10      | \$ 7.48                 | 218 | Tue, Aug 06 | 10   | \$ 92.27                        |
| 11      | \$ 6.94                 | 183 | Tue, Jul 02 | 11   | \$ 99.21                        |
| 12      | \$ 5.93                 | 238 | Mon, Aug 26 | 12   | \$ 105.14                       |
| 13      | \$ 5.02                 | 219 | Wed, Aug 07 | 13   | \$ 110.16                       |
| 14      | \$ 4.92                 | 269 | Thu, Sep 26 | 14   | \$ 115.08                       |
| 15      | \$ 4.80                 | 182 | Mon, Jul 01 | 15   | \$ 119.88                       |
| 16      | \$ 4.60                 | 190 | Tue, Jul 09 | 16   | \$ 124.48                       |
| 17      | \$ 4.58                 | 252 | Mon, Sep 09 | 17   | \$ 129.05                       |
| 18      | \$ 4.48                 | 179 | Fri, Jun 28 | 18   | \$ 133.54                       |
| 19      | \$ 4.37                 | 211 | Tue, Jul 30 | 19   | \$ 137.90                       |
| 20      | \$ 4.33                 | 228 | Fri, Aug 16 | 20   | \$ 142.23                       |



# Residential Climate Zone 15 Voluntary Program Impact

## Voluntary Impact

|   |           |                    |
|---|-----------|--------------------|
| Percentage of AC that is on                           | 90%       |                    |
| Percentage that receive and can act upon the signal   | 97%       |                    |
| Percentage that do not override                       | 80%       |                    |
| Overall fraction of technical potential               | 70%       |                    |
| Percentage w/ PCT participating in program            | 50%       |                    |
| Overall fraction of potential including participation | 35%       |                    |
| Avoided Cost Value                                    |           |                    |
| Avoided Cost Value (PV\$/ton)                         | \$ 142.23 |                    |
| AC tons per thermostat                                | 5.8       |                    |
| <b>Value per thermostat (PV\$/tstat)</b>              |           | <b>\$ 288.07</b>   |
| Comfort and productivity loss                         |           |                    |
| Comfort loss as a percentage of avoided cost          | 50%       |                    |
| <b>Comfort loss (\$PV/tstat)</b>                      |           | <b>\$ (144.04)</b> |



# Residential Climate Zone 15 Emergency Impact

## Emergency Impact

|   |           |          |               |
|---|-----------|----------|---------------|
| Class Weighted Average VOS (\$/kWh)                   | \$        | 42.02    |               |
| Comfort and Productivity Loss (\$/kWh)                | \$        | 2.50     |               |
| Net Gain of reduced outages costs (\$/kWh)            | \$        | 39.52    |               |
| Expected Outage Hours (hours per year)                |           | 2.4      |               |
| Reduced Outage Cost \$/kW-yr                          | \$        | 94.86    |               |
| Present Value Factor                                  |           | 19.60    |               |
| Real Discount Rate                                    |           | 3%       |               |
| Number of Years                                       |           | 30       |               |
| Reduced Outage Cost (\$PV/kW)                         | \$        | 1,859.29 |               |
| Percentage of air conditioners that are on            |           | 50%      |               |
| Percentage that receive and can act upon the signal   |           | 97%      |               |
| Percentage participating in program                   |           | 100%     |               |
| Percentage that override non-emergency signal         |           | 20%      |               |
| Overall fraction of potential including participation |           | 10%      |               |
| Average reduction per t-stat (kW/t-stat)              |           | 0.08     |               |
| <b>Reduced Outage Cost (\$/t-stat)</b>                | <b>\$</b> |          | <b>155.75</b> |



# Results per Thermostat

- Climate Zone 15 Example Residential Results

|                         |                 |
|-------------------------|-----------------|
| Non-emergency Impact    | \$144.04        |
| <u>Emergency Impact</u> | <u>\$155.75</u> |
| Total                   | \$299.78        |

- These are interim values to be verified
- PCT CASE report is still process



# PCT estimated installed costs

## E-Source survey

| Annual Volume | 1 way PCT's       |                   | 2 way PCT's       |                   |
|---------------|-------------------|-------------------|-------------------|-------------------|
|               | Retail            | Wholesale         | Retail            | Wholesale         |
| 50,000        | \$195 to<br>\$300 | \$175 to<br>\$260 | \$240 to<br>\$725 | \$230 to<br>\$615 |
| 100,000       | \$180 to<br>\$270 | \$160 to<br>\$235 | \$240 to<br>\$695 | \$227 to<br>\$590 |
| 250,000       | \$160 to<br>\$225 | \$145 to<br>\$200 | \$230 to<br>\$650 | \$216 to<br>\$555 |



# Incremental cost conclusions

- Incremental cost for one-way communicating PCTs < \$150
- Incremental costs for two-way communicating PCT's > \$250
- Additional infrastructure cost for two-way communications
- 2 –way: verify customer received signal



# Code Proposal

- Standards - Mandatory requirement
- Nonresidential - Section 122(c) Shut-off, Reset and Demand Response Controls for Space-conditioning Systems
- Residential - Section 150(i) Setback and Demand Responsive Thermostats



# Control Capabilities

- be capable and installed to set up the cooling setpoint by 4°F and ...
- if controlling a heat pump be capable and installed to turn off supplementary resistance heating ...
- during emergency or voluntary demand response period
- Not capable of being overridden during emergency demand response period
- Exceptions: zones that must have constant temperatures for patient health or to prevent degradation of: materials, a process, or plants or animals



# Other considerations

- Who creates PCT specification?
  - Each utility
  - Statewide specification in Title 24 (§112)
- Should cost of communications infrastructure be included?
- Demand response required for ECMS systems?



# For more information

- <http://www.title24dr.com/>
- Minutes and presentations of PCT stakeholder meetings
- Coming soon...
  - PCT cost-savings spreadsheet after validation
  - Revised TDV files including DR valuation
  - Preliminary draft PCT CASE report



# Acknowledgements

- CEC PIER Buildings Program
  - Nancy Jenkins
- SCE Codes & Standards Program
  - Carlos Haiad
- E3 Energy and Environmental Economics
  - Snuller Price & Brian Horii
- HMG Heschong Mahone Group
  - Douglas Mahone, Jon McHugh, Matt Tyler & Mudit Saxena
- E-Source/Platts
  - Rachael Reiss

