

July 11, 2008

Brian Bateman
Director of Engineering
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

Subject: **Submittal of Application for Authority to Construct
Willow Pass Generating Station**

Dear Mr. Bateman:

Mirant Willow Pass LLC, an indirect wholly owned subsidiary of Mirant Corporation ("Mirant"), proposes to build a nominally rated 550 (approximate) net megawatt (MW) combined cycle power generation project within Mirant's Pittsburg Power Plant in Pittsburg, California. The attached document is an Authority to Construct/Permit to Operate Application to the Bay Area Air Quality Management District (BAAQMD) for the Willow Pass Generating Station (WPGS).

The new WPGS will be a state-of-the-art power plant including two-275MW quick start combined cycle (Siemens Flex Plant 10) units using "dry" cooling technology for its operation. The WPGS will utilize the best available technology for environmental performance.

An Application for Certification for this project was filed with the California Energy Commission on June 30, 2008 (Docket # 08-AFC-6).

The enclosed application includes completed BAAQMD forms and supporting information, as well as a CD containing electronic copies of air quality and public health modeling input and output files. A check for the permit application fees is also enclosed (check # 7001268 in the amount of \$298,816).

Please contact me at (619) 243-2823 if you have any questions or require additional information.

Sincerely,

John Lague
Senior Air Quality Consultant
URS Corporation

Enclosures:

Application with CD - 3 sets
Check for Permit Application Fees

cc: Michelle Woods, California Energy Commission
Jon Sacks, Mirant
Ron Kino, Mirant
Lisa Cottle, Winston and Strawn
Kathy Rushmore, URS

URS Corporation
221 Main Street, Suite 600
San Francisco, CA 94105-1917
Tel: 415.896.5858
Fax: 415.882.9261

Application for Authority to Construct and Permit to Operate for **WILLOW PASS GENERATING STATION** Pittsburg, California

Submitted to:

BAY AREA AIR QUALITY MANAGEMENT DISTRICT

July 2008

Prepared for:



Prepared by:





July 11, 2008

Brian Bateman
Director of Engineering
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

Subject: **Submittal of Application for Authority to Construct
Willow Pass Generating Station**

Dear Mr. Bateman:

Mirant Willow Pass LLC, an indirect wholly owned subsidiary of Mirant Corporation ("Mirant"), proposes to build a nominally rated 550 (approximate) net megawatt (MW) combined cycle power generation project within Mirant's Pittsburg Power Plant in Pittsburg, California. The attached document is an Authority to Construct/Permit to Operate Application to the Bay Area Air Quality Management District (BAAQMD) for the Willow Pass Generating Station (WPGS).


The new WPGS will be a state-of-the-art power plant including two-275MW quick start combined cycle (Siemens Flex Plant 10) units using "dry" cooling technology for its operation. The WPGS will utilize the best available technology for environmental performance.

An Application for Certification for this project was filed with the California Energy Commission on June 30, 2008 (Docket # 08-AFC-6).

The enclosed application includes completed BAAQMD forms and supporting information, as well as a CD containing electronic copies of air quality and public health modeling input and output files. A check for the permit application fees is also enclosed (check # 7001268 in the amount of \$298,816).

Please contact me at (619) 243-2823 if you have any questions or require additional information.

Sincerely,



John Lague
Senior Air Quality Consultant
URS Corporation

Enclosures:

Application with CD – 3 sets
Check for Permit Application Fees

cc: Michelle Woods, California Energy Commission
Jon Sacks, Mirant
Ron Kino, Mirant
Lisa Cottle, Winston and Strawn
Kathy Rushmore, URS

URS Corporation
221 Main Street, Suite 600
San Francisco, CA 94105-1917
Tel: 415.896.5858
Fax: 415.882.9261

WILLOW PASS GENERATING STATION PROJECT

ATC/PTO APPLICATION
PITTSBURG, CALIFORNIA

Prepared For:

- Bay Area Air Quality Management District

Prepared on behalf of

Mirant Willow Pass, LLC

July 11, 2008

URS

1615 Murray Canyon Road, Suite 1000
San Diego, CA 92108

**ATC/PTO Application
Willow Pass Generating Station**

Table of Contents

1.0 INTRODUCTION..... 1-1

1.1 OVERVIEW 1-1

1.2 APPLICANT BACKGROUND INFORMATION..... 1-2

 1.2.1 *Business Name/Location* 1-2

 1.2.2 *Nature of Business*..... 1-3

 1.2.3 *Person to Contact Regarding Application*..... 1-3

 1.2.4 *Type of Entitlement*..... 1-3

 1.2.5 *Estimated Construction and Completion Dates*..... 1-3

 1.2.6 *Application Status*..... 1-3

 1.2.7 *Operating Schedule* 1-3

 1.2.8 *Compliance Certification*..... 1-3

2.0 PROJECT DESCRIPTION 2-1

2.1 EQUIPMENT 2-1

2.2 FUEL 2-1

2.3 ELECTRICAL 2-2

2.4 PROCESS OPERATION 2-2

2.5 EMISSION CONTROL TECHNOLOGY 2-2

 2.5.1 *NO_x Emissions Control*..... 2-2

 2.5.2 *CO and VOC Emissions Control*..... 2-2

 2.5.3 *PM₁₀ and SO₂ Emissions Control*..... 2-2

 2.5.4 *Continuous Emission Monitoring*..... 2-3

3.0 EQUIPMENT SPECIFICATIONS 3-1

3.1 EQUIPMENT LIST 3-1

3.2 GAS TURBINES 3-1

3.3 HEAT RECOVERY STEAM GENERATORS 3-1

3.4 SELECTIVE CATALYTIC REDUCTION SYSTEMS 3-2

3.5 CO OXIDATION CATALYST SYSTEMS..... 3-2

3.6 STEAM TURBINE GENERATORS 3-2

3.7 GAS FIRED FUEL PREHEATER..... 3-2

4.0 EXPECTED EMISSIONS..... 4-1

4.1 GAS TURBINE CRITERIA POLLUTANT AND HAZARDOUS AIR POLLUTANT (HAPS) EMISSIONS . 4-1

4.2 GAS-FIRED FUEL PREHEATER CRITERIA POLLUTANT AND TAC EMISSIONS 4-2

4.3 SUMMARY OF WPGS EMISSIONS OF HAZARDOUS AIR POLLUTANTS 4-2

5.0 LAWS, ORDINANCES, AND REGULATIONS 5-1

5.1 AMBIENT AIR QUALITY STANDARDS 5-1

5.2 PREVENTION OF SIGNIFICANT DETERIORATION REQUIREMENTS..... 5-1

5.3 ACID RAIN PROGRAM REQUIREMENTS..... 5-2

5.4 NEW SOURCE PERFORMANCE STANDARDS 5-3

5.5 FEDERALLY MANDATED OPERATING PERMITS 5-3

5.6 POWER PLANTS SITING REQUIREMENTS 5-3

5.7 AIR TOXIC “HOT SPOTS” PROGRAM..... 5-3

5.8 NEW SOURCE REVIEW REQUIREMENTS..... 5-4

5.9 BAY AREA AIR QUALITY MANAGEMENT DISTRICT REQUIREMENTS 5-4

6.0 EMISSION OFFSETS 6-1

7.0 AMBIENT AIR QUALITY AND PSD ANALYSIS..... 7-1

7.1 AIR DISPERSION MODELING..... 7-1

 7.1.1 *Model and Model Option Selections*..... 7-1

**ATC/PTO Application
Willow Pass Generating Station**

7.1.2	<i>Building Wake Effects</i>	7-2
7.1.3	<i>Meteorological Data</i>	7-2
7.1.4	<i>Receptor Locations</i>	7-4
7.1.5	<i>Turbine Impact Screening Modeling</i>	7-4
7.1.6	<i>Refined Modeling</i>	7-5
7.1.7	<i>Fumigation Analysis</i>	7-6
7.2	COMPLIANCE WITH AMBIENT AIR QUALITY STANDARDS AND PSD REQUIREMENTS.....	7-7
7.2.1	<i>Normal Plant Operation</i>	7-7
7.2.2	<i>Turbine Commissioning</i>	7-8
7.2.3	<i>Impacts for Non-Attainment Pollutants and their Precursors</i>	7-8
7.2.4	<i>Impacts on Air Quality Related Values in Class I Area</i>	7-9
8.0	BACT ANALYSIS	8-1
8.1	BACT ASSESSMENT METHODOLOGY	8-1
8.2	NO _x CONTROL TECHNOLOGIES.....	8-2
8.2.1	<i>Dry Combustion Controls</i>	8-2
8.2.2	<i>Wet Combustion Controls</i>	8-2
8.2.3	<i>Catalytic Combustors</i>	8-3
8.2.4	<i>Selective Catalytic Reduction (SCR)</i>	8-3
8.2.5	<i>Selective Non-Catalytic Reduction (SNCR)</i>	8-3
8.2.6	<i>Nonselective Catalytic Reduction (NSCR)</i>	8-3
8.2.7	<i>EMxTM</i>	8-4
8.3	CO AND VOC CONTROL TECHNOLOGIES.....	8-4
8.4	SO ₂ CONTROL TECHNOLOGIES.....	8-4
8.5	PM ₁₀ CONTROL TECHNOLOGIES.....	8-4
8.6	FUGITIVE DUST CONTROL.....	8-5
9.0	HEALTH RISK ASSESSMENT	9-1
9.1	PUBLIC HEALTH IMPACT ASSESSMENT APPROACH	9-1
9.2	CONSTRUCTION PHASE EMISSIONS	9-2
9.3	OPERATIONAL PHASE EMISSIONS.....	9-3
9.4	MODEL INPUT PARAMETERS	9-3
9.5	CALCULATION OF HEALTH EFFECTS	9-4
9.6	HEALTH EFFECTS SIGNIFICANCE CRITERIA.....	9-5
9.7	ESTIMATED LIFETIME CANCER RISK.....	9-5
9.8	ESTIMATED CHRONIC AND ACUTE TOTAL HAZARD INDICES	9-5
9.9	UNCERTAINTY IN THE PUBLIC HEALTH IMPACT ASSESSMENT	9-6
9.10	CRITERIA POLLUTANTS.....	9-7

List of Appendices

APPENDIX A. REFERENCES

APPENDIX B. ADDITIONAL PLOT PLAN FIGURES

APPENDIX C. EMISSIONS CALCULATIONS

APPENDIX D. APPLICATION FORMS

**ATC/PTO Application
Willow Pass Generating Station**

List of Tables

TABLE 2-1 HEAT AND MATERIAL BALANCE CASE DESCRIPTION – FLEX PLANT 10 POWER BLOCKS 2-7

TABLE 4-1 MAXIMUM FP10 UNIT OPERATING SCHEDULE AND STACK PARAMETERS 4-3

TABLE 4-2 1-HOUR OPERATING EMISSION RATES FOR ONE FP10 UNIT AS A FUNCTION OF LOAD AND
AMBIENT CONDITIONS..... 4-4

TABLE 4-3 CRITERIA POLLUTANT EMISSION RATES DURING STARTUP AND SHUTDOWN OF ONE FP10
UNIT 4-5

TABLE 4-4 COMBINED ANNUAL EMISSIONS OF CRITERIA POLLUTANTS FOR TWO FP10 UNITS 4-5

TABLE 4-5 HAPS EMISSION RATES FROM THE OPERATION OF ONE FP10 UNIT 4-6

TABLE 4-6 ANNUAL EMISSIONS OF CRITERIA POLLUTANTS FOR THE PREHEATER 4-7

TABLE 4-7 HAPS EMISSION RATES FROM THE OPERATION OF THE FUEL GAS PREHEATER 4-7

TABLE 4-8 SUMMARY OF ANNUAL HAPS EMISSION RATES FROM COMBINED OPERATION OF THE
WPGS EMISSION SOURCES..... 4-8

TABLE 5-1 NATIONAL AND CALIFORNIA AMBIENT AIR QUALITY STANDARDS..... 5-7

TABLE 5-2 ATTAINMENT STATUS FOR CONTRA COSTA COUNTY WITH RESPECT TO FEDERAL AND
CALIFORNIA AMBIENT AIR QUALITY STANDARDS 5-8

TABLE 5-3 PSD EMISSION THRESHOLD TRIGGERS FOR NEW STATIONARY SOURCES 5-8

TABLE 5-4 ALLOWABLE PSD INCREMENTS FOR SO₂, NO₂, AND PM₁₀..... 5-9

TABLE 6-1 EMISSION REDUCTION CREDIT CERTIFICATES OWNED BY MIRANT CALIFORNIA 6-2

TABLE 6-2 ESTIMATED EMISSION CREDIT REQUIREMENT TO OFFSET PROJECT EMISSIONS 6-2

TABLE 7-1 SURFACE MOISTURE CONDITIONS FOR YEARS 2002-2005 7-15

TABLE 7-2 LAND USE CHARACTERISTICS USED IN AERMET METEOROLOGICAL DATA SET A 7-15

TABLE 7-3 LAND USE CHARACTERISTICS USED IN AERMET METEOROLOGICAL DATA SET B 7-16

TABLE 7-4 WPGS TURBINE SCREENING RESULTS FP10 COMBINED-CYCLE UNITS WITH
METEOROLOGICAL DATA SET A..... 7-17

TABLE 7-5 WPGS TURBINE SCREENING RESULTS FP10 COMBINED-CYCLE UNITS WITH
METEOROLOGICAL DATA SET B..... 7-19

TABLE 7-6 MAXIMUM HOURLY NOX AND CO EMISSIONS 7-21

TABLE 7-7 CRITERIA POLLUTANT SOURCES AND EMISSIONS TOTALS FOR THE WORST CASE PROJECT
EMISSIONS SCENARIOS FOR ALL AVERAGING TIMES..... 7-22

TABLE 7-8 AERMOD MODELING RESULTS FOR WPGS OPERATIONS USING METEOROLOGICAL DATA
SET A..... 7-23

TABLE 7-9 AERMOD MODELING RESULTS FOR WPGS OPERATIONS USING METEOROLOGICAL DATA
SET B..... 7-24

TABLE 7-10 DURATION AND CRITERIA POLLUTANT EMISSIONS FOR COMMISSIONING OF A SINGLE FP10
UNIT (20 PPM ULN) ON NATURAL GAS AT 62°F 7-25

TABLE 7-11 TURBINE COMMISSIONING MODELING RESULTS USING METEOROLOGICAL DATA SET A 7-26

TABLE 7-12 TURBINE COMMISSIONING MODELING RESULTS USING METEOROLOGICAL DATA SET B..... 7-28

TABLE 8-1 SUMMARY OF PROPOSED BACT..... 8-6

TABLE 8-2 BACT DETERMINATION FOR THE WPGS EMISSION SOURCES 8-7

TABLE 9-1 OFFSITE WORKER RECEPTORS CONSIDERED IN THE HRA..... 9-8

TABLE 9-2 TOXICITY VALUES USED TO CHARACTERIZE HEALTH RISKS FOR TACS EMITTED BY WPGS
EMISSION SOURCES 9-9

TABLE 9-3 ESTIMATED CANCER RISK AND ACUTE AND CHRONIC NON-CANCER TOTAL HAZARD
INDICES DUE TO WPGS EMISSIONS OF TACS 9-10

ATC/PTO Application
Willow Pass Generating Station

List of Figures

FIGURE 1-1	PROJECT LOCATION MAP	1-3
FIGURE 1-2	VISUAL SIMULATION OF WILLOW PASS GENERATING STATION	1-4
FIGURE 2-1	FLEX PLANT 10 SITE LAYOUT	2-5
FIGURE 2-2	FLEX PLANT 10 HEAT AND MATERIAL BALANCE	2-6
FIGURE 7-1	ANNUAL WIND ROSE FOR 2002-2005	7-10
FIGURE 7-2	NEAR-FIELD MODEL RECEPTOR GRID	7-11
FIGURE 7-3	FAR-FIELD MODEL RECEPTOR GRID	7-12
FIGURE 7-4	LOCATIONS OF MAXIMUM PREDICTED GROUND LEVEL POLLUTANT CONCENTRATIONS FOR THE OPERATIONAL PROJECT AREA USING METEOROLOGICAL DATA SET A.....	7-13
FIGURE 7-5	LOCATIONS OF MAXIMUM PREDICTED GROUND LEVEL POLLUTANT CONCENTRATIONS FOR THE OPERATIONAL PROJECT AREA USING METEOROLOGICAL DATA SET B	7-14

**ATC/PTO Application
Willow Pass Generating Station**

List of Acronyms

$\mu\text{g}/\text{m}^3$	micrograms per cubic meter
$^{\circ}\text{C}$	degrees Celsius
$^{\circ}\text{F}$	degrees Fahrenheit
AAQS	Ambient Air Quality Standards
ACHE	Air-cooled heat exchanger
AERMOD	American Meteorological Society/Environmental Protection Agency Regulatory Model
AFC	Application for Certification
APN	Assessor's Parcel Number
AQRV	Air quality related values
ATC	Authority to construct
BAAQMD	Bay Area Air Quality Management District
BACT	Best available control technology
BPIP-Prime	Building Parameter Input Program – Prime
CAAQS	California Ambient Air Quality Standards
CARB	California Air Resources Board
CEC	California Energy Commission
CO	carbon monoxide
CTG	Combustion turbine generator
DAS	Data acquisition system
DEM	digital elevation models
DOC	Determination of compliance
FLAG	Federal Land Managers' Air Quality Related Values Workgroup
FP10	Flex Plant 10
HARP	Hotspots analysis and reporting program
HHV	higher heating value
HI	hazard index
HRA	Health risk assessment
HRSA	Health Risk Screening Analysis
HRSG	Heat recovery steam generator
ISCST3	Industrial Source Complex Short Term 3 rd version
IWAQM	Interagency Workgroup on Air Quality Modeling
kg/ha-yr	kilogram per hectare per year
km	kilometers
LORS	Laws, ordinances, regulations, and standards
MW	megawatt
NAAQS	National Ambient Air Quality Standards
NO_x	Nitrogen oxides
NPS	National Park Service
NSR	New source review
NWS	National Weather Service
O_3	ozone
OEHHA	Office of Environmental Health Hazard Assessment
OLM	ozone limiting method

ATC/PTO Application
Willow Pass Generating Station

Pb	lead
PG&E	Pacific Gas & Electric
PM ₁₀	particulate matter less than 10 µm in diameter
PM _{2.5}	particulate matter less than 2.5 µm in diameter
ppb	parts per billion
ppm	parts per million
PPP	Pittsburg Power Plant
PSD	Prevention of Significant Deterioration
RH	relative humidity
ROC	Reactive organic compound
SCR	Selective catalytic reduction
SIL	Significant impact level
SO _x	sulfur oxide
STG	steam turbine generator
TAC	toxic air contaminants
tpy	tons per year
ULN	Ultra Low NO _x
USEPA	United States Environmental Protection Agency
USFS	United States Forest Service
USGS	United States Geological Survey
UTM	Universal Transverse Mercator
VOC	volatile organic compounds
WPGS	Willow Pass Generating Station

**ATC/PTO Application
Willow Pass Generating Station**

1.0 INTRODUCTION

Mirant Willow Pass, LLC (Mirant Willow Pass) proposes to build and operate a new 550 MW natural-gas-fired generation facility with two Siemens Flex Plant 10 (FP10) combined-cycle units. The proposed Willow Pass Generating Station (WPGS) units are to be constructed wholly within the existing Pittsburg Power Plant (PPP) site owned and operated by Mirant Delta, LLC (Mirant Delta). This document is an Authority to Construct/Permit to Operate Application to the Bay Area Air Quality Management District (BAAQMD) for the WPGS project.

The existing PPP is an already permitted major facility. The proposed WPGS is also classified as a major facility and will apply for a new Title V permit.

1.1 Overview

Mirant Willow Pass proposes to build and operate new natural-gas-fired generation facilities and ancillary systems. The proposed WPGS units are to be constructed wholly within the existing PPP site. The WPGS will be situated on a parcel of approximately 26 acres that will be created by a lot line adjustment that will separate it from the existing PPP site. The PPP site is located at 696 West 10th Street, Pittsburg, CA, 94565 in Contra Costa County, California. The WPGS site is currently occupied by the existing power generation Units 1 through 4, which are now retired and which last operated in 2003; an unused surface impoundment; an administration building; an unused #6 fuel oil storage tank (Tank 7), temporary buildings; and other ancillary facilities. The site location and an aerial overview of the proposed WPGS are shown on Figure 1-1 and Figure 1-2, respectively. The project includes the demolition of Units 1 through 4, the administration building and Tank 7, as well as replacement of the existing hazardous materials and hazardous waste buildings.

Construction of the new power generation facility is expected to occur over a 34-month period (from October 2009 through July 2012). Construction (including demolition) is expected to cost approximately \$585 million (in 2008 dollars).

The generator output from the WPGS will be stepped-up to 230-kV transmission voltage and consists of two Siemens FP10 units operating in combined cycle mode. The FP10 units will be intermediate-load power blocks, expected to operate at 40 to 50 percent capacity factor, and generating approximately 550 megawatts (MW) (net) when both are operated together at an ambient temperature of 75 degrees Fahrenheit (°F) and 54 percent relative humidity. Commercial operation for the WPGS is expected by summer 2012.

Each Siemens FP10 unit includes one combustion turbine generator (CTG) equipped with dry ultra low NO_x (ULN) combustors and inlet air evaporative cooler, one heat recovery steam generator (HRSG), one steam turbine generator (STG), an air-cooled heat exchanger (ACHE), and associated auxiliary systems and equipment. Each HRSG will be equipped with an emissions control system to include a SCR and carbon monoxide (CO) catalyst, an ammonia system, a continuous emissions monitoring system (CEMS), and stack.. A small fuel gas preheater (approximately 5 MMBtu/hour) will be installed to treat the natural gas fuel provided to both CTGs.

The WPGS will be interconnected to the PG&E switchyard adjacent to the WPGS site. Pipeline-quality natural gas will be the exclusive fuel for the two CTGs and the preheater. Natural gas will be delivered to the WPGS via a new onsite 12-inch-diameter gas line connection from the existing PPP metering station.

ATC/PTO Application Willow Pass Generating Station

Several of the components of the proposed project will be located outside the proposed WPGS boundary, but within previously disturbed, graded or paved areas of the PPP and adjacent PG&E switchyard property. These include:

- Approximately 21.5 acres of construction, laydown, parking and office areas;
- Approximately 2,700 feet of new natural gas line which connects immediately upstream of the existing PPP gas meter station (with a dedicated meter)
- Approximately 1,600 feet of new transmission lines connecting to the PG&E switchyard;
- A new hazardous material building and a new hazardous waste building, which will be located on the PPP site, west of existing Unit 7;
- New screening walls, approximately 48 feet tall, which will be constructed between each of the existing Tanks 1 through 6, located on the eastern boundary of the PPP site.

A new potable water line and new sanitary line be constructed to connect the WPGS to existing potable water and sanitary lines on the PPP property.

Finally, the project will include an offsite component that extends beyond both the WPGS and the PPP site boundaries. Specifically, new 5-mile long water supply and waste water discharge lines will be constructed to connect the WPGS site to the Delta Diablo Sanitation District Wastewater Treatment Plant (DDSD WTP).

The project includes the demolition of Units 1 through 4, the administration building and Tank 7, as well as replacement of the existing hazardous materials and hazardous waste buildings.

Emission increases from the WPGS will be offset according to BAAQMD Regulation 2. Details of the emissions increases as a result of the project and offsets are discussed in Section 4.0 and Section 6.0, respectively.

Dispersion modeling was conducted to determine the potential impacts of criteria pollutant and hazardous air pollutant (HAP) emissions. The impacts from the project will not cause the exceedance of any of the California State or Federal Ambient Air Quality Standards (AAQS), or contribute significantly to any existing exceedance. However, the project will trigger Prevention of Significant Deterioration (PSD) Review. Section 7.0 details the AAQS standards and the PSD analysis. The project will not cause any exceedance of PSD significant ground level concentrations. The modeled health risks associated with increased emissions of toxic air contaminants are below significance levels, as discussed in Section 9.0.

The proposed WPGS project will trigger Best Available Control technology (BACT) requirements for Nitrogen Oxides (NO_x), Sulfur Oxides (SO_x), Volatile Organic Compound (VOC), Particulate Matter (PM), and Carbon Monoxide (CO). Section 8.0 describes the BACT analysis and proposed technologies that will be included to meet BACT requirements as implemented by the BAAQMD.

1.2 Applicant Background Information

1.2.1 Business Name/Location

Mirant Willow Pass, LLC – Willow Pass Generating Station

The WPGS will be located within the existing PPP site, Assessor's Parcel Number (APN) 085-010-014, in Pittsburg, California.

ATC/PTO Application
Willow Pass Generating Station

1.2.2 Nature of Business

The proposed Willow Pass Generating Station facility is an electric power generation facility.

1.2.3 Person to Contact Regarding Application

John Lague
Leader, Air Quality and Public Health,
URS Corporation
1615 Murray Canyon Road, Suite 1000
San Diego, CA 92108
Phone: (619) 294-9400
Fax: (619) 293-7920
John_Lague@urscorp.com

Ronald Kino
Manager, Environmental Health and Safety,
Mirant California, LLC
P.O. Box 192,696 W. 10th Street
Pittsburg, CA 94565
Phone: (925) 427-3567
Fax: (925) 427-3535
Ronald.kino@mirant.com

1.2.4 Type of Entitlement

This document is an application for an Authority to Construct/Permit to Operate for the WPGS project to be issued by the BAAQMD. The project includes two Siemens FP10 units operating in combined cycle mode and one fuel gas preheater to treat the natural gas fuel stream to the turbines. Each HRSG (FP10 units only) will be equipped with an emissions control system to include an SCR and carbon monoxide (CO) catalyst, an ammonia system, a continuous emissions monitoring system (CEMS), and stack. The fuel gas preheater will serve both FP10 power blocks.

1.2.5 Estimated Construction and Completion Dates

Construction of the new power generation facility is expected to occur over a 34-month period (from October 2009 through July 2012). Commercial operation is expected by summer 2012.

1.2.6 Application Status

This document is an original Authority to Construct/Permit to Operate application. An Application for Certification for the WPGS was submitted to the California Energy Commission on June 30, 2008.


1.2.7 Operating Schedule

The FP10 units will be intermediate-load power blocks, expected to operate at 40 to 50 percent capacity factor.

The natural gas-fired fuel preheater was conservatively assumed to operate at maximum capacity for all hours of operation for either turbine.

1.2.8 Compliance Certification

Mirant certifies that all facilities owned or operated by the Mirant Delta, LLC within the state are in compliance with applicable federal, state, and BAAQMD emission limits and applicable environmental standards.



**ATC/PTO Application
Willow Pass Generating Station**



T:\08\08 vsa...T\Mirant Pittsburg-Willow Pass\Graphics\ATC_Air Permt\1-2_aerial sim: WPGS.cdr

**ATC/PTO Application
Willow Pass Generating Station**

2.0 PROJECT DESCRIPTION

2.1 Equipment

The only stationary project emission sources will be the two Siemens FP10 units operating in combined cycle mode and one natural gas-fired fuel preheater.

Each Siemens FP10 unit includes one combustion turbine generator (CTG) equipped with ultra low NO_x (ULN) combustors and inlet air evaporative cooler, one heat recovery steam generator (HRSG), one steam turbine generator (STG), an air-cooled heat exchanger (ACHE), and associated auxiliary systems and equipment (see Figure 2-1). Each HRSG will be equipped with an emissions control system to include a SCR for NO_x control and carbon monoxide (CO) catalyst, an ammonia system, a continuous emissions monitoring system (CEMS), and stack.

Exhaust gases from the two power blocks will be discharged from separate stacks that are expected to be approximately 151 ft tall. Steam from each HRSG will be used to drive a steam turbine generator. The process flow diagram for the FP10 units is shown on Figure 2-2. The heat and material balance cases for the facility are shown in Table 2-1. Three cases are shown in the table for each power block: summer design conditions (94°F), average conditions (59°F), and extreme winter conditions (20°F). For the summer and average conditions, evaporative cooling is included for both power blocks. In addition, when operating at 100 percent load, power augmentation may be used. For the winter case, which is the lowest temperature at which the units would ever be expected to operate, neither evaporative coolers nor power augmentation would be in operation.

The natural gas-fired fuel preheater will be installed to condition the natural gas fuel to the turbines. The preheater will be rated at a fuel energy input of 5 MMBtu/hour. One fuel gas preheater will serve the two FP-10 units.

Although in reality the heater will not be used during some turbine operating periods, it has been conservatively assumed for this analysis that this unit will operate at maximum capacity during all hours of turbine operation. Based on BAAQMD Regulation 2-1-114, the natural gas-fired fuel preheater is exempt from permitting because they it is rated at less than 10 MMBtu/hour and fired exclusively on natural gas. However, these units will still be discussed in this application as a part of the project.

2.2 Fuel

The WPGS will use natural gas that will be delivered via a new 12-inch-diameter gas line connection, which will run from within the existing gas metering station of the PPP to the WPGS site. A new dedicated metering station will be provided within the western portion of the WPGS site.

The natural gas pressure will be increased by gas compressors to a pressure of approximately 600 pounds per square inch gauge (psig), filtered, and pressure-regulated before entering the CTGs. Safety pressure relief valves will be provided to protect the natural gas system components from over-pressurization.

Estimated emissions of sulfur oxides for combustion of this fuel by the project's equipment assumed full oxidation of all fuel sulfur to SO₂ and a natural gas sulfur content of 0.40 grains per 100 standard cubic feet (scf) annual average. For short-term emissions a conservative estimate of a natural gas sulfur content of 1.0 grains per 100 scf was used for the calculations, i.e., the upper limit as specified in PG&E's Rule 21 of Section C.

ATC/PTO Application Willow Pass Generating Station

2.3 Electrical

The two Siemens FP10 units of the proposed WPGS project will produce 550 MW. Each of the two combustion-gas turbines and two steam turbines will be connected to separate electric generators. The WPGS will be interconnected to the PG&E switchyard adjacent to the WPGS site. Electric power generated by the facility will be provided to the grid to serve energy needs throughout California.

2.4 Process Operation

The WPGS project includes two Siemens FP10 units operating in combined cycle mode. The average net generating capacity of each FP10 will be approximately 275 MW. The actual net output of the system will vary in response to ambient air temperature conditions, use of evaporative coolers, amount of auxiliary load, generator power factor, firing conditions of the combustion turbines, and other operating factors. The process flow diagram for the proposed power generation facility is shown on Figure 2-2.

2.5 Emission Control Technology

This section describes the technologies included in the Willow Pass Generating Station project to minimize the emission of criteria pollutants, specifically NO_x and CO.

2.5.1 NO_x Emissions Control

In the proposed turbine/HRSG trains, NO_x emissions will be controlled by two methods:

1. By the use of Ultra Low NO_x (ULN) combustors to limit the initial NO_x formation during fuel combustion, and
2. By the use of Selective Catalytic Reduction (SCR) emissions control equipment to remove NO_x from the combustion gas exhaust.

ULN combustors in the CTGs, followed by SCR in the HRSGs will control stack emissions of NO_x to a maximum 2.0 ppmvd for the FP10s. The ULN combustors control NO_x emissions to approximately 9.0 ppmvd at the CTG exhausts by pre-mixing fuel and air immediately before combustion. Pre-mixing inhibits NO_x formation by minimizing the flame temperature and the concentration of oxygen at the flame front.

The SCR process will use aqueous ammonia (NH₃) as a reagent. Stack emissions of ammonia, referred to as “ammonia slip,” will not exceed 5 ppmvd for the FP10 units. The SCR system includes a catalyst chamber containing a catalyst bed within each HRSG, an ammonia storage system, ammonia vaporization system, and ammonia injection system. The catalyst chamber and bed are located within a temperature zone of the HRSG where the catalyst is most effective over the range of loads at which the plant will operate. The ammonia injection grid is located upstream of the catalyst chamber. It is expected that the 20,000-gallon aqueous ammonia storage tank serving the two FP10s will have a 10-day storage capacity.

2.5.2 CO and VOC Emissions Control

An oxidation catalyst will be provided in the HRSG to limit CO emissions to less than 3 ppmvd, and VOC emissions to less than 2 ppmvd (corrected to 15 percent O₂). These emission levels correspond to current California best available control technology (BACT). This catalytic system will promote the oxidation of CO to carbon dioxide, and VOC to carbon dioxide and water vapor, without the need for additional reagents. The catalyst has a design life of seven to ten years.

2.5.3 PM₁₀ and SO₂ Emissions Control


PM₁₀ emissions consist primarily of hydrocarbon particles formed during combustion. PM₁₀ emissions will be controlled by inlet air filtration and by the use of natural gas fuel, which contains essentially zero particulate matter.

ATC/PTO Application
Willow Pass Generating Station


SO₂ emissions will be controlled by the use of pipeline-quality natural gas, which contains only trace quantities of sulfur from the injected mercaptan odorant.

2.5.4 Continuous Emission Monitoring

The continuous emissions monitoring system (CEMS) uses dilution and/or direct extractive sampling techniques for in-stack or in-duct monitoring. For each CTG, a separate CEMS will sample, analyze, and record fuel gas flow rate, NO_x and CO concentration levels, and percentage of O₂ in the exhaust gas from the stacks. The CEMS systems will transmit data to a data acquisition system (DAS) that will store the data and generate emission reports in accordance with permit requirements. The DAS will also include alarm features that will send signals to the plant DCS when the emissions approach or exceed pre-selected limits.



7/08/08 vaa..IT\Mirant\Pittsburg\Willow Pass\Graphics\ATC_Ar\Fem#2-1_LP10 layout.dwg



	Units	20°F, 90% RH 100% Load	75°F, 54% RH 100% Load	94°F, 32% RH 100% Load
Gross Power Output	MW	295.3	282.1	274.5
Gross Heat Rate (LHV)	Btu/kW-hr	6,927	6,995	6,970
1 Water Flow (Evap Cooler)	lb/hr	0	13,000	30,000
2 Steam How (Power Augmentation)	lb/hr	0	133,657	133,657
3 Fuel Flow	lb/hr	98,905	94,944	92,637
4 Blowdown	lb/hr	7,000	7,000	7,000
Net Power Output	MW	285.7	273.0	266.5

NOTE: 1 UNIT SHOWN TYPICAL OF 2

Source:
 CH2MHill Lockwood Greene, Process Flow Diagram, Willow Pass Heat Balance FP 10s
 Drawing No: MC-PR-10-A-001 (Rev. P2, 05/15/08)

FLEX PLANT 10 HEAT AND MATERIAL BALANCE
 Willow Pass Generating Station
 Mirant Willow Pass, LLC
 Pittsburg, California
 July 2008
 28067343
URS
 FIGURE 2-2

T:\08\08 vsa .\T:\Mirant\Pittsburg\Willow Pass\Graphics\ATC_Air Permit\2-2_Heat-Mat Balance.d

**ATC/PTO Application
Willow Pass Generating Station**

Table 2-1 Heat and Material Balance Case Description – Flex Plant 10 Power Blocks						
Case	Ambient Temperature (°F)	Relative Humidity (percent)	CTG Load (percent)	Evaporative Cooling	Power Augmentation	
1	A	94	32	100	Yes	Yes
	B	94	32	85	Yes	No
	C	94	32	60	Yes	No
2	A	59	54	100	Yes	Yes
	B	59	54	85	Yes	No
	C	59	54	60	Yes	No
3	A	20	90	100	No	No
	B	20	90	85	No	No
	C	20	90	60	No	No

**ATC/PTO Application
Willow Pass Generating Station**

3.0 EQUIPMENT SPECIFICATIONS

3.1 *Equipment List*

This section summarizes specifications regarding the following equipment comprising the Willow Pass Generating Station Project.

- S-1 CTG #1, Siemens FP10 Natural Gas-Fired CTG, 275 MW; 2271 million (MM)BTU per hour with Ultra Low NO_x combustors; abated by A-1 CO Catalyst System and A-2 SCR System
- S-2 CTG #2 Siemens FP10 Natural Gas-Fired CTG, 275 MW; 2271 million (MM)BTU per hour with Ultra Low NO_x combustors; abated by A-3 CO Catalyst System and A-4 SCR System
- S-3 Natural Gas Fired Fuel Preheater; 5.00 million (MM)BTU per hour; Serving S-1 and S-2
- A-1 CO Catalyst System #1 abating emissions from CTG #1 (S-1)
- A-2 SCR System #1 abating emissions from CTG #1 (S-1)
- A-3 CO Catalyst System #2 abating emissions from CTG #2 (S-2)
- A-4 SCR System #2 abating emissions from CTG #2 (S-2)
- P-1 Stack #1 releasing emissions from CTG #1 (S-1) after being abated by CO Catalyst System #1 (A-1) and SCR System #1 (A-2)
- P-2 Stack #2 releasing emissions from CTG #2 (S-2) after being abated by CO Catalyst System #2 (A-3) and SCR System #2 (A-4)
- P-3 Preheater Emission Point following natural gas-fired fuel preheater (S-3)

3.2 *Gas Turbines*

Quantity:	Two Units
Mfg:	Siemens
Model:	Flex Plant 10
Performance:	
Base Rating	275 MW
Heat Rating	~ 7,020 – 7,795 BTU/kilowatt-hour
Turbine Stack Temperature	333 to 350 F

3.3 *Heat Recovery Steam Generators*

Quantity:	Two Units
Mfg:	Siemens
Model:	TBD
Type:	Submerged-tube heat exchanger with single-pressure design and extended fin-tube construction. Each HRSG will be equipped with an emissions control system to include a SCR and carbon monoxide (CO) catalyst, an ammonia system, a continuous emissions monitoring system (CEMS), and stack.
Performance:	1,700 psig steam each

**ATC/PTO Application
Willow Pass Generating Station**

3.4 *Selective Catalytic Reduction Systems*

Quantity:	Two Units
Mfg:	Siemens
Type:	Vanadium pentoxide
Performance:	
Gas Flow	TBD
Gas Temperature	TBD
NO _x Reduction	2.0 ppmvd for FP10s
Differential Pressure	TBD
Catalyst Life	7 to 10 years

3.5 *CO Oxidation Catalyst Systems*

Quantity:	Two Units
Mfg:	Siemens
Type:	CO Catalyst
Performance:	
Gas Flow	TBD
Gas Temperature	TBD
CO Reduction	Reduces CO concentration to < 3 ppmvd, @ 15 % O ₂
NMHC Conversion	Reduces VOC concentration to < 2 ppmvd, @ 15 % O ₂
Differential Pressure	TBD
Catalyst Life	7 to 10 years

3.6 *Steam Turbine Generators*

Quantity:	Two Units
Mfg:	Siemens
Type:	SST-800 back pressure, single-case design with a high-efficiency blade path.

3.7 *Gas Fired Fuel Preheater*

Quantity:	One Unit
Mfg:	TBD
Type:	Natural Gas Fired
Performance:	
Heat Rating	5.00 MMBTU/hr
Stack Height	26.0 feet above grade
Stack Inside Diameter	8.0 inches
Exhaust Temperature	415 °F

ATC/PTO Application
Willow Pass Generating Station

4.0 EXPECTED EMISSIONS

This section discusses the expected emissions from the proposed power blocks. Emissions of both criteria pollutants and hazardous air pollutants were estimated. These emission rates will be used to show that the Willow Pass Generating Station project will not cause an exceedance of PSD increments, California or Federal AAQS, or significant health risk thresholds.

4.1 Gas Turbine Criteria Pollutant and Hazardous Air Pollutant (HAPs) Emissions

The primary emission sources of the project once it becomes operational will be the two Siemens Flex Plant 10 (FP10) turbines in combined cycle mode. Maximum short-term operational emissions from these units were determined from a comparative evaluation of potential emissions corresponding to turbine commissioning, normal operating conditions, and CTG startup/shutdown conditions. The long-term operational emissions from the units were estimated by summing the emissions contributions from normal operating conditions and CTG startup/shutdown conditions. Estimated annual emissions of air pollutants for the units FP-10s have been calculated based on the expected operating schedule for the units presented below in Table 4-1.

The criteria pollutant emission rates and stack parameters provided by the units vendors for three load conditions (60 percent, 85 percent, and 100 percent) at three ambient temperatures (94°F, 60°F, and 20°F) are presented for the FP10 units in Table 4-2.

The operating cases in Table 4-2 encompass CTG operations with and without power augmentation, and with and without evaporative cooling of the inlet air to the turbines. The combined scenarios presented in these tables bound the expected normal operating range of each proposed unit.

The expected emissions and durations associated with CTG startup and shutdown events are summarized in Table 4-3. Based on vendor information, startup (i.e., the period from initial firing to compliance with emission limits) of the FP10 units is expected to be achieved within 12 minutes. During a turbine shutdown event, the emission controls will continue to function efficiently at normal operating levels down to a load of 60 percent; thus, shutdown periods and the associated emissions are measured from the time this load is reached.

An hour that includes a turbine startup event will have higher rates of emissions for all criteria pollutants, than either an hour that include a shutdown event or an hour of normal operating conditions with fully functioning SCR and CO oxidation catalyst. Thus, the hours that include a startup event were used for the worst-case short- and long-term emission estimates in the air quality dispersion modeling simulations described later in this application.

The total combined annual emissions from both FP10 turbine units are shown in Table 4-4. Annual emissions of all pollutants for the FP10s were calculated based on 4,383 hours of operation with 193 startups and 193 shutdowns, 322 hours of normal operational emissions and 4,000 hours with power augmentation, all calculated at the yearly average ambient temperature of 59°F.

Toxic air contaminant emissions rate for the gas turbine units have been calculated based on the expected operating schedule and are presented in Table 4-5.

ATC/PTO Application
Willow Pass Generating Station

4.2 *Gas-fired Fuel Preheater Criteria Pollutant and TAC Emissions*

The fuel gas preheater will be rated at of 5.00 MMBTU per hour heat input, and has been conservatively assumed to be in operating at full capacity to treat the gas fuel to the turbines whenever they are in operation. Estimated criteria pollutant emissions from the preheater are shown in Table 4-6 and the corresponding emissions for toxic air contaminants (TACs) are shown in Table 4-7.

4.3 *Summary of WPGS Emissions of Hazardous Air Pollutants*

Under the Clean Air Act, Section 112, a major source of hazardous air pollutants (HAPs) is a source that emits 10 tons per year or more of any single HAP or 25 tons per year or more of any combination of HAPs. Therefore, based on the summary of annual emission from all WPGS operational sources in Table 4-8, the proposed project will not be a major source of HAPs.

ATC/PTO Application
Willow Pass Generating Station

Table 4-1	
Maximum FP10 Unit Operating Schedule and Stack Parameters	
Operating Conditions	Annual Numbers
Number of Starts per Turbine	193
Number of Shutdowns per Turbine	193
Startup Time (min)	12
Shutdown Time (min)	6
Turbine Operation with Power Augmentation (hours)	4,000
Normal Turbine Operation (hours)	322
Total Turbine Operation (hours)	4,383
Stack Height (feet)	150.5
Stack Diameter (feet)	21.33

**ATC/PTO Application
Willow Pass Generating Station**

**Table 4-2
1-Hour Operating Emission Rates for One FP10 Unit as a Function of Load and Ambient Conditions**

Case	Units	1A	1B	1C	2A	2B	2C	3A	3B	3C	3D	3E	3F
Ambient Temperature	°F	Winter Extreme Minimum: 20°F			Average: 59°F			Summer Design: 94°F					
CTG Load Level	%	100%	85%	60%	100%	85%	60%	100%	100%	100%	100%	85%	60%
Evaporative Cooling Status	off/on	Off	Off	Off	Off	Off	Off	On	On	Off	Off	Off	Off
Power Augmentation Status	off/on	Off	Off	Off	Off	Off	Off	On	Off	On	Off	Off	Off
Stack Outlet Temperature	°F	350	346	344	340	337	329	338	348	333	341	346	323
Exit Velocity	fps	70.5	61.5	50.1	64.3	57.0	44.9	65.2	62.5	61.6	59.0	53.4	42.8
NO _x (at 2.0 ppm)	lb/hr	17.4	15.1	12.0	15.8	13.9	10.0	16.3	15.2	15.3	14.3	12.9	10.0
CO (at 3 ppm)	lb/hr	15.9	13.8	10.7	14.6	12.8	9.5	15.0	14.0	14.1	13.1	11.7	9.0
VOC (at 2.0 ppm)	lb/hr	6.2	5.4	4.1	5.6	5.0	3.6	5.8	5.4	5.4	5.0	4.5	3.5
PM ₁₀	lb/hr	10.0	8.9	8.0	9.3	8.3	8.0	8.9	8.8	8.5	8.5	7.7	8.0
SO ₂ (1 gr/100 scf)	lb/hr	6.4	5.6	4.5	5.8	5.2	4.0	6.0	5.6	5.6	5.3	4.7	3.8

Notes:

CO = carbon monoxide
 CTG = combustion turbine generator
 fps = feet per second
 lb/hr = pounds per hour
 NO_x = nitrogen oxide
 O₂ = oxygen

PM₁₀ = particulate matter 10 microns in diameter
 ppm = parts per million
 scf = standard cubic feet
 SO₂ = sulfur dioxide
 VOC = volatile organic compounds

**ATC/PTO Application
Willow Pass Generating Station**

Table 4-3 Criteria Pollutant Emission Rates during Startup and Shutdown of One FP10 Unit				
	Startup (12 min)		Shutdown (7 min)	
	1 hr w/ 1 SU (lb/hr)	Total Emissions (lb/event)	1 hr w/1 SD (lb/hr)	Total Emissions (lb/event)
NO _x (2.0 ppm)	38.7	24.8	25.9	10.5
CO (3 ppm)	279.8	267.1	149.5	135.4
VOC (2 ppm)	17.7	12.7	10.7	5.2
SO ₂ (0.4 gr/100 scf)	2.7	0.6	2.4	0.2
SO ₂ (1 gr/100 scf)	6.7	1.6	6.1	0.4
PM ₁₀	11.1	3.1	9.9	1.1

Notes:
Startup/shutdown duration defined as operation of FP10s below 60 percent load when gaseous emission rates (lb/hr basis) exceed the controlled rates defined as normal operation
Startup and shutdown SO₂ emissions are calculated based on the total amount of fuel used for each event and the emission rate of SO₂ at a winter extreme of 20°F; 100% load

CO = carbon monoxide
NO_x = nitrogen oxide
PM₁₀ = particulate matter 10 microns in diameter
SD = shutdown
SO₂ = sulfur dioxide
SU = startup
VOC = volatile organic compounds

Table 4-4 Combined Annual Emissions of Criteria Pollutants for Two FP10 Units	
Pollutant	Emissions (tons/year)
	FP10 Units¹
NO _x	77.1
CO	142.4
VOC	28.5
SO ₂	10.5
PM ₁₀	39.4

Notes:
¹ FP10 emissions based on 4,383 hours of operation (4,000 hours with power augmentation, 322 hours normal operation, 193 startups, and 193 shutdowns).

ATC/PTO Application
Willow Pass Generating Station

Table 4-5			
HAPs Emission Rates from the Operation of One FP10 Unit			
Pollutant	Emission Factor (lb/MMBtu)	Hourly Emission Rate (lb/hr)	Annual Emission Rate (lb/yr)
Ammonia		16.1	7.06E+04
1,3-Butadiene	1.24E-07	2.82E-04	1.23E+00
Acetaldehyde	1.34E-04	3.04E-01	1.33E+03
Acrolein	3.62E-06	8.22E-03	3.60E+01
Benzene	3.26E-06	7.40E-03	3.24E+01
Ethylbenzene	1.75E-05	3.97E-02	1.74E+02
Formaldehyde	3.60E-04	8.18E-01	3.58E+03
Hexane	2.53E-04	5.74E-01	2.52E+03
Propylene	7.53E-04	1.71E+00	7.49E+03
Propylene Oxide	4.67E-05	1.06E-01	4.65E+02
Toluene	6.93E-05	1.57E-01	6.90E+02
Xylenes	2.55E-05	5.79E-02	2.54E+02
Polycyclic Aromatic Hydrocarbons (PAH)			
Benzo(a)anthracene	2.21E-08	5.01E-05	2.20E-01
Benzo(a)pyrene	1.36E-08	3.98E-05	1.32E-01
Benzo(b)fluoranthene	1.10E-08	2.51E-05	1.10E-01
Benzo(k)fluoranthene	1.07E-08	2.44E-05	1.07E-01
Chrysene	2.46E-08	5.59E-05	2.45E-01
Dibenz(a,h)anthracene	2.29E-08	5.21E-05	2.28E-01
Indeno(1,2,3-cd)pyrene	2.29E-08	5.21E-05	2.28E-01
Naphthalene	1.62E-06	3.68E-03	1.61E+01
Total PAHs		3.98E-03	1.74E+01
Notes: ¹ Hourly and annual emissions based on maximum CTG/HRSG operations. ² Annual emissions based on 4,383 hours of operations. ³ Emission factors obtained from the CATEF database for natural-gas-fired combustion turbines. Formaldehyde, Benzene, and Acrolein emission factors are from the Background document for AP-42, Section 3.1, Table 3.4-1, for a natural-gas-fired combustion turbine with a carbon monoxide catalyst. ⁴ Ammonia emission rate based on an exhaust ammonia limit of 5 parts per million by volume at 15 percent oxygen provided by the turbine vendor. ⁵ A HHV of 1,024 British thermal units per standard cubic foot was used to convert emission factor units.			

ATC/PTO Application
Willow Pass Generating Station

Table 4-6		
Annual Emissions of Criteria Pollutants for the Preheater		
	S-3 (Serving FP-10 Units S-1 and S-2)	
Pollutant	lbs/yr/unit	tons/yr/unit
CO	752	0.376
NO _x	657	0.329
PM ₁₀	64.5	0.032
SO ₂ *	24.5	0.012
VOC	60.2	0.030

Note: *based on natural gas fuel sulfur content of 0.4 gr total S / 100 scf

Table 4-7			
HAPs Emission Rates from the Operation of the Fuel Gas Preheater			
Pollutant	Emission Factor (lb/MMBtu)	Hourly Emission Rate (lb/hr)	Annual Emission Rate (lb/yr)
Acetaldehyde	1.37E-05	6.84E-05	3.00E-01
Acrolein	4.73E-06	2.36E-05	1.04E-01
Benzene	1.09E-05	5.47E-05	2.40E-01
Ethylbenzene	2.20E-06	1.10E-05	4.82E-02
Formaldehyde	7.23E-05	3.61E-04	1.58E+00
Propylene	2.29E-04	1.15E-03	5.03E+00
Toluene	2.88E-05	1.44E-04	6.31E-01
Xylenes	1.40E-05	6.98E-05	3.06E-01
Polycyclic Aromatic Hydrocarbons (PAH)			
Benzo(a)anthracene	1.91E-09	9.57E-09	4.19E-05
Benzo(a)pyrene	9.57E-10	4.79E-09	2.10E-05
Benzo(b)fluoranthene	1.11E-09	5.57E-09	2.44E-05
Benzo(k)fluoranthene	9.67E-10	4.83E-09	2.12E-05
Chrysene	1.36E-09	6.79E-09	2.97E-05
Dibenz(a,h)anthracene	8.96E-10	4.48E-09	1.96E-05
Indeno(1,2,3-cd)pyrene	1.14E-09	5.71E-09	2.50E-05
Naphthalene	1.09E-06	5.47E-06	2.40E-02
Total PAHs		5.51E-06	2.42E-02
Notes:			
1 Hourly and annual emissions based on maximum heater fuel energy consumption of 5 MMBtu/hour.			
2 Annual emissions based on 4,383 hours of operations.			
3 Emission factors obtained from the average species data from CATEF database for natural-gas-fired heaters (without controls).			
4 A HHV of 1,024 British thermal units per standard cubic foot was used to convert emission factor units.			

**ATC/PTO Application
Willow Pass Generating Station**

**Table 4-8
Summary of Annual HAPs Emission Rates
from Combined Operation of the WPGS Emission Sources**

Federal HAP	Annual Emission Rate (ton/yr)		
	2 FP-10s	1 Gas Heater	Total
1,3-Butadiene	0.001		0.001
Acetaldehyde	1.332	0.000	1.332
Acrolein	0.036	0.000	0.036
Benzene	0.032	0.000	0.033
Ethylbenzene	0.174	0.000	0.174
Formaldehyde	3.583	0.001	3.584
Hexane	2.518		2.518
Propylene Oxide	0.465		0.465
Toluene	0.690	0.000	0.690
Xylenes	0.254	0.000	0.254
Naphthalene	0.0161	0.0000	0.016
PAHs (other than naphthalene)	1.27E-03	9.15E-08	0.001
Total HAP emissions (ton/yr)			9.103
Notes: Ammonia and propylene are not federally regulated HAPs. For the CAA112 requirements, the combination of all Polyaromatic Hydrocarbons (PAH) will be considered Polycyclic Organic Matter (POM); each individual PAH is not a HAP.			

5.0 LAWS, ORDINANCES, AND REGULATIONS

The applicable laws, ordinances, regulations, and standards (LORS) related to the potential air quality impacts from the project are described below. These LORS are administered (either independently or cooperatively) by the BAAQMD, the U.S. EPA Region IX, the CEC, and the CARB.

5.1 *Ambient Air Quality Standards*

U.S. EPA, in response to the federal CAA of 1970, established NAAQS in 40 CFR Part 50. NAAQS include both primary and secondary standards for six “criteria” pollutants. These criteria pollutants are O₃, CO, NO₂, SO₂, PM₁₀, and Pb. Primary standards were established to protect human health, and secondary standards were designed to protect property and natural ecosystems from the effects of air pollution.

The 1990 Clean Air Act Amendments (CAAA) established attainment deadlines for all designated areas that were not in attainment with the NAAQS. In addition to the NAAQS described above, a new federal standard for PM_{2.5} and a revised O₃ standard were promulgated in July 1997. The new federal standards were challenged in a court case during 1998.

The court required revisions in both standards before U.S. EPA could enforce them. The U.S. Supreme Court upheld an appeal of the District Court decision in February 2001. Under an interim policy, the preexisting federal PM₁₀ and 1-hour O₃ standards would continue to be implemented for the next several years until any required actions by U.S. EPA were completed. In 1997, EPA established annual and 24-hour NAAQS for PM_{2.5} for the first time. In 2006, the federal annual PM₁₀ standard was revoked by the U.S. EPA due to a lack of evidence linking health problems to long-term exposure to coarse particle pollution. The 3-year average of the 98th percentile of 24-hour PM₁₀ concentrations (35 µg/m³) became effective as the criterion for measuring compliance on December 17, 2006. The State of California has adopted CAAQS that are in some cases more stringent than the federal NAAQS. The NAAQS and CAAQS relevant to the proposed project are summarized in Table 5-1.

The U.S. EPA, the CARB, and the local air pollution control districts determine air quality attainment status by comparing local ambient air quality measurements from the state or local ambient air monitoring stations with the NAAQS and CAAQS. Those areas that meet ambient air quality standards are classified as “attainment” areas; areas that do not meet the standards are classified as “nonattainment” areas. Areas that have insufficient air quality data may be identified as unclassifiable areas. These attainment designations are determined on a pollutant-by-pollutant basis. The proposed project site is designated a federal nonattainment area for O₃ based on air quality monitoring data showing exceedances of the NAAQS. The proposed project vicinity is designated a state nonattainment area for O₃, based on air quality monitoring data showing exceedances of the CAAQS. Table 5-2 presents the attainment status (both federal and state) for Contra Costa County in the BAAQMD.

BAAQMD Regulation 2-2, New Source Review (NSR) requires that the emissions from a new or modified source will not cause a violation of any Federal or State AAQS.

5.2 *Prevention of Significant Deterioration Requirements*

In addition to the ambient air quality standards described above (NAAQS), the federal PSD program has been established to protect deterioration of air quality in those areas that already meet national ambient air quality standards. The BAAQMD has been delegated PSD authority by the EPA. Specifically, the PSD program establishes allowable concentration increases for attainment pollutants due to new emission sources that are classified as major sources. These

ATC/PTO Application Willow Pass Generating Station

increases allow economic growth, while preserving the existing air quality, protecting public health and welfare, and protecting Class I areas (national parks and wilderness areas).

The PSD regulations define a “major stationary source” as any source type belonging to a list of 28 source categories that emits, or has the “potential to emit” 100 tons per year or more of any pollutant regulated under the CAA, or any other source type that has the potential to emit such pollutants in amounts equal to or greater than 250 tons per year. If a source is considered major for PSD purposes because of one pollutant, then PSD review is applicable for those other pollutants emitted from the source in amounts greater than the PSD significance levels. The PSD regulations require major stationary sources to undergo a pre-construction review that includes an analysis and implementation of BACT (see Section 8.0), a PSD increment consumption analysis, an ambient air quality impact analysis (see Section 7.0), and analysis of AQRVs (impacts on visibility and vegetation). The WPGS is subject to these requirements.

The incremental proposed project emissions for SO₂, NO_x, PM₁₀, VOC, and CO are as shown in Table 5-3 and compared with the PSD significance thresholds. The project emissions of NO_x, PM₁₀, VOC, and CO would be above these PSD triggers; thus, the Applicant must demonstrate through modeling (except for VOC for which no AAQS apply) that such emissions will not interfere with the attainment or maintenance of the applicable NAAQS and will not cause exceedances of the applicable PSD increments shown in Table 5-4.

For project emissions of CO that would exceed the trigger levels, the Applicant must demonstrate through modeling that the increase in emissions would not interfere with the attainment or maintenance of the CO NAAQS. Allowable PSD increments for SO₂ and NO_x in Class I and II areas are summarized in Table 5-4.

Point Reyes National Sea Shore is the only Class I area within 100 km of the project site and within the boundary of BAAQMD. All other areas are Class II areas; there are no Class III areas within the BAAQMD. An evaluation of impacts in Class I areas within 100 km (62 miles) of the project is typically conducted when the potential emissions increases from the project would be sufficient to trigger federal PSD requirements. The applicant contacted the National Park Service (NPS) administrator for Point Reyes National Seashore. The NPS has determined that a Class I impact analysis is not required for this project. Specifically, NPS stated, in an e-mail addressed to Ms. Julie Mitchell of URS on April 24, 2008:

“...based on the small amount of emissions by the proposed Pittsburg New Generation Project and the distance to Point Reyes National Seashore, a Class I area administered by the NPS which is approximately 73 km away, the NPS is not requesting that an increment or Air Quality Related Values analysis be performed for the permit.... You can forward this e-mail to the permitting agency.”

5.3 Acid Rain Program Requirements

Title IV of the CAAA applies to sources of air pollutants that contribute to acid rain formation, including certain sources of SO₂ and NO_x emissions. Title IV is implemented by the U.S. EPA under 40 CFR 72, 73, and 75. Allowances of SO₂ emissions are set aside in 40 CFR 73. Sources subject to Title IV are required to obtain SO₂ allowances, to monitor their emissions, and obtain SO₂ allowances when a new source is permitted. Sources such as the proposed project that use pipeline-quality natural gas are exempt from many of the acid rain program requirements. However, these sources must still estimate SO₂ and carbon dioxide (CO₂) emissions, and monitor NO_x emissions with certified CEMS. All subject facilities must submit an acid rain permit application to U.S. EPA within 24 months of commencing operation.

ATC/PTO Application Willow Pass Generating Station

5.4 New Source Performance Standards

New source performance standards (NSPS) have been established by U.S. EPA to limit air pollutant emissions from certain categories of new and modified stationary sources. The NSPS regulations are contained in 40 CFR Part 60 and cover many different industrial source categories. Stationary gas turbines are regulated under Subpart KKKK. The enforcement of NSPS has been delegated to the BAAQMD, and the NSPS regulations are incorporated by reference into the District's Regulation X. In general, local emission limitation rules or BACT requirements in California are far more restrictive than the NSPS requirements. For example, the controlled NO_x emission rate from the project's gas turbines of less than 0.06 pound (lb) of NO_x per MW-hour will be well below the Subpart KKKK requirement of 0.39 lb of NO_x per MW-hour. Similarly, the projected maximum SO₂ emissions from the WPGS gas turbines will be about 0.009 lb of SO₂ per MW-hour, which is substantially less than the Subpart KKKK requirement of 0.58 lb of SO₂ per MW-hour.

NSPS fuel requirements for SO₂ will be satisfied by the use of natural gas, and emissions and fuel monitoring that will be performed to meet the requirements of BACT will comply with NSPS, acid rain, and other regulatory requirements.

5.5 Federally Mandated Operating Permits

Title V of the CAA requires U.S. EPA to develop a federal operating permit program that is implemented under 40 CFR 70. This program is administered by BAAQMD under Regulation II, Rules 6. Permits must contain emission estimates based on potential-to-emit, identification of all emission sources and controls, a compliance plan, and a statement indicating each source's compliance status. The permits must also incorporate all applicable federal, state, or air quality control district orders, rules and regulations. Because the facility will undergo new construction and operations, the proposed project will apply for a new Title V permit.

5.6 Power Plants Siting Requirements

Under the California Environmental Quality Act (CEQA), the CEC has been charged with assessing the environmental impacts of each new power plant and considering the implementation of feasible mitigation measures to prevent potential significant impacts. CEQA Guidelines [Title 14, California Administrative Code, Section 15002(a)(3)] state that the basic purpose of CEQA is to "prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible."

The CEC siting regulations require that, unless certain conditions justifying an override are shown, a new power plant can only be approved if the proposed project complies with all federal, state, and local air quality rules, regulations, standards, guidelines, and ordinances that govern the construction and operation of the proposed project. A project must demonstrate that facility emissions will be appropriately controlled to mitigate significant impacts from the project and that it will not jeopardize attainment and maintenance of the state and federal AAQS. Cumulative impacts, impacts due to pollutant interaction, and impacts from non-criteria pollutants must also be considered.

5.7 Air Toxic "Hot Spots" Program

As required by the California Health and Safety Code Section 44300 (originally Assembly Bill 2588 – Air Toxics "Hot Spots" Information and Assessment Act). This program was created in 1987 to develop a statewide inventory of air toxics emissions from stationary sources. Applicable facilities must prepare the following: (1) an emissions inventory plan identifying air toxics; (2) an emission inventory report quantifying air toxics emissions; and (3) a health risk

ATC/PTO Application Willow Pass Generating Station

assessment, if air toxics emissions are at high levels. Facilities whose air toxics pose a significant health risk must also prepare and implement risk reduction plans. This requirement is applicable only after the start of operations. Section 9.0, Public Health, indicates that air toxics impacts from the proposed project would be insignificant.

5.8 New Source Review Requirements

NSR rules establish the criteria for siting new and modified emission sources. BAAQMD has been delegated authority for NSR rule development and enforcement; the district's NSR rules are contained in Regulation 2, Rule 2. There are three basic requirements within NSR rules. First, BACT must be applied to any new source that emits above specified threshold quantities (see Section 8.0). Second, all potential increases from the sources above must be offset by real, quantifiable, surplus, permanent, and enforceable emission decreases in the form of emission reduction credits (ERCs) (see Section 6.0). Third, ambient air quality impact assessment must be conducted to confirm that the proposed WPGS project does not cause or contribute to a violation of federal or California AAQS (see Section 7.0) or jeopardize public health (see Section 9.0)

5.9 Bay Area Air Quality Management District Requirements

The following paragraphs outline the BAAQMD rules and regulations that apply to the proposed project:

Regulation I—General Provisions and Definitions

Regulation I, Section 301 – Public Nuisance

The releases of air contaminants anticipated under the proposed project are not expected to “cause injury, detriment, nuisance or annoyance to any considerable number of persons or the public.” In addition, none of the proposed project's sources of air contaminants are expected to endanger “the comfort, repose, health or safety of any such persons or the public, or cause injury or damage to business or property.” The air quality impact analysis is designed to ensure that the proposed project will not cause any public nuisance.

Regulation II—Permits

Regulation II, Rule 1, Sections 301 and 302—Authority to Construct and Permit to Operate

Mirant Willow Pass, LLC will submit an application to the district to obtain an ATC and PTO for the combustion gas turbines.

Regulation II, Rule 2—New Source Review

The purpose of this rule is to provide for the review of new and modified sources and provide mechanisms.

Regulation 2, Rule 2, Section 301 (“Best Available Control Technology Requirement”) requires BACT for a new or modified sources that have the potential to emit 10 pounds or more per highest day of VOCs, non-precursor organic compounds (NPOC), NO_x, SO₂, PM₁₀, or CO.

Regulation 2, Rule 2, Section 302 (“Offset Requirements, Precursor Organic Compounds and Nitrogen Oxides”) stipulates that federally enforceable emission offsets are required for VOC and NO_x emission increases from permitted sources which will emit more than 35 tons per year or more on a pollution-specific basis. For these facilities that emit more than 35 tons per year or more of NO_x or VOC, offsets are provided at a ratio of 1.15 to 1.0. The project is expected to emit more than 35 tons per year of NO_x and VOC, so emission offsets would be provided as necessary. Section 303 (“Offset Requirement, PM₁₀ and Sulfur Dioxide”) stipulates that emission offsets would be provided at a ratio of 1:1 for facilities that will result in a cumulative increase

ATC/PTO Application Willow Pass Generating Station

minus any contemporaneous emission reduction credits at the facility, in excess of 1.0 ton per year of PM₁₀ or sulfur dioxide. The facility is expected to emit greater than 100 tons per year of PM₁₀, so emission offsets will be provided per this regulation. However, the facility is expected to release less than 100 tons per year of SO₂, so no emission offsets are required for this pollutant. Details of emission offset strategy are given in Section 6.0.

Pursuant to Regulation 2-2-414-1 (“PSD Air Quality Analysis”), air quality analysis was performed including meteorological and topographic data for the proposed project. This analysis includes ensuring that the emission increases caused by the facility will not cause or contribute to a violation of an air quality standard or an exceedance of any applicable PSD increment. The methodology and the results obtained from this modeling are presented in Section 7.0.

Pursuant to Regulation 2-2-417 (“Visibility, Soils, and Vegetation Analysis”), an analysis of the impairment to visibility, soils and vegetation that would occur as a result of the new or modified source and the general commercial, residential, industrial and other growth associated with the source or modification needs to be submitted with the application. The applicant need not provide an analysis of the impact on vegetation if it has no significant commercial or recreational value. Analysis of visual impacts is discussed in Section 7.0.

Regulations 2-2-304 and 2-2-305 (“PSD Requirements” and “Carbon Monoxide Modeling Requirement”) specify the incremental emission triggers for SO₂, NO_x, PM₁₀, and CO. For project emissions of SO₂, NO_x, or PM₁₀ above these PSD triggers, the applicant must demonstrate through modeling that no air quality standard will be exceeded. For project emissions of CO which exceed the trigger levels, the applicant must demonstrate through modeling that the increase in emissions will not interfere with the attainment or maintenance of the CO NAAQS. Section 7.0, discusses these PSD requirements further.

Regulation 2, Rule 3, (“Power Plants”) contains procedures for the review and standards for the approval of authorities to construct power plants. This regulation will be complied with through the submittal of a stand alone application for an Authority to Construct to BAAQMD.

Pursuant to Regulation 2, Rule 7 (“Acid Rain”), the gas turbine units will be subject to the requirements of Title IV of the Federal Clean Air Act. Allowances of SO₂ emissions are set aside in 40 CFR 73. See Section 5.3 for a discussion of compliance.

Regulation III–Fees

Regulation III identifies the fees that are applicable to permit modifications, new facilities, and permitted emissions. The required fees will be submitted with the application for Permit to Construct/Permit to Operate in compliance with this rule.

Regulation VI–Particulate Matter and Visible Emissions

The proposed project will utilize the following to minimize the release of particulate matter and diminish the visibility of emissions:

- Ultra low-NO_x burner technology and proper combustion practices;
- Natural gas as the combustion fuel for the proposed gas turbines; and

The emission sources of the project are expected to comply with the standards set forth in Regulation 6:

- No visible emission from any of the sources will be as dark or darker than No. 1 on the Ringelmann Chart, or of such opacity as to obscure an observer's view to an equivalent

ATC/PTO Application Willow Pass Generating Station

or greater degree for a period more of than three minutes in any hour (Regulation 6, Section 301);

- No visible emission from any of the sources will be equal to or greater than 20 percent opacity as perceived by an opacity sensing device for a period of more than three minutes in any hour (Regulation 6, Section 302);
- No emission from any of the sources will contain particulate matter in excess of 0.15 grains per dry cubic foot of exhaust gas volume (Regulation 6, Section 310).

Calculated in accordance with Regulation 6-310.3, the worst-case grain loading from operation of the turbines was calculated to be less than 0.05 grains per dry standard cubic foot of exhaust gas. Therefore, the grain loading from the turbines is expected to be in compliance with this regulation. Particulate matter associated with the construction of the facility is exempt from district permit requirements but is subject to Regulation 6. It is expected that the CEC will impose conditions on construction activities that will require the use of water or chemical dust suppressants to minimize PM₁₀ emissions and prevent visible particulate emissions.

Regulation VII–Odorous Substances

Regulation 7, Rule 302 prohibits the discharge of any odorous substances which remain odorous at the property line after dilution with four parts of odor-free air. Regulation 303 prohibits the discharge of ammonia in concentrations greater than 5,000 ppm. Because the ammonia emissions from the SCR units will be limited to 5 ppmvd for the combined cycle units at 15 percent O₂, the proposed project is expected to be in compliance with this regulation.

Regulation VIII–Organic Compounds

This regulation limits the emission of organic compounds to the atmosphere. The proposed project is exempt from this regulation per 8-2-110 because natural gas is the only fuel used in the project. Solvents used in cleaning and maintenance are expected to comply with Regulation 8, Rule 4, by emitting less than 5 tpy of VOCs.

Regulation IX–Inorganic Gaseous Pollutants

This regulation emission limits for various compounds.

Regulation 9, Rule 1, “Sulfur Dioxide”: Section 301 (“Limitations on Ground Level Concentrations”) limits SO₂ emissions to 0.5 ppm continuously for 3 consecutive minutes, 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours. Modeling results indicate that the maximum concentration of SO₂ released in one hour result in ground level concentrations less than 3 ppb. Section 302 (“General Emission Limitation”) prohibits emissions from a gas stream containing SO₂ in excess of 300 ppm (dry). Expected emissions of SO₂ are not expected to exceed 20 ppm.

Regulation 9, Rule 9, “Nitrogen Oxides from Stationary Gas Turbines”: General emission limits in 9-9-301.3 states that gas turbines rated at 10.0 MW and over, with SCR, shall not exceed 9 ppmv, except that, for non-gaseous fuel firing during natural gas curtailment or short testing periods, the limit is 25 ppmv. The project turbines are expected to comply with this rule.

**ATC/PTO Application
Willow Pass Generating Station**

**Table 5-1
National and California Ambient Air Quality Standards**

Pollutant	Averaging Time	NAAQS ¹		CAAQS ²
		Primary ^{3,4}	Secondary ^{3,5}	Concentration ³
Ozone (O ₃)	1-Hour	Revoked ⁸	Same as Primary Standard	0.09 ppm (180 µg/m ³)
	8-Hour	0.075 ppm		0.07 ppm (137 µg/m ³)
Carbon Monoxide (CO)	8-Hour	9 ppm (10 mg/m ³)	None	9.0 ppm (10 mg/m ³)
	1-Hour	35 ppm (40 mg/m ³)		20 ppm (23 mg/m ³)
Nitrogen Dioxide (NO ₂) ⁹	Annual Average	0.053 ppm (100 µg/m ³)	Same as Primary Standard	0.030 ppm (57 µg/m ³)
	1-Hour	-		0.18 ppm (339 µg/m ³)
Sulfur Oxides (SO ₂)	Annual Average	0.03 ppm (80 µg/m ³)	-	-
	24-Hour	0.14 ppm (365 µg/m ³)	-	0.04 ppm (105 µg/m ³)
	3-Hour	-	0.5 ppm (1300 µg/m ³)	-
	1-Hour	-	-	0.25 ppm (655 µg/m ³)
Suspended Particulate Matter (PM ₁₀)	24-Hour	150 µg/m ³	Same as Primary Standard	50 µg/m ³
	Annual Arithmetic Mean	Revoked ⁶		20 µg/m ³
Fine Particulate Matter (PM _{2.5}) ⁷	24-Hour	35 µg/m ³	Same as Primary Standard	-
	Annual Arithmetic Mean	15 µg/m ³		12 µg/m ³
Lead (Pb)	30-Day Average	-	-	1.5 µg/m ³
	Quarterly Average	1.5 µg/m ³	Same as Primary Standard	-
Hydrogen Sulfide (HS)	1-Hour	No Federal Standards		0.03 ppm (42 µg/m ³)
Sulfates (SO ₄)	24-Hour			25 µg/m ³
Visibility Reducing Particles	8-Hour (10 am to 6 pm, Pacific Standard Time)			In sufficient amount to produce an extinction coefficient of 0.23 per kilometer due to particles when the relative humidity is less than 70 percent.

µg/m³ = micrograms per cubic meter; mg/m³ – milligram per cubic meter; ppm – parts per million

Source: U.S. EPA-NAAQS (<http://www.epa.gov/air/criteria.html>); CARB-CAAQS (<http://www.arb.ca.gov/aqs/aaqs2.pdf>)

¹. National standards (other than ozone, particulate matter, and those based on annual averages or annual arithmetic mean) are not to be exceeded more than once a year. The ozone standard is attained when the fourth highest 8-hour concentration in a year, averaged over 3 years, is equal to or less than the standard. For PM₁₀, the 24-hour standard is attained when the expected number of days per calendar year with a 24-hour average concentration above 150 µg/m³ is equal to or less than one. For PM_{2.5}, the 24-hour standard is attained when 98 percent of the daily concentrations, averaged over 3 years, are equal to or less than the standard. Contact U.S. EPA for further clarification and current federal policies.

². California standards for ozone, carbon monoxide (except Lake Tahoe), sulfur dioxide (1 and 24 hour), nitrogen dioxide, suspended particulate matter—PM₁₀, PM_{2.5}, and visibility-reducing particles, are values that are not to be exceeded. All others are not to be equaled or exceeded. California ambient air quality standards are listed in the Table of Standards in Section 70200 of Title 17 of the California Code of Regulations.

³. Concentration expressed first in units in which it was promulgated. Equivalent units given in parentheses are based upon a reference temperature of 25°C and a reference pressure of 760 torr. Most measurements of air quality are to be corrected to a reference temperature of 25°C and a reference pressure of 760 torr; ppm in this table refers to ppm by volume, or micromoles of pollutant per mole of gas.

⁴. National Primary Standards: The levels of air quality necessary, with an adequate margin of safety to protect the public health.

⁵. National Secondary Standards: The levels of air quality necessary to protect the public welfare from any known or anticipated adverse effects of a pollutant.

⁶. Due to a lack of evidence linking health problems to long-term exposure to coarse particle pollution, the agency revoked the annual PM₁₀ standard in 2006 (effective December 17, 2006).

⁷. To attain this standard, the 3-year average of the 98th percentile of 24-hour concentrations at each population-oriented monitor within an area must not exceed 35 µg/m³ (effective December 17, 2006)

⁸. On June 15, 2005, the 1-hour ozone standard (0.12 ppm) was revoked for all areas except the 8-hour ozone nonattainment Early Action Compact Areas (EAC) areas.

ATC/PTO Application
Willow Pass Generating Station

Table 5-2		
Attainment Status for Contra Costa County with Respect to Federal and California Ambient Air Quality Standards		
Pollutant	Federal Attainment Status	State Attainment Status
Ozone	Nonattainment	Nonattainment
CO	Unclassified/Attainment	Attainment
NO ₂	Unclassified/Attainment	Attainment
SO ₂	Attainment	Attainment
PM ₁₀	Unclassified	Nonattainment
PM _{2.5}	Unclassified/Attainment	Nonattainment
Lead	Unclassified	Attainment

Source: National Area Designations and Proposed 2006 State Area Designations, CARB (<http://www.arb.ca.gov/desig/adm/adm.htm>)

Notes:
CO = carbon monoxide
NO₂ = nitrogen dioxide
SO₂ = sulfur dioxide
PM₁₀ = particulate matter less than 10 microns in diameter
PM_{2.5} = particulate matter less than 2.5 microns in diameter

Table 5-3			
PSD Emission Threshold Triggers for New Stationary Sources			
Pollutant	Significant Thresholds (tpy)	Project Emissions (tpy)	PSD Triggered by Project?
CO	100	142.78	Yes
SO ₂	40	10.51	No
NO _X	40	77.43	Yes
PM ₁₀	15	39.43	Yes
VOCs	40	28.53	No

Source: BAAQMD rule 2 (<http://www.baaqmd.gov/dst/regulations/rg0202.pdf>)
Project emissions include all emissions from natural gas.

Notes:
tpy = tons per year
CO = carbon monoxide
SO₂ = sulfur dioxide
NO_X = nitrogen oxide(s)
PM₁₀ = particulate matter less than 10 microns in diameter
VOCs = volatile organic compounds

ATC/PTO Application
Willow Pass Generating Station

Table 5-4		
Allowable PSD Increments for SO₂, NO₂, and PM₁₀		
Pollutant	Averaging Times	Maximum Allowable Increase (Micrograms Per Cubic Meter)
Class I		
PM ₁₀	PM ₁₀ Annual arithmetic mean	4
	PM ₁₀ 24-hr maximum	8
SO ₂	Annual arithmetic mean	2
	24-hr maximum	5
	3-hr maximum	25
NO ₂	Annual arithmetic mean	2.5
Class II		
PM ₁₀	PM ₁₀ Annual arithmetic mean	17
	PM ₁₀ 24-hr maximum	30
SO ₂	Annual arithmetic mean	20
	24-hr maximum	91
	3-hr maximum	512
NO ₂	Annual arithmetic mean	25
Source: BAAQMD rule 2 (http://www.baaqmd.gov/dst/regulations/rg0202.pdf) Notes: NO ₂ = nitrogen dioxide PM ₁₀ = particulate matter less than 10 microns in diameter SO ₂ = sulfur dioxide		

**ATC/PTO Application
Willow Pass Generating Station**

6.0 EMISSION OFFSETS

Per Bay Area Air Quality Management District Regulations 2-2-215, 302, and 303, the project is required to provide emission offsets in the form of emissions reduction credits (ERC) for increases in emissions of nonattainment pollutants in excess of specified thresholds that will result from the operation of the proposed facility on a pollutant-specific basis. Per District Regulations 2-2-302 VOC and NO_x ERCs are required to be provided at an offset ratio of 1.0:1.0 or 1.15:1.0, depending on the amount of emissions levels. Since both VOC and NO_x are ozone precursors, Regulations 2-2-302.2 allows ERCs of VOCs to be used as an inter-pollutant offset for NO_x, at the required offset ratios.

Sections 2-2-304 and 2-2-305 impose emissions offset requirements, or require project denial, if SO₂, NO₂, PM_{10/2.5}, or CO air quality modeling results indicate emissions will either interfere with the attainment or maintenance of the applicable AAQS, or exceed PSD increments. The modeling analyses show that facility emissions will not interfere with the attainment or maintenance of the applicable air quality standards.

For major sources subject to PSD review, Regulation 2-2-305 requires an applicant to either demonstrate through modeling that its emissions will comply with the CO AAQS, or provide contemporaneous emission offsets. The modeling analysis presented in Section 7.0 of this application demonstrates that the proposed project will not cause a violation of any applicable CO ambient air quality standard. Therefore, CO emission offsets are not required.

Mirant California emission offsets inventory and estimated required ERCs due to project operations are shown in Table 6-1 and Table 6-2, respectively. As demonstrated in these tables, Mirant California is in possession of sufficient emission reduction credits to provide the required emission offsets for the WPGS project, as well as the Marsh Landing Generating Station (MLGS) project, for which an ATC/PTO application was recently submitted to BAAQMD.

**ATC/PTO Application
Willow Pass Generating Station**

Certificate No	756	831	863	918	Total
VOC (tons/yr)	0.390	72.280	5.300	0.000	77.970
NO_x (tons/yr)	1.173	66.060	247.500	171.000	485.733
SO₂ (tons/yr)	0.000	0.000	130.179	0.000	130.179
CO (tons/yr)	14.602	450.600	114.000	0.000	579.202
PM₁₀ (tons/yr)	6.443	202.530	25.270	0.000	234.243
Issued Date	19-Jul-01	28-Aug-02	16-Jan-03	17-Mar-04	
Application No.	1000	5800	6925	9283	
Source Location	Hudson ICS	Crown Zellerbach Corporation	Pacific Gas & Electric Company	Crown Zellerbach Corporation	
	San Leandro, CA	Antioch, CA	Martinez, CA	Antioch, CA	

Source: BAAQMD Emission Bank Status Web Page http://www.baaqmd.gov/pmt/emissions_banking/banking.htm

Pollutant	Total WPGS Potential Emissions (ton/yr)	New Source Review Offset Ratio	Offsets Required (ton/yr)	Current ERC Holdings (ton/yr)	Holdings After Offsets for Marsh Landing Generating Station are Deducted (ton/yr)	Holdings After Offsets for Marsh Landing and Willow Pass Generating Stations are Deducted (ton/yr)
NO _x	78.6	1.15	90.39	485.7	375.7	285.34
CO	142.78	0	0	579.2	579.2	579.2
VOC	28.53	1.15	32.8095	78.0	38.3	5.49
SO ₂	10.51	1	10.51	130.2	117.7	107.19
PM ₁₀	39.43	1	39.43	234.2	187.8	148.37

Notes:
Notes
Offset ratios are 1.15 to 1 for NO_x and VOC emissions on a pollutant specific basis, for each pollutant (facility wide) over 35 tons per year. Below 35 tons, the ratio is 1 to 1.
Offset ratios are 1 to 1 for remaining criteria pollutants.
0.4 gr/100 scf annual average natural gas sulfur used in annual SO₂ emission calculations

7.0 AMBIENT AIR QUALITY AND PSD ANALYSIS

7.1 *Air Dispersion Modeling*

The purpose of the air quality impact analysis is to evaluate whether criteria pollutant emissions resulting from the proposed project would cause or contribute significantly to a violation of a CAAQS or NAAQS, or contribute significantly to degradation of air quality–related values in Class I areas. Mathematical models designed to simulate the atmospheric transport and dispersion of airborne pollutants are used to quantify the maximum expected impacts of project emissions for comparison with applicable regulatory criteria. Air quality impacts from WPGS operations would be associated with natural gas combustion in the CTG units and the fuel gas preheater.

The air quality modeling methodology described in this section has been documented in a formal modeling protocol, which has been submitted for comments to CEC and BAAQMD. The modeling approaches used to assess various aspects of the proposed project’s potential impacts to air quality incorporate the District’s recommendations and are discussed below.

7.1.1 Model and Model Option Selections

The impacts of project operations emissions on criteria pollutant concentrations in the area adjacent to the proposed project site were evaluated using the AERMOD dispersion model (Version 07026). AERMOD is appropriate because it has the ability to assess dispersion of emission plumes from multiple point, area, or volume sources in flat, simple, and complex terrain, while utilizing sequential hourly meteorological input data. The regulatory default options were used, including building and stack tip downwash, default wind speed profiles, exclusion of deposition and gravitational settling, consideration of buoyant plume rise, and complex terrain.

For the AERMOD simulations to evaluate impacts due to turbine commissioning and normal facility operational emissions on NO₂ concentrations, the ozone-limiting method option of the model was used to take into account the role of ambient ozone in limiting the conversion of emitted NO_x (which occurs mostly in the form of NO) to NO₂, the pollutant regulated by ambient standards. The input data to the AERMOD-OLM model includes representative hourly ozone monitoring data for the same years corresponding to the meteorological input record. These simulations used the ozone data from the BAAQMD Pittsburg 10th Street monitoring station for the years 2002-2005 (i.e., the same years for which meteorological data were input for the AERMOD simulations).

To evaluate whether urban or rural dispersion parameters should be used in the model simulations, an analysis of land uses adjacent to the proposed project site was conducted in accordance with Section 8.2.8 of the *Guideline on Air Quality Models* (U.S. EPA, 2003), *Correlation of Land Use and Cover with Meteorological Anomalies* (Auer, 1978), AERMOD implementation guide (U.S. EPA, 2005), and its addendum (U.S. EPA, 2006a). Based on the Auer land use classification procedure, more than 50 percent of the area within a 1.86-mile (3-kilometer) radius of the proposed project site is appropriately classified as rural. Thus, according to the U.S. EPA AERMOD implementation guide, AERMOD’s rural option was selected. Land use parameter values utilized for processing the onsite Pittsburg meteorological data are discussed in the Meteorological Data section.

ATC/PTO Application

Willow Pass Generating Station

7.1.2 Building Wake Effects

The effects of building wakes (i.e., downwash) on the plumes from the proposed project's CTGs and fuel preheater were evaluated in the modeling for operational emissions, in accordance with U.S. EPA guidance (U.S. EPA, 1985). Location coordinates and dimensions of the buildings within new and existing areas of the site that could potentially cause plume downwash effects for the new stacks were determined for different wind directions using the U.S. EPA Building Profile Input Program – Prime (BPIP-Prime) (Version 04274). The following existing and new structures were identified within the proposed project site to be included in the downwash analysis (the number of multiple identical structures are denoted with parenthesis):

- CTG-HRSGs (2)
- Air-cooled heat exchangers (2)
- Gas turbine inlet filters (2)
- Waste water storage tank
- Nitrified water storage tank
- Reverse Osmosis permeate storage tank
- Demineralized water storage tank
- Raw water storage tank
- Existing Unit 5 turbine generator
- Existing Unit 6 turbine generator
- Existing Units 5 and 6 boiler structures
- Existing Unit 7 turbine generator
- Existing Unit 7 boiler structure
- Existing Fuel Oil Tanks 1 through 6

The results of the BPIP-Prime analysis were included in the AERMOD input files to enable downwash effects to be simulated. Input and output electronic files for the BPIP-Prime analysis are included with those from all other dispersion modeling analyses in a CD accompanying this application package.

7.1.3 Meteorological Data

Onsite meteorological data have been collected on the western edge of the PPP property by PG&E for a number of years. Excellent data capture was achieved for the years 2002 through 2005, and thus these years were selected to create the AERMET input data file. The PG&E data were collected within the boundary of the PPP at the western end of the cooling tower island in the cooling pond, approximately 2.5 kilometers west of the WPGS turbines, and meet the U.S. EPA criteria for representativeness (U.S. EPA, 1995), as follows:

- **Proximity.** The data were collected within the PPP property boundary, and thus meet the criterion for proximity.
- **Complexity of Terrain and Exposure of Meteorological Monitoring Site.** Both the project site and the meteorological station are located on the southern bank of Suisun Bay and are the same distances from prominent terrain features in the surrounding area.
- **Period of Data Collection.** The 2002 through 2005 data set represents data collection over 4 years. Although only 1 year of onsite data is required for use in regulatory modeling under EPA guidelines, a 4-year data set was used to better

ATC/PTO Application Willow Pass Generating Station

represent project site conditions, as well as to capture worst-case meteorological conditions.

- **Data Quality.** The PG&E meteorological station was audited regularly to ensure that quality data were collected.

In accordance with the U.S. EPA meteorological monitoring guidance for regulatory modeling applications (U.S. EPA, 2000), meteorological instruments should be sited far enough from obstructions that these obstructions would not influence the meteorological parameter measured. If a meteorological tower is sited too close to a building, aerodynamic effects may influence the wind data collected, and if temperature measurements are too near paving, rooftops, or industrial heat sources, excessively high temperatures may be measured. The PG&E meteorological tower was sited near enough to the project sources to be representative, yet far enough not to be inappropriately influenced by the industrial site.

Onsite hourly data include wind speed, wind direction, standard deviation of the horizontal wind, and temperature for years 2002 through 2005.

In processing the data for input into AERMOD, additional parameters typically not collected at site-specific stations are required; thus, the PPP onsite data have been supplemented with data from the nearest National Weather Service (NWS) station. Surface data were obtained from the Concord Buchanan Field Airport for the same years as the onsite data -- 2002 through 2005. This station is approximately 15 kilometers southwest of the project site and is surrounded by suburban areas, in rolling terrain. The terrain immediately surrounding the project site can also be categorized as suburban with rolling hills; thus, the land use and the location with respect to near-field terrain features are similar. Cloud cover information from Concord Buchanan Field Airport were used in the WPGS modeling analysis; however, per BAAQMD guidance, Concord surface winds were not substituted for missing hours in the PPP onsite meteorological data sets.

The Oakland Airport upper air data monitoring station is approximately 45 kilometers southwest of the project. This is the closest upper air station and was determined the most representative upper air data available for use in this modeling analysis. The MODIFY option was used for AERMET processing of the Oakland upper air data to perform some preliminary quality control as the data were extracted.

Representative surface moisture inputs were determined for each month of every year using Antioch Pump Plant 3 meteorological station precipitation data, and use of the percentile method specified in the AERSURFACE User's Guide. The surface moisture determinations provided by BAAQMD are shown in Table 7-1. Months assigned to each season were as follows: Spring – February and March; Summer – April through July; Autumn – August through October; Winter (not receiving continuous snow cover) – November through January. Figure 7-1 presents the annual windrose based on the 2002-2005 PPP onsite meteorological data.

Two different sets of meteorological input data were processed each with different surface characteristics, per BAAQMD recommendation. The first set of meteorological data is described as “Set A”, while the second set of meteorological data is described as “Set B”. The following paragraphs describe how each data set was processed.

Set A meteorological data uses the AERSURFACE program to calculate the surface roughness from the land cover data for a 1-kilometer radius around the PPP meteorological tower and the Albedo and Bowen ratio values over a 10- by 10-kilometer area around the meteorological tower, adhering to the recommendations from the AERMOD Implementation Guide (U.S. EPA, 2008).

ATC/PTO Application Willow Pass Generating Station

The land uses surrounding the PG&E meteorological station were split into 2 categories, water with scattered wetlands to the north and suburban residential to the south. The AERSURFACE model was used to determine the surface characteristics from land cover data from United States Geological Survey (USGS). The seasonal output obtained for the surface characteristics for both sectors, dependent on average, wet, or dry surface moisture conditions, are presented in Table 7-2.

Set B meteorological data uses the AERSURFACE program to calculate the surface roughness from the land cover data for a 1-kilometer radius around the new WPGS turbines, as recommended by BAAQMD. Albedo and Bowen ratio values were determined over a 10- by 10-kilometer area around the new WPGS FP10 turbines and the land uses surrounding the turbines were split into 3 categories, also per BAAQMD guidance. The seasonal output obtained for the surface characteristics for all sectors, dependent on average, wet, or dry surface moisture conditions, are presented in Table 7-3.

7.1.4 Receptor Locations

The receptor grids used in the AERMOD modeling analyses described in this protocol for operational sources were as follows:

- 25-meter spacing along the WPGS fence line and extending from the fence line out to 100 meters beyond the PPP property line;
- 100-meter spacing from 100 m to 1 km beyond the property line;
- 500-meter spacing within 1 to 5 km of property line; and
- 1,000-meter spacing within 5 to 10 km of property line.

Figures 7-2 and 7-3 show the placement of near-field and far-field model receptor points, respectively. Within the grid portions with 500-meter and 1,000-meter spacing 3 to 6 km from the property line, it was determined that a tighter 250-meter and 25-meter spaced receptor grid would best cover the hills southwest of the project. Terrain heights at receptor grid points were determined from USGS digital elevation model (DEM) files. In the course of the refined modeling analysis to evaluate operational project emissions, when a maximum predicted concentration for a particular pollutant and averaging time was predicted within a portion of the receptor grid with spacing greater than 25 meters, a supplemental dense receptor grid was placed around the original maximum concentration point and the model was rerun. The dense grid used 25-m spacing and extended to the next grid point in all directions from the original point of maximum concentration. Terrain heights specifically corresponding to the supplementary grid points were determined from the USGS DEM files in the same manner as for the original receptors.

Due to the large computational time required to run AERMOD for multiple sources and 4 years of hourly meteorological input data, this receptor grid, with the additional dense nested grid points when required, was determined to best balance the need to predict maximum pollutant concentrations and allow all operational modeling runs to be completed within a reasonable period of time.

7.1.5 Turbine Impact Screening Modeling

Screening modeling analyses were performed to determine which CTG operating modes and stack parameters would produce the worst-case offsite impacts (i.e., maximum ground-level concentrations for each pollutant and averaging time). Screening modeling was performed for the two FP10 CTGs only, as these are by far the most important emission sources of the operational

ATC/PTO Application Willow Pass Generating Station

project. The screening model was accomplished with AERMOD, as described in the previous sections, using the same building wake information, receptor grid, and both the Set A and Set B 4 year meteorological data records as described above.

The AERMOD screening model simulation examined impacts due to the CTG emissions from two FP10 combined-cycle CTGs releasing emissions from separate 21.3 foot-diameter (6.5 m), 150.5 foot-tall (45.9 m) stacks.

The turbine stacks were modeled as point sources at their proposed locations within the project site. Tables 7-4 and 7-5 summarize separate CTG screening results for different CTG operating loads and ambient temperature conditions based on both Set A and Set B meteorological data, respectively. First, the model was run with unit emissions (1.0 grams per second) from each stack to obtain normalized concentrations that are not specific to any pollutant. CTG/HRSG vendor data used to derive the stack parameters for the different operating conditions evaluated in this screening analysis are included in Appendix C.

The maximum ground-level concentrations predicted to occur offsite with the unit turbine emission rates for each of the 12 operating conditions shown in Tables 7-4 and 7-5 were then multiplied by the corresponding turbine mass emission rates for specific pollutants. The highest resulting ground-level concentration values for each pollutant and averaging time were then identified (see bolded values in the tables).

The stack parameters associated with these maximum predicted impacts were used in all subsequent simulations of the refined AERMOD analyses described in the next subsection. Screening with both Set A meteorological data and Set B meteorological data resulted in identical stack parameters associated with the maximum predicted impacts. Therefore, the turbine stack parameters used in refined AERMOD analyses for each meteorological data set were the same. Note that the lower exhaust temperatures and flow rates at reduced turbine loads correspond to reduced plume rise, in some cases resulting in higher offsite pollutant concentrations than the higher base load emissions. Model input and output files for the screening modeling analyses are included on a CD accompanying this application package.

1-Hour Startup Scenarios

The worst-case 1-hour NO₂ and CO impacts would occur during an hour that includes startups for both FP10 turbines. Thus, the results of the screening analysis were not used to determine the turbine stack parameters used in the simulations to evaluate maximum 1-hour impacts for these pollutants. The results provided in Table 7-6 indicate that maximum hourly NO₂ and CO concentrations during normal operations would occur with the stack parameters corresponding to full-load operations. However, the magnitudes of the emissions for both pollutants during the worst-case 60 minutes of a two-turbine startup sequence would be higher than those during normal operations at any ambient temperature condition. Since a startup is a transition from non-operation to full-load operation, the stack exhaust velocity and temperature during most of this event are lower than the values indicated as “worst-case” by the turbine screening modeling. Accordingly, modeling simulations were conducted to estimate the maximum 1-hour NO₂ and CO concentrations based on a turbine startup scenario with reduced stack exhaust velocity and temperature.

7.1.6 Refined Modeling

A refined modeling analysis was performed to estimate offsite criteria pollutant impacts from operational emissions of the proposed project. The modeling was performed as described in the previous sections, using 4 years of hourly meteorological input data. The FP10 units were

ATC/PTO Application

Willow Pass Generating Station

modeled assuming the worst-case emissions corresponding to each averaging time and the turbine stack parameters that were determined in the turbine screening analysis (see above). The maximum mass emission rates that would occur over any averaging time, whether during turbine startups, normal operations, turbine shutdowns, or a combination of these activities, were used in all refined modeling analyses (see Table 7-7). Emission rate calculations and assumptions used for all pollutants and averaging times are documented in Appendix C.

7.1.7 Fumigation Analysis

Fumigation may occur when a plume that was originally emitted into a stable layer of air is mixed rapidly to ground level when unstable air below the plume reaches plume height. Fumigation can cause relatively high ground-level concentrations for some elevated point sources during either the breakup of the nocturnal radiation inversion by solar warming of the ground surface (inversion breakup fumigation), or by the transport of pollutants from a stable marine environment to an unstable onshore environment (shoreline fumigation). The transition from stable to unstable surroundings can rapidly draw a plume down to ground level and create relatively high pollutant concentrations for a short period. In general, this phenomenon will be transient, seldom persisting for as long as an hour. Typically, a fumigation analysis is conducted using SCREEN3 when the project site is rural and the stack height is greater than 10 meters.

The SCREEN3 model was used to calculate concentrations from both inversion breakup fumigation and shoreline fumigation. A unit emission rate was used (1 gram per second) in the fumigation modeling to represent the project emissions and the model results were scaled to reflect expected plant emissions for each pollutant. To calculate the inversion breakup fumigation, the default thermal internal boundary layer (TIBL) factor of 6 in the SCREEN3 model was used. For shoreline fumigation, a range of TIBL factors, 2, 4, and 6, were used to determine the highest impact. BAAQMD provided a modified version of SCREEN3 that allows the input of various TIBL factors.

Ground-level concentrations in simple terrain, from the breakup of nocturnal and shoreline inversion for the FP10 turbines, were estimated. SCREEN3 was also run to calculate the shoreline fumigation concentrations from the fuel gas heater, but it was determined that the plume height from this source was below the TIBL. Therefore, no shoreline fumigation calculation was made for the heater. No inversion fumigation was calculated for this source, because the fuel gas heater stack height is less than 10 meters. Only the ground-level concentration in simple terrain was estimated by SCREEN3 for the fuel gas heater. The peak nocturnal inversion concentration and simple terrain concentration for the FP10 turbines were estimated and combined following the U.S. EPA stationary source screening procedures (U.S. EPA, 1992) to determine the 3-, 8-, and 24-hour average concentrations. Then the peak fuel gas heater concentration was added to determine the maximum potential impact due to fumigation from project emissions.

SCREEN3 predicted the peak concentration from nocturnal inversion fumigation from project emissions to be as follows:

- 12.02 $\mu\text{g}/\text{m}^3$ for NO_2 1-hr;
- 1.62 $\mu\text{g}/\text{m}^3$ for SO_2 1-hr;
- 1.40 $\mu\text{g}/\text{m}^3$ for SO_2 3-hour;
- 0.58 $\mu\text{g}/\text{m}^3$ for SO_2 24-hour;
- 51.34 $\mu\text{g}/\text{m}^3$ for CO 1-hr;
- 14.67 $\mu\text{g}/\text{m}^3$ for CO 8-hr; and
- 0.81 $\mu\text{g}/\text{m}^3$ for $\text{PM}_{10}/\text{PM}_{2.5}$.

ATC/PTO Application Willow Pass Generating Station

The peak pollutant concentrations from the shoreline inversion fumigation analysis from project emissions were predicted to be the following:

45.83 $\mu\text{g}/\text{m}^3$ for NO_2 1-hr;
7.47 $\mu\text{g}/\text{m}^3$ for SO_2 1-hr;
4.04 $\mu\text{g}/\text{m}^3$ for SO_2 3-hour;
0.72 $\mu\text{g}/\text{m}^3$ for SO_2 24-hour;
293.62 $\mu\text{g}/\text{m}^3$ for CO 1-hr;
25.87 $\mu\text{g}/\text{m}^3$ for CO 8-hr; and
1.03 $\mu\text{g}/\text{m}^3$ for $\text{PM}_{10}/\text{PM}_{2.5}$.

7.2 Compliance with Ambient Air Quality Standards and PSD Requirements

Air dispersion modeling was performed according to the methodology described in Section 7.1 to evaluate the maximum increase in ground-level pollutant concentrations resulting from project emissions, and to compare the maximum predicted impacts, including background pollutant levels, with applicable short-term and long-term CAAQS and NAAQS. The same 4-year record of hourly meteorological data was used in the AERMOD modeling to evaluate the operational impacts.

In evaluating the operational impacts, the AERMOD model was used to predict the increases in criteria pollutant concentrations at all receptor concentrations due to project emissions only. Next, the maximum modeled incremental increases for each pollutant and averaging time were added to the maximum background concentrations, based on air quality data collected at the most representative monitoring stations during the last 3 years (i.e., 2005 through 2007). The resulting total pollutant concentrations were then compared with the most stringent CAAQS or NAAQS.

7.2.1 Normal Plant Operation

As described previously, the emissions used in the AERMOD simulations for the project operations were selected to ensure that the maximum potential impacts would be addressed for each pollutant and averaging time corresponding to an ambient air quality standard. The emissions used for each pollutant and averaging time were explained and quantified in Table 7-7. This subsection describes the maximum predicted operational impacts of the project for normal FP10 combined-cycle operating conditions. Commissioning impacts, which would occur on a temporary, one-time basis and would not be representative of normal operations, were addressed separately, as described below under Turbine Commissioning.

The maximum predicted criteria pollutant concentrations due to the operational FP10 combined-cycle plant are summarized in Table 7-8 for Meteorological Data Set A and in Table 7-9 for Meteorological Data Set B. The incremental impacts of project emissions would be below the federal PSD significant impact levels (SILs) for all attainment pollutants, despite the use of worst-case emissions scenarios for all pollutants and averaging times. Although maximum predicted values for PM_{10} are below the SILs, these thresholds do not apply to this pollutant because the project area is designated nonattainment with respect to the federal ambient standards. No SILs have been established yet for $\text{PM}_{2.5}$.

Tables 7-8 and 7-9 also show that the modeled impacts due to the project emissions, in combination with conservative background concentrations, would not cause a violation of any NAAQS and would not significantly contribute to the existing violations of the state and federal PM_{10} standards or the state $\text{PM}_{2.5}$ standards. In addition, as described later, all of the proposed project's operational emissions of nonattainment pollutants and their precursors will be offset to ensure a net air quality benefit.

ATC/PTO Application

Willow Pass Generating Station

The locations of predicted maximum impacts vary by pollutant and averaging time. The highest annual NO₂ concentration is expected to occur at the southwestern boundary line of the proposed project site. Peak annual average concentrations for PM₁₀, PM_{2.5}, and SO₂ are predicted to occur approximately 0.3 mile northeast of the project site. Peak 24-hour average concentrations for PM₁₀, PM_{2.5} are also predicted to occur northeast of the project site.

The 1-hour maximum values for NO₂, SO₂, and CO, 3-hour SO₂, 8-hour CO, and 24-hour SO₂, are predicted to occur at different locations in the elevated terrain approximately 3.5 miles southwest of the facility. Figures 7-4 and 7-5 show the locations of the maximum predicted operational impacts for all pollutants and averaging times for both meteorological data sets.

7.2.2 Turbine Commissioning

Each of the project CTGs could be operated for up to 500 hours with partially abated emissions for the purposes of commissioning the new generating equipment. Separate modeling was conducted using AERMOD to evaluate maximum short-term effects of these activities in terms of the impacts on offsite 1-hour NO₂ concentrations and 1-hour and 8-hour CO concentrations. These are the pollutants (along with VOCs, which are not modeled) for which emissions would be expected to be significantly higher than during normal operations, owing to the non-operability of the SCR and oxidation catalyst emission control systems during some of the commissioning tests. Emissions of SO_x and particulate matter (PM₁₀, PM_{2.5}) depend primarily on the rate of fuel combustion, and are unaffected by the availability or nonavailability of the SCR and oxidation catalyst. Thus, emissions of these pollutants during commissioning are not expected to exceed the levels that would occur during full-load normal operation of the turbines, and separate modeling for commissioning impacts on SO_x and PM levels is unnecessary.

Stack NO_x and CO emission rates during turbine commissioning are presented in Table 7-10. Modeling was conducted for the commissioning tests that were expected to produce the highest offsite concentrations at ground level (i.e., the test with the highest emission rate in combination with the lowest exhaust flow and temperature). For the NO_x modeling, the emissions for the row labeled “CTG 1 Testing at 40% load” in Table 7-10 were used. Maximum CO impacts were evaluated for the case labeled “CTG Testing (Full Speed No Load, FSNL, Excitation Test, Dummy Synch Checks).” Startup stack parameters were used.

Tables 7-11 and 7-12 show the results of the model simulations for turbine commissioning for both meteorological data sets. The tabulated impacts are the highest concentrations for the indicated averaging periods that are predicted by AERMOD to occur using 4 years of hourly meteorological input data. The modeling was conducted conservatively for commissioning of both FP10 turbines concurrently, although in practice commissioning tests may be conducted separately for each unit. Tables 7-11 and 7-12 demonstrate that when the maximum incremental commissioning impacts are added to conservative background concentrations and compared with the most stringent state or national ambient standards, no violations of the applicable standards for these pollutants are predicted to occur.

7.2.3 Impacts for Non-Attainment Pollutants and their Precursors

The emission offset program described in the BAAQMD Rules and Regulations was developed to facilitate net air quality improvement when new sources locate within the BAAQMD. Project impacts of nonattainment pollutants (PM₁₀, PM_{2.5}, and O₃) and their precursors (NO_x, SO₂, and VOC) will be fully mitigated by emission offsets. The emission reductions associated with these offsets have not been accounted for in the modeled impacts noted above. Thus, the impacts indicated in the foregoing presentation of model results for the project may be significantly overestimated.

ATC/PTO Application Willow Pass Generating Station

7.2.4 Impacts on Air Quality Related Values in Class I Area

U.S. EPA has promulgated PSD regulations applicable to Major Sources and Major Modifications, as these terms are defined in 40 CFR 51.166. The project would be a Major Modification to an existing Major Source because of the increases that would result in CO, PM₁₀, and NO_x emissions. Many of the PSD requirements are the same as those that must be met for compliance with the BAAQMD's New Source Review rule (Regulation II, Rule 2) and CEC's guidance for air quality impact evaluations (e.g., quantification of project emissions, demonstration of BACT, AAQS analysis). However, PSD requires the following additional analyses:

- An analysis of the potential incremental impacts from the new emissions from the project relative to PSD SILs, and if necessary with the PSD increments.
- An analysis of AQRVs to ensure the protection of visibility in federal Class I National Parks and National Wilderness Areas within 100 km (62 miles) of the project site;
- An evaluation of potential impacts on soils and vegetation of commercial and recreational value; and
- An evaluation of potential growth-inducing impacts.

Effects on Visibility from Plumes

Modern combined-cycle power plants burning natural gas fuel emit PM at levels far below the concentration corresponding to visible smoke. Combustion sources also emit water vapor that sometimes may condense in the atmosphere to form short visible plumes. However, the generally warm, dry conditions in Contra Costa County are not conducive to lengthy visible stack plumes, and the historical operation of the existing PPP Units 5, 6, and 7 indicates that moisture plumes rarely extend to appreciable distances. Evaporative cooling towers are another potentially more important source of visible moisture plumes at power plants, but the WPGS will employ air-cooled condensers that do not produce moisture plumes.


Impacts in Class II PSD Areas

As the proposed project would trigger PSD as a New Major Source, modeling is required to determine whether its incremental impacts on ambient levels of attainment pollutants (NO₂, SO₂, and CO) would exceed Class II SILs. The SILs for PM₁₀ are not applicable because of the federal nonattainment status of the San Francisco Bay Air Basin for this pollutant. If project emissions were predicted to cause the SILs for attainment pollutants to be exceeded, then an analysis of total increment consumption since the local PSD baseline date would be required. However, as demonstrated by Table 7-8 and 7-9, the maximum modeled incremental pollutant concentrations for all attainment pollutants are below the Class II SILs; thus, no further analysis of impacts in PSD Class II areas is required.

Impacts in Class I PSD areas

An evaluation of impacts in Class I areas within 100 km (62 miles) of the project is typically conducted when the potential emissions increases from the project would be sufficient to trigger federal PSD requirements. The applicant contacted the National Park Service (NPS) administrator for Point Reyes National Seashore, the only Class I area located within 100 km of the project. As described in Section 5.2, the NPS has determined that a Class I impact analysis is not required for this project.

**ATC/PTO Application
Willow Pass Generating Station**




Path: G:\pitt\pitt\1572000745\mirant_willow_pass\windrose.mxd, 06/08/08

7/9/08 via ...T:\Mirant\Pittsburg-Willow Pass\Graphical\ATC_Ar Permit\7.4_windrose.ai


ATC/PTO Application
 Willow Pass Generating Station




**ATC/PTO Application
Willow Pass Generating Station**



ATC/PTO Application
Willow Pass Generating Station



**ATC/PTO Application
Willow Pass Generating Station**



**ATC/PTO Application
Willow Pass Generating Station**

Table 7-1 Surface Moisture Conditions for Years 2002-2005												
Surface moisture condition by month for the Antioch Pump Plant 3 Station												
Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2002	dry	dry	avg	dry	avg	wet						
2003	avg	dry	avg	wet	wet	dry	dry	wet	dry	dry	avg	wet
2004	avg	wet	dry	dry	avg	dry	dry	dry	dry	wet	avg	wet
2005	wet	avg	wet	avg	avg	wet	dry	dry	dry	dry	dry	wet

Note: Surface moisture conditions provided by BAAQMD.

Table 7-2 Land Use Characteristics used in AERMET Meteorological Data Set A							
Month	Sector	Range	Land Use Characteristics				
			Albedo (α)	Bowen Ratio (β) Average Surface Moisture	Bowen Ratio (β) Dry Surface Moisture	Bowen Ratio (β) Wet Surface Moisture	Surface Roughness (z₀) (m)
Jan	1	90°-270°	0.15	0.35	0.57	0.26	0.023
Jan	2	270°-90°	0.15	0.35	0.57	0.26	0.007
Feb	1	90°-270°	0.14	0.27	0.47	0.23	0.025
Feb	2	270°-90°	0.14	0.27	0.47	0.23	0.007
Mar	1	90°-270°	0.14	0.27	0.47	0.23	0.025
Mar	2	270°-90°	0.14	0.27	0.47	0.23	0.007
Apr	1	90°-270°	0.14	0.31	0.54	0.24	0.026
Apr	2	270°-90°	0.14	0.31	0.54	0.24	0.007
May	1	90°-270°	0.14	0.31	0.54	0.24	0.026
May	2	270°-90°	0.14	0.31	0.54	0.24	0.007
Jun	1	90°-270°	0.14	0.31	0.54	0.24	0.026
Jun	2	270°-90°	0.14	0.31	0.54	0.24	0.007
Jul	1	90°-270°	0.14	0.31	0.54	0.24	0.026
Jul	2	270°-90°	0.14	0.31	0.54	0.24	0.007
Aug	1	90°-270°	0.14	0.35	0.57	0.26	0.026
Aug	2	270°-90°	0.14	0.35	0.57	0.26	0.007
Sep	1	90°-270°	0.14	0.35	0.57	0.26	0.026
Sep	2	270°-90°	0.14	0.35	0.57	0.26	0.007
Oct	1	90°-270°	0.14	0.35	0.57	0.26	0.026
Oct	2	270°-90°	0.14	0.35	0.57	0.26	0.007
Nov	1	90°-270°	0.15	0.35	0.57	0.26	0.023
Nov	2	270°-90°	0.15	0.35	0.57	0.26	0.007
Dec	1	90°-270°	0.15	0.35	0.57	0.26	0.023
Dec	2	270°-90°	0.15	0.35	0.57	0.26	0.007

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-3
Land Use Characteristics used in AERMET
Meteorological Data Set B**

Month	Sector	Range	Land Use Characteristics				
			Albedo (α)	Bowen Ratio (β) Average Surface Moisture	Bowen Ratio (β) Dry Surface Moisture	Bowen Ratio (β) Wet Surface Moisture	Surface Roughness (Z_0) (m)
Jan	1	102°-194°	0.15	0.34	0.55	0.25	0.517
Jan	2	194°-279°	0.15	0.34	0.55	0.25	0.3
Jan	3	279°-102°	0.15	0.34	0.55	0.25	0.011
Feb	1	102°-194°	0.14	0.27	0.47	0.23	0.548
Feb	2	194°-279°	0.14	0.27	0.47	0.23	0.322
Feb	3	279°-102°	0.14	0.27	0.47	0.23	0.011
Mar	1	102°-194°	0.14	0.27	0.47	0.23	0.548
Mar	2	194°-279°	0.14	0.27	0.47	0.23	0.322
Mar	3	279°-102°	0.14	0.27	0.47	0.23	0.011
Apr	1	102°-194°	0.14	0.3	0.52	0.24	0.569
Apr	2	194°-279°	0.14	0.3	0.52	0.24	0.333
Apr	3	279°-102°	0.14	0.3	0.52	0.24	0.011
May	1	102°-194°	0.14	0.3	0.52	0.24	0.569
May	2	194°-279°	0.14	0.3	0.52	0.24	0.333
May	3	279°-102°	0.14	0.3	0.52	0.24	0.011
Jun	1	102°-194°	0.14	0.3	0.52	0.24	0.569
Jun	2	194°-279°	0.14	0.3	0.52	0.24	0.333
Jun	3	279°-102°	0.14	0.3	0.52	0.24	0.011
Jul	1	102°-194°	0.14	0.3	0.52	0.24	0.569
Jul	2	194°-279°	0.14	0.3	0.52	0.24	0.333
Jul	3	279°-102°	0.14	0.3	0.52	0.24	0.011
Aug	1	102°-194°	0.14	0.34	0.55	0.25	0.569
Aug	2	194°-279°	0.14	0.34	0.55	0.25	0.333
Aug	3	279°-102°	0.14	0.34	0.55	0.25	0.011
Sep	1	102°-194°	0.14	0.34	0.55	0.25	0.569
Sep	2	194°-279°	0.14	0.34	0.55	0.25	0.333
Sep	3	279°-102°	0.14	0.34	0.55	0.25	0.011
Oct	1	102°-194°	0.14	0.34	0.55	0.25	0.569
Oct	2	194°-279°	0.14	0.34	0.55	0.25	0.333
Oct	3	279°-102°	0.14	0.34	0.55	0.25	0.011
Nov	1	102°-194°	0.15	0.34	0.55	0.25	0.517
Nov	2	194°-279°	0.15	0.34	0.55	0.25	0.3
Nov	3	279°-102°	0.15	0.34	0.55	0.25	0.011
Dec	1	102°-194°	0.15	0.34	0.55	0.25	0.517
Dec	2	194°-279°	0.15	0.34	0.55	0.25	0.3
Dec	3	279°-102°	0.15	0.34	0.55	0.25	0.011

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-4
WPGS Turbine Screening Results FP10 Combined-Cycle Units
With Meteorological Data Set A
(Page 1 of 2)**

Normal Operations – New Siemens Flex-Plant 10 Emissions and stack parameters per Turbine												
Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3A	Case 3B	Case 3C	Case 3D	Case 3E	Case 3F
	Winter Minimum – 20°F			Yearly Average-59°F			Summer Maximum – 94°F					
CTG Load Level	100%	85%	60%	100%	85%	60%	100%	100%	100%	100%	85%	60%
Evaporative Cooler Status/Effectiveness	OFF	OFF	OFF	OFF	OFF	OFF	ON	ON	OFF	OFF	OFF	OFF
Power Augmentation Status	OFF	OFF	OFF	OFF	OFF	OFF	ON	OFF	ON	OFF	OFF	OFF
Stack Outlet Temperature (°F)	350	346	343.7	340	337	328.7	338	348	333	341	346	323.3
Stack Outlet Temperature (°K)	449.82	447.59	446.32	444.26	442.59	437.98	443.15	448.71	440.37	444.82	447.59	434.98
Stack Exit Velocity (ft/s)	70.5	61.5	50.1	64.3	57.0	44.9	65.2	62.5	61.6	59.0	53.4	42.8
Stack Exit Velocity (m/s)	21.479	18.752	15.260	19.587	17.378	13.694	19.860	19.059	18.763	17.979	16.282	13.054
NO _x as NO ₂ (at 2.0 ppm) (lb/hr)	17.4	15.1	12.0	15.8	13.9	10.0	16.3	15.2	15.3	14.3	12.9	10.0
CO (at 3.0 ppm) (lb/hr)	26.1	22.7	18.0	23.7	20.9	15.0	24.5	22.8	23.0	21.5	19.3	15.0
SO ₂ (lb/hr) (based on 0.4 gr total S/100 scf)	2.6	2.3	1.8	2.3	2.1	1.6	2.4	2.2	2.3	2.1	1.9	1.5
SO ₂ (lb/hr) (based on 1.0 gr total S/100 scf)	6.4	5.6	4.5	5.8	5.2	4.0	6.0	5.6	5.6	5.3	4.7	3.8
PM ₁₀ (lb/hr)	10.0	8.9	8.0	9.3	8.3	8.0	8.9	8.8	8.5	8.5	7.7	8.0
NO _x (g/s)	2.194	1.904	1.513	1.993	1.753	1.261	2.056	1.917	1.930	1.803	1.623	1.261
CO (g/s)	3.292	2.856	2.270	2.989	2.629	1.892	3.083	2.875	2.894	2.705	2.435	1.892
SO ₂ (g/s) (based on 0.4 gr total S/100 scf)	0.324	0.284	0.226	0.294	0.260	0.201	0.303	0.283	0.285	0.266	0.239	0.191
SO ₂ (g/s) (based on 1.0 gr total S/100 scf)	0.811	0.710	0.565	0.736	0.650	0.501	0.758	0.707	0.712	0.664	0.598	0.477
PM ₁₀ (g/s)	1.261	1.122	1.009	1.173	1.047	1.009	1.122	1.110	1.072	1.072	0.965	1.009

ATC/PTO Application
Willow Pass Generating Station

**Table 7-4
WPGS Turbine Screening Results FP10 Combined-Cycle Units
With Meteorological Data Set A
(Page 2 of 2)**

Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3A	Case 3B	Case 3C	Case 3D	Case 3E	Case 3F	
Model Results – Maximum X/Q concentration ($\mu\text{g}/\text{m}^3/(\text{g}/\text{s})$) predicted from AERMOD (all receptors)													
1-hour	14.11850	15.01065	17.42864	14.68182	16.18494	18.72308	14.64591	14.76844	15.37029	15.65280	16.68121	19.27467	
3-hour	6.86020	8.04961	9.72690	7.80241	8.85959	10.50651	7.72645	7.87138	8.31029	8.49814	9.21476	10.69859	
8-hour	3.69092	3.97803	4.65019	3.87081	4.30786	4.94505	3.83739	3.90335	4.08284	4.16433	4.44611	5.02419	
24-hour	1.30576	1.33382	1.55034	1.33132	1.43621	1.64866	1.33028	1.33219	1.36119	1.38836	1.48230	1.67505	
annual	0.05248	0.06112	0.07999	0.05878	0.06897	0.09598	0.05806	0.05964	0.06332	0.06550	0.07309	0.10451	
Maximum Concentration ($\mu\text{g}/\text{m}^3$) Predicted per Pollutant Normal Operations (all receptors)													
NO _x	1 hour	30.98070	28.58445	26.37534	29.25434	28.37130	23.61188	30.10630	28.30946	29.65697	28.22809	27.07444	24.30750
	annual	0.11516	0.11639	0.12105	0.11712	0.12090	0.12104	0.11935	0.11432	0.12218	0.11812	0.11863	0.13180
CO	1 hour	46.47104	42.87667	39.56301	43.88151	42.55695	35.41783	45.15944	42.46419	44.48546	42.34213	40.61166	36.46125
	8 hour	12.14866	11.36291	10.55593	11.56921	11.32716	9.35439	11.83227	11.22343	11.81676	11.26486	10.82439	9.50409
SO ₂	1 hour	11.44851	10.65094	9.85488	10.80940	10.52557	9.38774	11.09935	10.43942	10.94531	10.40093	9.97586	9.18441
	3 hour	5.56285	5.71167	5.49999	5.74448	5.76167	5.26796	5.85546	5.56407	5.91783	5.64682	5.51070	5.09789
	24 hour	1.05882	0.94642	0.87663	0.98018	0.93401	0.82664	1.00815	0.94169	0.96931	0.92253	0.88646	0.79816
	annual	0.01702	0.01735	0.01809	0.01731	0.01794	0.01925	0.01760	0.01686	0.01804	0.01741	0.01748	0.01992
PM ₁₀	24 hour	1.64671	1.49706	1.56412	1.56142	1.50331	1.66331	1.49309	1.47843	1.45912	1.48824	1.43005	1.68994
	annual	0.06618	0.06860	0.08070	0.06894	0.07219	0.09683	0.06517	0.06619	0.06788	0.07021	0.07051	0.10544
Note: Bold type indicates highest concentration values for each pollutant and averaging time.													

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-5
WPGS Turbine Screening Results FP10 Combined-Cycle Units
With Meteorological Data Set B
(Page 1 of 2)**

Normal Operations – New Siemens Peaker Flex-Plant 10 Emissions and stack parameters per Turbine

Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3A	Case 3B	Case 3C	Case 3D	Case 3E	Case 3F
	Winter Minimum – 20°F			Yearly Average-59°F			Summer Maximum – 94°F					
CTG Load Level	100%	85%	60%	100%	85%	60%	100%	100%	100%	100%	85%	60%
Evaporative Cooler Status/Effectiveness	OFF	OFF	OFF	OFF	OFF	OFF	ON	ON	OFF	OFF	OFF	OFF
Power Augmentation Status	OFF	OFF	OFF	OFF	OFF	OFF	ON	OFF	ON	OFF	OFF	OFF
Stack Outlet Temperature (°F)	350	346	343.7	340	337	328.7	338	348	333	341	346	323.3
Stack Outlet Temperature (°K)	449.82	447.59	446.32	444.26	442.59	437.98	443.15	448.71	440.37	444.82	447.59	434.98
Stack Exit Velocity (ft/s)	70.5	61.5	50.1	64.3	57.0	44.9	65.2	62.5	61.6	59.0	53.4	42.8
Stack Exit Velocity (m/s)	21.479	18.752	15.260	19.587	17.378	13.694	19.860	19.059	18.763	17.979	16.282	13.054
NO _x as NO ₂ (at 2.0 ppm) (lb/hr)	17.4	15.1	12.0	15.8	13.9	10.0	16.3	15.2	15.3	14.3	12.9	10.0
CO (at 3.0 ppm) (lb/hr)	26.1	22.7	18.0	23.7	20.9	15.0	24.5	22.8	23.0	21.5	19.3	15.0
SO ₂ (lb/hr) (based on 0.4 gr total S/100 scf)	2.6	2.3	1.8	2.3	2.1	1.6	2.4	2.2	2.3	2.1	1.9	1.5
SO ₂ (lb/hr) (based on 1.0 gr total S/100 scf)	6.4	5.6	4.5	5.8	5.2	4.0	6.0	5.6	5.6	5.3	4.7	3.8
PM ₁₀ (lb/hr)	10.0	8.9	8.0	9.3	8.3	8.0	8.9	8.8	8.5	8.5	7.7	8.0
NO _x (g/s)	2.194	1.904	1.513	1.993	1.753	1.261	2.056	1.917	1.930	1.803	1.623	1.261
CO (g/s)	3.292	2.856	2.270	2.989	2.629	1.892	3.083	2.875	2.894	2.705	2.435	1.892
SO ₂ (g/s) (based on 0.4 gr total S/100 scf)	0.324	0.284	0.226	0.294	0.260	0.201	0.303	0.283	0.285	0.266	0.239	0.191
SO ₂ (g/s) (based on 1.0 gr total S/100 scf)	0.811	0.710	0.565	0.736	0.650	0.501	0.758	0.707	0.712	0.664	0.598	0.477
PM ₁₀ (g/s)	1.261	1.122	1.009	1.173	1.047	1.009	1.122	1.110	1.072	1.072	0.965	1.009

ATC/PTO Application
Willow Pass Generating Station

**Table 7-5
WPGS Turbine Screening Results FP10 Combined-Cycle Units
With Meteorological Data Set B
(Page 2 of 2)**

Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3A	Case 3B	Case 3C	Case 3D	Case 3E	Case 3F	
Model Results – Maximum X/Q concentration ($\mu\text{g}/\text{m}^3/(\text{g}/\text{s})$) predicted from AERMOD (all receptors)													
1-hour	13.61744	14.46845	16.59311	14.32206	15.23927	18.05774	14.27411	14.36636	14.60333	14.73768	15.76427	18.55109	
3-hour	6.48719	7.50849	9.29829	7.25352	8.35618	10.23958	7.17486	7.32528	7.79561	7.98974	8.72698	10.50271	
8-hour	3.52994	3.81550	4.37571	3.76827	4.02877	4.69361	3.75332	3.77813	3.87277	3.90273	4.16988	4.77928	
24-hour	1.23170	1.26717	1.61514	1.26270	1.45207	1.83690	1.26111	1.26402	1.28135	1.35449	1.50421	1.95088	
annual	0.10050	0.11910	0.15464	0.11492	0.13367	0.18303	0.11374	0.11640	0.12276	0.12655	0.14171	0.19653	
Maximum Concentration ($\mu\text{g}/\text{m}^3$) Predicted per Pollutant Normal Operations (all receptors)													
NO _x	1 hour	29.88120	27.55195	25.11091	28.53750	26.71359	22.77282	29.34202	27.53872	28.17713	26.57777	25.58620	23.39499
	annual	0.22053	0.22680	0.23402	0.22898	0.23432	0.23082	0.23381	0.22313	0.23687	0.22822	0.23000	0.24785
CO	1 hour	44.82180	41.32792	37.66636	42.80625	40.07039	34.15922	44.01303	41.30807	42.26569	39.86665	38.37930	35.09248
	8 hour	11.61880	10.89866	9.93286	11.26273	10.59331	8.87875	11.57305	10.86338	11.20876	10.55721	10.15189	9.04080
SO ₂	1 hour	11.04221	10.26622	9.38243	10.54453	9.91057	9.05414	10.81759	10.15520	10.39915	9.79286	9.42750	8.83962
	3 hour	5.26038	5.32771	5.25764	5.34036	5.43428	5.13412	5.43744	5.17805	5.55132	5.30900	5.21899	5.00456
	24 hour	0.99877	0.89913	0.91327	0.92966	0.94433	0.92102	0.95573	0.89350	0.91246	0.90003	0.89956	0.92960
	annual	0.03260	0.03380	0.03498	0.03384	0.03477	0.03671	0.03448	0.03291	0.03497	0.03364	0.03390	0.03746
PM ₁₀	24 hour	1.55331	1.42226	1.62950	1.48094	1.51991	1.85323	1.41546	1.40278	1.37354	1.45194	1.45119	1.96822
	annual	0.12674	0.13368	0.15601	0.13478	0.13992	0.18466	0.12766	0.12918	0.13159	0.13565	0.13671	0.19828
Note: Bold type indicates highest concentration values for each pollutant and averaging time.													

ATC/PTO Application
Willow Pass Generating Station

Table 7-6 Maximum Hourly NO_x and CO Emissions				
Pollutant and Averaging Time	Description: Turbine Load	FP10 Unit Exhaust Temperature (°F)	FP10 Unit Exhaust Velocity (ft/s)	Emission Rate per FP10 Unit Turbine (lb/hr)
NO _x 1-hour	All turbines starting up with the remainder of the period at normal operations	334	47.9	38.7
CO 1-hour	All turbines starting up with the remainder of the period at normal operations	334	47.9	279.8
Notes: CO = carbon monoxide °F = degrees Fahrenheit ft/sec = feet per second lb/hr = pounds per hour NO _x = nitrogen oxide(s)				

**ATC/PTO Application
Willow Pass Generating Station**

Table 7-7 Criteria Pollutant Sources and Emissions Totals for the Worst Case Project Emissions Scenarios for All Averaging Times				
Averaging Time	Pollutant	Two FP10 Unit turbines (lbs. entire period)	One Gas Preheater (lbs. entire period)	FP10 Turbines
1-hour	NO _x	32.6 (normal ops)	0.15	NOx and CO normal operations: 100% load operation (both FP10s) at 94°F ambient temperature NOx and CO startup operations: One startup (both FP10s) with remainder of period at normal operations (100%, 20°F) SO2: 100% load operation (both FP10s) at 20°F ambient temperature based on 1.0 gr total S / 100 scf
		77.4 (startup ops)		
	CO	30.0 (normal ops)	0.17	
		559.6 (startup ops)		
	SO ₂	13.4	0.014	
3-hour	SO ₂	40.2	0.042	SO2: 100% load operation (both FP10s) at 20°F ambient temperature based on 1.0 gr total S / 100 scf
8-hour	CO	1,577.20	1.36	CO: Two startups, one shutdown (both FP10s) with remainder of period at 100% load operation at 20°F ambient temperature
24-hour	PM ₁₀	486.00	0.360	PM10: Three startups, three shutdowns (both FP10s) with remainder of period at 100% load operation at 20°F ambient temperature
	SO ₂	308.60	0.336	SO2: 100% load operation (both FP10s) at 20°F ambient temperature based on 1.0 gr total S / 100 scf
annual	NO _x	154,206.00	657	All: both FP10 operates for 4000 hours with power augmentation and evaporative cooling on at 94°F, 322 hours at full load at 59°F, with 193 startups and shutdowns. SO2 emissions are based on 0.4 gr total S / 100 scf.
	PM ₁₀	78,800.80	64.5	
	SO ₂	21,041.20	24.5	

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-8
AERMOD Modeling Results for WPGS Operations
Using Meteorological Data Set A
(All Project Sources Combined)**

Pollutant	Averaging Period	Maximum Predicted Impact (µg/m³)	Significant Air Quality Impacts (µg/m³)	Background Concentration (µg/m³)¹	Total Concentration (µg/m³)	NAAQS (µg/m³)	CAAQS (µg/m³)	Maximum UTMX NAD27 (m)	Maximum UTM Y NAD27 (m)
NO ₂	1-hour ²	33.4 (normal operations)	19 ⁶	109.04	142	NA	339 ⁵	593,375	4,206,250
		99.9 (startup operations)	NA	109.04	208.94	NA	339 ⁵	593,770	4,206,725
	Annual ²	0.2	1.0	22.56	22.76	100	57 ⁵	597,073	4,210,413
SO ₂	1-hour	13.7	NA	122.67	136.37	NA	655	593,375	4,206,250
	3-hour	8.2	25	65.25	73.45	1300	NA	593,400	4,206,250
	24-hour	1.1	5	23.49	24.59	365	105	594,875	4,205,725
	Annual	0.02	1.0	7.83	7.85	80	NA	597,925	4,210,575
CO	1-hour	30.8 (normal operations)	2,000	3,762	3,793	40,000	23,000	593,375	4,206,250
		721.4 (startup operations)	NA	3,762	4,483	40,000	23,000	593,750	4,206,725
	8-hour	51.7	500	2,166	2,218	10,000	10,000	596,050	4,204,550
PM ₁₀	24-hour ^{3,4}	2.3	5	84	86.3	150	50	595,150	4,206,000
	Annual ^{3,4}	0.06	1.0	20	20.06	NA	20	597,925	4,210,575
PM _{2.5}	24-hour ^{3,4}	2.3	NA	62	64.3	35	NA	595,150	4,206,000
	Annual ^{3,4}	0.06	NA	10	10.06	15	12	597,925	4,210,575

Notes:

¹ Background represents the maximum values measured at the monitoring stations identified in Section 7.1.1.2.

² Results for NO₂ during operations used ozone limiting method with ambient ozone data collected at the Pittsburg air quality monitoring station for the years 2002-2005.

³ PM₁₀ and PM_{2.5} background levels exceed ambient standards.

⁴ All PM₁₀ emissions from project sources were also considered to be PM_{2.5}.

⁵ In February 2007, CARB approved new, more stringent CAAQS for NO₂ as shown in the table above. These changes became effective in March 2008.

⁶ If predicted maximum 1-hour NO₂ concentration due to new sources is below this significant threshold, no further analysis is required. Otherwise, it must be demonstrated that the project's impacts plus background will be below applicable ambient air quality standards.

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-9
AERMOD Modeling Results for WPGS Operations
Using Meteorological Data Set B
(All Project Sources Combined)**

Pollutant	Averaging Period	Maximum Predicted Impact (µg/m³)	Significant Air Quality Impacts (µg/m³)	Background Concentration (µg/m³)¹	Total Concentration (µg/m³)	NAAQS (µg/m³)	CAAQS (µg/m³)	Maximum UTMX NAD27 (m)	Maximum UTM Y NAD27 (m)
NO ₂	1-hour ²	32.4 (normal operations)	19 ⁶	109.04	141.4	NA	339 ⁵	593,350	4,206,250
		92.9 (startup operations)	NA	109.04	201.9	NA	339 ⁵	593,425	4,206,250
	Annual ²	0.2	1.0	22.56	22.8	100	57 ⁵	597,850	4,210,550
SO ₂	1-hour	13.3	NA	122.67	136.0	NA	655	593,350	4,206,225
	3-hour	7.9	25	65.25	73.2	1300	NA	593,400	4,206,225
	24-hour	1.1	5	23.49	24.6	365	105	594,925	4,205,700
	Annual	0.03	1.0	7.83	7.86	80	NA	597,850	4,210,550
CO	1-hour	29.9 (normal operations)	2,000	3,762	3792	40,000	23,000	593,350	4,206,250
		671.2 (startup operations)	NA	3,762	4133	40,000	23,000	593,425	4,206,250
	8-hour	51.3	500	2,166	2217	10,000	10,000	593,400	4,206,100
PM ₁₀	24-hour ^{3,4}	2.5	5	84	86.5	150	50	597,875	4,210,500
	Annual ^{3,4}	0.12	1.0	20	20.12	NA	20	597,850	4,210,550
PM _{2.5}	24-hour ^{3,4}	2.5	NA	62	86.5	35	NA	597,875	4,210,500
	Annual ^{3,4}	0.12	NA	10	20.12	15	12	597,850	4,210,550

Notes:

¹ Background represents the maximum values measured at the monitoring stations identified in Section 7.1.1.2.

² Results for NO₂ during operations used ozone limiting method with ambient ozone data collected at the Pittsburg air quality monitoring station for the years 2002-2005.

³ PM₁₀ and PM_{2.5} background levels exceed ambient standards.

⁴ All PM₁₀ emissions from project sources were also considered to be PM_{2.5}.

⁵ In February 2007, CARB approved new, more stringent CAAQS for NO₂ as shown in the table above. These changes became effective in March 2008.

⁶ If predicted maximum 1-hour NO₂ concentration due to new sources is below this significant threshold, no further analysis is required. Otherwise, it must be demonstrated that the project's impacts plus background will be below applicable ambient air quality standards.

ATC/PTO Application
Willow Pass Generating Station

Table 7-10
Duration and Criteria Pollutant Emissions for Commissioning of a Single FP10 Unit
(20 ppm ULN) on Natural Gas at 62°F

Activity	Duration (hours)	GT Load (%)	Modeling Load (%)	Total Emission			
				NO _x (lb)	CO (lb)	VOC (lb)	PM ₁₀ (lb)
GT Testing (FSNL, Excitation Test, Dummy Synch Checks)	8	0	FSNL	366	29,743	1275	75
GT Testing at 40% load	8	0-40	40	1,444	16,091	612	86
Steam Blow/HRSG Tuning	24	0-25	25	2,701	51,960	1637	222
Steam Blow	12	0-50	50	964	8,745	682	107
Steam Blow restoration, install SCR/CO Catalyst	0	0	0	0	0	0	0
HRSG Tuning/BOP Tuning	16	60	60	191	1,320	155	135
BOP Tuning	16	60	60	191	1,320	155	135
GT Load Test and Bypass Valve Tuning	32	60	60	382	2640	310	270
GT Load Test and Bypass Valve Tuning/ Safety Valve Testing	12	75	75	179	1,160	95	105
GT Base Load/Commissioning of Ammonia system	12	100	100	365	1,189	104	117
GT Load Test and Bypass Valve Tuning	12	100	100	365	1,189	104	117
Install Emissions Test Equipment	0	0	0	0	0	0	0
Bypass Operation/STG Initial Roll and Trip Test	10	0-60	60	149	1,227	123	87
Bypass Operation/STG Load Test	32	0-60	60	647	2,545	269	285
Combined-Cycle testing/Drift Test	48	0-100	100	1,184	1,513	199	415
Emissions Tuning/Drift Test	24	50-100	100	730	2,378	208	234
Pre-performance Testing/Drift Test	36	100	100	1,095	3,567	312	351
RATA/Pre-performance Testing/Source Testing	15	100	100	433	1,216	112	142
Pre-performance/Source Testing	26	50-100	100	776	2,396	213	250
Remove Emissions Test Equipment followed by Water Wash and Performance preparation	0	0	0	0	0	0	0
Performance Testing	48	100	100	1,276	2,594	272	432
CAISO Certification	24	50-100	100	730	2,378	208	234
GT Testing (FSNL, Excitation Test, Dummy Synch Checks)	8	0	FSNL	366	2,9743	1,275	75

Notes: SO_x emission during commissioning will not be higher than normal operation.

CT = combustion turbine
 CTG = combustion turbine generator
 FSNL = full speed, no load

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-11
Turbine Commissioning Modeling Results Using Meteorological Data Set A**

Modeling Scenario	Pollutant	Averaging Period	Maximum Estimated Impact ($\mu\text{g}/\text{m}^3$)	Background¹ ($\mu\text{g}/\text{m}^3$)	Total Predicted Concentration ($\mu\text{g}/\text{m}^3$)	Most Stringent Standard ($\mu\text{g}/\text{m}^3$)
Two FP10 Turbines commissioning with fuel gas heater	CO	1 hour	9,584	3,762	13,346	23,000
		8 hours	2,507	2,166	4,673	10,000
	NO ₂ ³	1 hour	217.3	109.04	326.34	339 ²

Notes:
¹ Background represents the maximum values measured at the monitoring stations.
² In February 2007, the CARB approved new, more stringent CAAQS for NO₂. The new standards of 339 $\mu\text{g}/\text{m}^3$ (1 hour) and 57 $\mu\text{g}/\text{m}^3$ (annual) became effective in March 2008.
³ NO₂ modeling for Commissioning was conducted with the OLM algorithm.

CO = carbon monoxide
 $\mu\text{g}/\text{m}^3$ = micrograms per cubic meter
NO₂ = nitrogen dioxide

**ATC/PTO Application
Willow Pass Generating Station**

**Table 7-12
Turbine Commissioning Modeling Results Using Meteorological Data Set B**

Modeling Scenario	Pollutant	Averaging Period	Maximum Estimated Impact ($\mu\text{g}/\text{m}^3$)	Background¹ ($\mu\text{g}/\text{m}^3$)	Total Predicted Concentration ($\mu\text{g}/\text{m}^3$)	Most Stringent Standard ($\mu\text{g}/\text{m}^3$)
Two FP10 Turbines commissioning with fuel gas heater	CO	1 hour	8,918	3,762	12,680	23,000
		8 hours	2,362	2,166	4,528	10,000
	NO ₂ ³	1 hour	216.0	109.04	325.0	339 ²

Notes:

¹ Background represents the maximum values measured at the monitoring stations.

² In February 2007, the CARB approved new, more stringent CAAQS for NO₂. The new standards of 339 $\mu\text{g}/\text{m}^3$ (1 hour) and 57 $\mu\text{g}/\text{m}^3$ (annual) became effective in March 2008.

³ NO₂ modeling for Commissioning was conducted with the OLM algorithm.

CO = carbon monoxide

$\mu\text{g}/\text{m}^3$ = micrograms per cubic meter

NO₂ = nitrogen dioxide

**ATC/PTO Application
Willow Pass Generating Station**

8.0 BACT ANALYSIS

Federal requirements pertaining to control of pollutants subject to PSD review (i.e., attainment pollutants) were promulgated by U.S. EPA in 40 CFR 51.21 (j). This regulation defines BACT as emission limits “based on maximum degree of reduction for each pollutant.” BACT determinations are made on a case-by-case basis, taking into account energy, environmental, and economic impacts, and other costs. Federal requirements pertaining to control non-attainment pollutants, or Lowest Achievable Emission Rate (LAER), were promulgated by U.S. EPA under 40 CFR 51.165 (a). This regulation defines LAER as the emissions limit based on either (1) the most stringent emission rate contained in State Implementation Plan, unless the source demonstrates the rate is not achievable; or (2) the most stringent emissions limitation that is achieved in practice. The federal LAER does not consider the cost impacts of the control implementation.

Per BAAQMD regulation 2-2-301, the application of BACT is required for any new or modified emissions unit if the new unit or modification results in an increase in permitted daily emissions greater than 10 pounds per day of any criteria pollutant. BACT is defined in Rule 2-2-206 as the most stringent emission limitation or control technique of the following:

- 206.1 The most effective emission control device or technique which has been successfully utilized for the type of equipment comprising such a source; or
- 206.2 The most stringent emission limitation achieved by an emission control device or technique for the type of equipment comprising such a source; or
- 206.3 Any emission control device or technique determined to be technologically feasible and cost-effective by the APCO; or
- 206.4 The most effective emission control limitation for the type of equipment comprising such a source which the EPA states, prior to or during the public comment period, is contained in an approved implementation plan of any state, unless the applicant demonstrates to the satisfaction of the APCO that such limitations are not achievable. Under no circumstances shall the emission control required be less stringent than the emission control required by any applicable provision of federal, state or District laws, rules or regulations.

The primary air emission sources for the proposed project are the two FP10 units. Each combined-cycle power block consists of one Siemens Flex Plant 10 (FP10). The steam produced by the each HRSG will be sent to an individual steam turbine generator (STG). The proposed power generation project will have emissions in excess of 10 pounds per day (lb/day) for NO_x, VOC, CO, PM₁₀, and SO_x. Therefore, BACT will be required for these pollutants.

The WPGS project proposes for NO_x control the use of Ultra dry-low-NO_x combustors and SCR with ammonia injection. This section contains the BACT analysis conducted for the proposed project, and demonstrates the proposed BACT limit for each CTG as shown in Table 8-1.

8.1 BACT Assessment Methodology

The BACT assessment conducted for the proposed project considered all NO_x and CO control technologies currently proposed or in use on large natural gas-fired combustion turbines. To identify feasible emission limits, several information sources were consulted, including the following:

- US EPA’s BACT/LAER Clearinghouse and updates;
- CARB’s BACT Clearinghouse database and CARB’s BACT Guidelines for Power Plant;

ATC/PTO Application Willow Pass Generating Station

- South Coast Air Quality Management District (SCAQMD) BACT Guidelines Manual;
- BAAQMD BACT Guidelines Manual; and
- Recent CEC Applications for Certification;

Table 8-2 lists the BACT guidelines from BAAQMD that are applicable to the FP10s.

The project must comply with the requirements of the BAAQMD's permit regulations requiring the application of the Best Available Control Technology (BACT) to control air emissions. To comply with the BAAQMD's BACT requirements for oxides of nitrogen (NO_x), the project's design includes ultra low NO_x combustion controls on the gas turbines and selective catalytic reduction (SCR) to control NO_x emissions. To comply with BAAQMD's BACT requirements for carbon monoxide (CO) and VOC, a CO oxidation catalyst will be employed.

8.2 NO_x Control Technologies

Based on a review of materials described above, the following NO_x emission control technologies are considered for the project. Potential NO_x control technologies for combustion gas turbines include the following:

Combustion controls

- Dry combustion controls
- Wet combustion controls
- Catalytic combustors (e.g., XONON)

Post-combustion controls

- Selective catalytic reduction (SCR)
- Selective non-catalytic reduction (SNCR)
- Non-selective catalytic reduction (NSCR)
- EMxTM (SCONO_xTM)

The technical feasibility of available NO_x control technologies is discussed below.

8.2.1 Dry Combustion Controls

Combustion modifications that lower NO_x emissions without wet injection include lean combustion, reduced combustor residence time, lean premixed combustion, and two-stage rich/lean combustion. Lean combustion uses excess air (greater than stoichiometric air-to-fuel ratio) in the combustor's primary combustion zone to cool the flame, thereby reducing the rate of thermal NO_x formation. Reduced combustor residence times are achieved by introducing dilution air between the combustor and the turbine sooner than with standard combustors. The combustion gases are at high temperatures for a shorter time, which also has the effect of reducing the rate of thermal NO_x formation. Dry ultra low NO_x combustion would be used on the Siemens FP10 gas turbines for this project.

8.2.2 Wet Combustion Controls

Steam or water injection directly into the turbine combustor is one of the most common NO_x control techniques. These wet injection techniques lower the peak flame temperature in the combustor, reducing the formation of thermal NO_x. The injected water or steam exits the turbine as part of the exhaust. Although the lower peak flame temperature has a beneficial effect on NO_x emissions, it can also reduce combustion efficiency and prevent complete combustion. As a

ATC/PTO Application Willow Pass Generating Station

result, emissions of carbon monoxide (CO) and volatile organic compounds (VOCs) may increase as water/steam injection rates increase.

Water and steam injection have been in use on both oil- and gas-fired combustion turbines in all size ranges for many years, so these NO_x control technologies are generally considered technologically feasible and widely available. Since dry low NO_x combustion controls are used in the Siemens FP10 gas turbines and are more effective than water injection, water injection is not considered for this project.

8.2.3 Catalytic Combustors

Catalytic combustors use a catalytic reactor bed mounted within the combustor to burn a very lean fuel-air mixture. This technology has been commercially demonstrated under the trade name XONON in a 1.5-MW natural gas-fired combustion turbine in Santa Clara, California. The technology has not been announced as being commercially available for the engines used at WPGS. No turbine vendor, other than Kawasaki, has indicated the commercial availability of catalytic combustion systems at the present time and the largest size is 18 MW. Therefore, catalytic combustion controls are not commercially available in the size range for this specific project and are not discussed further.

8.2.4 Selective Catalytic Reduction (SCR)

Selective catalytic reduction is a post-combustion technique that controls both thermal and fuel-bound NO_x emissions by reducing NO_x with a reagent (generally ammonia or urea) in the presence of a catalyst to form water and nitrogen. NO_x conversion is sensitive to exhaust gas temperature, and performance can be limited by contaminants in the exhaust gas that may mask the catalyst (sulfur compounds, particulates, heavy metals, and silica). SCR is used in numerous gas turbine installations throughout the United States, almost exclusively in conjunction with other wet or dry NO_x combustion controls. SCR requires the consumption of a reagent (ammonia or urea) and requires periodic catalyst replacement. Estimated levels of NO_x control are in excess of 90 percent. SCR would be used on this project in conjunction with the dry ultra low NO_x combustion controls on the FP10 gas turbine.

8.2.5 Selective Non-Catalytic Reduction (SNCR)

Selective non-catalytic reduction (SNCR) involves injection of ammonia or urea with proprietary conditioners into the exhaust gas stream without a catalyst. SNCR technology requires gas temperatures in the range of 1,200°F to 2,000°F and is most commonly used in boilers. Some form of exhaust gas reheat, such as additional fuel combustion, would be required to achieve exhaust temperatures compatible with SNCR operations, and this requirement makes SNCR technologically infeasible for WPGS.

8.2.6 Nonselective Catalytic Reduction (NSCR)

Nonselective catalytic reduction (NSCR) uses a catalyst without injected reagents to reduce NO_x emissions in an exhaust gas stream. NSCR is typically used in automobile exhaust and rich-burn stationary internal combustion (IC) engines, and employs a platinum/rhodium catalyst. NSCR is effective only in a stoichiometric or fuel-rich environment where the combustion gas is nearly depleted of oxygen, and this condition does not occur in turbine exhaust where the oxygen concentrations are typically between 14 and 16 percent. For this reason, NSCR is not technologically feasible for the WPGS.

ATC/PTO Application Willow Pass Generating Station

8.2.7 EMx™

EMx™ is a proprietary catalytic oxidation and adsorption technology that is marketed by EmeraChem (formerly marketed as SCONOX™ by Goal Line Technologies) that uses a single catalyst for the control of NO_x, CO, and VOC emissions. The catalyst is a monolithic design, made from a ceramic substrate with both a proprietary platinum-based oxidation catalyst and a potassium carbonate adsorption coating. The catalyst simultaneously oxidizes NO to NO₂, CO to CO₂, and VOCs to CO₂ and water, while NO₂ is adsorbed onto the catalyst surface where it is chemically converted to and stored as potassium nitrates and nitrites. The EMx™ potassium carbonate layer has a limited adsorption capability and requires regeneration approximately every 12 to 15 minutes in normal service. Each regeneration cycle requires approximately 3 to 5 minutes. At any point in time, approximately 20 percent of the compartments in an EMx™ system would be in regeneration mode, and the remaining 80 percent of the compartments would be in oxidation/absorption mode.

There are serious questions about the probability of a successful application of the EMx™ technology for application to WPGS, as well as the levels of emission control that can be consistently achieved. The principal reason for these questions is the fact that the system has never been demonstrated on turbines as large as those proposed for the WPGS. Therefore, this technology is not considered feasible for WPGS. As discussed above, the project's design includes ultra low NO_x combustion controls on the gas turbines and selective catalytic reduction (SCR) to comply with the BAAQMD's BACT requirements for NO_x.

8.3 *CO and VOC Control Technologies*

BACT for CO emissions from all power blocks will be achieved by using oxidation catalysts as a post-combustion control technology to reduce CO emissions to 3.0 ppmvd, corrected to 15 percent O₂. BAAQMD's BACT determinations indicate that the current BACT for combined-cycle combustion turbines is at 4.0 ppmvd CO (at 15 percent O₂). Therefore, the proposed combustion turbines will meet the BACT requirements for CO.

As shown on the BACT determinations listed on BAAQMD's website, BACT for VOC emissions will be achieved by use of oxidation catalysts as a post-combustion control technology to reduce VOC emissions to 2.0 ppmvd for each of the FP!0 units. As noted above, use of control technology will also enable each of the proposed combustion turbines to reduce CO emissions below the BACT requirements for CO (3.0 ppmvd, corrected to 15 percent O₂).

8.4 *SO₂ Control Technologies*

BAAQMD BACT Guideline 89.1.6 specifies that the BACT requirement for SO₂ emissions from combined-cycle combustion turbines with an output rating of ≥ 40 MW is the exclusive use of clean-burning natural gas with a sulfur content of < 1.0 grains per 100 scf. The proposed turbines will exclusively burn pipeline-quality natural gas that will be delivered by PG&E with an expected average sulfur content of 0.40 grains per 100 scf, which will result in minimal SO₂ emissions.

8.5 *PM₁₀ Control Technologies*

BACT for PM₁₀ is the exclusive use of pipeline-quality natural gas. The proposed turbines will exclusively burn pipeline-quality natural gas that will be delivered by PG&E. Therefore, the proposed combustion turbines will meet the BACT requirements for PM₁₀.

ATC/PTO Application
Willow Pass Generating Station

8.6 *Fugitive Dust Control*

Other controls that will be implemented at the WPGS site include best achievable control measures (BACM) to minimize dust emissions during the construction period. It is expected that the CEC license will impose Conditions of Certification on construction activities that will require the use of water or chemical dust suppressants to minimize PM₁₀ emissions and other measures to prevent visible particulate emissions, as also required by BAAQMD Regulation 6.

**ATC/PTO Application
Willow Pass Generating Station**

**Table 8-1
Summary of Proposed BACT**

Pollutant	Control Technology	Concentration
FP10 Units		
NO _x	Ultra low NO _x burner, SCR	2.0 ppmvd (1-hour average) at 15 percent O ₂
CO	Catalytic oxidation	3.0 ppmvd at 15 percent O ₂
VOC	Catalytic oxidation	2.0 ppmvd at 15 percent O ₂
SO ₂	Pipeline quality natural gas	N/A
PM ₁₀	Pipeline quality natural gas	N/A
Ammonia slip	Operational limitation	5.0 ppmvd at 15 percent O ₂

Notes:

BACT = Best Available Control Technology
 CO = carbon monoxide
 NA = not applicable
 NO_x = nitrogen oxides
 O₂ = oxygen

PM₁₀ = particulate matter less than or equal to 10 microns in diameter
 ppm = parts per million
 SCR = Selective catalytic reduction
 VOC = Volatile organic compounds
 SO₂ = sulfur dioxide

**ATC/PTO Application
Willow Pass Generating Station**

Table 8-2 BACT Determination for the WPGS Emission Sources		
Determination #	BAAQMD BACT Guideline 89.1.6	
Turbine Category	Combined-Cycle (≥ 40 Megawatts)	
Pollutant	BACT	Typical Technology
	1. Technologically Feasible/Cost Effective	
	2. Achieved in Practice	
POC	1. n/d	1. n/d
	2. 2.0 ppm, Dry at 15%O ₂	2. Oxidation Catalyst, or Efficient Dry Low-NO _x Combustors
NO _x	1. 2.0 ppm, Dry at 15% O ₂	1. SCR+ Low NO _x Combustors, or Water or Steam Injection, or a SCONOX System
	2. 2.5 ppmv, Dry at 15%O ₂ (2.0 ppm achieved in practice for 50 MW LM6000 combined cycle unit.)	2. SCR+ Dry Low-NO _x Combustors
SO ₂	1. n/d	1. n/d
	1. Natural Gas Fuel (sulfur content not to exceed 1.0 grain/100 scf)	2. Exclusive use of CPUC-regulated grade natural gas
CO	1. n/d	1. n/d
	2. 4.0 ppm, Dry @15% O ₂	2.. Oxidation Catalyst
PM ₁₀	1. n/d	1. n/d
	2. Natural Gas Fuel (sulfur content not to exceed 1.0 grain/100 scf)	2. Exclusive use of PUC-regulated grade natural gas
NPOC	1. n/a	1. n/a
	2. n/a	2. n/a
Notes: BAAQMD = Bay Area Air Quality Management District BACT = Best Available Control Technology CO = carbon monoxide FP10 = Flex Plant 10 unit NO _x = nitrogen oxide(s) NPOC = non-precursor organic compound PM ₁₀ = particulate matter less than 10 microns in diameter POC = precursor organic compound SO ₂ = sulfur dioxide		

ATC/PTO Application
Willow Pass Generating Station

9.0 HEALTH RISK ASSESSMENT

This section describes the evaluation of potential public health risks due to demolition, construction, and operation of the proposed WPGS power generation facility and the methodology and results of the HRA. A formal modeling protocol describing technical aspects of the HRA, as well as the criteria pollutant modeling described in Section 7.0, was submitted to BAAQMD and CEC in April, 2008 (URS 2008). The protocol and the comments received on that document from BAAQMD have guided the development of the analyses presented in this section.

For purposes of this HRA, a significant impact is defined as a maximum incremental cancer risk greater than 10 in 1 million, a chronic total hazard index (THI) greater than 1.0, or an acute THI greater than 1.0. Also, uncertainties in the HRA are discussed and other potential health impacts of the project are described.

9.1 Public Health Impact Assessment Approach

The potential human health risks posed by the project's emissions were assessed using procedures consistent with the BAAQMD Risk Assessment Procedures for Regulation 2, Rule 5 (BAAQMD, 2005a), BAAQMD Air Toxics NSR Program Health Risk Screening Analysis (HRSA) Guidelines (BAAQMD, 2005b), Office of Environmental Health Hazard Assessment (OEHHA) Air Toxics Hot Spots Program Risk Assessment Guidelines (Cal-EPA/OEHHA, 2002) and guidance from BAAQMD staff. The BAAQMD and OEHHA guidelines were developed to provide risk assessment procedures, as required under the Air Toxics Hot Spots Information and Assessment Act of 1987, Assembly Bill 2588 (Health and Safety Code Sections 44360 et seq.). The Hot Spots law established a statewide program to inventory air toxics emissions from individual facilities, as well as guidance for execution of risk assessments and requirements for public notification of potential health risks.

As recommended by BAAQMD staff and OEHHA Guidelines, the California Air Resources Board (CARB) Hotspots Analysis and Reporting Program (HARP) was used to perform an OEHHA Tier 1 HRA for the project. HARP includes two modules: a dispersion module and a risk module. The HARP dispersion module incorporates the USEPA ISCST3 air dispersion model, and the HARP risk module implements the latest Risk Assessment Guidelines developed by OEHHA. For consistency with the criteria pollutant modeling, the dispersion modeling was conducted with AERMOD. CARB has created a beta version software package, HARP File Converter, to convert AERMOD dispersion results into a format that can be read into the HARP risk module. Thus, HARP with AERMOD was used for this HRA.

The HRA was conducted in four steps using the HARP:

1. Hazard identification and emission quantification
2. Exposure assessment
3. Dose-response assessment
4. Risk characterization

First, hazard identification was performed to determine the potential health effects that could be associated with WPGS emissions. The purpose was to identify whether pollutants emitted during WPGS operation could be characterized as potential human carcinogens, or associated with other types of adverse health effects. Based on BAAQMD and OEHHA guidelines, a list of pollutants with potential cancer and non-cancer health effects associated with the emissions from the project has been constructed in Table 9-1. Note that the two FP10 gas turbines and the one natural gas-

ATC/PTO Application Willow Pass Generating Station

fired preheater are the only stationary sources of toxic air contaminants (TACs) associated with normal WPGS operations.

Second, an exposure assessment was conducted to estimate the extent of public exposure to the project emissions. Public exposure is quantified based on the predicted maximum short- and long-term ground-level concentrations resulting from project emissions, the exposure pathway(s), and the duration of exposure to those emissions. Dispersion modeling was performed using the AERMOD model to estimate the highest ground-level concentrations near the project site. The methods used in the dispersion modeling were consistent with the approach described in Section 7 and the modeling protocol submitted for the project to CEC and BAAQMD (URS, 2008).

Third, a dose-response assessment was performed in HARP incorporating the maximum 1-hour and annual ground level concentrations predicted by AERMOD to characterize the relationship between pollutant exposure and the potential incidence of an adverse health effect in the exposed populations. The dose-response relationship is expressed in terms of potency factors for cancer risk and reference exposure levels (RELs) for acute and chronic non-cancer risks. The OEHHA guidelines provide potency factors and RELs for an extensive list of TACs, including those listed in Table 9-1. All exposure pathways were included in this analysis, except the beef/dairy pasture pathways, because no cattle were found to exist within 10 km of the project site. For the drinking water pathway, the Contra Loma and Antioch Municipal Water Reservoirs were included in the HRA. Fish consumption was assumed to come from Suisun Bay. For the calculation of cancer risk, the duration of exposure to project emissions was assumed to be 24 hours per day, 350 days per year, for 70 years, at all receptors, the default assumption in HARP. The cancer risk was calculated in HARP using the Derived (Adjusted) Method, and the chronic THI was calculated in HARP using the Derived (OEHHA) Method.

Fourth, risk characterization was performed to integrate the health effects and public exposure information and provide qualitative estimates of health risks resulting from project emissions. Risk modeling was performed using HARP to estimate cancer and non-cancer health risks due to project operational emissions. The HARP model uses OEHHA equations and algorithms to calculate health risks based on input parameters such as emissions, “unit” ground-level concentrations, and toxicological data.

A detailed descriptions of the model input parameters and the results of the HRA are provided in Section 9.4.

9.2 Construction Phase Emissions

Due to the relatively short duration of the project demolition and construction (i.e., 34 months), significant long-term public health effects are not expected to occur as a result of the TAC emissions resulting from these activities. Of air pollutants emitted during the construction period, diesel particulate matter (DPM) has the largest potential for adverse human health effects. DPM has been classified by CARB and OEHHA as a TAC and a carcinogen. However, the HRA assessment conducted for carcinogens is typically based on a continuous exposure of 70 years. Due to the short duration of the construction effort, significant carcinogenic health risks are not predicted for the construction period.

During the demolition of the existing structures within the PPP, some asbestos may be encountered. However, emissions of asbestos when structures are demolished will be less than significant due to the prior removal of all regulated asbestos-containing material in compliance with BAAQMD Regulation 11, Rule 2, Asbestos Demolition, Renovation, and Removal.

ATC/PTO Application
Willow Pass Generating Station

9.3 Operational Phase Emissions

Facility operations were evaluated to determine whether particular substances would be used or generated at the project site that could cause adverse health effects upon their release to the air. The only sources of TAC emissions associated with facility operations would be the two natural-gas-fired combustion turbine generators (CTGs) and the small fuel gas heater. The substances that would be emitted from facility operations with potential toxicological impacts are shown in Table 9-1. These air toxic species were identified in the list of emission factors published in *California Air Toxics Emission Factor (CATEF)* (CARB, 1996) and U.S. EPA AP-42 (U.S. EPA, 1995). In addition, potential emissions from ammonia slip from the turbine/heat recovery steam generator HRSG selective catalytic reduction (SCR) systems were included.

Worst-case estimates of annual turbine emissions of TACs were made by assuming that:

Each FP10 turbine would operate with a maximum higher heating value (HHV) fuel energy input rate of 2,271 MMBtu/hr (100 percent load, 20°F) for 4,383 hours per year.

The fuel gas heater will operate at a maximum HHV fuel energy input rate of 5 MMBtu/hr and will operate during every hour of turbine operation.

Model simulations to estimate both hourly and annual average impacts used the following stack parameters:

For the FP10 units, exhaust temperature and stack exhaust velocity values corresponding to 60 percent load operation at an ambient temperature of 94°F.

For the fuel gas heater, exhaust temperature and stack exhaust velocity values corresponding to heater operation at maximum capacity.

The turbine stack parameters were determined by the turbine screening modeling for criteria pollutants (see Section 7.1) to produce the highest ground-level impacts outside the project site. These stack parameters ensure that impacts from the HRA will not be underestimated for any operating condition.

Emission factors for natural-gas-fired combustion turbines were obtained from the CATEF database, supplemented by data on those substances that have controlled emissions reflecting a carbon monoxide (CO) oxidizing catalyst in Table 3.4-1 of the background document for AP-42, Section 3.1. The emission factors and estimated maximum hourly and annual emissions from each FP10 combined-cycle CTG/HRSG were summarized in Table 4.5. Emission factors for the natural gas-fired heater were also obtained from the CATEF database and are utilized in the estimation of maximum hourly and annual TAC emissions from the fuel gas heater in Table 4-7. Annual emissions of federally regulated HAPS are summarized in Table 4-8.

9.4 Model Input Parameters

The HRA was conducted using worst-case turbine emissions (short-term and long-term). Cancer and chronic non-cancer health effects were evaluated using the HARP model with estimated annual average emission rates for both FP10 turbines and the fuel gas heater. Acute non-cancer health effects were analyzed based on the maximum hourly emissions from both turbines and the fuel gas heater.

ATC/PTO Application Willow Pass Generating Station

Dispersion modeling was performed using the AERMOD model and methods consistent with the approach described in Section 7.1 e.g., building downwash and meteorological input data), and the modeling protocol submitted for review to CEC and BAAQMD (URS, 2008). The AERMOD model is run with unit emission rates, 1 gram per second emissions, to calculate the concentration of TACs per unit emission rate due to each source. HARP then uses this information along with the estimated maximum source emission rates for specific TAC compounds (as described above) to calculate ground-level concentrations for each chemical species.

Meteorological data for the years 2002 through 2005 (the same years used in the air quality modeling analysis described in Section 7.1) were used in the HRA. Risk values were modeled for all sensitive receptors within 3 miles of the project site and at all grid and census receptors within 6 miles of the site. The same grid and refined hill receptors used in the air quality modeling were used in the HRA (see Section 7.1 for more details). The grid receptors extend 10 km in all directions from the project boundary, including receptors spaced every 25 meters (m) along the facility property line. Additional receptors were added on the hill approximately 3 km to the southwest of the project to ensure accurate pollutant concentrations were estimated by AERMOD in this area of complex terrain. To ensure that the maximum potential risks resulting from proposed project emissions would be addressed, all receptors were treated as sensitive receptors, except the offsite worker receptors. Receptors were placed at the nearest 27 offsite worker locations (see Table 9-1).

Toxicological data, cancer potency factors, and RELs for specific chemicals are built into the CARB's HARP model. The pollutant-specific cancer potency factors and RELs used in the HRA are listed in Table 9-2. The HARP model uses the toxicological data in conjunction with the other input data described above to perform health risk estimates based on OEHHA equations and algorithms.

9.5 Calculation of Health Effects

Adverse health effects are expressed in terms of cancer or non-cancer health risks. Cancer risk is typically reported as "lifetime cancer risk," which is the estimated maximum increase in the risk of developing cancer caused by long-term exposure to a pollutant suspected of being a carcinogen. The calculation of cancer risk conservatively assumes an individual is exposed continuously to the maximum pollutant concentrations 24 hours per day for 70 years. Although such continuous lifetime exposure to maximum TAC levels is highly unlikely, the goal of the approach is to produce a conservative worst-case estimate of potential cancer risk. All receptors except the worker receptors were treated as sensitive and the cancer risk was estimated as described above. The cancer risk at the worker locations was calculated based on a 40 year exposure, lower breathing rate, and the assumption that the offsite workers worked 8 hours per day, 5 days per week.

Non-cancer risk is typically reported as a THI. The THI is calculated for each target organ as a fraction of the maximum acceptable exposure level or REL for an individual pollutant. The REL is generally the level at (or below) which no adverse health effects are expected. The THIs are calculated for both short-term (acute) and long-term (chronic) exposures to non-carcinogenic substances by adding the ratios of predicted concentrations to RELs for all pollutants.

Both cancer and non-cancer risk estimates produced by the HRA represent incremental risks (i.e., risks due to the modeled sources only), and do not include potential health risks posed by existing background concentrations. The HARP model performs all of the necessary calculations to

ATC/PTO Application Willow Pass Generating Station

estimate the potential lifetime cancer risk and the acute and chronic non-cancer THIs due to the project's TAC emissions.

9.6 Health Effects Significance Criteria

Various state and local agencies provide different significance criteria for cancer and non-cancer health effects. For the project, the BAAQMD guidelines provide the significance criteria for potential cancer and non-cancer health effects due to project-related emissions. BAAQMD Regulation 2, Rule 5 states that if a HRA for a project predicts a cancer risk of greater than 1.0 in one million (1.0×10^{-6}), and/or a chronic hazard index greater than 0.20, then Toxic Best Available Control Technology (TBACT) must be applied. For carcinogenic health effects, an exposure is considered significant when the predicted increase in lifetime cancer risk exceeds 10 in 1 million (1.0×10^{-5}). For non-carcinogenic acute and chronic health effects, an exposure that affects each target organ is considered significant when the corresponding THI exceeds a value of 1.0.

9.7 Estimated Lifetime Cancer Risk

The maximum incremental cancer risk resulting from project emissions was estimated to be 0.086 in 1 million, at a location approximately 1 kilometer northeast of the WPGS property boundary (receptor coordinates 598,400 m east, 4,211,000 m north¹). The peak cancer risk predicted at a sensitive receptor was 0.056 in 1 million, at Kids Jump for Fun Center approximately 4 kilometers southwest of the project (594,105 m east, 4,207,202 m north). The maximum incremental cancer risk at an offsite worker receptor was estimated to be 0.037 in 1 million, at the Dockside Market about 2,313 feet east of the Unit 1 FP-10 turbine/HRSG stack (at 597,874.94 m east, 4,210,338 m north). Table 9-3 presents the detailed cancer risk results of the HRA for the project operations.

The estimated cancer risks at all locations are well below the significance criterion of 10 in 1 million and the TBACT threshold of 1 in 1 million. Thus, the project emissions are expected to pose a less-than-significant increase in terms of carcinogenic health risk. All HARP and AERMOD model files are provided electronically on a DVD that is supplied with this application.

9.8 Estimated Chronic and Acute Total Hazard Indices

The maximum chronic THI resulting from project's operational emissions was estimated to be 0.004 at the same receptor the peak cancer risk occurs, a location approximately 1 kilometer northeast of the WPGS property boundary (receptor coordinates 598,400 m east, 4,211,000 m north). The maximum predicted chronic THI at a sensitive receptor due to TAC emissions of the project was 0.003, at Kids Jump for Fun Center approximately 4 kilometers southwest of the project (594,105 m east, 4,207,202 m north). The maximum incremental chronic THI at an offsite worker receptor was estimated to be 0.014 at the Dockside Market about 2,313 feet east of the Unit 1 FP-10 turbine/HRSG stack (at 597,874.94 m east, 4,210,338 m north).

The maximum acute THI resulting from the project's operational emissions was estimated to be 0.142 at a location approximately 7 kilometers east-southeast of the WPGS property boundary (604,262 m east, 4,208,066 m north). The maximum predicted acute THI at a sensitive receptor due to TAC emissions of the project was 0.124, at Kids Jump for Fun Center approximately 4 kilometers southwest of the project (594,105 m east, 4,207,202 m north). The maximum

¹ Coordinates are provided in accordance with the Universal Transverse Mercator and North American Datum, 1927, Zone 10.

ATC/PTO Application Willow Pass Generating Station

predicted acute THI at an offsite worker receptor due to TAC emissions of the project was 0.045 at the City of Pittsburg Marina Harbormaster office, approximately 2,710 feet east of the FP-10 Unit 1 stack (597,964 m east, 4,210,262 m north). Table 9-3 summarizes the maximum non-cancer risks predicted by the HRA for the project operations.

The estimated maximum chronic and acute THIs are well below the significance criterion of 1.0 and the TBACT chronic threshold of 0.2 at all receptors. Thus, the project emissions of non-carcinogenic TACs would not be expected to pose a significant risk.

9.9 Uncertainty in the Public Health Impact Assessment

Sources of uncertainty in the results of an HRA include emissions estimates, dispersion modeling, exposure characteristics, and extrapolation of toxicity data in animals to humans. For this reason, assumptions used in HRAs are typically designed to provide sufficient health protection to avoid underestimation of risk to the public. Some sources of uncertainty applicable to this HRA and the procedures and assumptions used to ensure health-protective results are discussed below.

The turbine emission rates were derived using vendor data regarding ammonia slip rates and emission factors from CATEF and AP-42 for the other air toxics. Both the short- and long-term turbine emissions estimates were developed assuming that both gas turbines and the fuel gas preheater would operate continuously at the same time and at the maximum fuel energy input rate. Under actual operating conditions, the turbines and fuel gas preheater would typically operate fewer hours per year and at lower loads. Consequently, the emissions used for this HRA are likely to be higher than what would be experienced under normal plant operation.

Dispersion models approved for regulatory applications contain assumptions that lead to overprediction of ground-level concentrations. For example, the modeling performed in the HRA assumed a conservation of mass (i.e., all of the pollutants emitted from the sources remained in the atmosphere while being transported downwind). During the transport of pollutants from sources toward receptors, none of the emitted material was assumed to be removed from the source plumes by means of chemical reactions or losses at the ground surface due to reactions, gravitational settling, or turbulent impaction. In reality, these mechanisms work to reduce the level of pollutants remaining in the atmosphere during plume travel.

The exposure characteristics assessed in the HRA included the assumption that residents would be exposed to turbine emissions continuously at the same location for 24 hours per day, 350 days per year, for 70 years. It is extremely unlikely that any resident would actually experience such exposure to the maximum predicted concentrations of TACs over a period of this length. The conservative exposure assumption leads to overpredicted risk estimates in the HRA modeling.

The toxicity data used in the HRA contain uncertainties due to the extrapolation of health effects data from animals to humans. Typically, safety factors are applied when doing the extrapolation. Furthermore, the human population is much more diverse, both genetically and culturally, than bred experimental animals. The intraspecies variability is expected to be much greater among humans than in laboratory animals. With all of the uncertainty in the assumptions used to extrapolate toxicity data, significant measures are taken to ensure that sufficient health protection is built into the available health effects data.

Conservative measures to compensate for all of these uncertainties and ensure that potential health risks are not underestimated are compounded in the final HRA predictions. Therefore, the actual risk numbers are expected to be well below the values presented in this analysis.

ATC/PTO Application
Willow Pass Generating Station

9.10 *Criteria Pollutants*

The dispersion of the project's emissions of criteria pollutants (nitrogen dioxide, CO, sulfur dioxide, and particulate matter with an aerodynamic diameter of 10 and 2.5 microns or less [PM₁₀ and PM_{2.5}]) was modeled, and an evaluation of their impacts on air quality is presented in Section 7.0. The federal and state AAQS set limits on the allowable levels of air pollutants in the ambient air necessary to protect public health. The results of the air quality analysis show that the project would not cause a violation of any state or federal AAQS and would not significantly contribute to existing violations of the standards. Therefore, no significant adverse health effects are anticipated to result from the project's criteria pollutant emissions.

ATC/PTO Application
Willow Pass Generating Station

Table 9-1				
Offsite Worker Receptors Considered in the HRA				
Category	UTM Coordinates		Specific Receptor	Address
	NAD27 X	NAD27 Y		
PPP	596949	4210620	Unit 7 Power Building	
PPP	597058	4210614	Units 5&6 Power Building	
PPP	596940.22	4210466.119	Onsite Control Building	
PPP	596688.31	4210140.523	Gas Building	
Church	597446.54	4210060.43	All American Born Church	278 Odessa Ave, Pittsburg, CA 94565
School	597408.74	4210013.819	St. Peter Martyr Elem School	425 W 4th St, Pittsburg, CA 94565
Church	597505.4	4210454.975	Stewart Memorial Methodist	580 Front St
Church	597474.43	4210184.842	First Baptist	204 Odessa Ave
Church	597096.92	4209521.27		
Marina	597963.93	4210261.417	City of Pittsburg Harbormaster, Marina	51 Marina Blvd #E
Warehouse	597052.21	4209655.481		
Warehouse	597038.86	4209514.58		
Warehouse	596998.45	4209584.47		
Warehouse	596949.28	4209629.8		
Warehouse	596944.42	4209576.359		
Warehouse	596865.06	4209673.21	Fernandes Auto	650 W 10th
Warehouse	596811.94	4209588.728		
Warehouse	596877.17	4209540.098		
Warehouse	596918.57	4209442.198		
Warehouse	597051.18	4209442.599		
Warehouse	597198.26	4209416.17	Femin's Auto Body Shop	487 W 10th
Warehouse	596984.54	4209568.44	Auto Glass Center	580 W 10th
Warehouse	597209.02	4209430.69	David's Auto Repair	489 W 10th
Warehouse	596923.89	4209518.309	Jim's Auto Services	586 W 10th
Warehouse	597104.4	4209595.291	Alb, Inc.	552 W 10th
Store	597874.95	4210387.958	Dockside Market	27 Marina Blvd
Store	597530.54	4209465.534	La Aurora Market	290 W 10th

ATC/PTO Application
Willow Pass Generating Station

Table 9-2
Toxicity Values Used To Characterize
Health Risks for TACs Emitted by WPGS Emission Sources

Compound	Sources of Emissions	Inhalation Cancer Potency Factor (mg/kg-day)⁻¹	Chronic REL (µg/m³)	Acute REL (µg/m³)
Ammonia	Turbines	—	2.0E+02	3.2E+03
1,3-Butadiene	Turbines	6.0E-01	2.0E+01	—
Acetaldehyde	Turbines and Preheater	1.0E-02	9.0E+00	—
Acrolein	Turbines and Preheater	—	6.0E-02	1.9E-01
Benzene	Turbines and Preheater	1.0E-01	6.0E+01	1.3E+03
Ethylbenzene ¹	Turbines and Preheater	8.7E-03	2.0E+03	—
Formaldehyde	Turbines and Preheater	2.1E-02	3.0E+00	9.4E+01
Hexane	Turbines	—	7.0E+03	—
Propylene	Turbines and Preheater	—	3.0E+03	—
Propylene oxide	Turbines	1.3E-02	3.0E+01	3.1E+03
Toluene	Turbines and Preheater	—	3.0E+02	3.7E+04
Xylenes	Turbines and Preheater	—	7.0E+02	2.2E+04
Polycyclic Aromatic Hydrocarbons (PAHs)				
Naphthalene	Turbines and Preheater	1.2E-01	9.0E+00	—
Benzo(a)anthracene	Turbines and Preheater	3.9E-01	—	—
Benzo(a)pyrene	Turbines and Preheater	3.9E+00	—	—
Benzo(b)fluoranthene	Turbines and Preheater	3.9E-01	—	—
Benzo(k)fluoranthene	Turbines and Preheater	3.9E-01	—	—
Chrysene	Turbines and Preheater	3.9E-02	—	—
Dibenz(a,h)anthracene	Turbines and Preheater	4.1E-00	—	—
Indeno(1,2,3-cd)pyrene	Turbines and Preheater	3.9E-01	—	—
Source: Cal-EPA/OEHHA, 2005 and 2007				
Notes:				
¹ In November 2007, OEHHA adopted the new ethylbenzene cancer potency factor presented above, but the HARP risk assessment module has not yet been updated to incorporate the new cancer risk factor for this pollutant.				
— = not applicable				
mg/kg-day = milligrams per kilogram per day				
µg/m ³ = micrograms per cubic meter				
REL = reference exposure levels				

ATC/PTO Application
Willow Pass Generating Station

Table 9-3
Estimated Cancer Risk and Acute and Chronic Non-Cancer
Total Hazard Indices Due to WPGS Emissions of TACs

Location	Cancer Risk	Chronic Hazard Index	Acute Hazard Index
Point of maximum impact	0.074 excess risk in 1 million	0.003 total hazard index	0.072 total hazard index
Peak risk at a sensitive receptor	0.023 excess risk in 1 million	0.001 total hazard index	0.063 total hazard index
Peak risk at an off-site worker receptor	0.037 excess risk in a million	0.014 total hazard index	0.045 total hazard index

**ATC/PTO Application
Willow Pass Generating Station**

Appendix A. References

ATC/PTO Application
Willow Pass Generating Station

- Auer, August H., Jr., 1978. American Meteorological Society. *Journal of Applied Meteorology*, 17(5): 636-643. "Correlation of Land Use and Cover with Meteorological Anomalies," May 1978.
- Breiner, Joan, Benjamin Gimeno, and Mark Fenn, 2007. "Calculation of Theoretical and Empirical Nutrient N Critical Loads in the Mixed Conifer Ecosystems of Southern California," March 2007.
- CARB (California Air Resources Board), 2000. *Risk Management Guidance for the Permitting of New Stationary Source Diesel-Fueled Engines*, October 2000.
- CARB (California Air Resources Board), 2007. *Off-Road Mobile Source Emission Factors, Off-Road Emissions Inventory Program*.
- CEC (California Energy Commission), 1997. "Regulations Pertaining to the Rules of Practice and Procedure and Plant Site Certification." Title 20, California Code of Regulations. Chapters 1, 2, and 5.
- CEC (California Energy Commission), 2006. Rules of Practice and Procedure and Power Plant Site Certification Regulations Revisions, 04-SIT-2, December 14, 2006.
- Notar, John, 2008. Email correspondence from John Notar, National Park Service Air Resources Division, to Julie Mitchell, URS Corporation, dated April 24, 2008.
- NPS (National Park Service), 2007. Particulate Matter Speciation: <http://www2.nature.nps.gov/air/permits/ect/index.cfm>.
- SCAQMD (South Coast Air Quality Management District), 1993. *CEQA Air Quality Handbook*, April 1993.
- URS, 2008. Air Quality Modeling Protocol for the Willow Pass New Generation Project Pittsburg, California. Prepared on behalf of Mirant California LLC for submittal to Bay Area Air Quality Management District, California Energy Commission and National Park Service, April 22.
- U.S. EPA (U.S. Environmental Protection Agency), 1990. New Source Review Workshop Manual Prevention of Significant Deterioration and Nonattainment Area Permitting (Draft), Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711, October 1990.
- U.S. EPA (U.S. Environmental Protection Agency), 1992. *Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised*. EPA-454/R-92-019. October 1992.
- U.S. EPA (U.S. Environmental Protection Agency), 1995. *Building Profile Input Program-Prime*. Version 98086.
- U.S. EPA (U.S. Environmental Protection Agency), 1995. *Screen3 Model User's Guide*. EPA-454/B-95-004. September 1995.

ATC/PTO Application
Willow Pass Generating Station

- U.S. EPA (U.S. Environmental Protection Agency), 2000. Meteorological Monitoring Guidance for Regulatory Modeling Applications, February 2000.
- U.S. EPA (U.S. Environmental Protection Agency), 2003. *Guideline on Air Quality Models*. 40 CFR51 Appendix W, July 1, 2003, Edition.
- U.S. EPA (U.S. Environmental Protection Agency), 2004. *User's Guide for the AMS/EPA Regulatory Model-AERMOD*. (EPA-454/B-03-001), September 2004.
- U.S. EPA (U.S. Environmental Protection Agency), 2005. *AERMOD Implementation Guide*, September 2005.
- U.S. EPA (U.S. Environmental Protection Agency), 2006a. Addendum to *User's Guide for the AMS/EPA Regulatory Model-AERMOD*, December 2006.
- U.S. EPA (U.S. Environmental Protection Agency), 2006b. U.S. EPA AirData.
- U.S. EPA (U.S. Environmental Protection Agency), 2008a. *AERMOD Implementation Guide*,. January 2008.
- U.S. EPA (U.S. Environmental Protection Agency), 2008b. *AERSURFACE User's Guide*, January 2008.
- Western Regional Climate Center, 2007. Desert Research Institute, Las Vegas, NV (<http://www.wrcc.dri.edu/>)




**ATC/PTO Application
Willow Pass Generating Station**

Appendix B. Additional Plot Plan Figures


Appendix B Additional Plot Plan Figures

Willow Pass Generating Station Project



Appendix B Additional Plot Plan Figures

Willow Pass Generating Station Project



7/09/08 via .IT:Mirant\Pittsburg\Willow Pass\Graphics\ATC_Air Permits\B-2_Elevs_MBW.dwg

**ATC/PTO Application
Willow Pass Generating Station**

Appendix C. Emissions Calculations

Appendix C.1 Operational Emissions (Siemens Combined Cycle FP 10 Unit)

Willow Pass Generating Station Project

Turbine Operating Parameters

Ambient Temperature	UNITS	Winter Minimum (20°F / 90% RH)			Yearly Average (59°)			Summer Maximum (94°F)						
CTG Load Level	%	100%	85%	60%	100%	85%	60%	100%	100%	100%	100%	100%	85%	60%
Case No From Siemens Data		1	2	39	4	8	60	19	18	17	16			43
Evap Cooling Status	off / on	Off	Off	Off	Off	Off	Off	On	On	Off	Off	Off	Off	Off
Power Augmentation Status	off / on	Off	Off	Off	Off	Off	Off	On	Off	On	Off	Off	Off	Off
Stack Outlet Temperature	(°F)	350	346	343.7	340	337	328.7	338	348	333	341	346		323.3

Average Emission Rates from each Gas Turbine (lbs/hr/turbine) - Normal Operation

	UNITS	Winter Minimum (20°F / 90% RH)			Yearly Average (59°)			Summer Maximum (94°F)						
Net Power	kw	286,700	244,200	172,900	259,400	221,400	149,600	268,700	250,100	255,900	233,300	N/A		140,100.0
Heat Rate,	Btu/kWh (LHV)	7,135	7,330	8,250	7,160	7,410	8,455	7,115	7,130	7,020	7,185	N/A		8,580.0
Fuel Flow	MMBtu/hr (LHV)	2,046	1,790	1,426	1,857	1,641	1,265	1,912	1,783	1,796	1,676	1,509		1,202
Fuel Flow	MMBtu/hr (HHV)	2,271	1,987	1,583	2,062	1,821	1,404	2,122	1,979	1,994	1,861	1,674.6		1,334
Fuel Heating Value	Btu/scf	908	908	908	908	908	908	908	908	908	908	908.0		908.0
Oxygen	VOL%	12.3	12.4	12.8	12.3	12.5	12.7	10.9	12.0	11.1	12.3			12.8
CO ₂	VOL%	4.0	3.9	3.8	3.9	3.8	3.7	4.0	3.9	3.9	3.8			3.6
H ₂ O	VOL%	8.0	7.9	7.6	8.5	8.4	8.6	14.9	9.9	14.1	9.1			8.7
N ₂	VOL%	74.9	74.9	75.0	74.4	74.4	74.1	69.4	73.3	70.0	73.9			74.1
Ar	VOL%	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.9	0.8	0.9			0.9
Oxygen	lbm/hr	604,147.8	534,359.7	448,054.1	557,810.4	502,428.7	409,093.5	501,141.7	525,617.5	487,406.3	510,555.9	459,500.3		530,349.7
CO ₂	lbm/hr	267,228.7	232,086.9	182,164.7	242,994.2	213,078.2	161,725.3	250,167.8	233,504.7	170,789.3	159,522.8	143,570.5		150,639.2
H ₂ O	lbm/hr	220,485.3	191,262.8	149,961.9	217,605.1	191,070.1	155,590.9	386,375.4	242,824.1	617,906.9	378,451.1	340,606.0		359,376.2
N ₂	lbm/hr	3,215,827.9	2,822,939.8	2,307,879.6	2,950,136.9	2,629,121.3	2,085,751.8	2,799,994.9	2,801,704.9	3,066,324.5	3,069,151.4	2,762,236.2		3,073,372.2
Ar	lbm/hr	54,528.1	48,378.2	38,605.4	50,345.8	44,837.4	34,902.7	47,726.0	47,959.1	36,785.4	36,557.3	32,901.6		36,103.6
MW of exhaust gas	lb/lbmol	28.5	28.5	28.5	28.4	28.4	28.4	27.7	28.2	27.8	28.3	28.3		28.3
NO _x (@ 2.0 ppm)	lbm/hr	17.4	15.1	12.0	15.8	13.9	10.0	16.3	15.2	15.3	14.3	12.9		10.0
CO (@ 2.0 ppm)	lbm/hr	10.6	9.2	7.1	9.7	8.5	6.3	10.0	9.3	9.4	8.7	7.8		6.0
CO (@ 3 ppm)	lbm/hr	15.9	13.8	10.7	14.6	12.8	9.5	15.0	14.0	14.1	13.1	11.7		9.0
VOC (@ 2.0 ppm)	lbm/hr	6.2	5.4	4.1	5.6	5.0	3.6	5.8	5.4	5.4	5.0	4.5		3.5
SO ₂ (based on 0.4 gr total S / 100 scf)	lbm/hr	2.6	2.3	1.8	2.3	2.1	1.6	2.4	2.2	2.3	2.1	1.9		1.5
SO ₂ (based on 1.0 gr total S / 100 scf) worst-case	lbm/hr	6.4	5.6	4.5	5.8	5.2	4.0	6.0	5.6	5.6	5.3	4.7		3.8
PM ₁₀	lbm/hr	10.0	8.9	8.0	9.3	8.3	8.0	8.9	8.8	8.5	8.5	7.7		8.0
NH ₃ (@ 5 ppm slip)	lbm/hr	16.1	14.0	11.0	14.7	12.8	10.0	15.1	14.1	14.2	13.2	11.9		9.0
% of HC as VOC (using CO @ 3ppm)	%	28.1	28.1	27.8	27.8	28.2	27.6	27.9	27.9	27.7	27.7	27.7		28.0
Total Inerts	lbm/hr	4,363,324	3,828,197	3,129,789	4,018,750	3,580,309	2,847,064	3,985,700	3,851,272	3,800,335	3,675,203	3,307,683		2,731,651
Total	lbm/hr	4,363,392	3,828,256	3,129,837	4,018,812	3,580,364	2,847,107	3,985,764	3,851,332	3,800,395	3,675,259	3,307,733		2,731,692
Total Inerts	lbmol/hr	153,368	134,559	109,817	141,605	126,112	100,426	143,940	136,425	136,850	129,820	116,838		96,389
Total Inerts	ft ³ /min	1,511,297	1,319,398	1,073,724	1,378,149	1,222,758	963,566	1,397,371	1,341,016	1,320,217	1,265,033	1,145,639		918,497
Exit Velocity	fps	70.5	61.5	50.1	64.3	57.0	44.9	65.2	62.5	61.6	59.0	53.4		42.8

notes:

All turbine operating parameters and emissions data provided by Siemens based on expected operating parameters at the WPGS Site

Assumed average sulfur content in gas (for annual emission): 0.4 gr total S / 100 scf

Assumed average sulfur content in gas (for short term emissions): 1 gr total S / 100 scf

Assumed fuel heating value: 908 Btu/scf

HHV/LHV 1.11 ratio

Stack Diameter 21.33 ft

Appendix C.1 Operational Emissions (Siemens Combined Cycle FP 10 Unit)

Willow Pass Generating Station Project

Modeling Worst-Case 1 hr Emissions per Turbine

Pollutant	lb/hr/CT	g/sec/CT
NOx	38.7	4.9
CO	279.8	35.3
SO ₂	6.7	0.8
PM ₁₀	11.1	1.4
notes: Startup emissions represent worst case hr for NOx, CO, and SO ₂ and were used for the worst-case scenario SO ₂ emissions are based on 1 gr/100 scf		

Modeling Worst-Case 3 hr Emissions per Turbine

	(hr)	emission rate (lb/hr)	Emissions (lb/CT)
Total Hours of Operation	3.0		
Startup Duration	0.6		4.7
Shutdown Duration	0.0		0.0
Hours of Operation	2.4	6.4	15.4
SO₂ worst-case 3 hr emissions per turbine	20.1	lb/3 hr	
SO₂ worst-case 1 hr emissions per turbine	6.7	lb/hr	
SO₂ modeling worst-case emissions per turbine	0.8	g/sec	
notes: Only SO ₂ is considered for an average 3-hour Ambient Air Quality Standard. Operational emissions using "worst-case" (winter minimum - 20°F; 100% load) SO ₂ emissions are based on 1 gr/100 scf Worst-case 3 hr emissions assumes a start up of : 3 Worst-case 3 hr emissions assumes a shut down of : 0 Conservatively assumes 3 startups in a 3 hr period, no shut downs			

Appendix C.1 Operational Emissions (Siemens Combined Cycle FP 10 Unit)

Willow Pass Generating Station Project

Modeling Worst-Case 8 hr Emissions per Turbine

	(hr)	max emission rate (lb/hr)	Emissions (lb/8 hr/CT)
Total Hours of Operation	8.0		
Startup Duration	0.4		534.2
Shutdown Duration	0.1		135.4
Hours of Operation	7.5	15.9	119.0
CO worst-case 8 hr emissions per turbine	788.6	lb/8 hr	
	98.6	lb/hr	
	12.4	g/sec	
notes:			
Only CO is considered for an average 8-hour Ambient Air Quality Standard.			
Operational emissions using "worst-case" (winter minimum - 20°F; 100% load)			
Worst-case 8 hr emissions assumes a total start up of : 2			
Worst-case 8 hr emissions assumes a total shut down of : 1			

Modeling Worst-Case 24 Hour Emission Rate

SO₂ (lb/day/CT)	154.3
SO₂ (g/s/CT)	0.8
PM₁₀ (lb/day/CT)	243.0
PM₁₀ (g/s/CT)	1.3
Assumptions:	
Only SO2 and PM10 are considered for an average 24-hour Ambient Air Quality Standard.	
SO2 Conservative estimate: all 24 hrs of baseline operation are in winter minimum - 20°F; 100% load	
PM10 Conservative estimate: 24 hrs taken from worst-case daily below.	

Appendix C.1 Operational Emissions (Siemens Combined Cycle FP 10 Unit)

Willow Pass Generating Station Project

Worst-Case Daily Emissions per Turbine

Pollutant	Time in Start Up (hr)	Startup Emission Rate (lb/start)	Time in Shut Down (hr)	Shutdown Emission Rate (lb/start)	Time in Operation (hr)	Operational Emission Rate (lb/start)	Worst-Case Daily Emissions (lb/day/CT)	Modeling Worst-Case 24 Hr Emission (g/s/CT)
NOx	0.6	24.8	0.4	10.5	23.1	17.4	507.0	
CO	0.6	267.1	0.4	135.4	23.1	15.9	1,574.1	
VOC	0.6	12.7	0.4	5.2	23.1	6.2	196.6	
SO ₂	0.6	1.6	0.4	0.4	23.1	6.4	154.2	0.8
PM ₁₀	0.6	3.1	0.4	1.1	23.1	10.0	243.0	1.3

Assumptions:

For NOx, CO, VOC, SO₂ and PM₁₀-- emissions are calculated assuming:

Worst-case daily emissions assumes a total start up of : 3

Worst-case daily emissions assumes a total shut down of

: 3

Remainder of time is spent in operation at "worst-case" (winter minimum - 20°F; 100% load)

Appendix C.2 Process Heaters

Willow Pass Generating Station Project

Preheater - Emission Factors

Pollutant	Emission Factors		Emission Rate
	lbs/MCF/unit	lbs/MMBTU/unit	lbs/hr/unit
CO	35	0.034	0.17
NO _x	30.6	0.03	0.15
PM ₁₀	3	0.0029	0.015
SO ₂ (0.4 gr S/100 SCF)	1.14	0.0011	0.006
SO ₂ (1gr S/100 SCF)	2.85	0.0028	0.014
VOC	2.8	0.0027	0.014

note: these emission factors are from FIRE ver 6.25. Using "process heaters from natural gas" (SCC 3-10-004-04). The SCC# was obtained from <http://www.epa.gov/ttnchie1/eiip/techreport/volume02/ii10.pdf>. Except for Sox, which was calculated.

1020	BTU/SCF	conversion factor
5	MMBTU/hr	max heat input capacity

For Willow Pass

1	unit	number of Fuel Gas Heater, one for FP10
4,383	hours	number of hours FP10 is running

Modeling Worst-Case 1 hr Emissions per heater

pollutant	lbs/hr/unit	g/sec/unit
CO	0.172	0.0216
NO _x	0.150	0.0189
PM ₁₀	0.015	0.0019
SO ₂ (1gr S/100 SCF)	0.014	0.0018
VOC	0.014	0.0017

Appendix C.2 Process Heaters

Willow Pass Generating Station Project

Annual Emissions for the Fuel Gas Heater for FP10.

pollutant	lbs/yr/unit	tons/yr/unit	g/sec/unit
CO	752	0.376	0.01082
NO _x	657	0.329	0.00946
PM ₁₀	64.5	0.032	0.00093
SO ₂ (based on 0.4 gr total S / 100 scf)	24.5	0.012	0.00035
VOC	60.2	0.030	0.00087

Appendix C.3 Total Operational

Willow Pass Generating Station Project

Ave. Annual Emissions	Emissions from Both Combined Cycle Units (S-1 and S-2)	Preheater Emissions (S-3)	Total Willow Pass Potential Emissions (2 combined cycle turbines and one preheater)	PSD Threshold	Exceed PSD Threshold	New Source Review Offset Ratio	Offsets Required
	ton/yr/2CT	ton/yr/2CT	tons/yr	(ton/yr)			(ton/yr)
NO_x	77.10	0.329	77.429	40	Yes	1.15	90.39
CO	142.37	0.376	142.746	100	Yes	0	0
CO₂	1,098,099	1,294	1,099,393	---	---	---	---
VOC	28.46	0.030	28.49	40	No	1.15	32.8095
SO₂ (based on 0.4 gr total S / 100 scf)	10.52	0.012	10.532	40	No	1	10.51
PM₁₀	39.40	0.032	39.432	15	Yes	1	39.43
Notes: Offset ratios are 1.15 : 1 for NO _x and VOC emissions on a pollutant specific basis, for each pollutant (facility wide) over 35 tons per year. Below 35 tons , ratio is 1 : 1. Offset ratios are 1 : 1 for remaining criteria pollutants. 0.4 gr/100scf annual average natural gas sulfur used in annual SO ₂ emission calculations							

**ATC/PTO Application
Willow Pass Generating Station**

Appendix D. Application Forms



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street, San Francisco, CA 94109
Engineering Division (415) 749-4990
www.baaqmd.gov fax (415) 749-5030

Form P-101B

Authority to Construct/
Permit to Operate

--	--	--

1. Application Information

BAAQMD Plant No. _____ Company Name Mirant Willow Pass, LLC.

Equipment/Project Description Willow Pass Generating Station Project

2. Plant Information *If you have not previously been assigned a Plant Number by the District or if you want to update any plant data that you have previously supplied to the District, please complete this section.*

Equipment Location The new WPGS units will be constructed within the existing Pittsburg Power Plant site., Assessor's Parcel Number (APN) 085-010-014, in unincorporated Contra Costa County, California, Township 2 North, Range 1 East, on the U.S. Geological Survey (USGS) Honker Bay Topographic Quadrangle Map

City Pittsburg Zip Code 94565

Mail Address P.O. Box 192,696 W.10th Street

City Pittsburg State CA Zip Code 94565

Plant Contact Ronald Kino Title Manager EHS

Telephone (925) 427-3567 Fax (925) 427-3535 Email Ronald.kino@mirant.com

NAICS (North American Industry Classification System) see www.census.gov/epcd/naics02/naico602.htm 221112

3. Proximity to a School (K-12)

The sources in this permit application (check one) Are Are not within 1,000 ft of the outer boundary of the nearest school.

4. Application Contact Information *All correspondence from the District regarding this application will be sent to the plant contact unless you wish to designate a different contact for this application.*

Application Contact John Lague Title Senior Air Quality Consultant

Mail Address 1615 Murray Canyon Road, Suite 1000

City San Diego State CA Zip Code 92108

Telephone (619)294-9400 ext. 1127 Fax (619)293-7920 Email John_lague@urscorp.com

5. Additional Information *The following additional information is required for all permit applications and should be included with your submittal. Failure to provide this information may delay the review of your application. Please indicate that each item has been addressed by checking the box. Contact the Engineering Division if you need assistance.*

- If a new Plant, a local street map showing the location of your business
- A facility map, drawn roughly to scale, that locates the equipment and its emission points
- Completed data form(s) and a pollutant flow diagram for each piece of equipment. (See www.baaqmd.gov/pmt/forms/)
- Project/equipment description, manufacturer's data
- Discussion and/or calculations of the emissions of air pollutants from the equipment

6. Trade Secrets *Under the California Public Records Act, all information in your permit application will be considered a matter of public record and may be disclosed to a third party. If you wish to keep certain items separate as specified in Regulation 2, Rule 1, Section 202.7, please complete the following steps.*

- Each page containing trade secret information must be labeled "trade secret" with the trade secret information clearly marked.
- A second copy, with trade secret information blanked out, marked "public copy" must be provided.
- For each item asserted to be trade secret, you must provide a statement which provides the basis for your claim.

7. Small Business Certification You are entitled to a reduced permit fee if you qualify as a small business as defined in Regulation 3. In order to qualify, you must certify that your business meets all of the following criteria:

- The business does not employ more than 10 persons and its gross annual income does not exceed \$600,000.
- And the business is not an affiliate of a non-small business. (Note: a non-small business employs more than 10 persons and/or its gross income exceeds \$600,000.)

8. Accelerated Permitting The Accelerated Permitting Program entitles you to install and operate qualifying sources of air pollution and abatement equipment **without waiting for the District to issue a Permit to Operate**. To participate in this program you must certify that your project will meet all of the following criteria. Please acknowledge each item by checking each box.

- Uncontrolled emissions of any single pollutant are each less than 10 lb/highest day, or the equipment has been precertified by the BAAQMD.
- Emissions of toxic compounds do not exceed the trigger levels identified in Table 2-5-1 (see Regulation 2, Rule 5).
- The project is not subject to public notice requirements (the source is either more than 1000 ft. from the nearest school, or the source does not emit any toxic compound in Table 2-5-1).
- For replacement of abatement equipment, the new equipment must have an equal or greater overall abatement efficiency for all pollutants than the equipment being replaced.
- For alterations of existing sources, for all pollutants the alteration does not result in an increase in emissions.
- Payment of applicable fees (the minimum permit fee to install and operate each source). See Regulation 3 or contact the Engineering Division for help in determining your fees.

9. CEQA Please answer the following questions pertaining to CEQA (California Environmental Quality Act).

- A. Has another public agency prepared, required preparation of, or issued a notice regarding preparation of a California Environmental Quality Act (CEQA) document (initial study, negative declaration, environmental impact report, or other CEQA document) that analyzes impacts of this project or another project of which it is a part or to which it is related? YES NO If no, go to section 9B.


Describe the document or notice, preparer, and date of document or expected date of completion:

- B. List and describe any other permits or agency approvals required for this project by city, regional, state or federal agencies:

California Energy Commission

- C. List and describe all other prior or current projects for which either of the following statements is true: (1) the project that is the subject of this application could not be undertaken without the project listed below, (2) the project listed below could not be undertaken without the project that is the subject of this application:

10. Certification I hereby certify that all information contained herein is true and correct. (Please sign and date this form)

<u>John Lague</u>	<u>Senior Air Quality Consultant</u>		<u>July 10, 2008</u>
Name of person certifying (print)	Title of person certifying	Signature of person certifying	Date

Send all application materials to the BAAQMD Engineering Division, 939 Ellis Street, San Francisco, CA 94109.

FUELS

INSTRUCTIONS: Complete one line in Section A for each fuel. Section B is OPTIONAL. Please use the units at the bottom of each table. N/A means "Not Applicable."

SECTION A: FUEL DATA

	Fuel Name	Fuel Code**	Total Annual Usage***	Maximum Possible Fuel Use Rate	Typical Heat Content	Sulfur Content	Nitrogen Content (optional)	Ash Content (optional)
1.	Natural Gas		9.95E+07	2271 MM	N/A	N/A	N/A	N/A
2.								
3.								
4.								
5.								

<i>Use the appropriate units for each fuel</i>	Natural Gas	therm*	Btu/hr	N/A	N/A	N/A	N/A
	Other Gas	MSCF*	MSCF/hr	Btu/MSCF	ppm	N/A	N/A
	Liquid	m gal*	m gal/hr	Btu/m gal	wt%	wt%	wt%
	Solid	ton	ton/hr	Btu/ton	wt%	wt%	wt%

SECTION B: EMISSION FACTORS (optional)

	Fuel Name	Fuel Code**	Particulates		NOx		CO	
			Emission Factor	**Basis Code	Emission Factor	**Basis Code	Emission Factor	**Basis Code
1.								
2.								
3.								
4.								

Use the appropriate units for each fuel: Natural Gas = lb/therm*
 Other Gas = lb/MSCF*
 Liquid = lb/m gal*
 Solid = lb/ton

- Note:**
- * MSCF = thousand standard cubic feet
 - * m gal = thousand gallons
 - * therm = 100,000 BTU
 - ** See tables below for Fuel and Basis Codes
 - *** Total annual usage is:
 - Projected usage over next 12 months if equipment is new or modified.
 - Actual usage for last 12 months if equipment is existing and unchanged.

**Fuel Codes				**Basis Codes	
Code	Fuel	Code	Fuel	Code	Method
25	Anthracite coal	189	Natural Gas	0	Not applicable for this pollutant
33	Bagasse	234	Process gas - blast furnace	1	Source testing or other measurement by plant (attach copy)
35	Bark	235	Process gas - CO	2	Source testing or other measurement by BAAQMD (give date)
43	Bituminous coal	236	Process gas - coke oven gas	3	Specifications from vendor (attach copy)
47	Brown coal	238	Process gas - RMG	4	Material balance by plant using engineering expertise and knowledge of process
242	Bunker C fuel oil	237	Process gas - other	5	Material balance by BAAQMD
80	Coke	242	Residual oil	6	Taken from AP-42 (compilation of Air Pollutant Emission Factors, EPA)
89	Crude oil	495	Refuse derived fuel	7	Taken from literature, other than AP-42 (attach copy)
98	Diesel oil	511	Landfill gas	8	Guess
493	Digester gas	256	Solid propellant		
315	Distillate oil	466	Solid waste		
392	Fuel oil #2	304	Wood - hogged		
551	Gasoline	305	Wood - other		
158	Jet fuel	198	Other - gaseous fuels		
160	LPG	200	Other - liquid fuels		
165	Lignite	203	Other - solid fuels		
167	Liquid waste				
494	Municipal solid waste				

FUELS

INSTRUCTIONS: Complete one line in Section A for each fuel. Section B is OPTIONAL. Please use the units at the bottom of each table. N/A means "Not Applicable."

SECTION A: FUEL DATA

	Fuel Name	Fuel Code**	Total Annual Usage***	Maximum Possible Fuel Use Rate	Typical Heat Content	Sulfur Content	Nitrogen Content (optional)	Ash Content (optional)
1.	Natural Gas		9.95E+07	2271 MM	N/A	N/A	N/A	N/A
2.								
3.								
4.								
5.								

<i>Use the appropriate units for each fuel</i>	Natural Gas	therm*	Btu/hr	N/A	N/A	N/A	N/A
	Other Gas	MSCF*	MSCF/hr	Btu/MSCF	ppm	N/A	N/A
	Liquid	m gal*	m gal/hr	Btu/m gal	wt%	wt%	wt%
	Solid	ton	ton/hr	Btu/ton	wt%	wt%	wt%

SECTION B: EMISSION FACTORS (optional)

	Fuel Name	Fuel Code**	Particulates		NOx		CO	
			Emission Factor	**Basis Code	Emission Factor	**Basis Code	Emission Factor	**Basis Code
1.								
2.								
3.								
4.								

Use the appropriate units for each fuel: Natural Gas = lb/therm*
 Other Gas = lb/MSCF*
 Liquid = lb/m gal*
 Solid = lb/ton

- Note:**
- * MSCF = thousand standard cubic feet
 - * m gal = thousand gallons
 - * therm = 100,000 BTU
 - ** See tables below for Fuel and Basis Codes
 - *** Total annual usage is:
 - Projected usage over next 12 months if equipment is new or modified.
 - Actual usage for last 12 months if equipment is existing and unchanged.

**Fuel Codes				**Basis Codes	
Code	Fuel	Code	Fuel	Code	Method
25	Anthracite coal	189	Natural Gas	0	Not applicable for this pollutant
33	Bagasse	234	Process gas - blast furnace	1	Source testing or other measurement by plant (attach copy)
35	Bark	235	Process gas - CO	2	Source testing or other measurement by BAAQMD (give date)
43	Bituminous coal	236	Process gas - coke oven gas	3	Specifications from vendor (attach copy)
47	Brown coal	238	Process gas - RMG	4	Material balance by plant using engineering expertise and knowledge of process
242	Bunker C fuel oil	237	Process gas - other	5	Material balance by BAAQMD
80	Coke	242	Residual oil	6	Taken from AP-42 (compilation of Air Pollutant Emission Factors, EPA)
89	Crude oil	495	Refuse derived fuel	7	Taken from literature, other than AP-42 (attach copy)
98	Diesel oil	511	Landfill gas	8	Guess
493	Digester gas	256	Solid propellant		
315	Distillate oil	466	Solid waste		
392	Fuel oil #2	304	Wood - hogged		
551	Gasoline	305	Wood - other		
158	Jet fuel	198	Other - gaseous fuels		
160	LPG	200	Other - liquid fuels		
165	Lignite	203	Other - solid fuels		
167	Liquid waste				
494	Municipal solid waste				

FUELS

INSTRUCTIONS: Complete one line in Section A for each fuel. Section B is OPTIONAL. Please use the units at the bottom of each table. N/A means "Not Applicable."

SECTION A: FUEL DATA

	Fuel Name	Fuel Code**	Total Annual Usage***	Maximum Possible Fuel Use Rate	Typical Heat Content	Sulfur Content	Nitrogen Content (optional)	Ash Content (optional)
1.	Natural Gas		2.19E+5	5MM	N/A	N/A	N/A	N/A
2.								
3.								
4.								
5.								

<i>Use the appropriate units for each fuel</i>	Natural Gas	therm*	Btu/hr	N/A	N/A	N/A	N/A
	Other Gas	MSCF*	MSCF/hr	Btu/MSCF	ppm	N/A	N/A
	Liquid	m gal*	m gal/hr	Btu/m gal	wt%	wt%	wt%
	Solid	ton	ton/hr	Btu/ton	wt%	wt%	wt%

SECTION B: EMISSION FACTORS (optional)

	Fuel Name	Fuel Code**	Particulates		NOx		CO	
			Emission Factor	**Basis Code	Emission Factor	**Basis Code	Emission Factor	**Basis Code
1.								
2.								
3.								
4.								

Use the appropriate units for each fuel: Natural Gas = lb/therm*
 Other Gas = lb/MSCF*
 Liquid = lb/m gal*
 Solid = lb/ton


- Note:**
- * MSCF = thousand standard cubic feet
 - * m gal = thousand gallons
 - * therm = 100,000 BTU
 - ** See tables below for Fuel and Basis Codes
 - *** Total annual usage is:
 - Projected usage over next 12 months if equipment is new or modified.
 - Actual usage for last 12 months if equipment is existing and unchanged.

**Fuel Codes				**Basis Codes	
Code	Fuel	Code	Fuel	Code	Method
25	Anthracite coal	189	Natural Gas	0	Not applicable for this pollutant
33	Bagasse	234	Process gas - blast furnace	1	Source testing or other measurement by plant (attach copy)
35	Bark	235	Process gas - CO	2	Source testing or other measurement by BAAQMD (give date)
43	Bituminous coal	236	Process gas - coke oven gas	3	Specifications from vendor (attach copy)
47	Brown coal	238	Process gas - RMG	4	Material balance by plant using engineering expertise and knowledge of process
242	Bunker C fuel oil	237	Process gas - other	5	Material balance by BAAQMD
80	Coke	242	Residual oil	6	Taken from AP-42 (compilation of Air Pollutant Emission Factors, EPA)
89	Crude oil	495	Refuse derived fuel	7	Taken from literature, other than AP-42 (attach copy)
98	Diesel oil	511	Landfill gas	8	Guess
493	Digester gas	256	Solid propellant		
315	Distillate oil	466	Solid waste		
392	Fuel oil #2	304	Wood - hogged		
551	Gasoline	305	Wood - other		
158	Jet fuel	198	Other - gaseous fuels		
160	LPG	200	Other - liquid fuels		
165	Lignite	203	Other - solid fuels		
167	Liquid waste				
494	Municipal solid waste				

BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA . . . 94109 . . . (415) 749-4990 . . . Fax (415) 749-5030

Form P is for well-defined emission points such as stacks or chimneys only; do not use for windows, room vents, etc.



Business Name: Mirant Willow Pass, LLC. Plant No: _____

Emission Point No: P- 1

With regard to air pollutant flow into this emission point, what source(s) and/or abatement device(s) are **immediately** upstream?

S- 1 S- _____ S- _____ S- _____ S- _____
 S- _____ A- 1 A- 2 A- _____ A- _____ A- _____

Exit cross-section area: 357.15 sq. ft. Height above grade: 150.5 ft.

Effluent Flow from Stack

	<i>Typical Operating Condition</i>	<i>Maximum Operating Condition</i>
<i>Actual Wet Gas Flowrate</i>	1,378,149 cfm	1,511,297 cfm
<i>Percent Water Vapor</i>	8.5 Vol %	14.9 Vol %
<i>Temperature</i>	340 °F	350 °F

If this stack is equipped to measure (monitor) the emission of any air pollutants,

Is monitoring continuous? yes no

What pollutants are monitored? NO_x, CO, O₂

Person completing this form John Lague Date July 10, 2008

BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA . . . 94109 . . . (415) 749-4990 . . . Fax (415) 749-5030

Form P is for well-defined emission points such as stacks or chimneys only; do not use for windows, room vents, etc.

Business Name: Mirant Willow Pass, LLC. Plant No: _____

Emission Point No: P- 2

With regard to air pollutant flow into this emission point, what sources(s) and/or abatement device(s) are **immediately** upstream?

S- 2 S- _____ S- _____ S- _____ S- _____
 S- _____ A- 3 A- 4 A- _____ A- _____ A- _____

Exit cross-section area: 357.15 sq. ft. Height above grade: 150.5 ft.

Effluent Flow from Stack

	<i>Typical Operating Condition</i>	<i>Maximum Operating Condition</i>
<i>Actual Wet Gas Flowrate</i>	1,378,149 cfm	1,511,297 cfm
<i>Percent Water Vapor</i>	8.5 Vol %	14.9 Vol %
<i>Temperature</i>	340 °F	350 °F

If this stack is equipped to measure (monitor) the emission of any air pollutants,

Is monitoring continuous? yes no

What pollutants are monitored? NO_x, CO, O₂

Person completing this form John Lague Date July 10, 2008

BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA . . . 94109 . . . (415) 749-4990 . . . Fax (415) 749-5030

Form P is for well-defined emission points such as stacks or chimneys only; do not use for windows, room vents, etc.

Business Name: Mirant Willow Pass, LLC. Plant No: _____

Emission Point No: P-3

With regard to air pollutant flow into this emission point, what source(s) and/or abatement device(s) are **immediately** upstream?

S- 3 S- _____ S- _____ S- _____ S- _____
 S- _____ A- _____ A- _____ A- _____ A- _____ A- _____

Exit cross-section area: 0.35 sq. ft.

Height above grade: 26 ft.

Effluent Flow from Stack

	<i>Typical Operating Condition</i>	<i>Maximum Operating Condition</i>
<i>Actual Wet Gas Flowrate</i>	1,048 cfm	1,048, cfm
<i>Percent Water Vapor</i>	Vol %	Vol %
<i>Temperature</i>	415 °F	415 °F

If this stack is equipped to measure (monitor) the emission of any air pollutants,

Is monitoring continuous? yes no

What pollutants are monitored? _____

Person completing this form John Lague Date July 10, 2008



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA 94109 . . . (415) 749-4990 . . . FAX (415) 749-5030

--	--

for office use only

Abatement Device: Equipment/process whose primary purpose is to reduce the quantity of pollutant(s) emitted to the atmosphere.

1. Business Name: Mirant Willow Pass, LLC. Plant No: _____
(If unknown, leave blank)

2. Name or Description CO Catalyst System Abatement Device No: A- 1

3. Make, Model, and Rated Capacity TBD

4. Abatement Device Code (See table*) 2 Date of Initial Operation _____

5. With regard to air pollutant flow into this abatement device, what sources(s) and/or abatement device(s) are **immediately** upstream?

S- 1 S- _____ S- _____ S- _____ S- _____
 S- _____ A- _____ A- _____ A- _____ A- _____ A- _____

6. Typical gas stream temperature at inlet: 750 °F

If this form is being submitted as part of an application for an **Authority to Construct**, completion of the following table is mandatory. If not, and the Abatement Device is *already in operation*, completion of the table is requested but not required.

	Pollutant	Weight Percent Reduction (at typical operation)	Basis Codes (See Table**)
7.	Particulate		
8.	Organics	< 2 ppmvd@15%O ₂	
9.	Nitrogen Oxides (as NO ₂)		
10.	Sulfur Dioxide		
11.	Carbon Monoxide	< 3 ppmvd@15%O ₂	
12.	Other:		
13.	Other:		

14. Check box if this Abatement Device burns fuel; complete lines 1, 2 and 15-36 on Form C (using the Abatement Device No. above for the Source No.) and attach to this form.

15. With regard to air pollutant flow from this abatement device, what sources(s), abatement device(s) and/or emission point(s) are **immediately** downstream?

S- _____ A- 2 _____ A- _____ A- _____ P- 1 P- _____

Person completing this form: <u>John Lague</u>	Date: <u>July 10, 2008</u>
--	----------------------------

***ABATEMENT DEVICE CODES**

Code	DEVICE
	ADSORBER (See Vapor Recovery)
	AFTERBURNER
1	CO Boiler
2	Catalytic
3	Direct Flame
4	Flare
5	Furnace-firebox
6	Other
	BAGHOUSE (See Dry Filter)
	CYCLONE (See Dry Inertial Collector and Scrubber)
	DUST CONTROL
68	Water Spray
	DRY FILTER
7	Absolute
8	Baghouse, Pulse Jet
9	Baghouse, Reverse Air
10	Baghouse, Reverse Jet
11	Baghouse, Shaking
12	Baghouse, Simple
13	Baghouse, Other
14	Envelope
15	Moving Belt
16	Other
	DRY INERTIAL COLLECTOR
17	Cyclone, Dynamic
18	Cyclone, Multiple (12 inches dia. or more)
19	Cyclone, Multiple (less than 12 inches dia.)
20	Cyclone, Simple
21	Settling Chamber, Baffled/Louvered
22	Settling Chamber, Simple
23	Other
	ELECTROSTATIC PRECIPITATOR
24	Single Stage
25	Single Stage, Wet
26	Two Stage
27	Two Stage, Wet
28	Other
	INCINERATOR (See Afterburner)
	INTERNAL COMBUSTION ENGINE CONTROL
69	Catalyzed Diesel Particulate Filter
70	Non-Cat. Diesel Part. Filter w/ Active Regeneration
71	Diesel Oxidation Catalyst
72	Oxidation Catalyst
	INCINERATOR (See Afterburner)
	KNOCK-OUT POT (See Liquid Separator)
	LIQUID SEPARATOR
29	Knock-out Pot
30	Mist Eliminator, Horizontal Pad, Dry
31	Mist Eliminator, Panel, Dry
32	Mist Eliminator, Spray/Irrigated
33	Mist Eliminator, Vertical Tube, Dry
34	Mist Eliminator, Other
35	Other
	MIST ELIMINATOR (See Liquid Separator)

Code	DEVICE
	NO _x CONTROL
66	Selective Catalytic Reduction (SCR)
67	Non-Selective Catalytic Reduction (NSCR)
73	Selective Non-Catalytic Reduction (SNCR)
	SCRUBBER
36	Baffle and Secondary Flow
37	Centrifugal
38	Cyclone, Irrigated
39	Fibrous Packed
40	Impingement Plate
41	Impingement and Entrainment
42	Mechanically Aided
43	Moving Bed
44	Packed Bed
45	Preformed Spray
46	Venturi
47	Other
	SETTLING CHAMBER (See Dry Inertial Collector)
	SULFUR DIOXIDE CONTROL
48	Absorption and Regeneration, for Sulfur Plant
49	Claus Solution Reaction, for Sulfur Plant
50	Dual Absorption, for H ₂ S ₀₄ Plant
51	Flue Gas Desulfurization, for Fossil Fuel Combustion
52	Reduction and Solution Regeneration, for Sulfur Plant
53	Reduction and Stretford Process, for Sulfur Plant
54	Sodium Sulfite-Bisulfite Scrubber, for H ₂ S ₀₄ Plant
55	Other
	VAPOR RECOVERY
56	Adsorption, Activated Carbon/Charcoal
57	Adsorption, Silica
58	Adsorption, Other
59	Balance
60	Compression/Condensation/Absorption
61	Compression/Refrigeration
62	Condenser, Water-Cooled
63	Condenser, Other
64	Other
	MISCELLANEOUS
65	Not classified above

****BASIS CODES**

Code	Method
0	Not applicable for this pollutant
1	Source testing or other measurement by plant
2	Source testing or other measurement by BAAQMD
3	Specifications from vendor
4	Material balance by plant using engineering expertise and knowledge of process
5	Material balance by BAAQMD using engineering expertise and knowledge of process
6	Taken from AP-42 ("Compilation of Air Pollutant Emission Factors," EPA)
7	Taken from literature, other than AP-42
8	Guess



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA 94109 . . . (415) 749-4990 . . . FAX (415) 749-5030

for office use only

Abatement Device: Equipment/process whose primary purpose is to reduce the quantity of pollutant(s) emitted to the atmosphere.

1. Business Name: Mirant Willow Pass, LLC. Plant No: _____
(If unknown, leave blank)

2. Name or Description Selective Catalytic Reduction Abatement Device No: A- 2

3. Make, Model, and Rated Capacity TBD

4. Abatement Device Code (See table*) 2 Date of Initial Operation _____

5. With regard to air pollutant flow into this abatement device, what sources(s) and/or abatement device(s) are **immediately** upstream?

S- 1 S- _____ S- _____ S- _____ S- _____
S- _____ 1 A- _____ A- _____ A- _____ A- _____

6. Typical gas stream temperature at inlet: 750 °F

If this form is being submitted as part of an application for an **Authority to Construct**, completion of the following table is mandatory. If not, and the Abatement Device is *already in operation*, completion of the table is requested but not required.

	Pollutant	Weight Percent Reduction (at typical operation)	Basis Codes (See Table**)
7.	Particulate		
8.	Organics		
9.	Nitrogen Oxides (as NO ₂)	2.0 ppmvd	
10.	Sulfur Dioxide		
11.	Carbon Monoxide		
12.	Other:		
13.	Other:		

14. Check box if this Abatement Device burns fuel; complete lines 1, 2 and 15-36 on Form C (using the Abatement Device No. above for the Source No.) and attach to this form.

15. With regard to air pollutant flow from this abatement device, what sources(s), abatement device(s) and/or emission point(s) are **immediately** downstream?

S- _____ A- _____ A- _____ A- _____ P- 1 P- _____

Person completing this form: John Lague Date: July 10, 2008

***ABATEMENT DEVICE CODES**

Code	DEVICE
	ADSORBER (See Vapor Recovery)
	AFTERBURNER
1	CO Boiler
2	Catalytic
3	Direct Flame
4	Flare
5	Furnace-firebox
6	Other
	BAGHOUSE (See Dry Filter)
	CYCLONE (See Dry Inertial Collector and Scrubber)
	DUST CONTROL
68	Water Spray
	DRY FILTER
7	Absolute
8	Baghouse, Pulse Jet
9	Baghouse, Reverse Air
10	Baghouse, Reverse Jet
11	Baghouse, Shaking
12	Baghouse, Simple
13	Baghouse, Other
14	Envelope
15	Moving Belt
16	Other
	DRY INERTIAL COLLECTOR
17	Cyclone, Dynamic
18	Cyclone, Multiple (12 inches dia. or more)
19	Cyclone, Multiple (less than 12 inches dia.)
20	Cyclone, Simple
21	Settling Chamber, Baffled/Louvered
22	Settling Chamber, Simple
23	Other
	ELECTROSTATIC PRECIPITATOR
24	Single Stage
25	Single Stage, Wet
26	Two Stage
27	Two Stage, Wet
28	Other
	INCINERATOR (See Afterburner)
	INTERNAL COMBUSTION ENGINE CONTROL
69	Catalyzed Diesel Particulate Filter
70	Non-Cat. Diesel Part. Filter w/ Active Regeneration
71	Diesel Oxidation Catalyst
72	Oxidation Catalyst
	INCINERATOR (See Afterburner)
	KNOCK-OUT POT (See Liquid Separator)
	LIQUID SEPARATOR
29	Knock-out Pot
30	Mist Eliminator, Horizontal Pad, Dry
31	Mist Eliminator, Panel, Dry
32	Mist Eliminator, Spray/Irrigated
33	Mist Eliminator, Vertical Tube, Dry
34	Mist Eliminator, Other
35	Other
	MIST ELIMINATOR (See Liquid Separator)

Code	DEVICE
	NO _x CONTROL
66	Selective Catalytic Reduction (SCR)
67	Non-Selective Catalytic Reduction (NSCR)
73	Selective Non-Catalytic Reduction (SNCR)
	SCRUBBER
36	Baffle and Secondary Flow
37	Centrifugal
38	Cyclone, Irrigated
39	Fibrous Packed
40	Impingement Plate
41	Impingement and Entrainment
42	Mechanically Aided
43	Moving Bed
44	Packed Bed
45	Preformed Spray
46	Venturi
47	Other
	SETTLING CHAMBER (See Dry Inertial Collector)
	SULFUR DIOXIDE CONTROL
48	Absorption and Regeneration, for Sulfur Plant
49	Claus Solution Reaction, for Sulfur Plant
50	Dual Absorption, for H ₂ S ₀₄ Plant
51	Flue Gas Desulfurization, for Fossil Fuel Combustion
52	Reduction and Solution Regeneration, for Sulfur Plant
53	Reduction and Stretford Process, for Sulfur Plant
54	Sodium Sulfite-Bisulfite Scrubber, for H ₂ S ₀₄ Plant
55	Other
	VAPOR RECOVERY
56	Adsorption, Activated Carbon/Charcoal
57	Adsorption, Silica
58	Adsorption, Other
59	Balance
60	Compression/Condensation/Absorption
61	Compression/Refrigeration
62	Condenser, Water-Cooled
63	Condenser, Other
64	Other
	MISCELLANEOUS
65	Not classified above

****BASIS CODES**

Code	Method
0	Not applicable for this pollutant
1	Source testing or other measurement by plant
2	Source testing or other measurement by BAAQMD
3	Specifications from vendor
4	Material balance by plant using engineering expertise and knowledge of process
5	Material balance by BAAQMD using engineering expertise and knowledge of process
6	Taken from AP-42 ("Compilation of Air Pollutant Emission Factors," EPA)
7	Taken from literature, other than AP-42
8	Guess



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA 94109 . . . (415) 749-4990 . . . FAX (415) 749-5030

--	--

for office use only

Abatement Device: Equipment/process whose primary purpose is to reduce the quantity of pollutant(s) emitted to the atmosphere.

1. Business Name: Mirant Willow Pass, LLC. Plant No: _____
(If unknown, leave blank)

2. Name or Description CO Catalyst System Abatement Device No: A- 3

3. Make, Model, and Rated Capacity TBD

4. Abatement Device Code (See table*) 2 Date of Initial Operation _____

5. With regard to air pollutant flow into this abatement device, what sources(s) and/or abatement device(s) are **immediately** upstream?

S- 2 S- _____ S- _____ S- _____ S- _____
 S- _____ A- _____ A- _____ A- _____ A- _____ A- _____

6. Typical gas stream temperature at inlet: 750 °F

If this form is being submitted as part of an application for an **Authority to Construct**, completion of the following table is mandatory. If not, and the Abatement Device is *already in operation*, completion of the table is requested but not required.

	Pollutant	Weight Percent Reduction (at typical operation)	Basis Codes (See Table**)
7.	Particulate		
8.	Organics	< 2 ppmvd@15%O2	
9.	Nitrogen Oxides (as NO ₂)		
10.	Sulfur Dioxide		
11.	Carbon Monoxide	< 3 ppmvd@15%O2	
12.	Other:		
13.	Other:		

14. Check box if this Abatement Device burns fuel; complete lines 1, 2 and 15-36 on Form C (using the Abatement Device No. above for the Source No.) and attach to this form.

15. With regard to air pollutant flow from this abatement device, what sources(s), abatement device(s) and/or emission point(s) are **immediately** downstream?

S- _____ A- 4 _____ A- _____ A- _____ P- 2 P- _____

Person completing this form: <u>John Lague</u>	Date: <u>July 10, 2008</u>
--	----------------------------

***ABATEMENT DEVICE CODES**

Code	DEVICE
	ADSORBER (See Vapor Recovery)
	AFTERBURNER
1	CO Boiler
2	Catalytic
3	Direct Flame
4	Flare
5	Furnace-firebox
6	Other
	BAGHOUSE (See Dry Filter)
	CYCLONE (See Dry Inertial Collector and Scrubber)
	DUST CONTROL
68	Water Spray
	DRY FILTER
7	Absolute
8	Baghouse, Pulse Jet
9	Baghouse, Reverse Air
10	Baghouse, Reverse Jet
11	Baghouse, Shaking
12	Baghouse, Simple
13	Baghouse, Other
14	Envelope
15	Moving Belt
16	Other
	DRY INERTIAL COLLECTOR
17	Cyclone, Dynamic
18	Cyclone, Multiple (12 inches dia. or more)
19	Cyclone, Multiple (less than 12 inches dia.)
20	Cyclone, Simple
21	Settling Chamber, Baffled/Louvered
22	Settling Chamber, Simple
23	Other
	ELECTROSTATIC PRECIPITATOR
24	Single Stage
25	Single Stage, Wet
26	Two Stage
27	Two Stage, Wet
28	Other
	INCINERATOR (See Afterburner)
	INTERNAL COMBUSTION ENGINE CONTROL
69	Catalyzed Diesel Particulate Filter
70	Non-Cat. Diesel Part. Filter w/ Active Regeneration
71	Diesel Oxidation Catalyst
72	Oxidation Catalyst
	INCINERATOR (See Afterburner)
	KNOCK-OUT POT (See Liquid Separator)
	LIQUID SEPARATOR
29	Knock-out Pot
30	Mist Eliminator, Horizontal Pad, Dry
31	Mist Eliminator, Panel, Dry
32	Mist Eliminator, Spray/Irrigated
33	Mist Eliminator, Vertical Tube, Dry
34	Mist Eliminator, Other
35	Other
	MIST ELIMINATOR (See Liquid Separator)

Code	DEVICE
	NO _x CONTROL
66	Selective Catalytic Reduction (SCR)
67	Non-Selective Catalytic Reduction (NSCR)
73	Selective Non-Catalytic Reduction (SNCR)
	SCRUBBER
36	Baffle and Secondary Flow
37	Centrifugal
38	Cyclone, Irrigated
39	Fibrous Packed
40	Impingement Plate
41	Impingement and Entrainment
42	Mechanically Aided
43	Moving Bed
44	Packed Bed
45	Preformed Spray
46	Venturi
47	Other
	SETTLING CHAMBER (See Dry Inertial Collector)
	SULFUR DIOXIDE CONTROL
48	Absorption and Regeneration, for Sulfur Plant
49	Claus Solution Reaction, for Sulfur Plant
50	Dual Absorption, for H ₂ S ₀₄ Plant
51	Flue Gas Desulfurization, for Fossil Fuel Combustion
52	Reduction and Solution Regeneration, for Sulfur Plant
53	Reduction and Stretford Process, for Sulfur Plant
54	Sodium Sulfite-Bisulfite Scrubber, for H ₂ S ₀₄ Plant
55	Other
	VAPOR RECOVERY
56	Adsorption, Activated Carbon/Charcoal
57	Adsorption, Silica
58	Adsorption, Other
59	Balance
60	Compression/Condensation/Absorption
61	Compression/Refrigeration
62	Condenser, Water-Cooled
63	Condenser, Other
64	Other
	MISCELLANEOUS
65	Not classified above

****BASIS CODES**

Code	Method
0	Not applicable for this pollutant
1	Source testing or other measurement by plant
2	Source testing or other measurement by BAAQMD
3	Specifications from vendor
4	Material balance by plant using engineering expertise and knowledge of process
5	Material balance by BAAQMD using engineering expertise and knowledge of process
6	Taken from AP-42 ("Compilation of Air Pollutant Emission Factors," EPA)
7	Taken from literature, other than AP-42
8	Guess



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 Ellis Street . . . San Francisco, CA 94109 . . . (415) 749-4990 . . . FAX (415) 749-5030

--	--

for office use only

Abatement Device: Equipment/process whose primary purpose is to reduce the quantity of pollutant(s) emitted to the atmosphere.

1. Business Name: Mirant Willow Pass, LLC. Plant No: _____
(If unknown, leave blank)

2. Name or Description Selective Catalytic Reduction Abatement Device No: A- 4

3. Make, Model, and Rated Capacity TBD

4. Abatement Device Code (See table*) 2 Date of Initial Operation _____

5. With regard to air pollutant flow into this abatement device, what sources(s) and/or abatement device(s) are **immediately** upstream?

S- 2 S- _____ S- _____ S- _____ S- _____
 S- _____ 3 _____
 _____ A- _____ A- _____ A- _____ A- _____ A- _____

6. Typical gas stream temperature at inlet: 750 °F

If this form is being submitted as part of an application for an **Authority to Construct**, completion of the following table is mandatory. If not, and the Abatement Device is *already in operation*, completion of the table is requested but not required.

	Pollutant	Weight Percent Reduction (at typical operation)	Basis Codes (See Table**)
7.	Particulate		
8.	Organics		
9.	Nitrogen Oxides (as NO ₂)	2.0 ppmvd	
10.	Sulfur Dioxide		
11.	Carbon Monoxide		
12.	Other:		
13.	Other:		

14. Check box if this Abatement Device burns fuel; complete lines 1, 2 and 15-36 on Form C (using the Abatement Device No. above for the Source No.) and attach to this form.

15. With regard to air pollutant flow from this abatement device, what sources(s), abatement device(s) and/or emission point(s) are **immediately** downstream?

S- _____ A- _____ A- _____ A- _____ P- 2 P- _____

Person completing this form: <u>John Lague</u>	Date: <u>July 10, 2008</u>
--	----------------------------

***ABATEMENT DEVICE CODES**

Code	DEVICE
	ADSORBER (See Vapor Recovery)
	AFTERBURNER
1	CO Boiler
2	Catalytic
3	Direct Flame
4	Flare
5	Furnace-firebox
6	Other
	BAGHOUSE (See Dry Filter)
	CYCLONE (See Dry Inertial Collector and Scrubber)
	DUST CONTROL
68	Water Spray
	DRY FILTER
7	Absolute
8	Baghouse, Pulse Jet
9	Baghouse, Reverse Air
10	Baghouse, Reverse Jet
11	Baghouse, Shaking
12	Baghouse, Simple
13	Baghouse, Other
14	Envelope
15	Moving Belt
16	Other
	DRY INERTIAL COLLECTOR
17	Cyclone, Dynamic
18	Cyclone, Multiple (12 inches dia. or more)
19	Cyclone, Multiple (less than 12 inches dia.)
20	Cyclone, Simple
21	Settling Chamber, Baffled/Louvered
22	Settling Chamber, Simple
23	Other
	ELECTROSTATIC PRECIPITATOR
24	Single Stage
25	Single Stage, Wet
26	Two Stage
27	Two Stage, Wet
28	Other
	INCINERATOR (See Afterburner)
	INTERNAL COMBUSTION ENGINE CONTROL
69	Catalyzed Diesel Particulate Filter
70	Non-Cat. Diesel Part. Filter w/ Active Regeneration
71	Diesel Oxidation Catalyst
72	Oxidation Catalyst
	INCINERATOR (See Afterburner)
	KNOCK-OUT POT (See Liquid Separator)
	LIQUID SEPARATOR
29	Knock-out Pot
30	Mist Eliminator, Horizontal Pad, Dry
31	Mist Eliminator, Panel, Dry
32	Mist Eliminator, Spray/Irrigated
33	Mist Eliminator, Vertical Tube, Dry
34	Mist Eliminator, Other
35	Other
	MIST ELIMINATOR (See Liquid Separator)

Code	DEVICE
	NO _x CONTROL
66	Selective Catalytic Reduction (SCR)
67	Non-Selective Catalytic Reduction (NSCR)
73	Selective Non-Catalytic Reduction (SNCR)
	SCRUBBER
36	Baffle and Secondary Flow
37	Centrifugal
38	Cyclone, Irrigated
39	Fibrous Packed
40	Impingement Plate
41	Impingement and Entrainment
42	Mechanically Aided
43	Moving Bed
44	Packed Bed
45	Preformed Spray
46	Venturi
47	Other
	SETTLING CHAMBER (See Dry Inertial Collector)
	SULFUR DIOXIDE CONTROL
48	Absorption and Regeneration, for Sulfur Plant
49	Claus Solution Reaction, for Sulfur Plant
50	Dual Absorption, for H ₂ S ₀₄ Plant
51	Flue Gas Desulfurization, for Fossil Fuel Combustion
52	Reduction and Solution Regeneration, for Sulfur Plant
53	Reduction and Stretford Process, for Sulfur Plant
54	Sodium Sulfite-Bisulfite Scrubber, for H ₂ S ₀₄ Plant
55	Other
	VAPOR RECOVERY
56	Adsorption, Activated Carbon/Charcoal
57	Adsorption, Silica
58	Adsorption, Other
59	Balance
60	Compression/Condensation/Absorption
61	Compression/Refrigeration
62	Condenser, Water-Cooled
63	Condenser, Other
64	Other
	MISCELLANEOUS
65	Not classified above

****BASIS CODES**

Code	Method
0	Not applicable for this pollutant
1	Source testing or other measurement by plant
2	Source testing or other measurement by BAAQMD
3	Specifications from vendor
4	Material balance by plant using engineering expertise and knowledge of process
5	Material balance by BAAQMD using engineering expertise and knowledge of process
6	Taken from AP-42 ("Compilation of Air Pollutant Emission Factors," EPA)
7	Taken from literature, other than AP-42
8	Guess