

DOCKET**08-AFC-8**DATE JUN 24 2009RECD. JUL 02 2009

June 24, 2009

Gerardo Rios
Chief, Permits Office
US Environmental Protection Agency
Air Division (AIR-3)
75 Hawthorne St.
San Francisco, CA 94105

**Subject: Submittal of Prevention of Significant Deterioration Application –
Hydrogen Energy California**

Dear Mr. Rios:

Hydrogen Energy International LLC (HEI) proposes to build a nominally rated 250 (approximate) net megawatt (MW) integrated gasification combined cycle power generation unit at a site in Kern County, California. The attached document is an application for a Prevention of Significant Deterioration (PSD) of air quality permit for the "HECA" project.

HECA will be a state-of-the-art integrated gasification combined cycle gas turbine power plant, will produce low-carbon baseload electricity by capturing carbon dioxide (CO₂) and transporting to Elk Hills Oil Field for enhanced oil recovery (EOR) and sequestration, and will utilize the best available technology for environmental performance.

A Revised Application for Certification for this unit was filed with the California Energy Commission (Docket # 08-AFC-8 filed on May 28, 2009). An Authority to Construct / Permit to Operate Application will be filed with the San Joaquin Valley Air Pollution Control District (SJVAPCD).

The attached application includes a complete PSD application and supporting information. Please contact me at (562) 276-1511 or Mark Strehlow at (510) 874-3055 if you have any questions or require additional information.

**RIO
TINTO**

A joint venture between
BP Alternative Energy and Rio Tinto



Page 2 of 2

Sincerely,

Gregory D. Skannal
Manager, HSSE
Hydrogen Energy International LLC

Attachment: Application

Copy: California Energy Commission
Mark Strehlow, URS

Prevention of Significant Deterioration (PSD) Permit Application

Revised Application for Certification (08-AFC-8) for **HYDROGEN ENERGY CALIFORNIA** Kern County, California

Prepared for:

Hydrogen Energy International
LLC



hydrogen energy

Submitted to:

U.S. Environmental Protection Agency
Region 9

June 2009

Prepared by:

URS




TABLE OF CONTENTS

Executive Summary.....	ES-1
Section 1 Introduction.....	1-1
1.1 Project Location	1-1
1.2 Facility Description.....	1-1
1.3 Emissions Control and Monitoring.....	1-5
1.3.1 SCR Emissions Control System	1-5
1.3.2 CO Oxidation System	1-5
1.3.3 Continuous Emissions Monitoring System.....	1-6
1.4 Project Schedule.....	1-6
1.5 Project Ownership.....	1-6
1.6 Applicant Contact Information	1-7
Section 2 Laws, Regulations, Ordinances, and Standards.....	2-1
2.1 Ambient Air Quality Standards	2-8
2.2 Prevention of Significant Deterioration	2-10
2.3 Acid Rain Program Requirements	2-11
2.4 New Source Performance Standards.....	2-12
2.5 Federally Mandated Operating Permits	2-12
2.6 California Power Plants Siting Requirements.....	2-13
2.7 Air Toxics “Hot Spots” Program	2-13
2.8 Determination of Compliance, Authority to Construct and Permit to Operate.....	2-13
2.9 San Joaquin Valley Air Pollution Control District Requirements	2-14
2.10 Rules and Regulations.....	2-14
2.11 Permitting/Project Coordination	2-20
Section 3 Affected Environment	3-1
3.1 Climatology.....	3-1
3.2 Existing Air Quality.....	3-2
Section 4 Emission Controls.....	4-1
Section 5 Emission Characterization.....	5-1
5.1 Power Block.....	5-1
5.2 Gasification Block	5-12
5.3 Total Combined Facility-Wide Emissions.....	5-14
5.4 Greenhouse Gas Emissions.....	5-25
5.5 Mobile Sources	5-25

TABLE OF CONTENTS

Section 6	Modeling Impact Analysis.....	6-1
6.1	Model and Model Option Selections	6-1
6.2	Building Wake Effects.....	6-2
6.3	Meteorological Data.....	6-2
6.4	Receptor Locations	6-3
6.5	Turbine Impact Screening Modeling	6-4
6.5.1	1-Hour Startup Scenarios.....	6-4
6.6	Refined Modeling	6-8
6.6.1	Fumigation Analysis	6-9
6.7	Compliance With Ambient Air Quality Standards	6-9
6.8	Compliance With PSD Increments	6-13
Section 7	Other Environmental Impacts.....	7-1
7.1	Air Quality Related Values	7-1
7.1.1	Class I Areas	7-1
7.1.2	Class II Areas	7-3
Section 8	References	8-1

Tables

1-1	Project Disturbed Acreage
2-1	Laws, Ordinances, Regulations, and Standards – Air Quality
2-2	Relevant Ambient Air Quality Standards
2-3	Attainment Status for Kern County with Respect to Federal and California Ambient Air Quality Standards
2-4	PSD Emission Threshold Triggers for New Stationary Sources
2-5	Prevention of Significant Deterioration Allowable Increments ($\mu\text{g}/\text{m}^3$)
2-6	Proposed BACT for the Project
3-1	Temperature and Precipitation Data for Buttonwillow Station Buttonwillow, California
3-2	Ambient Ozone Levels at Shafter-Walker Street 1999-2008 (ppm)
3-3	Ambient PM_{10} Levels at Bakersfield-Golden State Highway 1999 --2008 ($\mu\text{g}/\text{m}^3$)
3-4	Ambient $\text{PM}_{2.5}$ Levels at Bakersfield-Golden State Highway 1999-2008 ($\mu\text{g}/\text{m}^3$)
3-5	Ambient CO Levels at Bakersfield-Golden State Highway 1990-2008 (ppm)
3-6	Ambient NO_2 Levels at Shafter-Walker Street 1999 -2008 (ppm)
3-7	Ambient SO_2 Levels Nearest to the Project Location 1999-2008 (ppm)
5-1	Maximum CTG/HRSG Operating Schedule

TABLE OF CONTENTS

5-2	1-Hour Operating Emission Rates for CTG/HRSG Operating Load Scenarios
5-3	CTG/HRSG Criteria Pollutant Emission Rates During Startup and Shutdown
5-4	Criteria Pollutant Sources and Emission Totals for the Worst-Case CTG Emissions Scenario for All Averaging Times
5-5	Average Annual Emissions per Turbine Operating Scenario
5-6	Maximum Auxiliary CTG Operating Schedule
5-7	Auxiliary CTG Criteria Pollutant Emission Rates During Startup and Shutdown
5-8	Criteria Pollutant Sources and Emission Totals for the Worst-Case Auxiliary CTG Emissions Scenario for All Averaging Times
5-9	Total Combined Annual Criteria Pollutant Emissions
5-10	Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Natural Gas at 59°F
5-11	Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Hydrogen Rich-Syngas at 59°F
5-12	Duration and Criteria Pollutant Emissions for Commissioning of the Auxiliary CTG on Natural Gas at 59°F
5-13	On-Site Truck Trips by Period
5-14	EMFAC2007 Heavy Truck Emission Factors and AERMOD Emission Rates
6-1	Turbine Screening Results Normal Operations – Emissions and Stack Parameters per Turbine
6-2	DEGADIS Model Inputs and Parameters
6-3	AERMOD Modeling Results for Project Operations (All Project Sources Combined)
7-1	PSD Class I Increment Significance Analysis – CALPUFF Results
7-2	Visibility Analysis – CALPUFF Results
7-3	Total Nitrogen and Sulfur Deposition Analysis – CALPUFF Results
7-4	Class II Surrounding Area Level II VISCREEN Results
7-5	SACTI Cooling Tower Plume Predictions Winter Day-Time No Fog Hours (Mass Flow Rate = 11554.9 kg/s)
7-6	CSVP HRSG Stack Plume Characteristics During Seasonal Daylight Clear Hours

Figures

1-1	Vicinity Map
1-2	Project Location Map
1-3	Preliminary Plot Plan

TABLE OF CONTENTS

6-1	Near-Field Model Receptor Grid
6-2	Far-Field Model Receptor Grid
6-3	Locations of Maximum Predicted Ground Level Pollutant Concentrations for the Operational Project Area

Appendices

A	Best Available Control Technology (BACT) Analysis
B	Emissions
C	Air Quality Modeling Protocol
D	Downwash Parameters
E	Class I Visibility/CALPUFF Analysis

Acronyms and Abbreviations

AAQS	Ambient Air Quality Standard
AFC	Application for Certification
AGR	acid gas removal
APN	Assessor's Parcel Number
APE	area of potential effect
Applicant	Hydrogen Energy International LLC
AQMP	air quality management plan
AQRVs	Air quality-related values
ASU	air separation unit
ATC	Authority to Construct
BACT	Best Available Control Technology
CAAA	Clean Air Act Amendment of 1990
CAAQS	California Ambient Air Quality Standard
CAISO	California Independent System Operator
CB	Construction Battalion
CCS	cryptocrystalline
CEMS	Continuous Emission Monitoring Systems
CEC	California Energy Commission
CEQA	California Environmental Quality Act
CO	carbon monoxide

TABLE OF CONTENTS

CO ₂	carbon dioxide
CRM	Cultural Resource Monitor
CTG	combustion turbine generator
DOC	Determination of Compliance
DOE	Department of Energy
EOR	enhanced oil recovery
EPA	Environmental Protection Agency (federal)
gpm	gallons per minute
HECA	Hydrogen Energy California
HEI	Hydrogen Energy International LLC
HRSG	heat recovery steam generator
IGCC	Integrated Gasification Combined Cycle
MW	megawatt
µg/m ³	micrograms per cubic meter
NAAQS	National Ambient Air Quality Standard
NO ₂	nitrogen dioxide
NPS	National Park Service
PM _{2.5}	fine particulate matter
PM ₁₀	particulate matter
ppmvd	parts per million volumetric dry
Project	Hydrogen Energy California
PSD	Prevention of Significant Deterioration
PTO	permit to operate
SCR	selective catalytic reduction
SJVAB	San Joaquin Valley Air Basin
SJVAPCD	San Joaquin Valley Air Pollution Control District
SIP	state implementation plan
SO ₂	sulfur dioxide
TGTU	tail gas treating unit
USFS	U.S. Forest Service
USGS	U. S. Geological Survey
VOCs	volatile organic compounds

TABLE OF CONTENTS

This Prevention of Significant Deterioration (PSD) Permit application is for the construction and operation of the Hydrogen Energy California Integrated Gasification Combined Cycle (IGCC) Project (HECA or Project). This PSD permit application is a stand-alone document submitted with the intention of obtaining a PSD permit from the U.S. Environmental Protection Agency (EPA). An Application for Certification (AFC) and an Authority to Construct/Permit to Operate application have also been submitted to the California Energy Commission (CEC) and the San Joaquin Valley Air Pollution Control District (SJVAPCD), respectively.

Hydrogen Energy International LLC (HEI or Applicant) is jointly owned by BP Alternative Energy North America Inc. and Rio Tinto Hydrogen Energy LLC. HEI is proposing to build the Project in Kern County, California. The Project will produce low-carbon baseload electricity by capturing carbon dioxide (CO₂) and transporting it for enhanced oil recovery (EOR) and sequestration.

The 473-acre Project Site is located approximately 7 miles west of the outermost edge of the city of Bakersfield and 1.5 miles northwest of the unincorporated community of Tupman in western Kern County, California, as shown in Figure 1-1, Project Vicinity Map. HEI is also acquiring an additional 628 acres of land adjacent to the Project Site, herein referred to as “Controlled Area” (see Figure 1-2). HEI will own this property and have control over public access and future land use. For the purposes of the Air Quality analysis, impacts were determined outside of both the Project Site and the Controlled Area.

The Project Site is near an oil producing area known as the Elk Hills Field. The entire Project Site is presently used for agricultural purposes, including cultivation of cotton, alfalfa, and onions. Existing surface elevations vary from about 282 feet to 291 feet above mean sea level.

The Project will gasify petroleum coke (or blends of petroleum coke and coal, as needed) to produce hydrogen to fuel a combustion turbine operating in combined cycle mode. The Gasification Unit feeds a 390 gross megawatt (MW) combined cycle plant. The net electrical generation output from the Project will provide California with approximately 250 MW, net, of low-carbon baseload power to the grid. The Gasification Unit will also capture approximately 90 percent of the carbon dioxide from the syngas at steady-state operation, which will be transported to the Elk Hills Field for CO₂ EOR and Sequestration. In addition, approximately 100 MW of natural gas generated peaking power will be available from the Project.

The HECA sources will be equipped with Best Available Control Technology (BACT) to control criteria pollutant emissions. The sources and control measures are discussed in Appendix B and listed in Table 2-6.

Operational emission estimates were based on full load operation of the sources comprising the power block, gasification block, and supporting systems. The emissions from power generation and gasification processes includes maximum supplemental firing and consideration of startup/shutdown events. An air dispersion modeling analysis was conducted to demonstrate that maximum modeled impacts are below applicable federal PSD significant impact levels for all criteria pollutants for which there are PSD increments. Air dispersion modeling also indicates that nitrogen dioxide (NO₂), sulfur dioxide (SO₂), carbon monoxide (CO), particulate matter (PM₁₀), and fine particulate matter (PM_{2.5}) impacts from the operation of the Project when combined with background are below the Ambient Air Quality Standard (AAQS) and would not significantly contribute to the existing violations of the state PM₁₀ or ozone standards, or

negatively impact visibility in Class I areas. See Chapter 2 for an explanation of federal, state, and local laws, ordinances, regulations, and standards. Criteria pollutant emissions are discussed in Chapter 5, and air dispersion modeling and compliance with ambient air quality standards and PSD increments are discussed in Chapter 6.

Air quality-related values (AQRVs) include visibility, terrestrial resources, and aquatic resources. AQRVs were assessed for the closest Class I area, which is the San Rafael Wilderness Area. A visibility analysis demonstrates that HECA will not significantly impact visibility. Maximum modeled annual NO₂ and SO₂ impacts from normal plant operations were assessed to ensure any nitrogen or sulfur deposition would not impact terrestrial or aquatic resources. All impacts are below U.S. Forest Service (USFS) significance criteria. Details of the analysis are included in Section 7.

1.1 PROJECT LOCATION

The Project Site consists of approximately 473 acres located near an oil producing area in Kern County, California, as shown in Figure 1-1, Vicinity Map. The Project Site is located in a predominantly agricultural area of the county, 1.5 miles northwest of the unincorporated community of Tupman. The 473-acre Project Site is located within Section 10 of Township 30 South, Range 24 East in Kern County. The Project Site Assessor's Parcel Numbers (APN) are as follows:

- Part of 159-040-16
- Part of 159-040-18

HEI is also acquiring an additional 628 acres of land adjacent to the Project Site, herein referred to as Controlled Area. HEI will own this property, and have control over public access and future land use. These areas are shown on Figure 1-2. The associated APNs of the Controlled Area are as follows:

- 159-040-02
- 159-040-04
- 159-040-11
- Remnant part of 159-040-16
- Remnant part of 159-040-18
- 159-190-09

The Project Site is predominantly used for agricultural purposes, including cultivation of cotton, alfalfa, and onions. The Project Site vicinity consists primarily of agricultural uses. Adjacent land uses include Adohr Road and agricultural uses to the north; Tupman Road and agricultural uses to the east, agricultural uses and an irrigation canal to the south; and a residence, structures (used for grain storage and organic fertilizer production), agricultural uses, and Dairy Road right of way to the west. The West Side/Outlet Canal, Kern River Flood Control Canal, and the California Aqueduct (State Water Project) are approximately 500, 700, and 1,900 feet south of the Project Site, respectively.

1.2 FACILITY DESCRIPTION

The preliminary plot plan for the Project is shown in Figure 1-3. The facility will gasify 100 percent petroleum coke (or blends of petroleum coke and coal, as needed) to produce hydrogen to fuel a combustion turbine operating in combined cycle mode. The Project will produce low carbon electricity while substantially reducing greenhouse gas emissions by capturing carbon dioxide (CO₂), transporting it for enhanced oil recovery (EOR), and sequestration.

Highlights of the Project are as follows:

- The Project is designed to operate with 100 percent petroleum coke from California refineries, and has the flexibility to operate with up to 75 percent thermal input (higher heating value) western bituminous coal.

- The feedstock will be gasified to produce a synthesis gas (syngas) that will be processed and purified to produce a hydrogen-rich gas, which will be used to fuel the combustion turbine for electric power generation. A portion of the product (hydrogen-rich gas) will also be used to supplementally fire the heat recovery steam generator (HRSG) that produces steam from the combustion turbine exhaust heat.
- At least 90 percent of the carbon in the raw syngas will be captured in a high-purity carbon dioxide stream during steady-state operation, compressed and transported by pipeline to the custody transfer point for injection into deep underground hydrocarbon reservoirs for CO₂ enhanced oil recovery and sequestration.
- Project greenhouse gas emissions (e.g., CO₂) and sulfur emissions will be reduced through carbon dioxide sequestration and state-of-the-art emission-control technology. The power produced by the Project will have a low-carbon emission profile significantly lower than would be produced by traditional fossil-fueled sources, including natural gas.
- The net electrical generation output from the Project will provide approximately 250 megawatts (MW) of low carbon baseload power to the grid, feeding major load sources to the north and to the south. In addition, approximately 100 MW of natural gas generated peaking power will be available from the Project.
- The water source for the Project will be brackish groundwater supplied by the Buena Vista Water Storage District, and treated on-site to meet Project standards. Potable water will be supplied by West Kern Water Bank for drinking and sanitary purposes.
- There will be no direct surface water discharge of industrial wastewater or storm water. Process wastewater will be treated on-site and recycled within the gasification and power plant systems. Other wastewaters from cooling tower blowdown and the water treatment plant will be collected and directed to one of two on-site plant wastewater Zero Liquid Discharge units.

The Project is designed with state-of-the-art emission-control technology. The gasification process will feature near zero sulfur emissions during steady-state operation. The Project is also designed to avoid flaring during steady-state operation, and to minimize flaring and sulfur emissions during startup and shut down operations.

The Project also includes the following off-site facilities, as shown on Figure 1-2, Project Location Map.

- **Electrical Transmission Line** – An electrical transmission line will interconnect the Project to Pacific Gas & Electric's (PG&E) Midway Substation. Two alternative transmission line routes are proposed; both alternatives are approximately 8 miles in length.
- **Natural Gas Supply Pipeline** – A natural gas interconnection will be made with PG&E or So Cal Gas natural gas pipelines, each of which is located southeast of the Project Site. The natural gas pipeline is approximately 8 miles in length.
- **Water Supply Pipelines** – The Project will utilize brackish groundwater supplied from the Buena Vista Water Storage District located to the northwest. The raw water supply pipeline will be approximately 15 miles in length. Potable water for drinking and sanitary use will be

supplied by West Kern Water District to the southeast. The potable water supply pipeline is approximately 7 miles in length.

- **Carbon Dioxide Pipeline** – The carbon dioxide pipeline will transfer the carbon dioxide captured during gasification from the Project Site southwest to the custody transfer point. Two alternative carbon dioxide pipeline routes are proposed; each of these alternatives is approximately 4 miles in length.

All temporary construction equipment laydown and parking, including construction parking, offices, and construction laydown areas, will be located on the Project Site.

The disturbed acreage associated with the Project is summarized in Table 1-1, Project Disturbed Acreage.

**Table 1-1
Project Disturbed Acreage**

Project Component	Size	Approx. Linear Length (miles)	ROW Construction	ROW Permanent	Temporary Disturbance	Permanent Disturbance
Project Site	473 acres	NA	NA	NA	473 acres	250
Electrical transmission line	25-foot diameter structural base (60 structures total)	8	175 FT ¹	150 FT	24 acres	0.67 ²
Natural gas pipeline	16-inch diameter	8	50 FT	25 FT	50 ³	0.33 ⁴
Process Water pipeline	20-inch diameter	15	50 FT	25 FT	93 ⁵	0.29 ⁶
Potable Water pipeline	6-inch diameter	7	Accounted for in Natural Gas Line ROW	Accounted for in Natural Gas Line ROW	Accounted for in Natural Gas Line ROW	Accounted for in Natural Gas Line ROW
CO ₂ pipeline	12-inch diameter	4	50 FT	25 FT	25 ³	0.11 ⁷
Temporary Construction Areas	Accounted for in Project Site	NA	NA	NA	Accounted for in Project Site	None
Total Project Disturbance					665	251.4

Source: HECA Project

Notes:

~ = approximately
CO₂ = carbon dioxide
ROW = right of way

¹ This is a maximum width required in areas where structures will be installed. However, total temporary disturbance along the entire route is calculated based on the following: (1) 150 FT x 150 FT area is required for each of the 60 structures, equaling 31 acres, and (2) 25-foot temporary roadway is required along the entire 8 mile line, equaling 24 acres.

² Consists of permanent ground disturbance associated with the base of the 60 new structures.

³ Acreage includes the area required for the entry/exit pits.

⁴ Acreage includes permanent disturbance occupied by the gas metering station located within the Controlled Area southeast of the Project Site.

⁵ Acreage includes the 100 by 150 foot temporarily disturbed area required for the construction of each of five groundwater wells.

⁶ Acreage includes the 50 by 50 foot permanent disturbed area required for each of five groundwater wells.

⁷ Acreage includes two 50 by 50 valve boxes positioned along the pipeline route.

1.3 EMISSIONS CONTROL AND MONITORING

The Project is designed with state-of-the-art emission-control technology. Emissions control systems will be designed to meet the BACT levels for nitrogen oxides, carbon monoxide, sulfur dioxide, and volatile organic compounds (VOCs), as proposed in this application, based on the most current industry data and manufacturers' information. Project emission control systems are described in detail below.

1.3.1 SCR Emissions Control System

The selective catalytic reduction (SCR) system reduces nitrogen oxide emissions from the HRSG stack gases and a separate SCR system reduces nitrogen oxide emissions from the Auxiliary Combustion Turbine Generator (CTG), each by up to about 70 to 80 percent. Diluted 19 percent aqueous ammonia is injected into the stack gases upstream of a catalytic system, which converts nitrogen oxide and ammonia to nitrogen and water.

The expected components in the SCR system are as follows:

Aqueous Ammonia Storage Tank – The aqueous ammonia storage tank is a horizontal or vertical vessel which stores 16,000 gallons of 19 weight percent aqueous ammonia for the SCR system. The storage tank will be complete with relief valves, level gauges, local audio alarms, and will also be located inside a containment area.

Aqueous Ammonia Forwarding Pumps – The aqueous ammonia forwarding pumps will transfer aqueous ammonia from the storage tank to the aqueous ammonia vaporizer.

Ammonia Vaporizer – The aqueous ammonia vaporizer atomizes and vaporizes the ammonia and water solution. Plant air or steam will atomize the aqueous ammonia to assist in the vaporization. The energy to vaporize the aqueous ammonia will come from a slip stream of hot stack gas or by heating ambient air with a heating element.

Vaporizer Blower – The vaporizer blower delivers fresh air or recycled hot stack gas from the HRSG into the aqueous ammonia vaporizer.

Ammonia Injection Grid – Once the aqueous ammonia is properly vaporized, the ammonia is sent to an injection grid where the ammonia stream is divided into various injection points upstream of a catalyst. The flow of ammonia to each injection point can be balanced to provide optimum nitrogen oxide reduction.

SCR Catalyst – The SCR catalyst provides the surface area and the catalyst to react ammonia and nitrogen oxide to form nitrogen and water. The SCR catalyst will be installed in a reactor housing located within the HRSG at the proper flue gas temperature-point for good nitrogen oxide conversion.

1.3.2 CO Oxidation System

A carbon monoxide catalyst will be installed in the HRSG casing and in the CTG upstream of the SCR ammonia injection location to reduce carbon monoxide emissions. The carbon monoxide catalyst will oxidize the carbon monoxide and VOCs produced from the CTG and duct burners.

1.3.3 Continuous Emissions Monitoring System

Continuous Emission Monitoring Systems (CEMS) will be installed on several stack emission sources as required by applicable regulations and permit conditions. The CEMS will be designed, installed, and certified in accordance with the applicable SJVAPCD and EPA standards for analyzer performance, data acquisition, and data reporting. In general, it is expected that these systems will sample, analyze, and record stack emission data for several specified pollutants. CEMS will incorporate data handling and acquisition systems to automatically generate emissions data logs and compliance documentation. Alarms will alert operators if stack emissions exceed specified limits. Each CEMS system will undergo periodic calibration, audits, and testing to verify accuracy. It is anticipated that the following CEMS systems will be required for the indicated emissions:

- HRSG – nitrogen oxide, carbon monoxide, and oxygen
- Auxiliary CTG – nitrogen oxide, carbon monoxide, and oxygen
- Tail Gas Thermal Oxidizer – sulfur dioxide and oxygen
- Hydrogen-rich Fuel – Total sulfur

In addition to continuous monitoring, the Project will perform periodic stack emission tests to verify compliance as required.

1.4 PROJECT SCHEDULE

The milestones for the Project are anticipated to be as follows:

Completion of CEC permitting process	May 2011
Start of construction	December 2011
Completion of construction	December 2014
Commissioning and initial startup	October 2014 through August 2015
Full-scale operation of the Project	September 2015

1.5 PROJECT OWNERSHIP

HEI is jointly owned by BP Alternative Energy North America Inc. and Rio Tinto Hydrogen Energy LLC, with the prime objective of producing hydrogen for low-carbon power generation. HEI proposes to be the owner and operator of the IGCC facilities and has the option to purchase the 473-acre Project Site, as defined below, from the site owner. HEI also has the option to purchase 628 acres that comprise the Controlled Area.

The transmission line will be owned by HEI up to the point of interconnect (Midway Substation) as stipulated by the California Independent System Operator (CAISO). HEI will own the carbon dioxide (CO₂) pipeline up to the custody transfer point. Natural gas supply lines will be owned by PG&E or Southern California Gas Company. The process water supply line will be owned by Buena Vista Water District. The potable water supply line will be owned by West Kern Water District.

1.6 APPLICANT CONTACT INFORMATION**Applicant Contact**

Gregory D. Skannal
HSSE Manager
Hydrogen Energy International LLC
One World Trade Center, Suite 1600
Long Beach, CA 90831-1600
Direct office phone: (562) 276-1511
Mobile phone: (630) 779-1882
email: gregory.skannal@hydrogenenergy.com

Technical Contact

Mark A. Strehlow
Senior Project Manager
URS Corporation
1333 Broadway, Suite 800
Oakland, CA 94612
Phone: (510) 874-3055
email: mark_strehlow@urscorp.com




PROJECT VICINITY

May 2009
28067571

Hydrogen Energy California (HECA)
Kern County, California

URS

FIGURE 1-1



LEGEND

AFC Project Site

Controlled Area

Carbon Dioxide

Natural Gas (NG)

Potable Water

Potable Water/NG

Process Water

Transmission

SITE PLAN


May 2009
28067571

Hydrogen Energy California (HECA)
Kern County, California

URS

FIGURE 1-2

Aerial Photo, Digital Globe, June 1, 2008.



EPA has ultimate responsibility for ensuring, pursuant to the Clean Air Act Amendments of 1990 (CAAA), that all areas of the U.S. meet, or are making progress toward meeting, the national ambient air quality standards (NAAQS). The State of California falls under the jurisdiction of EPA Region 9, which is headquartered in San Francisco. EPA requires that all states submit State Implementation Plans (SIPs) for non-attainment areas that describe how the NAAQS will be achieved and maintained. Attainment plans must be approved by the California Air Resources Board (CARB) before they are submitted to EPA.

Regional or local air quality management districts (or air districts), such as SJVAPCD are responsible for preparation of plans for attainment of federal and state standards. CARB is responsible for overseeing attainment of the California ambient air quality standards (CAAQS), implementation of nearly all phases of California's motor vehicle emissions program, and oversight of the operations and programs of the regional air districts.

Each air district is responsible for establishing and implementing rules and control measures to achieve air quality attainment within its district boundaries. The air district also prepares an air quality management plan (AQMP) that includes an inventory of all emission sources within the district (both man-made and natural), a projection of future emissions growth, an evaluation of current air quality trends, and an assessment of any rules or control measures needed to attain the NAAQS and CAAQS. This AQMP is submitted to CARB, which then compiles AQMPs from all air districts within the state into the SIP. The responsibility of the air districts is to maintain an effective permitting system for existing, new, and modified stationary sources, to monitor local air quality trends, and to adopt and enforce such rules and regulations as may be necessary to achieve the NAAQS and CAAQS.

Applicable laws, ordinances, regulations and standards (LORS) related to the potential air quality impacts from the Project are described below, and shown in Table 2-1, Laws, Ordinances, Regulations, and Standards – Air Quality. These LORS are administered (either independently or cooperatively) by the SJVAPCD, EPA Region 9, the California Energy Commission (CEC), and CARB. The area of responsibility for each of these agencies is described below.

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
Federal		
Clean Air Act 160-169A and implementing regulations, Title 42 United States Code (USC) 7470-7491 (42 USC 7470-7491; Title 40 Code of Federal Regulations (CFR) Parts 51 and 52 (40 CFR Parts 51 and 52) Prevention of Significant Deterioration Program)	Requires prevention of significant deterioration (PSD) review and facility permitting for construction of new or modified major stationary sources of air pollution. PSD review applies to pollutants for which ambient concentrations are lower than NAAQS.	USEPA Region 9
CAA 171-193, 42 USC 7501 et seq. (New Source Review)	Requires new source review (NSR) facility permitting for construction or modification of stationary sources. NSR applies to pollutants for which ambient concentrations are higher than NAAQS.	USEPA Region 9
CAA 401 (Title IV), 42 USC 7651 (Acid Rain Program); SJVAPCD Regulation IV, Rule 2540	Requires reductions in NO _x and SO ₂ emissions.	SJVAPCD, with USEPA Region 9 oversight
CAA 501 (Title V), 42 USC 7661 (Federal Operating Permits Program)	Establishes comprehensive permit program for major stationary sources.	SJVAPCD, with USEPA Region 9 oversight
CAA 111, 42 USC 7411, 40 CFR Part 60 (New Source Performance Standards, or NSPS)	Establishes national standards of performance for new stationary sources. This rule incorporates the New Source Performance Standards from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR).	SJVAPCD, with USEPA Region 9 oversight
State		
H&SC 44300-44384; Title 17 of The California Code of Regulations (17 CCR 93300-93300.5) Toxic “Hot Spots” Act	Requires preparation and biennial updating of facility emission inventory of hazardous substances; health risk assessments.	CARB
H&SC 41700	Provides that no person shall discharge from any source quantities of air contaminants of material which cause injury, detriment, nuisance, or annoyance to considerable number of persons or to the public which endanger the comfort, repose, health or safety or which can cause injury or damage to business or property.	CARB
California Public Resources Code 25523(a); 20 CCR 1752, 2300 2309 and Div. 2, Chap. 5, Art. 1, Appendix B, Park (k) (CEC and	Requires that CEC’s decision on the AFC include requirements to assure protection of environmental quality; AFC is required to address air quality protection.	CEC

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
CARB Memorandum of Understanding)		
The California Global Warming Solutions Act of 2006	Requires new baseload generation power plants to not exceed the rate of greenhouse gas emissions	CARB
California Code of Regulation. Title 20, §2902, Greenhouse Gases Emission Performance Standard.	The greenhouse gases emission performance standard (EPS) applicable to this chapter is 1,100 pounds of carbon dioxide per megawatt hour of electricity.	CARB
California Code of Regulation. Title 20, §2903, Compliance with the Emission Performance Standard	A power plant's compliance with the EPS shall be determined by dividing the power plant's annual average carbon dioxide emissions in pounds by the power plant's annual average net electricity production in MWh.	CARB
California Code of Regulation. Title 20, §2904, Annual Average Carbon Dioxide Emissions	<p>Except as provided in Subsections (b) and (c), a power plant's annual average carbon dioxide emissions are the amount of carbon dioxide produced on an annual average basis by each fuel used in any component directly involved in electricity production, including, but not limited to, the boiler, combustion turbine, reciprocating or other engine, and fuel cell. The fuels used in this calculation shall include, but are not limited to, primary and secondary fuels, backup fuels, and pilot fuels, and the calculation shall assume that all carbon in the fuels is converted to carbon dioxide. Fuels used in ancillary equipment, including, but not limited to, fire pumps, emergency generators, and vehicles shall not be included.</p> <p>(b) [not presented in this report because it pertains to biomass fuels and does not affect the Project]</p> <p>(c) For covered procurements that employ geological formation injection for CO2 sequestration, the annual average carbon dioxide emissions shall not include the carbon dioxide emissions that are projected to be successfully sequestered. The EPS for such power plants shall be determined based on projections of net emissions over the life of the power plant. Carbon dioxide emissions shall be considered successfully sequestered if the sequestration project meets the following requirements:</p> <p>(1) Includes the capture, transportation, and geologic formation injection of CO2 emissions;</p>	CARB

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
	(2) Complies with all applicable laws and regulations; and (3) Has an economically and technically feasible plan that will result in the permanent sequestration of CO2 once the sequestration project is operational.	
Local		
SJVAPCD Regulation II, Rule 2201	This rule shall apply to all new stationary sources and all modifications to existing stationary sources which are subject to the District permit requirements and after construction emit or may emit one or more affected pollutant. The requirements of this rule in effect on the date the application is determined to be complete by the Air Pollution Control Officer (APCO) shall apply to such application except as provided in Section 2.1.	SJVAPCD

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
SJVAPCD Regulation II, Rule 2520	<p>The purpose of this rule is to provide for the following:</p> <p>1.1 An administrative mechanism for issuing operating permits for new and modified sources of air contaminants in accordance with requirements of 40 Code of Federal Regulations (CFR) Part 70.</p> <p>1.2 An administrative mechanism for issuing renewed operating permits for sources air contaminants in accordance with requirements of 40 CFR Part 70.</p> <p>1.3 An administrative mechanism for revising, reopening, revoking, and terminating operating permits for sources of air contaminants in accordance with requirements of 40 CFR Part 70.</p> <p>1.4 An administrative mechanism for incorporating requirements authorized preconstruction permits issued under District Rule 2201 (New and Modified Stationary Source Review) in a Part 70 permit as administrative amendments, provided that such permits meet procedural requirements substantially equivalent the requirements of 40 CFR 70.7 and 70.8, and compliance requirements substantially equivalent to those contained in 40 CFR 70.6.</p> <p>1.5 The applicable federal and local requirements to appear on a single permit.</p>	SJVAPCD
SJVAPCD Regulation II, Rule 2540	All stationary sources subject to Part 72, Title 40, CFR	SJVAPCD
SJVAPCD Regulation II, Rule 2550	The provisions of this rule shall only apply to applications to construct or reconstruct a major air toxics source with Authority to Construct issued on or after 28 June 1998. Requirements for other projects that result in increases in emissions of hazardous air pollutants are addressed in the District's Risk Management Policy for Permitting New and Modified Sources.	SJVAPCD
SJVAPCD Regulation III	Identifies fees that are applicable to permit modifications, new facilities, and permitted emissions	SJVAPCD
SJVAPCD Regulation IV, Rule 4001	All new sources of air pollution and modification of existing sources of air pollution shall comply with the standards, criteria, and requirements set forth therein.	SJVAPCD
SJVAPCD Regulation IV, Rule 4002	This rule incorporates the National Emission Standards for Hazardous Air Pollutants from Part 61, Chapter I, Subchapter C, Title 40, CFR and the National Emission Standards for Hazardous Air Pollutants for Source Categories from Part 63, Chapter I, Subchapter C, Title 40, CFR.	SJVAPCD
SJVAPCD Regulation IV, Rule 4101	The provisions of this rule shall apply to any source operation which emits or may emit air contaminants.	SJVAPCD

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
SJVAPCD Regulation IV, Rule 4102	This rule shall apply to any source operation which emits or may emit air contaminants or other materials.	SJVAPCD
SJVAPCD Regulation IV, Rule 4201	Particulate Matter Concentration 0.1 grains/scf of gas at dry standard conditions.	SJVAPCD
SJVAPCD Regulation IV, Rule 4202	Particulate Matter Emission - this rule provides a table of emission rates in lbs/hr, based on process feed rates.	SJVAPCD
SJVAPCD Regulation IV, Rule 4301	The purpose of this rule is to limit the emission of air contaminants from fuel burning equipment. This rule limits the concentration of combustion contaminants and specifies maximum emission rates for sulfur dioxide, nitrogen oxides and combustion contaminant emissions.	SJVAPCD
SJVAPCD Regulation IV, Rule 4304	The purpose of this rule is to provide an equipment tuning procedure for boilers, steam generators and process heaters to control visible emissions and emissions of both nitrogen oxides (NO _x) and carbon monoxide (CO).	SJVAPCD
SJVAPCD Regulation IV, Rule 4305-4308	The purpose of this rule is to limit emissions of NO _x and CO from boilers, steam generators, and process heaters.	SJVAPCD
SJVAPCD Regulation IV, Rule 4311	Potential conflicts with SJVAPCD flaring regulations	SJVAPCD
SJVAPCD Regulation IV, Rule 4701	Except as provided in Section 4.0, the provisions of this rule apply to any internal combustion engine, rated greater than 50 brake horsepower (bhp) that requires a Permit to Operate (PTO).	SJVAPCD
SJVAPCD Regulation IV, Rule 4702	This rule applies to any internal combustion engine with a rating of greater than 50 bhp.	SJVAPCD
SJVAPCD Regulation IV, Rule 4703	Stationary Gas Turbines - will affect NO _x and CO emissions.	SJVAPCD
SJVAPCD Regulation IV, Rule 4801	Sulfur Compounds - 0.2 % by volume calculated as SO ₂	SJVAPCD
SJVAPCD Regulation VIII	The purpose of Regulation VIII (Fugitive PM ₁₀ Prohibitions) is to reduce ambient concentrations of fine particulate matter (PM ₁₀) by requiring actions to prevent, reduce or mitigate anthropogenic fugitive dust emissions. The Rules contained in this Regulation have been developed pursuant to U.S. Environmental Protection Agency guidance for Serious PM ₁₀ Nonattainment Areas. The rules are applicable to specified anthropogenic fugitive dust sources. Fugitive dust contains PM ₁₀ and particles larger than PM ₁₀ . Controlling fugitive dust emissions when visible emissions are detected will not prevent all	SJVAPCD

Table 2-1
Laws, Ordinances, Regulations, and Standards – Air Quality

Laws, Ordinances, Regulations, and Standards	Applicability	Administering Agency
	PM10 emissions, but will substantially reduce PM10 emissions.	
SJVAPCD Regulation IX	This Rule specifies the criteria and procedures for determining the conformity of federal actions with the SJVAPCD's air quality implementation plan.	SJVAPCD
Industry		
None Applicable	None Applicable	

Notes:

bhp = brake horsepower
 CAA = Clean Air Act (federal)
 CAAQS = California Ambient Air Quality Standard
 CARB = California Air Resources Board
 CEC = California Energy Commission
 CFR = Code of Federal Regulations
 CO = Carbon monoxide
 NAAQS = National Ambient Air Quality Standard
 NO_x = Nitrous Oxide
 PM₁₀ = particulate matter
 SJVAPCD = San Joaquin Valley Air Pollution Control District
 SO₂ = Sulfur dioxide

2.1 AMBIENT AIR QUALITY STANDARDS

The EPA, in response to the federal CAA of 1970, established NAAQS in Title 40 CFR Part 50. The NAAQS include both primary and secondary standards for six “criteria” pollutants. These criteria pollutants are ozone (O₃), carbon monoxide (CO), nitrogen dioxide (NO₂), sulfur dioxide (SO₂), particulate matter (PM₁₀), and lead (Pb). Primary standards were established to protect human health, and secondary standards were designed to protect property and natural ecosystems from the effects of air pollution.

The 1990 CAAA established attainment deadlines for all designated areas that were not in attainment with the NAAQS. In addition to the NAAQS described above, a new federal standard for fine particulate matter (PM_{2.5}) and a revised O₃ standard were promulgated in July 1997. The new federal standards were challenged in a court case during 1998. The court required revisions in both standards before EPA could enforce them. The U.S. Supreme Court upheld an appeal of the District Court decision in February 2001. These issues were resolved and the 1-hour O₃ standard revoked in 2005 while the revised PM_{2.5} standard was made effective in 2006. The state of California has adopted CAAQS that are in some cases more stringent than the NAAQS. The NAAQS and CAAQS relevant to the Project are summarized in Table 2-2, Relevant Ambient Air Quality Standards.

EPA, CARB, and the local air pollution control districts determine air quality attainment status by comparing local ambient air quality measurements from the state or local ambient air monitoring stations with the NAAQS and CAAQS. Those areas that meet ambient air quality standards are classified as “attainment” areas; areas that do not meet the standards are classified as “non-attainment” areas. Areas that have insufficient air quality data may be identified as unclassifiable areas. These attainment designations are determined on a pollutant-by-pollutant basis. The area around the Project Site is classified as attainment with respect to the NAAQS for NO₂, PM₁₀, CO, and SO₂, and non-attainment for O₃ and PM_{2.5}. With respect to CAAQS, the area around the Project Site is classified as attainment for NO₂, CO, sulfates, Pb, hydrogen sulfide (H₂S), and SO₂, and non-attainment for O₃, PM₁₀, and PM_{2.5}. Nitrogen dioxide and SO₂ are regulated as PM₁₀ precursors, and NO₂ and volatile organic compounds (VOCs) as O₃ precursors. Table 2-3, Attainment Status for Kern County with Respect to Federal and California Ambient Air Quality Standards, presents the attainment status (both federal and state) for the San Joaquin Valley Air Basin (SJVAB).

As mentioned above, both EPA and CARB are involved with air quality management in the San Joaquin Air Basin (SJVAB) area along with the SJVAPCD.

Table 2-2
Relevant Ambient Air Quality Standards

Pollutant	Averaging Time	NAAQS ¹		CAAQS ²
		Primary ^{3,4}	Secondary ^{3,5}	Concentration ³
Ozone (O ₃)	1-Hour	Revoked ⁸	Same as Primary Standard	0.09 ppm (180 µg/m ³)
	8-Hour	0.075 ppm		0.07 ppm (137 µg/m ³)
Carbon Monoxide (CO)	8-Hour	9 ppm (10 mg/m ³)	None	9.0 ppm (10 mg/m ³)
	1-Hour	35 ppm (40 mg/m ³)		20 ppm (23 mg/m ³)
Nitrogen Dioxide (NO ₂) ⁹	Annual Average	0.053 ppm (100 µg/m ³)	Same as Primary	0.030 ppm (57 µg/m ³)

**Table 2-2
Relevant Ambient Air Quality Standards**

Pollutant	Averaging Time	NAAQS ¹		CAAQS ²
		Primary ^{3,4}	Secondary ^{3,5}	Concentration ³
	1-Hour	-	Standard	0.18 ppm (339 µg/m ³)
Sulfur Dioxide (SO ₂)	Annual Average	0.03 ppm (80 µg/m ³)	-	-
	24-Hour	0.14 ppm (365 µg/m ³)	-	0.04 ppm (105 µg/m ³)
	3-Hour	-	0.5 ppm (1,300 µg/m ³)	-
	1-Hour	-	-	0.25 ppm (655 µg/m ³)
Suspended Particulate Matter (PM ₁₀)	24-Hour	150 µg/m ³	Same as Primary Standard	50 µg/m ³
	Annual Arithmetic Mean	Revoked ⁶		20 µg/m ³
Fine Particulate Matter (PM _{2.5}) ⁷	24-Hour	35 µg/m ³	Same as Primary Standard	-
	Annual Arithmetic Mean	15 µg/m ³		12 µg/m ³
Lead (Pb)	30-Day Average	-	-	1.5 µg/m ³
	Quarterly Average	1.5 µg/m ³	Same as Primary Standard	-
Hydrogen Sulfide (H ₂ S)	1-Hour	No Federal Standards		0.03 ppm (42 µg/m ³)
Sulfates (SO ₄)	24-Hour			25 µg/m ³
Visibility Reducing Particles	8-Hour (10 am to 6 pm, Pacific Standard Time)			In sufficient amount to produce an extinction coefficient of 0.23 per kilometer due to particles when the relative humidity is less than 70 percent.

Source: CARB. 2009. (<http://www.arb.ca.gov/aqs/aaqs2.pdf>)

Notes:

- National standards (other than ozone, particulate matter, and those based on annual averages or annual arithmetic mean) are not to be exceeded more than once a year. The ozone standard is attained when the fourth highest 8-hour concentration in a year, averaged over 3 years, is equal to or less than the standard. For PM₁₀, the 24-hour standard is attained when the expected number of days per calendar year with a 24-hour average concentration above 150 µg/m³ is equal to or less than one. For PM_{2.5}, the 24-hour standard is attained when 98 percent of the daily concentrations, averaged over 3 years, are equal to or less than the standard. Contact USEPA for further clarification and current federal policies.
- California standards for ozone, carbon monoxide (except Lake Tahoe), sulfur dioxide (1 and 24 hour), nitrogen dioxide, suspended particulate matter—PM₁₀, PM_{2.5}, and visibility-reducing particles, are values that are not to be exceeded. All others are not to be equaled or exceeded. California ambient air quality standards are listed in the Table of Standards in § 70200 of Title 17 of the California Code of Regulations.
- Concentration expressed first in units in which it was promulgated. Equivalent units given in parentheses are based upon a reference temperature of 25°C and a reference pressure of 760 torr. Most measurements of air quality are to be corrected to a reference temperature of 25°C and a reference pressure of 760 torr; ppm in this table refers to ppm by volume, or micromoles of pollutant per mole of gas.
- National Primary Standards: The levels of air quality necessary, with an adequate margin of safety to protect the public health.
- National Secondary Standards: The levels of air quality necessary to protect the public welfare from any known or anticipated adverse effects of a pollutant.
- Due to a lack of evidence linking health problems to long-term exposure to coarse particle pollution, the agency revoked the annual PM₁₀ standard in 2006 (effective 17 December 2006).
- To attain this standard, the 3-year average of the 98th percentile of 24-hour concentrations at each population-oriented monitor within an area must not exceed 35 µg/m³ (effective 17 December 2006)
- On 15 June 2005, the 1-hour ozone standard (0.12 ppm) was revoked for all areas except the 8-hour ozone nonattainment Early Action Compact Areas (EAC) areas.

µg/m³ = micrograms per cubic meter

NAAQS = National Ambient Air Quality Standards

Table 2-2
Relevant Ambient Air Quality Standards

Pollutant	Averaging Time	NAAQS ¹		CAAQS ²
		Primary ^{3,4}	Secondary ^{3,5}	Concentration ³
CAAQS = California Ambient Air Quality Standards ppm = parts per million ³				
mg/m ³ = milligram per cubic meter				

Table 2-3
Attainment Status for Kern County with Respect to
Federal and California Ambient Air Quality Standards

Pollutant	Federal Attainment Status	State Attainment Status
Ozone	Non-attainment	Non-attainment
CO	Attainment	Attainment
NO ₂	Attainment	Attainment
SO ₂	Attainment	Attainment
PM ₁₀	Attainment ¹	Non-attainment
PM _{2.5}	Non-attainment	Non-attainment
Lead	Unclassified	Attainment

Source: CARB-CAAQS (<http://www.arb.ca.gov/aqs/aaqs2.pdf>)

Notes:

1 = On September 25, 2008, EPA redesignated the San Joaquin Valley to attainment for the PM₁₀ National Ambient Air Quality Standard (NAAQS) and approved the PM₁₀ Maintenance Plan.

CO = carbon monoxide

NO₂ = nitrogen dioxide

PM₁₀ = particulate matter less than 10 microns in diameter

PM_{2.5} = particulate matter less than 2.5 microns in diameter

SO₂ = sulfur dioxide

2.2 PREVENTION OF SIGNIFICANT DETERIORATION

The federal prevention of significant deterioration (PSD) program has been established to protect deterioration of air quality in those areas that already meet NAAQS. The PSD program specifies allowable concentration increases for attainment pollutants due to new emission sources. These increases allow economic growth while preserving the existing air quality, protecting public health and welfare, and protecting Class I areas (national parks and wilderness areas). The PSD regulations require major stationary sources to undergo a pre-construction review that includes an analysis and implementation of BACT, a PSD increment consumption analysis, an ambient air quality impact analysis, and analysis of AQRVs (impacts on visibility). The Project is subject to these requirements.

The PSD applicability triggers for CO, SO₂, NO_x, PM₁₀, VOCs, and Pb are as shown in Table 2-4, PSD Emission Threshold Triggers for New Stationary Sources. For Project emissions of CO, NO_x, and PM₁₀ above these PSD triggers, the Applicant must demonstrate through modeling that such emissions will not interfere with the attainment or maintenance of the

applicable NAAQS and will not cause an exceedance of the applicable PSD increments shown in Table 2-5, Prevention of Significant Deterioration Allowable Increments (in micrograms per cubic meter [$\mu\text{g}/\text{m}^3$]). For all Project emissions, the Applicant must demonstrate through modeling that the increase in emissions will not interfere with the attainment or maintenance of the NAAQS.

Table 2-4
PSD Emission Threshold Triggers for New Stationary Sources

Pollutant	Applicability Thresholds (tpy)	Project Emissions (tpy)	PSD Triggered by Project?
CO	100	350	Yes
SO ₂	100	42.2	No
NO _x	100	204	Yes
PM ₁₀	100	141	Yes
VOCs	100	32.5	No
Pb	0.6	<0.6	No

Source: 40 CFR § 52.21 and HECA Project.

Notes:

Project emissions include all emissions from natural gas.

CO = carbon monoxide

NO_x = nitrogen dioxide

Pb = lead

PM₁₀ = particulate matter less than 10 microns in diameter

SO₂ = sulfur dioxide

VOC = volatile organic compound

Table 2-5
Prevention of Significant Deterioration Allowable Increments
($\mu\text{g}/\text{m}^3$)

Standard	Class I Area	Class II Area	Class III Area
PM ₁₀ Annual Arithmetic Mean	4	17	34
PM ₁₀ 24-Hour Maximum	8	30	60
SO ₂ Annual Arithmetic Mean	2	20	40
SO ₂ 24-Hour Maximum	5	91	182
SO ₂ 3-Hour Maximum	25	512	700
NO ₂ Annual Arithmetic Mean	2.5	25	50

Source: 40 CFR § 52.21.

$\mu\text{g}/\text{m}^3$ = micrograms per cubic meter

NO₂ = nitrogen dioxide

PM₁₀ = particulate matter less than 10 microns in diameter

SO₂ = sulfur dioxide

2.3 ACID RAIN PROGRAM REQUIREMENTS

Title IV of the CAAA applies to sources of air pollutants that contribute to acid rain formation, including certain sources of SO₂ and NO_x emissions. Title IV is implemented by USEPA under

40 CFR 72, 73, and 75. The SJVAPCD has been delegated the authority by EPA to administer Title IV requirements under its Title V Operating Permit program in Regulation II. The Acid Rain Program provisions of 40 CFR Part 72, Subparts A through I are incorporated in SJVAPCD Rule 2540. Allowances of SO₂ emissions are set aside in 40 CFR 73. Sources subject to Title IV are required to obtain SO₂ allowances, to monitor their emissions, and obtain SO₂ allowances when a new source is permitted. Sources such as the Project that utilize fossil-derived fuel are required to comply with the acid rain program requirements. Under this program, the Applicant is subject to the following requirements:

- Submittal of an Acid Rain permit application
- Remain in compliance with SO₂ and NO_x limitations/allowances
- Preparation and maintenance of an Acid Rain Compliance Plan
- Installation and maintenance of emission monitoring system

The Project is a new facility, and therefore, an Acid Rain Permit application will be submitted to SJVAPCD at least 24 months before the date of initial operation of the unit.

To meet the NO_x and SO₂ requirements, the Project must estimate SO₂ and carbon dioxide emissions, and monitor NO_x emissions with certified CEMS.

2.4 NEW SOURCE PERFORMANCE STANDARDS

New Source Performance Standards (NSPS) have been established by USEPA to limit air pollutant emissions from certain types of new and modified stationary sources. The NSPS regulations are contained in 40 CFR Part 60 and cover nearly 70 source categories. CTG/HRSG is regulated under Subpart Da.

In general, local emission limitation rules or BACT requirements are more restrictive than the NSPS requirements. A case-by-case applicability of NSPS regulations for the sources is further discussed in the BACT analysis document (Appendix A).

2.5 FEDERALLY MANDATED OPERATING PERMITS

Title V of the CAAA requires EPA to develop a federal operating permit program that is implemented under 40 CFR Part 70. This program is administered by SJVAPCD under Regulation II, Rule 2520. Each major source, Phase II acid rain facility, and other source types designated by USEPA must obtain a Part 70 permit. Permits must contain emission estimates based on potential-to-emit, identification of all emission sources and controls, a compliance plan, and a statement indicating each source's compliance status. The permits must also incorporate all applicable federal, state, or SJVAPCD orders, rules and regulations.

Because the Project will constitute a new stationary source, the Applicant will submit a complete Title V permit application for a Title V permit to operate within 12 months after Power Block startup.

2.6 CALIFORNIA POWER PLANTS SITING REQUIREMENTS

Under its approved certified regulatory program, which is a CEQA equivalent program, CEC has been charged with assessing the environmental impacts of each new power plant and considering the implementation of feasible mitigation measures to prevent potential significant impacts. CEQA Guidelines (Title 14, California Administrative Code, §15002(a)(3)) state that the basic purpose of CEQA is to “prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible.”

CEC’s siting regulations require that, except under certain conditions, a new power plant can only be approved if the project complies with all federal, state, and local air quality rules, regulations, standards, guidelines, and ordinances that govern the construction and operation of the project. A project must demonstrate that project emissions will be appropriately controlled to mitigate significant impacts from the project and that it will not jeopardize attainment and maintenance of the ambient air quality standards. Cumulative impacts, impacts due to pollutant interaction, and impacts from non-criteria pollutants must also be considered.

2.7 AIR TOXICS “HOT SPOTS” PROGRAM

As required by the California Health and Safety Code §44300, all facilities with criteria air pollutant emissions in excess of 10 tons per year are required to submit air toxic “Hot Spots” emissions information. The Project will be required to provide quantitative information to SJVAPCD on the Project’s emissions of toxic air contaminants. This requirement is applicable only after the start of operation.

2.8 DETERMINATION OF COMPLIANCE, AUTHORITY TO CONSTRUCT AND PERMIT TO OPERATE

Under Regulation II, Rule 2010, 2070, and 2201, SJVAPCD administers the air quality regulatory program for the construction, alteration, replacement, and operation of new power plants. As part of the AFC process, the Project will be required to obtain a pre-construction Determination of Compliance (DOC) from the SJVAPCD. Regulation II, Rule 2201 incorporates other SJVAPCD rules that pertain to sources that may emit air contaminants through the issuance of air permits (i.e., Authority to Construct [ATC] and Permit to Operate [PTO]). This permitting process allows the SJVAPCD to adequately review new and modified air pollution sources to ensure compliance with all applicable prohibitory rules and to ensure that appropriate emission controls are used. An ATC allows for the construction of the air pollution source and remains in effect until the PTO application is granted, denied, or cancelled. Projects that are reviewed under the CEC application process must obtain an ATC from the local air district (in this case, SJVAPCD) prior to construction of the new power plant. For power plants under the siting jurisdiction of the CEC, the SJVAPCD issues a DOC in lieu of an ATC. The DOC is incorporated into the CEC license. The ATC remains in effect until the PTO application is granted, denied, or cancelled. Once the Project commences operations and demonstrates compliance with the DOC, SJVAPCD will issue a PTO. The PTO specifies conditions that the air pollution source must meet to comply with other air quality standards and will incorporate

applicable DOC requirements. An application for the DOC will be submitted to the SJVAPCD simultaneously with the filing of the Revised AFC.

2.9 SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT REQUIREMENTS

The SJVAPCD has been delegated responsibility for implementing the federal, state, and local regulations on air quality in Kern County to achieve and maintain both state and federal air quality standards; implementing permit programs established for the construction, modification, and operation of sources of air pollution; enforcing air pollution statutes, regulations and prohibitory rules governing non-vehicular sources; and developing programs to reduce emissions from indirect sources. The Project is subject to SJVAPCD regulations that apply to new sources of emissions, to the prohibitory regulations that specify emissions standards, and to the requirements for evaluation of air pollutant impacts for both criteria and toxic air pollutants. The following sections include the evaluation of the Project's compliance with the applicable SJVAPCD requirements.

2.10 RULES AND REGULATIONS

Rule 1080, Stack Monitoring

Outlines facility requirements for continuous monitoring equipment from any facility emitting pollutants for which emission limits have been established. The Project will be constructed and operated to comply with the requirements of Rule 1080.

Rule 1081, Source Sampling

Outlines facility design requirements for source sampling from any facility emitting pollutants for which emission limits have been established. The Project will be constructed and operated to comply with the requirements of Rule 1081.

Rule 1100, Equipment Breakdown

This rule details the notification and corrective action requirements necessary in an equipment breakdown situation. As operator of the Project, the Applicant will comply with these requirements.

Rule 2010, Permits Required

An ATC and PTO will be required for the Project. The Applicant will submit the required application materials for these permits to SJVAPCD.

Rule 2201, New and Modified Stationary Source Review

This rule outlines the emission standards, the offset requirements and conditions, the required demonstrations that the new source or modification will not cause or contribute to violations of the ambient air quality standards, procedures for power plants under the CEC process, methods for calculating project emissions, and required air quality analysis procedures. Compliance with the specific provisions of this rule is discussed below.

BACT. An Applicant must apply BACT to any new or modified emissions unit that has a potential to emit 2.0 pounds per day or more of any pollutant. The SJVAPCD maintains a list of current BACT standards for specific source categories, which is posted on the District's website. Appendix A provides a formal BACT evaluation for the Project. The proposed BACT levels for the Project turbines are shown in Table 2-6, Proposed BACT for the Project.

**Table 2-6
Proposed BACT for the Project**

Pollutant	Technology	Emission Limit
CTG/HRSG Combustion Turbine (excluding Start up/Shutdown conditions)		
NOx	Diluent Injection, Selective Catalytic Reduction	4 ppm NO _x @ 15% O ₂ on hydrogen-rich fuel and natural gas fuel, 3-hour average
CO	Good Combustion Practice (GCP), CO Catalyst	3 ppm CO @ 15% O ₂ on hydrogen-rich fuel, 5 ppm CO @ 15% O ₂ on natural gas fuel
PM/PM ₁₀	GCP, Gas Cleanup, Gaseous Fuels	24 lb/hr on hydrogen-rich fuel, 18 lb/hr on natural gas fuel
SO ₂	Hydrogen-rich Gas cleanup, pipeline quality natural gas	≤ 5 ppmv in undiluted total sulfur (hydrogen-rich syngas) ≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC	CO Catalyst	1 ppm VOC @ 15% O ₂ on hydrogen-rich fuel, 2 ppm VOC @ 15% O ₂ on natural gas fuel
NH ₃	Selective Catalytic Reduction	5 ppm NH ₃ slip on hydrogen-rich fuel and natural gas fuel
Auxiliary CTG (excluding Start up/Shutdown conditions) Natural Gas fired.103.3 MW		
NOx	Diluent Injection, Selective Catalytic Reduction	2.5 ppm NO _x @ 15% O ₂ on natural gas fuel, 3-hour average
CO	CO Catalyst	6.0 ppm CO @ 15% O ₂
PM/PM ₁₀	PUC regulated natural gas	6 lb/hr on natural gas fuel
SO ₂		≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC	CO Catalyst	2 ppm VOC @ 15% O ₂ on natural gas fuel
NH ₃	Selective Catalytic Reduction	10 ppm NH ₃ slip on natural gas fuel
Cooling Towers		
PM/PM ₁₀	High Efficiency Drift Eliminators, TDS limit in circulating water, and Good Operating Practice	0.0005% drift as percent of the circulating water
Auxiliary Boiler, Natural Gas 142 MMBtu/hr		
NOx	Low NO _x Burner with FGR	9 ppm NO _x @ 3% O ₂ on natural gas fuel
CO	GCP	50 ppmvd @ 3% O ₂
PM/PM ₁₀	GCP, PUC grade natural gas fuel	0.005 lb/MMBtu heat input
SO ₂		≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC		0.004 lb/MMBtu heat input
Emergency Diesel Engines (2 Emergency Generators)		
NOx	Combustion controls, restricted operating hours	0.5 g/brake horsepower (bhp)/hr
CO		0.29 g/bhp/hr
PM/PM ₁₀	Combustion controls, Low Sulfur Diesel fuel, restricted operating hours	0.03 g/bhp/hr
SO ₂		N/A
VOC		0.11 g/bhp/hr

**Table 2-6
Proposed BACT for the Project**

Pollutant	Technology	Emission Limit
Emergency Diesel Engines (Fire Pump)		
NOx	Combustion controls, restricted operating hours	1.5 g/bhp/hr
CO		2.60 g/bhp/hr
PM/PM ₁₀	Combustion controls, Low Sulfur Diesel fuel, restricted operating hours	0.015 g/bhp/hr
SO ₂		N/A
VOC		0.14 g/bhp/hr
Gasification Flare		
NO _x , CO, PM/PM ₁₀ , SO ₂ , VOC		GCP, gaseous fuel only, Gas cleanup/Limit on reduced sulfur in syngas
Thermal Oxidizer (Sulfur Recovery System)		
NOx	GCP	4.8 lb/hr 24-hour average
CO		4.0 lb/hr, 1-hour average
PM/PM ₁₀		0.16 lb/hr 24-hour average
SO ₂	GCP, Gas cleanup	2.02 lb/hr, 3-hour average
VOC	GCP	32.84 lb/hr, annual average
SRU Flare with natural gas assist (Sulfur Recovery System)		
NO _x		GCP
CO		
PM/PM ₁₀		GCP, gaseous fuel only
SO ₂		GCP, Caustic Scrubber
VOC		GCP
CO ₂ Vent		
CO	Gas Cleanup	1,000 ppmv
VOC	Gas Cleanup	40 ppmv
Gasifier Warming (refractory heater)		
NOx	GCP	0.11 lb/MMBtu, higher heating value (HHV)
CO	GCP	0.09 lb/MMBtu, HHV
PM/PM ₁₀	GCP, gaseous fuel only	0.008 lb/MMBtu, HHV
SO ₂	GCP, PUC grade Natural gas	0.002 lb/MMBtu, HHV (12.65 ppm)
VOC	GCP	0.007 lb/MMBtu, HHV
Feedstock		
PM/PM ₁₀	Dust Collector	0.005 grain/scf outlet dust loading

Source: HECA Project

Notes:

BACT = best available control technology
 CO = carbon monoxide
 CPUC = California Public Utility Commission
 CTG = combustion turbine generator
 FGR = flue gas recirculation
 MMBtu = million British thermal units

NO_x = nitrogen dioxide
 O₂ = oxygen
 PM/PM₁₀ = particulate matter/particulate matter less than 10 microns
 ppm = parts per million
 ppmvd = parts per million volumetric dry
 SCF = standard cubic feet
 SO₂ = sulfur dioxide
 VOC = volatile organic compound

Section 4.5, Emissions Offset Requirements. This section of Rule 2201 requires that offsets be provided for a new stationary source with a potential to emit equal to or exceeding the established levels.

Section 4.14, Ambient Air Quality Standards. Emissions from a new or modified Stationary Source may not cause or make worse the violation of an AAQS. Modeling used for the purposes of demonstrating compliance with this rule must be consistent with the requirements contained in the most recent edition of USEPA's *Guidelines on Air Quality Models*, unless the Air Pollution Control Officer finds that such model is inappropriate for use. After making such a finding, the Air Pollution Control Officer may designate an alternate model only after allowing for public comments and only with the concurrence of CARB or the USEPA.

As described in Section 6.7, Compliance with Ambient Air Quality Standards, an air quality modeling analysis has been conducted to demonstrate that the Project will not cause or make worse the violation of any air quality standard.

Section 5.8, Power Plants. This section applies to all power plants proposed to be constructed in the SJVAPCD and for which a Notice of Intention or AFC has been accepted by the CEC. It describes the actions to be taken by SJVAPCD to provide information to CEC and CARB to ensure that the Project will conform to the District's rules and regulations. After the application has been submitted to CEC and other responsible agencies, including SJVAPCD, the Air Pollution Control Officer is required to conduct a DOC review. This determination consists of a review identical to that which would be performed if an application for an ATC had been received for the power plant. If the information contained in the AFC does not meet the requirements of this regulation, then the Air Pollution Control Officer is required to so inform the CEC within 20 calendar days following receipt of the AFC. In such an instance, the AFC is considered to be incomplete and returned to the Applicant for re-submittal.

Section 6.0, Certification of Conformity. This section describes how a new or modified source that is subject to the requirements of Rule 2520 may choose to apply for a certificate of conformity with the procedural requirements of 40 CFR Part 70 for a Federal Operating Permit. A certificate of conformity will allow changes authorized by the ATC permit to be incorporated in the Part 70 permit as administrative permit amendments.

Rule 2520, Federally Mandated Operating Permits

Provides an administrative mechanism for issuing operating permits for new and modified sources of air contamination accordance with the federal requirements of 40 CFR Part 70. Under this rule, the Project will be required to obtain an operating permit, because it will include emission units that are subject to recently promulgated NSPS and because it will also require an acid rain permit.

Rule 3010/3020, Permit Fees

This rule and the fee schedules in rule 3020 establish the filing and permit review fees for specific types of new sources, as well as annual renewal fees and penalty fees for existing sources.

Rule 3110, Air Toxics Fees

This rule applies to facilities subject to the requirements of the Air Toxics “Hot Spots” Information and Assessment Act (§§ 44340 and 44383 of the California Health and Safety Code) and to facilities subject to National Emission Standards for Hazardous Air Pollutants (NESHAPs) issued pursuant to §112 of the federal CAA.

Rule 3135, Dust Control Plan Fee

This rule recovers the District’s cost for reviewing Dust Control Plans and conducting site inspections to verify compliance with such plans.

Rule 3170, Federally Mandated Ozone Non-attainment Fee

The purpose of this rule is to satisfy requirements specified in §185 and §182(f) of the CAA. This rule applies to major sources of NO_x and VOC. The fees required pursuant to this section are additional to the permit fees and other fees required under other Rules and Regulations. This rule will cease to be effective when the Administrator of USEPA designates the SJVAPCD to be in attainment of the federal 1-hour standard for O₃. The Project will be a major source under either the federal or SJVAPCD definitions and is subject to Rule 3170.

Rule 4001, New Source Performance Standards

This rule incorporates the federal NSPS from 40 CFR Part 60.

Rule 4002, National Emission Standards for Hazardous Air Pollutants

This rule incorporates the federal NESHAPs from Part 61 and Part 63, Chapter I, Subchapter C, Title 40 CFR.

Rule 4101, Visible Emissions

This rule applies to the opacity of discharges from any single source. Emissions from the sources of the Project will be below threshold opacity levels described in this rule.

Rule 4102, Nuisance

This rule states that there shall be no discharge of such quantities of any pollutant or material which could cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public or which endanger the comfort, repose, health, or safety of any such persons or the public or which cause or have a natural tendency to cause injury or damage to business or property.

Rule 4201, Particulate Matter Concentration

This rule applies to the discharge of particulate matter into the atmosphere. The relevant limit for the Project is expressed in Rule 4201, which states that no person shall release or discharge into the atmosphere from any single source operation dust, fumes, or total suspended particulate matter, in excess of 0.1 grains per dry standard cubic foot of natural gas as determined by following test methods: Particulate matter concentration – USEPA Method 5; Stack gas velocity – USEPA Method 2; Stack gas moisture – USEPA Method 4. The Project natural gas turbines

will easily comply with this requirement, with a maximum PM₁₀ emission rate of approximately 0.045 grains per dry standard foot of natural gas consumption.

Rule 4301, Fuel-burning Equipment

This rule limits the emission levels of NO_x, SO₂, and fuel combustion contaminants (particulates) from any fuel burning equipment unit. The specific limits are 140 pounds per hour of NO_x, calculated as NO₂, 200 pounds per hour of SO₂, 0.1 grains per cubic foot of gas calculated to 12 percent of carbon dioxide at dry standard conditions, and 10 pounds per hour of combustion contaminants.

Rule 4703, Stationary Gas Turbines

This rule limits the NO_x and CO emissions from gas turbines with ratings greater than 0.3 MW. NO_x emissions concentrations shall be averaged over a 3-hour period using consecutive 15-minute sampling periods, or if CEMS are used, all applicable requirements of 40 CFR Part 60 must be met.

Rule 4801 – Sulfur Compounds

This rule limits the emissions of sulfur compounds to less than 0.2 percent by volume on a dry basis averaged over 15 consecutive minutes by using USEPA Method 8 and CARB Method 1-100.

Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities

This rule limits fugitive dust emissions from construction, demolition, excavation, extraction, and other earthmoving activities such that opacity levels are kept to no more than 20 percent.

Rule 8041, Carryout and Trackout

This rule requires the limiting of carryout and trackout dust emissions from sites is applicable to construction of the Project.

Rule 8051, Open Areas

This rule applies to any open area of 3.0 acres or more in rural areas with at least 1,000 square feet of disturbed surface area. Dust emissions must be kept below 20 percent opacity.

Rule 8061, Paved and Unpaved Roads

This rule limits the emission of fugitive dust from roads to no more than 20 percent opacity through different control measures. Depending on traffic levels, the road must meet certain width requirements.

Rule 8071, Unpaved Vehicle/Equipment Traffic Areas

This rule limits the emission of fugitive dust to no more than 20 percent opacity through different control measures.

2.11 PERMITTING/PROJECT COORDINATION

The ATC permitting process that would otherwise apply is superseded in the case of CEC power plant licensing projects by the DOC process, which is its functional equivalent. The CEC's final decision on this Revised AFC will serve as the principal approval required to ensure that the Project's impacts to air quality would be within acceptable levels. However, a PTO would be awarded following SJVAPCD confirmation that the Project has been constructed to operate as described in the permit applications. The SJVACPD review and approval process is expected to occur on a schedule within the overall CEC AFC review process.

EPA will require this PSD permit be in place prior to the start of some elements of the construction. The EPA review and approval process is expected to occur on a schedule within the overall CEC AFC review process.

3.1 CLIMATOLOGY

The California Air Resources Board (CARB) has divided California into regional air basins according to topographic drainage features. The Project Site is located near the unincorporated community of Tupman, Kern County within the jurisdiction of the San Joaquin Valley Air Basin (SJVAB).

SJVAB, which is approximately 250 miles long and 35 miles wide, is the second largest air basin in the state. Air pollution, especially the dispersion of air pollutants, is directly related to a region's topographic features. The SJVAB is defined by the Sierra Nevada Mountains in the east (8,000 to 14,000 feet in elevation), the Coast Range in the west (averaging 3,000 feet in elevation), and the Tehachapi Mountains in the south (6,000 to 8,000 feet in elevation). The valley opens to the sea at the Carquinez Strait where the San Joaquin-Sacramento Delta empties into San Francisco Bay.

The SJVAB has an inland Mediterranean climate, averaging more than 260 sunny days per year. The valley floor is characterized by warm, dry summers and cooler winters. Long-term average temperature and precipitation data have been collected at Buttonwillow, the surface meteorological station nearest to the Project Site, and are presented in Table 3-1, Temperature and Precipitation Data for Buttonwillow Station, Buttonwillow, California. Average low and high temperatures during the summer vary from the high 60s to the mid 90s, respectively (in degrees Fahrenheit [°F]). Summer precipitation is extremely low due to the strong stationary high-pressure system located off the coast that prevents most weather systems from moving through the area. The Project Site receives an average of 6 inches of rain annually. During the winter, average low and high temperatures vary from the mid-30s to the mid-50s, respectively. About 80 percent of the precipitation in the area occurs from November through March, generally in association with storm systems that move through the region.

Table 3-1
Temperature and Precipitation
Data for Buttonwillow Station Buttonwillow, California

Month	Average Temperatures (°F) ^a			Precipitation (inches)
	Low	High	Daily	
January	35.1	56.3	45.7	1.08
February	38.9	63.2	51.1	1.08
March	43	69.1	56	1
April	47.2	76	61.6	0.56
May	54	84.7	69.4	0.22
June	60	92.4	76.2	0.05
July	65.2	98.4	81.8	0.02
August	63.2	96.7	80	0.02
September	57.6	91.5	74.6	0.13
October	48.6	81.5	65.1	0.28
November	39.1	67.4	53.3	0.54
December	34.4	57.1	45.8	0.67
Annual Average	48.9	77.9	63.4	5.65

Source: Western Regional Climate Center February 2009.

Note:

^a Average temperature and precipitation data represent 1940–2008.

Large climatic variations occur within relatively short distances, given the nature of the surrounding topography. These zones may be classified as valley, mountain, and desert. The overall climate, however, is warm and semi-arid.

The annual and seasonal wind roses are presented in Figures A-1 through A-5 of the Modeling Protocol, which is included in Appendix C. Winds for all seasons and all years blow predominantly from the sector between northwest and north, although the directional pattern is more variable during the fall and winter seasons.

3.2 EXISTING AIR QUALITY

Ambient air quality standards have been set by both the federal government and the state of California to protect public health and welfare with an adequate margin of safety. Pollutants for which National Ambient Air Quality Standards (NAAQS) or California Ambient Air Quality Standards (CAAQS) have been set are often referred to as “criteria” air pollutants. The term is derived from the comprehensive health and damage effects review that culminates in pollutant-specific air quality criteria documents, which precede NAAQS and CAAQS standard setting. These standards are reviewed on a legally prescribed frequency and revised as new health and welfare effects data warrant.

Each NAAQS or CAAQS is based on a specific averaging time over which the concentration is measured. Different averaging times are based upon protection of short-term, high-dosage effects or longer-term, low dosage effects. NAAQS may be exceeded no more than once per year. CAAQS are not to be exceeded.

A protocol was submitted to air regulatory agencies with jurisdiction over this Project that included the list of locations of available CARB ambient air quality monitoring stations (URS 2009). The ambient air quality in Kern County is represented by data monitored at four permanent air monitoring stations. Air quality monitoring data to represent existing air quality in the Project area were obtained from the USEPA Air Data (2008) and the CARB-California Air Quality Data website (2008). The maximum concentration recorded at these monitoring stations over the most recent three-year period will be used as a conservative representation of existing air quality condition at the Project Site.

The monitoring station in the county that is closest to the Project Site is the Shafter-Walker Street Station, within 13 miles (21 kilometer [km]) from the Project Site. However, this station only measures ozone (O₃), NO_x, and total VOCs. The Bakersfield Golden Highway station is the next closest and the most complete station that measures all pollutants except SO₂. This station is located approximately 21 miles (33 km) to the east of the Project Site. The only station in the SJVAB that monitors SO₂ is the CARB station at First Street in Fresno, located approximately 102 miles (164 km) to the north. Sulfur dioxide data have only been recorded in Fresno County for 3 of the last 10 years (2003, 2007, 2008), a practice that is justified by the low levels that have been recorded for this pollutant when measurements have been made. Air quality measurements taken at these stations are presented in Tables 3-2 through 3-7. These tables show the pollutant levels recorded for the previous 10-year periods, as available. For the air quality impact analysis, the maximum background concentration from the past 3 years from all monitoring stations was used.

The monitoring data indicate that the air is in compliance with all federal NAAQS and CAAQS for NO₂, CO, and SO₂ for all averaging periods. However, the monitoring data indicate that the NAAQS and/or the CAAQS are periodically exceeded for O₃, PM₁₀, and PM_{2.5}.

Ozone (O₃). SJVAB is designated as a non-attainment area for O₃ (state 1-hour, state 8-hour, and federal 8-hour). Table 3-2, Ambient Ozone Levels at Shafter-Walker Street, 1999-2008, shows that the 8-hour O₃ NAAQS of 0.08 parts per million (ppm) has been frequently exceeded in the past 10 years at the Shafter-Walker Street Station and that the 1-hour O₃ NAAQS of 0.12 ppm (a standard revoked by USEPA on 15 June 2005) has not been exceeded in the last 10 years at the Shafter-Walker Street Station except for 2008. The more stringent 1-hour CAAQS of 0.09 ppm has been frequently exceeded in the past 10 years at the Shafter-Walker Street Station. The federal standard requires maintaining 0.08 ppm as a 3-year average of the fourth-highest daily maximum value. Therefore, the number of days that the maximum concentration exceeds the standard concentration is not the number of violations of the standard for the year.

**Table 3-2
Ambient Ozone Levels at Shafter-Walker Street 1999-2008
(ppm)**

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008
Shafter-Walker Street Station, Kern County										
Maximum 1-Hour Average	0.116	0.123	0.110	0.112	0.121	0.100	0.104	0.106	0.111	0.131
Number of Days Exceeding California 1-Hour Standard (0.09 ppm)	31	18	26	22	18	3	14	20	3	14
Number of Days Exceeding Federal 1-Hour Standard (0.12 ppm)	0	0	0	0	0	0	0	0	0	1
Maximum 8-Hour Average	0.097	0.106	0.104	0.100	0.104	0.092	0.096	0.099	0.102	0.111
Number of Days Exceeding Federal 8-Hour Standard (0.08 ppm) ^a	25	25	30	25	15	3	15	55	18	33

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov; USEPA AIRS, 2009, www.epa.gov/air/data/index.html. Last Update: 9 March 2009

Notes:

- a Number of days with an 8-hour average exceeding federal standard concentration of 0.08 ppm. Regulatory standard is to maintain 0.08 ppm as a 3-year average of the fourth-highest daily maximum. Therefore, number of days exceeding standard concentration is not the number of violations of the standard for the year.
 - 1 Maximum average values occurring during the most recent 3 years are indicated in bold.
 - 2 National standards, other than those for O₃ and based on annual averages, are not to be exceeded more than once a year. The O₃ standard is attained when the expected number of days per calendar year with maximum hourly average concentrations above the standard is equal to or less than one.
 - 3 New federal 8-hour O₃ and fine particulate matter (PM_{2.5}) standards were promulgated by USEPA on 18 July 1997. The federal 1-hour O₃ standard was revoked by USEPA on 15 June 2005.
- ppm = parts per million

Particulate Matter (PM₁₀ and PM_{2.5}). SJVAB is designated as a non-attainment area for PM₁₀ and PM_{2.5}. Table 3-3, Ambient PM₁₀ Levels at Bakersfield Golden State Highway, 1999-, 2008, shows that the 24-hour average CAAQS of 50 micrograms per cubic meter (µg/m³) for PM₁₀ has been frequently exceeded in the Bakersfield area. The 24-hour average PM₁₀ NAAQS of 150

$\mu\text{g}/\text{m}^3$ was exceeded six times within the past 10 years (in 1999 to 2002, 2006, and 2008). The maximum 24-hour PM_{10} background concentration of $266 \mu\text{g}/\text{m}^3$ was measured at the Bakersfield Golden Highway Station in 2008. 2008.

The annual geometric mean presented in Table 3-3, Ambient PM_{10} Levels at Bakersfield Golden State Highway, 1999 - 2008, is also called the state annual average and is a geometric mean of all measurements. The annual arithmetic mean is also called the national annual average and is an arithmetic average of the four arithmetic quarterly averages (the federal PM_{10} standard was revoked on 22 September 2006). All of the annual geometric concentrations from 1999 to 2006 are above the California PM_{10} ambient air quality standard of $20 \mu\text{g}/\text{m}^3$. The annual geometric concentrations from 2007 and 2008 are currently unavailable.

The annual and 24-hour $\text{PM}_{2.5}$ data are presented in Table 3-4, Ambient $\text{PM}_{2.5}$ Levels at Bakersfield Golden State Highway, 1999-2008. $\text{PM}_{2.5}$ data have a relatively short collection history. The 3-year average, 98th percentile is above the NAAQS of $35 \mu\text{g}/\text{m}^3$. The 3-year average, arithmetic mean is above the CAAQS of $12 \mu\text{g}/\text{m}^3$.

Table 3-3
Ambient PM_{10} Levels at Bakersfield-Golden State Highway 1999 --2008
($\mu\text{g}/\text{m}^3$)

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008
Bakersfield-Golden State Highway Station, Kern County										
Maximum 24-Hour Average	186.0	153.0	216.0	194.0	134.0	84.0	109.0	162.0	135.0	266.8
Annual Geometric Mean	60.1	53.9	--	59.9	52.4	43	43.4	56.5	--	--
Annual Arithmetic Mean	59.5	53.1	54.4	59.2	52.4	42.8	43.2	55.4	54.8	50.4
Estimated Number of Days Exceeding California 24-Hour Standard ($50 \mu\text{g}/\text{m}^3$)	28	26	29	42	26	19	20	27	28	29

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov.

Last Update: 1 April 2009

Notes:

Maximum average values occurring during the most recent 3 years are indicated in bold.

-- = Data not available

$\mu\text{g}/\text{m}^3$ = micrograms per cubic meter

Table 3-4
Ambient PM_{2.5} Levels at Bakersfield-Golden State Highway 1999-2008
(µg/m³)

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008
Bakersfield-Golden State Highway Station, Kern County										
Maximum 24-Hour Average	133.9	108.1	120.4	85.0	67.8	66.6	83.6	76.4	154.0	88.7
Estimated Number of Days Exceeding Federal 24-Hour Standard (35 µg/m ³)	68.5	66.8	44.6	84.9	45.4	44	45.7	38.7	--	--
1-Year 98th Percentile	95.3	93.9	95.9	80.4	51.9	53.9	74.9	64.4	67.7	60.8
3-Year Average, 98th Percentile ^a	--	--	95	90	76	62	60	64	69	64
Annual Arithmetic Mean	26.2	22.6	21.8	24.1	19.6	18.2	19.1	18.6	25.5	--
3-Year Average, Arithmetic Mean ^b	--	--	24	23	22	21	19	19	21	--
State Annual Average	133.9	108.1	120.4	85.0	67.8	66.6	83.6	76.4	154.0	88.7

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov.

Last Update: 1 April 2009

Notes:

a The 3-Year Average, 98th Percentile is above the National Ambient Air Quality Standard of 35 µg/m³.

b The 3-Year Average, Arithmetic Mean is above the California Ambient Air Quality Standard of 12 µg/m³

Maximum average values occurring during the most recent 3 years are indicated in bold.

-- = Data not available

µg/m³ = micrograms per cubic meter

Carbon Monoxide (CO). SJVAB is designated as an attainment area for CO. The data in Table 3-5, Ambient CO Levels at Bakersfield-Golden State Highway, 1999-1999-2008, show that the measured concentrations of CO are all below the applicable federal and California standards.

Table 3-5
Ambient CO Levels at Bakersfield-Golden State Highway 1990-2008
(ppm)

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008
Bakersfield-Golden State Highway Station, Kern County										
Maximum 1-Hour Average ^a	5.4	10.1	8.1	4.5	4.5	4.1	3.2	3.3	2.8	3.5
Maximum 8-Hour Average ^b	4.06	5.38	3.49	2.5	3.7	2.6	2.1	2.19	1.97	2.17

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov. ; USEPA AIRS, 2009, www.epa.gov/air/data/index.html

Last Update: 1 April 2009

Notes:

Maximum average values occurring during the most recent 3 years are indicated in bold.

a All 1-hour concentrations are below the federal and California CO ambient air quality standards of 35 ppm and 20 ppm, respectively.

b All 8-hour concentrations are below the federal and California CO ambient air quality standard of 9 ppm.

ppm = parts per million

Nitrogen Oxides (NO_x). SJVAB is designated as an attainment area for NO₂. The data in Table 3-6, Ambient NO₂ Levels at Shafter-Walker Street and Bakersfield-Golden State Highway Station 1999 -2008, show that the measured concentrations of NO₂, are all below the applicable federal and California standards.

Table 3-6
Ambient NO₂ Levels at Shafter-Walker Street 1999 -2008
(ppm)

	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008
Shafter-Walker Street Station, Kern County										
Maximum 1-Hour Average ^a	0.073	0.064	0.072	0.062	0.071	0.074	0.063	0.100	0.101	0.045
Bakersfield-Golden State Highway Station, Kern County										
Annual Average ^b	0.027	0.023	0.015	0.024	0.023	0.021	0.021	0.021	0.020	0.017

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov. ; USEPA AIRS, 2009, www.epa.gov/air/data/index.html
Last Update: 1 April 2009

Notes:

Maximum average values occurring during the most recent 3 years are indicated in bold.

Arithmetic average 1-hour for the 2006 – 2008 period equals 0.082 ppm.

a All 1-hour concentrations are below the California NO₂ ambient air quality standard of 0.25 ppm.

b All annual average concentrations are below the federal NO₂ ambient air quality standard of 0.053 ppm.

ppm = parts per million.

Sulfur Dioxide (SO₂). SJVAB is designated as an attainment area for SO₂. The data in Table 3-7, Ambient SO₂ Levels Nearest to the Project Location, 1999-2008, show that the measured concentrations of SO₂ are all below the applicable federal and California standards.

Table 3-7
Ambient SO₂ Levels Nearest to the Project Location 1999-2008
(ppm)

	1999	2000	2001	2003	2007	2008
Monitoring Station	Bakersfield-5558 California Avenue	Bakersfield-5558 California Avenue	Bakersfield-5558 California Avenue	Fresno-Fremont School	Fresno-First St	Fresno-First St
Maximum 1-Hour Average ^a	--	--	0.030	0.009	0.130 ^d	0.060
Maximum 24-Hour Average ^b	0.006	0.003	0.005	0.004	0.052	0.027
Annual Average ^c	0.003	0.003	0.002	0.002	0.007	0.010

Source: California Air Resources Board (CARB), 2009, www.arb.ca.gov. ; USEPA AIRS, 2009, www.epa.gov/air/data/index.html.
Last Update: 1 April 2009

Notes:

a All 1-hour average concentrations are below the California SO₂ ambient air quality standard of 0.25 ppm (655 µg/m³).

b All 24-hour average concentrations are below the California SO₂ ambient air quality standard of 0.04 ppm (105 µg/m³) and the National Ambient Air Quality Standard (NAAQS) of 0.14 ppm (365 µg/m³).

c All annual average concentrations are below the SO₂ NAAQS of 0.03 ppm (80 µg/m³).

d It was observed that higher monitoring concentrations were observed at the Fresno -1st Street station on July 4 and July 5, 2007 (the day of and the day after Independence Day). Because these values are much higher than concentrations observed during the rest of the year, they were assumed to have been caused by fireworks. These values will fall into the category EPA Rule 40 CFR 50.14. Therefore, concentrations on July 4 and Jul 5, 2007 were not considered, and the next highest 1-hour and 3-hour concentrations were used instead. Confirmed in an email from Leland Villalvazo on February 4, 2009.

-- = Data not available

ppm = parts per million

BACT was discussed in Section 2.0 Laws, Ordinances, Regulations, and Standards and presented in Table 2-1. The full BACT analysis is presented in Appendix A.

The Project is a nominal 250 MW IGCC power generating facility consisting of a gasification block/syngas production with carbon capture capability and a combined-cycle power block. The gasification block will feature GE Quench gasifiers and sour shift, and a Rectisol acid gas removal (AGR) unit to remove sulfur components and recover carbon dioxide. The power block will feature one GE 7FB combustion turbine-generator (CTG) that can be fueled with hydrogen-rich syngas from the gasification plant, natural gas, or a mixture of the two; a heat recovery steam generator (HRSG) with duct firing of hydrogen-rich syngas or natural gas; a condensing steam turbine-generator; and a GE LMS100® simple cycle CTG fueled with natural gas as an auxiliary combustion turbine. The operational emissions from the Project are mainly generated from the combustion of the hydrogen-rich syngas. Other emission sources include cooling towers, solids handling, and an auxiliary boiler and auxiliary CTG. For emission calculation purposes, each emission source is categorized as power block, gasification block, or ancillary equipment. The classification of the criteria pollutant emission sources from the Project is as follows.

Power Block	Gasification Block	Ancillary Equipment
<ul style="list-style-type: none"> • Combustion Turbine (GE 7FB) • Auxiliary CTG (GE LMS100®) • Power Block Cooling Tower 	<ul style="list-style-type: none"> • Gasifier Refractory Heaters • Auxiliary Boiler • Gasification Flare • SRU Flare • Rectisol Flare • Tail Gas Thermal Oxidizer • ASU and Gasification Cooling Towers • Carbon Dioxide Vent • Dust collection (Feedstock) 	<ul style="list-style-type: none"> • Diesel Generator • Emergency Diesel Firewater Pump

5.1 POWER BLOCK

Power Block CTG/HRSG Operating Emissions

The most significant emission source of the Project will be the CTG/HRSG train. The power block design will be optimized for performance on 100 percent hydrogen-rich syngas, 100 percent natural gas, or co-firing hydrogen-rich syngas and natural gas. Most of the hydrogen-rich syngas from the gasification plant will be used to fully load the CTG, with any excess (up to about 10 to 14%) duct fired in the HRSG. The CTG will operate on hydrogen-rich syngas, natural gas, or a mixture of the two (45 to 90% hydrogen-rich syngas) over the compliance load range of 60 to 100 percent. The CTG will be co-fired with natural gas as required to maintain baseload operation whenever the quantity of hydrogen-rich syngas is insufficient.

Maximum short-term operational emissions from the CTG/HRSG were determined from a comparative evaluation of potential emissions corresponding to normal operating conditions

(including HRSG duct-firing), and CTG startup/shutdown conditions. The long-term operational emissions from the CTG/HRSG were estimated by summing the emissions contributions from normal operating conditions (including hours with and without duct-firing) and CTG/HRSG startup/shutdown conditions. Estimated annual emissions of air pollutants for the CTG/HRSG have been calculated based on the expected operating schedule for the CTG/HRSG presented below in Table 5-1, Maximum CTG/HRSG Operating Schedule.

Operational emissions from the CTG/HRSG were estimated for all the applicable scenarios using base emission rates and startup/shutdown emissions. The base criteria pollutant emission rates provided by the turbine vendor and the engineer for three load conditions (60%, 80%, and 100%) and three ambient temperatures (20°F, 65°F, and 97°F) when firing natural gas, syngas, or co-firing are presented in Table 5-2, 1-Hour Operating Emission Rates for CTG/HRSG Operating Load Scenarios.

Table 5-1
Maximum CTG/HRSG Operating Schedule

Operating Conditions	Annual Numbers
Total Hours of Operation	8,322
Total Number of Cold Starts	10
Cold Start Duration (hr)	3
Total Number of Hot Starts	10
Hot Start Duration (hr)	1
Total Number of Shutdowns	20
Shutdown Duration (hr)	0.5
Duct Burner Operation (hr)	8,272

Source: HECA Project

Notes:

CTG = combustion turbine generator

HRSG = heat recovery steam generator

Table 5-2
1-Hour Operating Emission Rates for CTG/HRSG Operating Load Scenarios

Ambient Temperature	UNITS	Winter Minimum, 20°F				Yearly Average, 65°F				Summer Maximum, 97°F			
CTG Load Level	% Load	100%	100%	80%	60%	100%	100%	80%	60%	100%	100%	80%	60%
Evap Cooling Status	off/on	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Duct Burner Status	off/on	On	Off	Off	Off	On	Off	Off	Off	On	Off	Off	Off
Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation Natural Gas													
NO _x (@ 4.0 ppm)	lb/hr	36.3	29.0	24.8	20.8	35.1	27.0	23.1	19.4	33.3	26.1	22.4	18.7
CO (@ 5.0 ppm)	lb/hr	27.6	22.1	18.8	15.8	26.7	20.5	17.6	14.8	25.3	19.8	17.0	14.2
VOC (@ 2.0 ppm)	lb/hr	6.3	5.0	4.3	3.6	6.1	4.7	4.0	3.4	5.8	4.5	3.9	3.2
SO ₂ (@ 12.65 ppmv in fuel)	lb/hr	5.1	4.1	3.5	3.0	4.8	3.8	3.3	2.8	4.7	3.7	3.2	2.7
PM ₁₀ = PM _{2.5}	lb/hr	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0
NH ₃ (@ 5.0 ppm slip)	lb/hr	16.7	13.4	11.4	9.6	16.2	12.5	10.7	9.0	15.4	12.1	10.3	8.6
Average Emission Rates from CTG(lbs/hr/turbine) - Normal Operation Syngas													
NO _x (@ 4.0 ppm)	lb/hr		37.2	31.5	26.1	39.7	36.9	31.0	25.6	39.7	38.0	30.9	25.6
CO (@ 3.0 ppm)	lb/hr		17.0	14.4	11.9	18.1	16.8	14.1	11.7	18.1	17.4	14.1	11.7
VOC (@ 1.0 ppm)	lb/hr		3.2	2.7	2.3	3.5	3.2	2.7	2.2	3.5	3.3	2.7	2.2
SO ₂ (@ 5.0 ppmv in fuel)	lb/hr		6.1	5.2	4.4	6.8	6.1	5.1	4.3	6.8	6.0	5.1	4.3
PM ₁₀ = PM _{2.5}	lb/hr		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
NH ₃ (@ 5.0 ppm slip)	lb/hr		17.2	14.6	12.0	18.4	17.0	14.3	11.8	18.4	17.6	14.3	11.8
Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation Co-firing													
NO _x (@ 4.0 ppm)	lb/hr	41.3	34.0			38.7	31.7						
CO (@ 5.0 ppm)	lb/hr	31.4	25.9			29.4	24.1						
VOC (@ 2.0 ppm)	lb/hr	7.2	5.9			6.7	5.5						
SO ₂ (@ 6.7 ppmv in fuel)	lb/hr	7.4	5.2			7.0	4.8						
PM ₁₀ = PM _{2.5}	lb/hr	24.0	24.0			24.0	24.0						
NH ₃ (@ 5.0 ppm slip)	lb/hr	19.1	15.7			17.9	14.6						

Source: HECA Project

Notes:

- Co-firing emissions are controlled at the same amount as natural gas.
- Emission rates not provided were not necessary to determine the maximum hourly, 3-hour, 8-hour, 24-hour emission rates or the annual average emission rates.

CO = carbon monoxide
 CTG = combustion turbine generator
 HRSG = heat recovery steam generator
 NH₃ = ammonia

ppm = parts per million
 PM₁₀ = particulate matter 10 microns in diameter and is assumed to equal PM_{2.5} = particulate matter 10 microns in diameter
 SO₂ = sulfur dioxide

Table 5-2
1-Hour Operating Emission Rates for CTG/HRSG Operating Load Scenarios

Ambient Temperature	UNITS	Winter Minimum, 20°F	Yearly Average, 65°F	Summer Maximum, 97°F
NO _x = nitrogen oxides			VOC = volatile organic compound	

CTG/HRSG Startup and Shutdown Emissions

Because startup and shutdown events typically had higher emission rates than operating conditions, they were incorporated into the short- and long-term emissions estimates for the CTG/HRSG for modeling purposes. When firing natural gas, syngas, or co-firing, the CTG/HRSG will always be started burning natural gas fuel. Therefore, the expected emissions and duration of startup events summarized in Table 5-3, CTG/HRSG Criteria Pollutant Emission Rates During Startup and Shutdown, reflect the emissions from natural gas startup and shutdown. Based on vendor information, a cold startup of the CTG and associated steam turbine is expected to take 180 minutes.

Similarly, the hot start for the CTG/HRSG will occur over intervals of 60 minutes, and shutdown will be completed in 30 minutes. During a shutdown event, the efficiency of the emission controls will continue to function at normal operating levels down to a load of 60 percent; thus, shutdown periods and emissions are measured from the time this load is reached.

Because hours that include startup and shutdown events will have higher NO_x, CO, and VOC emissions than the normal operating condition with fully functioning selective catalytic reduction (SCR) and CO oxidation catalyst, they were incorporated (as applicable) into the worst-case short- and long-term emissions estimates in the air quality dispersion modeling simulations for these pollutants.

CTG/HRSG Emissions Scenarios for Modeling

Reasonable worst-case short-term emissions from the turbines were calculated for use in the air quality modeling. For worst-case 1-hour emissions, the worst-case startup NO_x and CO emission rate was used. Based on the startup information, NO_x and CO emissions during a hot startup and a cold startup, respectively, are the worst-case conditions. Sulfur oxide (SO_x) emissions are maximized at peak fuel usage for all firing scenarios (natural gas, syngas, and co-firing).

The 3-hour SO_x emission rate for all firing scenarios (natural gas, syngas, and co-firing) was based on the scenario at peak fuel usage for corresponding firing scenarios.

The 8-hour CO emission rate for all firing scenarios (natural gas, syngas, and co-firing) was calculated assuming two full cold start, three shutdown and the balance (0.5 hour) operating at the worst-case operating condition (at peak fuel usage for corresponding firing scenarios).

The 24-hour NO_x (for visibility) rate was calculated assuming 20 hours of natural gas firing at the winter minimum (20°F) without duct firing and 4 hours of co-firing at the winter minimum (20°F) without duct firing. PM₁₀ and SO₂ worst-case 24-hour emission rates were calculated assuming the worst-case operating condition (at peak fuel usage for corresponding firing scenario)

Table 5-4, Criteria Pollutant Sources and Emission Totals for the Worst-Case CTG Emissions Scenario for All Averaging Times, summarizes the worst-case emissions scenarios adopted to assess maximum impacts to air quality and air quality-related values in the modeling analyses presented in Section 6, Modeling Impact Analysis. Note that modeling of turbine commissioning impacts was conducted separately due to the temporary, one-time nature of this activity.

Table 5-3
CTG/HRSG Criteria Pollutant Emission Rates During Startup and Shutdown

Cold Startup			Hot Startup			Shutdown		
180 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/180 min.)	60 (min. in hot startup)	Max 1-hr. (lb/hr)	Total (lb/60 min.)	30 (min. in shutdown)	Max 1-hr. (lb/hr)	Total (lb/30 min.)
NO _x	90.7	272.0	NO _x	167.0	167.0	NO _x	62.0	62.0
CO	1,679.7	5,039.0	CO	394.0	394.0	CO	126.0	126.0
VOC	266.7	800.0	VOC	98.0	98.0	VOC	21.0	21.0
SO ₂	5.1	15.3	SO ₂	5.1	5.1	SO ₂	2.6	2.6
PM ₁₀ = PM _{2.5}	21.3	64.0	PM ₁₀ = PM _{2.5}	23.0	23.0	PM ₁₀ = PM _{2.5}	5.0	5.0

Source: HECA Project

Notes:

CTGs will always be started burning natural gas. Startup and shutdown emission rates above reflect natural gas.

Startup and shutdown SO₂ emissions will always be lower than normal operation SO₂ emissions. Startup and shutdown emissions are assumed equal to normal operations (burning natural gas) at the max emission rate.

Startup/shutdown duration defined as operation of CTG below 60 % load when gaseous emission rates (lb/hr basis) exceed the controlled rates defined as normal operation

CO = carbon monoxide

NO_x = nitrogen oxides

PM₁₀ = particulate matter 10 microns in diameter and is assumed to equal PM_{2.5} = particulate matter 10 microns in diameter

SO₂ = sulfur dioxide

VOC = volatile organic compounds

Table 5-4
Criteria Pollutant Sources and Emission Totals for
the Worst-Case CTG Emissions Scenario for All Averaging Times

Averaging Time	Worst-case Emission Scenarios by Operating Equipment	Pollutant	Emissions in pounds – Entire Period		
			CTG/HRSG (Natural Gas)	CTG/HRSG (Syngas)	CTG/HRSG (Co-firing)
1 hour	NO_x : Cold startup hour	NO _x	167.0	167.0	167.0
	CO : Cold startup hour	CO	1,679.7	1,679.7	1,679.7
	SO_x : Full-load turbine operation with duct firing at peak fuel usage	SO _x	5.1	6.8	7.4
3 hour	SO_x : Continuous full-load turbine operation with duct firing (both turbines) at peak fuel usage	SO _x	15.3	20.5	22.1
8 hour	CO : Two cold start, three shutdown, and remainder of period at full load operation with full duct firing (both turbines) at peak fuel usage	CO	10,469.8	10,465.1	10,471.7
24 hour	NO_x : 20 hours of natural gas firing at the winter minimum (20°F) without duct firing and 4 hours of co-firing at the winter minimum (20°F) without duct firing	NO _x	20 hrs = 580.5 Total = 716.5	n/a	4 hrs = 136.0 Total = 716.5
	SO_x, PM₁₀ : Continuous full-load turbine operation with duct firing (both turbines) at peak fuel usage; except PM ₁₀ for natural gas: four cold start, four shutdown, and remainder of period at full load operation with full duct firing (both turbines) at peak fuel usage	PM ₁₀ = PM _{2.5}	432	576	576
		SO _x	122.4	163.8	177.2
Annual	NO_x, CO, VOC, PM₁₀, and SO_x : 10 hot starts, 10 cold starts and 20 shutdowns, and remainder of turbine operates at full load with duct firing	NO _x	296,044.0	334,353.0	325,712.3
		CO	277,817.2	206,919.2	300,390.9
		VOC	59,906.8	37,984.6	65,066.5
		PM ₁₀ = PM _{2.5}	149,866.0	199,498.0	199,498.0
		SO _x	40,045.4	56,713.0	58,357.9

Source: HECA Project

Notes:

°F = degrees Fahrenheit

CO = carbon monoxide

CTG = combustion turbine generator

HRSG = heat recovery steam generator

NO_x = nitrogen oxides

PM₁₀ = particulate matter 10 microns in diameter and is assumed to equal PM_{2.5} = particulate matter 10 microns in diameter

SO_x = sulfur oxides

VOC = volatile organic compounds

Estimated annual emission totals for all pollutants incorporate the maximum anticipated emissions related to startups and shutdowns, as well as the maximum steady-state operating emissions with and without duct firing. For purposes of developing the annual emission estimates, the contributions associated with all normal operating hours were calculated based on assumed 100 percent turbine load and ambient temperature of 65°F for the specified number of hours per year. Emissions for normal operating hours with duct firing assumed the maximum duct burner fuel input rate at 65°F. The analysis is conservative because no credit was taken for downtime that would normally follow each shutdown. Estimated maximum annual emissions for the GE 7FB turbine are presented in Table 5-5, Average Annual Emissions per Turbine Operating Scenario. Emissions calculations for all scenarios are contained in Appendix B.

Table 5-5
Average Annual Emissions per Turbine Operating Scenario

Pollutant	HRSG Stack - Nat Gas (tons/yr/CT)	HRSG Stack - Syn Gas (tons/yr/CT)	HRSG Stack - Co Firing (tons/yr/CT)	Maximum (tons/yr/CT)
NO _x	148.0	167.2	162.9	167.2
CO	138.9	103.5	150.2	150.2
VOC	30.0	19.0	32.5	32.5
SO ₂	20.0	28.4	29.2	29.2
PM ₁₀ = PM _{2.5}	74.9	99.7	99.7	99.7
NH ₃	67.1	75.9	73.9	75.9

Source: HECA Project

Notes:

- CT = combustion turbine
- CO = carbon monoxide
- HRSG = heat recovery steam generator
- NH₃ = ammonia
- NO_x = nitrogen oxides
- PM₁₀ = particulate matter 10 microns in diameter
- PM_{2.5} = particulate matter 2.5 microns in diameter (PM_{2.5} is assumed to equal PM₁₀)
- SO₂ = sulfur dioxide
- VOC = volatile organic compounds

Natural Gas-fired Auxiliary CTG

In addition to the main GE 7FB combined cycle turbine, the power block also includes a single natural gas fired auxiliary gas turbine to provide backup power to the gasification plant during forced outage periods and to provide beneficial spot market power production to the grid. The auxiliary CTG will be equipped with water injection and SCR for the control of NO_x emissions and an oxidation catalyst for control of emissions of CO and VOC. The auxiliary CTG is a natural gas fired GE LMS100® in a simple cycle configuration.

The auxiliary simple cycle CTG is designed to operate independently from the rest of the facility and can be used to supply additional export power when needed. The auxiliary CTG requires high pressure natural gas and the natural gas compressor will be operated whenever the auxiliary CTG is operated. Estimated annual emissions of air pollutants for the auxiliary CTG have been

calculated based on the expected operating schedule presented below in Table 5-6, Maximum Auxiliary CTG Operating Schedule.

Operational emissions from the auxiliary CTG were estimated for all applicable scenarios using base emission rates and startup/shutdown emissions. The base criteria pollutant emission rates provided by the turbine vendor and the engineer for three load conditions (50%, 75%, and 100%) and three ambient temperatures (20°F, 65°F, and 97°F) when firing natural gas are presented in Table 5-2, 1-Hour Operating Emission Rates for CTG/HRSG Operating Load Scenarios. Table 5-7, Auxiliary CTG Criteria Pollutant Emission Rates During Startup and Shutdown, summarizes the expected emissions and duration of startup and shutdown from the auxiliary CTG.

Table 5-6
Maximum Auxiliary CTG Operating Schedule

Total Hours of Operation	4,110
Total Number of Cold Starts	325
Cold Start Duration (hr)	0.2
Total Number of Shutdowns	325
Shutdown Duration (hr)	0.2
Evaporative Cooling Operation (hr)	4,000

Source: HECA Project

Assumptions: Average annual operational emissions are calculated using yearly average: 65°F, at 100% load, with evaporative cooling.

Note:

CTG = combustion turbine generator

Table 5-7
Auxiliary CTG Criteria Pollutant Emission Rates During Startup and Shutdown

Cold Startup			Shutdown		
10 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/10 min.)	10.3 (min. in shutdown)	Max 1-hr. (lb/hr)	Total (lb/10.3 min.)
NO _x	9.0	3.0	NO _x	12.0	4.0
CO	30.6	10.2	CO	39.6	13.2
VOC	0.5	0.2	VOC	0.6	0.2
SO ₂ (@ 12.65 ppmv)	1.9	0.3	SO ₂	1.9	0.3
PM ₁₀ = PM _{2.5}	6.0	1.7	PM ₁₀ = PM _{2.5}	6.0	1.7

Source: HECA Project

Notes:

NO_x, CO, and VOC startup and shutdown emissions (max 1-hr) assume 3 startup and 3 shut down.

Startup and shutdown SO₂ and PM₁₀ emissions will always be lower than normal operational emissions. Startup and shutdown emissions are assumed equal to normal operations max emission rate, with evaporative cooling.

CTG = combustion turbine generator

CO = carbon monoxide

NO_x = nitrogen oxides

PM₁₀: = Particulate matter 10 microns in diameter

PM_{2.5} = particulate matter 2.5 microns in diameter (PM_{2.5} is assumed to equal PM₁₀)

SO₂ = sulfur dioxide

VOC = volatile organic compounds

Auxiliary CTG Emissions Scenarios for Modeling

Reasonable worst-case short-term emissions from the auxiliary CTG were calculated for use in the air quality modeling. For worst-case 1-hour emissions, the worst-case startup scenario for NO_x and CO was used. Based on the startup information, NO_x and CO emissions were conservatively estimated as the contribution from three startups and three shutdowns over a 1-hour period. SO_x emissions are maximized at normal operating scenario.

The 3-hour SO_x emission rate is maximized at normal operating scenario.

The 8-hour CO emission rate was calculated assuming four cold starts and four shutdowns.

The 24-hour NO_x emission rate was calculated assuming four cold starts, four shutdowns and the balance (10 hours) normal operation at maximum emission rate. PM₁₀ and SO_x worst-case 24-hour emission rates were calculated assuming normal operation at the maximum emission rate

Table 5-8, Criteria Pollutant Sources and Emission Totals for the Worst-Case Auxiliary CTG Emissions Scenario for All Averaging Time, summarizes the worst-case emissions scenarios adopted to assess maximum impacts to air quality and air quality-related values in the modeling analyses presented in Section 6, Modeling Impact Analysis.

Table 5-8
Criteria Pollutant Sources and Emission Totals for the Worst-Case Auxiliary CTG
Emissions Scenario for All Averaging Times

Averaging Time	Worst-case Emission Scenarios by Operating Equipment	Pollutant	Emissions in pounds – Entire Period
1 hour	NO _x : Contribution from three startups and three shutdowns over a 1-hour period.	NO _x	20.7
	CO: Contribution from three startups and three shutdowns over a 1-hour period.	CO	69.0
	SO _x : Normal Operation at maximum emission rate.	SO _x	1.9
3 hour	SO _x : Normal Operation at maximum emission rate.	SO _x	5.6
8 hour	CO: Four cold startups and four shutdowns.	CO	172.6
24 hour	NO _x : four cold starts, four shutdowns, and remainder of normal operation at maximum emission rate.	NO _x	212.4
	SO _x , PM ₁₀ : Normal Operation at maximum emission rate.	PM ₁₀ =	144.0
		PM _{2.5}	44.6
Annual	NO _x , CO, VOC, PM ₁₀ , and SO _x : 325 cold starts and 325 shutdowns, and remainder of turbine operates with evaporative cooling.	NO _x	34,840.6
		CO	55,179.1
		VOC	9,182.0
		PM ₁₀ =	24,660.0
		PM _{2.5}	7,644.4

Source: HECA Project

Notes:

CO = carbon monoxide

CTG = combustion turbine generator

NO_x = nitrogen oxides

SO_x = sulfur oxides

PM₁₀ = particulate matter 10 microns in diameter

PM_{2.5} = particulate matter 2.5 microns in diameter (PM_{2.5} is assumed to equal PM₁₀)

VOC = volatile organic compounds

Power Block Cooling Tower

Power cycle heat rejection will consist of a steam turbine generator surface condenser, cooling tower, and cooling water system. The heat rejection system receives exhaust steam from the low pressure steam turbine and condenses it to water for reuse. Approximately 175,000 gallons per minute (gpm) of water will be circulated in the power block cooling tower with an hourly circulation rate of 88 million pounds per hour.

The cooling water will circulate through a mechanical draft-cooling tower, which uses electric motor-driven fans to move the air into contact with the flow of the cooling water. The heat removed in the condenser will be discharged to the atmosphere by heating the air and through evaporation of some of the cooling water. Maximum drift, that is, the fine mist of water droplets entrained in the warm air leaving the cooling tower, will be limited to 0.0005 percent of the circulating water flow. Circulating water could range from 3,000 to 9,000 ppm total dissolved solids depending on makeup water quality and tower operation. Therefore, PM₁₀ emissions would vary proportionately. For emission calculation purposes, it is assumed that 9,000 ppm total dissolved solids is dissolved in the circulating cooling water. A summary of the power block cooling tower emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

5.2 GASIFICATION BLOCK

Gasifier: The gasification plant consists of three gasifiers. The plant will be capable of continuous operation of one or two gasifiers, each at up to maximum flow (each at 100 percent of rated operation). Each of the three gasification trains will have one natural gas fired burner used to warm the gasification refractory to facilitate startup. These burners will not operate when the gasification train is operating.

The only criteria pollutant emissions from the gasifier units are the by-products of the natural gas fired burners (3 total, 1 per gasifier) during start-up. The gasifier warming burners operate at 18 million British thermal units (MMBtu)/hour firing natural gas for a total of 1,800 hours of normal operation per year. A summary of the gasifier warming emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

During gasifier startup, unprocessed/unreacted vent gas is vented to the flaring system.

Auxiliary Boiler: The auxiliary boiler will provide steam to facilitate CTG startup and for other industrial purposes. The auxiliary boiler will be designed to burn pipeline-quality natural gas at the design maximum fuel flow rate of 142 MMBtu/hour (higher heating value). The auxiliary boiler emissions are based on 2,190 hours of operation per year. Emissions are based on vendor supplied emission factors. NO_x emissions are based on 9 parts per million volumetric dry (ppmvd) at 3 percent O₂ with installation of ultra-low NO_x combustors and flue gas recirculation. Carbon monoxide emissions are based on 50 ppmvd 3 percent O₂. A summary of auxiliary boiler emissions is presented in Table 5-10, Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Natural Gas at 59°F. Emissions and calculations are included in Appendix B.

Gasification Flare, SRU Flare, and Rectisol Flare System: The gasification block will operate a Gasification flare to safely dispose of gasifier startup gases (see previous discussion) and

syngas, generated during short-term combustion turbine outages and other unplanned power plant upsets or equipment failures. In addition, there will be an SRU flare installed to safely dispose of gas emissions from the AGR source during startup (after passing via a scrubber) or to oxidize releases during emergency or upset events. The Rectisol flare will be used to safely dispose of low temperature gas streams during startup, shutdown and unplanned upsets or emergency events.

During normal operation, the three flares will have pilot lights that will operate continuously. Emissions from the flares are generated from the continual operation of the natural gas fired pilot lights and from periodic vent gas that are oxidized during unsteady state operation of the gasification and power blocks. A summary of each flare emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

Tail Gas Thermal Oxidizer: Associated with the operation of the sulfur recovery process, the Project will incorporate a thermal oxidizer on the tail gas treating unit (TGTU). The thermal oxidizer will serve as a control device to oxidize any remaining H_2S (after scrubbing) and other vent gas that are generated during startup, shutdown, and times of non-delivery of carbon dioxide product. In addition, miscellaneous oxidizing streams from the gasification area (e.g., atmospheric tank vents and miscellaneous equipment vents) are directed to the thermal oxidizer during normal operation to prevent nuisance odors. The thermal oxidizer operates at high temperature and provides sufficient residence time in order to ensure essentially complete destruction of reduced sulfur compounds like H_2S to SO_2 . The thermal oxidizer fires natural gas continually to reach and maintain the required operating temperature for proper thermal destruction. Pollutant emissions are generated from the firing of natural gas and the periodic oxidation of vent gas during system upset. A summary of the tail gas oxidizer emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

ASU and Gasification Cooling Towers: The ASU and gasification block cooling water system designs are similar to the power block cooling design, but they have substantially lower duties. The ASU cooling tower is located in the ASU unit near the cooling loads. The ASU cooling tower has separate pumps and piping systems and is operated independently of the other cooling water systems. The ASU cooling tower circulation rate is approximately 40,200 gpm and the tower is supplied with high efficiency drift eliminators designed to reduce drift to less than 0.0005 percent of circulation.

The gasification unit cooling tower is collocated with the power block cooling tower. Each tower has a separate cooling water basin, pumps, and piping system, and operates independently. The gasification cooling tower circulation rate is about 42,300 gpm and the tower is supplied with high efficiency drift eliminators designed to reduce drift to less than 0.0005 percent of circulation. A summary of the ASU and gasification block cooling tower emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

Carbon Dioxide Vent: A carbon dioxide vent stack will allow for start-up and intermittent emergency venting of produced carbon dioxide when the carbon dioxide injection system is unavailable. The carbon dioxide vent will enable the Project to operate, rather than be disabled, by brief periods when the carbon dioxide injection system is unavailable, and in doing so,

prevents gasifier shutdown and subsequent gasifier restart with associated emissions. The Project design indicates that the carbon dioxide vent stack will be located beyond the downwash zones caused by the structures associated with the Project. However, the physical height of the carbon dioxide vent stack of 79.3 meters (260 feet) is greater than the *de-minimus* Good Engineering Practice height of 65 meters.

A 260-foot stack height was chosen to satisfy HEI's inherently safe design practices to minimize ground-level carbon dioxide concentrations in the event of a carbon dioxide vent under very low wind speeds.

The carbon dioxide vent exhaust stream will be nearly all carbon dioxide, with small amounts of CO and H₂S. A summary of the carbon dioxide vent stack emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B.

Dust collection (Feedstock): In addition to the sources above, there will be emissions of PM₁₀ from feedstock and gasifier solids materials handling operations. These operations include bulk material unloading, loading, belt conveying, belt transfer points, silo loading, and reclaim. A summary of the dust collection system emissions is presented in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. Emissions and calculations are included in Appendix B

Ancillary Equipment

Emergency Generator Engine and Firewater Pump Engine: The Project will include two 2,800 horsepower standby diesel generators and one 556 horsepower, standby firewater pump, located adjacent to the firewater tank. The diesel engines will exclusively combust ultra low sulfur (15 ppm) No. 2 diesel fuel.

The 2,800 horsepower diesel engines are installed in an outdoor enclosure and will be connected to the 480 volt (V) switchgear. The switchgear supplies essential service power to critical lube oil and cooling pumps, gasification and auxiliary steam systems, gasification quench system, station battery chargers, uninterruptible power supply, heat tracing, control room and emergency exit lighting, and other critical plant loads. Emissions were estimated based on hourly manufacturers' emission rates as well as USEPA Tier 4 emissions standards for 2011 model equipment. Sulfur dioxide emissions were estimated using ultra-low sulfur diesel fuel containing 15 ppm sulfur. Emissions estimates for the three diesel engines are shown in Table 5-9, Total Combined Annual Criteria Pollutant Emissions. The annual emissions from these engines are based on a maximum non-emergency use rate of 50 hours of operation per year each for the emergency generator engines and 100 hours of operation per year for the fire pump engine.

5.3 TOTAL COMBINED FACILITY-WIDE EMISSIONS

The total combined annual emissions from all emission sources of the Project are shown in Table 5-9, Total Combined Annual Criteria Pollutant Emissions.

Table 5-9
Total Combined Annual Criteria Pollutant Emissions

	Total Annual	HRS Stack Maximum¹	Auxiliary CTG	Cooling Towers²	Auxiliary Boiler	Emergency Generators³	Fire Water Pump	Gasification Flare	SR/US U Flare	Rectisol Flare	Tail Gas Thermal Oxidizer	CO₂ Vent	Gasifier	Feedstock⁴
Pollutant	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)	(ton/yr)
NO _x	203.8	167.2	17.4	--	1.7	0.2	0.1	4.3	0.2	0.2	10.9	--	1.8	--
CO	350.3	150.2	27.6	--	5.8	0.1	0.2	48.8	0.1	0.1	9.1	106.9	1.5	--
VOC	40.7	32.5	4.6	--	0.6	0.03	0.01	0.003	0.002	0.002	0.3	2.4	0.1	--
SO ₂	42.2	29.2	3.8	--	0.3	0.001	0.0003	0.004	0.055	0.003	8.8	--	0.03	--
PM ₁₀	141.1	99.7	12.3	24.1	0.8	0.01	0.001	0.007	0.004	0.004	0.4	--	0.1	3.6
PM _{2.5} ⁽⁵⁾	128.9	99.7	12.3	14.5	0.8	0.01	0.001	0.007	0.004	0.004	0.4	--	0.1	1.0
NH ₃	100.0	75.9	24.1	--	--	--	--	--	--	--	--	--	--	--
H ₂ S	1.3	--	--	--	--	--	--	--	--	--	--	1.3	--	--

Source: HECA Project

Notes:

¹ Total annual HRS emissions represents the maximum emissions rate from a composite firing scenario (all three fuels)

² Includes contributions from all three cooling towers

³ Includes contributions from both emergency generators

⁴ Feedstock emissions are shown as the contribution of all dust collection points.

⁵ Where PM₁₀ = PM_{2.5}, it is assumed that PM₁₀ is 100% PM_{2.5}

CO = carbon monoxide

CO₂ = carbon dioxide

CTG = combustion turbine generator

H₂S = hydrogen sulfide

NH₃ = ammonia

NO_x = nitrogen oxides

PM₁₀ = particulate matter 10 microns in diameter

PM_{2.5} = particulate matter 2.5 microns in diameter (PM_{2.5} is assumed to equal PM₁₀)

SO₂ = sulfur dioxide

VOC = volatile organic compounds

Plant Startup Emissions

This section describes a plant-wide “cold” startup. If the Project is being restarted after a short outage, where little or no maintenance is required, the durations of each step will be much shorter than indicated in the following description. This sequence assumes that all the necessary utility and support systems are already in service (plant distributed control system, fire protection and other safety systems, electrical switchyard and in-plant electrical distribution, water treatment, wastewater deep well injection, natural gas, steam, instrument and plant air, purge nitrogen, etc.).

The power block startup sequence on natural gas is similar to a conventional natural gas combined cycle plant. Once all the startup permissives are met, GE’s Frame 7FB start signal is given and the gas turbine generator is used as a motor to rotate the gas turbine and accelerate it until the operation is self sustaining (static start). The gas turbine compressor is first partially loaded to provide enough air flow and duration to purge the HRSG. Following the purge, natural gas is introduced into the CTG combustors and the gas turbine operation becomes self sustaining and the static start is discontinued. When the gas turbine reaches 3,600 revolutions per minute (RPM), or “full speed, no load,” it is synchronized with the electrical grid and the main breaker is closed. Shortly after the CTG is synchronized it is loaded to a minimum or “spinning reserve” load. All the preceding steps are executed automatically by the CTG’s control computer. At this point the HRSG begins warming up and rapidly begins to produce steam. The steam is initially vented to the atmosphere and as pressure builds in the steam system the atmospheric vents close and the steam flow is diverted to the surface condenser.

Once dry steam is available the steam turbine startup sequence can be initiated. The steam turbine metal temperature determines how quickly the steam turbine can be loaded. If the steam turbine has been down for an extended period of time, it will follow the “cold start” sequence. The cold start sequence requires the CTG to operate at reduced load (below the emission compliance level) for up to 3 hours. During this time, the gas turbine load is slowly increased to match the steam temperature to the steam turbine metal temperature to heat the steam turbine while minimizing thermal stress. Once the gas turbine reaches the required load, steam is introduced to control NO_x formation. Once the SCR catalyst reaches the required temperature, ammonia injection is initiated and the HRSG stack emissions will fall to the required compliance levels. The CTG can then be loaded normally to baseload and the steam turbine will reach a load based on the available steam. At this point the power block is producing more than enough power to support the rest of the Project.

The ASU will require about 4 days to start up and reach full capacity. Because the ASU operates at cryogenic conditions, the startup sequence includes an extensive cool down and drying period. During this time, the main air compressor and booster air compressor will be operated to provide the “auto refrigeration” necessary to cool and dry the ASU. Near the end of the startup sequence, the ASU will begin producing liquid oxygen and liquid nitrogen. The liquid oxygen is stored to provide a backup oxygen supply to cover a compressor trip or other short ASU outage. The liquid nitrogen storage is provided as a backup supply for the purge nitrogen system. Once the ASU is producing enough oxygen to operate at least one gasifier, the liquid oxygen pumping and vaporization system can be started to make high pressure O₂ vapor available to the gasification unit.

The AGR unit is assumed to be ready to start (purged with N₂ and with startup methanol levels established in the circulating system). Methanol circulation is started and the refrigeration system is started to begin cooling the methanol to normal operating temperature (approximately -40°F). This sequence is expected to take about 2 days and will complete at about the same time that sufficient O₂ is available to start a gasifier.

The SRU includes two conventional Claus reactor trains. Operation of the second Claus reactor train is not required if only one gasifier is operating, or if both gasifiers are operating on low sulfur coal/coke blends. This sequence assumes that both trains will be needed and that the first train is started up along with the single TGTU. The SRU reactor furnace is refractory lined. After an extended outage, both the refractory and the SRU catalyst require a gradual heating program that will take about 3 days. The heating is provided by firing natural gas with air in the reaction furnace. The combustion products flow through the reactor furnace, catalyst beds, and boilers to the tail gas thermal oxidizer. During the refractory dryout/cure period, the hydrogenation reactor in the TGTU will also be preheated. The hydrogenation reactor catalyst requires pre-sulfiding which will be timed to complete when the SRU is feed ready and the first gasifier is feed ready. At the end of this sequence, the amine circulation in the TGTU will be established and operating conditions will be established.

The gasifier vessels are refractory lined and require about 1 to 2 days to heat up to the temperature that allows O₂ and the feedstock to be introduced.

The shift reactors require warm-up and pre-sulfiding before sour syngas can be introduced. The shift reactor catalyst is heated by circulating hot nitrogen across the catalyst beds for about 2 days. The nitrogen is heated indirectly with a high pressure steam heater. Once the catalyst is hot, a small amount of sulfur-containing compound is added to the circulating N₂. The pre-sulfiding is completed when traces of sulfur are detected in the effluent of the second shift reactor. The shift reactors are then isolated hot and ready for feed.

The carbon dioxide compression system will be purged and ready to compress carbon dioxide. The carbon dioxide compressor startup sequence will be timed to coincide with the time the AGR is producing CO₂ in sufficient quantity to allow sustained operation of the carbon dioxide compressor.

When the gasifier refractory reaches operating temperature, the gasifier can be started by introducing oxygen and a sulfur-free feedstock, then switching to the petroleum coke and/or petroleum coke-coal blend feedstock. Raw syngas produced is sent to gasification flare until the system pressure and flow are stabilized. For normal start-up, the syngas sent to flare is essentially sulfur-free.

Syngas is diverted through the shift reactors and low-temperature gas cooling sections and then to AGR. The AGR unit solution will begin absorbing the carbon dioxide in the syngas. Once the carbon dioxide concentration in the “rich” solution reaches the required level, the flash drums will begin separating carbon dioxide vapor. This carbon dioxide will be washed to remove any traces of methanol and vented to the atmosphere at the top of the absorber column.

Once sufficient hydrogen-rich fuel production is available, GE’s Frame 7FB can initiate a switch either to co-firing or to 100 percent hydrogen-rich syngas. At this point the startup is complete and normal operation begins.

Commissioning

Commissioning will be completed by system with the utilities (power, water, natural gas, steam, etc.) completed first. In general, the major process units will be commissioned in a sequence that begins with the feed producing units and ends with the product producing units and systems.

The commissioning sequence will begin with the auxiliary CTG operating in commissioning mode for up to 356 hours. After this, the auxiliary CTG and auxiliary boiler will run in normal mode for 892 hours while the HRSG operates in commissioning mode on natural gas.

As described in Section 2.6.4, Commissioning, the major process units will be commissioned sequentially. The major gasification block units consume substantial amounts of electrical power. Therefore, the power block needs to be highly reliable and functioning on natural gas prior to commissioning on hydrogen-rich syngas. For this reason, the power block will be commissioned about 6 months ahead of the gasification block. The commissioning for the Project will require four distinct phases which are described as follows.

- Combined cycle unit commissioning on natural gas;
- Commissioning of the auxiliary simple cycle CTG on natural gas;
- Gasification block, including ASU, and balance of plant commissioning; and
- Commissioning the combined cycle unit on hydrogen-rich fuel.

The startup and commissioning period of the Project (CTG, ASU, process block and BOP, IGCC) is expected to be completed within one year from mechanical completion. Commercial operation will start when the commissioning and startup activities are completed and the licensor/contractor guarantees and milestones have been achieved. The ramp-up period to maturity is estimated to be 3 years from the start of commercial operation. The hydrogen-rich fuel availability for mature operation is estimated to be greater than 80 percent. The power availability for mature operation is estimated to be greater than 90 percent.

While considerable data exists on commissioning periods on power generation involving natural gas, and mature operation is reached within a few months for NGCC type systems, the power generation involving hydrogen-rich fuel from solid feedstock such as petroleum coke or coal requires a longer ramping duration due to the shakedown periods involved in the various technologies employed in the process block; in particular, the solid feedstock gasification. For this reason, the process block is expected to have an availability much less than 80 percent during the first 3 years.

After the one-year initial Startup and basic Commissioning Phase, there will be multiple gasifier starts per year. These will occur over the lifespan of the Project, and therefore, can be considered as part of the 'normal' operations of the Project, from an air quality standpoint. Consequently, these gasifier startup emissions from the gasification flare are no greater than the emissions from the gasification flare from normal gasifier start-ups. However, the frequency and duration of gasification flare operations are speculative. Although each individual unit and technology has been demonstrated, the integration of the technologies in this Project is unique. Therefore, total gasifier commissioning emissions are speculative.

Combined Cycle Unit Commissioning on Natural Gas

The natural gas commissioning procedure for the combined cycle unit (CTG/HRSG) is similar to that used for conventional natural gas fired combined cycle plants. The GE Frame 7FB uses diffusion combustors with steam injection, rather than dry-low NO_x combustors, so the NO_x tuning procedure is the primary difference between this Project and conventional natural gas fired combined cycle turbines. The following list briefly describes the steps for commissioning on natural gas:

- First fire
- Green rotor run-in
- Support of steam blows
- Initial steam turbine roll
- NO_x tuning with steam injection
- Water wash and simple cycle CTG performance and emissions testing
- Duct burner testing
- Installation of SCR and oxidation catalyst
- Continuous emissions monitoring system (CEMS) drift test and source testing
- Combined cycle functional testing
- Water wash and combined cycle performance testing and continuous operation test

The emissions associated with the sequence above are shown in Table 5-10, Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Natural Gas at 59°F.

The duration of all tests may be affected by unforeseen events, and therefore can only be estimated in advance. A maximum of 892 hours of operation during commissioning of the combustion turbine with partially abated emissions is expected over a period not to exceed 5 months. The annual frequency of turbine starts during the year when commissioning occurs is not expected to exceed the frequency of turbine starts during operation (see Table 5-10, Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Natural Gas at 59°F). Fuel flow monitoring will be conducted for all tests.

Table 5-10
Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Natural Gas at 59°F

Test Phase	Hours of Operation	CTG Load	SCR/CO Status	SO _x (lb)	NO _x (lb)	CO (lb)	VOC (lb)	PM ₁₀ (lb)
First Fire	4	FSNL	Not Operating	4	232	8,800	1,380	72
Green Rotor Run-In	12	10%	Not Operating	16	1,320	14,400	780	216
Steam Blows	168	30%	Not Operating	365	57,960	8,400	1,680	3,024
Restoration	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Initial Steam Turbine Roll	24	10%	Not Operating	31	2,640	28,800	1,560	432
NO _x Tuning with Steam Injection and initial STG loading	16	60%	Not Operating	44	1,936	936	54	288
NO _x Tuning with Steam Injection and initial STG loading	16	100%	Not Operating	59	2,688	1,282	75	288
Finalize NO _x Control Constants	40	60%	Not Operating	109	4,840	2,340	136	720
Finalize NO _x Control Constants	40	80%	Not Operating	129	5,800	2,732	160	720
Finalize NO _x Control Constants	96	100%	Not Operating	357	16,128	7,690	451	1,728
CTG Water Wash and Contractor's Emission and Simple Cycle Performance Testing	16	100%	Not Operating	59	2,688	1,282	75	288
Duct Burner Testing	96	100%	Not Operating	453	19,488	12,490	1,171	1,728
Install SCR and Oxidation Catalyst	24	100%	Testing	89	4,032	1,922	113	432
CEMS Drift and Source Testing	64	100%	Operating	238	2,157	1,312	301	1,152
Functional Testing Demonstration Hours	12	Various	Operating	10	500	5,560	920	100
Functional Testing Steady State Hours	48	100%	Operating	178	1,618	984	226	864
CTG Water Wash and Preparation for Performance Testing	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Combined Cycle Performance Testing	24	100%	Operating	113	1,054	641	180	432
Continuous Operation Test	192	100%	Operating	713	6,470	3,936	902	3,456
	892			2,966	131,550	103,506	10,165	15,940
				1.5	65.8	51.8	5.1	8.0

Source: HECA Project

Notes:

CEMS = continuous emissions monitoring system
CO = carbon monoxide

CTG = combustion turbine generator
HRSG = heat recovery steam generator
N/A = not applicable
NO_x = nitrogen oxides

PM₁₀ = particulate matter 10 microns in diameter
SCR = selective catalytic reduction
SO_x = sulfur oxides
VOC = volatile organic compound

The gas turbine commissioning periods begin when the turbines first burn natural gas. The Applicant will make every effort to minimize emissions of CO, VOCs, and NO_x during the commissioning period. However, not all of the equipment to abate these emissions will be fully operational at the start of the commissioning period. The Applicant requests a maximum of 552 hours of partially abated emissions for the gas turbine train.

Once it has been installed, the oxidation catalyst will abate CO and VOC emissions from the gas turbine and the duct burners because it is essentially a passive device. While the SCR catalyst is in some cases able to be installed prior to initial startup of the combustion turbine, it may not be installed until later in the commissioning period, after completion of steam blows which could deposit debris and otherwise damage the catalyst. The SCR catalyst may not be installed at the same time as the oxidation catalyst. Nitrogen oxide emissions from the gas turbines and the duct burners may be only partially abated during times that the gas turbine burners are being tuned and the SCR system is being tested.

Commissioning emissions were very conservatively estimated as worst case by assuming that the control efficiency of the applicable abatement systems is essentially zero during significant portions of the commissioning phase. Where applicable, emission offsets will be the mitigation of these emissions.

The CEMS will also be undergoing commissioning at this time. Once the CEMS is commissioned, it will record emissions of NO_x and CO. Emissions of SO₂ and PM₁₀ may be quantified by using emission factors based on fuel flow.

Combined Cycle Block Commissioning on Hydrogen Rich Syngas

The combined cycle block will require additional testing and NO_x tuning with hydrogen-rich syngas. The testing will cover the range of natural gas/hydrogen-rich syngas blends and allowable load ranges. The combined cycle block is assumed to have been commissioned first on natural gas. The oxidation catalysts are assumed to be in service and active when the HRSG operating temperature is sufficient. The SCR catalyst and ammonia injection system are assumed to be operating whenever the SCR catalyst temperature is in the required range and operation is sufficiently stable. Ammonia injection may be off-line during the initial phases of NO_x tuning. The key activities and events that are expected to produce air emissions are listed below:

- Startup and shutdown of GE's Frame 7FB on natural gas
- Standby operation of the combined cycle block on natural gas
- CTG NO_x tuning on co-firing
- CTG NO_x tuning on 100 percent hydrogen-rich syngas
- CTG NO_x tuning on part load
- Water wash and performance testing on hydrogen-rich fuel
- Duct burner testing on hydrogen-rich syngas
- Source testing on hydrogen-rich fuel blends across the load range
- Functional testing including fuel transfers and load changes

- Plant-wide performance test
- Plant-wide operational reliability test

The emissions associated with the sequence above are shown in Table 5-11, Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG on Hydrogen Rich-Syngas at 59°F.

The duration of all tests may be affected by unforeseen events, and therefore can only be estimated in advance. A maximum of 644 hours of operation during commissioning of the auxiliary combustion turbine with partially abated emissions is expected over a period not to exceed 5 months. The annual frequency of turbine starts during the year when commissioning occurs is not expected to exceed the frequency of turbine starts during operation. Fuel flow monitoring will be conducted for all tests.

Table 5-11
Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG
on Hydrogen Rich-Syngas at 59°F

Test Phase	Hours of Operation	CTG Load	SCR/CO Status	SO _x (lb)	NO _x (lb)	CO (lb)	VOC (lb)	PM ₁₀ (lb)
CTG Starts on Natural Gas	30	Various	Not Operating	84	5,010	11,820	2,940	690
CTG Fired Shutdowns	30	Various	Not Operating	30	1,860	3,780	630	300
CTG/HRSG Standby Operation on Natural Gas	120	60%	Operating	327	2,904	1,776	408	2,160
CTG NO _x Tuning @ 45% Hydrogen-Rich Syngas Co-firing	16	100%	50% SCR, 90% CO (*)	49	1,584	692	88	576
CTG NO _x Tuning @ 90% Hydrogen-Rich Syngas Co-firing	16	100%	50% SCR, 90% CO (*)	38	1,832	744	48	576
CTG NO _x Tuning @ 100% Hydrogen-Rich Fuel	16	100%	50% SCR, 90% CO (*)	38	928	146	45	576
CTG NO _x Tuning @ 100% Hydrogen-Rich Fuel Min Load	16	60%	50% SCR, 90% CO (*)	27	768	102	37	576
CTG Water Wash and Contractor's Emission and Simple Cycle Performance Testing on Hydrogen-Rich Fuel	24	100%	Operating	57	1,106	403	77	864
Duct Burner Testing on Hydrogen-Rich Syngas	48	100%	Operating	128	2,386	869	168	1,728
Source Testing @ 100% Hydrogen-Rich Syngas	16	100%	Operating	38	738	269	51	576
Source Testing @ 100% Hydrogen-Rich Syngas	16	100%	Operating	43	795	290	56	576

Table 5-11
Duration and Criteria Pollutant Emissions for Commissioning of the CTG/HRSG
on Hydrogen Rich-Syngas at 59°F

Test Phase	Hours of Operation	CTG Load	SCR/CO Status	SO _x (lb)	NO _x (lb)	CO (lb)	VOC (lb)	PM ₁₀ (lb)
Source Testing @ 45% Hydrogen-Rich Syngas Co-firing	16	100%	Operating	49	634	386	88	576
Source Testing @ 90% Hydrogen-Rich Syngas Co-firing	16	100%	Operating	38	774	470	107	576
Functional Testing Steady State Hours	48	100%	Operating	128	2,386	869	168	1,728
CTG Water Wash and Preparation for Performance Testing	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
IGCC Performance Testing	24	100%	Operating	64	1,193	434	84	864
Continuous Operation Test	192	100%	Operating	512	9,542	3,475	672	6,912
Notes: During weeks 44 through 53, none of the emissions overlap	644			1,650	34,440	26,525	5,667	19,854
				0.8	17.2	13.3	2.8	9.9

Source: HECA Project

Notes:

CO = carbon monoxide
 CTG = combustion turbine generator
 HRSG = heat recovery steam generator
 N/A = not applicable
 NO_x = nitrogen oxides
 PM₁₀ = particulate matter 10 microns in diameter
 SCR = selective catalytic reduction
 SO_x = sulfur oxides
 VOC = volatile organic compound

Commissioning the Auxiliary Simple Cycle CTG on Natural Gas

The auxiliary simple cycle CTG (GE LMS100[®]) is exclusively fueled by natural gas and is provided with water injection for primary NO_x control. The following list briefly describes the steps for commissioning on natural gas:

- First fire
- NO_x tuning with water injection
- Installation of SCR and oxidation catalyst
- CEMS drift test and source testing
- Water wash and performance and functional testing

The emissions associated with the sequence above are shown in Table 5-12, Duration and Criteria Pollutant Emissions for Commissioning of the Auxiliary CTG on Natural Gas at 59°F.

The duration of all tests may be affected by unforeseen events, and therefore can only be estimated in advance. A maximum of 356 hours of operation during commissioning of the auxiliary combustion turbine with partially abated emissions is expected over a period not to exceed 5 months.

The gas turbine commissioning periods begin when the turbines first burn natural gas. The Applicant will make every effort to minimize emissions of CO, VOCs, and NO_x during the commissioning period. However, not all of the equipment to abate these emissions will be fully operational at the start of the commissioning period. The Applicant requests a maximum of 236 hours of partially abated emissions for the gas turbine train.

Table 5-12
Duration and Criteria Pollutant Emissions for Commissioning
of the Auxiliary CTG on Natural Gas at 59°F

Test Phase	Hours of Operation	CTG Load	SCR/CO Status (3)	SO _x (lb)	NO _x (lb)	CO (lb)	VOC (lb)	PM ₁₀ (lb)
First Fire	4	FSNL	Not Operating	2	282	1,500	12	24
NO _x Tuning with Water Injection	16	50%	Not Operating	17	1,128	2,616	48	96
NO _x Tuning with Water Injection	16	100%	Not Operating	29	1,944	4,512	82	9696
Finalize NO _x Control Constants	40	50%	Not Operating	42	1,880	4,360	80	240
Finalize NO _x Control Constants	40	75%	Not Operating	57	2,600	5,960	108	240
Finalize NO _x Control Constants	96	100%	Not Operating	176	7,776	18,048	326	576
Install SCR and Oxidation Catalyst	24	100%	Testing	44	1,944	4,512	82	144
CEMS Drift and Source Testing	64	100%	Operating	117	531	762	147	384
Functional Testing Steady State Hours	48	100%	Operating	88	398	571	110	288
Preparation for Performance Testing	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Contract Performance Test	8	100%	Operating	15	66	95	18	48
	356			587	18,550	42,936	1,014	2,136
			tons	0.3	9.3	21.5	0.5	1.1

Source: HECA Project

Notes:

CO	=	carbon monoxide	NO _x	=	nitrogen oxides
CTG	=	combustion turbine generator	PM ₁₀	=	particulate matter 10 microns in diameter
HRS	=	heat recovery steam generator	SCR	=	selective catalytic reduction
N/A	=	not applicable	SO _x	=	sulfur oxides
			VOC	=	volatile organic compound

5.4 GREENHOUSE GAS EMISSIONS

California has enacted a law, Assembly Bill 32 (AB 32), to reduce greenhouse gas emissions to 1990 levels by 2020. Furthermore, California Governor Schwarzenegger's Executive Order S-3-05 sets a state target of reducing greenhouse gas emissions to 80 percent below 1990 levels by 2050. AB 32 requires the California Air Resources Board (CARB) to assign emissions targets to each sector in the California economy and to develop regulatory and market methods to ensure compliance, which take effect in 2012. The California Public Utilities Commission (CPUC) and CEC are to develop specific proposals to CARB for implementing AB 32 in the electricity sector, possibly including a cap-and-trade program. Senate Bill 1368 is a state regulation setting limits on greenhouse gas emissions from utilities.

Carbon dioxide emissions for the solid feedstock IGCC plant are 250 lbs/MWh on steady-state operations on syngas. The table included in Appendix B presents the peak or maximum possible carbon dioxide emissions for all Project emission sources. The annual average for steady-state operations of the IGCC, is expected to be less than 400 lbs/MWh, including emissions from typical natural gas co-firing, normal usage of natural gas, start-up, and shut-down. These steady-state emissions are approximately one-half of those from a typical natural gas combined cycle power plant. In summary, the Project's greenhouse gas emissions will be well below the 1,100 lbs/MWh threshold requirement (natural gas combined cycle comparison) of SB 1368.

5.5 MOBILE SOURCES

On-site truck trip emissions were incorporated in the dispersion modeling. Trucks delivering coal and coke feedstock would be traveling to the Project Site daily. In addition, trucks handling and storing gasification solids from the gasifiers would also be traveling around the Project Site on an hourly basis. The number of truck trips by period (e.g., hourly, daily, annual) is summarized in Table 5-13 below.

Table 5-13
On-Site Truck Trips by Period

Period	Coke and Coal	On-Site Gasifier Solids Handling
1 hour	18	2
3 hours	54	7
8 hours	144	13
24 hours	180	38
Annual	35,500	2,900

The feedstock trucks would enter the plant from Adohr Road on the north side, and then proceed to the truck unloading station north of the inactive feedstock storage. At the truck unloading area, each truck would idle for about 5 to 10 minutes while unloading, then loop back around through the truck scales and wash rack to exit the plant onto Adohr Road.

Typically, the gasification solids handling trucks would travel from the gasifiers, where they pick up the gasifier solids in containers, then drive offsite. Alternatively they may drive around to the gasifier solids storage area where they would off load the containers. The conservative

assumption that they do not immediately leave was used in this analysis. These trucks would also travel at about 10 miles per hour. At the pick up and drop off points, trucks would idle for about five to 10 minutes. The distance traveled within the site for all trucks would be less than one mile.

Heavy-duty diesel truck emission factors were obtained from the CARB on-road emissions model EMFAC2007. It was assumed that all trucks would be diesel trucks. Emission factors from EMFAC2007 are provided in terms of grams per mile, which were converted to grams per second for the AERMOD dispersion model, based on the distance traveled and the number and frequency of truck trips. EMFAC2007 factors vary depending on the calendar year for which the model is run, because the emission factors reflect adopted CARB engine and fuel standards and are also based on the vehicle fleet age and composition. The vehicle fleet used by EMFAC2007 is based on an analysis of California Department of Motor Vehicles (DMV) registration data, which vary by calendar year and geographic area. Thus, EMFAC2007 runs for earlier calendar years will produce higher emission factors because of older, higher-polluting vehicles still in the vehicle fleet.

EMFAC2007 emissions factors for calendar year 2015 were used for the dispersion modeling analysis. The anticipated Project start date is 2015, and the Project must show upon commencing operations that it will not violate PSD significance levels or ambient air quality standards for criteria pollutants. The EMFAC2007 2015 calendar year factors were used in the modeling of on-site trucks to demonstrate compliance with these standards. EMFAC2007 gram-per-mile factors from the model output and gram-per-second rates used in the AERMOD modeling are summarized in Table 5-14 below.

Table 5-14
EMFAC2007 Heavy Truck Emission Factors and AERMOD Emission Rates

Pollutant	Emission Factors from EMFAC			
	Onsite Coke and Coal Trucks		Onsite Gasifier Solids Handling Trucks	
	Running (g/mi)	Idling (g/hr)	Running (g/mi)	Idling (g/hr)
NO _x	16.59	115.98	23.65	115.98
CO	8.29	47.47	12.05	47.47
SO ₂	0.03	0.06	0.04	0.06
PM ₁₀ ^a	1.09	1.12	1.47	1.12
PM _{2.5}	0.79	1.03	1.14	1.03
Pollutant	Emission Rates for AERMOD			
	Onsite Coke and Coal Trucks		Onsite Gasifier Solids Handling Trucks	
	Running (g/s)	Idling (g/s)	Running (g/s)	Idling (g/s)
NO _x				
1-hour	0.080	0.068	0.007	0.005
Annual	0.018	0.015	0.001	0.001
CO				
1-hour	0.040	0.028	0.004	0.002
8-hour	0.040	0.028	0.004	0.002

Table 5-14
EMFAC2007 Heavy Truck Emission Factors and AERMOD Emission Rates

Pollutant	Emission Rates for AERMOD			
	Onsite Coke and Coal Trucks		Onsite Gasifier Solids Handling Trucks	
	Running (g/s)	Idling (g/s)	Running (g/s)	Idling (g/s)
SO ₂				
1-hour	1.4e-4	3.6e-5	1.2e-5	2.9e-6
3-hour	1.4e-4	3.6e-5	1.4e-5	3.3e-6
24-hour	6.0e-5	1.5e-5	9.1e-6	2.2e-6
Annual	3.3e-5	8.1e-6	1.9e-6	4.8e-7
PM ₁₀				
24-hour	0.002	2.7e-4	3.6e-4	4.0e-5
Annual	0.001	1.5e-4	7.7e-5	8.5e-6
PM _{2.5}				
24-hour	0.002	2.5e-4	2.8e-4	3.7e-5
Annual	0.001	1.3e-4	6.0e-5	7.9e-6

Notes:

1. Includes tire wear, brake wear, and entrained road dust.

The purpose of the air quality impact analyses is to evaluate whether or not criteria pollutant emissions resulting from the Project will cause or contribute significantly to a violation of a California or national AAQS or contribute significantly to degradation of air quality-related values in Class I areas. Mathematical models, designed to simulate the atmospheric transport and dispersion of airborne pollutants, are used to quantify the maximum expected impacts of Project emissions for comparison with applicable regulatory criteria. The impacts from operations will be associated with the operation of the gasification block, power block, and ancillary equipment.

The air quality modeling methodology described in this section has been documented in a formal modeling protocol, which has been submitted for comment to CEC, SJVAPCD, and EPA Region 9. A copy of this protocol is provided in Appendix C. The modeling approaches used to assess various aspects of the Project's potential impacts to air quality are discussed below. The approaches discussed below follow the Modeling Protocol. Modeling of on-site mobile emissions was included in response to a comment by CEC during review of the Modeling Protocol. Copies of the modeling files are included on the digital versatile disks (DVD) entitled HECA Air Quality Modeling Files provided with this PSD application.

6.1 MODEL AND MODEL OPTION SELECTIONS

The impacts of Project operations on criteria pollutant concentrations in receptor areas within 31 miles (50 km) from the Project Site and Controlled Area were evaluated using the American Meteorological Society/Environmental Protection Agency Regulatory Model (AERMOD) (Version 07026). AERMOD is appropriate for this Revised AFC because it has the ability to assess dispersion of emission plumes from multiple point, area, or volume sources in flat, simple, and complex terrain, and to use sequential hourly meteorological input data. The regulatory default options were used, including building and stack tip downwash, default wind speed profiles, exclusion of deposition and gravitational settling, consideration of buoyant plume rise, and complex terrain.

Compliance with SJVAPCD Rule 2201 modeling requirements for attainment pollutants will be demonstrated by modeling the maximum ground level concentrations of the Project at any receptor and adding conservative background concentrations, based on recent data from the most representative air quality monitoring stations. The Project will not be considered to cause or contribute to a near-field ambient air quality violation unless impacts from these sources combined with the background concentration exceed the most stringent AAQS.

Note that emissions reduction credits will be obtained by the Applicant to offset Project emissions increases of the following pollutants: NO_x, VOC, PM₁₀, and SO₂. They are above the SJVAPCD emission offset triggering levels specified in the District's Rule 2201.4.5.3. The modeling did not take into account any reduction in emissions due to offsets.

Evaluation of commissioning and operational NO₂ concentrations (1-hour and annual averaging times) was accomplished using the OLM option in AERMOD. The OLM option accounts for the role of ambient O₃ in limiting the conversion of emitted NO_x (which occurs mostly in the form of nitrogen oxides [NO]) to NO₂, the pollutant regulated by ambient standards. The input data to the AERMOD-OLM model includes representative hourly O₃ monitoring data for the years corresponding to the meteorological input record.

To evaluate whether urban or rural dispersion parameters should be used in model simulations, an analysis of land use adjacent to the Project Site was conducted in accordance with Section 8.2.8 of the *Guideline on Air Quality Models* (USEPA 2003) and Auer (1978), USEPA AERMOD implementation guide (2004), and its addendum (2006). Based on the Auer land use procedure, more than 50 percent of the area within a 1.9 mile (3 km) radius of the Project is classified as rural. Since the Auer classification scheme requires more than 50 percent of the area within the 1.9 mile (3 km) radius around a proposed new source to be non-rural for an urban classification, the rural mode will be used in the AERMOD modeling analyses. All regulatory default options will be used, including building and stack tip downwash, default wind speed profiles, exclusion of deposition and gravitational settling, consideration of buoyant plume rise, and complex terrain.

6.2 BUILDING WAKE EFFECTS

The effects of building wakes (i.e., downwash) on plumes from the Project's operational sources were evaluated in accordance with USEPA guidance (USEPA 1985). Data on the buildings on the Project Site that could potentially cause plume downwash effects for the sources were determined for different wind directions using the USEPA Building Profile Input Program – Prime (BPIP-Prime) (Version 98086) (USEPA 1995). Forty-two structures were identified within the Project Site to be included in the downwash analysis, including 21 buildings and 21 tanks. A table listing all the structures evaluated in the downwash analysis is included in Appendix D.

The results of the BPIP-Prime analysis were included in the AERMOD input files to enable downwash effects to be simulated. Input and output electronic files for the BPIP-Prime analysis are included with those from all other dispersion modeling analyses on the digital versatile discs (DVDs) that are being submitted with this Application.

6.3 METEOROLOGICAL DATA

Meteorological data suitable for direct input to AERMOD were obtained from the SJVAPCD website. Hourly surface data for calendar years 2000, 2001, 2002, 2003, and 2004 were obtained from the SJVAPCD at the Bakersfield Airport meteorological station which is located in the city of Bakersfield, within 20 miles (32.2 km) east-northeast of the Project Site. These data have been pre-processed by the SJVAPCD with the Oakland upper air data to create an input data set specifically tailored for input to AERMOD. The SJVAPCD prepared this data specifically for applicants use for locations such as HECA.

The meteorological data recorded at Bakersfield Airport are acceptable for use at the Project Site for two reasons – proximity and terrain similarity. The terrain immediately surrounding the Project Site property can be categorized as a fairly flat, or gradually sloping rural area in a region with developed oil wells. The terrain around the Bakersfield Airport also consists of relatively flat, or gradually sloping rural or suburban areas. Thus, the land use and the location with respect to near-field terrain features are similar. Both are located in areas of medium surface roughness (as opposed to low surface roughness like bodies of water or grassy prairies or high surface roughness like highly urbanized cities or forests). Both locations are on the valley floor and approximately the same elevation. Additionally, there are no significant terrain features

separating the Bakersfield Airport from the Project Site that would cause significant differences in wind or temperature conditions between these respective areas. Therefore, the 5 years of meteorological data selected from the Bakersfield Airport were determined to be representative for the purposes of evaluating the Project's air quality impacts. The Bakersfield Airport is the closest full-time meteorological recording station to the Project Site, and thus meteorological conditions at the sites will be very similar.

Seasonal and annual wind roses based on the 5 years of Bakersfield Airport surface meteorological data are provided in the modeling protocol in Appendix C. Winds for all seasons and all years blow predominantly from the sector between northwest and north, although the directional pattern is more variable during the fall and winter seasons.

6.4 RECEPTOR LOCATIONS

The receptor grids used in the AERMOD modeling analyses for operational sources were as follows:

- 25-meter spacing along the fenceline and extending from the fenceline out to 100 meters beyond the Project Site and Controlled Area line
- 50-meter spacing from 100 to 250 meters beyond the Project Site and Controlled Area line
- 100-meter spacing from 250 to 500 meters beyond the Project Site and Controlled Area line
- 250-meter spacing from 500 meters to 1 km beyond the Project Site and Controlled Area line
- 500-meter spacing within 1 to 2 km of Project sources
- 1,000-meter spacing within 2 to 10 km of Project sources

Figure 6-1, Near-Field Model Receptor Grid and Figure 6-2, Far-Field Model Receptor Grid, show the placement of near-field and far-field receptor points, respectively. Terrain heights at receptor grid points were determined from U.S. Geological Survey digital elevation model files. During the refined modeling analysis for operational Project emissions, if a maximum predicted concentration for a particular pollutant and averaging time is located within the portion of the receptor grid with spacing greater than 25 meters, a supplemental dense receptor grid will be placed around the original maximum concentration point and the model will be rerun. The dense grid will use 25-meter spacing and will extend to the next grid point in all directions from the original point of maximum concentration.

Consistent with accepted practice, this AERMOD receptor grid, with the additional dense nested grid points, was determined to best balance the need to predict maximum pollutant concentrations and allow all operational modeling runs to be completed in less than 1 week.

Because construction emission sources release pollutants to the atmosphere from small equipment exhaust stacks or from soil disturbances at ground level, maximum predicted construction impacts for all pollutants and averaging times will occur within the first km from the Project Site boundary. Accordingly, only the portion of the above grid with 25-meter spacing out to a distance of 200 meters was used for the construction modeling.

The same receptor grid used in the criteria pollutant modeling for the operational Project will be used in the health risk assessment modeling, with additional receptors placed at all sensitive

locations (e.g., schools, hospitals, etc.) out to 10 km (6 miles). Finally, discrete receptors will be placed at the locations of all nearby residences.

6.5 TURBINE IMPACT SCREENING MODELING

As described previously, a screening modeling analysis was performed to determine which CTG/HRSG operating mode and stack parameters produced worst-case off-site impacts (i.e., maximum ground level concentrations for each pollutant and averaging time). Only the emissions from the CTGs with and without duct firing and evaporative cooling were considered in this preliminary modeling step. The screening modeling used AERMOD, as described in the previous sections. Building wake information and the receptor grid described above were also used. All 5 years of meteorological data were used in the screening analysis.

The AERMOD model simulated natural gas combustion emissions from the 20-foot-diameter (6.10 meters), 213-foot-tall (65 meters) stack for the CTG/HRSG unit and the 16-foot diameter (4.88 meters), 110-foot tall (33.5 meters) auxiliary CTG unit. The stacks were modeled as point sources at their proposed locations within the Project Site. Table 6-1, Turbine Screening Results Normal Operations – Emissions and Stack Parameters per Turbine, summarizes the combustion CTG screening results for the different CTG operating load conditions. First, the model was run with unit emissions (1.0 grams per second) from each stack to obtain normalized concentrations that are not specific to any pollutant. CTG vendor data used to derive the stack parameters for the different operating conditions evaluated in this screening analysis are included in Appendix B.

The maximum ground level concentrations predicted to occur off site with unit turbine emission rates for each of the seven operating conditions shown in Table 6-1, Turbine Screening Results Normal Operations – Emissions and Stack Parameters per Turbine, were then multiplied by the corresponding turbine emission rates for specific pollutants. The highest resulting concentration values for each pollutant and averaging time were then identified (see bolded values in the table).

The stack parameters associated with these maximum predicted impacts were used in all subsequent simulations of the refined AERMOD analyses described in the next subsection. (Note that the lower exhaust temperatures and flow rates at reduced turbine loads correspond to reduced plume rise, in some cases resulting in higher off-site pollutant concentrations than the higher baseload emissions.) Model input and output files for the screening modeling analysis are included with those from all other modeling tasks on the Air Quality modeling DVD that is provided with this application.

6.5.1 1-Hour Startup Scenarios

The worst-case 1-hour NO₂ and CO impacts will occur during an hour with a startup, thus the results of the screening analysis were not used to determine the turbine stack parameters. The results in Table 6-1 indicate that maximum hourly NO₂ and CO concentrations during normal operations will occur with the stack parameters corresponding to 60 percent load. However, the magnitude of the emissions for both these pollutants during the worst-case 60 minutes of the turbine startup sequence will be higher than those during normal operations at any ambient temperature condition. Since a startup is a transition from non-operation to full-load operation, the stack exhaust velocity and temperature during most of this operation are lower than the values indicated as “worst-case” by the turbine screening modeling. Accordingly, modeling

simulations were conducted to estimate the maximum 1-hour NO₂ and CO concentrations during a startup with reduced stack exhaust velocity and temperature.

Table 6-1
Turbine Screening Results Normal Operations – Emissions and Stack Parameters per Turbine

Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3	Case 4A	Case 4B	Case 4C
Scenario Description	HRSG Stack, Hydrogen-rich Fuel			HRSG Stack, Natural Gas Fuel			HRSG Stack Co-Firing	Auxiliary CTG		
HRSG/CTG Load Level	100% Load	80% Load	60% Load	100% Load	80% Load	60% Load	100% Load	100% Load	75% Load	50% Load
Stack Outlet Temperature (°F)	200.0	190.0	180.0	180.0	170.0	160.0	190.0	740.0	740.0	760.0
Stack Outlet Temperature (°K)	366.48	360.93	355.37	355.37	349.82	344.26	360.93	666.48	666.48	677.59
Stack Exit Velocity (ft/s)	63.3	51.8	42.7	53.1	45.6	37.7	58.4	70.2	61.7	50.2
Stack Exit Velocity (m/s)	19.3	15.8	13	16.2	13.9	11.5	17.8	21.4	18.8	15.3
NO _x as NO ₂ (lb/hr)	166.7	166.7	166.7	166.7	166.7	166.7	166.7	20.6	20.6	20.6
CO (lb/hr)	1,679.4	1,679.4	1,679.4	1,679.4	1,679.4	1,679.4	1,679.4	69.0	69.0	69.0
SO ₂ (lb/hr)	8.7	8.7	8.7	8.7	8.7	8.7	8.7	2.4	2.4	2.4
PM ₁₀ (lb/hr)	35.7	35.7	35.7	35.7	35.7	35.7	35.7	10.3	10.3	10.3
NO _x (g/s)	21	21	21	21	21	21	21	2.6	2.6	2.6
CO (g/s)	211.6	211.6	211.6	211.6	211.6	211.6	211.6	8.7	8.7	8.7
SO ₂ (g/s) (based on 0.4 grains total S/100 scf) (grains of total sulfur per 100 standard cubic feet of gas)	1.1	1.1	1.1	1.1	1.1	1.1	1.1	0.3	0.3	0.3
PM ₁₀ (g/s)	4.5	4.5	4.5	4.5	4.5	4.5	4.5	1.3	1.3	1.3
Model Results – Maximum X/Q concentration (µg/m³/[g/s]) predicted from AERMOD (all receptors)										
1-hour	3.682	4.114	4.483	4.191	4.668	6.536	3.966	3.250	3.655	4.530
3-hour ¹	3.313	3.703	4.035	3.771	4.201	5.882	3.569	2.925	3.289	4.077
8-hour ¹	2.577	2.880	3.138	2.933	3.268	4.575	2.776	2.275	2.558	3.171
24-hour ¹	1.473	1.646	1.793	1.676	1.867	2.614	1.586	1.300	1.462	1.812
annual ¹	0.295	0.329	0.359	0.335	0.373	0.523	0.317	0.260	0.292	0.362
Maximum Concentration (µ g/m³) Predicted per Pollutant Normal Operations (all receptors)										
NO _x 1 hour	77.313	86.394	94.140	88.001	98.030		83.280	8.450	9.502	11.779
NO _x annual	6.185	6.911	7.531	7.040	7.842		6.662	0.676	0.760	0.942
CO 1 hour	779.024	870.518	948.575	886.714	987.766		839.142	28.276	31.795	39.414

Table 6-1
Turbine Screening Results Normal Operations – Emissions and Stack Parameters per Turbine

Case	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3	Case 4A	Case 4B	Case 4C
Scenario Description	HRSG Stack, Hydrogen-rich Fuel			HRSG Stack, Natural Gas Fuel			HRSG Stack Co-Firing	Auxiliary CTG		
CO 8 hour	545.317	609.363	664.003	620.700	691.436		587.399	19.793	22.256	27.590
SO ₂ 1 hour	4.050	4.525	4.931	4.610	5.135		4.362	0.975	1.096	1.359
SO ₂ 3 hour	3.645	4.073	4.438	4.149	4.621		3.926	0.878	0.987	1.223
SO ₂ 24 hour	1.620	1.810	1.972	1.844	2.054		1.745	0.390	0.439	0.544
SO ₂ annual	0.324	0.362	0.394	0.369	0.411		0.349	0.078	0.088	0.109
PM ₁₀ 24 hour	6.627	7.405	8.069	7.543	8.403		7.138	1.690	1.900	2.356
PM ₁₀ annual	1.325	1.481	1.614	1.509	1.681		1.428	0.338	0.380	0.471
	Case 1A	Case 1B	Case 1C	Case 2A	Case 2B	Case 2C	Case 3	Case 4A	Case 4B	Case 4C

Source: HECA Project

¹ Only 1-hour impacts were modeled. Impact concentrations for other averaging times were estimated with USEPA Screening Factors: 0.9 for a 3-hour avg. time, 0.7 for an 8-hour avg. time, 0.4 for a 24-hr avg. time, and 0.08 for an annual average.

Notes:

- °F = degrees Fahrenheit
- °K = degrees Kelvin
- CO = carbon monoxide
- CTG = combustion turbine generator
- μ g/m³ = micrograms per cubic meter
- g/s = grams per second
- HRSG = heat recovery steam generator
- NO₂ = nitrogen dioxide
- NO_x = nitrogen oxides
- PM₁₀ = particulate matter 10 microns in diameter
- SCR = selective catalytic reduction
- SO₂ = sulfur dioxide

6.6 REFINED MODELING

A refined modeling analysis was performed to estimate off-site criteria pollutant impacts from operational emissions of the Project. The modeling was performed as described in the previous sections, using 5 years of hourly meteorological input data. The new Project CTG/HRSG was modeled assuming the worst-case emissions corresponding to each averaging time and the turbine stack parameters that were determined in the turbine screening analysis (see previous subsection). The maximum mass emission rates that will occur over any averaging time, whether during turbine startups, normal operations, turbine shutdowns, or a combination of these activities, were used in all refined modeling analyses (see Table 6-1). Emissions from the other sources were also included in the refined modeling runs. Emission rate calculations and assumptions used for all pollutants and averaging times are documented in Appendix B.

The DEGADIS model was used to calculate CO and H₂S impacts from the carbon dioxide vent because the plume from the carbon dioxide vent is denser than air and could not be modeled with AERMOD. The DEGADIS model is a USEPA-approved screening model for dense gas plumes. As a screening model, it cannot use hourly meteorological data; it uses worst-case meteorology and can model 1-hour and 8-hour averaging times. The model calculates downwind concentrations until the plume centerline reaches ground level; at that point the model stops calculating concentrations. The SCREEN3 model was used to extend the then neutral density plume downwind to locations offsite when DEGADIS predicted a ground-level maximum within the Project Site and Controlled Area boundary. Model inputs and CO and H₂S emission rates are summarized in Table 6-2, DEGADIS Model Inputs and Parameters, below.

Table 6-2
DEGADIS Model Inputs and Parameters

Max Value at Exit of Stack	100% Flow
Molecular Weight of vent gas	44.0
Flow, pounds/hour	656,000
Flow, kilograms/second	82.656
Temp, F	65
Temp, K	291.6
Stack diameter, inches	42
Stack diameter, meters	1.067
Stack height, feet	260
Stack height, meters	79.3
H ₂ S Concentration (ppm)	10
H ₂ S Emission Rate (lb/hr)	5.15
CO Concentration (ppm)	1,000
CO Emission Rate (lb/hr)	418.5
Stability Class	D
Wind speed, meters	1

Source: HECA Project

Notes:

CO = carbon monoxide
 F = Fahrenheit
 K = Kelvin
 H₂S = hydrogen sulfide

6.6.1 Fumigation Analysis

Fumigation can occur when a stable layer of air lies a short distance above the release point of a plume and unstable air lies below. Especially on sunny mornings with light winds, the heating of the earth's surface causes a layer of turbulence, which grows in depth over time and may intersect an elevated exhaust plume. The transition from stable to unstable surroundings can rapidly draw a plume down to ground level and create relatively high pollutant concentrations for a short period. Typically, a fumigation analysis is conducted using the USEPA model SCREEN3 when the Project Site is rural and the stack height is greater than 10 m.

A fumigation analysis was performed using SCREEN3 to calculate concentrations from inversion breakup fumigation. A unit emission rate was used (1 gram per second) in the fumigation modeling to obtain a maximum unit concentration (x/Q), and the model results were scaled to reflect expected Project emissions for each pollutant. Inversion breakup fumigation concentrations were calculated for 1- and 3-hour averaging times using USEPA-approved conversion factors. These multiple-hour model predictions are conservative, since inversion breakup fumigation is a transitory condition that would most likely affect a given receptor location for only a few minutes at a time.

Since SCREEN3 only models the impacts from one source, the model was run for each combustion source: the CTG/HRSG unit, auxiliary CTG, tail gas thermal oxidizer, and gasifier refractory heater. To calculate the inversion breakup fumigation, the default thermal internal boundary layer factor of 6 in the SCREEN3 model was used.

Fumigation impacts were determined for each source, then summed over all sources using peak predicted fumigation concentrations regardless of location. Since fumigation impacts can affect concentrations longer than 1 hour, the procedures described in Section 4.5.3 of "Screening Procedures for Estimating the Air Quality Impact of Stationary Sources" (USEPA 1992) were used to determine the 3- and 8-hour average concentrations.

6.7 COMPLIANCE WITH AMBIENT AIR QUALITY STANDARDS

Air dispersion modeling was performed according to the methodology described in above. This was done to evaluate the maximum increase in ground level pollutant concentrations resulting from Project emissions, and to compare the maximum predicted impacts, including background pollutant levels, with applicable short-term and long-term CAAQS and NAAQS. The impacts from construction activities and operations were analyzed separately because they will occur during different time periods. The same 5-year record of hourly meteorological data described in Section 6.3 was used in the AERMOD modeling to evaluate both construction and operational impacts.

In evaluating both construction and operational impacts, AERMOD was used to predict the increases in criteria pollutant concentrations at all receptor locations due to Project emissions only. Next, the maximum modeled incremental increases for each pollutant and averaging time were added to the maximum background concentrations, based on air quality data collected at the most representative monitoring stations during the last 3 years (i.e., 2006 through 2008). These background concentrations are presented and discussed in Section 3.2, Existing Air Quality. The resulting total pollutant concentrations were then compared with the most stringent CAAQS or NAAQS.

As described previously, the emissions used in the AERMOD simulations for the Project operations were selected to ensure that the maximum potential impacts will be addressed for each pollutant and averaging time corresponding to an AAQS. The emissions used for each pollutant and averaging time are explained and quantified in Section 5.1.2.2, Operational Emissions. This subsection describes the maximum predicted operational impacts of the Project for normal combined cycle operating conditions. Commissioning impacts, which will occur on a temporary, one-time basis and will not be representative of normal operations, were addressed separately, as described in the next subsection.

Table 6-3, AERMOD Modeling Results for Project Operations (All Project Sources Combined), summarizes the maximum predicted criteria pollutant concentrations due to Project emissions. The incremental impacts of Project emissions will be below the federal PSD significant impact levels (SILs) for all attainment pollutants, despite the use of worst-case emissions scenarios for all pollutants and averaging times. Although maximum predicted values for PM₁₀ are below the SILs, these thresholds do not apply to this pollutant because the SJVAB is designated non-attainment with respect to the federal ambient standards. No SILs have been established yet for PM_{2.5}.

Table 6-3, AERMOD Modeling Results for Project Operations (All Project Sources Combined), also shows that the modeled impacts due to the Project emissions, in combination with conservative background concentrations, will not cause a violation of any AAQS and will not significantly contribute to the existing violations of the federal and state PM₁₀ and PM_{2.5} standards. In addition, as described later, all of the Project's operational emissions of non-attainment pollutants and their precursors will be offset to ensure a net air quality benefit.

The locations of predicted maximum impacts will vary by pollutant and averaging time. Figure 6-3, Locations of Maximum Predicted Ground Level Pollutant Concentrations for the Operational Project Area, shows the locations of the maximum predicted operational impacts for all pollutants and averaging times. The peak 24-hour PM₁₀ and PM_{2.5} concentrations are predicted to occur on the western boundary of the Project Site, while the peak annual PM₁₀, PM_{2.5}, SO₂, and NO_x concentrations are predicted to occur on the southern boundary of the Project Site. The peak SO₂ 1- and 3-hour concentrations, peak CO 1- and 8-hour concentrations, and peak NO_x 1-hour concentration are predicted to occur within approximately 1.5 miles south of the Project Site.

Carbon monoxide impacts from the carbon dioxide vent were predicted to be 2,934 µg/m³ at a point off of the Project Site and Controlled Area at 778 meters from the source. This value is below the CAAQS for CO and below the 8-hour CO SIL, but above the 1-hour CO SIL. A stability class of D combined with one meter per second wind speed was found to calculate the worst-case results. The 1-hour CO SIL exceedence is not significant because the ensuing AAQS evaluation estimated total estimated CO levels at less than 20 percent of the applicable AAQS and there are no PSD increments for CO.

Hydrogen sulfide impacts from the carbon dioxide vent were predicted to be 35.84 µg/m³ at the maximum impact point off of the Project Site and Controlled Area at 778 meters from the source. This value is below the 1-hour CAAQS of 42 µg/m³.

Table 6-3
AERMOD Modeling Results for Project Operations (All Project Sources Combined)

Pollutant	Averaging Period	2000	2001	2002	2003	2004	Max	Class II Significance Level	% of SIL	Back-ground Conc. ⁵	Monitoring Station Description ⁵	CAAQS	NAAQS	Total Conc.
		(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)		(µg/m ³)		(µg/m ³)	(µg/m ³)	(µg/m ³)
NO ₂ ¹	1-hour (OLM) ^{1,6}	96.84	97.45	100.50	96.28	97.07	100.50	NA	NA	190.1	1	339	NA	291
	Annual (OLM) ¹	0.83	0.87	0.82	0.87	0.79	0.87	1	87%	39.6	1	57	100	40
CO ³	1-hour ⁶	1231.13	1133.15	1422.59	1053.30	1091.04	1422.59	2,000	71%	4025	2	23,000	40000	5448
	8-hour ⁶	213.28	169.18	187.52	181.40	151.98	213.28	500	43%	2444	2	10,000	10000	2657
SO ₂	1-hour ⁶	21.46	16.81	21.45	16.55	19.95	21.46	NA	NA	340.6	3	655	NA	362
	3-hour ⁶	7.84	6.24	7.15	7.31	7.11	7.84	25	31%	195	3	NA	1300	203
	24-hour ⁶	0.62	0.65	0.50	0.66	0.91	0.91	5	18%	81.38	3	105	365	82
	Annual	0.13	0.13	0.13	0.14	0.14	0.14	1	14%	26.7	3	NA	80	27
PM10	24-hour ⁶	2.56	2.39	2.90	2.64	2.58	2.90	5	58%	267.4	4	50	150	-
	Annual	0.53	0.53	0.56	0.58	0.59	0.59	1	59%	56.5	4	20	Revoked	-
PM2.5 ⁴	24-hour ⁶	1.65	1.63	1.74	1.67	2.22	2.22	5	44%	154	5	NA	35	-
	Annual	0.41	0.41	0.43	0.44	0.45	0.45	1	45%	25.2	5	12	15	-
H ₂ S ⁷	1-hour	35.84	35.84	35.84	35.84	35.84	35.84	NA	NA	NA	NA	42	NA	35.84

Source: HECA Project

Notes:

¹ Ozone Limiting Method (OLM) was applied using hourly O₃ data.

³ CO₂ Vent was not included in the AERMOD analysis; it was modeled using DEGADIS/SCREEN3, which predicted maximum impacts of 2,934 µg/m³ for the 1-hour average. The current assumption is that only one gasifier heater is expected to be operational at any time. Aux Boiler does not operate with HRSG at the same time for short-term average period. Therefore, the Aux Boiler was not included in the modeling analysis while HRSG was included because HRSG gives more impact on off-Project Site and Controlled Area concentration.

⁵ Monitoring station for the maximum background concentration is described below:

- 1) CARB, Maximum of last three years (2006-2008), Bakersfield Golden State Highway, 2006; 2) CARB, Maximum of last three years (2006-2008), Bakersfield Golden State Highway, 2007; 3) CARB, Maximum of last three years (2006-2008), Bakersfield Golden State Highway, 2008; 4) CARB, Maximum of last three years (2006-2008), Shafter-Walker Street, 2007; 5) CARB, Maximum of last three years (2006-2008), Fresno – 1st Street, 2007

Table 6-3
AERMOD Modeling Results for Project Operations (All Project Sources Combined)

Pollutant	Averaging Period	2000	2001	2002	2003	2004	Max	Class II Significance Level	% of SIL	Back-ground Conc. ⁵	Monitoring Station Description ⁵	CAAQS	NAAQS	Total Conc.
		(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)	(µg/m ³)		(µg/m ³)		(µg/m ³)	(µg/m ³)	(µg/m ³)

⁶ For short-term (1, 3, 8, and 24-hour) modeling, only one emergency generator will be operational at any one time and the current assumption is that only one gasifier heater is expected to be operational at any one time.

⁷ H₂S was modeled using DEGADIS (its only source is the CO₂ vent). DEGADIS is a screening model that uses worst-case meteorology rather than actual monitored hourly meteorological data.

µg/m³ = micrograms per cubic meter

CAAQS = California Ambient Air Quality Standard

CO = carbon monoxide

H₂S = hydrogen sulfide

NAAQS = National Ambient Air Quality Standard

NO₂ = nitrogen dioxide

OLM = ozone limiting method

PM₁₀ = particulate matter less than 10 microns in diameter

PM_{2.5} = particulate matter less than 2.5 microns in diameter


SO₂ = sulfur dioxide

6.8 COMPLIANCE WITH PSD INCREMENTS

Federal PSD regulations require that proposed major sources, such as HECA, as well as other sources constructed since a specified “baseline date,” not contribute to air pollution in excess of PSD increments in criteria pollutant attainment areas. These PSD increments and significant impact levels are presented in Table 6-2. To implement PSD, attainment areas are divided into Class I and Class II areas. Class I areas, such as formally designated wilderness areas, national parks, and national monuments, are protected by the most stringent (i.e., smallest) PSD increments. In addition, Class I areas are protected by visibility standards (discussed in Section 7.0). All other non-Class I areas within attainment areas are considered to be Class II areas and are protected by the less-stringent Class II PSD increments.


The Project is located within a Class II area. The nearest Class I area is the San Rafael Wilderness, located approximately 50 km from the Project site. PSD is only applicable to those criteria pollutants that are currently in attainment of the NAAQS in Kern County: NO_x , CO, PM_{10} , and SO_2 . Project emissions trigger PSD review for NO_x , CO, and PM_{10} . The PSD requirements are not applicable to those criteria pollutants that are currently in non-attainment.

The Project’s maximum modeled air impacts for CO are $1,422 \mu\text{g}/\text{m}^3$ (1-hour average) and $213 \mu\text{g}/\text{m}^3$ (8-hour average), and the modeled impacts for NO_2 are $0.87 \mu\text{g}/\text{m}^3$. The modeled impacts for PM_{10} are $2.9 \mu\text{g}/\text{m}^3$ (24-hour average) and $0.59 \mu\text{g}/\text{m}^3$ (annual). As shown in Table 6-3, these impacts are well below the respective ambient impact levels. Because the HECA NO_x and PM_{10} impacts will be less than the SILs, increment consumption will be insignificant and no preconstruction monitoring or additional impact analyses are required. There are no PSD increments for CO. The Project’s VOC emissions do not trigger PSD review for VOC.




\\GIS\HECA\Projects\Figures\Fig 5-1-1 Near-field receptors.mxd

Sources: USGS (7.5' quads: Taft 1982, Delano 1982). Created using TOPOI, ©2006 National Geographic Maps, All Rights Reserved. Kern County and State of California (proposed and approved projects).



J:\GIS\HECA\Projects\Figures\Fig 5-2 Far field receptors.mxd

Sources: USGS (30' x 60' quads: Taft 1982, Delano 1982). Created using TOPOI, ©2006 National Geographic Maps, All Rights Reserved. Kern County and State of California (proposed and approved projects).



\\GIS\HECA\Projects\Figures\Fig 5-3 pollutants.mxd

Sources: USGS (7.5' quads: Taft 1982, Delano 1982). Created using TOPOI, ©2006 National Geographic Maps, All Rights Reserved. Kern County and State of California (proposed and approved projects).

7.1 AIR QUALITY RELATED VALUES

7.1.1 Class I Areas

Specific national parks, wilderness areas, and national monuments are designated as Class I areas and are protected by the most stringent PSD requirements. A Major Source must evaluate impacts to visibility and other AQRV at all Class I areas that are located within a 100-km radius of the Project Site. All pollutants for which Project emissions are above the Major Source threshold (in this case, 100 tons per year [tpy]) and all pollutants for which emissions are above the PSD Significant Emissions Rates must be evaluated.

An evaluation of potential impacts in Class I areas within 62.1 miles (100 km) of the Project Site was conducted, because the Project's potential emissions increases of some pollutants are large enough to be considered a Major Source, thus triggering the federal PSD program. This section summarizes the dispersion models and modeling techniques that were used in performing the Class I area air quality analyses. A complete description of the modeling performed in support of the impacts to Class I areas is contained in Appendix E. The objectives of the modeling are to demonstrate whether air emissions from the Project will cause or contribute to a PSD increment exceedance or cause a significant impact on visibility, regional haze or sulfur, or nitrogen deposition in any Class I area.

Three Class I areas are located within the region of the Project Site: Dome Land Wilderness Area, Sequoia National Park, and San Rafael Wilderness Area. However, Dome Land Wilderness Area and Sequoia National Park are greater than 62.1 miles (100 km) from the Project Site. Therefore, these two Class I areas do not meet the criterion of being within 62.1 miles (100 km) and will not be included in this analysis. The nearest parts of the San Rafael Wilderness are located beyond 31.1 miles (50 km) and within 62.1 miles (100 km) from the Project Site, thus, only this Class I area and only far-field AQRV analyses were completed. PSD increment analysis for the San Rafael Wilderness Class I area are shown in Table 7-1, PSD Class I Increment Significance Analysis – CALPUFF Results. No Class I PSD increments will be exceeded.

Table 7-1
PSD Class I Increment Significance Analysis – CALPUFF Results

Class I Area	Pollutant	Annual NO _x	3-hour SO ₂	24-hour SO ₂	Annual SO ₂	24-hour Particulate Matter	Annual Particulate Matter
	Unit	µg/m ³	µg/m ³	µg/m ³	µg/m ³	µg/m ³	Annual
	Threshold	0.1	1	0.2	0.08	0.32	0.16
San Rafael Wilderness Area	2001	3.98E-03	2.37E-01	1.17E-02	8.23E-04	7.72E-02	4.38E-03
	2002	4.58E-03	2.70E-01	1.75E-02	9.99E-04	7.97E-02	5.20E-03
	2003	4.60E-03	3.13E-01	1.81E-02	9.97E-04	7.43E-02	5.12E-03
Exceed?		No	No	No	No	No	No

Source: HECA Project

µg/m³ = micrograms per cubic meter

NO_x = nitrogen oxides

SO₂ = sulfur dioxide

Effects on Visibility. The Clean Air Act (CAA) established the importance of visibility for Class I areas by declaring a goal to prevent future visibility impairment and remedy existing visibility impairment due to man-made air pollution. The CAA also specifically requires that visibility be addressed as an AQRV within all Class I areas. However, visibility is not uniformly affected by air pollution. Visibility varies on a site-by-site basis and is affected by meteorology, topography, the relative position of the viewer and the sun, and other variables. In addition, the assessment of visibility depends on subjective human perceptions. As a result, it is often difficult to assess the condition of the visibility AQRV.

This analysis was conducted using the CALPUFF model. Applicable recommendations from the CALPUFF Reviewer's Guide (Draft) of September 2005 prepared for the National Park Service (NPS) and the USFS were implemented in the screening version of CALPUFF AQRV modeling.

Using weather from a 3-year meteorological data set developed using a combination of surface station and mesoscale meteorological (MM5) data for 2001-2003 in CALPUFF resulted in no days per year with 5 percent extinction change. Visibility impact results for the San Rafael Wilderness Class I area are shown in Table 7-2, Visibility Analysis – CALPUFF Results. No maximum extinction change exceeds 5 percent. Therefore, the Project screening successfully passed all screening criteria.

Table 7-2
Visibility Analysis – CALPUFF Results

Class I Area	Pollutant	No. of Days > 5%	Maximum Extinction Change	Day of Maximum Extinction Change
	Unit	Days	%	Day
	Threshold	0	5	
San Rafael Wilderness Area	2001	0	4.42	308
	2002	0	4.72	287
	2003	0	3.68	247
Exceed?		No	No	No

Source: HECA Project

Terrestrial Resources. Maximum modeled annual NO₂ and SO₂ impacts from normal plant operations, as well as estimates of total nitrogen and sulfur deposition estimated by CALPUFF, were compared against Deposition Analysis Threshold (DAT) for individual sources established by the NPS for vegetation and ecosystems for Class I Wilderness Areas. Table 7-3, Total Nitrogen and Sulfur Deposition Analysis – CALPUFF Results, summarizes the maximum modeled impacts versus the NPS and the USFS significance criteria. All impacts are below the significance criteria.

Table 7-3
Total Nitrogen and Sulfur Deposition Analysis – CALPUFF Results

Class I Area	Pollutant	Deposition Nitrogen	Deposition Sulfur
	Unit	g/m ² /s	g/m ² /s
	Threshold	1.59E-11	1.59E-11
San Rafael Wilderness Area	2001	1.06E-12	4.41E-13
	2002	1.40E-12	6.00E-13
	2003	1.34E-12	5.23E-13
Exceed?		No	No

Source: HECA Project

Notes:

g/m²/s = grams per square meter per second.

Aquatic Resources. A significant effect of NO_x and SO₂ emissions on aquatic resources is nitrogen and sulfur deposition and subsequent acidification. However, because any increased nitrogen and sulfur deposition due to the Project will be minimal, impacts to water acid neutralizing capacity (ANC) and pH, and, therefore, acidification or eutrophication, are not likely to occur.

7.1.2 Class II Areas

The PSD regulations (40 CFR 52 §52.21(o)) require an Additional Impact Analysis for all PSD major modifications for Class II areas. The additional impact analysis is an evaluation of the following:

- the visibility impact for the surrounding area that results from the general growth associated with the modification.
- visible plumes
- the impairment to visibility, soils, and vegetation that would result from the modification; and

The Project complies with the requirements of 40 CFR 52.21. The Project should not result in any significant commercial, residential, or industrial growth within Kern County. Additionally, the Project should not cause any impairment to the visibility, soils, or vegetation within the surrounding area of Kern County.

7.1.2.1 Surrounding Area Visibility Analysis

A visibility analysis was performed for the area that surrounds the Project Site. Since little or no growth (i.e., municipal, residential, commercial and industrial) is expected from the Project, the visibility assessment focused on the significant emission increases from the Project. EPA's VISCREEN model (Version 1.01) was used to conduct the analysis. The approach is expected to provide a conservative estimate of the Project's impact on visibility in the surrounding Class II area.

The VISCREEN model is designed to ascertain whether the plume from a facility has the potential to be perceptible to an untrained observer under “reasonable worst-case” conditions. The model measures the change in perceptibility of a plume due to an increase in emissions as a function of contrast and color changes at different values of the scattering angle (angle between direct solar radiation and the line of sight). The green contrast value (C_p) was developed as a measure of the perceived reduction in contrast. The color difference parameter (ΔE) was developed to specify the perceived magnitude of brightness and color changes due to a plume.

The VISCREEN model performs four tests that are based upon the Tier I screening criteria for ΔE and C_p (2.0 and 0.05, respectively). The first two tests refer to visual impacts caused by plume parcels located inside the boundaries of a given area. The last two tests refer to visual impacts caused by plume parcels located outside the boundaries of a given area. For internal and external visibility assessments, the two tests assess the perceptibility of the plume in relation to two plume-viewing backgrounds (i.e., the horizon sky and a black terrain object). When the potential for impacts in Tier I analysis is greater than the screening criteria, a Tier II screening procedure should be conducted, as described in the *Plume Visual Impact Screening Workbook* (EPA, 1988 and 1992).

The VISCREEN analysis incorporated a Nitrogen Oxides (NO_x) emission rate of 16.6072 g/s and a Particulate Matter (PM_{10}) emission rate of 4.7538 g/s. The NO_x and PM_{10} emission rate represents the post-Project, 24-hour PTE for all emission sources that are affected by the Project. A target background visual range distance of 25 km was used for the area surrounding the HECA facility (EPA, 1992). The distance between the Project and observer in the VISCREEN model was set equal to 25 km. The default background ozone concentration of 0.04 ppm was used.

Reasonable worst-case conditions are based upon meteorological data and observer distance. The Tier I screening approach uses worst-case meteorological conditions (i.e., extremely stable (stability category F) atmospheric conditions, low wind speed (1 m/sec) persisting for 12 hours, and wind direction that would transport the plume directly adjacent to the observer.

The Tier II analysis refined the default wind speed and stability category with site-specific information from the Bakersfield Regional Airport meteorological station (NWS 23840). This data set was first analyzed to determine the frequency of various combinations of wind speed and stability in all wind direction sectors that would carry the HECA facility plume toward nearby Class II areas located at 25 km from the HECA site. The frequency distributions were developed separately for four diurnal time periods (midnight-6:00 am, 6:00 am-noon, noon-6:00 pm, and 6:00 pm-midnight). For each time period, five wind speed categories corresponding to 0-1 meters per second (m/s), 1-2 m/s, 2-3 m/s, 3-4 m/s, and 4-5 m/s were analyzed for each of six stability classes (Class A-most unstable through Class F-most stable, Class G is considered as Class F) and wind direction compass sector toward the Class I area from the Project Site. For each time of day, 14 wind speed/stability combinations were ranked in order of increasing values of the dispersion parameter, $\sigma_z u$ as described above. The combinations include F stability for wind speed classes 1 through 4, E stability with wind speed classes 1 through 5, and D stability with wind speed classes 1 through 5, as per the Tier II guidance. Note that the lowest values of this parameter correspond to the most restrictive dispersion conditions. Finally, a table was constructed showing the percent frequency of occurrence for each combination of stability and wind speed or, alternatively for each value of $\sigma_z u$. These data are tabulated in terms of the

frequency of each combination, as well as the cumulative frequency of all combinations with lower values of σ_z u.

The meteorological condition for 25 km distant-Class II area with a cumulative frequency of 1 or greater, and with a wind speed fast enough to transport the plume to the given Class II area within 12 hours was selected. Based upon 2000-2004 meteorological data, the wind speed and stability class when the sum of all frequencies of occurrence of conditions worse than the conditions totals 1 percent is 1.5 m/s and the stability category was F. Table 7-4 presents the results of the Tier II screening analysis for the Project. The Delta E values were below the default screening threshold values. Therefore, visibility impacts caused by emissions from the Project will not be perceptible to most individuals in the area surrounding the Project.

Table 7-4
Class II Surrounding Area Level II VISCREEN Results

Maximum Visual Impacts INSIDE Area Screening Criteria ARE NOT Exceeded					
Background	Theta	Delta E		Contrast	
		Plume	Critical Value	Plume	Critical Value
SKY	10	1.306	2.00	0.003	0.05
SKY	140	0.427	2.00	-0.008	0.05
TERRAIN	10	0.514	2.00	0.007	0.05
TERRAIN	140	0.111	2.00	0.005	0.05
Maximum Visual Impacts OUTSIDE Area Screening Criteria ARE NOT Exceeded					
Background	Theta	Delta E		Contrast	
		Plume	Critical Value	Plume	Critical Value
SKY	10	1.359	2.00	0.004	0.05
SKY	140	0.429	2.00	-0.008	0.05
TERRAIN	10	0.857	2.00	0.009	0.05
TERRAIN	140	0.241	2.00	0.009	0.05

7.1.2.2 Visible Plumes

Modern combined cycle power plants burning natural gas fuel emit particulate matter at levels far below the concentration corresponding to visible smoke. Combustion sources also emit water vapor that sometimes may condense in the atmosphere to form visible plumes.

The potential exists for vapor plumes (water vapor condensation) to be visible from two sources at the Project Site: (1) plumes from the 50-foot-high wet cooling towers (4-celled ASU cooling tower and 17-celled Power Block/Gasification cooling towers); and (2) plumes from the 213-foot-high CTG/HRSG stack. Both sources of condensed water vapor plumes were analyzed. The following analysis describes the plume modeling methodology, input data, and assumptions used in the analysis, as well as the results.

Methodology

The frequency, persistence, and size of visible condensate plumes depends primarily on the design and type of combustion turbine generator/HRSG and/or cooling tower, as well as meteorological conditions of temperature and humidity. Specifically, visible plume formation depends on local ambient temperature, humidity conditions, and wind patterns. A location with higher temperature and lower humidity (i.e., general climate in Kern County) would have fewer extended visible plumes compared to operation of the same project at a cooler, more humid location. Visible plume formation is more frequent during the cooler seasons (i.e., winter) when ambient conditions are more conducive to plume formation. Results focused on seasonal daylight clear hours and winter day-time no fog hours. For the purposes of this analysis, **Seasonal Daylight Clear Hours** are defined as: daylight hours from November through April without naturally occurring fog, rain, or limited visibility and include all hours of clear skies and 50 percent of the scattered or broken skies. **Winter Day-Time No Fog Hours** are defined as winter days without any naturally occurring fog. It should be noted that the same ambient conditions that result in plume formation from Project cooling towers will often cause natural weather conditions such as fog, haze, and precipitation to occur, which generally reduces visibility. Days when fog, haze or precipitation is present were excluded from plume frequency calculations for this analysis.

The characteristics of visible plumes important to an assessment of visual impacts include plume length (the distance over which a plume remains intact), plume height (the distance from ground to the centerline of the plume), plume width (the horizontal cross wind spread of the plume) and plume depth (the cross plume spread perpendicular to the width, typically in the vertical direction).

Plumes from the wet cooling towers were modeled using the Seasonal/Annual Cooling Tower Impact (SACTI) model. SACTI is a mathematical model used to predict cooling tower visible plume dimensions over a full range of meteorological conditions experienced at a given location and the frequency of different plume lengths, widths, and heights as a function of direction from the cooling tower. The model is designed to provide predictions and may be used for the licensing of power plants with cooling towers. SACTI model results are summarized in terms of typical and reasonable worst-case visible plume dimensions for the entire year, and during daytime and nighttime hours. For purposes of this analysis, the “typical” plume dimension (height, width, length) is the one that is exceeded 50 percent of the time, and the “reasonable worst-case” is the condition that is exceeded only 10 percent of the time. A description of this model, model data inputs, and model results may be found in Appendix C, Modeling Protocol.

Plumes from the HRSG stack were analyzed using the Combustion Source Visible Plume (CSVP) model. The CSVP model determines visible water vapor plume frequency. The model consists of a series of programs, which ultimately calculate the distance downwind the visible plume can extend, the plume height and width. The model requires ambient temperature, relative humidity, precipitation, wind direction, wind speed and stability per hour of input data. The model was originally created to determine plume size for HRSGs. The first module of the program, CSVP, determines if the plume will reach saturation, and the second module, PLUMEWV, determines plume size by modeling the plume until the centerline of the plume crosses the second intersection point on the saturation curve. Parameters used in the model included the fixed HRSG stack height and diameter at 213 feet and 20 feet respectively. A

description of this model, model data inputs, and model results may be found in Appendix C, Modeling Protocol.

Model Results

As stated above, visible plume formation is more frequent during the cooler seasons (i.e., winter) when ambient conditions are more favorable to plume formation. Therefore, Table 7-5, displays the dimensions of the “reasonable worst-case” plumes from both the Power Block/Gasification and ASU cooling towers predicted to be visible during clear winter day-time hours, when the plumes will be most noticeable. In addition, the dimensions of the typical (or average) daytime plumes from Project cooling towers are also provided in the table below. Typical plumes generated from Project cooling towers were predicted to be much smaller in length, height and width than the worst-case plumes. Visible plumes that extend beyond the cooling tower buildings are predicted to occur approximately 15 to 22% of the winter day-time no fog hours.

Table 7-5
SACTI Cooling Tower Plume Predictions
Winter Day-Time No Fog Hours (Mass Flow Rate = 11554.9 kg/s)

	Power Block/ Gasification Cooling Tower	ASU Cooling Tower
Length (m)		
50% (Typical)	30m – 40m	30m – 40m
10% (Reasonable Worst-case)	600m – 700m	200m – 250m
Height (m)		
50% (Typical)	20m - 30m	20m – 30m
10% (Reasonable Worst-case)	300m – 310m	90m – 100m
Width (m)		
50% (Typical)	30m – 40m	20m – 30m
10% (Reasonable Worst-case)	130m – 140m	60m – 70m
% of hours Visible Plume Extends Beyond Cooling Tower Building (greater than 30 meters from center)	15.53%	21.64%

Source: SACTI Model Output (provided in Appendix C, Modeling Protocol)

Notes:

m = meters

Winter Day-Time No Fog Hours = Clear winter days, when a cold, high humidity conditions conducive to plume formation exists.

Similar to the results of the SACTI model, the results presented in Table 7-6, provided below, represents the reasonable worst-case (the 10% longest plume), and the typical plume expected (the 50% longest plume). The results depict only the hours that the plumes are visible in seasonal daylight clear conditions.

The reasonable worst-case visible plume predicted by the CSVP model has a plume height of 271.4 meters (890 feet); however, the average height of the visible plume was predicted to be 152.8 meters (501 feet) during seasonal daylight clear hours. Visible plumes are predicted to occur approximately 78% of the seasonal daylight clear hours; however are predicted to occur only 40% of all hours modeled.

Table 7-6
CSVP HRSG Stack Plume Characteristics During Seasonal Daylight
Clear Hours

	Plume Length (m)	Plume Height (m)	Plume Width (m)	Plume Depth (m)
Reasonable Worst Case (10%)	716	271.4	84.9	75.6
Typical Case (50%)	197	152.8	34.5	39.1

Source: CSVP Model Output (provided in Appendix C, Modeling Protocol)

Notes:

m = meters

Seasonal Daylight Clear Hours = daylight hours from November through April without rain, fog, or limited visibility that include clear skies and 50 percent of the scattered or broken skies excluding overcast skies.

Impact Analysis

Plumes generated from Project operations would be visible from residences and travelers within the VSOI. When plumes are formed over the Project Site they will be above and extend downwind of the Project structures.

The reasonable worst-case winter day-time no fog cooling tower plume height starts above the 50 foot (15.2m) Power Block/Gasification and ASU cooling towers and can reach an ultimate height of approximately 1,017 feet (310m) and 328 feet (100m), respectively. However, this worst case scenario is predicted to occur during just 10 percent of the winter day-time no fog hours in the 5 years modeled. Visible plumes lengths are not expected to extend beyond the Power Block/Gasification and ASU cooling towers structures more than 15.5 percent and 21.6 percent during all modeled winter day-time no fog hours.

The reasonable worst-case seasonal daylight clear HRSG plume height starts above the 213 foot (65m) HRSG stack and can reach an ultimate height of approximately 890 feet (271.4m) and is visible for approximately 764 feet (233m) downwind of the stack. However, this scenario is predicted to occur for only 15-25 percent of the seasonal daylight clear hours in the 5 years modeled. The model predicts some type of visible plume from the HRSG stack for 40% of all modeled hours (day, night, and all weather and sky conditions).

Plumes are expected to be visually subordinate from distant viewpoints, and subordinate to co-dominant from middleground to foreground viewpoints, depending upon specific viewing locations and conditions. Currently there are few to no visible plumes within the existing viewshed. Although the addition of plumes to the Project Area would create a change to existing conditions, most viewers will be at such distances that impacts from visible plumes are considered to be less than significant. The area of highest concern for visible plumes is for the nearest resident within the VSOI, represented by KOP #2.

For KOP #2, reasonable worst case visible plumes generated from Project operations would create a co-dominant effect related to the Project structures. However, typical plumes generated from Project operations were predicted to be much smaller in length, height and width than the reasonable worst-case plumes, and the typical plumes are what KOP #2 and other viewers within the VSOI would see more often.

Project operations would largely be in peak operation during the summer months (outside of the November to April seasonal hours), at which time the temperature at the Project Site is generally too high for long plumes to occur. Both size and frequency of typical Project cooling tower and HRSG plumes (occurring outside of the winter/no fog and seasonal daylight clear period) are expected to be visually subordinate and would be less than significant. Project cooling tower and HRSG plumes during the reasonable worst case (within the winter/no fog and seasonal daylight clear period) conditions would be visually co-dominant to dominant, however plumes of this size would occur for less than 10 percent of the winter/no fog and seasonal daylight clear period and were thus considered to be less than significant. As plume formation depends upon highly variable atmospheric conditions, peak operation of HECA would be during hot, summer months not conducive to plume formation, and the proximity of most viewers would be at such distances that any potential plumes would be remotely visible, less than significant impacts related to plume generation at the Project Site are anticipated.

Nighttime plumes could present a potential visual impact under two possible circumstances. If bright upwardly directed night lighting were to illuminate the plumes, they could become visually dominant and obtrusive. However, no such light exists in the Project vicinity and on-site lighting would be shielded and directed downward. Thus, no significant impacts from illuminated plumes are anticipated.

7.1.2.3 Soils and Vegetation Analyses

The soil type in the area of the HECA is dominantly Lokern-Buttonwillow, and the soil types of in the surrounding area of the HECA are Cajon-Westhaven, Elkhills, Garces-Panoche, Kimberlina-Wasco, and Milham. These soils are characterized as follows:

- Lokern-Buttonwillow is a deep, nearly level, somewhat poorly drained clay. This unit is used for native and irrigated pasture, irrigated crops, wildlife habitat, and some urban development. The saline-alkali condition of the soils, restricted permeability, and fine texture are the main limitations.
- Cajon-Westhaven is a deep, nearly level and gently sloping, well drained and somewhat excessively drained loamy sand and fine sandy loam. This unit is mainly used for irrigated crops. Low available water capacity and a hazard of soil blowing are the main limitation.
- Elkhills is a deep, rolling to steep, well drained soils that formed in mixed, stratified alluvium. Most areas of this unit are used as rangeland. Oil wells are common on the unit. Steepness of slope and a hazard of erosion are the main limitations.
- Garces-Panoche is a deep, nearly level, saline-alkali, well drained silt loam and clay loam. This unit is mainly used for irrigated crops and pasture. The saline-alkali condition of the soils and very slow permeability are the main limitations.
- Kimberlina-Wasco is deep, nearly level, well drained fine sandy loam and sandy loam. This unit is mainly used for irrigated crops.
- Milham is deep, nearly level, well drained sandy loam. This unit is mainly used for irrigated crops (USDA, 2009)

In general, soils are mainly affected through the leaching of particulate contaminants and through the removal of gases by precipitation followed by surface deposition. The adsorption rate is dependent on the distance from the source, the concentration of pollutant, soil properties, hydrological situations, and meteorological conditions. The dominant area soil types noted above are expected to exhibit a relatively low sorption capacity, as demonstrated by generally slow permeability, for the PSD significant emission rate increases in CO, NO_x, PM₁₀, SO₂, and VOC emissions associated with the Project. Also, the PSD modeling concentration results are below the NAAQS (since the concentration is compliance with the significance level); that are designed to protect health and welfare from any known or anticipated adverse pollutant impacts. Therefore, the soils in the area of the Project should not be adversely affected as a result of the Project.

The predominate food crops grown in the Kern County are wheat, corn, barley, cotton, and beans. Predicted average acreage yields are 96.5 bushels per acre of wheat; 182 bushel per acre of corn; 1,540 pounds per acre of cotton; and 2,552 pounds per acre of beans (USDA, 2009).

The direct effects of NO_x on vegetation are usually associated with and confined to areas near specific industrial sources. For example, vegetation injury from exposure to NO₂ has been observed near nitric acid factories and arsenals, but there is little published information regarding vegetation injury in the field due to NO or other NO_x (U.S. EPA, 1982).

Many reports, however, have substantiated NO_x effects on vegetation grown in laboratory conditions. In vivo experiments performed by Hill and Bennet (1970) showed that both NO and NO₂ inhibit apparent photosynthesis of oat (*Avena sativa*) and alfalfa (*Medicago sativa*) plants at concentrations below those that caused visible foliar injury. They found the threshold does for this inhibition was 740 µg/m³ for NO and 1130 µg/m³ for NO₂ in 90-minute fumigations. Other researchers have found a reduction in the photosynthetic rate of tomato (*Lycopersicon esculentum*) exposed to 470 µg/m³ NO₂ and 310 µg/m³ NO. The effect of the two gases in combination had an additive inhibitive effect on photosynthesis.

Czeh and Nothdruff (1951) fumigated a wide range of agricultural and horticultural crops with NO₂ in the laboratory and small greenhouses. Rape (*Brassica rapus*), wheat (*Triticum aestivum*), oats (*Avena sativa*), peas (*Pisum sp.*), potatoes (*Solanum tuberosum*), and beans (*Phaseolus vulgaris*) showed little or no injury from 564 µg/m³ NO₂ for one hour of exposure. Taylor and Cardiff (cited in Taylor et al., 1975) exposed field crop to NO₂ in sunlight chambers. Several field crops exposed to 18,880 µg/m³ NO₂ for 90 minutes showed little or no injury, but in tomato, a 90-minute exposure to 28,200 µg/m³ increased the extent of injury by 90 percent. The authors concluded that the injury threshold for several field crops would be 18,800 to 28,200 µg/m³ NO₂ for 90-minute exposures.

The effect of NO_x on several eastern forest tree species has been documented by Kress (1982). Two of the seven tree species he exposed, Virginia pine (*Pinus virginiana*) and Loblolly pine (*Pinus taeda*), exhibited significant height growth effects in response to NO₂ administered at 191 µg/m³.

A threshold value of 191 µg/m³ for long-term (10,000-hour) laboratory exposures of crops and trees has been widely used (U.S. EPA, 1982). The maximum modeled concentration from the Project is compliance with the National Ambient Air Quality Standard (NAAQS) (since the

concentration is compliance with the significance level); therefore, no detrimental effects on vegetation in the Project area will likely result from NO_x emissions from the Project.

There are very few data on the effects of S compounds on mature trees or other native plants (USDA, 1992). Data on tree seedlings (Hogsett and others 1989, cited in USDA, 1992) indicated that SO₂ concentrations below 20 ppb (52.29 µg/m³) (24-hour mean) do not produce visible injury symptoms. According to *Guidelines for evaluation air pollution impacts on Class I wilderness areas in California* (USDA, 1992), maximum SO₂ concentrations should not exceed 40-50 ppb (104.6 µg/m³– 130.7 µg/m³) (24-hour mean), and annual average SO₂ concentration should not exceed 8-12 ppb (20.9 µg/m³– 31.4 µg/m³) in order to maximize protection of all plant species. The SO₂ PSD modeling concentration results are below the NAAQS (since the concentration is compliance with the significance level); that are designed to protect health and welfare from any known or anticipated adverse pollutant impacts. Therefore, the vegetation in the surrounding area should not be adversely affected by the SO₂ emission increase occurring with the Project.

Particulate matter less than 10 microns (PM₁₀) emissions are not harmful to vegetation unless the emissions are either highly caustic or the emission rate is great enough for heavy particulate deposits to occur. The PM₁₀ emissions from the Project are neither classified as caustic nor will the increase due to the Project exceed the PM₁₀ significance modeling thresholds. Thus, the PM₁₀ emissions are not considered a dangerous threat to the local vegetation.

Little is known regarding the effects of CO on vegetation, but some response may occur at levels approaching 1000 ppm (1.15 x 10⁶ µg/m³) for a week or more. The maximum 1-hour CO concentration resulting from the Project is predicted to be well below this level; therefore, no significant impact on local vegetation from the CO emission increase is expected.

7.1.2.4 Growth Induced Impacts

There are no changes to the land uses or zoning designations surrounding the area of the Project Site. The existing character of the immediate area surrounding the Project Site will remain unchanged by the development of the Project. Construction of the Project would require approximately 1,500 employees. The Project will require 100 full-time employees working at the power plant during operation. It is anticipated that approximately 60 percent of operations employees will originate from the Kern County labor force. The remaining employees will originate from outside Kern County. Of the 40 percent non-local workers (40 workers), it is assumed for the purposes of this analysis that half (20 employees) will relocate to Kern County. The other half (20 employees) will commute on a daily or weekly basis. The Project's impacts with regard to land use planning and public policy will be minimal. The use of the 315-acre Project Site will change from mineral and petroleum defined land uses to power generation. No prime farmlands will be converted to non-agricultural use.

- Auer, August H., Jr. 1978. American Meteorological Society. *Journal of Applied Meteorology*, 17(5): 636-643. "Correlation of Land Use and Cover with Meteorological Anomalies," May 1978.
- Capron, T.M., and T.A. Mansfield, 1976. "Inhibition of net photosynthesis in tomato in air polluted with NO and NO₂." *J. Exp. Bot.* 27: 1181-1186.
- CARB (California Air Resources Board), 2000. *Risk Management Guidance for the Permitting of New Stationary Source Diesel-Fueled Engines*, October 2000.
- CARB (California Air Resources Board), 2007. *Off-Road Mobile Source Emission Factors*, Off-Road Emissions Inventory Program.
- CARB (California Air Resources Board). 2009. Top 4 Air Quality Data Summaries, <http://www.arb.ca.gov/adam/cgi-bin/db2www/adamtop4b.d2w/start>. Accessed April 1, 2009.
- CCAR (California Climate Action Registry). 2009. California Climate Action Registry General Reporting Protocol, ver. 3.1. January 2009.
- CEC (California Energy Commission). 1997. "Regulations Pertaining to the Rules of Practice and Procedure and Plant Site Certification." Title 20, California Code of Regulations. Chapters 1, 2, and 5.
- CEC (California Energy Commission). 2006. Rules of Practice and Procedure and Power Plant Site Certification Regulations Revisions, 04-SIT-2, December 14, 2006.
- Czeh, M., and W. Nothdruff, 1951. "Investigations of the damage to field and horticultural crops by chlorine, nitrous and sulfur dioxide gases." *Landwirtsch Forsch.* 4: 1-36.
- Darley, E.F., 1966. "Studies on the effect of cement-kiln dust on vegetation." *J. Air Pollut. Control Assoc.* 16: 145-150.
- Hill, A.C., and J.H. Bennett, 1970. "Inhibition of apparent photosynthesis by nitrogen oxides." *Atmos. Environ.* 4: 341-348.
- Kress, L.W., 1982. "Response of several eastern forest tree species to chronic doses of ozone and nitrogen dioxide." *Plant Dis.* 66: 1149-1152.
- MRI (Midwest Research Institute). 1996. Improvement of Specific Emission Factors (BACM Project No. 1), Final Report. Prepared by Midwest Research Institute for South Coast AQMD.SCAQMD (South Coast Air Quality Management District). 1993. *CEQA Air Quality Handbook*. April 1993.
- Taylor, O.C., C.R. Thompson, O.T. Tingey, and R.A. Reinert, 1975. "Oxides of nitrogen." In: *Responses of Plants to Air Pollution*. J.B. Mudd and T.T. Kozlowski, eds. Academic Press, Inc., New York, NY. pp. 121-139.
- U.S. Census Bureau, 2009. 'Population Finder- Kern County, California', Online at: <http://www.census.gov/>.
- U.S. Department of Agriculture, 2009. 'USDA National Agricultural Statistics Service – California County Data', Online at: http://www.nass.usda.gov/Statistics_by_State/California/index.asp.

- U.S. Department of Agriculture, 2009. "Soil Survey of Kern County, California. Northwestern Part" Soil Conservation Service.
- U.S. Environmental Protection Agency, October 1992. "Workbook for Plume Visual Impact Screening and Analysis." EPA-450/R-92-023.
- U.S. Environmental Protection Agency, September 1982. *Air Quality Criteria for Oxides of Nitrogen*. U.S. EPA Publication No. EPA 600/8-82-026.
- URS Corporation. 2009. Air Quality Modeling Protocol for the Hydrogen Energy California (HECA) Project, Kern County. Prepared by URS for San Joaquin Valley Air Pollution Control District, California Energy Commission, U.S. Environmental Protection Agency Region IX and National Park Service.
- USEPA (U.S. Environmental Protection Agency). 2009. AIRS Air Quality Monitoring Data Reports, www.epa.gov/air/data/index.html, accessed April 1, 2009.
- USEPA (U.S. Environmental Protection Agency), 1985. *Guideline for Determination of Good Engineering Stack Height (Technical Support Document for the Stack Height Regulation)* (Revised), EPA-450/4-80-023R. Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina. June 1985.
- USEPA (U.S. Environmental Protection Agency). 1990. *New Source Review Workshop Manual Prevention of Significant Deterioration and Nonattainment Area Permitting* (Draft), Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711. October 1990.
- USEPA (U.S. Environmental Protection Agency). 1992. *Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised*. EPA-454/R-92-019. October 1992.
- USEPA (U.S. Environmental Protection Agency). 1995a. *Building Profile Input Program-Prime*. Version 98086.
- USEPA (U.S. Environmental Protection Agency). 2003. *Guideline on Air Quality Models*.
- USEPA (U.S. Environmental Protection Agency). 2004. *AERMOD Implementation Guide*.
- USEPA (U.S. Environmental Protection Agency). 2005. *Average Carbon Dioxide Emissions Resulting from Gasoline and Diesel Fuel*. EPA 420-F-05-001. February.
- USEPA (U.S. Environmental Protection Agency). 2006. Addendum to User's Guide for the AMS/EPA Regulatory Model-AERMOD. December 2006.
- Western Regional Climate Center. 2008. Desert Research Institute, Las Vegas, NV. (<http://www.wrcc.dri.edu/>).
- Western Regional Climate Center. 2009. Buttonwillow, CA, <http://www.wrcc.dri.edu/cgi-bin/cliMAIN.pl?ca1244>, accessed February 2009.

Appendix A

BACT Analysis

APPENDIX A
BEST AVAILABLE CONTROL
TECHNOLOGY (BACT) SECTION
HECA POWER PROJECT
KERN COUNTY, CALIFORNIA

Prepared For:

San Joaquin Valley Air Pollution Control District
California Energy Commission
U.S. Environmental Protection Agency Region IX

Prepared on behalf of

Hydrogen Energy International LLC

June 2009

URS

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Table of Contents

1.0	Applicable Regulations.....	A-1
2.0	BACT Review Process	A-2
3.0	Project Sources Subject to BACT Analysis.....	A-4
4.0	Consideration of Alternative Generating Technology.....	A-6
5.0	Other Permitted IGCC Projects	A-7
6.0	Source-Specific BACT Analysis	A-8
6.1	CTG/HRSG BACT Analysis	A-9
6.1.1	Nitrogen Oxides BACT Analysis for the CTG/HRSG	A-9
6.1.2	Carbon Monoxide BACT Analysis for the CTG/HRSG	A-15
6.1.3	Particulate Matter Emissions BACT Analysis for the CTG/HRSG	A-18
6.1.4	Sulfur Dioxide and Sulfuric Acid Mist BACT Analysis for the CTG/HRSG.....	A-20
6.1.5	Volatile Organic Compounds BACT Analysis for the CTG/HRSG	A-24
6.2	Auxiliary CTG BACT Analysis.....	A-27
6.2.1	Nitrogen Oxides BACT Analysis for the Auxiliary CTG	A-27
6.2.2	Carbon Monoxide BACT Analysis for the Auxiliary CTG.....	A-27
6.2.3	Particulate Emissions BACT Analysis for the Auxiliary CTG	A-27
6.2.4	Sulfur Oxides BACT Analysis for the Auxiliary CTG.....	A-28
6.2.5	Volatile Organic Compounds BACT Analysis for the Auxiliary CTG.....	A-28
6.3	Cooling Towers Particulate Emissions BACT Analysis	A-28
6.4	Auxiliary Boiler BACT Analysis.....	A-30
6.4.1	Nitrogen Oxides BACT Analysis for the Auxiliary Boiler	A-31
6.4.2	Carbon Monoxide BACT Analysis for the Auxiliary Boiler.....	A-32
6.4.3	Particulate Emissions, Sulfur Oxides, Volatile Organic Compounds BACT Analysis for the Auxiliary Boiler	A-33
6.5	Diesel Engines BACT Analysis.....	A-33
6.5.1	BACT Analysis for the Standby Diesel Generators	A-34
6.5.2	BACT Analysis for the Firewater Pump Diesel Engine	A-35
6.6	Gasification Flare BACT Analysis	A-35
6.7	Sulfur Recovery System BACT Analysis.....	A-37
6.8	CO ₂ Vent BACT Analysis	A-40
6.9	Gasifier Warming (Refractory Heaters) BACT Analysis.....	A-42
6.10	Feedstock Handling System BACT Analysis.....	A-42
6.10.1	Particulate Matter BACT Analysis for the Feedstock-Handling System.....	A-43
7.0	Reference	A-43

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

List of Tables

Table 3-1	Proposed BACT for Project
Table 6-1	Permitted Criteria Pollutant BACT Limits for Combined Cycle-Combustion Turbine
Table 6-2	NO _x BACT Emission Limit Comparison
Table 6-3	CO BACT Emission Limit Comparison
Table 6-4	PM BACT Emission Limit Comparison
Table 6-5	SO ₂ BACT Emission Limit Comparison
Table 6-6	VOC BACT Emission Limit Comparison
Table 6-7	Gasification Flare Total Criteria Pollutant Emissions
Table 6-8	Sulfur Recovery System Emissions
Table 6-9	Gasifier Warming (Refractory Heater) Emissions

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

1.0 APPLICABLE REGULATIONS

Federal requirements pertaining to control of pollutants subject to PSD review (i.e., attainment pollutants) were promulgated by U.S. EPA in 40 Code of Federal Regulations (CFR) 42.21 (j). This regulation defines Best Available Control Technology (BACT) as emission limits “based on the maximum degree of reduction for each pollutant.” BACT determinations are made on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs.

Federal requirements pertaining to control of non-attainment pollutants, or Lowest Achievable Emission Rate (LAER), were promulgated by USEPA under 40 CFR 51.165 (a). This regulation defines LAER as the emissions limit based on either (1) the most stringent emission rate contained in a State Implementation Plan (SIP), unless the [source] demonstrates the rate is not achievable; or (2) the most stringent emissions limitation that is achieved in practice. The federal LAER does not consider the cost impacts of control.

BACT must be applied to any new or modified source resulting in an emissions increase exceeding any San Joaquin Valley Air Pollution Control District (SJVAPCD) BACT threshold. SJVAPCD Rule 2201 requires HECA to apply BACT to any source that has an increase in emissions of oxides of nitrogen (NO_x), volatile organic compounds (VOC), sulfur dioxide (SO₂), carbon monoxide (CO), and particulate matter equal to or less than 10 microns in diameter (PM₁₀) (criteria pollutants) in excess of 2.0 pounds per highest day. BACT for the applicable pollutants was determined by reviewing the SJVAPCD BACT Guidelines Manual, the South Coast Air Quality Management District BACT Guidelines Manual, the most recent Compilation of California BACT Determinations, CAPCOA (2nd Ed., November 1993), and USEPA’s BACT/LAER Clearinghouse.

BACT review is required for the proposed Project because the proposed Project will result in a significant net emissions increase for NO_x, CO, VOC, PM₁₀, and SO₂.

The basis for the emissions-related analyses is annual average operation at a design capacity of nominally 250 megawatts. The proposed Project as currently configured will involve the following major processes and emission units:

- One hydrogen-rich fuel and/or natural-gas-fired Combustion Turbine Generator (CTG) with Heat Recovery Steam Generator (HRSG) and one Steam Turbine-Generator (STG);
- One Natural-Gas – fired Simple-Cycle Auxiliary CTG
- One Multi-cell, Mechanical-draft Cooling Tower for the combined-cycle power block
- One Multi-cell, Mechanical-draft Cooling Tower for the Air Separation Unit
- One Multi-cell, Mechanical-draft Cooling Tower for the gasification block
- One Auxiliary Boiler
- Solid Feedstock Receiving and Handling System
- Gasification Block, including an Elevated Gasification Flare
- Three Natural-Gas – Fired Gasifier Warming (Refractory Heaters)

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

- Sulfur Recovery System (Tail Gas Thermal Oxidizer and two elevated flares with natural gas assist)
- Two Emergency, Diesel-Engine — Driven Generators
- One Diesel-Engine – Driven Fire – Water Pump
- One carbon dioxide (CO₂) vent stack

Section 2 of the revised AFC provides a complete description of the Project indicating the layout of the major plant components within the site, and general discussion of the project components.

2.0 BACT REVIEW PROCESS

BACT is defined in the PSD regulations as:

“... an emission limitation based on the maximum degree of reduction for each pollutant subject to regulation under the Act which would be emitted from any proposed major stationary source ... which [is determined to be achievable], on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs” [40 CFR 52.21(b)(12)]

In a December 1, 1987 memorandum from the USEPA Assistant Administrator for Air and Radiation, the agency provided guidance on the “top-down” methodology for determining BACT. The “top-down” process involves the identification of all applicable control technologies according to control effectiveness. Evaluation begins with the “top,” or most stringent, control alternative. If the most stringent option is shown to be technically or economically infeasible, or if environmental impacts are severe enough to preclude its use, then it is eliminated from consideration, and the next most stringent control technology is similarly evaluated. This process continues until the BACT level under consideration cannot be eliminated by technical or economic considerations, energy impacts, or environmental impacts. The top control alternative that is not eliminated in this process becomes the proposed BACT basis.

This top-down BACT analysis process can be considered to contain five basic steps, described below (from the USEPA’s Draft New Source Review Workshop Manual, 1990)¹:

Step 1. Identify all available control technologies with practical potential for application to the specific emission unit for the regulated pollutant under evaluation;

Step 2. Eliminate all technically infeasible control technologies;

Step 3. Rank remaining control technologies by control effectiveness and tabulate a control hierarchy;

Step 4. Evaluate most effective controls and document results; and

Step 5. Select BACT, which will be the most effective practical option not rejected, based on economic, environmental, and/or energy impacts.

¹ “New Source Review Workshop Manual,” DRAFT October 1990, USEPA Office of Air Quality Planning and Standards

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Formal use of these steps is not always necessary. However, the USEPA has consistently interpreted the statutory and regulatory BACT definitions as containing two core requirements, which USEPA believes must be met by any BACT determination, irrespective of whether it is conducted in a “top-down” manner. First, the BACT analysis must include consideration of the most stringent available technologies, i.e., those that provide the “maximum degree of emissions reduction.”

Second, any decision to require a lesser degree of emissions reduction must be justified by an objective analysis of “energy, environmental, and economic impacts” contained in the record of the permit decisions.

Additionally, the minimum control efficiency to be considered in a BACT analysis must result in an emission rate no less stringent than the applicable New Source Performance Standard (NSPS) emission rate, if any NSPS standard for that pollutant is applicable to the source.

This BACT analysis was conducted in a manner consistent with this stepwise approach. Control options for potential reductions in criteria pollution emissions were identified for each source. These options were identified by researching the USEPA database known as the RACT/BACT/LAER Clearinghouse (RBLC), drawing upon previous environmental permitting experience for similar units and surveying available literature. Available controls that are judged to be technically feasible are further evaluated based on an analysis of economic, environmental, and energy impacts.

Assessing the technical feasibility of emission control alternatives is discussed in USEPA’s draft “New Source Review Workshop Manual.” Using terminology from this manual, if a control technology has been “demonstrated” successfully for the type of emission unit under review, then it would normally be considered technically feasible. For an undemonstrated technology, “availability” and “applicability” determine technical feasibility. An available technology is one that is commercially available, meaning that it has advanced through the following steps:

- Concept stage;
- Research and patenting;
- Bench-scale or laboratory testing;
- Pilot-scale testing;
- Licensing and commercial demonstration; and
- Commercial sales.

Suitability for consideration as a BACT measure involves not only commercial availability (as evidenced by past or expected near-term deployment on the same or similar type of emission unit), but also involves consideration of the physical and chemical characteristics of the gas stream to be controlled. A control method applicable to one emission unit may not be applicable to a similar unit, depending on differences in the gas streams’ physical and chemical characteristics.

For this BACT analysis, the available control options were identified by querying the USEPA RBLC and by consulting available literature on control options for integrated gasification combined cycle (IGCC). The analysis also involves review of currently permitted and operating IGCC facilities.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

3.0 PROJECT SOURCES SUBJECT TO BACT ANALYSIS

HECA will consist of several facility blocks/systems representing sources of regulated air pollutants that are addressed in this BACT analysis. To evaluate possible emission control technologies, it is first important to understand the unique IGCC process and the supporting ancillary plant processes. The process descriptions for the various processes that make up HECA are included in Chapter 2 of this Application. The proposed BACT controls and associated emission rates for each emission unit are summarized in Table 3-1.

HECA includes one type of source unique to power generation facilities operating at this time – the CTG/HRSG equipped to combust syngas. It is important to emphasize that BACT for this source is based on the “best of class” in current diffusion combustor based syngas fired gas turbine technology. The emissions profile contained in this application for this source is as good as or better than other syngas IGCC permitted to date, as discussed later in this section. However, the IGCC BACT level emissions should not be compared to the natural gas combined cycle (NGCC) gas turbine technology using dry low NO_x burner technology emission levels.

Table 3-1
Proposed BACT for Project

Pollutant	Technology	Emission Limit
CTG/HRSG Combustion Turbine (excluding Start up / Shutdown conditions).		
NO _x	Diluent Injection, Selective Catalytic Reduction	4 ppm NO _x @ 15 percent O ₂ on hydrogen-rich fuel and natural gas fuel, 3-hour average
CO	Good Combustion Practice (GCP), CO Catalyst	3 ppm CO @ 15 percent O ₂ on hydrogen-rich fuel, 5 ppm CO @ 15 percent O ₂ on natural gas fuel
PM/PM ₁₀	GCP, Gas Cleanup, Gaseous Fuels	24 lb/hr on hydrogen-rich fuel, 18 lb/hr on natural gas fuel
SO ₂	Hydrogen-rich Gas cleanup, pipeline quality natural gas	≤ 5 ppmv in undiluted total sulfur (hydrogen-rich fuel) ≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC	CO Catalyst	1 ppm VOC @ 15 percent O ₂ on hydrogen-rich fuel, 2 ppm VOC @ 15 percent O ₂ on natural gas fuel
NH ₃	Selective Catalytic Reduction	5 ppm NH ₃ slip on hydrogen-rich fuel and natural gas fuel
Auxiliary CTG (excluding Start up / Shutdown conditions). Natural Gas fired. 103.3 MW		
NO _x	Selective Catalytic Reduction	2.5 ppm NO _x @ 15 percent O ₂ on natural gas fuel, 3-hour average
CO	CO Catalyst	6.0 ppm CO @ 15 percent O ₂
PM/PM ₁₀	PUC regulated natural gas	6 lb/hr on natural gas fuel
SO ₂		≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC	CO Catalyst	2 ppm VOC @ 15 percent O ₂ on natural gas fuel

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

**Table 3-1
Proposed BACT for Project (Continued)**

Pollutant	Technology	Emission Limit
NH ₃	Selective Catalytic Reduction	10 ppm NH ₃ slip on natural gas fuel
Cooling Towers		
PM/PM ₁₀	High Efficiency Drift Eliminators, Total Dissolved Solids (TDS) limit in circulating water, and Good Operating Practice	0.0005 percent drift as percent of the circulating water
Auxiliary Boiler, Natural Gas 142 MMBTU/hr		
NO _x	Low NO _x Combustor with FGR	9 ppm NO _x @ 3 percent O ₂ on natural gas fuel
CO	GCP	50 ppmvd @ 3 percent O ₂
PM/PM ₁₀	GCP, PUC grade natural gas fuel	0.005 lb/MMBtu heat input
SO ₂		≤ 0.75 grain / 100 SCF (12.65 ppm for natural gas)
VOC		0.004 lb/MMBtu heat input
Emergency Diesel Engines (2 Emergency Generators)		
NO _x	Combustion controls, restricted operating hours	0.5 g/brake horsepower (Bhp)/hr
CO		0.29 g/Bhp-hr
PM/PM ₁₀	Combustion controls, Low Sulfur Diesel fuel, restricted operating hours	0.03 g/Bhp-hr
SO ₂		N/A
VOC		0.11 g/bhp-hr
Emergency Diesel Engines (Fire Pump)		
NO _x	Combustion controls, restricted operating hours	1.5 g/bhp-hr
CO		2.60 g/bhp-hr
PM/PM ₁₀	Combustion controls, Low Sulfur Diesel fuel, restricted operating hours	0.015 g/bhp-hr
SO ₂		N/A
VOC		0.14 g/bhp-hr
Gasification Flare (an elevated flare)		
NO _x , CO, PM/PM ₁₀ , SO ₂ , VOC		GCP, gaseous fuel only, Gas cleanup/Limit on reduced sulfur in hydrogen-rich fuel
Thermal Oxidizer (Sulfur Recovery System)		
NO _x	GCP	4.8 lb/hr 24-hour average
CO		4.0 lb/hr, 1-hour average
PM/PM ₁₀		0.16 lb/hr 24-hour average
SO ₂	GCP, Gas cleanup	2.02 lb/hr, 3-hour average
VOC	GCP	32.84 lb/hr, annual average

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Table 3-1
Proposed BACT for Project (Continued)

Pollutant	Technology	Emission Limit
SRU Flare (an elevated flare with natural gas assist)		
NO _x	GCP	
CO		
PM/PM ₁₀	GCP, gaseous fuel only	
SO ₂	GCP, Caustic Scrubber	
VOC	GCP	
CO₂ Vent		
CO	Gas Cleanup	1000 ppmv
H ₂ S	Acid Gas Removal	10 ppmv
VOC	Gas Cleanup	40 ppmv
Gasifier Warming (refractory heater)		
NO _x	GCP	0.11 lb/MMBtu, higher heating value (HHV)
CO	GCP	0.09 lb/MMBtu, HHV
PM/PM ₁₀	GCP, gaseous fuel only	0.008 lb/MMBtu, HHV
SO ₂	GCP, PUC grade Natural gas	0.002 lb/MMBtu, HHV (12.65 ppm)
VOC	GCP	0.007 lb/MMBtu, HHV
Feedstock		
PM/PM ₁₀	Dust Collector	0.005 grain/scf outlet dust loading

Source: HECA Project

Notes:

BACT = best available control technology

CO = carbon monoxide

CPUC = California Public Utility Commission

CTG = combustion turbine generator

FGR = flue gas recirculation

MMBTU = million British thermal units

NO_x = nitrogen dioxide

NH₃ = ammonia

O₂ = oxygen

PM/PM₁₀ = particulate matter/particulate matter less than 10 microns

ppm = parts per million

ppmvd = parts per million volumetric dry

SCF = standard cubic feet

SO₂ = sulfur dioxide

VOC = volatile organic compound

HHV = higher heating value

4.0 CONSIDERATION OF ALTERNATIVE GENERATING TECHNOLOGY

This section addresses recent guidance relating to the need for consideration of alternative electrical generating technologies for the proposed project, as part of the BACT analysis. Compared to pulverized coalpc (PC)-fired boilers and circulating fluidized bed (CFB) boilers, the proposed IGCC process is the very lowest emitting solid fuel-based electricity generating technology available, and selection of a completely different solid fuel-based generating technology would not result in lower emissions. Later portions of this BACT analysis address

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

the specific controls that are proposed to minimize the emissions from the proposed IGCC process.

The first step in a BACT determination process is to identify all available control technologies that could potentially be used to minimize the emissions of the source and pollutant under evaluation. The most common control technologies considered in a BACT analysis are add-on control measures and inherent process characteristics that minimize generation of pollutants, in addition to process or work practice modifications to improve the emissions performance of a proposed project. These types of process modifications/measures, when applicable, are properly considered in a BACT analysis.

In contrast, consideration of alternatives that would involve completely “redefining the design” of the proposed process are not required to be considered (1990 Draft New Source Review Workshop Manual, Section IV.A.3). Alternative generating processes, such as natural-gas-fired combined-cycle plants, represent a completely different family of power generation plant designs from IGCC. Although there are certain types of components in common, such as cooling towers and steam-driven turbine generators, the technical basis for a gas-fired plant differs markedly from that of an IGCC facility.

Because CFB or PC boilers or a natural-gas-fired electrical generating plant would be a completely different processes, and represent “redefining the design” compared to IGCC, it is reasonable to conclude that the USEPA would not require that the BACT analysis for HECA compare these different technologies. This point was recently reinforced in a December 13, 2005 letter from Stephen Page, Director of the USEPA’s OAQPS, to E3 Consulting, LLC regarding BACT requirements for proposed coal-fired power plant projects. In that letter, the USEPA clarified that a BACT analysis need not consider an alternative “which would wholly replace the proposed facility with a different type of facility.”

The remainder of this BACT analysis describes the various emission control options for specific IGCC facility processes, and demonstrates that as proposed, HECA would achieve the lowest emissions rate technically and economically feasible for such a facility.

5.0 OTHER PERMITTED IGCC PROJECTS

For this BACT analysis, the available control options were identified by querying the RBLC database and by consulting available literature on control options for IGCC. Applications and/or permits from a number of other IGCC facilities that have completed the New Source Review process were also reviewed to provide additional reference material for this BACT analysis. A brief summary of the other recently permitted IGCC plants in the United States and their emissions limits is presented in this section.

Other recently permitted IGCC facilities that will be used as comparison reference for this BACT analysis are:

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

- Duke Energy, Edwardsport Generating Station
- ERORA Group, Taylorville Energy Center
- ERORA Group, Cash Creek Generating Station

The air permits, BACT analyses, and additional literature were reviewed for each of these recently permitted IGCC facilities. Each facility is discussed briefly below. The facilities that were subject to BACT determinations are listed as such.

Duke Energy, Edwardsport Generating Station: Duke Energy Indiana, owner of Edwardsport Generating Station, obtained approval, via Indiana Department of Environmental Management Significant Modification Title V Permit, to install an IGCC facility in Knox County, Indiana. The Title V Significant Modification Permit was issued in January 2008. The 630-megawatt (net) IGCC plant will replace four older, less efficient generating units capable of generating approximately 160 megawatts at the Edwardsport site. The Edwardsport Generating Station is expected to use coal as feedstock, and SCR as add-on control to minimize NO_x emissions from the plant.

ERORA Group - Taylorville Energy Center: The ERORA Group is developing the Taylorville Energy Center, a 630 megawatt (net) IGCC facility to be located in Christian County, southern Illinois. Taylorville Energy Center obtained a final Illinois Environmental Protection Agency air permit in June 2007. Taylorville Energy Center proposed to use GE Energy gasification technology and local coals (Illinois coal) as the feedstock. Taylorville Energy Center will use Selexol® AGR systems, as well as SCR. The Taylorville Energy Center site is in an ozone attainment area, so SCR is not required for BACT purposes. ERORA is using SCR to minimize NO_x emissions from the plant, but not as BACT. This will allow them to minimize the cost to acquire NO_x allowances from the market. ERORA notes that in order to increase the chance that the SCR system will work in this unproven application on coal-derived syngas, higher sulfur removal, by using Selexol® instead of MDEA, will be required.

ERORA Group – Cash Creek Generating Station: The ERORA Group is developing the Cash Creek Generation Station IGCC facility, to be located near Owensboro, Henderson County, Kentucky. Cash Creek Generation Station obtained a final Kentucky DAQ air permit in January 2008. The 630 megawatt IGCC proposes to use GE Energy gasification technology and local coals (Kentucky coal) as the feedstock. Cash Creek Generation Station will use Selexol® AGR systems, as well as SCR. Because the proposed facility site is in an ozone attainment area, SCR is not required for BACT purposes. ERORA is using SCR to minimize NO_x emissions from the plant, but not as BACT. This will allow them to minimize the cost to acquire NO_x allowances from the market. ERORA notes that in order to increase the chance that the SCR system will work in this unproven application on coal-derived syngas, higher sulfur removal, by using Selexol® instead of MDEA, will be required.

6.0 SOURCE-SPECIFIC BACT ANALYSIS

The following BACT analysis evaluates control technologies applicable to each of the criteria pollutants that would be emitted from the proposed Project to determine appropriate BACT

emission limits. This BACT analysis is based on the current state of IGCC technology, energy and environmental factors, current expected economics, energy, and technical feasibility.

6.1 CTG/HRSG BACT Analysis

The following is the BACT analysis for the proposed combustion turbine. The proposed combustion turbine will be a GE 7FB model turbine with a nominal capacity of 232 megawatt. The GE 7FB is a new turbine model designed to optimally uses hydrogen-rich fuel and natural gas, and includes changes to the fuel system, combustion system, and hot gas path. The use of hydrogen-rich fuel requires the use of a diffusion-type combustor, because the high concentration of hydrogen precludes the use of dry low NO_x (DLN) combustor technology.

The air permits, BACT analyses, and additional literature for each of the recently permitted IGCC facilities discussed in the last section were reviewed. Table 6-1 summarizes the criteria pollutant emission levels permitted for the combustion turbine units at each facility.

6.1.1 Nitrogen Oxides BACT Analysis for the CTG/HRSG

The criteria pollutant NO_x is primarily formed in combustion processes via the reaction of elemental nitrogen and oxygen in the combustion air (thermal NO_x), and the oxidation of nitrogen contained in the fuel (fuel NO_x). The hydrogen-rich fuel produced in the proposed project contains negligible amounts of fuel-bound nitrogen; therefore, it is expected that essentially all NO_x emissions from the CTG/HRSG will originate as thermal NO_x.

The rate of formation of thermal NO_x in a combustion turbine is a function of residence time, oxygen radicals, and peak flame temperature. Front-end NO_x control techniques are aimed at controlling one or more of these variables during combustion. Examples include dry low-NO_x combustors, flue gas recirculation, and diluent injection (steam, water, or nitrogen). These technologies are considered to be commercially available pollution prevention techniques. It is necessary to recognize the fundamental differences between natural-gas-fired and hydrogen-rich fuel-fired combustion turbines in evaluating these techniques. Compared to natural gas and syngas, hydrogen-rich fuel has a much higher hydrogen content (natural gas is often over 90 percent methane), and a much lower heating value (about 250 Btu/scf for hydrogen-rich fuel vs. 1,000 Btu/scf for natural gas). HECA will be fired on hydrogen-rich fuel. The other power plants used for comparison in this Appendix are fired on syngas.

1. Identify Control Technologies

The following NO_x control technologies were evaluated for the proposed CTG/HRSG:

Combustion Process Controls

- Dry Low NO_x Burner
- Diluent Injection

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Post-Combustion Controls

- SCONO_xTM
- Selective Non-Catalytic Reduction (SNCR)
- Selective Catalytic Reduction (SCR)

Table 6-1
Permitted Criteria Pollutant BACT Limits for Combined-Cycle Combustion Turbine

Facility	HECA	Cash Creek Generation Station	Edwardsport Generating Station	Taylorville Energy Center
Location	Kern County, CA	Henderson County, KY	Knox County, IN	Christian County, IL
MW	250	630	630	630 (net)
Turbine	GE 7FB	GE 7FB	GE 7FB	GE 7FB
NO _x	4 ppmc on hydrogen-rich fuel (0.019 lb/MMBtu), 4.0 ppmc on Natural Gas (0.016 lb/MMBtu)	0.0331 lb/MMBtu (approx 5 ppmc) Syngas 0.0246 lb/MMBtu on Nat Gas	0.027 lb/MMBtu Syngas 0.018 lb/MMBtu on Nat Gas	0.034 lb/MMBtu (5.0 ppmc) Syngas 0.025 lb/MMBtu on Nat Gas
SO ₂	≤ 5 ppmv in undiluted hydrogen-rich fuel ((0.003 lb/MMBtu) 0.75 grains/100 scf of total sulfur on Nat Gas (0.002 lb/MMBtu)	0.0158 lb/MMBtu (3.8 ppmc) Syngas 0.0006 lb/MMBtu on Nat Gas	0.0138 lb/MMBtu Syngas 0.0006 lb/MMBtu on Nat Gas	0.016 lb/MMBtu Syngas (10 ppm Sulfur in Syngas) 0.001 lb/MMBtu on Nat Gas.
CO	3 ppmc on Hydrogen-rich fuel (0.008 lb/MMBtu), 5 ppmc on Nat Gas (0.012 lb/MMBtu)	0.0485 lb/MMBtu Syngas 0.0449 lb/MMBtu on Nat Gas	0.0441 lb/MMBtu Syngas 0.0421 lb/MMBtu on Natural Gas	0.049 lb/MMBtu (25.0 ppmvd) Syngas 0.045 lb/MMBtu (25.0 ppmvd) on Nat Gas
PM ₁₀ (Scaled to HECA MW size)	24 lb/hr on hydrogen-rich fuel and 18 lb/hr on Nat Gas	47 lb/hr on syngas and 35 lb/hr on Nat Gas	39.1 lb/hr on syngas and 18.1 lb/hr on Nat Gas	48 lb/hr on syngas and 24 lb/hr on Nat Gas
VOC	1 ppmc on Hydrogen-rich fuel (0.0016 lb/MMBtu), 2 ppmc on Nat Gas (0.0028 lb/MMBtu)		0.0016 lb/MMBtu Syngas or on Nat Gas	

Notes:

Only HECA would use duct firing. All emissions specified for HECA apply to non-duct-firing and duct-firing operation. HECA SO₂ on natural gas is worst case short-term average based on limit of 0.75 gr./100 scf.

Taylorville CO values inconsistent in ratio of lb/MMBtu per ppmc for NO_x. Scaling ratio from NO_x would result in CO value of 0.049 lb/MMBtu (11.8 ppmc.) on Hydrogen-rich fuel(lower CO ppmc would be more conservative).

CO = carbon monoxide

MMBtu = million British thermal units

MW = megawatt

NO_x = oxides of nitrogen

PM₁₀ = particulate matter 10 microns or less in diameter

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Table 6-1
Permitted Criteria Pollutant BACT Limits for Combined-Cycle Combustion Turbine

Facility	HECA	Cash Creek Generation Station	Edwardsport Generating Station	Taylorville Energy Center
----------	------	----------------------------------	-----------------------------------	------------------------------

ppm = parts per million
 ppmc = parts per million by volume, dry basis, corrected to 15 percent O₂
 SO₂ = sulfur dioxide
 VOC = volatile organic compound

2. Evaluate Technical Feasibilities

- Dry Low-NO_x Combustor**

DLN combustor technology has been successfully demonstrated to reduce thermal NO_x formation from natural-gas combustion turbines. This is done by designing the combustors to control both the stoichiometry and temperature of combustion by tuning the fuel and air locally within each individual combustor's flame envelope. Combustor design includes features that regulate the aerodynamic distribution and mixing of the fuel and air. A lean, pre-mixed combustor design mixes the fuel and air prior to combustion. This results in a homogeneous air/fuel mixture, which minimizes localized fuel-rich pockets that produce elevated combustion temperatures and higher NO_x emissions. A lean fuel-to-air ratio approaching the lean flammability limit is maintained, and the excess air serves as a heat sink to lower the combustion temperature, which in turn lowers thermal NO_x formation. A pilot flame is used to maintain combustion stability in this fuel-lean environment.

Hydrogen-rich fuel is different than syngas and has a similar heating value, but with much less CO and carbon dioxide. Hydrogen-rich fuel differs from natural gas in heating value, gas composition, and flammability characteristics. Available DLN combustor technologies are designed for natural gas (methane-based) fuels and will not operate on the syngas (hydrogen/CO-based) fuels used by an IGCC combustion turbine. DLN combustors are not technically feasible for this application due to the potential for explosion hazard in the combustion section due primarily to the high hydrogen content of the syngas. No manufacturer currently makes DLN combustors that can be used for a combustion turbine fueled by petroleum coke (petcoke) or coal-derived syngas. Research is ongoing to develop DLN for syngas-fueled combustion turbines; however, such combustors are not yet commercially available. Thus, DLN combustor is not a technically feasible control option for this unit.

- Diluent Injection**

Higher peak flame temperature during combustion may increase thermodynamic efficiency, but it also increases the formation of thermal NO_x. The injection of an inert diluent such as atomized water, steam, or nitrogen into the high-temperature region of a combustor flame serves to inhibit thermal NO_x formation by reducing the peak flame temperature.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

For the Project's CTG/HRSG, nitrogen is used as a diluent that reduces thermal NO_x produced when hydrogen-rich gas is combusted. Steam is used as a diluent when natural gas is combusted. This method effectively lowers the fuel heat content, and consequently, the combustion temperature, thereby reducing NO_x emissions.

GE guarantees that diluent injection can achieve turbine exhaust emission levels of 15 ppmvd NO_x (at 15 percent oxygen) over a 3-hour average (excluding start up, shutdown, and upset periods) when firing 100 percent hydrogen-rich fuel. For natural-gas combustion and co-firing, GE guarantees emission levels of 25 ppmvd NO_x (at 15 percent oxygen) from the turbine exhaust. The higher emission is caused by the difference in combustion characteristic of natural gas compared to the hydrogen-rich fuel.

A secondary benefit of diluent injection is that it will increase the mass flow of the exhaust. Therefore, the power output per unit of fuel input also increases.

Diluent injection represents an inherently lower-emitting process for IGCC units, and is a technically feasible control technology. Diluent injection (steam for natural gas and nitrogen for hydrogen-rich fuel) is proposed as the baseline case for the CGT/HRSG combustion turbine NO_x BACT analysis. This NO_x control technology and emission level have also been determined as BACT for all other recent IGCC permits, and has been demonstrated to achieve NO_x emission rates of 15 ppmvd (at 15 percent O₂) when firing 100 percent syngas fuel. This NO_x diluent injection control technology has been commercially demonstrated on syngas on the GE 7FA, but not on hydrogen-rich fuel on the GE 7FB.

- SCONO_x™

The SCONO_x™ system is an add-on control device that reduces emissions of multiple pollutants. SCONO_x™ uses a single catalyst for the reduction of CO, VOC, and NO_x, which are converted to CO₂, water (H₂O), and nitrogen (N₂).

All installations of the technology have been on small natural gas facilities, and have experienced performance issues. The fact that SCONO_x™ has not been applied to large-scale natural gas combustion turbines creates concerns regarding the timing, feasibility, and cost-effectiveness of necessary design improvements. SCONO_x™ has also not been applied to syngas (or hydrogen-rich fuel).

In evaluating technical feasibility for large IGCC projects, the additional concerns are:

- SCONO_x™ uses a series of dampers to re-route air streams to regenerate the catalyst. The proposed HECA project is significantly larger than the facilities where SCONO_x™ has been used. This would require a significant redesign of the damper system, which raises feasibility concerns regarding reliable mechanical operation of the larger and more numerous dampers that would be required for application to the HECA CTG/HRSG.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

- SCONO_xTM would not be expected to achieve lower guaranteed NO_x levels than SCR, and, for reasons described above, it has even greater feasibility concerns with respect to application on IGCC turbines than those for SCR.

For the above reasons, SCONO_xTM is considered technically infeasible for this unit.

- Selective Non-Catalytic Reduction

Selective non-catalytic reduction is a post-combustion NO_x control technology in which a reagent (NH₃ or urea) is injected into the exhaust gases to react chemically with NO_x to form elemental nitrogen and water without the use of a catalyst. The success of this process in reducing NO_x emissions is highly dependent on the ability to achieve uniform mixing of the reagent into the flue gas, which must occur within a narrow flue gas temperature zone (typically from 1,700 to 2,000 degrees Fahrenheit [°F]).



The consequences of operating outside the optimum temperature range are severe. Above the upper end of the temperature range, the reagent will be converted to NO_x. Below the lower end of the temperature range, the reagent will not react with the NO_x resulting in very high NH₃ slip concentrations (NH₃ discharge from the stack).

This technology is occasionally used in conventional fired heaters or boilers upstream of any HRSG or heat recovery unit. SNCR has never been applied in IGCC service, primarily because there are no flue gas locations within the combustion turbine or upstream of the HRSG with the optimal requisite temperature and residence time characteristics to facilitate the SNCR flue gas reactions. Therefore, SNCR is not technically feasible for this unit.

- Selective Catalytic Reduction

SCR is a technology that achieves post-combustion reduction of NO_x from flue gas within a catalytic reactor. The SCR process involves the injection of NH₃ into the exhaust gas stream upstream of a specialized catalyst module to promote the conversion of NO_x to molecular nitrogen. SCR is a common control technology for use on natural-gas-fired combustion turbines.

In the SCR process, NH₃, usually diluted with air or steam, is injected through a grid system into the exhaust gas upstream of the catalyst bed. On the catalyst surface, the NH₃ reacts with NO_x to form molecular nitrogen and water. The basic reactions are:



The Project selected SCR and diluent injection technology to control NO_x emissions from the CTG/HRSG unit. The SCR system reduces nitrogen oxide emissions from the HRSG stack gases by up to about 80 percent. Diluted 19 percent aqueous ammonia is injected into the stack gases upstream of a catalytic system that converts nitrogen oxide and ammonia to nitrogen and water.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

It is anticipated that this combination of control processes will achieve a NO_x emission limit of 4 ppmvd at 15 percent oxygen, based on a 3-hour rolling average, when firing hydrogen-rich fuel, natural gas, or a combination of hydrogen-rich fuel and natural gas. This emission limitation represents a removal efficiency that is better than the approved emissions for recently permitted IGCC units. HRSG vendors confirm the feasibility of achieving the NO_x levels cited in the revised AFC.

3. Rank Control Technologies

Among the control technologies considered in the previous subsection, only one was determined to be both technically feasible and commercially demonstrated at a cost level acceptable as a BACT option. Specifically, the feasible option is diluent injection upstream of the combustion zone to achieve a controlled level of 15 ppmvd NO_x at 15 percent O₂ while firing hydrogen-rich fuel, and 25 ppmvd NO_x at 15 percent O₂ while firing natural gas or a combination of hydrogen-rich fuel and natural gas.

Although there is no commercial demonstration of SCR performance for an IGCC plant using coal or petcoke feedstock, SCR technology has been proposed as emission limits for recently permitted IGCC projects. HRSG vendors confirm that SCR catalyst will be able to achieve combined NO_x reduction down to 4 ppmvd at 15 percent oxygen, based on a 3-hour rolling average, on all firing scenarios.

4. Evaluate Control Options

The next step in a BACT analysis is to evaluate the feasible control technology. Based on the evaluation in the previous step, the only feasible technologies suitable for establishment of BACT limits are diluent injection and SCR. The principal environmental consideration with respect to implementation of SCR is that, while it will reduce NO_x emissions, it will add NH₃ emissions associated with use of NH₃ as the reagent chemical. A portion of the unreacted NH₃ passes through the catalyst and is emitted from the stack. This is called ammonia slip, and the magnitude of these emissions depends on the catalyst activity and the degree of NO_x control desired. For this project, the concentration of ammonia slip is limited to 5 ppmvd at 15 percent oxygen.

Table 6-2 shows the typical NO_x BACT determination (when firing hydrogen-rich fuel and natural gas, respectively) and control technology for other recently permitted IGCC projects, in comparison with HECA's proposed NO_x BACT for the CTG/HRSG.

As shown in Table 6-2, the BACT limitation for NO_x emissions from HECA CTG/HRSG is more stringent than the historic BACT determination for other recently permitted IGCC projects.

NSPS 40 CFR 60 Subpart Da is considered as the BACT "floor" for this source category. As shown above, the BACT emission limit proposed for HECA is significantly lower than the applicable NSPS Subpart Da limit of 0.5 lb/MMBTU heat input for gaseous fuel. The proposed NO_x reduction technology is also more stringent than the NSPS Subparts Da recommended minimum reduction efficiency of 25 percent.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As has been explained, for this application of hydrogen-rich fuel-fired combustion turbines within an IGCC facility, diluent injection in the combustion turbine and SCR installation as post-combustion NO_x control are the appropriate control techniques for setting BACT-based emission limits. The BACT selection described above is strongly supported by recent precedents for similar IGCC projects.

The proposed BACT limits based on this technology are 4 ppmvd NO_x at 15 percent O₂ for hydrogen-rich–fuel firing, natural-gas firing, and co-firing.

Table 6-2
NO_x BACT Emission Limit Comparison

Facility	State	MW	Turbine	NO _x BACT Technology	Emission Limit on Hydrogen-Rich or Syngas Fuels		Emission Limit on Natural Gas	
					ppm	lb/MMBTU Hydrogen-Rich Fuel	ppm	lb/MMBTU NG
HECA	CA	250	GE Model Number 7FB.	SCR	4 ^a	0.019	4 ^a	0.016
Cash Creek Generation Station	KY	630	GE Model Number 7FB.	SCR	5 ^a	0.0331		0.0246
Edwardsport Generating Station	IN	630	GE Model Number 7FB.	SCR operated in trial mode		0.027 ^b		0.018 ^b
Taylorville Energy Center	IL	630 (net)	GE Model Number 7FB.	SCR	5 ^a	0.034		0.025

Notes:

^a Parts per million by volume, dry basis, corrected to 15 percent O₂.

^b Calculated from mass emissions rate of 57 lb/hr on hydrogen-rich fuel and 38 lb/hr on natural gas.

MMBtu = million British thermal units

ppm = parts per million

MW = megawatt

SCR = selective catalytic reduction

6.1.2 Carbon Monoxide BACT Analysis for the CTG/HRSG

CO is a product of incomplete combustion. Control of CO is typically accomplished by providing adequate fuel residence time and high temperature in the combustion zone to ensure complete combustion. However, these same control factors can increase NO_x emissions. Conversely, lower NO_x emission rates achieved through flame temperature control (by diluent injection) can increase CO emissions for natural gas and un-shifted syngas. Thus, a compromise

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

must be established whereby the flame temperature reduction is set to achieve the lowest NO_x emission rate possible while keeping CO emissions to an acceptable level. However, CO emissions are inherently low for hydrogen-rich fuels that contain very little reduced carbon and are less affected by the conventional trade-off between CO and NO_x.

1. Identify Control Technologies

The following CO control technologies were evaluated for the proposed CTG/HRSG:

Combustion Process Controls

- Good Combustion Practices (GCPs)

Post-Combustion Controls

- SCONO_xTM
- Oxidation Catalyst

2. Evaluate Technical Feasibilities

Good Combustion Practices

Good combustion practices include the use of operational and design elements that optimize the amount and distribution of excess air in the combustion zone to ensure optimum complete combustion. GE guarantees the turbine exhaust can achieve CO emission levels of 5 ppmvd CO when firing hydrogen-rich fuel, and 25 ppmvd CO when operating on natural gas.

This technology has been determined to be BACT for CO emissions in other operational or recently permitted IGCC projects.

- SCONO_xTM

The SCONO_x system was evaluated in the NO_x BACT analysis, and determined to be not technically feasible for this unit.

- Oxidation Catalysts

Catalytic oxidation is a post-combustion control technology that uses a catalyst to oxidize CO into CO₂. Because of the catalyst fouling concerns, the use of oxidation catalysts has been previously limited to processes combusting natural gas. Oxidation catalysts have never been applied to coal-based IGCC processes. Other operational or recently permitted IGCC projects determined GCPs as the only feasible BACT for CO emissions. The project anticipated CO conversions up to 90 percent are attainable across the CO catalyst. HECA proposed CO emission limits of 3.0 ppmvd at 15 percent O₂ while firing hydrogen-rich fuel, and 5.0 ppmvd CO at 15 percent O₂ while firing natural gas.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

3. Rank Control Technologies

Oxidation catalyst is the only technically feasible CO control technology identified in addition to Good Combustion Practices.

4. Evaluate Control Options

GCP is considered the baseline and only feasible and commercially demonstrated CO control technology for IGCC combustion turbines. GCP has been selected as BACT for all other recent IGCC permits. Oxidation catalysts have not been applied to the other coal-based IGCC processes. In comparison to other operational or recently permitted IGCC projects, this emission limitation represents a removal efficiency that is lower than the emission achieved in practice at currently operating IGCC units, and the lowest proposed emission limits for proposed coal-fired units, including other proposed IGCC units.

Table 6-3 shows the typical CO BACT determination (when firing hydrogen-rich fuel and natural gas, respectively) and control technology for other recently permitted IGCC projects, in comparison with HECA's proposed CO BACT for the CTG/HRSG.

Table 6-3
CO BACT Emission Limit Comparison

Facility	State	MW	Turbine	CO BACT Technology	Emission Limit on Hydrogen-Rich Fuel		Emission Limit on Nat Gas	
					ppm	lb/MMBTU Hydrogen-Rich Fuel or Syngas Fuels	ppm	lb/MMBTU NG
HECA	CA	250	GE Model Number 7FB.	CO catalyst and GCP	3 ^a	0.008	5 ^a	0.012
Cash Creek Generation Station	KY	630	GE Model Number 7FB.	GCP		0.0485		0.0449
Edwardsport Generating Station	IN	630	GE Model Number 7FB.	GCP		0.0441b		0.0421b
Taylorville Energy Center	IL	630 (net)	GE Model Number 7FB.	GCP	25	0.049	25	0.045

Notes:

^a Parts per million by volume, dry basis, corrected to 15 percent O₂.

^b Calculated from mass emissions rate of 93 lb/hr on hydrogen-rich fuel and 88.7 lb/hr on natural gas.

MMBtu = million British thermal units

MW = megawatt

ppm = parts per million

As shown in Table 6-3, the BACT limitation for CO emissions from HECA CTG/HRSG is more stringent than the historic BACT determination for other recently permitted IGCC units. This

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

emission limitation represents a removal efficiency that is better than the emission achieved in practice at currently operating IGCC units, and the lowest proposed emission limits compared to recently permitted IGCC units.

5. *Select Control Technology*

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As explained, GCPs and oxidation catalyst are the appropriate control technique for setting BACT-based emission limits.

HECA proposed the CO BACT-based limit of 3.0 ppmvd at 15 percent O₂ while firing hydrogen-rich fuel, and 5.0 ppmvd CO at 15 percent O₂ while firing natural gas during non-startup operation, using GCPs and an oxidation catalyst.

6.1.3 Particulate Matter Emissions BACT Analysis for the CTG/HRSG

Particulate matter emissions from natural-gas — fired combustion sources consist of inert contaminants in natural gas, sulfates from fuel sulfur, ammonia compounds for the SCR reagent, dust drawn in from the ambient air that passes through the combustion turbine inlet air filters, and particles of carbon and hydrocarbons resulting from incomplete combustion. Low ash content and high combustion efficiency exhibit correspondingly low particulate matter emissions for other fuel such as hydrogen-rich fuel.

1. *Identify Control Technologies*

The following particulate matter control technologies were evaluated for the proposed CTG/HRSG:

Pre-Combustion Controls

- Gas Cleanup (for hydrogen-rich fuel)

Combustion Process Controls

- Good Combustion Practices

Post-Combustion Controls

- Baghouse
- Electrostatic Precipitation

2. *Evaluate Technical Feasibilities*

In a typical solid fuel combustion process, fuel particulate matter is removed by post-combustion processes such as fabric filters or electrostatic precipitators. However, in an IGCC plant, particulate matter could damage the turbine, so particulate matter is removed prior to

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

combustion. Post-combustion controls, such as electrostatic precipitators (ESPs) or baghouses, have never been applied to commercial combustion turbines burning gaseous fuels. Therefore, the use of ESPs and baghouses is considered technically infeasible control technology.

In the absence of add-on controls, the most effective control method demonstrated for gas-fired combustion turbines is the use of low-ash fuel, such as natural gas or hydrogen-rich fuel and GCPs. Therefore, it is necessary to use pre-combustion controls such as particulate removal as an integral part of the gasification process, in addition to GCPs.

The use of clean hydrogen-rich fuel and good combustion control is proposed as BACT for PM/PM₁₀ control in the proposed HECA CTG/HRSG. These operational controls will limit filterable plus condensable PM/PM₁₀ emissions to 24 lb/hr when operating on hydrogen-rich fuel, and 18 lb/hr when operating on natural gas.

3. Rank Control Technologies

The use of clean fuels with low potential particulate emissions from optimum gas cleanup processes and GCPs were identified as the only technically feasible particulate emissions control technologies applicable to the proposed combustion turbines.

4. Evaluate Control Options

The USEPA has indicated that particulate matter control devices are not typically installed on combustion turbines and that the cost of installing a particulate matter control device is prohibitive. When the NSPS for Stationary Gas Turbines (40 CFR 60 Subpart GG) was promulgated in 1979, the USEPA acknowledged, “Particulate emissions from stationary gas turbines are minimal.” Similarly, the recently revised Subpart GG NSPS (2004) did not impose a particulate emission standard. Therefore, performance standards for particulate matter control of stationary gas turbines have not been proposed or promulgated at a federal level.

Table 6-4 shows the typical PM BACT determination (when firing hydrogen-rich fuel and natural gas, respectively) and control technology for other recently permitted IGCC projects, in comparison with HECA’s proposed PM BACT for the CTG/HRSG.

Based on the evaluation in the previous step, GCPs and optimum gas cleanup are considered as technically feasible PM/PM₁₀ control technologies that are suitable for establishment of BACT limits. As shown in Table 6-4, HECA emission limitation represents a removal efficiency that is cleaner in comparison to other operational or recently permitted IGCC units. Therefore, the BACT limitation for PM emissions from HECA CTG/HRSG is more stringent than the historic BACT determination for other recently permitted IGCC units.

NSPS 40 CFR 60 Subpart Da is considered as the BACT “floor” for this source category. The BACT emission limits proposed in Table 6-4 are equivalent to 0.011 lb/MMBTU on hydrogen-rich fuel, and 0.008 lb/MMBTU on natural gas. These emission limits are significantly lower than the applicable NSPS Subpart Da limit of 0.03 lb/MMBtu heat input derived from the combustion of solid, liquid, or gaseous fuel.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As explained, GCPs and optimum gas cleanup are the appropriate control technique for setting BACT-based emission limits. The use of optimum gas cleanup to produce clean fuels with low potential particulate emissions and GCPs were selected as LAER for particulate emissions from the proposed combustion turbines. The following emission limit resulting from the implementation of these technologies is proposed for each combustion turbine.

HECA proposed the PM BACT-based limit of 24 lb/hr while firing hydrogen-rich fuel, and 18 lb/hr while firing natural gas during non-startup operation, using GCPs and optimum gas cleanup.

Table 6-4
PM BACT Emission Limit Comparison

Facility	State	MW	Turbine	PM10 BACT Technology	Emission Limit on Hydrogen-Rich Fuel or Syngas Fuels	Emission Limit on Natural Gas
					lb/hr	lb/hr
HECA	CA	250	GE Model Number 7FB.	Gas Cleanup and GCP	24	18
Cash Creek Generation Station	KY	630	GE Model Number 7FB.	Gas Cleanup and GCP	47	35
Edwardsport Generating Station	IN	630	GE Model Number 7FB.	Gas Cleanup and GCP	39.1	18.1
Taylorville Energy Center	IL	630 (net)	GE Model Number 7FB.	Gas Cleanup and GCP	48	24

Notes:

MW = megawatt

PM₁₀ = particulate matter 10 microns in diameter

6.1.4 Sulfur Dioxide and Sulfuric Acid Mist BACT Analysis for the CTG/HRSG

Sulfur dioxide emissions from any combustion process are largely defined by the sulfur content of the fuel being combusted and the rate of the fuel usage. The combustion of hydrogen-rich fuel in the combustion turbines creates primarily SO₂ and small amounts of sulfite (SO₃) by the oxidation of the fuel sulfur. The SO₃ can react with the moisture in the exhaust to form sulfuric acid mist, or H₂SO₄. Emissions of these sulfur species can be controlled, either by limiting the sulfur content of the fuel (pre-combustion control), or by scrubbing the SO₂ from the exhaust gas (post-combustion control).

1. Identify Control Technologies

The following sulfur dioxide and sulfuric acid mist control technologies were evaluated for the proposed CTG/HRSG when operating on hydrogen-rich fuel:

Pre-Combustion Controls

- Chemical Absorption Acid Gas Removal (AGR), e.g., methyldiethanol-amine (MDEA)
- Physical Absorption Acid Gas Removal, e.g., Selexol®, Rectisol

Post-Combustion Controls

- Flue Gas Desulfurization

The sulfur dioxide BACT for the proposed CTG/HRSG when operating on natural gas is PUC-grade natural gas fuel with less than 0.75 grain/100 scf sulfur content.

2. Evaluate Technical Feasibilities

- Acid Gas Removal

In the gasification process, sulfur in the petcoke or coal feedstock converts primarily to hydrogen sulfide (H_2S). Solvent-based acid gas cleanup is commonly used for “gas sweetening” processes in petroleum refinery fuel gas or tail gas treating units, where H_2S in the process gas is removed before use as a fuel. The removed H_2S is recovered either as elemental sulfur in a Sulfur Recovery Unit (e.g., using a Claus process).

In a chemical absorption process, acid gases in the sour syngas are removed by chemical reactions with a solvent that is subsequently separated from the gas and regenerated. The chemical absorption occurs in amine-based systems that use solvents such as MDEA. Amine solvents chemically bond with the H_2S . The H_2S can be easily liberated with low-level heat in a stripper to regenerate the solvent. However, amine-based systems such as MDEA are not effective at removing COS and have not demonstrated the deep total sulfur removal levels required by the Project.

Lower levels of sulfur removal are possible using physical absorption AGR systems. Physical absorption methods, including Selexol® and Rectisol, use solvents that dissolve acid gases under pressure. Selexol® or Rectisol are normally applied when low syngas sulfur levels are required for SCR. Solubility of an acid gas is proportional to its partial pressure and is independent of the concentrations of other dissolved gases in the solvent. Consequently, increased operating pressure in an absorption column facilitates separation and removal of an acid gas like H_2S . The dissolved acid gas can then be removed from the solvent, which is regenerated by depressurization in a stripper.

To selectively remove H_2S and CO_2 , two absorption and regeneration columns or two-stage process are required. In general, H_2S is selectively removed in the first column by a lean

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

solvent that has been deeply stripped with steam, while CO₂ is removed from the now H₂S-free gas in the second absorber. The second-stage solvent can be regenerated if very deep CO₂ removal is required. If only bulk CO₂ removal is required, then the flashed gas containing the bulk of the CO, can be vented, and the second regenerator duty can be substantially lowered or totally eliminated.

A detailed technology assessment was completed by the Applicant and discussed in Section 6, Alternatives.

- **Flue Gas Desulfurization**

Flue gas desulfurization is a post-combustion SO₂ control technology that reacts an alkaline with SO₂ in the exhaust gas. Typical FGD processes operate by contacting the exhaust gas downstream of the combustion zone with an alkaline slurry or solution that absorbs and subsequently reacts with the acidic SO₂. FGD technologies may be wet, semi-dry, or dry, based on the state of the reagent as it is injected or pumped into the absorber vessel. Also, the reagent may be regenerable (where it is treated and reused) or non-regenerable (all waste streams are de-watered and either discarded or sold). Wet, calcium-based processes that use lime (CaO) or limestone (CaCO₃) as the alkaline reagent, are the most common FGD systems in PC unit applications. After the exhaust gas has been scrubbed, it is passed through a mist eliminator and exhausted to the atmosphere through a stack

FGD systems are commonly employed in conventional PC plants, where the concentration of oxidized sulfur species in the exhaust is relatively high. If properly designed and operated, FGD technology can reliably achieve more than 95 percent sulfur removal. However, FGD cannot provide as high a level of control as the pre-combustion AGR systems. In addition, FGD has the environmental drawbacks of substantial water usage and the need to dispose of a solid byproduct (the scrubber sludge). The solid by-product requires the installation of a significant number of ancillary support systems to accommodate treatment, handling, and disposal. Given these disadvantages and the fact that FGD could not achieve the high removal efficiencies associated with AGR, even though FGD is not technically infeasible, it is not considered to be a reasonable technical option for IGCC. Therefore FGD will not be considered further in this BACT analysis

3. Rank Control Technologies

Both chemical and physical absorption methods for AGR are considered feasible for an IGCC, and can achieve control of the sulfur in syngas up to 99 percent or better. Both of these systems are further considered in the BACT analysis. A detailed technology assessment was completed by the Applicant and discussed in Section 6, Alternatives.

4. Evaluate Control Options

Physical absorption AGR systems (including Selexol® and Rectisol) are considered as feasible sulfur dioxide and sulfuric acid mist control technology for the proposed CTG/HRSG turbine. Selexol® has been selected as BACT for all other recent IGCC permits. Rectisol has not yet

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

been applied to other coal-based IGCC processes but has been widely used in gasification projects in the chemical industry where both deep sulfur removal and CO₂ removal are required. Both Rectisol and Selexol® are considered viable alternatives to MDEA. However, the Project selected Rectisol because there are more units operating at similar capacities and similar conditions to those required for the Project, making Rectisol the more proven alternative.

Table 6-5 shows the typical SO₂ BACT determination (when firing hydrogen-rich fuel and natural gas, respectively) and control technology for other recently permitted IGCC projects, in comparison with HECA's proposed SO₂ BACT for the CTG/HRSG.

Table 6-5
SO₂ BACT Emission Limit Comparison

Facility	State	MW	Turbine	SO ₂ BACT Technology	Emission Limit on Hydrogen-Rich Fuel		Emission Limit on Nat Gas	
					ppm	lb/MMBTU Hydrogen-Rich Fuel or Syngas Fuels	ppm	lb/MMBTU NG
HECA	CA	250	GE Model Number 7FB.	AGR, Rectisol	≤ 5 ppm Sulfur in undiluted Hydrogen-rich fuel	0.003	0.75 grains/100 scf	0.002
Cash Creek Generation Station	KY	630	GE Model Number 7FB.	AGR, Selexol®	3.8a	0.0158		0.0006
Edwardsport Generating Station	IN	630	GE Model Number 7FB.	AGR, Selexol®		0.0138b		0.0006b
Taylorville Energy Center	IL	630 (net)	GE Model Number 7FB.	AGR, Selexol®	10 ppm Sulfur in Hydrogen-rich fuel	0.016		0.001

Notes:

^a Parts per million by volume, dry basis, corrected to 15 percent O₂.

^b Calculated from mass emissions rate of 2.9 lb/hr on hydrogen-rich fuel and 1.30 lb/hr on natural gas.

MMBtu = million British thermal units

MW = megawatt

ppm = parts per million

As shown in Table 6-5, the BACT limitation for SO₂ emissions from HECA CTG/HRSG when firing hydrogen-rich fuel is more stringent than the historic BACT determination for other recently permitted IGCC units. This emission limitation represents a removal efficiency that is better than the emission achieved in practice at currently operating IGCC units, and the lowest proposed emission limits compared to recently permitted IGCC units.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

NSPS 40 CFR 60 Subpart Da is considered as the BACT “floor” for this source category. The proposed SO₂ emission limits are significantly lower than the applicable NSPS Subpart Da limit of 180 nanograms per joule (1.4 lb/MWh) or 95 percent reduction on a 30-day rolling average.

When firing natural gas, sulfur dioxide emission from CTG/HRSG is slightly higher than other recently permitted IGCC units. The sulfur dioxide BACT for the proposed CTG/HRSG when operating on natural gas is PUC-grade natural gas fuel with less than 0.75 grain/100 scf sulfur content.

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. HECA selected Rectisol as syngas cleanup control technology to remove sulfur dioxide from the hydrogen-rich fuel stream entering the CTG/HRSG. The reduction efficiency of Rectisol is above the NSPS floor requirement, and the overall performance of this technology is more stringent than the historic BACT determination for other recently permitted IGCC units. The following emission limit resulting from the implementation of these technologies is proposed for each combustion turbine.

HECA proposed the PM BACT-based limit of ≤ 5 ppmv sulfur in undiluted H₂-rich syngas, and ≤ 0.75 grains/100 scf of natural gas sulfur content, using an AGR system (Rectisol) and PUC-grade natural gas.

6.1.5 Volatile Organic Compounds BACT Analysis for the CTG/HRSG

VOCs are a product of incomplete combustion of the organic components in the hydrogen-rich fuel. Hydrogen-rich fuel contains very low concentrations of VOC; therefore, emissions of VOC are inherently very low. Reduction of VOC emissions is accomplished by providing adequate fuel residence time and a high temperature in the combustion zone to ensure complete combustion. A survey of the RBLC database indicated that good combustion control and burning clean gas fuel are the VOC control technologies primarily determined to be BACT. The advantage of IGCC technology is the fact that the combustion turbine operates on hydrogen-rich fuel, which contains a very low organic content, and yields very low levels of uncombusted VOC emissions.

1. Identify Control Technologies

The following VOC control technologies were evaluated for the proposed CTG/HRSG:

Combustion Process Controls

- Good Combustion Practices

Post-Combustion Controls

- SCONOXTM
- Oxidation Catalyst

2. Evaluate Technical Feasibilities

- **Good Combustion Practices**

GCPs include the use of operational and design elements that optimize the amount and distribution of excess air in the combustion zone to ensure optimum complete combustion.

This technology has been determined to be BACT for VOC emissions in other operational or recently permitted IGCC projects.

- **SCONO_xTM**

The SCONO_x system was evaluated in the NO_x BACT analysis, and determined to be not technically feasible for this unit.

- **Oxidation Catalysts**

Catalytic oxidation is a post-combustion control technology that uses a catalyst to oxidize VOC. The catalyst beds that functions to reduce CO emissions can also be effective in reducing VOC emissions. Such systems typically achieve a maximum VOC removal efficiency of up to 50 percent, while providing control for CO.

Because of the catalyst fouling concerns, the use of oxidation catalysts has been previously limited to processes combusting natural gas. Oxidation catalysts have never been applied to coal-based IGCC processes. Other operational or recently permitted IGCC projects determined GCPs as the only feasible BACT for CO emissions. GE guarantees the turbine exhaust can achieve VOC emission levels of 1.0 ppmvd VOC (at 15 percent oxygen) when firing hydrogen-rich fuel, and 2.0 ppmvd CO (at 15 percent oxygen) when operating on natural gas.

3. Rank Control Technologies

Oxidation catalyst is the only technically feasible VOC control technology identified in addition to GCPs.

4. Evaluate Control Options

GCPs is considered the baseline and only feasible and commercially demonstrated VOC control technology for IGCC combustion turbines. GCP has been selected as BACT for all other recent IGCC permits. Oxidation catalysts have never been applied to other coal-based IGCC processes. In comparison to other operational or recently permitted IGCC projects, this emission limitation represents a removal efficiency that is lower than the emission achieved in practice at currently operating IGCC units, and the lowest proposed emission limits for proposed coal-fired units, including other proposed IGCC units.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Table 6-6 shows the typical VOC BACT determination (when firing hydrogen-rich fuel and natural gas, respectively) and control technology for other recently permitted IGCC projects, in comparison with HECA's proposed VOC BACT for the CTG/HRSG.

As shown in Table 6-6, the BACT limitation for VOC emissions from HECA CTG/HRSG is comparable to the historic BACT determination for other recently permitted IGCC units. This emission limitation represents a removal efficiency that is as good as the emissions proposed in recently permitted IGCC units

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As explained, GCPs and oxidation catalyst are the appropriate control technique for setting BACT-based emission limits.

HECA proposed the VOC BACT-based limit of 1.0 ppmvd at 15 percent O₂ while firing hydrogen-rich fuel, and 2.0 ppmvd VOC at 15 percent O₂ while firing natural gas during non-startup operation, using GCPs and oxidation catalyst.

Table 6-6
VOC BACT Emission Limit Comparison

Facility	State	MW	Turbine	VOC BACT Technology	Emission Limit on Hydrogen-Rich Fuel		Emission Limit on Nat Gas	
					ppm	lb/MMBTU Hydrogen-Rich Fuel or Syngas Fuels	ppm	lb/MMBTU NG
HECA	CA	250	GE Model Number 7FB.	CO catalyst and GCP	1 ^a	0.0016	2 ^a	0.0028
Cash Creek Generation Station	KY	630	GE Model Number 7FB.	GCP		N/A		N/A
Edwardsport Generating Station	IN	630	GE Model Number 7FB.	GCP		0.0016 ^b		0.0016 ^b
Taylorville Energy Center	IL	630 (net)	GE Model Number 7FB.	GCP		N/A		N/A

Notes:

^a Parts per million by volume, dry basis, corrected to 15 percent O₂.

^b Calculated from mass emissions rate of 3.3 lb/hr on hydrogen-rich fuel and natural gas.

MMBtu = million British thermal units

MW = megawatt

ppm = parts per million

VOC = volatile organic compound

6.2 Auxiliary CTG BACT Analysis

The following is the BACT analysis for the proposed auxiliary combustion turbine (Aux CTG). The proposed Aux CTG is a 103 megawatt natural-gas – fired GE LMS100® in a simple-cycle configuration, equipped with water injection for nitrogen oxide control. Post-combustion emission controls will include SCR and CO catalyst systems natural gas.

HECA proposed to apply the SJVAPCD BACT Guidelines for Gas Turbine ≥ 50 MW, Uniform Load without Heat Recovery, as the BACT for the Aux CTG unit.

6.2.1 Nitrogen Oxides BACT Analysis for the Auxiliary CTG

The achieved-in-practice or contained in the SIP BACT guideline for NO_x is 5.0 ppmvd at 15 percent O_2 , based on a 3-hour average with high-temperature SCR, or equal. The NO_x emission limitation of 2.5 ppmvd at 15 percent O_2 , (3-hour average) is categorized as technically feasible control technology.

HECA proposed the application of water injection as combustion process control, and SCR as post-combustion control to reduce NO_x emission from the Auxiliary CTG down to 2.5 ppmvd at 15 percent O_2 . As explained in the BACT analysis for the CTG/HRSG unit, water injection reduces the formation of thermal NO_x in the combustion chamber by reducing the peak flame temperature, while SCR promotes the conversion of NO_x to molecular nitrogen.

6.2.2 Carbon Monoxide BACT Analysis for the Auxiliary CTG

The achieved-in-practice or contained in the SIP BACT guideline for CO is 6.0 ppmvd at 15 percent O_2 , based on a 3-hour average with oxidation catalyst, or equal, technology. HECA proposed the application of GCPs and CO catalyst as the control technology to reduce CO emission from the Auxiliary CTG down to 6.0 ppmvd at 15 percent O_2 as recommended in the BACT guideline.

6.2.3 Particulate Emissions BACT Analysis for the Auxiliary CTG

The achieved-in-practice or contained in the SIP BACT guideline for PM_{10} is Air inlet cooler/filter, lube oil vent coalescer (or equal), and either PUC-regulated natural gas, LPG, or non-PUC regulated gas with < 0.75 grains Sulfur/100 dscf.

HECA auxiliary CTG is equipped with the following accessories to provide safe and reliable operation: evaporative coolers, inlet air filters, metal acoustical enclosure, duplex shell; and tube lube oil coolers for the turbine and generator, compressor water wash system, fire detection and protection system, hydraulic starting system, and compressor variable-bleed valve vent. In addition, this unit exclusively combusts PUC-grade natural gas with < 0.75 grain/100 dscf sulfur content. Therefore, the unit meets the recommended BACT emission limitation.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

In addition to the recommendation from the BACT guideline, HECA proposed a PM₁₀ emission limit of 6 lbs/hour. This emission limit is proposed based on the lowest PM₁₀ BACT determination for a similar source from recently permitted power plants in California².

6.2.4 Sulfur Oxides BACT Analysis for the Auxiliary CTG

The achieved-in-practice or contained in the SIP BACT guideline for sulfur oxides is PUC-regulated natural gas, LPG, or non-PUC regulated gas with < 0.75 grain S/100 dscf. As mentioned in the previous section, the auxiliary CTG is proposed to be exclusively fueled by PUC-regulated gas with < 0.75 grain S/100 dscf. Therefore, this unit meets the recommended BACT.

6.2.5 Volatile Organic Compounds BACT Analysis for the Auxiliary CTG

The achieved-in-practice or contained in the SIP BACT guideline for VOCs is 2.0 ppmvd at 15 percent O₂, based on a 3-hour average with oxidation catalyst, or equal, technology. HECA proposed the application of GCPs and CO catalyst as the control technology to reduce VOC and CO emission from the Auxiliary CTG down to 2.0 ppmvd at 15 percent O₂ as recommended in the BACT guideline.

6.3 Cooling Towers Particulate Emissions BACT Analysis

There will be three cooling towers proposed for the Project: two cooling towers (gasification cooling tower and the ASU cooling tower) are associated with the gasification process, and the third cooling tower (power block cooling tower) is used by the power block. Compared to similar-sized combined-cycle power plants, the power block cooling duty is somewhat greater due to the heat integration with gasification resulting in the generation of additional steam for power production in the steam turbine. Each tower has a separate cooling water basin, pumps, and piping system, and operates independently. The cooling water will circulate through a mechanical draft-cooling tower that uses electric motor-driven fans to move the air into contact with the flow of the cooling water. The heat removed in the condenser will be discharged to the atmosphere by heating the air, and through evaporation of some of the cooling water.

The power block cooling tower is designed for an approximate capacity of 175,000 gallons per minute (gpm) of water, with an hourly circulation rate of 88 million lb/hr. The ASU and gasification block cooling water systems are similar in design to the power block cooling design, but they have substantially lower duties. The ASU cooling tower circulation rate is approximately 40,000 gpm, and the gasification cooling tower circulation rate is about 42,000 gpm.

All cooling towers are supplied with high-efficiency drift eliminators designed to reduce the maximum drift;; that is, the fine mist of water droplets entrained in the warm air leaving the cooling tower, to less than 0.0005 percent of the circulating water flow. Circulating water could range in TDS depending on makeup-water quality and tower operation. Therefore, PM₁₀ emissions would vary proportionately.

² Final Decision Panoche Energy Center (2007)

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Wet (evaporative) cooling towers emit aqueous aerosol “drift” particles that evaporate to leave crystallized solid particles that are considered PM₁₀ emissions. The proposed control technology for PM₁₀ is high-efficiency drift eliminators to capture drift aerosols upstream of the release point to the atmosphere.

1. Identify Control Technologies

The following particulate matter control technologies were evaluated for the proposed cooling towers:

Potential Cooling Tower Control Technology

- Drift Elimination System with limited TDS level

2. Evaluate Technical Feasibilities

High-efficiency drift eliminators and limits on TDS concentrations in the circulating water are the techniques that set the basis for cooling tower BACT emission limits. The efficiency of drift eliminator designs is characterized by the percentage of the circulating water flow rate that is lost to drift. The drift eliminators to be used on the proposed cooling tower will be designed such that the drift rate is less than 0.0005 percent of the circulating water. Typical geometries for the drift eliminators include chevron-type.

There is no PM₁₀ BACT guideline for mechanical draft cooling towers in the SJVAPCD. However, the use of high-efficiency drift-eliminating media to de-entrain aerosol droplets from the air flow exiting the wetted-media tower is a commercially proven technique to reduce PM₁₀ emissions. Compared to “conventional” drift eliminators, advanced drift eliminators reduce the PM₁₀ emission rate by more than 90 percent.

In addition to the use of high-efficiency drift eliminators, management of the tower water balance to control the concentration of dissolved solids in the cooling water can also reduce particulate emissions. Dissolved solids accumulate in the cooling water due to increasing concentrations of dissolved solids in the make-up water as the circulating water evaporates;; and secondarily, to the addition of anti-corrosion, anti-biocide additives.

3. Rank Control Technologies

A drift elimination system is the only technically feasible control technology identified for the proposed cooling towers, and historically has been selected as BACT for other projects.

4. Evaluate Control Options

The highest control efficiency to reduce the PM₁₀ emission from the proposed cooling towers involves the instillation of drift eliminators and adoption of TDS limit for the circulating water. Development of increasingly effective de-entrainment structures has resulted in equipment vendors’ claims that a cooling tower may be specified to achieve drift release no higher than

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

0.0005 percent of the circulating water rate for the HECA project. This level of reduction has been approved in other recently permitted IGCC projects.

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As has been explained, drift elimination system is selected as BACT for the proposed cooling towers. The proposed cooling tower will be designed with a high-efficiency drift elimination system to minimize potential drift and particulate emissions, achieving a maximum drift of 0.0005 percent of the circulating water. This measure, along with a limit on the circulating water TDS, is considered to be the BACT option for particulate emissions from the cooling towers.

6.4 Auxiliary Boiler BACT Analysis

The auxiliary boiler will provide steam to facilitate CTG startup, and for other industrial purposes. The auxiliary boiler will be designed to burn pipeline-quality natural gas at the design maximum fuel flow rate of 142 MMBtu/hr (HHV). During normal operation, the auxiliary boiler may be kept in warm standby (steam sparged, no firing) or cold standby (no firing), and will not have emissions. The boiler will produce a maximum of about 100,000 pounds per hour of steam.

Pollutant emissions from natural gas boiler units include NO_x, PM₁₀, CO, SO₂, and VOCs. The auxiliary boiler emissions are based on 2,190 hours of operation per year. The applicant is proposing proper boiler design and operation, low-NO_x combustors with FGR, and use of natural gas to be the BACT for the auxiliary boiler. This emission limitation is proposed to meet the SJVAPCD BACT Guidelines for greater than 20.0 MMBtu/hr natural-gas-fired boiler (base-loaded or with small load swings).

1. Identify Control Technologies

The following criteria pollutant emissions control technologies were evaluated for the proposed auxiliary boilers:

Potential Auxiliary Boiler Control Technology

- Good Combustion Practices
- Low NO_x combustor
- CO Oxidation Catalysts
- Low NO_x combustor with Flue Gas Recirculation
- Selective Catalytic Reduction
- Selective Non-Catalytic Reduction

6.4.1 Nitrogen Oxides BACT Analysis for the Auxiliary Boiler

2. *Evaluate Technical Feasibilities*

- Low NO_x Combustors

Low NO_x combustors reduce thermal NO_x formation by regulating the distribution and mixing of fuel and air to control the stoichiometry and temperature of combustion. Historically, low NO_x combustors have been selected as BACT for natural-gas-fired auxiliary boilers. Therefore, low-NO_x combustor technology is technically feasible for the proposed auxiliary boiler.

- Low NO_x Combustors with Flue Gas Recirculation

FGR reduces boiler NO_x emissions by recirculating a portion of the flue gas into the main combustion chamber. The increase in gas flow within the combustion chamber reduces the peak combustion temperature and oxygen in the combustion air/flue gas mixture, thereby reducing the formation of thermal NO_x. The application of FGR is typically in combination with low-NO_x combustor technology and has been selected as BACT for some auxiliary boiler processes. Therefore, FGR is considered technically feasible for the proposed auxiliary boiler.

- Selective Catalytic Reduction

SCR is a technology that achieves post-combustion reduction of NO_x from flue gas within a catalytic reactor. The SCR process involves the injection of NH₃ into the exhaust gas stream upstream of a specialized catalyst module to promote the conversion of NO_x to molecular nitrogen. SCR technology has been most commonly applied to pulverized-coal-generating units and to natural-gas-fired combustions turbines. However, no examples have been identified where an SCR has been applied to an auxiliary boiler. The auxiliary boiler will provide steam to facilitate CTG startup, and will be kept in warm standby (steam sparged, no firing) or cold standby during normal operation. This operation results in varying flue gas characteristics that may not be suitable for continuous SCR operation. Therefore, SCR is not technically feasible for the intended operation of the auxiliary boiler.

- Selective Non-Catalytic Reduction

Selective non-catalytic reduction is a post-combustion NO_x control technology in which a reagent (NH₃ or urea) is injected into the exhaust gases to react chemically with NO_x to form elemental nitrogen and water without the use of a catalyst. The success of this process in reducing NO_x emissions is highly dependent on the ability to achieve uniform mixing of the reagent into the flue gas, which must occur within a narrow flue gas temperature zone (typically from 1,700°F to 2,000°F).

The consequences of operating outside the optimum temperature range are severe. Above the upper end of the temperature range, the reagent will be converted to NO_x. Below the

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

lower end of the temperature range, the reagent will not react with the NO_x , resulting in very high NH_3 slip concentrations (NH_3 discharge from the stack).

SNCR has never been applied in an auxiliary boiler unit, primarily because there are no flue gas locations within the process with the optimal requisite temperature and residence time characteristics to facilitate the SNCR flue gas reactions. Therefore, SNCR is not technically feasible for this unit.

3. Rank Control Technologies

The use of low NO_x combustor and flue gas recirculation is the only technically feasible control option identified for reducing NO_x emissions. These control technologies are commonly used in combination and historically have been selected as BACT for other projects.

4. Select Control Technology

Low- NO_x combustor technology and flue gas recirculation have historically been selected as BACT for natural-gas-fired auxiliary boilers. These technologies are commonly used in combination to reduce NO_x emissions in other recently permitted IGCC projects.

The proposed auxiliary boiler will be designed with a Low NO_x combustor technology and flue gas recirculation, achieving a maximum NO_x emission concentration of 9 ppm NO_x at 3 percent O_2 on natural gas fuel.

6.4.2 Carbon Monoxide BACT Analysis for the Auxiliary Boiler

An inadequate degree of fuel mixing, lack of available oxygen, or low temperatures in the combustion zone are common causes of incomplete combustion that results in CO emissions. Fuel quality and good combustion practices can limit CO emissions. Good combustion practice has commonly been determined as BACT for natural-gas-fired auxiliary boilers. Post-combustion control technologies using catalytic reduction have also been employed in some processes to reduce CO and VOC emissions.

2. Evaluate Technical Feasibilities

Good Combustion Practices

GCPs include the use of operational and design elements that optimize the amount and distribution of excess air in the combustion zone to ensure complete combustion. Good combustion practice has historically been determined as BACT for CO and VOC emissions from auxiliary boilers, and is a technically feasible control strategy for the proposed auxiliary boiler.

Oxidation Catalyst

Catalytic oxidation is a post-combustion control technology that uses a catalyst to oxidize CO and VOC into CO_2 or H_2O . The technology has most commonly been applied to natural-gas–

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

fired combustion turbines. No examples were identified where oxidation catalyst technology has been applied to an auxiliary boiler. Because of the low potential CO and VOC emission without an oxidation catalyst and the limited use of the proposed auxiliary boiler, the use of catalytic oxidation technology is determined to be infeasible.

3. Rank Control Technologies

Good combustion practice is the only feasible control strategy identified, and has historically been selected as BACT for CO emissions from the auxiliary boiler.

4. Select Control Technology

The use of good combustion practices has been selected as BACT for potential CO emission from the proposed auxiliary boiler. Boiler vendor information indicates that a CO worst-case hourly emission for the proposed auxiliary boiler is 50 ppmvd at 3 percent O₂.

6.4.3 Particulate Emissions, Sulfur Oxides, Volatile Organic Compounds BACT Analysis for the Auxiliary Boiler

For these pollutants, the commercially available control measures that are identified in the most stringent BACT determinations are use of low-sulfur, PUC natural gas, and GCP. Based on SJVAPCD BACT Guidelines for > 20.0 MMBtu/hr Natural-Gas-Fired Boiler (base-loaded or with small load swings), add-on controls were not implemented to achieve BACT limits for these pollutants.

Boiler vendor information indicates that the worst-case hourly emissions for this unit with these technologies would be 0.005 lb SO₂/MMBtu;; 0.004 lb VOC /MMBtu; and 0.005 lb PM₁₀/MMBtu. These rates, or corresponding lb/hour emission rates, are proposed as BACT limits for the auxiliary boiler emission unit.

6.5 Diesel Engines BACT Analysis

The Project will include two 2,800 HP standby diesel generators and one 556 HP, standby firewater pump. HECA proposed to apply the SJVAPCD BACT Guidelines for Emergency Diesel I.C. Engine = or > 400 hp as the BACT for the standby diesel generator engines, and SJVAPCD BACT Guidelines for Emergency Diesel I.C. Engine Driving a Fire Pump as the BACT for the standby firewater pump engine. The BACT emission limits will be achieved by the following control effort.

- Low Sulfur Fuel Selection

The diesel engines will exclusively combust ultra-low sulfur diesel fuel. SO₂ emissions were estimated using ultra-low sulfur diesel fuel containing 15 ppm sulfur.

- Clean Combustion Process Selection

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

The engines will meet USEPA Tier 4 emissions standards for 2011 model equipment.

Standby diesel generator engine: 0.3 g/bhp-hr NMHC; 0.5 g/bhp-hr NO_x; 2.6 g/bhp-hr CO; 0.07 g/bhp-hr PM

Standby firewater pump engine: 0.14 g/bhp-hr NMHC; 1.5 g/bhp-hr NO_x; 2.6 g/bhp-hr CO; 0.015 g/bhp-hr PM

- **Restricted Operating Hours**

The standby diesel generators will operate less than 50 hours per year per engine for non-emergency purposes such as: routine testing, maintenance, and inspection purposes. The fire pump will operate than less than 50 hours per year per engine for non-emergency purposes.

6.5.1 BACT Analysis for the Standby Diesel Generators

The achieved-in-practice or contained in the SIP BACT guideline for NO_x is certified emissions of 6.9 g/bhp-hr or less. The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment will meet this BACT limit with 0.5 g/bhp-hr NO_x. Although it is technically feasible to install add-on NO_x control, this option is cost prohibitive due to the emergency nature of the engine operations.

The achieved-in-practice or contained in the SIP BACT guideline for CO is 2.0 g/bhp-hr. The vendor emission factor for the diesel engines guaranteed 0.29 g/bhp-hr of CO emission. This emission limit is substantially below the required BACT limit. Although it is feasible to install a CO oxidation catalyst to further reduce CO emissions from the engines, the cost for oxidation catalyst for CO control will be prohibitive, given the low number of routine operating hours per year of the engines.

The achieved-in-practice or contained in the SIP BACT guideline for PM₁₀ is 0.1 gram/bhp-hr (if TBACT is triggered) or 0.4 g/bhp-hr (if TBACT is not triggered). The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment will meet this BACT limit with 0.07 g/bhp-hr PM.

The achieved-in-practice or contained in the SIP BACT guideline for sulfur oxides is low-sulfur diesel fuel (500 ppmw sulfur or less) or Very Low-Sulfur Diesel fuel (15 ppmw sulfur or less). The standby diesel generator engines will exclusively combust ultra-low sulfur diesel fuel. SO₂ emissions were estimated using ultra-low sulfur diesel fuel containing 15 ppm sulfur.

There is no numerical emission limit achieved in practice or contained in the SIP BACT guideline for VOC. The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment proposed a BACT limit with 0.3 g/bhp-hr VOC for this unit.

6.5.2 BACT Analysis for the Firewater Pump Diesel Engine

The achieved-in-practice or contained in the SIP BACT guideline for NO_x is certified emissions of 6.9 g/bhp-hr or less. The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment will meet this BACT limit with 1.5 g/bhp-hr NO_x. Although it is technically feasible to install add-on NO_x control, this option is cost prohibitive due to the emergency nature of the fire/water pump engine operations.

There is no numerical emission limit achieved in practice or contained in the SIP BACT guideline for CO. The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment proposed a BACT limit with 2.6 g/bhp-hr CO for this unit. Although it is feasible to install CO oxidation catalyst to further reduce CO emissions from the engines, the cost for an oxidation catalyst for CO control will be prohibitive, given the low number of routine operating hours per year of the fire water pump.

The achieved-in-practice or contained in the SIP BACT guideline for PM₁₀ is 0.1 grams/bhp-hr (if TBACT is triggered) or 0.4 grams/bhp-hr (if TBACT is not triggered). The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment will meet this BACT limit with 0.015 g/bhp-hr PM.

The achieved-in-practice or contained in the SIP BACT guideline for sulfur oxides is low-sulfur diesel fuel (500 ppmw sulfur or less) or ultra-low sulfur diesel fuel (15 ppmw sulfur or less). The firewater-pump diesel engine will exclusively combust ultra-low sulfur diesel fuel. SO₂ emissions were estimated using ultra-low sulfur diesel fuel containing 15 ppm sulfur.

No numerical emission limit is achieved in practice or contained in the SIP BACT guideline for VOC. The proposed control of using engines that meet USEPA Tier 4 emissions standards for 2011 model equipment proposed a BACT limit with 0.14 g/bhp-hr VOC for this unit.

6.6 Gasification Flare BACT Analysis

The gasification block will be provided with a relief system and associated gasification flare to safely dispose of gasifier streams during startup, shutdown, and unplanned upsets or emergency events, syngas during AGR startup, hydrogen-rich gas during short-term emergency combustion turbine outages, or other various streams within the Project during other unplanned upsets or equipment failures. Note that sulfur compounds will be treated upstream of the gasification flare header by the Gasification Amine Absorber.

Two flare-control technologies were evaluated for the proposed facility: an elevated flare, and an enclosed ground flare. Elevated flare technology uses a stack to vent combustible process gases to a combustor located at the top, resulting in an open flame at the stack discharge. Elevated flares provide for greater dispersion of heat and combustion products than ground flares. Elevated flares are the most common technology used by refinery, steel, and chemical industries, and are used by operational and recently permitted IGCC projects.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Compared to an elevated flare, an enclosed ground flare offers reduced noise, reduced visual impact, potentially, and better CO destruction. However, an enclosed ground flare poses potentially decreased dispersion of combustion gases and increased reliability concerns and have never been installed on any IGCC plants and so are considered unproven technology in this application with an associated risk. Elevated flares are used extensively with IGCC applications and therefore, the gasification block will be designed with an elevated flare to safely dispose of gasifier startup gases, hydrogen-rich fuel during AGR startup, hydrogen-rich gas during short-term emergency combustion turbine outages, or other various streams within the Project during other unplanned upsets or equipment failures. The low-pressure sour syngas sent to the flare from the gasification and shift units during shutdown depressurizing operations is first scrubbed in the Gasification Amine Absorber to remove essentially all of the sulfur bearing compounds. Flaring of untreated syngas or other streams within the plant would only occur as an emergency safety measure during unplanned plant upsets or equipment failures.

The gasification flare will emit criteria pollutants that are products of combustion. However, the chemical compositions of the predominant gaseous fuels that would be flared, i.e., syngas and natural gas, result in very low emissions of PM₁₀, SO₂, and VOC. For the syngas case, there is very little unoxidized carbon in the fuel, which limits the formation of particulate matter during combustion even below the rate for natural gas. Formation of SO₂ is limited by the pre-treatment of the syngas flare stream, and the inherently low sulfur content of pipeline natural gas.

1. Identify Control Technologies

The following control technologies were evaluated for the proposed gasification flare:

- Clean pilot fuel (Natural gas) and Good Combustion Practices
- Low NO_x Combustor
- Add-On Controls

2. Evaluate Technical Feasibilities

- Clean pilot fuel (Natural Gas) and Good Combustion Practices

A certain level of flame temperature control can be exercised for the gasification flare by implementing fuel/air ratio control. Flare BACT options that have been achieved in practice in California (e.g., CAPCOA BACT Clearinghouse) indicate a natural gas pilot and “proper burner management and monitoring” are used to control the emissions of CO, VOCs and NO_x.

- Low-NO_x Combustor

Low-NO_x combustor and ultralow NO_x combustor technology alter air-to-fuel ratio in the combustion zone by staging the introduction of the air to promote a “lean-premixed” flame. This results in lower combustion temperatures and reduced NO_x formation. Such designs are not available for elevated flares, that do not have a confined combustion zone, which would

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

allow staged introduction of fuel and air streams. Therefore, this control technology is not feasible for the proposed gasification flare.

- **Add-On Controls**

The gasification block flare is not a candidate for add-on abatement systems. It is generally recognized in the chemical process industries that adoption of add-on control can impede the ability of a flare to respond to unexpected upset conditions. Therefore, this control technology is not feasible for the proposed gasification flare.

For plant safety, the flare must provide a “fail-safe” that is available regardless of the functioning of pollution control devices.

3. Rank Control Technologies

The use of natural gas as pilot fuel and good combustion practices were identified as the only technically feasible criteria pollutant emissions control technologies applicable to the proposed gasification flare.

4. Evaluate Control Options

As determined in the last section, the use of natural gas as pilot fuel and good combustion practices are the only feasible control strategy identified. Based on review of SJVAPCD BACT guideline, there is no BACT determination source category for flare that supports the gasification process.

5. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As has been explained, use of natural gas as pilot fuel and GCPs are selected as BACT for the proposed gasification flare. The measure, along with natural gas pilot and processes flare gas for non-emergency operation are considered to be the best available control option for criteria pollutant emissions from the gasification flare. The proposed control and criteria pollutant emissions for the gasification flare are summarized in Table 6-7.

6.7 Sulfur Recovery System BACT Analysis

The sulfur recovery system is designed to process acid gas streams from the AGR system and IGCC process into an elemental sulfur by-product. Sulfur is removed from the processing facility through a sulfur complex which consists of a Claus unit (thermal stage) plus catalytic converters otherwise known as the SRU, and a Tail Gas Treating Unit (TGTU). The SRU is a totally enclosed process with no discharges to the atmosphere. The tail gas from the SRU is composed mostly of carbon dioxide, water vapor, and sulfur vapor with trace amounts of H₂S and SO₂. The tail gas is routed to the TGTU where the majority of the sulfur is recovered. The overhead of the TGT Unit is combined with the much larger product CO₂ stream and exported offsite for oil reservoir injection.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

Table 6-7
Gasification Flare Total Criteria Pollutant Emissions

Pollutant	Emissions			
	Pilot (ton/yr)	Start-Up/ Shut-Down (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NO _x	0.26	4.04	1.08	4.3
CO	0.18	48.65	12.21	48.8
VOC	0.003	0.00	0.001	0.003
SO ₂	0.004	0.00	0.001	0.004
PM ₁₀ = PM _{2.5}	0.01	0.00	0.002	0.01

Notes:

CO = carbon monoxide

NO_x = oxides of nitrogen

PM₁₀ = PM_{2.5} = particulate matter 10 microns in diameter or smaller and is assumed to equal PM_{2.5} = particulate matter 10 microns in diameter

SO₂ = sulfur dioxide

VOC = volatile organic compound

The proposed sulfur process facility consists of 2 by 50 percent SRUs, and 1 by 100 percent TGTU. The SRU and TGTU give an overall sulfur recovery efficiency of 99.9 percent. Associated with the operation of the sulfur recovery system, HECA proposed the integral use of two elevated flares, a caustic scrubber, and a thermal oxidizer as control devices to provide for the safe and efficient destruction of combustible gas streams. These control devices are primarily used intermittently during short-term periods of startup, shutdown, and malfunction operations.

1. Identify Control Technologies

The following control technologies were evaluated for the proposed Sulfur Recovery System:

- Thermal Oxidizer
- Flare
- Caustic Scrubber

2. Evaluate Control Technologies

- Thermal Oxidizer

In the thermal oxidizer, the TGTU tail gas and other oxidizing streams are subjected to a high temperature and a sufficient residence time to cause an essentially complete destruction of reduced sulfur compounds such as H₂S. The thermal oxidizer uses natural gas to reach the necessary operating temperature for optimal thermal destruction. The thermal oxidizer also controls emissions from various systems during normal operations, including the sulfur pit

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

vent. A continuous natural gas pilot will be in service on both controls. The flare and thermal oxidizer are the only control technologies identified that are capable of controlling the variable potential gas streams associated with the sulfur recovery process and the startup, shutdown, and malfunction of the integrated IGCC systems.

Good thermal oxidizer design includes optimization of parameters that maintain efficiency, such as temperature, residence time, and the mixing of gas streams in the combustion zone. The proposed thermal oxidizer will use natural gas for preheating and to facilitate the combustion of process gases in the thermal oxidizer. Implementation of these elements into the design and operation of the thermal oxidizer, in combination with the use of a natural-gas pilot flame, will support a thermal oxidizer control technology that minimizes incomplete combustion, which directly correlates to potential criteria pollutant emissions.

- **Flare**

Emissions from the IGCC gas cleanup process cannot be directed to certain control systems and/or the combustion turbines during startup and shutdown operations, or during operational malfunctions. Directly venting these emissions to the atmosphere could result in very high concentrations of SO₂, CO, VOCs, NO_x, and/or H₂SO₄ being released. In this case, two elevated flares are selected to accommodate the variability inherent in these operations: Sulfur Recovery Unit Flare, and Rectisol Flare.

An SRU Flare will be used to safely dispose of gas streams containing sulfur during startup and shutdown, and gas streams containing sulfur during unplanned upsets or emergency events. Acid gas derived from the AGR, gasification unit, and SWS overhead is normally routed to the SRU for recovery as elemental sulfur. During cold plant startup of the gasifiers, AGR, and Shift units, these acid-gas streams will be diverted to the SRU Flare Header for a short time. To reduce the emissions of sulfur compounds to the environment during SRU or TGTU shutdown, the acid gas is routed to the Emergency Caustic Scrubber, where the sulfur compounds are absorbed with caustic solution. After scrubbing, the gas is then routed to the elevated SRU Flare Stack.

Enclosed ground flares have the potential to minimize flame appearance and provide a setting for monitoring post-combustion gas streams. However, they have not been proven for the proposed facility because of reliability concerns.

Elevated flares are used extensively with IGCC applications and therefore, are considered proven technology. The gasification block will be designed with an elevated flare.

- **Caustic Scrubber**

During cold plant startup of the gasification block, acid-gas streams will be diverted to a caustic scrubber prior to being directed to the elevated flare for a short time. The caustic scrubber removes H₂S from the acid gas stream with an anticipated scrubbing efficiency of at least 99.6 percent sulfur removal.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

3. Select Control Technology

The final step in the top-down BACT analysis process is to select BACT based on the results of the previous steps. As discussed, the use of flares, thermal oxidizer, and caustic scrubber are the proposed technologies designed to control criteria pollutant emissions from the sulfur recovery system, in addition to an efficient IGCC process design. These technologies complement one another, and may operate in combination with each other.

Including the proposed control system to provide for the safe and efficient destruction of combustible sulfur-rich acid-gas streams, the emissions from the sulfur recovery system are categorized into three emission sources of tail gas thermal oxidizer, SRU flare and Rectisol flare (elevated flares with natural gas assist). Each emission source has its own emission control measure to reduce its criteria pollutant emissions. The proposed control and criteria pollutant emissions for the sulfur recovery system are summarized in Table 6-8.

Table 6-8
Sulfur Recovery System Emissions

Pollutant	Thermal Oxidizer Emissions (lb/MMBtu, HHV)	SRU Flare Emissions				Rectisol Flare Emissions*		
		Pilot (ton/yr)	Start-Up/ Shut-Down (ton/yr)	Total (ton/qtr)	Total (ton/yr)	Pilot (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NO _x	0.13	0.16	0.0130	0.04	0.2	0.16	0.04	0.2
CO	0.04	0.11	0.0086	0.03	0.1	0.11	0.03	0.1
VOC	0.0070	0.002	0.0001	0.000	0.002	0.002	0.000	0.002
SO ₂	See Below	0.003	0.05	0.014	0.1	0.003	0.001	0.003
PM ₁₀ = PM _{2.5}	0.008	0.004	0.0003	0.001	0.004	0.004	0.001	0.004

Assume an allowance of 2 lb/hr SO₂ emission to account for sulfur in the various vent streams, plus fuel.

Notes:

CO = carbon monoxide

NO_x = oxides of nitrogen

PM₁₀ = PM_{2.5} = particulate matter 10 microns in diameter or smaller and is assumed to equal PM_{2.5} = particulate matter 10 microns in diameter

SO₂ = sulfur dioxide

VOC = volatile organic compound

* = Rectisol Flare will be used exclusively for emergency events. During normal plant operation, Rectisol Flare will have a natural-gas-fired pilot light (there is no planned operation expected for this source).

6.8 CO₂ Vent BACT Analysis

The Project will produce electricity while substantially reducing greenhouse gas emissions by capturing CO₂. At least 90 percent of the carbon in the raw syngas will be captured in a high-purity carbon dioxide stream during steady-state operation, which will be compressed and

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

transported by pipeline off site for injection into deep underground oil reservoirs for enhanced oil recovery and sequestration.

A CO₂ vent stack will allow for infrequent venting of produced CO₂ from the AGR and TGTU when the CO₂ injection system is unavailable, unable to export, or other upset condition. The CO₂ vent will enable HECA to operate, rather than be disabled, by brief periods of gasifier shutdown and subsequent gasifier restart. The CO₂ vent exhaust stream will be nearly all CO₂, with small amounts of CO, VOC, and H₂S.

Due to the infrequent nature of the venting event, the option of using add-on control technology is cost prohibitive for this emission point. In order to reduce the impact of this infrequent venting event, good engineering practice stack height, limited venting duration, and vent gas concentration limits are selected as BACT for this source.

HECA proposed a maximum of 504 hours of venting duration for this unit. The pollutant concentrations in the vent gas are limited to 1,000 ppm for CO, 40 ppm for VOCs, and 10 ppm for H₂S to reduce the overall impact of the venting event.

Good Engineering Practice Stack Height

The USEPA provides specific guidance for determining the Good Engineering Practice (GEP) stack height and for determining whether building downwash will occur in the *Guidance for Determination of Good Engineering Practice Stack Height (Technical Support Document for the Stack Height Regulations)*. GEP is defined as “the height necessary to ensure that emissions from the stack do not result in excessive concentrations of any air pollutant in the immediate vicinity of the source as a result of atmospheric downwash, eddies, and wakes that may be created by the source itself, nearby structures, or nearby terrain obstacles.”

The GEP definition is based on the observed phenomenon of atmospheric flow in the immediate vicinity of a structure. It identifies the minimum stack height at which significant adverse aerodynamics (downwash) are avoided. The U.S. EPA GEP stack height regulations specify that the GEP stack height is calculated in the following manner:

$$H_{\text{GEP}} = H_{\text{B}} + 1.5L$$

where:

H_{B} = the height of adjacent or nearby structures;; and

L = the lesser dimension (height or projected width) of the adjacent or nearby structures.

The regulations also specify that the creditable stack height for modeling purposes is either the GEP stack height as calculated, or a de minimis height of 65 meters.

A 260-foot stack height was chosen to satisfy HEI’s inherently safe design practices to minimize ground-level CO₂ concentrations in the event of a CO₂ vent under very low wind speeds.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

6.9 Gasifier Warming (Refractory Heaters) BACT Analysis

HECA proposed to install three natural-gas-fired gasification refractory heaters, each rated at 18 MMBtu/hr. Each of the three gasification trains will have one natural-gas fired combustor used to warm the gasification refractory to facilitate startup. The heaters are restricted to operate for gasifier startup with maximum total gasifier warming duration of 1,800 hours per year during mature operations.

No examples were found regarding the application of LAER for the case-specific emissions associated with natural gas combustion. To control criteria pollutant emissions from the heaters' natural gas combustion, HECA selected GCPs, natural-gas fuel, and restricted operating hours as BACT for the heaters. The total of potential PM and VOC emissions from the gasifiers are negligible (less than 0.2 tons/year). Therefore, the use of natural gas was determined to be LAER for the heaters. Good combustion practices will optimize the performance of the combustor, thereby minimizing the emission of NO_x and CO. Because the heaters will only combust natural gas, the potential for SO₂, VOC, and PM emissions is minimized. The proposed BACT/LAER emission rates for each gasifier refractory heater are presented in Table 6-9.

Table 6-9
Gasifier Warming (Refractory Heater) Emissions

Pollutant	Emission Limit
NO _x	0.11 lb/MMBtu, HHV
CO	0.09 lb/MMBtu, HHV
PM/ PM ₁₀	0.008 lb/MMBtu, HHV
SO ₂	0.002 lb/MMBtu, HHV (12.65 ppm)
VOC	0.007 lb/MMBtu, HHV

Notes:

- CO = carbon monoxide
- NO_x = oxides of nitrogen
- PM/ PM₁₀ = particulate matter/ particulate matter 10 microns in diameter
- SO₂ = sulfur dioxide
- VOC = volatile organic compound

6.10 Feedstock Handling System BACT Analysis

Two major IGCC feedstock with particulate emission potential are petcoke and fluxant. Petcoke will be delivered to the plant via truck from refineries in the Los Angeles, Santa Maria, or Bakersfield areas, and/or other regional sources. Fluxant will be delivered to the Project Site via truck from regional sources. The transportation and preparation processes related to the feedstock have a potential to emit particulate matter to the atmosphere. The following is the BACT analysis for the proposed feedstock-handling system in HECA.

APPENDIX A

BEST AVAILABLE CONTROL TECHNOLOGY (BACT) SECTION

6.10.1 Particulate Matter BACT Analysis for the Feedstock-Handling System

Because the feedstock preparation processes will be within an enclosed conveyor system, a forced air dust collection system is the most appropriate and common control technology for particulate matter emission control from the emission points.

- Truck Unloading
- Petcoke/coal Silos (filling)
- Mass Flow Bins (in/out)
- Petcoke/coal Silos (loadout)
- Crusher Inlet/Outlet
- Fluxant Bins (filling)

HECA selected dust collection systems consisting of hoods and baghouses as BACT to control particulate emissions from the aforementioned emission points. HECA will have six bag houses, with the maximum dust collector PM emission rate based on expected supplier guarantee of 0.005 grain/scf outlet dust loading.

AA dust collection system using baghouses has been proposed as BACT in other operating and recently permitted IGCC projects. The proposed emission limitation represents a removal efficiency that is comparable with the emission achieved in practice at currently operating IGCC units, and the lowest recently permitted IGCC units.

7.0 REFERENCE

Korens, Nick, et al., 2002. "Process Screening Analysis of Alternative Gas Treating and Sulfur Removal for Gasification." U.S. Department of Energy. National Energy Technology Laboratory. December 2002. SFA Pacific, Inc. Mountain View, California. Available online at <http://www.netl.doe.gov/technologies/coalpower/gasification/pubs/pdf/SFA%20Pacific_Process%20Screening%20Analysis_Dec%202002.pdf>

IGCC Permits and Applications for Cash Creek Generating Station, Edwardsport Generating Station, and Taylorville Energy Center.

CEC, 2007. Final Decision Panoche Energy Center.

Appendix B

Emissions

Modeling Parameters for Emission Sources

Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

		CTG/HRSG , H2-rich Fuel			CTG/HRSG , Natural Gas Fuel			CTG/HRSG Co-Firing **	Auxiliary CTG		
		100% Load ⁽²⁾	80% Load	60% Load	100% Load ⁽³⁾	80% Load	60% Load	100% Load	100% Load	75% Load	50% Load
English Units											
Stack height above grade ⁽¹⁾	ft	213	213	213	213	213	213	213	110	110	110
Stack diameter	ft	20	20	20	20	20	20	20	16	16	16
Stack outlet temperature	° F	200	190	180	180	170	160	190	740	740	760
Stack exit flow, act	ft ³ /s	19,900	16,300	13,400	16,700	14,300	11,900	18,300	14,100	12,400	10,100
Metric Units											
Stack height above grade ⁽¹⁾	m	65.0	65.0	65.0	65.0	65.0	65.0	65.0	33.5	33.5	33.5
Stack diameter	m	6.1	6.1	6.1	6.1	6.1	6.1	6.1	4.9	4.9	4.9
Stack outlet temperature	K	366.5	360.9	355.4	355.4	349.8	344.3	360.9	666.5	666.5	677.6
Stack exit flow, act	m ³ /s	563.5	461.6	379.4	472.9	404.9	337.0	518.2	399.3	351.1	286.0
Stack Area	m ²	29.2	29.2	29.2	29.2	29.2	29.2	29.2	18.7	18.7	18.7
Stack exit velocity, act	m/s	19.3	15.8	13.0	16.2	13.9	11.5	17.8	21.4	18.8	15.3

Parameter		Aux Boiler	Gasification Flare(4)	SRU Flare(6)	Rectisol Flare (6)	Tail Gas Oxidizer ⁽⁷⁾	Gasifier Warming Vent (ea.)	Cooling Towers (per cell) ⁽⁵⁾	Diesel Generator (ea.)	Fire Pump Engine	CO ₂ Vent
English Units											
Stack height above grade ⁽¹⁾	ft	80	250	250	250	165	210	55	20	20	260
Stack diameter	ft	4.5	9.8	2	1.3	2.5	1.0	30	1.2	0.7	3.5
Stack outlet temperature	° F	300	(NA)	(NA)	(NA)	1200	150	75	760	850	65
Stack exit flow, act	ft ³ /s	480	0.5/900	0.3/36	0.3	120	68	18,500	250	60	1,765
Metric Units											
Stack height above grade ⁽¹⁾	m	24.4	76.2	76.2	76.2	50.3	64.0	16.8	6.1	6.1	79.2
Stack diameter	m	1.4	3.0	0.6	0.4	0.8	0.3	9.1	0.4	0.2	1.1
Stack outlet temperature	K	422.0	(NA)	(NA)	(NA)	922.0	338.7	297.0	677.6	727.6	291.5
Stack exit flow, act	m ³ /s	13.6	0.01/25.49	0.01/1.02	0.01	3.4	1.9	523.9	7.1	1.7	50.0
Stack Area	m ²	1.5	7.0	0.3	0.1	0.5	0.1	65.7	0.1	0.0	0.9
Stack exit velocity, act	m/s	9.2	0.001/3.64	0.03/3.4	0.1	7.5	26.4	8.0	67.4	47.5	55.9

Notes:

(1) Minimum stack height assumed for worst-case dispersion.

(2) Volume Flow Value shown in table for H2-rich fuel is based on full load syn gas combustion (relatively constant for varying ambient temperatures). Duct firing of the HSRG changes the stack volumetric flow by about 1% or less.

(3) Full load stack flow for natural gas combustion will vary from the value shown in the table during warm summer ambient temperatures to about 18,000 act ft3/sec for winter ambient temperatures. Stack flow rates for co-firing of H2-rich gas and natural gas will range between the values shown for the two fuels separately.

(4) Based on gasifier startup; stack parameters estimated from a previous project, to be confirmed by current flare suppliers.

(5) Thirteen cells estimated for power block cooling tower; four cells estimated for process cooling tower, and four cells estimated for the ASU cooling tower.

(6) Waste gas heat release, 10*6 Btu/hr, HHV. First exit flow value is normal pilot gas, the second value is the maximum startup heat release (Rectisol Flare has no planned operation than standby with pilot on)

(7) Estimated oxidizer stack outlet flow for normal operating case of miscellaneous vent gas disposal; SRU startup case will be about 50% greater.

** HRSG Stack Cofiring is estimated assuming 47% Syngas and the balance natural gas

Modeling Parameters for Emission Sources
Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Parameter		Feed Stock - Dust Collection Units								
		DC-1	DC-2	DC-3	DC-4	DC-5	DC-6			
English Units										
Ground elevation	ft	289	289	289	289	289	289			
Stack elevation	ft	314	459	428	314	368	428			
Stack height above grade	ft	25	170	139	25	79	139			
Stack diameter	ft	1.7	2.7	1.8	1.4	1.4	0.8			
Stack outlet temperature ⁽¹⁾	° F	Ambient	Ambient	Ambient	Ambient	Ambient	Ambient			
Stack exit flow, act	ft ³ /s	108	273	127	81	78	21			
Metric Units										
Stack height above grade	m	7.6	51.8	42.4	7.6	24.1	42.4			
Stack diameter	m	0.5	0.8	0.6	0.4	0.4	0.2			
Stack outlet temperature ⁽¹⁾	K	Ambient	Ambient	Ambient	Ambient	Ambient	Ambient			
Stack exit flow, act	m ³ /s	3.1	7.7	3.6	2.3	2.2	0.6			
Stack Area	m ²	0.2	0.5	0.2	0.1	0.1	0.0			
Stack exit velocity, act	m/s	15.0	14.9	14.7	15.7	15.1	14.2			

(1) Assume ambient temperature

Total Project Modeling Emission Rates

Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 1 hr Emissions																				
	CTG/HRSG Maximum ⁽¹⁾	Auxiliary CTG	Cooling Towers ⁽²⁾			Auxiliary Boiler	Emergency Generators ⁽³⁾	Fire Water Pump	Gasification Flare	SRU Flare	Rectisol Flare	Tg Thermal Oxidizer	CO ₂ Vent	Gasifier ⁽⁴⁾	Feedstock					
															DC-1 (g/sec)	DC-2 (g/sec)	DC-3 (g/sec)	DC-4 (g/sec)	DC-5 (g/sec)	DC-6 (g/sec)
			Power Block (g/sec/cell)	Process Area (g/sec/cell)	ASU (g/sec/cell)										(g/sec)	(g/sec/gen)	(g/sec)	(g/sec)	(g/sec)	(g/sec)
NOx	21.0	2.6	--	--	--	0.2	0.4	0.2	7.9	0.544	0.005	0.6	--	0.2	--	--	--	--	--	--
CO	211.6	8.7	--	--	--	0.7	0.2	0.4	113.4	0.363	0.003	0.5	53.4	0.2	--	--	--	--	--	--
SO ₂	0.9	0.2	--	--	--	0.04	0.004	0.0007	0.0001	2.19	0.0001	0.3	--	0.00	--	--	--	--	--	--
H ₂ S	--	--	--	--	--	--	--	--	--	--	--	--	0.6	--	--	--	--	--	--	--

- (1) HRSG modeling emission rates represents the maximum emissions rate from a composite firing scenario (all three fuels)
- (2) There are three separate cooling towers. The modeling rates are per cell.
- (3) There are two separate generators. Modeling rates are shown per individual generator.
- (4) There are three gasifiers. The modeling rate shown is per individual gasifier. However, only one gasifier warming will be operational at any one time.

Modeling Worst-Case 3 hr Emissions																				
	CTG/HRSG Maximum ⁽¹⁾	Auxiliary CTG	Cooling Towers ⁽²⁾			Auxiliary Boiler	Emergency Generators ⁽³⁾	Fire Water Pump	Gasification Flare	SRU Flare	Rectisol Flare	Tg Thermal Oxidizer	CO ₂ Vent	Gasifier ⁽⁴⁾	Feedstock					
			Power Block (g/sec/cell)	Process Area (g/sec/cell)	ASU (g/sec/cell)										DC-1 (g/sec)	DC-2 (g/sec)	DC-3 (g/sec)	DC-4 (g/sec)	DC-5 (g/sec)	DC-6 (g/sec)
SO ₂	0.9	0.2	--	--	--	0.04	0.002	0.0005	0.0001	2.19	0.00	0.3	--	0.00	--	--	--	--	--	

- (1) HRSG modeling emission rates represents the maximum emissions rate from a composite firing scenario (all three fuels)
- (2) There are three separate cooling towers. The modeling rates are per cell.
- (3) There are two separate generators. Modeling rates are shown per individual generator.
- (4) There are three gasifiers. The modeling rate shown is per individual gasifier. However, only one gasifier warming will be operational at any one time.

Modeling Worst-Case 8 hr Emissions																				
	CTG/HRSG Maximum ⁽¹⁾	Auxiliary CTG	Cooling Towers ⁽²⁾			Auxiliary Boiler	Emergency Generators ⁽³⁾	Fire Water Pump	Gasification Flare	SRU Flare	Rectisol Flare	Tg Thermal Oxidizer	CO ₂ Vent	Gasifier ⁽⁴⁾	Feedstock					
															Power Block (g/sec/cell)	Process Area (g/sec/cell)	ASU (g/sec/cell)	DC-1 (g/sec)	DC-2 (g/sec)	DC-3 (g/sec)
			(g/sec)	(g/sec)	(g/sec/cell)										(g/sec/cell)	(g/sec/cell)	(g/sec)	(g/sec/gen)	(g/sec)	(g/sec)
CO	164.9	2.7	--	--	--	0.7	0.06	0.1	113.4	0.138	0.003	0.5	53.4	0.2	--	--	--	--	--	--

- (1) HRSG modeling emission rates represents the maximum emissions rate from a composite firing scenario (all three fuels)
- (2) There are three separate cooling towers. The modeling rates are per cell.
- (3) There are two separate generators. Modeling rates are shown per individual generator.
- (4) There are three gasifiers. The modeling rate shown is per individual gasifier. However, only one gasifier warming will be operational at any one time.

Total Project Modeling Emission Rates

Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 24 Hour Emission Rate																				
	CTG/HRSG Maximum ⁽¹⁾ (g/sec)	Auxiliary CTG (g/sec)	Cooling Towers ⁽²⁾			Auxiliary Boiler (g/sec)	Emergency Generators ⁽³⁾ (g/sec/gen)	Fire Water Pump (g/sec)	Gasification Flare (g/sec)	SRU Flare (g/sec)	Rectisol Flare (g/sec)	Tg Thermal Oxidizer (g/sec)	CO ₂ Vent (g/sec)	Gasifier ⁽⁴⁾ (g/sec)	Feedstock					
			Power Block (g/sec/cell)	Process Area (g/sec/cell)	ASU (g/sec/cell)										DC-1 (g/sec)	DC-2 (g/sec)	DC-3 (g/sec)	DC-4 (g/sec)	DC-5 (g/sec)	DC-6 (g/sec)
SO ₂	0.9	0.2	--	--	--	0.04	0.0003	0.0001	0.0001	0.2742	0.0001	0.3	--	0.00	--	--	--	--	--	
PM ₁₀	3.0	0.8	0.038	0.030	0.028	0.09	0.002	0.0002	0.0002	0.0018	0.0001	0.02	--	0.02	0.030	0.076	0.041	0.026	0.025	
PM _{2.5} ⁽⁵⁾	3.0	0.8	0.023	0.018	0.017	0.09	0.002	0.0002	0.0002	0.0018	0.0001	0.02	--	0.02	0.009	0.022	0.012	0.008	0.007	

- (1) HRSG modeling emission rates represents the maximum emissions rate from a composite firing scenario (all three fuels)
- (2) There are three separate cooling towers. The modeling rates are per cell.
- (3) There are two separate generators. Modeling rates are shown per individual generator.
- (4) There are three gasifiers. The modeling rate shown is per individual gasifier. However, only one gasifier warming will be operational at any one time.
- (5) Where PM₁₀ = PM_{2.5}, it is assumed that PM₁₀ is 100% PM_{2.5}

Modeling Annual Average Emission Rate																				
	CTG/HRSG Maximum ⁽¹⁾ (g/sec)	Auxiliary CTG (g/sec)	Cooling Towers ⁽²⁾			Auxiliary Boiler (g/sec)	Emergency Generators ⁽³⁾ (g/sec/gen)	Fire Water Pump (g/sec)	Gasification Flare (g/sec)	SRU Flare (g/sec)	Rectisol Flare (g/sec)	Tg Thermal Oxidizer (g/sec)	CO ₂ Vent (g/sec)	Gasifier ⁽⁴⁾ (g/sec)	Feedstock					
			Power Block (g/sec/cell)	Process Area (g/sec/cell)	ASU (g/sec/cell)										DC-1 (g/sec)	DC-2 (g/sec)	DC-3 (g/sec)	DC-4 (g/sec)	DC-5 (g/sec)	DC-6 (g/sec)
NO _x	4.8	0.5	--	--	--	0.05	0.002	0.003	0.1	0.005	0.005	0.3	--	0.05	--	--	--	--	--	--
CO	4.3	0.8	--	--	--	0.2	0.001	0.005	1.4	0.003	0.003	0.26	3.1	0.04194	--	--	--	--	--	--
VOC	0.9	0.1	--	--	--	0.02	0.0005	0.0002	0.0001	0.00005	0.00005	0.01	0.1	0.00326	--	--	--	--	--	--
SO ₂	0.8	0.1	--	--	--	0.01	0.00002	0.00001	0.0001	0.0016	0.0001	0.3	--	0.00095	--	--	--	--	--	--
PM ₁₀	2.9	0.4	0.036	0.028	0.027	0.02	0.0001	0.00003	0.0002	0.0001	0.0001	0.01	--	0.004	0.006	0.015	0.036	0.023	0.022	0.0004
PM _{2.5} ⁽⁵⁾	2.9	0.4	0.022	0.017	0.016	0.02	0.0001	0.00003	0.0002	0.0001	0.0001	0.01	--	0.004	0.002	0.004	0.011	0.0068	0.007	0.0001
H ₂ S	--	--	--	--	--	--	--	--	--	--	--	--	0.0	--	--	--	--	--	--	--

- (1) HRSG modeling emission rates represents the maximum emissions rate from a composite firing scenario (all three fuels)
- (2) There are three separate cooling towers. The modeling rates are per cell.
- (3) There are two separate generators. Modeling rates are shown per individual generator.
- (4) There are three gasifiers. The modeling rate shown is per individual gasifier. However, only one gasifier warming will be operational at any one time.
- (5) Where PM₁₀ = PM_{2.5}, it is assumed that PM₁₀ is 100% PM_{2.5}

Total Annual Project Emissions

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Pollutant	Total Annual (ton/yr)	CTG/HRSG Maximum ⁽¹⁾ (ton/yr)	Auxiliary CTG (ton/yr)	Cooling Towers ⁽²⁾ (ton/yr)	Auxiliary Boiler (ton/yr)	Emergency Generators ⁽³⁾ (ton/yr)	Fire Water Pump (ton/yr)	Gasification Flare (ton/yr)	SRU Flare (ton/yr)	Rectisol Flare (ton/yr)	Tg Thermal Oxidizer (ton/yr)	CO ₂ Vent (ton/yr)	Gasifier Warming (ton/yr)	Feedstock ⁽⁴⁾ (ton/yr)
NO _x	203.8	167.2	17.4	--	1.7	0.2	0.1	4.3	0.2	0.2	10.9	--	1.8	--
CO	350.3	150.2	27.6	--	5.8	0.1	0.2	48.8	0.1	0.1	9.1	106.9	1.5	--
VOC	40.7	32.5	4.6	--	0.6	0.03	0.01	0.003	0.002	0.002	0.3	2.4	0.1	--
SO ₂	42.2	29.2	3.8	--	0.3	0.001	0.0003	0.004	0.055	0.003	8.8	--	0.03	--
PM ₁₀	141.1	99.7	12.3	24.1	0.8	0.01	0.001	0.007	0.004	0.004	0.4	--	0.1	3.6
PM _{2.5} ⁽⁵⁾	128.9	99.7	12.3	14.5	0.8	0.01	0.001	0.007	0.004	0.004	0.4	--	0.1	1.0
NH ₃	100.0	75.9	24.1	--	--	--	--	--	--	--	--	--	--	--
H ₂ S	1.3	--	--	--	--	--	--	--	--	--	--	1.3	--	--
CO ₂ e ⁽⁶⁾	383,317	5,290	198,200	--	16,466	146	29	6,348	176	139	4,797	150,011	1,716	--

(1) Total annual HRSG emissions represents the maximum emissions rate from a composite firing scenario (all three fuels)

(2) Includes contributions from all three cooling towers

(3) Includes contributions from both emergency generators

(4) Feedstock emissions are shown as the contribution of all dust collection points.

(5) Where PM₁₀ = PM_{2.5}, it is assumed that PM₁₀ is 100% PM_{2.5}

(6) CO₂e emission rates are shown as metric tons (tonnes)

CTG/HRSG Stack - Comparison of all Firing Scenarios**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Summary of CTG/HRSG Emission Rates Under the Three Different Firing Scenarios**Average Annual Emissions per Turbine**

	CTG/HRSG - Nat Gas (ton/yr/CT)	CTG/HRSG - Syn Gas (ton/yr/CT)	CTG/HRSG - Co Firing (ton/yr/CT)	Maximum (ton/yr/CT)
NO _x	148.0	167.2	162.9	167.2
CO	138.9	103.5	150.2	150.2
VOC	30.0	19.0	32.5	32.5
SO ₂	20.0	28.4	29.2	29.2
PM ₁₀ = PM _{2.5}	74.9	99.7	99.7	99.7
NH ₃	67.1	75.9	73.9	75.9

Modeling Worst-Case 1 hr Emissions per Turbine

	CTG/HRSG - Nat Gas (g/sec/CT)	CTG/HRSG - Syn Gas (g/sec/CT)	CTG/HRSG - Co Firing (g/sec/CT)	Maximum (g/sec/CT)
NO _x	21.0	21.0	21.0	21.0
CO	211.6	211.6	211.6	211.6
SO ₂	0.6	0.86	0.93	0.9

Modeling Worst-Case 3 hr Emissions per Turbine

	CTG/HRSG - Nat Gas (g/sec/CT)	CTG/HRSG - Syn Gas (g/sec/CT)	CTG/HRSG - Co Firing (g/sec/CT)	Maximum (g/sec/CT)
SO ₂	0.6	0.86	0.93	0.9

CTG/HRSG Stack - Comparison of all Firing Scenarios**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 8 hr Emissions per Turbine

	CTG/HRSG - Nat Gas (g/sec/CT)	CTG/HRSG - Syn Gas (g/sec/CT)	CTG/HRSG - Co Firing (g/sec/CT)	Maximum (g/sec/CT)
CO	164.9	164.8	164.9	164.9

Modeling Worst-Case 24 Hour Emission Rate

	CTG/HRSG - Nat Gas (g/sec/CT)	CTG/HRSG - Syn Gas (g/sec/CT)	CTG/HRSG - Co Firing (g/sec/CT)	Maximum (g/sec/CT)
SO ₂	0.6	0.86	0.93	0.9
PM ₁₀ = PM _{2.5}	2.4	3.0	3.0	3.0

Modeling Annual Average Emission Rate per Turbine

	CTG/HRSG - Nat Gas (g/sec/CT)	CTG/HRSG - Syn Gas (g/sec/CT)	CTG/HRSG - Co Firing (g/sec/CT)	Maximum (g/sec/CT)
NO _x	4.3	4.8	4.7	4.8
CO	4.0	3.0	4.3	4.3
VOC	0.9	0.5	0.9	0.9
SO ₂	0.6	0.82	0.84	0.8
PM ₁₀ = PM _{2.5}	2.2	2.9	2.9	2.9

CTG/HRSG Stack - Natural Gas

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

CTG Operating Parameters

Ambient Temperature	UNITS	Winter Minimum - 20°F				Yearly Average- 65°F				Summer Maximum - 97°F			
CTG Load Level	Percent Load (%)	100%	100%	80%	60%	100%	100%	80%	60%	100%	100%	80%	60%
Evap Cooling Status	off / on	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Duct Burner Status	off / on	On	Off	Off	Off	On	Off	Off	Off	On	Off	Off	Off

Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation

	UNITS	Winter Minimum - 20°F				Yearly Average- 65°F				Summer Maximum - 97°F			
NO _x (@ 4.0 ppm)	lbm/hr	36.3	29.0	24.8	20.8	35.1	27.0	23.1	19.4	33.3	26.1	22.4	18.7
CO (@ 5.0 ppm)	lbm/hr	27.6	22.1	18.8	15.8	26.7	20.5	17.6	14.8	25.3	19.8	17.0	14.2
VOC (@ 2.0 ppm)	lbm/hr	6.3	5.0	4.3	3.6	6.1	4.7	4.0	3.4	5.8	4.5	3.9	3.2
SO ₂ (@ 12.65 ppmv)	lbm/hr	5.1	4.1	3.5	3.0	4.8	3.8	3.3	2.8	4.7	3.7	3.2	2.7
PM ₁₀ = PM _{2.5}	lbm/hr	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0
NH ₃ (@ 5.0 ppm slip)	lbm/hr	16.7	13.4	11.4	9.6	16.2	12.5	10.7	9.0	15.4	12.1	10.3	8.6

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

Startup / Shutdown Emissions from Turbine (1CT)

Cold Startup			Hot Startup			Shutdown		
180 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/180min)	60 (min. in hot startup)	Max 1-hr. (lb/hr)	Total (lb/60min)	30 (min. in shutdown)	Max 1-hr. (lb/hr)	Total (lb/30min)
NO _x	90.7	272.0	NO _x	167.0	167.0	NO _x	62.0	62.0
CO	1,679.7	5,039.0	CO	394.0	394.0	CO	126.0	126.0
VOC	266.7	800.0	VOC	98.0	98.0	VOC	21.0	21.0
SO ₂ (@ 12.65 ppmv)	5.1	15.3	SO ₂	5.1	5.1	SO ₂	2.6	2.6
PM ₁₀ = PM _{2.5}	21.3	64.0	PM ₁₀ = PM _{2.5}	23.0	23.0	PM ₁₀ = PM _{2.5}	5.0	5.0

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

Startup and shutdown SO₂ emissions will always be lower than normal operation SO₂ emissions. Startup and shutdown emissions are assumed equal to the normal operations max emission rate.

Average Annual Emissions

Total Hours of Operation	8,322.0		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT	Emissions g/sec/CT
Total Number of Cold Starts	10.0		NO _x	296,044.0	148.0	4.3
Cold Start Duration (hr)	3.0		CO	277,817.2	138.9	4.0
Total Number of Hot Starts	10.0		VOC	59,906.8	30.0	0.9
Hot Start Duration (hr)	1.0		SO ₂	40,045.4	20.0	0.6
Total Number of Shutdowns	20.0		PM ₁₀ = PM _{2.5}	149,866.0	74.9	2.2
Shutdown Duration (hr)	0.5		NH ₃	134,158.6	67.1	1.9
Duct Burner Operation (hr)	8,272.0					
Average Normal Operation (hr)	0.0					
Assumptions: Average annual normal operational emissions are calculated using yearly average- 65°F, at 100 % load. Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.						

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Hydrogen Energy, Inc
HECA Project

6/30/2009

First Quarter Emissions (Jan, Feb, Mar)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	74,011.0	37.0
Total Number of Hot Starts	2.5		CO	69,454.3	34.7
Hot Start Duration (hr)	1.0		VOC	14,976.7	7.5
Total Number of Shutdowns	5.0		SO ₂	10,011.4	5.0
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	37,466.5	18.7
Duct Burner Operation (hr)	2,068.0		NH ₃	33,539.7	16.8
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65F, at 100 % load with duct burners.					

Second Quarter Emissions (Apr, May, Jun)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	74,011.0	37.0
Total Number of Hot Starts	2.5		CO	69,454.3	34.7
Hot Start Duration (hr)	1.0		VOC	14,976.7	7.5
Total Number of Shutdowns	5.0		SO ₂	10,011.4	5.0
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	37,466.5	18.7
Duct Burner Operation (hr)	2,068.0		NH ₃	33,539.7	16.8
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Modeling Worst-Case 1 hr Emissions per Turbine

Pollutant	lb/hr/CT	g/sec/CT
NOx	167.0	21.0
CO	1,679.7	211.6
SO ₂	5.1	0.6
Assumptions:		
Startup emissions represent worst case hr for NOx and CO.		
NOx emissions are from hot start		
CO emissions are from cold start		
Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational SO ₂ emissions.		

Modeling Worst-Case 3 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT
Total Hours of Operation	3.0		
Startup Duration	0.0		0.0
Shutdown Duration	0.0		0.0
Hours of Normal Operation (burning natural gas)	3.0	5.1	15.3
SO ₂ worst-case 3 hr emissions per turbine	15.3	lb/3 hr	
SO ₂ worst-case 1 hr emissions per turbine	5.1	lb/hr	
SO ₂ modeling worst-case emissions per turbine	0.6	g/sec	
Assumptions:			
Only SO ₂ is considered for an average 3-hour Ambient Air Quality Standard.			
Normal operation assumes max emission rate			
Worst-case 3 hr emissions assumes a total start up of :	0		
Worst-case 3 hr emissions assumes a total shut down of :	0		
Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational SO ₂ emissions			

Third Quarter Emissions (Jul, Aug, Sep)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	74,011.0	37.0
Total Number of Hot Starts	2.5		CO	69,454.3	34.7
Hot Start Duration (hr)	1.0		VOC	14,976.7	7.5
Total Number of Shutdowns	5.0		SO ₂	10,011.4	5.0
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	37,466.5	18.7
Duct Burner Operation (hr)	2,068.0		NH ₃	33,539.7	16.8
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Fourth Quarter Emissions (Oct, Nov, Dec)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions	Emissions
Total Number of Cold Starts	2.5			lb/yr/CT	ton/yr/CT
Cold Start Duration (hr)	3.0		NO _x	74,011.0	37.0
Total Number of Hot Starts	2.5		CO	69,454.3	34.7
Hot Start Duration (hr)	1.0		VOC	14,976.7	7.5
Total Number of Shutdowns	5.0		SO ₂	10,011.4	5.0
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	37,466.5	18.7
Duct Burner Operation (hr)	2,068.0		NH ₃	33,539.7	16.8
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 8 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	8.0			
Startup Duration (cold start)	6.0		10,078.0	contribution over 8 hr from start up
Shutdown Duration	1.5		378.0	contribution over 8 hr from shut down
Hours of Normal Operation (burning natural gas)	0.5	27.6	13.8	contribution over 8 hr from normal operation
CO worst-case 8 hr emissions per turbine	10,469.8	lb/8 hr		
CO worst-case 1 hr emissions per turbine	1,308.7	lb/hr		
CO modeling worst-case emissions per turbine	164.9	g/sec		
Assumptions:				
Only CO is considered for an average 8-hour Ambient Air Quality Standard.				
Normal operation assumes max emission rate				
Worst-case 8 hr emissions assumes a total COLD start up of :				
Worst-case 8 hr emissions assumes a total shut down of :				

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

SO ₂ (lb/day/CT)	122.4
SO ₂ (g/s/CT) (burning natural gas)	0.6
PM ₁₀ = PM _{2.5} (lb/day/CT)	
PM ₁₀ = PM _{2.5} (g/s/CT) (burning natural gas)	
Assumptions:	
Only SO ₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.	
For SO ₂ 24 hrs of normal operation at max emission rate	
For PM emissions are calculated below assuming startup and shutdown contributions.	

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

Pollutant	Time in Startup hr	Startup Emission Rate lb/start	Time in Shut Down hr	Shutdown Emission Rate lb/shutdown	Time in Normal Operation hr	Normal Operation Emission Rate lb/start	Worst-Case Daily Emissions lb/day/CT	Modeling Worst- Case 24 Hr Emission g/s/CT
Nox (1 COLD start up and 1 shut down)	3.0	272.0	0.5	62.0	17.5	36.3	1,426.4	7.5
Nox (2 HOT start ups and 2 shut downs)	2.0	167.0	1.0	62.0				
CO	12.0	5,039.0	2.0	126.0	10.0	27.6	20,935.8	
VOC	12.0	800.0	2.0	21.0	10.0	6.3	3,347.0	
SO ₂								
PM ₁₀ = PM _{2.5}	12.0	64.0	2.0	5.0	10.0	18.0	456.0	2.4
Assumptions:								
For CO, VOC, and PM -- emissions are calculated assuming:								
Worst-case daily emissions assumes a total COLD start up of :	4							
Worst-case daily emissions assumes a total shut down of :	4							
Remainder of time is spent in normal operation at winter minimum - 20°F; 100% load								
For CALPUFF modeling purposes, NOx emissions are calculated assuming:								
Worst-case daily emissions assumes a total COLD start up of :	1	and a total HOT start up of:	2					
Worst-case daily emissions assumes a total shut down of :	3							
Remainder of time is spent in normal operation at winter minimum - 20°F; 100% load								
See above calculation for worst-case daily SO ₂ ;calculated as 24 hrs of normal operation at max emissions rate								

CTG/HRSG Stack - SynGas

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

CTG Operating Parameters

Ambient Temperature	UNITS	Winter Minimum - 20°F				Yearly Average- 65°F				Summer Maximum - 97°F			
CTG Load Level	Percent Load (%)	100%	100%	80%	60%	100%	100%	80%	60%	100%	100%	80%	60%
Evap Cooling Status	off / on	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Duct Burner Status	off / on	On	Off	Off	Off	On	Off	Off	Off	On	Off	Off	Off

Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation

	UNITS	Winter Minimum - 20°F				Yearly Average- 65°F				Summer Maximum - 97°F			
NO _x (@ 4.0 ppm)	lbm/hr		37.2	31.5	26.1	39.7	36.9	31.0	25.6	39.7	38.0	30.9	25.6
CO (@ 3.0 ppm)	lbm/hr		17.0	14.4	11.9	18.1	16.8	14.1	11.7	18.1	17.4	14.1	11.7
VOC (@ 1.0 ppm)	lbm/hr		3.2	2.7	2.3	3.5	3.2	2.7	2.2	3.5	3.3	2.7	2.2
SO ₂ (@ 5.0 ppmv)	lbm/hr		6.1	5.2	4.4	6.8	6.1	5.1	4.3	6.8	6.0	5.1	4.3
PM ₁₀ = PM _{2.5}	lbm/hr		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
NH ₃ (@ 5.0 ppm slip)	lbm/hr		17.2	14.6	12.0	18.4	17.0	14.3	11.8	18.4	17.6	14.3	11.8

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

Startup / Shutdown Emissions from Turbine (1CT)

Cold Startup			Hot Startup			Shutdown		
180 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/180min)	60 (min. in hot startup)	Max 1-hr. (lb/hr)	Total (lb/60min)	30 (min. in shutdown)	Max 1-hr. (lb/hr)	Total (lb/30min)
NO _x	90.7	272.0	NO _x	167.0	167.0	NO _x	62.0	62.0
CO	1,679.7	5,039.0	CO	394.0	394.0	CO	126.0	126.0
VOC	266.7	800.0	VOC	98.0	98.0	VOC	21.0	21.0
SO ₂ (@ 12.65 ppmv)	5.1	15.3	SO ₂	5.1	5.1	SO ₂	2.6	2.6
PM ₁₀ = PM _{2.5}	21.3	64.0	PM ₁₀ = PM _{2.5}	23.0	23.0	PM ₁₀ = PM _{2.5}	5.0	5.0

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

CTGs will always be started burning natural gas. Startup and shutdown emission rates above reflect natural gas.

Startup and shutdown SO₂ emissions will always be lower than normal operation SO₂ emissions. Startup and shutdown emissions are assumed equal to normal operations (burning natural gas) at the max emission rate.

Average Annual Emissions

			Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT	Emissions g/sec/CT
Total Hours of Operation	8,322.0					
Total Number of Cold Starts	10.0					
Cold Start Duration (hr)	3.0		NO _x	334,353.0	167.2	4.8
Total Number of Hot Starts	10.0		CO	206,919.2	103.5	3.0
Hot Start Duration (hr)	1.0		VOC	37,984.6	19.0	0.5
Total Number of Shutdowns	20.0		SO ₂	56,713.0	28.4	0.8
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	199,498.0	99.7	2.9
Duct Burner Operation (hr)	8,272.0		NH ₃	151,855.7	75.9	2.2
Average Normal Operation (hr)	0.0					

Assumptions:

Average annual normal operational emissions are calculated using yearly average- 65°F, at 100 % load.

Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Hydrogen Energy, Inc
HECA Project

6/30/2009

First Quarter Emissions (Jan, Feb, Mar)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	83,588.3	41.8
Total Number of Hot Starts	2.5		CO	51,729.8	25.9
Hot Start Duration (hr)	1.0		VOC	9,496.2	4.7
Total Number of Shutdowns	5.0		SO ₂	14,178.3	7.1
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	37,963.9	19.0
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Second Quarter Emissions (Apr, May, Jun)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions	Emissions
Total Number of Cold Starts	2.5			lb/yr/CT	ton/yr/CT
Cold Start Duration (hr)	3.0		NO _x	83,588.3	41.8
Total Number of Hot Starts	2.5		CO	51,729.8	25.9
Hot Start Duration (hr)	1.0		VOC	9,496.2	4.7
Total Number of Shutdowns	5.0		SO ₂	14,178.3	7.1
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	37,963.9	19.0
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Modeling Worst-Case 1 hr Emissions per Turbine

Pollutant	lb/hr/CT	g/sec/CT
NOx	167.0	21.0
CO	1,679.7	211.6
SO ₂	6.8	0.9
Assumptions: Startup emissions represent worst case hr for NOx and CO. Startup and shutdown only burn natural gas. NOx emissions are from hot start CO emissions are from cold start Normal operation burning syngas represents worst case SO ₂ . Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational (burning natural gas) SO ₂ emissions.		

Modeling Worst-Case 3 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	3.0			
Startup Duration	0.0		0.0	contribution over 3 hr from start up
Shutdown Duration	0.0		0.0	contribution over 3 hr from shut down
Hours of Normal Operation (burning syngas)	3.0	6.8	20.5	contribution over 3 hr from normal operation
SO ₂ worst-case 3 hr emissions per turbine	20.5	lb/3 hr		
SO ₂ worst-case 1 hr emissions per turbine	6.8	lb/hr		
SO ₂ modeling worst-case emissions per turbine	0.9	g/sec		
Assumptions: Only SO ₂ is considered for an average 3-hour Ambient Air Quality Standard. Normal operation burning syngas represents worst case SO ₂ . Worst-case 3 hr emissions assumes a total start up of : 0 Worst-case 3 hr emissions assumes a total shut down of : 0 Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational (burning natural gas) SO ₂ emissions.				

Third Quarter Emissions (Jul, Aug, Sep)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	83,588.3	41.8
Total Number of Hot Starts	2.5		CO	51,729.8	25.9
Hot Start Duration (hr)	1.0		VOC	9,496.2	4.7
Total Number of Shutdowns	5.0		SO ₂	14,178.3	7.1
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	37,963.9	19.0
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Fourth Quarter Emissions (Oct, Nov, Dec)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	83,588.3	41.8
Total Number of Hot Starts	2.5		CO	51,729.8	25.9
Hot Start Duration (hr)	1.0		VOC	9,496.2	4.7
Total Number of Shutdowns	5.0		SO ₂	14,178.3	7.1
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	37,963.9	19.0
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 8 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	8.0			
Startup Duration	6.0		10,078.0	contribution over 8 hr from start up
Shutdown Duration	1.5		378.0	contribution over 8 hr from shut down
Hours of Normal Operation (burning syngas)	0.5	18.1	9.1	contribution over 8 hr from normal operation
CO worst-case 8 hr emissions per turbine	10,465.1	lb/8 hr		
CO worst-case 1 hr emissions per turbine	1,308.1	lb/hr		
CO modeling worst-case emissions per turbine	164.8	g/sec		
Assumptions:				
Only CO is considered for an average 8-hour Ambient Air Quality Standard.				
Normal operation assumes max rate.				
Worst-case 8 hr emissions assumes a total COLD start up of :	2			
Worst-case 8 hr emissions assumes a total shut down of :	3			

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

SO ₂ (lb/day/CT)	163.8
SO ₂ (g/s/CT) (burning syngas)	0.9
PM ₁₀ = PM _{2.5} (lb/day/CT)	576.0
PM ₁₀ = PM _{2.5} (g/s/CT) (burning syngas)	3.0
Assumptions:	
Only SO ₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.	
For SO ₂ 24 hrs of normal operation max emission rate	
For PM 24 hrs of normal operation max emission rate	

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

	Time in Startup hr	Startup Emission Rate lb/start	Time in Shut Down hr	Shutdown Emission Rate lb/shutdown	Time in Normal Operation hr	Normal Operation Emission Rate lb/start	Worst-Case Daily Emissions lb/day/CT	Modeling Worst- Case 24 Hr Emission g/s/CT	
Pollutant									
NOx	12.0	272.0	2.0	62.0	10.0	39.7	1,733.4		
CO	12.0	5,039.0	2.0	126.0	10.0	18.1	20,841.4		
VOC	12.0	800.0	2.0	21.0	10.0	3.5	3,318.6		
SO ₂									
PM ₁₀ = PM _{2.5}									
Assumptions:									
For NOx, CO, and VOC -- emissions are calculated assuming:									
Worst-case daily emissions assumes a total start up of :	4								
Worst-case daily emissions assumes a total shut down of :	4								
Remainder of time is spent in normal operation at max emission rate									
See above calculation for worst-case daily SO ₂ and PM: calculated as 24 hrs of normal operationat max emissions rate									

CTG/HRSG Stack - Co Firing

Hydrogen Energy, Inc
HECA Project

CTG Operating Parameters

Ambient Temperature	UNITS	Winter Minimum - 20°F					
CTG Load Level	Percent Load (%)	100%	100%	80%	60%	100%	
Evap Cooling Status	off / on	N/A	N/A	N/A	N/A	N/A	
Duct Burner Status	off / on	On	Off	Off	Off	On	

Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation

	UNITS	Winter Minimum - 20°F					
NO _x (@ 4.0 ppm)	lbm/hr	41.3	34.0			38.7	
CO (@ 5.0 ppm)	lbm/hr	31.4	25.9			29.4	
VOC (@ 2.0 ppm)	lbm/hr	7.2	5.9			6.7	
SO ₂ (@ 6.7 ppmv, average) (12.65 ppm duct firing)	lbm/hr	7.4	5.2			7.0	
PM ₁₀ = PM _{2.5}	lbm/hr	24.0	24.0			24.0	
NH ₃ (@ 5.0 ppm slip)	lbm/hr	19.1	15.7			17.9	

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters. 5.0659
Co-firing emissions are controlled at the same amount as natural gas.

Startup / Shutdown Emissions from Turbine (1CT)

Cold Startup			Hot Startup				
180 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/180min)	60 (min. in hot startup)	Max 1-hr. (lb/hr)	Total (lb/60min)	30 (min. in shutdown)	
NO _x	90.7	272.0	NO _x	167.0	167.0	NO _x	
CO	1,679.7	5,039.0	CO	394.0	394.0	CO	
VOC	266.7	800.0	VOC	98.0	98.0	VOC	
SO ₂ (@ 12.65 ppmv)	5.1	15.3	SO ₂	5.1	5.1	SO ₂	
PM ₁₀ = PM _{2.5}	21.3	64.0	PM ₁₀ = PM _{2.5}	23.0	23.0	PM ₁₀ = PM _{2.5}	

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.
CTGs will always be started burning natural gas. Startup and shutdown emission rates above reflect natural gas.
Startup and shutdown SO₂ emissions will always be lower than normal operation SO₂ emissions. Startup and shutdown emissions are assumed equal to normal operations (burning natural gas) at the max emission rate.

Average Annual Emissions

Total Hours of Operation	8,322.0		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT	Emissions g/sec/CT
Total Number of Cold Starts	10.0					
Cold Start Duration (hr)	3.0		NO _x	325,712.3	162.9	4.7
Total Number of Hot Starts	10.0		CO	300,390.9	150.2	4.3
Hot Start Duration (hr)	1.0		VOC	65,066.5	32.5	0.9
Total Number of Shutdowns	20.0		SO ₂	58,357.9	29.2	0.8
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	199,498.0	99.7	2.9
Duct Burner Operation (hr)	8,272.0		NH ₃	147,864.1	73.9	2.1
Average Normal Operation (hr)	0.0					
Assumptions:						
Average annual normal operational emissions are calculated using yearly average- 65°F, at 100 % load.						
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.						

CTG/HRSG Stack - Co Firing

Hydrogen Energy, Inc
HECA Project

First Quarter Emissions (Jan, Feb, Mar)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	81,428.1	40.7
Total Number of Hot Starts	2.5		CO	75,097.7	37.5
Hot Start Duration (hr)	1.0		VOC	16,266.6	8.1
Total Number of Shutdowns	5.0		SO ₂	14,589.5	7.3
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	36,966.0	18.5
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Second Quarter Emissions (Apr, May, Jun)

Total Hours of Operation	2,080.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	2.5				
Cold Start Duration (hr)	3.0		NO _x	81,428.1	40.7
Total Number of Hot Starts	2.5		CO	75,097.7	37.5
Hot Start Duration (hr)	1.0		VOC	16,266.6	8.1
Total Number of Shutdowns	5.0		SO ₂	14,589.5	7.3
Shutdown Duration (hr)	0.5		PM ₁₀ = PM _{2.5}	49,874.5	24.9
Duct Burner Operation (hr)	2,068.0		NH ₃	36,966.0	18.5
Average Normal Operation (hr)	0.0				
Assumptions:					
Quarterly normal operational emissions are calculated using yearly average- 65°F, at 100 % load.					
Duct burner emissions are calculated using yearly average- 65°F, at 100 % load with duct burners.					

Modeling Worst-Case 1 hr Emissions per Turbine

Pollutant	lb/hr/CT	g/sec/CT
NOx	167.0	21.0
CO	1,679.7	211.6
SO ₂	7.4	0.93
Assumptions: Startup emissions represent worst case hr for NOx and CO. Startup and shutdown only burn natural gas. NOx emissions are from hot start CO emissions are from cold start Normal operation co firing represents worst case SO ₂ Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational (burning natural gas) SO ₂ emissions.		

Modeling Worst-Case 3 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT
Total Hours of Operation	3.0		
Startup Duration	0.0		0.0
Shutdown Duration	0.0		0.0
Hours of Normal Operation (co firing)	3.0	7.4	22.1
SO ₂ worst-case 3 hr emissions per turbine	22.1	lb/3 hr	
SO ₂ worst-case 1 hr emissions per turbine	7.4	lb/hr	
SO ₂ modeling worst-case emissions per turbine	0.9	g/sec	
Assumptions: Only SO ₂ is considered for an average 3-hour Ambient Air Quality Standard. Normal operation co firing represents worst case SO ₂ Worst-case 3 hr emissions assumes a total start up of : 0 Worst-case 3 hr emissions assumes a total shut down of : 0 Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational (burning natural gas) SO ₂ emissions.			

Third Quarter Emissions (Jul, Aug, Sep)

Total Hot	
Total Nun	
Cold Star	
Total Nun	
Hot Start	
Total Nur	
Shutdown	
Duct Buri	
Average I	
Assumption	
Quarterly no	
Duct burner i	

Fourth Quarter Emissions (Oct, Nov, Dec)

Total Hot	
Total Nun	
Cold Star	
Total Nun	
Hot Start	
Total Nur	
Shutdown	
Duct Bur	
Average I	
Assumption	
Quarterly no	
Duct burner,	

CTG/HRSG Stack - Co Firing

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 8 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	8.0			
Startup Duration	6.0		10,078.0	contribution over 8 hr from start up
Shutdown Duration	1.5		378.0	contribution over 8 hr from shut down
Hours of Normal Operation (co firing)	0.5	31.4	15.7	contribution over 8 hr from normal operation
CO worst-case 8 hr emissions per turbine	10,471.7	lb/8 hr		
CO worst-case 1 hr emissions per turbine	1,309.0	lb/hr		
CO modeling worst-case emissions per turbine	164.9	g/sec		
Assumptions: Only CO is considered for an average 8-hour Ambient Air Quality Standard. Normal operation assumes max rate. Worst-case 8 hr emissions assumes a total COLD start up of : 2 Worst-case 8 hr emissions assumes a total shut down of : 3				

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

SO ₂ (lb/day/CT)	177.2
SO2 (g/s/CT) (co firing)	0.9
PM ₁₀ = PM _{2.5} (lb/day/CT)	576.0
PM ₁₀ = PM _{2.5} (g/s/CT) (cofiring)	3.0
Assumptions: Only SO ₂ and PM are considered for an average 24-hour Ambient Air Quality Standard. For SO ₂ 24 hrs of normal operation max emission rate For PM 24 hrs of normal operation max emission rate	

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

Pollutant	Time in Startup hr	Startup Emission Rate lb/start	Time in Shut Down hr	Shutdown Emission Rate lb/shutdown	Time in Normal Operation hr	Normal Operation Emission Rate lb/start	Worst-Case
NOx	12.0	272.0	2.0	62.0	10.0	41.3	
CO	12.0	5,039.0	2.0	126.0	10.0	31.4	
VOC	12.0	800.0	2.0	21.0	10.0	7.2	
SO ₂							
PM ₁₀ = PM _{2.5}							
Assumptions: For NOx, CO, and VOC -- emissions are calculated assuming: Worst-case daily emissions assumes a total start up of : 4 Worst-case daily emissions assumes a total shut down of : 4 Remainder of time is spent in normal operation at max emission rate See above calculation for worst-case daily SO ₂ and PM: calculated as 24 hrs of normal operationat max emissions rate							

Auxiliary CTG

Hydrogen Energy, Inc
HECA Project

CTG Operating Parameters

Ambient Temperature	UNITS	Winter Minimum - 20°F					
CTG Load Level	Percent Load (%)	100%	100%	75%	50%	100%	
Evap Cooling Status	off / on	Off	Off	Off	Off	On	

Average Emission Rates from CTG (lbs/hr/turbine) - Normal Operation

	UNITS	Winter Minimum - 20°F					
NO _x (@ 2.5 ppm)	lbm/hr		7.9	6.4	4.7	8.1	
CO (@ 6.0 ppm)	lbm/hr		11.5	9.3	6.9	11.9	
VOC (@ 2.0 ppm)	lbm/hr		2.2	1.8	1.3	2.3	
SO ₂ (@ 12.65 ppmv)	lbm/hr		1.8	1.4	1.1	1.9	
PM ₁₀ = PM _{2.5}	lbm/hr		6.0	6.0	6.0	6.0	
NH ₃ (@ 10.0 ppm slip)	lbm/hr		11.6	9.5	7.0	12.0	

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

Startup / Shutdown Emissions from Turbine (1CT)

Cold Startup			Hot Startup				
10.0 (min. in cold startup)	Max 1-hr. (lb/hr)	Total (lb/10min)	0 (min. in hot startup)	Max 1-hr. (lb/hr)	Total (lb/60min)	10.3 (min. in shutdown)	
NO _x	9.0	3.0	NO _x			NO _x	
CO	30.6	10.2	CO			CO	
VOC	0.5	0.2	VOC			VOC	
SO ₂ (@ 12.65 ppmv)	1.9	0.3	SO ₂			SO ₂	
PM ₁₀ = PM _{2.5}	6.0	1.0	PM ₁₀ = PM _{2.5}			PM ₁₀ = PM _{2.5}	

All turbine operating parameters and emissions data provided by FLUOR based on expected operating parameters.

NOx, CO, and VOC startup and shutdown emissions (max 1-hr) assume 3 startup and 3 shut down

Startup and shutdown SO2 and PM10 emissions will always be lower than normal operational emissions. Startup and shutdown emissions are assumed equal to normal operations max emission rate, with evap cooling.

Average Annual Emissions and Modeling Rates

Total Hours of Operation	4,110		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT	Emissions g/sec/CT
Total Number of Cold Starts	325.0		NO _x	34,840.6	17.4	0.5
Cold Start Duration (hr)	0.2		CO	55,179.1	27.6	0.8
Total Number of Hot Starts	0.0		VOC	9,182.0	4.6	0.1
Hot Start Duration (hr)	0.0		SO ₂	7,644.4	3.8	0.1
Total Number of Shutdowns	325.0		PM ₁₀ = PM _{2.5}	24,660.0	12.3	0.4
Shutdown Duration (hr)	0.2		NH ₃	48,140.5	24.1	0.7
Evaporative Cooling Operation (hr)	4,000					
Average Normal Operation (hr)	0.0					
Assumptions:						
Average annual operational emissions are calculated using yearly average- 65°F, at 100 % load, with evaporative cool ing.						

Auxiliary CTG

Hydrogen Energy, Inc
HECA Project

First Quarter Emissions (Jan, Feb, Mar)

Total Hours of Operation	1,027.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	81.3				
Cold Start Duration (hr)	0.2		NO _x	8,710.2	4.4
Total Number of Hot Starts	0.0		CO	13,794.8	6.9
Hot Start Duration (hr)	0.0		VOC	2,295.5	1.1
Total Number of Shutdowns	81.3		SO ₂	1,911.1	1.0
Shutdown Duration (hr)	0.2		PM ₁₀ = PM _{2.5}	6,165.0	3.1
Evaporative Cooling Operation (hr)	1,000.0		NH ₃	12,035.1	6.0
Average Normal Operation (hr)	0.0				
Assumptions: Quarterly operational emissions are calculated using yearly average- 65°F, at 100 % load, with evaporative cooling.					

Second Quarter Emissions (Apr, May, Jun)

Total Hours of Operation	1,027.5		Pollutant	Turbine Emissions lb/yr/CT	Emissions ton/yr/CT
Total Number of Cold Starts	81.3				
Cold Start Duration (hr)	0.2		NO _x	8,710.2	4.4
Total Number of Hot Starts	0.0		CO	13,794.8	6.9
Hot Start Duration (hr)	0.0		VOC	2,295.5	1.1
Total Number of Shutdowns	81.3		SO ₂	1,911.1	1.0
Shutdown Duration (hr)	0.2		PM ₁₀ = PM _{2.5}	6,165.0	3.1
Evaporative Cooling Operation (hr)	1,000.0		NH ₃	12,035.1	6.0
Average Normal Operation (hr)	0.0				
Assumptions: Quarterly operational emissions are calculated using yearly average- 65°F, at 100 % load, with evaporative cooling.					

Modeling Worst-Case 1 hr Emissions per Turbine

Pollutant	lb/hr/CT	g/sec/CT
NOx	20.7	2.6
CO	69.0	8.7
SO ₂	1.9	0.2
Assumptions: Startup emissions represent worst case hr for NOx and CO. NOx, and CO worst case 1 hr assume the contribution over 1 hr from 3 startup and 3 shut down Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational SO ₂ emissions.		

Modeling Worst-Case 3 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	3.0			
Startup Duration	0.0		0.0	contribution over 3 hr from start up
Shutdown Duration	0.0		0.0	contribution over 3 hr from shut down
Hours of Normal Operation	3.0	1.9	5.6	contribution over 3 hr from normal operation
SO ₂ worst-case 3 hr emissions per turbine	5.6	lb/3 hr		
SO ₂ worst-case 1 hr emissions per turbine	1.9	lb/hr		
SO ₂ modeling worst-case emissions per turbine	0.2	g/sec		
Assumptions: Only SO ₂ is considered for an average 3-hour Ambient Air Quality Standard. Normal operation assumes max emission rate Worst-case 3 hr emissions assumes a total start up of : 0 Worst-case 3 hr emissions assumes a total shut down of : 0 Calculation assumes that startup and shutdown SO ₂ emissions will always be lower than normal operational SO ₂ emissions				

Th

Tc
To
Cc
To
Hc
Tc
Sh
Ev
Av
Ast
Qu:

Fo

Tc
To
Cc
To
Hc
Tc
Sh
Ev
Av
Ast
Qu:

Auxiliary CTG

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 8 hr Emissions per Turbine

	hr	emission rate lb/hr	Emissions lb/CT	
Total Hours of Operation	8.0			
Startup Duration	0.7		40.8	contribution over 8 hr from start up
Shutdown Duration	0.7		52.8	contribution over 8 hr from shut down
Hours of Normal Operation	6.6	11.9	79.0	contribution over 8 hr from normal operation
CO worst-case 8 hr emissions per turbine	172.6	lb/8 hr		
CO worst-case 1 hr emissions per turbine	21.6	lb/hr		
CO modeling worst-case emissions per turbine	2.7	g/sec		
Assumptions: Only CO is considered for an average 8-hour Ambient Air Quality Standard. Normal operation assumes annual average - 65°F; 100% loa d, with evap cooling. Worst-case 8 hr emissions assumes a total start up of : 4 Worst-case 8 hr emissions assumes a total shut down of : 4				

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

SO ₂ (lb/day/CT)	44.6
SO ₂ (g/s/CT)	0.2
PM ₁₀ = PM _{2.5} (lb/day/CT)	144.0
PM ₁₀ = PM _{2.5} (g/s/CT)	0.8
Assumptions: Only SO ₂ and PM are considered for an average 24-hour Ambient Air Quality Standard. For SO ₂ 24 hrs of normal operation at maximum emission rate For PM 24 hrs of normal operation at maximum emission rate	

Worst-Case Daily Emissions per Turbine and Modeling Worst-Case 24 Hour Emission Rate

	Time in Startup hr	Startup Emission Rate lb/start	Time in Shut Down hr	Shutdown Emission Rate lb/shutdown	Time in Normal Operation hr	Normal Operation Emission Rate lb/start	
Pollutant							
NOx	0.7	3.0	0.7	4.0	22.6	8.1	
CO	0.7	10.2	0.7	13.2	22.6	11.9	
VOC	0.7	0.2	0.7	0.2	22.6	2.3	
SO ₂							
PM ₁₀ = PM _{2.5}							
Assumptions:							
For NOx, CO, and VOC -- emissions are calculated assuming:							
Worst-case daily emissions assumes a total start up of :	4						
Worst-case daily emissions assumes a total shut down of :	4						
Remainder of time is spent in normal operation at max emission rate							
See above calculation for worst-case daily SO ₂ and PM: calculated as 24 hrs of normal operationat max emission rate							

Auxiliary Boiler**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Auxiliary Boiler - Annual Operating Emissions

Total Hours of Operation	2,190	hr/yr			
Firing Rate	142	MMBtu/hr			
Auxiliary Boiler Emission Factors					
NOx (low NOx burner and flue gas recirculation, 9 ppmvd (3% O2))	0.011	lb/MMBtu			
CO (50 ppmvd (3% O2))	0.037	lb/MMBtu			
VOC	0.004	lb/MMBtu			
SO ₂ (12.65 ppmv total sulfur in pipeline natural gas)	0.00204	lb/MMBtu			
PM ₁₀ = PM _{2.5}	0.005	lb/MMBtu			
Auxiliary Boiler Pollutant Emission Rates					
Pollutant	Auxiliary Boiler Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NOx	1.56	37.49	3,420.78	0.43	1.7
CO	5.25	126.10	11,506.26	1.44	5.8
VOC	0.57	13.63	1,243.92	0.16	0.6
SO ₂	0.29	6.96	635.09	0.08	0.3
PM ₁₀ = PM _{2.5}	0.71	17.04	1,554.90	0.19	0.8

Hours per Qtr			
Q1	Q2	Q3	Q4
547.5	547.5	547.5	547.5

Assuming equal operation in each quarter

Hours per Qtr			
Q1	Q2	Q3	Q4
547.5	547.5	547.5	547.5

Assuming equal operation in each quarter

Auxiliary Boiler**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 1 hr Emissions

NO _x (g/sec)	0.2
CO (g/sec)	0.7
SO ₂ (g/sec)	0.04

Only NO_x, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	0.87
SO ₂ (g/sec)	0.04

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	42.03
CO (g/sec)	0.7

Only CO is considered for an average 8-hour Ambient Air Quality Standard.

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	6.96
SO ₂ (g/sec)	0.04
PM ₁₀ = PM _{2.5} (lb/24-hr)	17.04
PM ₁₀ = PM _{2.5} (g/sec)	0.09

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.

Modeling Annual Average Emissions

NO _x (g/sec)	0.05
CO (g/sec)	0.2
VOC (g/sec)	0.02
SO ₂ (g/sec)	0.01
PM ₁₀ = PM _{2.5} (g/sec)	0.02

Gasification Flare**Emis**

Hydrogen Energy, Inc
HECA Project

Gasification Flare - Normal Operating Emissions From Pilot

Total Hours of Operation	8,760	hr/yr
Gasification Flare Pilot Fuel Use =	0.5	MMBtu/hr

Hours per Qtr		
Q1	Q2	Q3
2190	2190	2190

Assuming equal operation in each quarter

Pilot Pollutant Emission Factors

NO _x (lb/MMBtu, HHV)	0.12
CO (lb/MMBtu, HHV)	0.08
VOC (lb/MMBtu, HHV)	0.0013
SO ₂ (lb/MMBtu, HHV) (12.65 ppm)	0.002
VOC (lb/MMBtu, HHV)	0.0013
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)	0.003

Pilot Pollutant Emission Rates

Pollutant	Pilot Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NO _x	0.060	1.44	525.60	0.07	0.26
CO	0.040	0.96	350.40	0.04	0.18
VOC	0.001	0.02	5.69	0.0007	0.003
SO ₂	0.001	0.02	8.94	0.0011	0.004
PM ₁₀ = PM _{2.5}	0.002	0.04	13.14	0.00	0.007

Gasification Flare**Emis**

Hydrogen Energy, Inc
HECA Project

Gasification Flare - Operating Emissions During Gasifier Startup and Shutdown

Total Flare SU/SD Operation	115,500	MMBtu/yr
Wet Unshifted Gas Heat Rate	900	MMBtu/hr
Dry Shifted Gas Heat Rate	768	MMBtu/hr
Approximate Operating Hours (wet)	96	hr/yr
Approximate Operating Hours (dry)	38	hr/yr

Startup and shutdown flared gas scenario

Cold plant startup =	30,000 MMBtu/yr (1 event)	(assume 20% unshifted)
Plant shutdown =	500 MMBtu/yr (1 event)	(assume 100% unshifted)
Gasifier outages =	60,000 MMBtu/yr (24 events)	(assume 100% unshifted)
Gasifier hot restarts =	25,000 MMBtu/yr (12 events)	(assume 100% unshifted)
Total	115,500 MMBtu/yr	(approx 75% unshifted)

SU/SD Flare Pollutant Emission Factors

NO _x (lb/MMBtu, HHV)	0.07
CO (lb/MMBtu, HHV) (wet)	1.00
CO (lb/MMBtu, HHV) (dry)	0.37
VOC (lb/MMBtu, HHV)	0
SO ₂ (lb/MMBtu, HHV)	0
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)	0

SU/SD Flare Pollutant Emission Rates

Pollutant	SU/SD Flare Emissions					
	lb/hr (wet)	lb/hr (dry)	% Wet	% Dry	lb/hr (wet/dry)	ton/qtr (wet/dry)
NO _x	63.0	53.8	75.0%	25.0%	60.70	1.01
CO	900.0	284.3	75.0%	25.0%	746.08	12.16
VOC	0	0	0	0	0	0
SO ₂	0	0	0	0	0	0
PM ₁₀ = PM _{2.5}	0	0	0	0	0	0

Total emissions are determined based on the fractional amount of wet and dry gas burned.

Gasification Flare**Emis**

Hydrogen Energy, Inc
HECA Project

Total Gasification Flare Emissions

Pollutant	Emissions			
	Pilot (ton/yr)	SU/SD (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NO _x	0.26	4.04	1.08	4.3
CO	0.18	48.65	12.21	48.8
VOC	0.003	0.00	0.001	0.003
SO ₂	0.004	0.00	0.001	0.004
PM ₁₀ = PM _{2.5}	0.01	0.00	0.002	0.01

Modeling Worst-Case 1 hr Emissions

NO _x (g/sec)	7.9
CO (g/sec)	113.4
SO ₂ (g/sec)	0.0001

Only NO_x, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.

NO_x and CO rates are taken from the SU/SD flaring events

SO₂ rate is from pilot operation

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	0.003
SO ₂ (g/sec)	0.0001

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

SO₂ pounds per 3-hr assumes three (3) hours of pilot operation.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	7,200.00
CO (g/sec)	113.4

Only CO is considered for an average 8-hour Ambient Air Quality Standard.

Pounds per 8-hr assumes eight (8) hours of SU/SD flaring events.

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	0.02
SO ₂ (g/sec)	0.0001
PM ₁₀ = PM _{2.5} (lb/24-hr)	0.04
PM ₁₀ = PM _{2.5} (g/sec)	0.0002

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.
Pounds per 24-hr assumes 24 hours of pilot operation.

Modeling Annual Average Emissions

NO _x (g/sec)	0.1
CO (g/sec)	1.4
VOC (g/sec)	0.0001
SO ₂ (g/sec)	0.0001
PM ₁₀ = PM _{2.5} (g/sec)	0.0002

Pounds per year assumes contributions from both pilot operation and SU/SD flaring

SRU Flare**Emiss**

Hydrogen Energy, Inc
HECA Project

SRU Flare - Normal Operating Emissions from Pilot

Total Hours of Operation	8,760	hr/yr
SRU Flare Pilot Firing Rate	0.3	MMBtu/hr

Hours per Qtr		
Q1	Q2	Q3
2190	2190	2190

Assuming equal operation in each quarter

Pilot Pollutant Emission Factors

NOx (lb/MMBtu, HHV)	0.12
CO (lb/MMBtu, HHV)	0.08
VOC (lb/MMBtu, HHV)	0.0013
SO ₂ (lb/MMBtu, HHV) (12.65 ppm)	0.002
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)	0.003

Pilot Pollutant Emission Rates

Pollutant	Pilot Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NOx	0.036	0.86	315.36	0.04	0.2
CO	0.024	0.58	210.24	0.03	0.1
VOC	0.0004	0.01	3.42	0.0004	0.002
SO ₂	0.0006	0.01	5.37	0.0007	0.003
PM ₁₀ = PM _{2.5}	0.0009	0.02	7.88	0.00	0.004

SRU Flare**Emis**

Hydrogen Energy, Inc
HECA Project

SRU - Operating Emissions During Gasifier Startup and Shutdown

Natural Gas Heat Rate (assist gas)	36.0	MMBtu/hr			
Approximate Operating Hours	6.0	hr/yr	approximately	2	events
Control efficiency of scrubber =	99.62%				
Acid gas lb/hr SO ₂ =	4,600	lb/hr scrubbed SO ₂ =	17.3		

SU/SD Flare Pollutant Emission Factors

NO _x (lb/hr)	4.32
CO (lb/hr)	2.88
VOC (lb/hr)	0.05
SO ₂ (lb/hr) from natural gas	0.07
SO ₂ (lb/hr) from sour flaring	17.33
PM ₁₀ = PM _{2.5} (lb/hr)	0.11

Natural gas emissions are the same as those listed for the pilot multiplied by the heat rate of the assist gas

SU/SD Flare Pollutant Emission Rates

Pollutant	SU/SD Flare Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NO _x	4.32	13.0	25.9	0.00324	0.0130
CO	2.88	8.6	17.3	0.00216	0.0086
VOC	0.05	0.1	0.3	0	0.0001
SO ₂	17.41	52.2	104.4	0.01	0.0522
PM ₁₀ = PM _{2.5}	0.11	0.3	0.6	0	0.0003

SRU Flare - Total Annual Emissions

Pollutant	Emissions			
	Pilot (ton/yr)	SU/SD (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NO _x	0.16	0.0130	0.04	0.2
CO	0.11	0.0086	0.03	0.1
VOC	0.002	0.0001	0.000	0.002
SO ₂	0.003	0.05	0.014	0.1
PM ₁₀ = PM _{2.5}	0.004	0.0003	0.001	0.004

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 1 hr Emissions

NO _x (g/sec)	0.544
CO (g/sec)	0.363
SO ₂ (g/sec)	2.19

Only NO_x, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.
NO_x, CO, and SO₂ one (1) hr rates are from taken from the SU/SD flaring events

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	52.22
SO ₂ (g/sec)	2.19

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.
Pounds per 3-hr assumes approximately 3 hours (1 event) from SU/SD flaring.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	8.76
CO (g/sec)	0.138

Only CO is considered for an average 8-hour Ambient Air Quality Standard.
Pounds per 8-hr assumes approximately 3 hours (1 event) from SU/SD flaring and the remainder in pilot operation.

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	52.23
SO ₂ (g/sec)	0.27
PM ₁₀ = PM _{2.5} (lb/24-hr)	0.34
PM ₁₀ = PM _{2.5} (g/sec)	0.0018

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.
SO₂ and PM pounds per 24-hr assume approximately 3 hours (1 event) from SU/SD flaring and the remainder in pilot operation.

Hydrogen Energy, Inc
HECA Project

Modeling Annual Average Emissions

NOx (g/sec)	0.005
CO (g/sec)	0.003
VOC (g/sec)	0.00005
SO ₂ (g/sec)	0.002
PM ₁₀ = PM _{2.5} (g/sec)	0.0001

Pounds per year assumes contributions from both pilot operation and SU/SD flaring

Rectisol Flare

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Rectisol - Normal Operating Emissions from Pilot

Total Hours of Operation		8,760	hr/yr		
Rectisol Flare Pilot Firing Rate		0.3	MMBtu/hr		
Pilot Pollutant Emission Factors			Hours per Qtr		
			Q1	Q2	Q3
			2190	2190	2190
			Assuming equal operation in each quarter		
NOx (lb/MMBtu, HHV)		0.12			
CO (lb/MMBtu, HHV)		0.08			
VOC (lb/MMBtu, HHV)		0.0013			
SO ₂ (lb/MMBtu, HHV) (12.65 ppm)		0.002			
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)		0.003			
Pilot Pollutant Emission Rates					
Pollutant	Pilot Emissions lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NOx	0.036	0.86	315.36	0.04	0.2
CO	0.024	0.58	210.24	0.03	0.1
VOC	0.0004	0.01	3.42	0.0004	0.002
SO ₂	0.0006	0.01	5.37	0.0007	0.003
PM ₁₀ = PM _{2.5}	0.0009	0.02	7.88	0.00	0.004

Rectisol Flare - Total Annual Emissions

Pollutant	Emissions Pilot (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NOx	0.16	0.04	0.2
CO	0.11	0.03	0.1
VOC	0.002	0.000	0.002
SO ₂	0.003	0.001	0.003
PM ₁₀ = PM _{2.5}	0.004	0.001	0.004

Modeling Worst-Case 1 hr Emissions

NOx (g/sec)	0.005
CO (g/sec)	0.003
SO ₂ (g/sec)	0.0001

Only NOx, CO, and SO2 are considered for an average 1-hour Ambient Air Quality Standard.
NOx, CO, and SO2 one (1) hr rates are from taken from the natural gas pilot emissions

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	0.0018
SO ₂ (g/sec)	0.0001

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

Hydrogen Energy, Inc
HECA Project

6/30/2009

Pounds per 3-hr assumes aproximately 3 hours the natural gas pilot emissions.

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	0.19
CO (g/sec)	0.003

Only CO is considered for an average 8-hour Ambient Air Quality Standard.
Pounds per 8-hr assumes aproximately 8 hours of pilot operation.

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	0.01
SO ₂ (g/sec)	0.0001
PM ₁₀ = PM _{2.5} (lb/24-hr)	0.02
PM ₁₀ = PM _{2.5} (g/sec)	0.0001

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.
SO₂ and PM pounds per 24-hr assume aproximately 32 hoursof pilot operation.

Modeling Annual Average Emissions

NOx (g/sec)	0.005
CO (g/sec)	0.003
VOC (g/sec)	0.00005
SO ₂ (g/sec)	0.0001
PM ₁₀ = PM _{2.5} (g/sec)	0.0001

Pounds per year assumes contributions from both pilot operation and SU/SD flaring

Tail Gas Thermal Oxidizer**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Thermal Oxidizer - Process Vent Disposal Emissions

Total Hours of Operation	8,760	hr/yr
Thermal Oxidizer Firing Rate	10	MMBtu/hr

Hours per Qtr			
Q1	Q2	Q3	Q4
2190	2190	2190	2190

Assuming equal operation in each quarter

Process Vent Gas Pollutant Emission Factors

NO _x (lb/MMBtu, HHV)	0.24
CO (lb/MMBtu, HHV)	0.20
VOC (lb/MMBtu, HHV)	0.0070
SO ₂ (lb/MMBtu, HHV)	See Below
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)	0.008

Assume an allowance of 2 lb/hr SO₂ emission to account for sulfur in the various vent streams plus fuel.

Process Vent Gas Pollutant Emission Rates

Pollutant	Process Vent Gas Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NO _x	2.40	57.60	21,024.00	2.63	10.5
CO	2.00	48.00	17,520.00	2.19	8.8
VOC	0.07	1.68	613.20	0.0767	0.3
SO ₂	2.00	48.00	17,520.00	2.1900	8.8
PM ₁₀ = PM _{2.5}	0.08	1.92	700.80	0.09	0.4

Assume an allowance of 2 lb/hr SO₂ emission to account for sulfur in the various vent streams plus fuel.

Tail Gas Thermal Oxidizer

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Thermal Oxidizer - SRU Startup Waste Gas Disposal

Total Hours of Operation	300	hr/yr
Thermal Oxidizer Firing Rate	10	MMBtu/hr
SRU Startup Waste Gas Disposal Emission Factors		
NOx (lb/MMBtu, HHV)	0.24	
CO (lb/MMBtu, HHV)	0.20	
VOC (lb/MMBtu, HHV)	0.007	
SO ₂ (lb/MMBtu, HHV) (12.65 ppm)	0.002	
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)	0.008	
SRU Startup Waste Gas Disposal Pollutant Emission Rates		
Pollutant	lb/hr	SRU Startup Waste Gas Disposal Emissions
		lb/day lb/yr ton/qtr ton/yr
NOx	2.40	57.60 720.00 0.09 0.36
CO	2.00	48.00 600.00 0.08 0.30
VOC	0.07	1.68 21.00 0.003 0.011
SO ₂	0.02	0.49 6.17 0.001 0.003
PM ₁₀ = PM _{2.5}	0.08	1.92 24.00 0.003 0.012

Hours per Qtr			
Q1	Q2	Q3	Q4
75	75	75	75

Assuming equal operation in each quarter

Thermal Oxidizer - Total Annual Emissions

Pollutant	Emissions			
	Vent (ton/yr)	SU/SD (ton/yr)	Total (ton/qtr)	Total (ton/yr)
NOx	10.51	0.36	2.72	10.9
CO	8.76	0.30	2.27	9.1
VOC	0.31	0.011	0.08	0.3
SO ₂	8.76	0.003	2.19	8.8
PM ₁₀ = PM _{2.5}	0.35	0.012	0.09	0.4

Tail Gas Thermal Oxidizer**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 1 hr Emissions

NOx (g/sec)	0.6
CO (g/sec)	0.50
SO ₂ (g/sec)	0.25

Only NOx, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.

NOx, CO, and SO₂ one (1) hr rates include contributions from both process venting and SRU startup.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	6.06
SO ₂ (g/sec)	0.3

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

SO₂ pounds per 3-hr assumes three (3) hours of oxidation from both process venting and SRU startup.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	32.00
CO (g/sec)	0.5

Only CO is considered for an average 8-hour Ambient Air Quality Standard.

Pounds per 8-hr assumes eight (8) hours of oxidation from both process venting and SRU startup.

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	48.49
SO ₂ (g/sec)	0.3
PM ₁₀ = PM _{2.5} (lb/24-hr)	3.84
PM ₁₀ = PM _{2.5} (g/sec)	0.02

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.

Pounds per 24-hr assumes 24 hours of oxidation from both process venting and SRU startup.

Modeling Annual Average Emissions

NOx (g/sec)	0.3
CO (g/sec)	0.26
VOC (g/sec)	0.01
SO ₂ (g/sec)	0.3
PM ₁₀ = PM _{2.5} (g/sec)	0.01

Pounds per year assumes all contributions from annual waste gas oxidation and periodic SRU startup.

Gasifier Warming**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Gasifier Warming Emissions - Normal Operation

Total Hours of Operation			1,800	hr/yr	Hours per Qtr			
Gasifier Firing Rate			18	MMBtu/hr	Q1	Q2	Q3	Q4
Gasifier Pollutant Emission Factors					450	450	450	450
NO _x (lb/MMBtu, HHV)			0.11		Assuming equal operation in each quarter			
CO (lb/MMBtu, HHV)			0.09					
VOC (lb/MMBtu, HHV)			0.007					
SO ₂ (lb/MMBtu, HHV) (12.65 ppm)			0.002					
PM ₁₀ = PM _{2.5} (lb/MMBtu, HHV)			0.008					
Gasifier Pollutant Emission Rates					Gasifier Emissions			
Pollutant	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr			
NO _x	1.98	47.52	3,564.00	0.45	1.8			
CO	1.62	38.88	2,916.00	0.36	1.5			
VOC	0.13	3.02	226.80	0.03	0.1			
SO ₂	0.04	0.88	66.10	0.01	0.0			
PM ₁₀ = PM _{2.5}	0.14	3.46	259.20	0.03	0.1			

Please Note That There Are Three Gassifiers; However, Under Normal Operations, Only One Operates At A Time.

Gasifier Warming

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 1 hr Emissions

NO _x (g/sec)	0.2
CO (g/sec)	0.2
SO ₂ (g/sec)	0.0046

Only NO_x, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.

NO_x, CO, and SO₂ one (1) hr rates assume normal operation.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	0.11
SO ₂ (g/sec)	0.0046

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

SO₂ pounds per 3-hr assumes three (3) hours of normal operation.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	12.96
CO (g/sec)	0.2

Only CO is considered for an average 8-hour Ambient Air Quality Standard.

Pounds per 8-hr assumes eight (8) hours of normal operation.

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	0.88
SO ₂ (g/sec)	0.0046
PM ₁₀ = PM _{2.5} (lb/24-hr)	3.46
PM ₁₀ = PM _{2.5} (g/sec)	0.02

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.

Pounds per 24-hr assumes 24 hours of normal operation.

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Annual Average Emissions

NOx (g/sec)	0.1
CO (g/sec)	0.0419
VOC (g/sec)	0.0033
SO ₂ (g/sec)	0.0010
PM ₁₀ = PM _{2.5} (g/sec)	0.0037

Pounds per year assumes 1,800 hours of annual normal operation.

Cooling Towers**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Cooling Towers - Annual Operating Emissions

Total Hours of Operation		8,322	hr/yr	<table><tr><th colspan="4">Hours per Qtr</th></tr><tr><th>Q1</th><th>Q2</th><th>Q3</th><th>Q4</th></tr><tr><td>2080.5</td><td>2080.5</td><td>2080.5</td><td>2080.5</td></tr></table>				Hours per Qtr				Q1	Q2	Q3	Q4	2080.5	2080.5	2080.5	2080.5
Hours per Qtr																			
Q1	Q2	Q3	Q4																
2080.5	2080.5	2080.5	2080.5																
				Assuming equal operation in each quarter															
Cooling Tower Operating Parameters																			
	Power Block	Process Area	ASU	Basis															
Cooling water (CW) circulation rate, gpm	175,000	42,300	40,200	Typical plant performance															
CW circulation rate (million lb/hr)	88	21	20																
CW dissolved solids (ppmw)	9,000	9,000	9,000	(See note)															
Drift, fraction of circulating CW	0.0005%	0.0005%	0.0005%	Expected BACT															
Note: Assumed 9,000 ppm TDS in circulating cooling water. Circulating water could range from 1200 to 90,000 ppm TDS depending on makeup water quality and tower operation. PM10 emissions would vary proportionately.																			
Cooling Tower PM₁₀ Emissions																			
	Cooling Tower PM₁₀ Emissions																		
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr														
Power Block Cooling Tower PM₁₀ Emissions	3.94	94.50	32,767.88	4.10	16.38														
Process Area Cooling Tower PM₁₀ Emissions	0.95	22.84	7,920.46	0.99	3.96														
ASU Cooling Tower PM₁₀ Emissions	0.90	21.71	7,527.25	0.94	3.76														

Cooling Towers**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Total Cooling Tower PM₁₀ Emissions

	(ton/yr)
PM ₁₀	24.11
PM _{2.5}	14.46

PM_{2.5} emission factors were determined by multiplying PM₁₀ numbers by a "PM_{2.5} fraction of PM₁₀" value. Fractional values for PM_{2.5} were taken from the SCAQMD guidance: Final - Methodology to Calculate PM_{2.5} and PM_{2.5} Significance Thresholds, October 2006: Appendix A - Updated CEIDARS Table with PM_{2.5} Fractions.

Modeling Worst-Case 24 Hour Emissions	Power Block	Process Area	ASU
Cells per Cooling Tower	13	4	4
PM ₁₀ (lb/24-hr)	94.50	22.84	21.71
PM ₁₀ (g/sec/cell)	0.038	0.030	0.028
PM _{2.5} (lb/24-hr)	56.70	13.71	13.02
PM _{2.5} (g/sec/cell)	0.023	0.018	0.017

PM is considered for an average 24-hour Ambient Air Quality Standard.

Pounds per 24-hr assumes 24 hours of continual operation.

Modeling Worst-Case Annual Emissions	Power Block	Process Area	ASU
Cells per Cooling Tower	13	4	4
PM ₁₀ (ton/yr)	16.38	3.96	3.76
PM ₁₀ (g/sec/cell)	0.036	0.028	0.027
PM _{2.5} (lb/24-hr)	9.830	2.376	2.258
PM _{2.5} (g/sec/cell)	0.022	0.017	0.016

PM is considered for an annual average Ambient Air Quality Standard.

Assumes continual annual operation.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Emergency Diesel Generators**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Emergency Generator - Expected Emergency Operation and Maintenance

Total Hours of Operation	50	hr/yr				
Generator Specification	2,800	Bhp				
Generator Pollutant Emission Factors (per generator)						
NOx (g/Bhp/hr)	0.50					
CO (g/Bhp/hr)	0.29					
VOC (g/Bhp/hr)	0.11					
SO ₂ (g/Bhp/hr)	N/A					
PM ₁₀ = PM _{2.5} (g/Bhp/hr)	0.03					
Generator Pollutant Emission Rates (per generator)						
Pollutant	Generator Emissions					
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr	
	NOx	3.09	6.17	154.32	0.02	0.1
	CO	1.79	3.58	89.51	0.01	0.04
	VOC	0.68	1.36	33.95	0.00	0.02
	SO ₂	0.03	0.06	1.40	0.00	0.001
	PM ₁₀ = PM _{2.5}	0.16	0.32	8.02	0.00	0.00

Hours per Qtr			
Q1	Q2	Q3	Q4
12.5	12.5	12.5	12.5

Assuming equal operation in each quarter

Hours per Qtr			
Q1	Q2	Q3	Q4
12.5	12.5	12.5	12.5

Assuming equal operation in each quarter

Fuel sulfur content = 15 ppmw
SO₂ emissions = 0.20 lb SO₂/1000 gal
Fuel flow 140.00 gal/hr

Pounds per day assumes two (2) hours of operation for maintenance and testing.

Please note that there are two generators; all emissions are shown for individual generators.

Modeling Worst-Case 1 hr Emissions (per generator)

NO _x (g/sec)	0.4
CO (g/sec)	0.2
SO ₂ (g/sec)	0.004

Only NO_x, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Emergency Diesel Generators**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 3 hr Emissions (per generator)

SO ₂ (lb/3-hr)	0.06
SO ₂ (g/sec)	0.002

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.
Pounds per 3-hr assumes two (2) hours of operation.

Modeling Worst-Case 8 hr Emissions (per generator)

CO (lb/8-hr)	3.58
CO (g/sec)	0.06

Only CO is considered for an average 8-hour Ambient Air Quality Standard.
Pounds per 8-hr assumes two (2) hours of operation.

Modeling Worst-Case 24 Hour Emissions (per generator)

SO ₂ (lb/24-hr)	0.06
SO ₂ (g/sec)	0.0003
PM ₁₀ = PM _{2.5} (lb/24-hr)	0.32
PM ₁₀ = PM _{2.5} (g/sec)	0.002

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.
Pounds per 24-hr assumes two (2) hours of operation.

Modeling Annual Average Emissions (per generator)

NO _x (g/sec)	0.002
CO (g/sec)	0.001
VOC (g/sec)	0.000
SO ₂ (g/sec)	0.00002
PM ₁₀ = PM _{2.5} (g/sec)	0.0001

Pounds per year assumes 50 hours of operation.

Emergency Diesel Firewater Pump**Emission***Hydrogen Energy, Inc**HECA Project***Fire Water Pump - Expected Emergency Operation and Maintenance**

Total Hours of Operation	100	hr/yr
Fire Water Pump Specification	556	Bhp

Hours per Qtr		
Q1	Q2	Q3
25	25	25

Assuming equal operation in each quarter

Fire Water Pump Pollutant Emission Factors

NO _x (g/Bhp/hr)	1.50
CO (g/Bhp/hr)	2.60
VOC (g/Bhp/hr)	0.14
SO ₂ (g/Bhp/hr)	N/A
PM ₁₀ = PM _{2.5} (g/Bhp/hr)	0.015

Fire Water Pump Pollutant Emission Rates

Pollutant	Fire Water Pump Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
NO _x	1.84	3.68	183.86	0.02	0.1
CO	3.19	6.37	318.69	0.04	0.2
VOC	0.17	0.34	17.16	0.00	0.01
SO ₂	0.01	0.01	0.56	0.0001	0.0003
PM ₁₀ = PM _{2.5}	0.02	0.04	1.84	0.00	0.00

Fuel sulfur content =

15

ppmw

Pounds per day assumes two (2) hours of operation for maintenance

SO₂ emissions =

0.20

lb SO₂/1000 gal

Fuel flow

28.00

gal/hr

Emergency Diesel Firewater Pump**Emission**

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 1 hr Emissions

NOx (g/sec)	0.2
CO (g/sec)	0.4
SO ₂ (g/sec)	0.0007

Only NOx, CO, and SO₂ are considered for an average 1-hour Ambient Air Quality Standard

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 3 hr Emissions

SO ₂ (lb/3-hr)	0.01
SO ₂ (g/sec)	0.0005

Only SO₂ is considered for an average 3-hour Ambient Air Quality Standard.

Pounds per 3-hr assumes two (2) hours of operation.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	6.37
CO (g/sec)	0.1

Only CO is considered for an average 8-hour Ambient Air Quality Standard.

Pounds per 8-hr assumes two (2) hours of operation.

Emergency Diesel Firewater Pump

Emission

Hydrogen Energy, Inc
HECA Project

Modeling Worst-Case 24 Hour Emissions

SO ₂ (lb/24-hr)	0.01
SO ₂ (g/sec)	0.0001
PM ₁₀ = PM _{2.5} (lb/24-hr)	0.04
PM ₁₀ = PM _{2.5} (g/sec)	0.0002

Only SO₂ and PM are considered for an average 24-hour Ambient Air Quality Standard.
Pounds per 24-hr assumes two (2) hours of operation.

Modeling Annual Average Emissions

NO _x (g/sec)	0.003
CO (g/sec)	0.005
VOC (g/sec)	0.0002
SO ₂ (g/sec)	0.00001
PM ₁₀ = PM _{2.5} (g/sec)	0.00003

Pounds per year assumes 100 hours of operation.

Intermittent CO₂ Vent**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Intermittent CO₂ Vent - Venting Operation

Total Days of Operation	21	day/yr			
Total Hours of Operation	504	hr/yr			
Total Flow	656,000	lb/hr			
Total Flow	15,150	lbmol/hr			
Vent Gas Pollutant Emission Factors					
CO (ppmv)	1000				
VOC (ppmv)	40				
H ₂ S (ppmv)	10				
Molecular weight					
H ₂ S	34	lb/lbmol			
CO	28	lb/lbmol			
VOC	16	lb/lbmol			
Vent Gas Pollutant Emission Rates					
Pollutant	Vent Gas Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
CO	424.20	10,180.88	213,798.43	26.72	106.9
VOC	9.70	232.71	4,886.82	0.61	2.4
H ₂ S	5.15	123.62	2,596.12	0.32	1.3

Hours per Qtr			
Q1	Q2	Q3	Q4
5.25	5.25	5.25	5.25

Assuming equal operation in each quarter

Intermittent CO₂ Vent**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Modeling Worst-Case 1 hr Emissions

CO (g/sec)	53.4
H ₂ S (g/sec)	0.6

Only H₂S and CO are considered for an average 1-hour Ambient Air Quality Standard.
H₂S and CO one (1) hr rates assume normal venting operation.

Modeling Worst-Case 8 hr Emissions

CO (lb/8-hr)	3,393.63
CO (g/sec)	53.4

Only CO is considered for an average 8-hour Ambient Air Quality Standard.
Pounds per 8-hr assumes eight (8) continuous hours of venting.

Modeling Annual Average Emissions

CO	3.1
VOC	0.1
H ₂ S	0.0

Pounds per year assumes normal venting averaged over the entire year.

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Feedstock - Dust Collection

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

Operation

Total Hours of Operation		8,760	hr/yr	<table><tr><td colspan="4">Hours per Qtr</td></tr><tr><td>Q1</td><td>Q2</td><td>Q3</td><td>Q4</td></tr><tr><td>2190</td><td>2190</td><td>2190</td><td>2190</td></tr><tr><td colspan="4">Assuming equal operation in each quarter</td></tr></table>						Hours per Qtr				Q1	Q2	Q3	Q4	2190	2190	2190	2190	Assuming equal operation in each quarter			
Hours per Qtr																									
Q1	Q2	Q3	Q4																						
2190	2190	2190	2190																						
Assuming equal operation in each quarter																									
Description	Dust Collector No.	Max Feed Handling Rate (ton/hr)	Air Flow to Collector (acfm)	Max Collector PM Emission Rate (lb/hr)	Emission Factor (lb/ton)	Max 24-hr Average		Annual Average																	
						Feed Rate (ton/hr)	PM Emission (lb/hr)	Feed Rate (ton/hr)	PM Emission (lb/hr)																
Truck Unloading	DC-1	900	6,463	0.277	0.00031	775	0.239	150	0.046																
Coke/coal Silos (filling)	DC-2	900	16,376	0.702	0.00078	775	0.604	150	0.117																
Mass Flow Bins (in/out)	DC-3	170	7,620	0.327	0.00192	170	0.327	150	0.288																
Coke/coal Silos (loadout)	DC-4	170	4,872	0.209	0.00123	170	0.209	150	0.184																
Crusher Inlet/Outlet	DC-5	170	4,673	0.200	0.00118	170	0.200	150	0.177																
Fluxant Bins (filling)	DC-6	100	1,234	0.053	0.00053	40	0.021	6	0.003																

Maximum dust collector PM emission rate based on expected supplier guarantee of 0.005 grain/scf outlet dust loading.

The maximum 24-hr feed rate to the gasifiers is limited by the grinding mill capacity.

Duct Collector Emission Rates

Pollutant	Collector Emissions				
	lb/hr	lb/day	lb/yr	ton/qtr	ton/yr
Dust Collector 1 (DC-1)	0.24	5.72	404.40	0.05	0.2
Dust Collector 2 (DC-2)	0.60	14.50	1,024.67	0.13	0.5
Dust Collector 3 (DC-3)	0.33	7.84	2,524.21	0.32	1.3
Dust Collector 4 (DC-4)	0.21	5.01	1,613.90	0.20	0.8
Dust Collector 5 (DC-5)	0.20	4.81	1,547.98	0.19	0.8
Dust Collector 6 (DC-6)	0.02	0.51	27.80	0.00	0.0

Pounds per hour and pounds per day calculated based on the maximum 24-hr average emission rate.

Pounds per year calculated based on the annual average emission rate.

	lb/yr	ton/qtr	ton/yr
PM ₁₀	7,143.0	0.9	3.6
PM _{2.5}	2085.7	0.3	1.0

PM_{2.5} emission factors were determined by multiplying PM₁₀ numbers by a "PM_{2.5} fraction of PM₁₀" value. Fractional values for PM_{2.5} were taken from the SCAQMD guidance: Final - Methodology to Calculate PM_{2.5} and PM_{2.5} Significance Thresholds, October 2006: Appendix A - Updated CEIDARS Table with PM_{2.5} Fractions.

Feedstock - Dust Collection**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

Parameters

Days per year:	365
Hours per day:	24
Minutes per hour:	60
Seconds per minute:	60

Modeling Worst-Case 24 Hour Emissions	DC-1	DC-2	DC-3	DC-4	DC-5	DC-6
PM ₁₀ (lb/day)	5.72	14.50	7.84	5.01	4.81	0.51
PM ₁₀ (g/sec)	0.030	0.076	0.041	0.026	0.025	0.003
PM _{2.5} (lb/24-hr)	1.672	4.235	2.289	1.463	1.404	0.148
PM _{2.5} (g/sec)	0.009	0.022	0.012	0.008	0.007	0.001

PM is considered for an average 24-hour Ambient Air Quality Standard.

Pounds per hour calculated based on the maximum 24-hr average emission rate.

Modeling Annual Average Emissions	DC-1	DC-2	DC-3	DC-4	DC-5	DC-6
PM ₁₀ (lb/yr)	404.40	1,024.67	2,524.21	1,613.90	1,547.98	27.80
PM ₁₀ (g/sec)	0.006	0.015	0.036	0.023	0.022	0.000
PM _{2.5} (lb/24-hr)	118.085	299.204	737.068	471.259	452.010	8.117
PM _{2.5} (g/sec)	0.002	0.004	0.011	0.007	0.007	0.000

Pounds per year calculated based on the annual average emission rate.

GHG Emissions Summary by Source**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

Natural Gas GHG Emission Factors

CO ₂ =	52.78	kg/MMBtu =	116.36	lb/MMBtu
CH ₄ =	0.0059	kg/MMBtu =	0.013	lb/MMBtu
N ₂ O =	0.0001	kg/MMBtu =	0.00022	lb/MMBtu

Diesel GHG Emission Factors

CO ₂ =	10.15	kg/gal =	22.38	lb/gal
CH ₄ =	0.0003	kg/gal =	0.001	lb/gal
N ₂ O =	0.0001	kg/gal =	0.0002	lb/gal

CO₂, CH₄, and N₂O emission factors are taken from Appendix C of the California Climate Action Registry (CCAR) General Reporting Protocol Version 2.2 (March 2007)

HRSG Stack

Operating Hours	50	hr/yr			
HRSG Heat Input	1,998	MMBtu/hr			
CO ₂ =	5,274	tonne/yr			
CH ₄ =	1	tonne/yr =	12	tonne CO ₂ e/yr	
N ₂ O =	0.01	tonne/yr =	3	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr = 5,290

During mature operation of the HRSG, the unit will fire only syngas, except during periods of startup and shutdown.

Startup and shutdown of the HRSG will be accomplished using natural gas. The total startup and shutdown operating hours are estimated at 50 hr/yr.

HRSG heat input rate is assumed to be the maximum heat input rate firing natural gas, which corresponds to winter minimum (20 F).

Auxiliary CTG

Operating Hours	4,110	hr/yr			
HRSG Heat Input	911	MMBtu/hr			
CO ₂ =	197,620	tonne/yr			
CH ₄ =	22	tonne/yr =	464	tonne CO ₂ e/yr	
N ₂ O =	0.4	tonne/yr =	116	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr = 198,200

Average annual GHG operational emissions are calculated using yearly average (65 F) at 100 % load, with evaporative cooling.

GHG Emissions Summary by Source**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

Auxiliary Boiler

Operating Hours	2,190	hr/yr				
HRSR Heat Input	142	MMBtu/hr				
CO ₂ =	16,418	tonne/yr				
CH ₄ =	2	tonne/yr =	39	tonne CO ₂ e/yr		
N ₂ O =	0.03	tonne/yr =	10	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	16,466

Emergency Generators

Operating Hours	50	hr/yr				
HRSR Heat Input	2,800	Bhp				
CO ₂ =	3,201	lb/hr =	73	tonne CO ₂ /yr		
CH ₄ =	0.09	lb/hr =	0.045	tonne CO ₂ e/yr		
N ₂ O =	0.03	lb/hr =	0.2218	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr* =	146

The following conversions were used to convert from lb/gallon to lb/hp-hour; and then multiplying by the rated horsepower rating: 1 gallon/137,000 Btu; and 7,000 Btu/hp-hour.

* Total tonnes CO₂e per year represent the contributions from both generators.

Fire Water Pump

Operating Hours	100	hr/yr				
HRSR Heat Input	556	Bhp				
CO ₂ =	636	lb/hr =	29	tonne CO ₂ /yr		
CH ₄ =	0.02	lb/hr =	0.018	tonne CO ₂ e/yr		
N ₂ O =	0.01	lb/hr =	0.0881	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	29

The following conversions were used to convert from lb/gallon to lb/hp-hour; and then multiplying by the rated horsepower rating: 1 gallon/137,000 Btu; and 7,000 Btu/hp-hour.

GHG Emissions Summary by Source**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

Gasification Flare

Pilot Operation						
Operating Hours		8,760	hr/yr			
HRS Heat Input		0.5	MMBtu/hr			
CO ₂ =	231	tonne/yr				
CH ₄ =	0.03	tonne/yr =	0.5	tonne CO ₂ e/yr		
N ₂ O =	0.0004	tonne/yr =	0.1	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	232
Flaring Events						
Total Operation		115,500	MMBtu/yr			
CO ₂ =	6,098	tonne/yr				
CH ₄ =	0.7	tonne/yr =	14	tonne CO ₂ e/yr		
N ₂ O =	0.01	tonne/yr =	4	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	6,116

GHG emissions from flaring events are conservatively estimated using GHG emission factors for natural gas combustion.

SRU Flare

Pilot Operation						
Operating Hours	8,760	hr/yr				
HRS G Heat Input	0.3	MMBtu/hr				
CO ₂ =	139	tonne/yr				
CH ₄ =	0.02	tonne/yr =	0.3	tonne CO ₂ e/yr		
N ₂ O =	0.0003	tonne/yr =	0.08	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	139

GHG Emissions Summary by Source**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

Flaring Events (assist gas)					
Operating Hours	6	hr/yr			
HRS _G Heat Input	36	MMBtu/hr			
CO ₂ =	11	tonne/yr			
CH ₄ =	0.001	tonne/yr =	0.03	tonne CO ₂ e/yr	
N ₂ O =	0.00002	tonne/yr =	0.007	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr = 11
Throughput (inerts)					
H ₂ S =	25	%			
CO ₂ (inerts) =	75	%			
H ₂ S =	72	lbmol/hr			
CO ₂ (inerts) =	216	lbmol/hr			
CO ₂ (inerts) =	9,488	lb/hr			
Operating Hours	6	hr/yr			
Total tonne CO ₂ e/yr =					26

GHG emissions from flaring events are conservatively estimated using GHG emission factors for natural gas combustion.

Throughput (inerts) amount calculated from the relationship of CO₂ to H₂S in the SRU Flare.

GHG Emissions Summary by Source

Emissions Summary

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

Rectisol Flare

Pilot Operation						
Operating Hours	8,760	hr/yr				
HRSG Heat Input	0.3	MMBtu/hr				
CO ₂ =	139	tonne/yr				
CH ₄ =	0.02	tonne/yr =	0.3	tonne CO ₂ e/yr		
N ₂ O =	0.0003	tonne/yr =	0.08	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	139

GHG emissions from flaring events are conservatively estimated using GHG emission factors for natural gas combustion.

Tail Gas Thermal Oxidizer

Process Vent Disposal Emissions						
Operating Hours	8,760	hr/yr				
HRSG Heat Input	10	MMBtu/hr				
CO ₂ =	4,625	tonne/yr				
CH ₄ =	0.52	tonne/yr =	10.9	tonne CO ₂ e/yr		
N ₂ O =	0.0088	tonne/yr =	2.7	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	4,638

SRU Startup Waste Gas Disposal			
Operating Hours	300	hr/yr	
HRSG Heat Input	10	MMBtu/hr	

GHG Emissions Summary by Source**Emissions Summary**

Hydrogen Energy, Inc
HECA Project

6/30/2009

GHG emissions are numerically depicted as metric tons (tonne) of carbon dioxide equivalents (CO₂e). CO₂e represents CO₂ plus the additional warming potential from CH₄ and N₂O. CH₄ and N₂O have 21 and 310 times the warming potential of CO₂, respectively.

CO ₂ =	158	tonne/yr				
CH ₄ =	0.018	tonne/yr =	0.37	tonne CO ₂ e/yr		
N ₂ O =	0.00030	tonne/yr =	0.093	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr =	159

GHG emissions from flaring events are conservatively estimated using GHG emission factors for natural gas combustion.

Intermittent CO₂ Vent

Operating Hours	504	hr/yr			
CO ₂ Emission Rate	656,000	lb/hr			
					Total tonne CO ₂ e/yr = 150,011

Assumes 21 days per year venting at full rate.

Gasifier Warming

Operating Hours	1,800	hr/yr			
HRSR Heat Input	18	MMBtu/hr			
CO ₂ =	1,711	tonne/yr			
CH ₄ =	0	tonne/yr =	4	tonne CO ₂ e/yr	
N ₂ O =	0.00	tonne/yr =	1	tonne CO ₂ e/yr	Total tonne CO ₂ e/yr = 1,716

Total tonne CO ₂ e/yr =	383,317
------------------------------------	---------

Summary of Truck Emissions - HECA

Emissions Summary

Hydrogen Energy International LLC
HECA Project

6/30/2009

Calculations for Trucks Operation Modeling

Data Supplied By Client				
Parameter	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions	Idling Emissions	Running Emissions	Idling Emissions
Distance Traveled (mi)	0.9659		0.568	
Per Truck Idle Time (hr)		0.117		0.083
Maximum number of trucks or loads:				
1-hr	18	18	2	2
3-hr	54	54	7	7
8-hr	144	144	13	13
24-hr	180	180	38	37.5
Annual average trucks or loads	35,500	35500	2,900	2900

Emission Factor based on equation from AP-42, Chapter 13 (Paved Roads)

$$E = k \left(\frac{sL}{2} \right)^{0.65} \times \left(\frac{W}{3} \right)^{1.5} - C$$

E = particulate emission factor

k = particle size multiplier for particle size range and units of interest

sL = road surface silt loading

W = average weight (tons) of the vehicles traveling the road

C = emission factor for 1980's vehicle fleet exhaust, brake wear and tire wear.

Parameter	Value	Unit
k =	0.016	lb/VMT
C =	0.00047	lb/VMT
sL =	0.031	g/m ²
W =	2.65	ton
E =	4.1E-04	lb/VMT
	0.19	g/VMT

AP 42, Table 13.2-1.1: default k value for PM₁₀

AP 42, Table 13.2-1.2: default C value for PM₁₀

Default value from URBEMIS 9.2 for Kern County

Default value from URBEMIS 9.2 for Kern County

Default value from URBEMIS 9.2 for Kern County

Default value from URBEMIS 9.2 for Kern County

Summary of Truck Emissions - HECA

Emissions Summary

Hydrogen Energy International LLC
HECA Project

6/30/2009

EMFAC2007 Emission Factors (g/mi or g/idle-hour)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions	Idling Emissions	Running Emissions	Idling Emissions
CO	8.289	47.47	12.05	47.47
NOx	16.59	115.98	23.645	115.98
SOx	0.03	0.062	0.04	0.062
PM10 *	1.09	1.115	1.47	1.115
PM2.5	0.794	1.026	1.142	1.026

* PM10 includes entrained road dust factor for paved roads obtained from AP-42 Ch. 13, using defaults from URBEMIS 9.2

1-hr Emission Rates for AERMOD (g/s)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions (0.84 mile route)	Idling Emissions (at each Idle Point)	Running Emissions (0.568 mile route)	Idling Emissions (at each Idle Point)
CO	0.040	0.028	0.004	0.002
NOx	0.080	0.068	0.007	0.005
SOx	1.4E-04	3.6E-05	1.2E-05	2.9E-06
PM10	0.005	0.001	0.000	5.2E-05
PM2.5	0.004	0.001	3.60E-04	4.8E-05

3-hr Emission Rates for AERMOD (g/s)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions (0.84 mile route)	Idling Emissions (at each Idle Point)	Running Emissions (0.568 mile route)	Idling Emissions (at each Idle Point)
CO	0.040	0.028	0.004	0.003
NOx	0.080	0.068	0.009	0.006
SOx	1.4E-04	3.6E-05	1.4E-05	3.3E-06
PM10	0.005	0.001	0.001	6.0E-05
PM2.5	0.004	0.001	4.20E-04	5.5E-05

Summary of Truck Emissions - HECA**Emissions Summary**

Hydrogen Energy International LLC
HECA Project

6/30/2009

8-hour Emission Rates for AERMOD (g/s)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions (0.84 mile route)	Idling Emissions (at each Idle Point)	Running Emissions (0.568 mile route)	Idling Emissions (at each Idle Point)
CO	0.040	0.028	0.003	0.002
NOx	0.080	0.068	0.006	0.004
SOx	1.4E-04	3.6E-05	9.5E-06	2.3E-06
PM10	0.005	0.001	3.8E-04	4.2E-05
PM2.5	0.004	0.001	2.9E-04	3.9E-05

24-hour Emission Rates for AERMOD (g/s)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions (0.84 mile route)	Idling Emissions (at each Idle Point)	Running Emissions (0.568 mile route)	Idling Emissions (at each Idle Point)
CO	0.017	0.012	0.003	0.002
NOx	0.033	0.028	0.006	0.004
SOx	6.0E-05	1.5E-05	9.1E-06	2.2E-06
PM10	0.002	2.7E-04	3.6E-04	4.0E-05
PM2.5	0.002	2.5E-04	2.8E-04	3.7E-05

Annual Emission Rates for AERMOD (g/s)

Pollutant	Coke and Coal Trucks (@ 10 mph)		Onsite Gasifier Solids Handling (@ 5 mph)	
	Running Emissions (0.84 mile route)	Idling Emissions (at each Idle Point)	Running Emissions (0.568 mile route)	Idling Emissions (at each Idle Point)
CO	0.009	0.006	0.001	0.000
NOx	0.018	0.015	0.001	0.001
SOx	3.3E-05	8.1E-06	1.9E-06	4.8E-07
PM10	0.001	1.5E-04	7.7E-05	8.5E-06
PM2.5	0.001	1.3E-04	6.0E-05	7.9E-06

Appendix C

Modeling Protocol

**AIR QUALITY MODELING PROTOCOL FOR THE
HYDROGEN ENERGY CALIFORNIA (HECA)
PROJECT**

AIR QUALITY MODELING PROTOCOL FOR THE HECA POWER PROJECT KERN COUNTY, CALIFORNIA

Prepared For:

- San Joaquin Valley Air Pollution Control District
- California Energy Commission
- U.S. Environmental Protection Agency Region IX
- U.S. Forest Service
- National Park Service

Prepared on behalf of

Hydrogen Energy International LLC

February 6, 2009

URS

1333 Broadway, Suite 800
Oakland, CA 94612

TABLE OF CONTENTS

Section 1	Introduction	1-1
	1.1 Background.....	1-1
	1.2 Purpose	1-4
Section 2	Project Description	2-1
	2.1 Project Location.....	2-1
	2.2 Description of The Proposed Sources.....	2-1
Section 3	Regulatory Setting.....	3-1
	3.1 California Energy Commission Requirements	3-1
	3.2 San Joaquin Valley Air Pollution Control District Requirements	3-1
	3.3 U.S. Environmental Protection Agency Requirements.....	3-2
Section 4	Air Quality Impact Analysis for Class II Areas.....	4-1
	4.1 Turbine Screening Modeling	4-1
	4.2 Refined Modeling	4-1
	4.2.1 PSD Modeling Analyses	4-3
	4.2.2 Ambient Air Quality Standards Analysis.....	4-3
	4.2.3 Health Risk Assessment Analysis.....	4-3
	4.3 Modeling Emissions Inventory	4-4
	4.3.1 Operational Project Sources	4-4
	4.3.2 Project Construction Sources	4-6
	4.3.3 Toxic Air Contaminant Sources.....	4-6
	4.3.4 Cumulative Impact Analysis Including Off-Property Sources	4-7
	4.4 Building Wake Effects.....	4-7
	4.5 Receptor Grid	4-7
	4.6 Meteorological and Air Quality Data	4-8
	4.6.1 Meteorological Data.....	4-8
	4.6.2 Air Quality Monitoring Data.....	4-9
	4.7 Fumigation modeling.....	4-11
Section 5	Air Quality Impact Analysis For Class I Areas.....	5-1
	5.1 Near-Field Class I Areas Air Quality Impact Analysis	5-4
	5.2 Far-field Class I Area Air Quality Impact Analysis: CALPUFF Modeling	5-4
	5.2.1 CALPUFF/CALMET Description.....	5-5
	5.2.2 Far-Field Class I Areas Visibility and Regional Haze Analysis	5-6
	5.2.3 PSD Class I Significance Analysis	5-7
	5.2.4 Deposition Analysis	5-8
	5.2.5 Soils and Vegetation	5-8
Section 6	Presentation of Modeling Results.....	6-1
	6.1 PSD, NAAQS and CAAQS Analyses	6-1
	6.2 Health Risk Assessment Analysis	6-1

TABLE OF CONTENTS

6.3	Class I Analysis	6-1
6.4	Data Submittal	6-1
Section 7	References	7-1

List of Tables, Figures, and Appendices

Tables

Table 4-1	Relevant Ambient Air Quality Standards and Significance Levels
Table 4-2	Approximate Annual Pollutant Emissions for the HECA Turbine/HRSG, Auxiliary CTG, Auxiliary Boiler and the Cooling Towers at Steady State Operation
Table 4-3	Highest Monitored Pollutant Concentrations Near the Proposed HECA Site (2004 – 2006)
Table 5-1	Class I Areas Evaluated with Respect to 100-km Radius of the Proposed HECA Facility
Table 5-2	Scattering Coefficients used in CALPUFF Analysis for the San Rafael Wilderness Class I Area
Table 5-3	FLAG (Proposed) Class I Significance Impact Levels

Figures

Figure 1	General Vicinity – Hydrogen Energy California
Figure 2	HECA Facility Plot Plan
Figure 3	HECA Process Diagram
Figure 4	Calpuff Domain and Receptor For the Class I Area Surrounding HECA

Appendices

Appendix A	Annual and Seasonal Windroses for the Bakersfield International Airport (2000-2004)
------------	---

List of Acronyms and Abbreviations

$\mu\text{g}/\text{m}^3$	Micrograms per cubic meter
AAQS	Ambient Air Quality Standards
AERMOD	American Meteorological Society/Environmental Protection Agency Regulatory Model
AFC	Application for certification
APN	Assessor Parcel Number
AQRV	Air quality related values
ARB	Air Resources Board
ARM	Ambient Ratio Method
ATC	Authority to construct
BACT	Best available control technology
BART	Best available retrofit technology
BPAE	BP Alternative Energy
BPIP	Building profile input program
BPIP-Prime	Building Parameter Input Program – Prime
CAAQS	California Ambient Air Quality Standards
CARB	California Air Resources Board
CEC	California Energy Commission
CO	Carbon monoxide
CO ₂	Carbon dioxide
CTG	Combustion turbine generator
°C	degrees Celsius
DAT	Deposition analysis threshold
DCS	Distributed Control System
DEGADIS	Dense gas dispersion model
DEM	Digital elevation model
DOC	Determination of compliance
EC	Element carbon
ERC	Emission reduction credit
FLAG	Federal land manager air quality related values group
FLM	Federal Land Manager
°F	Degree Fahrenheit
GEP	Good engineering practice
g/s	Gram per second
H ₂ S	Hydrogen Sulfide
HARP	Hotspots analysis and reporting program
HECA	Hydrogen Energy California
HEI	Hydrogen Energy Inc
HHV	Higher heating value
HI	Hazard Indices
HNO ₃	Nitric acid
HRA	Health risk assessment
HRSG	Heat recovery steam generator
IGCC	Integrated gasification combined cycle
ISCST3	Industrial Source Complex Short Term 3 rd version

List of Acronyms and Abbreviations

ISO	International Organization for Standardization
IWAQM	Interagency Workgroup on Air Quality Modeling
km	Kilometers
LAC	Level of acceptable change
LCC	Lambert Conformal Conic
LORS	Laws, ordinances, regulations, and standards
LULC	Land use land cover
MEI	Maximally exposed individual
m	Meters
mm	Millimeters
MICR	Minimum individual cancer risk
MM5	Mesoscale meteorological
MMBtu/hr	Million British thermal unit per hour
MW	Megawatt
NAAQS	National Ambient Air Quality Standards
NH ₄ NO ₃	Ammonium nitrate
(NH ₄) ₂ SO ₄	Ammonium sulfate
NNSR	Non-attainment New Source Review
NO ₂	Nitrogen dioxide
NO ₃	Nitrate
NO _x	Nitrogen oxides
NPS	National Park Service
NSR	New source review
NWS	National Weather Service
O ₃	Ozone
OEHHA	Office of Environmental Health Hazard Assessment
OLM	Ozone limiting method
Pb	Lead
PM _{2.5}	Particulate matter less than 2.5 µm in diameter
PM ₁₀	Particulate matter less than 10 µm in diameter
ppb	Parts per billion
ppm	Parts per million
PMS	Particulate Matter Speciation
PSD	Prevention of significant deterioration
PTE	Potential to emit
RH	Relative humidity
ROC	Reactive organic compound
SCR	Selective catalytic reduction
SIL	Significant impact level
SJVAPCD	San Joaquin Valley Air Pollution Control District
SO ₂	Sulfur dioxide
SO _x	Sulfur oxides
SOA	Secondary organic aerosol
STG	Steam turbine generator
TAC	Toxic air contaminants

List of Acronyms and Abbreviations

T-BACT	Best available control technology for toxics
TGT	Tail gas treatment
tpy	Tons per year
TSP	Total suspended particles
USEPA	United States Environmental Protection Agency
USFS	United States Forest Service
USGS	United States Geological Survey
UTM	Universal Transverse Mercator
VOC	Volatile organic compound
WRAP	Western regional air partnership
ZOI	Zone of impact

SECTION 1 INTRODUCTION**1.1 BACKGROUND**

This document is being submitted to your agency for review and approval. Your agency received a similar document in April 2008 which was commented on and approved. This document was modified from the 2008 version because a new site location about 2.5 km north of the previous site has been selected for the project. All agency comments received for the previous version have been incorporated into this modification. The modeling methodology is unchanged. Ambient monitoring data has been updated.

Hydrogen Energy California (HECA) will be a nominal net 250-megawatt (MW) integrated gasification combined cycle (IGCC) power plant to be constructed on an approximately 1,100-acre parcel near an oil producing area in Kern County, Southern California. The Project will be owned and operated by Hydrogen Energy International LLC, a joint venture of BP Alternative Energy (BPAE) and Rio Tinto. HECA will integrate a gasification block consisting of two active gasification trains (and one spare in hot standby mode) and associated equipment and a power block consisting of one hydrogen-fired or natural gas-fired, or a combination of hydrogen and natural gas, combustion turbine-electrical generator (CTG), duct-fired heat recovery steam generator (HRSG), one condensing steam turbine generator (STG) and associated equipment. HECA will be permitted as a base loaded facility. A blend of petroleum coke and coal or 100 percent petroleum coke will be the primary feedstock to the gasifier. The Carbon Dioxide (CO₂) gas exiting the gasifier will be separated from the hydrogen stream and injected into the nearby oil fields to reduce greenhouse gas emissions from the project and for enhanced recovery of oil. Natural gas will be used in the CTG during startups and at other times in the CTG and the HRSG to supplement the hydrogen fuel. The project will also include an auxiliary CTG for electrical power production for on-site and off-site use. This will be a natural gas-fired simple cycle gas turbine GE model number LMS-100 with an output of approximately 100 MW.

The HECA site area is approximately 543 security fenced acres within a 1,100 acre property located near an oil producing area in Kern County, Southern California. It is 34 km southwest of Bakersfield near Buttonwillow. The parcel is just west of Tupman Road and southeast of the town of Buttonwillow. The legal description of the property is as follows: Southeast ¼ of Section 9 (only the portion north of the West Side Canal), Section 10 (excluding 5 acres in the northwest quadrant), and Section 15 (only the portion north of the West Side Canal) within Township 30 South, Range 24 East in Kern County. The Assessor's Parcel Numbers (APN) are:

- 159-040-02
- 159-040-04
- 159-040-11
- 159-040-16
- 159-040-18
- 159-190-09

The project is subject to the site licensing requirements of the California Energy Commission (CEC). The CEC will coordinate its independent air quality evaluations with the San Joaquin Valley Air Pollution Control District (SJVAPCD) through the Determination of Compliance (DOC) process. The HECA will

be a Major Source as this term is defined in the United States Environmental Protection Agency's (USEPA) Prevention of Significant Deterioration (PSD) regulations, because it is a categorical source (fossil-fuel fired steam electric plant of more than 250 MMBtu/hr heat input), and will have a potential to emit more than 100 tons per year (tpy) of nitrogen oxides (NO_x), particulate matter of diameter less than or equal to 10 microns (PM₁₀) and carbon monoxide (CO). Volatile Organic Compounds (VOC) and sulfur oxides (SO_x) will be emitted in lesser amounts. Because the project will emit more than 100 tpy of at least one attainment pollutant, PSD analyses are also required for any other criteria pollutants for which the proposed facility's Potential to Emit exceeds PSD significant emission levels.


The annual emissions estimates described above are based on the following annual operating parameters:

- One gasification block cold startup and shutdown each year;
- Up to 12 gasifier hot restarts per year;
- Up to 3 cold power block starts, 2 warm power block starts and 5 shutdowns per year of the CTG;
- Up to 7,500 hours/year at steady state operation of the power block;
- Up to 8,520 hours/year operation of the cooling towers;
- Up to 4,000 hours per year operation of the Auxiliary CTG
- Up to 25 percent annual capacity of the auxiliary boiler; and
- Intermittent testing of the emergency diesel generator and the emergency diesel fire pump.

Because the project triggers PSD review, the air dispersion modeling for this project will be conducted in conformance with PSD requirements. For example, worst-case predicted impacts will be compared with the applicable monitoring exemption limits to demonstrate that the project will be exempt from the requirements relating to pre-construction ambient air quality monitoring. The PSD regulations apply only to those pollutants for which the project area is in attainment of the National Ambient Air Quality Standards (NAAQS). State and local new source review (NSR) and non-attainment NSR (NNSR) regulations potentially apply to all criteria pollutants, depending on the quantity of pollutants emitted.

SECTION ONE

Figure 1
General Vicinity – Hydrogen Energy California



The area around HECA is classified as attainment with respect to the NAAQS for nitrogen dioxide (NO₂), particulate matter with diameter less than 10 micrometers (PM₁₀), CO, and SO₂, and non-attainment for ozone (O₃) and particulate matter with diameter less than 2.5 micrometers (PM_{2.5}). With respect to the California Ambient Air Quality Standards (CAAQS), the area around HECA is classified as attainment for NO₂, CO, sulfates, lead (Pb), hydrogen sulfide, and SO₂, and non-attainment for O₃, PM₁₀, and PM_{2.5}. NO₂ and SO₂ are regulated as PM₁₀ precursors, and NO₂ and volatile organic compounds (VOC) as O₃ precursors. Project emissions of non-attainment pollutants and their precursors will be offset to satisfy federal and local NNSR regulations.

1.2 PURPOSE

The CEC, SJVAPCD and USEPA all require the use of atmospheric dispersion modeling to demonstrate that a new power generation facility or modification to an existing facility will comply with applicable air quality standards. These agencies also require an assessment of the potential impacts on human health from the toxic air contaminants that may be emitted by such projects. In addition, CEC power plant siting regulations require modeling to evaluate the cumulative impacts of the proposed project with other new and reasonably foreseeable projects within 10 km (6 miles) of the project site.

This document summarizes the procedures that are proposed for the air dispersion modeling for project certification and permitting. Modeling of both operation and construction emissions due to the proposed power plant will be performed in accordance with CEC and SJVAPCD guidance. This Protocol is being submitted to the CEC and SJVAPCD for their review and comment prior to completion of the applicable permit applications. The Protocol is also being provided to USEPA Region IX, U.S. Forest Service and National Park Service, because of the need to obtain a separate PSD permit for the proposed project. The proposed model selection and modeling approach is based on review of applicable regulations and agency guidance documents, and recent discussions with staffs of the responsible agencies.

SECTION 2 PROJECT DESCRIPTION

2.1 PROJECT LOCATION

The location of the proposed project is shown on Figure 1, which also illustrates the project site, and nearby roads and other features. The HECA site is approximately 1,100 acres in size. The site is accessible from Bakersfield via State Highway 119 westbound and west of Tupman Road.

2.2 DESCRIPTION OF THE PROPOSED SOURCES

Figure 2 shows the preliminary layout of the proposed power plant, including property lines and the locations of all major equipment. The process diagram of the project is shown in Figure 3. Emission points are identified on Figure 2 by number and shown in the legend. These numbers are used in the discussions below.

The proposed power generation facility (power block) will consist of one GE Model 7FB or equivalent Siemens CTG with an ISO base load gross output of approximately 230 MW. The CTG will be designed and constructed to burn multiple fuels (i.e., a combination of fuels ranging from hydrogen to pipeline-quality natural gas and mixtures of the two) with an evaporative cooling system installed on the inlet air for use when the ambient temperatures exceed 59°F. The CTG will be followed by a Heat Recovery Steam Generator (HRSG). The HRSG will also be designed to burn the same multiple fuels as the CTG. The maximum fuel flow rate for the CTG and HRSG will be approximately 1,850 MMBtu/hr and 500 MMBtu/hr (higher heating value, HHV), respectively. Exhaust from the CTG/HRSG will exit through a stack with a height of 213 feet (Emission Point No. 4).

An air/nitrogen mixture is supplied to the CTG through an inlet air filter, inlet air evaporative cooling system, compressor section of the combustion turbine and then exits through the compressor discharge casing to the combustion chambers. Fuel is also supplied to the combustion chambers where it is ignited with the compressed air/nitrogen mixture, expanding through the turbine blades, driving the turbine, electricity generator, and the CTG compressor. Exhaust gas from the CTG is directed through internally insulated ductwork to the HRSG. Steam generated in the HRSG is admitted to a steam turbine generator (STG) for electric power generation. The STG system, rated at approximately 150 MW consists of a steam turbine, gland steam system, lube oil system, hydraulic control system, and a hydrogen cooled generator with all required accessories.

A diffusion combustor system using nitrogen as a diluent when firing hydrogen and using steam as a diluent when firing natural gas will be used to control the NO_x emissions from the CTG. A selective catalytic reduction (SCR) system will be provided in the HRSG to further reduce the NO_x emissions to the atmosphere. The SCR system for the HRSG will inject aqueous ammonia into the exhaust gas stream upstream of a catalyst bed to reduce NO_x to inert nitrogen and water. An oxidation catalyst system will also be incorporated into the air quality control system to control emissions of CO and ROG.

The auxiliary CTG will be fired exclusively on natural gas and will be equipped with water injection and selective catalytic reduction (SCR) for the control of NO_x emissions and an oxidation catalyst for control

emissions of CO and ROG_s. The auxiliary CTG will operate in simple cycle mode and will have an exhaust stack with a height of 110 feet (Emission Point No. 12).

An auxiliary boiler (Emission Point No. 6) will provide steam to facilitate CTG startup and for other purposes. The auxiliary boiler will be designed to burn a single fuel (i.e., pipeline-quality natural gas) at the design maximum fuel flow rate of 142 MMBtu/hr HHV. The auxiliary boiler will be equipped with ultra-low NO_x combustors and will have an estimated annual capacity of 25 percent.

HECA will also incorporate a thermal oxidizer (Emission Point No. 7) on the tail gas treatment (TGT) unit to control emissions during startup of the TGT unit. After the TGT unit is started, emissions from the TGT thermal oxidizer will cease being emitted and will be returned to the process. A Gasification Flare (Emission Point No. 10) will be used to safely dispose of gas streams during startup, shutdown and unplanned upsets or emergency events. A Sulfur Recovery Unit (SRU) Flare (Emission Point No. 9) will be used to safely dispose of gas streams containing sulfur during startup and shutdown (such streams having first passed through an absorber or scrubbing unit for sulfur removal) and gas streams containing sulfur during unplanned upsets or emergency events. A Rectisol Flare (Emission Point No. 13) will be used to safely dispose of low temperature gas streams during unplanned upsets or emergency events.

Each of the three gasification trains will have one natural-gas fired burner used to warm up the gasification train upon start-up (Emission Point Nos. 11a -11c). These burners will not operate when the gasification train is operating.

A 16-celled mechanical draft cooling tower (Emission Point No. 2) will be installed to perform the required cooling for the CTGs, STG, and associated equipment. Other sources of emissions will include a 4-celled mechanical draft cooling tower for the air separation unit (Emission Point No. 1), diesel-fired internal combustion engine drivers for an emergency fire pump rated at about 550 horsepower (Emission Point No. 5), and two 1 MW each emergency generators (Emission Point No. 3).

A CO₂ vent stack (Emission Point No. 8) will provide an alternative operating scenario for releasing the produced CO₂ when the CO₂ injection system is unavailable. The CO₂ vent will enable HECA to operate for brief periods rather than be disabled by a gasifier shutdown and subsequent gasifier restart. The CO₂ vent exhaust stream will be nearly all CO₂, with small amounts of CO and Hydrogen Sulfide (H₂S).

In addition to the sources above, there will be emissions of PM₁₀ from feedstock and gasifier solids materials handling operations. These operations include bulk material unloading, loading, belt conveying, belt transfer points, silo loading and reclaim. The PM₁₀ emissions will be controlled with the help of a dust collection system consisting of hoods and baghouses.

URS

Figure 2
HECA Facility Plot Plan





Figure 3
HECA Process Diagram



SECTION 3 REGULATORY SETTING**3.1 CALIFORNIA ENERGY COMMISSION REQUIREMENTS**

For projects with electrical power generation capacity greater than 50 MW, CEC requires that applicants prepare a comprehensive Application for Certification (AFC) document addressing the proposed project's environmental and engineering features. An AFC must include the following air quality information (CEC, 1997):

- A description of the project, including project emissions of air pollutants and greenhouse gases, fuel type(s), control technologies and stack characteristics;
- The basis for all emission estimates and/or calculations;
- An analysis of Best Available Control Technology (BACT) according to San Joaquin Valley Air Pollution Control District (SJVAPCD) Rules;
- Existing baseline air quality data for all regulated pollutants;
- Existing meteorological data, including temperature, wind speed and direction, and mixing height;
- A listing of applicable laws, ordinances, regulations, standards (LORS), and a determination of compliance with all applicable LORS;
- An emissions offset strategy;
- An air quality impact assessment (i.e., national and state ambient air quality standards [AAQS] and PSD review) and protocol for the assessment of cumulative impacts of the proposed project along with permitted and under construction projects within a 10 km radius; and
- An analysis of human exposure to air toxics (i.e., health risk assessment [HRA]).

For HECA, the air quality impact assessment, the cumulative impacts assessment, and the HRA will be performed using dispersion models.

3.2 SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT REQUIREMENTS

The SJVAPCD has promulgated NSR requirements under Rule 2201. In general, all equipment with the potential to emit air pollutants is subject to the requirements of this rule, which has the following major requirements that potentially apply to new sources such as HECA:

- Installation of BACT,
- Ambient air quality impact modeling to demonstrate compliance with NAAQS and CAAQS and to evaluate impacts to plume visibility in Class I areas near the proposed source(s),
- Emission offsets,
- Statewide compliance for all applicant-owned or operated facilities in California,

Assembly Bill 2588, California Air Toxics Hot Spots Program and SJVAPCD Rule 3110 establish allowable incremental health risks for new or modified sources of toxic air contaminant (TAC) emissions. This rule specifies limits for maximum individual cancer risk (MICR), cancer burden, and non-carcinogenic acute and chronic hazard indices (HI) for new or modified sources of TAC emissions. The health risks resulting from project emissions, as demonstrated by means of an approved health risk assessment, must not exceed established threshold values.

3.3 U.S. ENVIRONMENTAL PROTECTION AGENCY REQUIREMENTS

USEPA has promulgated PSD regulations applicable to new Major Sources and Major Modifications to existing Major Sources. HECA will be a Major Source because it is a fossil-fuel fired steam electric plant of more than 250 MMBtu/hr heat input and will have the potential to emit more than 100 tpy of NO_x, and CO. Many of the PSD requirements are the same as the AFC and SJVAPCD Rule 2201 requirements described above (e.g., project description, BACT, ambient air quality standards analysis). However, PSD requires the following additional analyses:

- An analysis of the potential impacts from the new emissions from HECA relative to PSD Significant Impact Levels (SILs) and PSD Increments;
- An analysis of air quality related values (AQRV) to ensure the protection of visibility in federal Class I National Parks and National Wilderness Areas within 100 km of the proposed project;
- An evaluation of potential impacts on soils and vegetation of commercial and recreational value; and
- An evaluation of potential growth-inducing impacts.

SECTIONFOUR

SECTION 4 AIR QUALITY IMPACT ANALYSIS FOR CLASS II AREAS

This section describes the dispersion models and modeling techniques that will be used in performing the near-field criteria pollutant impact analysis for HECA. The objectives of the modeling are to demonstrate that air emissions from HECA will not cause incremental impacts that exceed the Class II PSD Significant Impact Levels (SILs), nor contribute to exceedances of state and federal ambient air quality standards. A discussion of the Class II visibility analysis for the visible plumes from the cooling towers and the HRSG will be provided in the Visual Resources Section (Section 5.11) of the AFC.

In November 2005, the USEPA officially recognized the American Meteorological Society/Environmental Protection Agency Regulatory Model (AERMOD) as the preferred dispersion model for regulatory applications, replacing the Industrial Source Complex Short Term 3 (ISCST3) model. Also, both CEC staff recommendations and the SJVAPCD guidance for air dispersion modeling (SJVAPCD, 2006) support the use of AERMOD for power plant licensing/permitting analyses. Accordingly, AERMOD (Version 07026) will be used for the dispersion modeling associated with HECA.

4.1 TURBINE SCREENING MODELING

An initial screening modeling analysis will be conducted to determine the turbine stack parameters for the most important project source, i.e., the CTG/HRSG that correspond to maximum ground-level pollutant concentrations. This information will be obtained by running a series of AERMOD simulations with the full meteorological input data set (see Section 4.6) with source inputs representing a range of different load conditions and ambient temperatures. The stack parameters that align with the highest offsite impact from these sources for each pollutant and averaging time period will be used in the subsequent refined modeling simulations.

4.2 REFINED MODELING

The purpose of the refined modeling analysis is to demonstrate that air emissions from HECA will not cause or contribute to an ambient air quality violation. The AERMOD model (version 07026) will be used for the refined modeling of criteria pollutants. Specific modeling procedures that will be used for evaluating project impacts versus the state and federal ambient air quality standards, PSD significance thresholds and applicable health risk criteria are discussed below. Table 4-1 shows the regulatory criteria that will be used to evaluate the significance of predicted pollutant concentrations.

Analysis of land uses adjacent to HECA was conducted in accordance with Section 8.2.8 of the Guideline on Air Quality Models (EPA-450/2-78-027R and Auer [1978]), EPA AERMOD implementation guide (2004), and its addendum (2006).

Based on the Auer land use procedure, more than 50 percent of the area within a 3-km radius of HECA power plant is classified as rural. Since the Auer classification scheme requires more than 50 percent of the area within the 3-km radius around a proposed new source to be non-rural for an urban classification, the rural mode will be used in the AERMOD modeling analyses. All regulatory default options will be used, including building and stack tip downwash, default wind speed profiles, exclusion of deposition and gravitational settling, consideration of buoyant plume rise, and complex terrain.

SECTIONFOUR

Air Quality Impact Analysis For Class II Areas

Table 4-1
Relevant Ambient Air Quality Standards and Significance Levels

Pollutant	Averaging Time	CAAQS (a, b)	NAAQS (b, c)	PSD Class II Significance Impact Levels ($\mu\text{g}/\text{m}^3$)	PSD Significant Emission Rates (tpy)	PSD Increments ($\mu\text{g}/\text{m}^3$)	
						Class I	Class II
CO	8-hour	9.0 ppm (10,000 $\mu\text{g}/\text{m}^3$)	9.0 ppm (10,000 $\mu\text{g}/\text{m}^3$)	500	100		
	1-hour	20 ppm (23,000 $\mu\text{g}/\text{m}^3$)	35 ppm (40,000 $\mu\text{g}/\text{m}^3$)	2,000			
NO ₂ ^(d)	Annual	0.030 ppm (57 $\mu\text{g}/\text{m}^3$)	0.053 ppm (100 $\mu\text{g}/\text{m}^3$)	1	40	2.5	25
	1-hour	0.18 ppm (339 $\mu\text{g}/\text{m}^3$)					
SO ₂	Annual		0.03 ppm (80 $\mu\text{g}/\text{m}^3$)	1	40	2	20
	24-hour	0.04 ppm ^(e) (105 $\mu\text{g}/\text{m}^3$)	0.14 ppm (365 $\mu\text{g}/\text{m}^3$)	5		5	91
	3-hour		0.5 ppm (1,300 $\mu\text{g}/\text{m}^3$)	25		25	512
	1-hour	0.25 ppm (655 $\mu\text{g}/\text{m}^3$)					
PM ₁₀	Annual	20 $\mu\text{g}/\text{m}^3$	See footnote ^(e)	1	15	4	17
	24-hour	50 $\mu\text{g}/\text{m}^3$	150 $\mu\text{g}/\text{m}^3$	5		8	30
PM _{2.5}	Annual	12 $\mu\text{g}/\text{m}^3$	15 $\mu\text{g}/\text{m}^3$				
	24-hour		35 $\mu\text{g}/\text{m}^3$				
O ₃	8-hour	0.07 ppm (137 $\mu\text{g}/\text{m}^3$)	0.075 ppm (147 $\mu\text{g}/\text{m}^3$)	See footnote ^(f)			
	1-hour	0.09 ppm (180 $\mu\text{g}/\text{m}^3$)	See footnote ^(g)				
H ₂ S	1-hour	0.03 ppm ^(h)					

Notes:

- California standards for ozone (as volatile organic compound), carbon monoxide, sulfur dioxide (1-hour), nitrogen dioxide, and PM₁₀, are values that are not to be exceeded. The visibility standard is not to be equaled or exceeded.
- Concentrations are expressed first in units in which they were promulgated. Equivalent units are given in parentheses and based on a reference temperature of 25°C and a reference pressure of 760 mm of mercury. All measurements of air quality area to be corrected to a reference temperature of 25°C and a reference pressure of 760 mm of mercury (1,013.2 millibars).
- National standards, other than those for ozone and based on annual averages, are not to be exceeded more than once a year. The ozone standard is attained when the expected number of days per calendar year with maximum hourly average concentrations above the standard is ≤ 1 .
- NO₂ is the compound regulated as a criteria pollutant; however, emissions are usually based on the sum of all NO_x.
- The federal annual PM₁₀ standard was revoked by USEPA on October 17, 2006.
- Modeling is required for any net increase of 100 tons per year or more of ROC subject to PSD.
- New federal 8-hour ozone and fine particulate matter (PM_{2.5}) standards were promulgated by USEPA on July 18, 1997. The federal 1-hour ozone standard was revoked by USEPA on June 15, 2005.
- The Hydrogen Sulfide ambient air quality standard is an odor based threshold instead of health based.

4.2.1 PSD Modeling Analyses

As the proposed project will trigger PSD as a Major Source, modeling will be required to determine whether its incremental impacts on ambient levels of attainment pollutants (NO₂, SO₂ and CO) will exceed Class II significant impact levels, or SILs. If these SILs were predicted to be exceeded, then an analysis of increment consumption due to all new sources that commenced operation since the local PSD baseline date would be required. However, it is anticipated that the increased emissions of these pollutants due to HECA will not cause incremental effects above the federal SILs.

4.2.2 Ambient Air Quality Standards Analysis

Compliance with the SJVAPCD Rule 2201 modeling requirements for attainment pollutants will be demonstrated by modeling the maximum ground-level concentrations of the proposed Project at any receptor and adding conservative background concentrations, based on recent data from the most representative SJVAPCD air quality monitoring station. HECA will not be considered to cause or contribute to a near-field ambient air quality violation unless impacts from these sources combined with the background concentration exceed the most stringent ambient air quality standard.

NO₂ impact estimates for both the 1-hour and annual averaging times will be modeled by executing AERMOD with the USEPA ozone limiting method (OLM) option for both hourly and annual impacts. Please note that OLM will use ozone data from 2000-2004, which corresponds to the same range of years that was used for the meteorological data.

Note that emissions reduction credits will be obtained by the applicant to offset Project emissions increases of all non-attainment pollutants and their precursors, i.e. NO_x, ROG, PM₁₀ and SO₂ that are above the SJVAPCD offset triggering levels specified in the Districts Rule 2201.4.5.3.

4.2.3 Health Risk Assessment Analysis

Both CEC and SJVAPCD require a health risk assessment (HRA) to evaluate potential health effects of TAC emissions from the operation of the project. Contaminants emitted by the project with potential carcinogenic effects or chronic and/or acute non-carcinogenic effects will be considered. This health risk assessment will be performed following the Office of Environmental Health Hazard Assessment (OEHHA), *Air Toxics Hot Spots Program Risk Assessment Guidelines* (OEHHA, 2003). As recommended by the *Guidelines*, the California Air Resources Board (CARB) Hotspots Analysis and Reporting Program (HARP) (CARB, 2005) will be used to perform an OEHHA Tier 1 health risk assessment for the project. HARP includes two modules: a dispersion module and a risk module. The HARP dispersion module incorporates the USEPA ISCST3 air dispersion model, and the HARP risk module implements the latest Risk Assessment Guidelines developed by OEHHA. For consistency with the criteria pollutant modeling, the dispersion modeling will be conducted with AERMOD. ARB has created a beta version software package, HARP File Converter, to convert AERMOD dispersion results into a format that can be read into the HARP risk module. Thus HARP with AERMOD will be used for this HRA.

SECTIONFOUR

First, ground-level concentrations from HECA emissions will be estimated using the AERMOD dispersion model. The dispersion modeling analysis will be consistent with, and use input parameters that are similar to those discussed above for the criteria pollutant analyses using AERMOD. The same five-year Bakersfield meteorological data set that will be used for the criteria pollutant air quality impact assessment will also be used in the HRA. The maximum 1-hour and annual impacts determined by AERMOD will be used in the HARP model to estimate the corresponding health risks. Receptor spacing will be the same as for the criteria pollutant modeling described later in this Protocol. The HARP simulations will also include the census receptors out to 10 km, and additional receptors will be placed at all sensitive locations (e.g., schools, hospitals, etc.) out to a distance of 5 km (3 miles). Receptors will also be placed at all nearby residents.

Incremental cancer risk will be estimated using the “Derived (Adjusted)” calculation method in HARP. For the calculation of cancer risk, the duration of exposure to project emissions will be assumed to be 24 hours per day, 365 days per year, for 70 years, at all receptors. Chronic non-cancer risks will be calculated by means of the “Derived (OEHHA)” method. No bodies of water are near HECA, thus fish ingestion and drinking water consumption pathways will not be included in this analysis.

The HRA performed by means of the HARP model will follow the following steps:

- Define the location of the maximally exposed individual (MEI) (i.e., the location where the highest carcinogenic risk may occur);
- Define the locations of the maximum chronic non-carcinogenic health effects and the maximum acute health effects;
- Calculate concentrations and health effects at locations of maximum impact for each pollutant; and
- Calculate cancer burden if the maximum cancer risk is predicted to be greater than one in a million.

4.3 MODELING EMISSIONS INVENTORY

4.3.1 Operational Project Sources

Operational emissions from the project will be dominated by the CTG with HRSG. Conceptual plant design includes SCR for NO_x and oxidation catalysts for CO that will comply with recent BACT determinations for similar IGCC projects recently permitted in United States. Emissions of SO₂ and PM₁₀ will be maintained at low levels, owing to HECA commitment to have SO₂ and PM₁₀ emissions comparable to a similarly sized integrated gasification combined cycle power plant having exclusive use of hydrogen as fuel for the gas turbine. Table 4-2 summarizes the estimated annual emissions from the main project sources for each criteria pollutant. The CTG and HRSG emissions estimates reflect the assumed operating hours and numbers of turbine startups described in Section 1.1. Table 4-2 does not include the small contributions to project emissions that will come from the one emergency diesel generator and the one emergency firewater pump engine, or the startup emissions from the thermal oxidizer and the three flares. The engines will normally be operated only a few hours per year in order to test their operability in the event of an emergency situation. The thermal oxidizer and the three flares will

have only pilot flame emissions during normal operation. However, non-emergency emissions from these engines, the thermal oxidizer and the three flares will be included in the dispersion modeling conducted for HECA. A more detailed explanation of the sources and their operations including startup will be provided in AFC Section 2: Project Description and Section 5.1: Air Quality and in the Air Quality Appendix C.

SECTION FOUR

**Table 4-2
Approximate Annual Pollutant Emissions for HECA Turbine/HRSG, Auxiliary CTG, Auxiliary Boiler, and the Cooling Towers at Steady State Operation**

Pollutant	Annual Emissions (tpy)				
	Turbine/HRSG ⁽¹⁾	Auxiliary CTG	Auxiliary Boiler	Cooling Towers ⁽²⁾	Total HECA Emission Approximation *
NO _x	169	17	2	0	< 250
CO	132	28	6	0	> 250
SO ₂	28	2	0	0	<50
PM ₁₀	99	21	0	24	< 250
VOC	31	5	1	0	<50

Note: * Total HECA emission approximations include bulk materials handling dust emissions and fixed duration events such as startups and shutdown

Note: Auxiliary CTG is used to supply additional peaking power for HECA and for external use.

(1) Total annual HRSG emissions represents the maximum emissions rate from a composite firing scenario (all three fuels)

(2) Includes contributions from all three cooling towers

4.3.2 Project Construction Sources

Temporary construction emissions will result from heavy equipment exhaust (primarily NO_x and diesel particulate emissions) and fugitive dust (PM₁₀) from earthmoving activities and vehicle traffic on paved and unpaved surfaces. A detailed Excel Workbook will be created to estimate criteria pollutant emissions for non-overlapping phases of Project construction, based on information from the Project design engineers on the equipment use by month throughout the construction schedule and the area extent of ground disturbance that will occur during different construction phases. Depending on the magnitude of emissions for different pollutants and the proximity of construction activities to the property boundary for each phase, one or more emission scenarios representing reasonable worst-case equipment activity and ground disturbance for each averaging time will be selected for subsequent dispersion modeling to ensure that maximum off-site air quality impacts due to these temporary activities will be assessed. The selected emissions scenarios will be modeled using AERMOD with the same near-field receptor grids and the same meteorological input data used for the modeling of the Project's operational emissions. Fugitive dust emissions from the construction site, including the corridors for new transmission lines, gas lines or water pipelines, parking areas and lay-down areas will be modeled as area or volume sources. Equipment exhaust emissions of gaseous pollutants and particulates will be modeled as a series of point sources distributed over the site and linear corridors, as appropriate. Ultra-low sulfur diesel fuel (15 ppm by weight or less) will be utilized on any emission calculations for construction equipment used at HECA site.

4.3.3 Toxic Air Contaminant Sources

TACs will also be emitted from the operational HECA project due to combustion of natural gas, hydrogen gas and diesel fuels. Only small quantities of TACs will be emitted from these sources - primarily benzene, formaldehyde, and polycyclic aromatic hydrocarbons, when natural gas will be used as fuel for

SECTIONFOUR

the CTG/HRSG train and the auxiliary boiler. Two new diesel-fired engines are proposed as part of the project. These include one fire pump engine and two standby emergency generator engine drivers. Emission estimates for TACs from these sources will be based on diesel particulate mater (DPM) emission factors obtained from standard SJVAPCD, CARB and EPA factors and/or vendor data, if available. The cooling towers' TAC emissions will be estimated using cooling tower feedwater quality data and drift calculations. Emissions of TACs from the CTG/HRSG train when hydrogen is being used and from the flares and the tailgas incinerator during periods of startup and shutdown will be estimated using a combination of emission factors, inventories from other IGCC facilities and vendor data, if available.

4.3.4 Cumulative Impact Analysis Including Off-Property Sources

A cumulative modeling analyses will be performed using AERMOD to evaluate the combined impacts of HECA Project emissions increases with those of any other new sources within 10 km (6 miles) from HECA that are currently either under construction, undergoing permitting or expected to be permitted in the near future. Requests will be made to the SJVAPCD, Kern County Planning Department, the City of Bakersfield, and adjacent cities to request information that will be used to develop lists of all such new or planned emission sources. When received, these lists will be forwarded to CEC for review. Based on this information, and the CEC response, additional sources may be included in the cumulative source modeling analysis. However, because of the relative remoteness and rural nature of the project site area, few recent new sources are expected to be identified.

4.4 BUILDING WAKE EFFECTS

The effect of building wakes (i.e., downwash) upon the stack plumes of emission sources at the facility will be evaluated in accordance with USEPA guidance (USEPA, 1985). Direction-specific building data will be generated for stacks below good engineering practice (GEP) stack height using the most recent version of USEPA Building Parameter Input Program – Prime (BPIP-Prime). Appropriate information will be provided in the AFC and other permit applications that describe the input assumptions and output results from the BPIP-Prime model.

4.5 RECEPTOR GRID

The receptor grids that will be used in the AERMOD modeling analyses described in this Protocol for operational sources will be as follows:

- 25-m spacing along the fenceline and extending from the fenceline out to 100 m beyond the property line;
- 50-m spacing from 100 to 250 m beyond the property line;
- 100-m spacing from 250 to 500 m beyond the property line;
- 250-m spacing from 500 m to 1 km beyond the property line;
- 500-m spacing within 1 to 2 km of project sources; and
- 1,000-m spacing within 2 to 10 km of project sources.

SECTIONFOUR

During the refined modeling analysis for operational Project emissions, if a maximum predicted concentration for a particular pollutant and averaging time is located within the portion of the receptor grid with spacing greater than 25 m, a supplemental dense receptor grid will be placed around the original maximum concentration point and the model will be rerun. The dense grid will use 25-m spacing and will extend to the next grid point in all directions from the original point of maximum concentration.

Due to the large computation time required to run AERMOD, this receptor grid, with the additional dense nested grid points, was determined to best balance the need to predict maximum pollutant concentrations and allow the all operational modeling runs to be completed in less than one week.

Because construction emission sources release pollutants to the atmosphere from small equipment exhaust stacks or from soil disturbances at ground level, maximum predicted construction impacts for all pollutants and averaging times will occur within the first kilometer from the HECA site boundary. Accordingly, only the portion of the above grid with 25 m spacing out to a distance of 1 km will be used for the construction modeling.

The same receptor grid used in the criteria pollutant modeling for the operational project will be used in the HRA modeling, with additional receptors placed at all sensitive locations (e.g., schools, hospitals, etc.) out to 5 km (3 miles). Census receptors out to 10 km will also be included in the populated areas nearest to the proposed HECA facility. Finally, discrete receptors will be placed at the locations of all nearby residences.

A detailed project map and a 7 ½- minute U.S Geological Survey (USGS) map will be provided in the AFC showing the locations of the grid receptors. Actual Universal Transverse Mercator (UTM) coordinates will be used. The CAAQS and NAAQS apply to all locations outside the applicant's facility, i.e. everywhere where public access is not under the control of the applicant. Therefore, the fenceline will be placed along the facility's property boundary, and the receptors will be placed on and outside of the fenceline.

4.6 METEOROLOGICAL AND AIR QUALITY DATA

4.6.1 Meteorological Data

According to the Guidance for Air Dispersion Modeling – San Joaquin Valley Air Pollution Control District (08/06 Rev 1.2), the SJVAPCD prepared regional meteorological data sets for use in AERMOD. The SJVAPCD expressed that “The availability of standard meteorological data will reduce inconsistencies in data quality and requests to the regulatory agency on obtaining data.” The SJVAPCD used the following meteorological elements in AERMET processing for the 5 year period from 2000 to 2004: ceiling height, wind speed, wind direction, air temperature, total cloud opacity, and total cloud amount. Hourly surface data for calendar years 2000, 2001, 2002, 2003, and 2004 were obtained from the SJVAPCD for the Bakersfield Airport meteorological station which is located, in the City of Bakersfield approximately 32.2 km (20 miles) ENE of the HECA site. Also, these data have been pre-processed by the SJVAPCD with the Oakland upper air data to create an input data set specifically tailored for input to AERMOD.

SECTIONFOUR

The “Bakersfield” meteorological data set is available from the SJVAPCD webpage: http://www.valleyair.org/busind/pto/Tox_Resources/AirQualityMonitoring.htm. The guidance describes that the meteorological data provides a standard data set that can be used for air quality studies using AERMOD. The regional data set should not be modified. Therefore, the HECA project site used the SJVAPCD’s model-ready AERMET data set.

In addition, the meteorological data recorded at Bakersfield Airport are acceptable for use at HECA facility for two reasons, proximity and terrain similarity. The terrain immediately surrounding the Project site can be categorized as a fairly flat, or gradually sloping rural area in an area with developed oil wells. The terrain around the Bakersfield Airport also consists of relatively flat, or gradually sloping rural or suburban areas. Thus the land use and the location with respect to near-field terrain features are similar. Additionally, there are no significant terrain features separating the Bakersfield Airport from the HECA facility site that would cause significant differences in wind or temperature conditions between these respective areas. Therefore the five years of meteorological data selected from the Bakersfield Airport were determined to be representative for purposes of evaluating the Project’s air quality impacts. The Bakersfield Airport is the closest full-time meteorological recording station to the HECA facility site, and thus meteorological conditions at the sites will be very similar.

Seasonal and annual wind roses based on the five years of Bakersfield Airport surface meteorological data are provided as Appendix A to this Protocol. Winds for all seasons and all years blow predominantly from the sector between northwest and north, although the directional pattern is more variable during the fall and winter seasons.

4.6.2 Air Quality Monitoring Data

Air quality monitoring data to represent existing air quality in the Project area were obtained from the USEPA AirData (2008) and the CARB-California Air Quality Data website (2008). The most recent three years of data (2006-2008) from the Taft-College, Shafter, Bakersfield Golden State Highway, and Bakersfield 5558 California Avenue monitoring stations were collected to determine the most representative baseline concentrations for each air pollutant and averaging period addressed in the California and National ambient air quality standards. The maximum concentration recorded at these monitoring stations over the three-year period will be used as a conservative representation of existing air quality condition at the proposed Project site. Please note that the background monitoring data from 2006-2008 is used to estimate criteria pollutant impacts using the highest reported values from the most recent three years of available data. This data should not be confused with the ozone data used in the OLM, where the ozone data was obtained from 2000-2004.

The Taft-College monitoring station is located approximately 21 km to the southwest of the HECA facility site. The Taft-College station only monitors PM₁₀, and TSP (until 2005). The Bakersfield Golden Highway station monitors all the criteria pollutants, except SO₂, and is located approximately 56 km to the southeast of the HECA facility site. The Bakersfield 5558 California Avenue station also measures all pollutants except CO and SO₂. This station is located about 30 km east of the HECA site. The only station in the San Joaquin Valley Air Basin that monitors SO₂ is the CARB station at First Street in Fresno, located approximately 163 km to the north. SO₂ data have only been recorded in Fresno County for the

last two years (2007 and 2008), a practice that is justified by the low levels that have been recorded for this pollutant when measurements have been made.

The selected maximum baseline concentrations for all pollutants are summarized in Table 4-3. These data will be added to the modeled maximum impacts due to project emissions for each pollutant and averaging time, and the totals will then be compared with the applicable AAQS. This is a conservative approach because it assumes that the highest recorded background values and the modeled maximum impacts occur at the same time and location for each pollutant and averaging time, a highly unlikely scenario. Note that the maximum background concentrations of PM_{10} and $PM_{2.5}$ in the project area currently exceed the corresponding CAAQS and NAAQS.

**Table 4-3
Highest Monitored Pollutant Concentrations Near the Proposed HECA Site (2006 – 2008)**

Pollutant	Averaging Time	Highest Monitoring Concentration	Monitoring Station Address	Year
CO	8-hour	2.2 ppm (2,444 µg/m ³)	Bakersfield Golden State Highway	2006
	1-hour	3.5 ppm (4,025 µg/m ³)	Bakersfield Golden State Highway	2008
NO ₂	Annual	0.021 ppm (39.6 µg/m ³)	Bakersfield Golden State Highway	2006
	1-hour	0.101 ppm (190.1 µg/m ³)	Shafter-Walker Street	2007
SO ₂	Annual	0.010 ppm (26.7 µg/m ³)	Fresno – 1 st Street	2008
	24-hour	0.031 ppm (81.38 µg/m ³) ^a	Fresno – 1 st Street	2007
	3-hour	0.075 ppm (195.0 µg/m ³) ^b	Fresno – 1 st Street	2007
	1-hour	0.130 ppm (340.6 µg/m ³) ^b	Fresno – 1 st Street	2007
PM ₁₀ ^c (Non-attainment area)	Annual	56.5 µg/m ³	Bakersfield Golden State Highway	2006
	24-hour	267.4 µg/m ³	Bakersfield Golden State Highway	2008
PM _{2.5} ^d (Non-attainment area)	Annual	25.2 µg/m ³	Bakersfield Golden State Highway	2007
	24-hour	154 µg/m ³	Bakersfield Golden State Highway	2007

Source: CARB ADAM website (Last access: February, 2009).

^a The highest SO₂ monitoring concentration occurred at the Fresno – 1st Street station on July 5, 2007, and was found to be 0.067 ppm. This value was assumed to fall into the category of the EPA Rule 40 CFR 50.14 “Treatment of air quality monitoring data influenced by exceptional events.” Because this value occurred on the day after the Independence Day holiday and was twice as high as the next highest monitored 24-hour SO₂ value, it was assumed to have been caused by fireworks. Therefore, the concentration on July 5 2007 was not considered for Table 4-3 and the second highest 24-hour value was used instead. Confirmed in an email from Leland Villalvazo on February 4, 2009

^b It was observed that higher monitoring concentrations were observed at the Fresno -1st Street station on July 4 and July 5, 2007 (the day of and the day after Independence Day). Because these values are much higher than concentrations observed during the rest of the year, they were assumed to have been caused by fireworks. These values will fall into the category EPA Rule 40 CFR 50.14. Therefore, concentrations on July 4 and Jul 5, 2007 were not considered for Table 4-3 and the next highest 1-hour and 3-hour concentrations were used instead. Confirmed in an email from Leland Villalvazo on February 4, 2009

^c Although EPA has determined that the San Joaquin Valley Air Basin has attained the federal PM₁₀ standards, their determination does not constitute a redesignation to attainment per section 107(d)(3) of the Federal Clean Air Act. The Valley will continue to be designated nonattainment until all of the Section 107(d)(3) requirements are met. This area will be treated as the federal PM₁₀ non-attainment area until future redesignation.

^d The Valley is designated nonattainment for the 1997 PM_{2.5} federal standards. EPA designations for the 2006 PM_{2.5} standards will be finalized in December 2009. The District has determined, as of the 2004-06 PM_{2.5} data, that the Valley has attained the 1997 24-Hour PM_{2.5} standard. . This area will be treated as the federal PM_{2.5} non-attainment area until future redesignation.

4.7 FUMIGATION MODELING

Fumigation can occur when a stable layer of air lies a short distance above the release point of a plume and unstable air lies below. Especially on sunny mornings with light winds, the heating of the earth’s surface causes a layer of turbulence, which grows in depth over time and may intersect an elevated exhaust plume. The transition from stable to unstable surroundings can rapidly draw a plume down to ground level and create relatively high pollutant concentrations for a short period. Typically, a fumigation analysis is conducted using the USEPA model SCREEN3 when the project site is rural and the stack height is greater than 10 m.

A fumigation analysis will be performed using SCREEN3 to calculate concentrations from inversion breakup fumigation; no shoreline fumigation modeling will be performed for the HECA location. A unit emission rate will be used (1 gram per second) in the fumigation modeling simulations to represent the plant emissions, and the model results will be scaled to reflect expected plant emissions for each pollutant. Inversion breakup fumigation concentrations will be calculated for 1- and 3-hour averaging times using USEPA-approved conversion factors. These multiple-hour model predictions are conservative, since inversion breakup fumigation is a transitory condition that would most likely affect a given receptor location for only a few minutes at a time.

SECTION 5 AIR QUALITY IMPACT ANALYSIS FOR CLASS I AREAS

An evaluation of potential impacts in Class I areas within 100 km of the HECA site will be conducted, because HECA's potential emissions increases of some pollutants will be sufficiently high to be considered a Major Source, thus triggering the federal PSD program. A Major Source must evaluate impacts to visibility and other air quality related values (AQRV) at all Class I areas that are located within a 100-km radius of the facility. All pollutants for which Project emissions are above the Major Source threshold (in this case, 100 tpy) and all pollutants for which emissions are above the PSD Significant Emissions Rates must be evaluated. This section describes the dispersion models and modeling techniques that will be used in performing the Class I area air quality analyses for HECA. The objectives of the modeling are to demonstrate whether air emissions from HECA would cause or contribute to a PSD increment exceedance or cause a significant impact on visibility, regional haze or sulfur or nitrogen deposition in any Class I area.


Three Class I areas are located within the region of the HECA site and require further evaluation: Dome Land Wilderness Area, Sequoia National Park, and San Rafael Wilderness Area. However, detailed review of the locations of these Class I areas relative to the HECA site shows that Dome Land Wilderness Area and Sequoia National Park are greater than 100 km from HECA. Therefore, these two Class I areas do not meet the screening criterion of being within 100 km and will not be included in the HECA analysis. NPS has confirmed in comments submitted on a previous version of this document that given the distance and low emissions, they do not believe there will be any significant air quality impacts at Sequoia National Park. The nearest parts of the San Rafael Wilderness are located beyond 50 km and within 100 km from the proposed facility, thus only this Class I area and only far-field AQRV analyses will need to be completed. The CALMET/CALPUFF (full-CALPUFF) model will be used to evaluate potential impacts in the far-field Class I area, including potential air quality impacts, sulfur and nitrogen deposition, and impacts to visibility.

Figure 3 shows the locations of the Class I areas relative to the proposed site for HECA and Table 5-1 lists the distances from HECA to the closest and farthest points in each Class I area. Figure 3 also shows the domain to be used for CALPUFF modeling of the San Rafael Wilderness Area (indicated by the blue rectangle). The federal authority in charge of the two Wilderness Areas is the United States Forest Service (USFS) and the National Park Service (NPS) has jurisdiction in Sequoia National Park. The AQRV analyses for the San Rafael Wilderness area will be conducted in a manner consistent with guidance from the NPS and USFS following the procedures set forth in the Federal Land Managers' Air Quality Related Values Workgroup (FLAG) Phase I Report (USFS, 2000) and the Calpuff Reviewer's Guideline (USFS and NPS, 2005).

Table 5-1
Class I Areas Evaluated with Respect to 100-km Radius of the Proposed HECA Facility

Class I areas	Distance from HECA (km)	
Dome Land Wilderness Area	Closest	110
	Farthest	132
Sequoia National Park	Closest	125
	Farthest	181
San Rafael Wilderness Area	Closest	62
	Farthest	81

Figure 4
Calpuff Domain and Receptor For the Class I Area Surrounding HECA



The CALPUFF modeling domain selected for the modeling analyses will extend at least 50 km past the farthest edge in all directions from any of the Class I area being analyzed in order to reduce the probability that mass will be lost due to possible wind recirculation (Figure 3).

5.1 NEAR-FIELD CLASS I AREAS AIR QUALITY IMPACT ANALYSIS

There are no Class I Areas within 50 km of the proposed project location; therefore, no near field AQRV analyses are necessary.

5.2 FAR-FIELD CLASS I AREA AIR QUALITY IMPACT ANALYSIS: CALPUFF MODELING

To analyze potential impact of project emissions to visibility, PSD increment and sulfur and nitrogen deposition in the Class I area located within 100 km from the proposed project site, the CALPUFF model will be used in conjunction with the CALMET diagnostic meteorological model. CALPUFF is a transport and dispersion model that simulates the advection and dispersion of “puffs” of material emitted from modeled sources. CALPUFF can incorporate three-dimensionally varying wind fields, wet and dry deposition, and atmospheric gas and particle phase chemistry. The CALMET model is used to prepare the necessary gridded wind fields for use in the CALPUFF model. CALMET can also accept as input; mesoscale meteorological (MM5) data, surface station, upper air, precipitation, cloud cover, and over-water meteorological data (all in a variety of input formats). These data are merged and the effects of terrain and land cover types are simulated. This process results in the generation of gridded 3-dimensional wind fields that account for the effects of slope flows, terrain blocking effects, flow channeling, and spatially varying land uses.

The USEPA-approved regulatory air quality dispersion model CALPUFF (version 5.8) will be used for all far-field Class I area impact analyses. In addition, all supporting Version 5.8 editions of the pre- and post-processors will be used. Recommendations from the regulatory guidance documents listed below will be followed.

- *Federal Land Managers Air Quality Related Values Workgroup (FLAG) Phase 1 Report. (USEPA December 2000),*
- *Interagency Workgroup on Air Quality Modeling (IWAQM), Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts. (USEPA December 1998), and*
- *Calpuff Reviewer's Guide (Draft), (USFS and NPS, 2005).*

Model options will be based on FLM guidance from the above documents and direct discussions with NPS and USFS air quality staff.

Copies of the model input and output files generated in the preparation of this and all other modeling analyses described in this Protocol will be provided with the final application.

SECTION FIVE

5.2.1 CALPUFF/CALMET Description

5.2.1.1 Location and Land-Use

The CALMET and CALPUFF models incorporate assumptions regarding land-use classification, leaf-area index, and surface roughness length to estimate deposition of emitted materials during atmospheric transport. U.S. Geological Survey (USGS) 1:250,000 scale digital elevation models (DEMs) and Land Use Land Cover (LULC) classification files will be used to develop the geophysical input files required by the CALMET model. Outputs of the terrain pre-processor (TERREL) and land use pre-processor (CTGPROC) will be combined in the geo-physical preprocessor (MAKEGEO) to prepare the CALMET geo-physical input file. The CALMET model will incorporate the necessary parameters in the CALMET output files for use in the CALPUFF model.

The CALPUFF modeling domain will extend from the HECA site 150 km to the west, 180 km to the north, 125 km to the east, and 150 km to the south. The grid-cells over this domain will be 4 km wide. The modeling domain will be specified using the Lambert Conformal Conic (LCC) projection system.

5.2.1.2 Meteorological Data

Pursuant to FLM guidance, a three-year meteorological data set will be developed using a combination of surface station and mesoscale meteorological (MM5) data for 2001-2003. Hourly CALMET data derived from the MM5 data for these three years will be obtained from the WRAP BART modeling for the Nevada-Utah domain. Surface meteorological, precipitation and ozone data will also be obtained from the WRAP BART modeling for the Nevada-Utah domain. No upper air stations will be used, since there are none within the domain shown in Figure 3 and the MM5 data provide a good first approximation of the vertical profile of the atmosphere.

CALMET wind fields will be generated using a combination of the MM5 data sets augmented with the surface data from the National Weather Service (NWS) stations described above. Per IWAQM guidance, the MM5 data will be interpolated to the CALMET fine-scale grid to create the “initial-guess” wind fields (IPROG = 14 for MM5).

5.2.1.3 Other Model Options

Size parameters for dry deposition of nitrate, sulfate, and PM₁₀ particles will be based on default CALPUFF model options. Chemical parameters for gaseous dry deposition and wet scavenging coefficients will be based on default values presented in the CALPUFF User's Guide. For the CALPUFF runs that incorporate deposition and chemical transformation rates (i.e. deposition and visibility), the full chemistry option of CALPUFF will be activated (MCHEM = 1). The nighttime loss for SO₂, NO_x and nitric acid (HNO₃) will be set at 0.2 percent per hour, 2 percent per hour and 2 percent per hour, respectively. CALPUFF will also be configured to allow predictions of SO₂, sulfate (SO₄), NO_x, HNO₃, nitrate (NO₃) and PM₁₀ using the MESOPUFF II chemical transformation module.

Hourly ozone concentration files for the CALPUFF modeling will be obtained from the WRAP BART modeling data for the Nevada-Utah domain. Only data from the ozone monitoring stations within the HECA domain will be used.

The background ammonia concentration will be set to 10 ppb, which is representative for a grassland or agricultural site, per the FLAG guidelines.

The regulatory default setting for MDISP=3 which utilizes the Pasquill-Gifford dispersion coefficients will be used in the CALPUFF modeling.

5.2.1.4 Receptors

Discrete receptors for the CALPUFF modeling within the San Rafael Wilderness Area will be obtained from the NPS Class One Area receptor database. No modifications to the receptor locations or heights provided in the database will be made. Latitude/Longitude coordinates of the Class I receptors will be converted to Lambert Conformal Conic (LCC) coordinates, based on the domain setup shown in CALMET options. These receptor points are shown in Figure 3.

5.2.2 Far-Field Class I Area Visibility and Regional Haze Analysis

For the analysis of visibility effects due to emissions of air pollutants, CALPUFF requires project emission rate inputs for six pollutant species, i.e., directly emitted PM₁₀, NO_x, and SO₂, and secondary SO₄, HNO₃, and NO₃. The maximum 24-hour averaged emission rates of PM₁₀, NO_x and SO₂ from all sources of HECA will be used for the visibility analysis. The turbine/HRSG emissions of SO₂ will be specified to SO₂ and SO₄ as indicated in the NPS Particulate Matter Speciation (PMS) guidelines for gas fired combustion turbines (NPS, 2008). The total turbine/HRSG PM₁₀ emissions will be specified to elemental carbon and organic carbon [emitted as Secondary Organic Aerosol (SOA)] per the PMS. Direct emissions of PM₁₀, NO_x, and SO₂ from the auxiliary boiler, emergency generators and fire pump will be modeled without speciation. The cooling towers will emit only PM₁₀. Direct emissions of the remaining species, HNO₃ and NO₃, are assumed to be zero for the natural gas burning sources of HECA.

Modeled impacts will be converted to visibility impacts using the CALPOST post processor. CALPOST will be used to post-process estimated 24-hour averaged concentrations of ammonium nitrate, ammonium sulfate, EC, and SOA into extinction coefficient values for each day at each modeled receptor.

CALPUFF also requires a background light extinction reference level. The analysis will be run using the FLAG recommended background extinction values for the Class I area. The background extinction coefficient is composed of hygroscopic scattering components, wherein the addition of water enhances particle light-scattering efficiencies, non-hygroscopic scattering components and Rayleigh scattering. Ammonium sulfate and ammonium nitrate compose the hygroscopic scattering components, while organic aerosols, soils, coarse particles, particle absorption from elemental carbon and absorption from gases (primarily from nitrogen dioxide) compose the non-hygroscopic scattering components.

In accordance with the FLAG guideline the total background extinction coefficient is calculated for the Class I area using the following equation:

$$b_{\text{ext}} = b_{\text{hygro}} \cdot f(\text{RH}) + b_{\text{non-hygro}} + b_{\text{Ray}}$$

where:

b_{hygro} = the hygroscopic scattering component (Mm^{-1})
 $= 3[(\text{NH}_4)_2\text{SO}_4 + \text{NH}_4\text{NO}_3]$

$b_{\text{non-hygro}}$ = the non-hygroscopic scattering component (Mm^{-1})
 $= b_{\text{OC}} + b_{\text{Soil}} + b_{\text{Course}} + b_{\text{ap}} + b_{\text{ag}}$

b_{Ray} = the Rayleigh scattering component (Mm^{-1}) = 10 Mm^{-1} (FLAG)

$f(\text{RH})$ = relative humidity adjustment factor

In the CALPOST post-processing program, the monthly background concentration of ammonium sulfate is set to one-third of the hygroscopic scattering component, and the monthly background concentration of soil particles is set to the non-hygroscopic scattering component, as recommended in the FLAG report. The scattering coefficients that will be used in CALPUFF for the Class I areas are presented in Table 5-2.

The FLAG relative humidity (RH) adjustment factors (MVISBK=2) and the RHMAX = 95 % will be used as suggested by the NPS FLM.

The extinction coefficient percent change (background extinction coefficient vs. modeled extinction coefficient), predicted by CALPUFF will be compared to the level of acceptable change (LAC) of 5%. If the change in extinction is greater than 5%, but less than 10%, the conditions surrounding that prediction will be examined to determine if inclement weather may obscure actual viewing of the plume in the Class I area.

Table 5-2
Scattering Coefficients used in CALPUFF Analysis for the San Rafael Wilderness Class I Area

Class I Area	Total Background Extinction (Mm^{-1})				Hygroscopic Scattering Component (Mm^{-1}) = BKSO4	Non- hygroscopic Scattering Component (Mm^{-1}) = BKSOIL	Rayleigh Scattering (Mm^{-1})
	Winter	Spring	Summer	Fall			
San Rafael Wilderness Area	16.1	16.0	16.0	16.0	0.6	4.5	10.0

5.2.3 PSD Class I Significance Analysis

A PSD analysis of incremental air pollutant concentrations in the Class I area due to project emissions will be required, because HECA will be a Major Source as defined in the PSD regulations. Accordingly, the maximum predicted incremental criteria pollutant concentrations from HECA sources in the Class I area will be compared with the Proposed PSD significant impact level for Class I areas (see Table 5-3) for each pollutant.

Table 5-3
FLAG (Proposed) Class I Significance Impact Levels

Pollutant and Averaging Time	NO _x	PM ₁₀		SO ₂		
	Annual	24-hour	Annual	3-hour	24-hour	Annual
Concentration Threshold (µg/m ³)	0.1	0.3	0.2	1	0.2	0.1

All NO₂ and PM₁₀, sources of the proposed project will be modeled at the full potential-to-emit (PTE) in the CALPUFF PSD modeling for each averaging time. The facility SO₂ emission rate will be portioned into SO₂ and SO₄ emissions according to the NPS PMS guidance for natural gas combustion turbines. The full chemistry option of CALPUFF will be activated (MCHEM =1, MESOPUFF II scheme), and deposition options will also be turned on (MWET = 1 and MDRY = 1).

5.2.4 Deposition Analysis

For the Class I area beyond 50 km from the facility, CALPUFF will be used to evaluate the potential for nitrogen and sulfur deposition due to HECA emissions of nitrogen and sulfur oxides emissions. Total deposition rates for each pollutant will be obtained by summing the modeled wet and/or dry deposition rates. The annual average pollutant emission rates for Project sources will be used in this analysis, since annual deposition rates are to be estimated.

For sulfur deposition, the wet and dry fluxes of sulfur dioxide (SO₂) and sulfate (SO₄) are calculated, normalized by the molecular weight of sulfur, and expressed as total sulfur. Total nitrogen deposition is the sum of nitrogen contributed by wet and dry fluxes of nitric acid (HNO₃), nitrate (NO₃⁻), ammonium nitrate (NH₄NO₃), ammonium sulfate ((NH₄)₂SO₄) and the dry flux of NO_x.

The total modeled nitrogen and sulfur deposition rates will be compared to the NPS/USFS deposition analysis thresholds (DAT) for western states. The DAT values for nitrogen and sulfur are each 0.005 kilogram per hectare per year (kg/ha-yr), which converts to 1.59E-11 g/m²/s.

5.2.5 Soils and Vegetation

The designated Class I area contains vegetative ecosystems that are identified by the Federal Land Managers (FLM) (USFS, 1992). For each ecosystem, sensitive species or groups of species will be designated to represent potential impacts to each vegetative species in the ecosystem. These species are impacted primarily by ozone but may also be impacted by nitrogen and sulfur compounds. Acidity in rain, snow, cloudwater, and dry deposition can affect soil fertility and nutrient cycling processes in watersheds, and can result in acidification of lakes and streams with low buffering capacity. Therefore, the soil and vegetation analysis will be conducted using the CALPUFF model to predict total sulfur and nitrogen deposition rates and monitored ozone concentrations at the nearest air quality monitoring stations. In order to protect sensitive species, the USFS (1992) recommends that short-term maximum SO₂ levels should not exceed 40 to 50 parts per billion (ppb). Annual average SO₂ concentrations should not exceed 8 to 12 ppb, and annual average NO₂ concentration should not exceed 15 ppb.

SECTION 6 PRESENTATION OF MODELING RESULTS**6.1 PSD, NAAQS AND CAAQS ANALYSES**

The results of the PSD and AAQS analyses to evaluate the construction and operational impacts of the HECA facility will be presented in summary tables. A figure indicating the locations of the maximum predicted pollutant concentrations for each applicable pollutant and averaging time will be provided. The maximum modeled values of NO₂, SO₂ and CO will be compared with current Class II and proposed Class I SILs. If the model impact exceeds the SILs, the background concentrations (see Section 4.6.2) will be added to the maximum modeled values from the HECA sources to yield total concentrations, which will be compared with the NAAQS and CAAQS. The cumulative impact values from combination of project sources in HECA and new sources within 10 km (6 miles) of the proposed project site will be added to the background concentrations for the corresponding pollutants and averaging times and will be compared with the NAAQS and CAAQS.

6.2 HEALTH RISK ASSESSMENT ANALYSIS

Maps depicting the following data will be prepared:

- Elevated terrain within a 10-km radius of the project;
- The locations of sensitive receptors, including schools, pre-schools, hospitals, etc., within a 5 - km (3 miles) radius of the project, and the nearby residences included in the HRA;
- Isopleths for any areas where predicted exposures to air toxics result in estimated chronic non-cancer impacts and acute impacts equal to or exceeding a hazard index of 1; and
- Isopleths for any areas where exposures to air toxics lead to an estimated carcinogenic risk equal to or greater than one in one million.

Health risk assessment modeling results will be summarized to include maximum annual (chronic, carcinogenic, and non-carcinogenic) and hourly (acute) adverse health effects from HECA's toxic air contaminant emissions. The estimated cancer burden will be presented if the maximum off-site cancer risk is predicted to be greater than one in a million. Health risk values will be calculated and presented in the summary table for the points of maximum impact and the sensitive receptors with the maximum risk values.

6.3 CLASS I ANALYSIS

The results of the visibility, PSD and deposition analyses to evaluate the operational impacts of the HECA facility will be presented in summary tables and compared with all relevant significance thresholds. Isopleth drawing showing the predicted spatial distributions of criteria pollutant concentrations in the Class I areas due to the proposed project emissions will also be prepared.

6.4 DATA SUBMITTAL

Electronic copies of the modeling input and output files for all the analyses described in this Protocol will be provided to SJVAPCD, CEC and EPA Region IX, U.S. Forest Service and National Park Service.

SECTION 7 REFERENCES

- American Meteorological Society. Journal of Applied Meteorology, 17(5): 636-643. "Correlation of Land Use and Cover with Meteorological Anomalies", August Auer Jr., May 1978.
- ARB 2003. HARP User Guide – Software for Emission Inventory Database Management, Air Dispersion Modeling Analyses, and Health Risk Assessment version 1.3, Air Resources, Board, California Environmental Protection Agency. December 2003.
- CEC, 1997. "Regulations Pertaining to the Rules of Practice and Procedure and Plant Site Certification". Title 20, California Code of Regulations. Chapter 1, 2, 5.
- CEC, 2006. Rules of Practice and Procedure & Power Plant Site Certification Regulations Revisions, 04-SIT-2, December 14, 2006.
- National Park Service, 2008. Particulate Matter Speciation:
<http://www.nature.nps.gov/air/Permits/ect/ectGasFiredCT.cfm>
- Office of Environmental Health Hazard Assessment (OEHHA), 2003. Air Toxics Hot Spots Program Risk Assessment Guidelines, August 2003.
- San Joaquin Valley Air Pollution Control District, 2006. Guidelines for Air Dispersion Modeling, (Rev. 1.2), August 2006.
- United States Environmental Protection Agency, 1988. Workbook for Plume Visual Impact Screening and Analysis, U.S. Environmental Protection Agency, Research Triangle Park, NC. September 1988.
- United States Environmental Protection Agency, 1990. New Source Review Workshop Manual, Prevention of Significant Deterioration and Nonattainment Area Permitting (Draft), Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711. October 1990.
- United States Environmental Protection Agency, 1992. Addendum to Workbook for Plume Visual Impact Screening and Analysis, U.S. Environmental Protection Agency, Research Triangle Park, NC. October 1992.
- United States Environmental Protection Agency, 1998. Interagency Workgroup on Air Quality Modeling (IWAQM), Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts. EPA-454/R-98-019. December 1998.
- United States Environmental Protection Agency, 2004. User's Guide for the AMS/EPA Regulatory Model-AERMOD. September 2004.

United States Environmental Protection Agency, 2005. AERMOD Implementation Guide. September 2005.

United States Environmental Protection Agency, 2006. Addendum to User's Guide for the AMS/EPA Regulatory Model-AERMOD. December 2006.

United States Environmental Protection Agency, 2006. USEPA AirData

United States Forest Service et al. 2000. Federal Land Managers Air Quality Related Values Workgroup (FLAG) Phase 1 Report. Prepared by U.S. Forest Service Air Quality Program, National Park Service Air Resources Division, U.S. Fish and Wildlife Service Air Quality Branch. December 2000.

USDA Forest Service and National Park Service, 2005. CALPUFF Reviewer's Guide (DRAFT) prepared by Howard Gebhart. September 2005

APPENDIX A

Annual and Seasonal Windroses for the Bakersfield Airport (2000 through 2004)

2000-2004 Annual (Jan - Dec)




Figure A-1 Annual Windrose for Bakersfield Airport based on Surface Data for 2000-2004

APPENDIX A

Annual and Seasonal Windroses for the Bakersfield Airport (2000 through 2004)

2000-2004 Spring (Mar, Apr, May)




Figure A-2 Spring Season Windrose for Bakersfield Airport based on Surface Data for 2000-2004

APPENDIX A

Annual and Seasonal Windroses for the Bakersfield Airport (2000 through 2004)

2000-2004 Summer (Jun, July, Aug)




Figure A-3 Summer Season Windrose for Bakersfield Airport based on Surface Data for 2000-2004

Annual and Seasonal Windroses for the Bakersfield Airport (2000 through 2004)

Figure A-4 Fall Season Windrose for Bakersfield Airport based on Surface Data for 2000-2004

APPENDIX A

Annual and Seasonal Windroses for the Bakersfield Airport (2000 through 2004)

2000-2004 (Dec, Jan, Feb)




Figure A-5 Winter Season Windrose for Bakersfield Airport based on Surface Data for 2000-2004

CEC Written Comments on the Modeling Protocol for Hydrogen Energy California Project

Note: Applicant's Response provided in italic font following comment.

HECA Modeling Protocol Comments

- 1) Section 4.2.2 Page 4-3. If any of the construction modeling analyses show 1-hour NO₂ values greater than 339 µg/m³ with the maximum NO₂ background added, we request that an hourly NO₂ background comparison using 2000-2004 data from the same monitoring site as the ozone data be performed to determine if any hours would still exceed 339 µg/m³.

Applicant acknowledges this approach but it was not necessary in this case.

- 2) Section 4.3.1 – Due to the unusually high fuel delivery/handling requirements for this project, staff requests that operational emission modeling analysis include the dedicated onsite vehicle emissions and onsite fuel haul truck and/or train emissions, and the onsite paved/unpaved road dust.

These emissions sources have been included in the modeling analysis.

- 3) Section 4.3.1 – The expected flaring and other expected upset/emergency emissions should be modeled to determine worst-case short-term impacts. This section of the protocol should discuss how these potential short-term worst-case events will be included in the operational project sources modeling analysis. Analysis of acute air toxic exposures from these events should also be discussed.

Two of the three flares are expected to operate during normal startup and shutdown of the facility and their emissions during these times have been included in the modeling analysis. The third flare is not expected to operate during normal startup and shutdown so there are no emissions from this flare to include in the modeling. There will be no air quality impacts from operations of the flares during “other expected” upset/emergency operations because there are no other expected upset/emergency operations of the flares. Unexpected operation of the flares may occur, but it's too speculative to quantify the nature and frequency of these occurrences in the detail required to provide meaningful input to the model. Impacts to air quality based on speculative input also would be speculative. The approach to modeling the flares is

therefore consistent with the approach used to model the diesel generator engines and diesel fire water pump engine. Modeling of operations of these diesel engines during, expected, routine testing is included because these are planned operations, emissions from which may be quantified. Modeling of the emergency operations of the engines is not required because the forecast of their emergency operation is too speculative. The flares and the diesel engines are each included in the project as prudent safety measures and to comply with applicable codes and regulations. It is conceivable (and also desirable) that neither the flares nor the diesel engines would operate in an upset/emergency situation during the year.

- 4) Section 4.3.1 – A modeling analysis of the CO₂ vent should be completed to show it is properly designed to keep potentially harmful CO₂ concentrations from impacting facility employees or any offsite receptors. The modeled concentration levels should be compared to appropriate NIOSH and OSHA worker exposure limits and any other relevant sensitive receptor exposure limits.

The DEGADIS modeling estimated the worst case hourly (D stability and 1 meter per second wind speed) maximum ground level concentrations of CO₂ during intermittent CO₂ venting to be 6,131 ppm. This value is about 15 percent of the IDLH concentration of 40,000 ppm and less than 20 percent of the NIOSH short-term exposure limit of 30,000 ppm. Therefore it is well below potentially harmful concentrations.

- 5) Section 4.3.2 – Please identify the basic source input modeling parameters that will be used for the area, volume, and point sources used for the construction modeling (i.e. initial height, temperature, initial lateral and vertical dimensions, etc. as appropriate for each source type).

This information has been included in the modeling analysis.

- 6) Table 4-3 page 4-11. We believe that footnote “c” in this table is now dated as the final redesignation appears to have been noticed in the Federal Register on November 12th 2008.

Comment noted. The designation of PM₁₀ under the National Standards is shown in the AFC as “Attainment.”

- 7) Section 4.7 – Please indicate the emission sources that will be included in the fumigation modeling analysis.

The sources included in the fumigation model are identified in Section 5.1.2.4.

Additional Note:

- 1) In order to try to minimize additional modeling run corrections/requests during project discovery, we would like to point out that several emission sources are inconsistent with other similar equipment staff has experience in licensing, including: a) the PM₁₀ emission rate for the cooling towers is based on a very high TDS content so we suggest reviewing whether such a high TDS is reasonable considering normal TDS limiting issues such as silica content; b) the PM₁₀ emission rate from the LMS100 auxiliary turbine is much higher than any other similar LMS100 project licensed (10.5 lb/hour vs. 6 lb/hour for Panoche and Walnut Creek); c) the PM₁₀ emission rate for the main CTG/HRSG appears high in comparison to other licensed plants on a fuel input basis and 4 ppm for NO_x may be too high to meet BACT for a large gas turbine, certainly when operating on natural gas. We suggest a review of these emission sources be performed prior to modeling, because if they are not revised they will certainly be data requests topics.

The applicant has revised the BACT emission limit for PM₁₀ from the LMS100 auxiliary combustion turbine to 6 lb/hr per the determinations identified above. The cooling tower TDS has not been modified due to the resulting implications on water usage it would create. The CTG/HRSG BACT limit for NO_x when firing natural gas has not been modified due to vendor guarantee limitations. For a complete discussion of the proposed BACT technologies and emission limits see Appendix D-2.

Appendix D

Downwash Parameters

Downwash Structures

HECA

Buildings

	Building Name	Comment	Number of Tiers	Tier Number	Base Elevation (ft)	Tier Height (ft)	Number of Corners	Corner 1 East (X) (m)	Corner 1 North (Y) (m)
1	FINESLAG	Fine Slag Handling Enclosure	1	1	288.5	70	4	283221.4	3912480
2	SLRYPREP	Slurry Preparation Building	1	1	288.5	165	4	283149.2	3912326
3	GASIFIER	Gassifier Structure	1	1	288.5	200	4	283204	3912352
4	AGR	AGR Refrigeration Compressor Enclosure	1	1	288.5	40	4	283132.3	3912194
5	CO2	CO2 Compressor Enclosure	1	1	288.5	50	4	283148.9	3912117
6	ASU_COOL	ASU Cooling Tower	1	1	288.5	50	4	282884	3912012
7	STG	Steam Turbine Generator Structure	1	1	288.5	50	12	282851	3912173
8	CTG	Combustion Turbine Generator	1	1	288.5	50	10	282851.4	3912218
9	AUX_CTG	Auxiliary CTG Structure	1	1	288.5	45	20	282856.5	3912256
10	HRSG	Heat Recovery Steam Generator	1	1	288.5	90	4	282934.2	3912219
11	KO_DRUM	Flare KO Drum	1	1	288.5	35	8	283056.8	3912304
12	PWR_COOL	Power Block and Gassification Cooling To	1	1	288.5	50	4	283024.1	3912010
13	ASU_COMP	ASU Main Air Compressor Enclosure	1	1	288.5	40	4	282893.5	3912076
14	AUX_BOIL	Auxiliary Boiler	1	1	288.5	50	4	282913.4	3912286
15	EMER_GN1	Emergency Generator - 1	1	1	288.5	20	4	282933.4	3912178
16	EMER_GN2	Emergency Generator - 2	1	1	288.5	20	4	282933.3	3912169
17	AIR_SEP	Air Separation Column Can	1	1	288.5	85	22	282918.2	3912110
18	AGR_METH	AGR Methanol Wash Column	1	1	288.5	235	4	283091.7	3912224
19	LOX_TANK	LOx Tank	1	1	288.5	90	8	282870.4	3912114
20	DEMIN1	Demineraized Storage Tank 1	1	1	288.5	45	4	282965.9	3912234
21	DEMIN2	Demineraized Storage Tank 2	1	1	288.5	45	4	282965.9	3912215

Tanks

	Tank Name	Description	Base Elevation (ft)	Center East (X) (m)	Center North (Y) (m)	Tank Height (ft)	Tank Diameter (ft)
1	PROC_WTR	Process Water Treatment Feed Tank	288.5	283173.3	3912430	32	35
2	GREY_WTR	Grey Water Tank	288.5	283158.5	3912415	40	30

3	SETTLER	Settler	288.5	283184.2	3912394	35	85
4	SLURTK_N	Slurry Run Tank - N	288.5	283184	3912318	75	38
5	SLURTK_S	Slurry Run Tank - S	288.5	283183.4	3912302	75	38
6	SOUR_WTR	Sour Water Stripper Feed Tank	288.5	283022.5	3912124	32	48
7	CONDENSA	Condensate Storage Tank	288.5	282957	3912250	24	34
8	FIREWATR	Firewater Storage Tank	288.5	282758.5	3912510	48	110
9	RAWWATER	Raw Water Tank	288.5	282850.6	3912507	48	100
10	TREATD_W	Treated Water Tank	288.5	282857.4	3912462	40	90
11	SILO_W	Feedstock Storage Silos - West	288.5	283261.6	3912672	150	80
12	SILO_C	Feedstock Storage Silos - Central	288.5	283290.1	3912671	150	80
13	SILO_E	Feedstock Storage Silos - East	288.5	283316.9	3912670	150	80
14	METHNL	Methanol Storage Tank	288.5	283115.2	3912061	40	40
15	AIR_CAN	Air Separation Can	288.5	282943.5	3912107	205	33
16	DEMINERA	Demineraized Storage Tank	288.5	282857.3	3912364	40	60
17	PURH2O_1	Purified Water Tank	288.5	282857.4	3912424	48	90
18	PURH2O_2	Purified Water Tank	288.5	282839.4	3912395	48	42.5
19	PURH2O_3	Purified Water Tank	288.5	282865.6	3912396	32	35
20	WATERT_N	Water Treatment Tank North	288.5	282761	3912395	48	120

Appendix E
Class I Visibility/CALPUFF Analysis

APPENDIX E
CALMET/CALPUFF
AIR QUALITY MODELING IMPACT
ANALYSIS FOR FAR-FIELD CLASS I
AREAS
KERN COUNTY, CALIFORNIA

Prepared For:

U.S. Environmental Protection Agency Region IX

U.S. Forest Service

Prepared on behalf of

Hydrogen Energy International LLC



May 2009

TABLE OF CONTENTS

Table of Contents

E1.0	Background.....	E1-1
	E1.1 Model Selection and Setup	E1-1
	E1.2 Domain.....	E1-2
E2.0	CALMET Processing	E2-1
	E2.1 MM5 Data.....	E2-1
	E2.2 Hourly Surface and Precipitation Data	E2-1
	E2.3 Upper Air Data.....	E2-2
	E2.4 CALMET ZFACE and ZIMAX Settings.....	E2-3
	E2.5 Wind Field Model Options	E2-3
	E2.6 LULC and TERREL processing	E2-4
E3.0	CALPUFF Processing.....	E3-1
	E3.1 Sources Included in CALPUFF Modeling.....	E3-1
	E3.2 CALPUFF Parameters	E3-12
	E3.3 PSD Class I Increment Significance Analysis	E3-13
	E3.4 Class I Area Visibility Reduction Analysis	E3-13
	E3.5 Total Nitrogen and Sulfur Deposition Analysis.....	E3-14
E4.0	Modeling Results.....	E4-1
E5.0	References	E5-1

Figures

1	CALMET/CALPUFF Modeling Domain
2	MM5 and CALMET/CALPUFF Modeling Domain
3	Locations of Surface and Precipitation Data Stations
4	3-D Terrain Elevation Contours
5	Land Use Land Cover

Tables

1	Class I Areas near the Project Site
2	Maximum Emission Rates of Each Averaging Time Period
3	Source Location and Parameters
4	3-Hour Averaged Emission Inventory for CALPUFF (3-hour SO ₂ Increment Analysis)
5	24-Hour Averaged Emission Inventory for CALPUFF (24-hour NO _x , SO ₂ , and PM ₁₀ Increment and Visibility Analyses)
6	Annual Averaged Emission Inventory for CALPUFF (Annual NO _x , SO ₂ , and PM ₁₀ Increment and Deposition Analyses)
7	Size Distribution of SOA

TABLE OF CONTENTS

8	PSD Class I Increment Significance Analysis – CALPUFF Results
9	Visibility Analysis – CALPUFF Results
10	Total Nitrogen and Sulfur Deposition Analysis – CALPUFF Results

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E1.0 BACKGROUND

In accordance with comments from the National Park Service (NPS), U.S. Forest Service (USFS) and U.S. Environmental Protection Agency (USEPA) Region IX regarding far-field air quality modeling analysis for the proposed Hydrogen Energy California (HECA) project (the Project), a refined CALPUFF modeling analysis was performed in conjunction with the CALMET diagnostic meteorological model. Based on the written comments from the NPS and EPA and verbal comments from the USFS, the refined CALPUFF modeling considered only the San Rafael Wilderness Class I PSD area for the analysis, described in Section 3.0.

E1.1 MODEL SELECTION AND SETUP

The CALPUFF air dispersion model is the preferred model for long-range transport recommended by the Federal Land Managers' Air Quality Related Value Workgroup (FLAG) guidance and the Interagency Work group on Air Quality Modeling (IWAQM) Phase 2 Summary Report. To estimate air quality impacts at distances greater than 50 kilometers, the CALPUFF model was used in conjunction with the CALMET diagnostic meteorological model. CALPUFF is a puff-type model that can incorporate three-dimensionally varying wind fields, wet and dry deposition, and atmospheric gas and particle-phase chemistry.

The CALMET model is used to prepare the necessary gridded wind fields for use in the CALPUFF model. CALMET can accept as input, mesoscale meteorological data (MM5 data), surface, upper air, precipitation, cloud cover, and over-water meteorological data (all in a variety of input formats). These data are merged and the effects of terrain and land cover types are estimated. This process results in the generation of a gridded three-dimensional (3-D) wind field that accounts for the effects of slope flows, terrain blocking effects, flow channelization, and spatially varying land use types.

The development of model inputs and options for CALMET/CALPUFF processor was based on guidance provided in the following references:

- Federal Land Managers' Air Quality Related Values Workgroup (FLAG) Phase I Report (December 2000);
- Inter-agency Working Group on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long-Range Transport Impacts (December 1998);
- CALMET/CALPUFF Protocol for BART Exemption Screening Analysis for Class I Areas in the Western United States (August 15, 2006);
- CALPUFF Reviewer's Guide (DRAFT) prepared for the United States Department of Agriculture (USDA) Forest Service and NPS (September 2005); and
- Permit application PSD particulate matter speciation methodology developed by Don Shepherd, NPS (2009).

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

Key input and model options selected are discussed in the following sections.

The most recent EPA-approved versions of the CALMET, CALPUFF, CALPOST system (version 5.8, version 5.8 and version 5.6394, respectively) were used.

E1.2 DOMAIN


For this Project, the CALMET/CALPUFF modeling domain was specified using the Lambert Conformal Conic (LCC) Projection system in order to capture the earth curvature of the large modeling domain more accurately for this Project.. The false easting and northing at the projection origin were both set to zero. The latitude and longitude of the projection origin were set to 35.057 N and 119.643 W, respectively. Matching parallels of latitude 1 and 2 were defined as 34.38 N and 35.67 N, respectively. The choice of the matching parallels was made according to the latitudinal extent of the modeling domain, and therefore the parallels should be contained within the modeling domain in order to minimize distortion. An accepted rule-of-thumb is the rule of sixths which calls for one parallel to be placed 1/6th of the domain's north-south extent south of the domain's north edge, and an identical distance north of the domain's south edge (WDEQ 2006). The modeling domain was defined using a grid-cell arrangement that is 52 cells in X (easting) direction and 54 cells in Y (northing) direction. The grid-cells are 4 kilometers wide. Therefore, the southwestern corner of the grid cell (1,1) was set to -101 kilometer and -110 kilometer.

At least 50 kilometers of buffer distance was set between the most outer-boundary of all Class I areas within the modeling domain in order to prevent the loss of mass outside the boundary under some meteorological scenarios that might be associated with transport to nearby Class I areas. The total CALMET/CALPUFF modeling domain is shown in Figure 1. The entire MM5 data set domain is shown for information only in Figure 2.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Figure 1
CALMET/CALPUFF Modeling Domain



Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

Figure 2
MM5 and CALMET/CALPUFF Modeling Domain



Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E2.0 CALMET PROCESSING

E2.1 MM5 DATA

An MM5 data set was used in conjunction with the actual surface and precipitation meteorological data observations. Three years (2001 through 2003) of MM5 data were obtained from Western Regional Air Partnership (WRAP). These MM5 data were used for Utah and Nevada's Best Available Retrofit Technology (BART) analysis by WRAP (WRAP 2006). The MM5 data had a 36 kilometer resolution. Initial-guess wind fields based on hourly 36-kilometer MM5 meteorological fields for 2001, 2002 and 2003 (IPROG = 14) were used. MM5 domain is shown in Figure 2.

E2.2 HOURLY SURFACE AND PRECIPITATION DATA

CALMET pre-processed hourly surface data were obtained from WRAP's CALPUFF BART website (WRAP 2008). WRAP used approximately 190 different surface meteorological data stations for a 3-year period (2001 through 2003) for BART analysis. Although thirteen stations are located within the HECA CALPUFF modeling domain, all surface stations were used for this modeling analysis.


This modeling analysis considered the effects of chemical transformations and deposition processes on ambient pollutant concentrations; therefore, observation of precipitation was included in the CALMET analysis. CALMET pre-processed precipitation data were also collected from WRAP's BART website (WRAP 2008). The precipitation stations are co-located with surface meteorological data stations. The inverse-distance-squared interpolation scheme was used to generate a gridded precipitation field with hourly precipitation data. The radius of influence for the interpolation method was set to 100 kilometers.

The locations of both surface and precipitation stations used in this analysis are illustrated in Figure 3.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Figure 3
Locations of Surface and Precipitation Data Stations



E2.3 UPPER AIR DATA

No observed upper-air meteorological observations were used because they are redundant to the MM5 data and may introduce spurious artifacts in the wind field (WRAP 2006). WRAP explains that the twice-daily upper-air meteorological observations are used as input, with the MM5 model estimates nudged to the observations as part of the Four Dimensional Data Assimilation (FDDA) in the application of the MM5. This results in higher temporal (hourly versus 12-hour) and spatial (36-kilometer versus approximately 300-kilometer) resolution upper-air meteorology

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

in the MM5 field that is dynamically balanced, than contained in the upper-air observations. Therefore, the use of the upper-air observations with CALMET is not needed and in fact will upset the dynamic balance of the meteorological fields potentially producing spurious vertical velocities (WRAP 2006).

E2.4 CALMET ZFACE AND ZIMAX SETTINGS

Eleven vertical layers were used with vertical cell face (ZFACE) heights at 0, 20, 100, 200, 350, 500, 750, 1,000, 2,000, 3,000, 4,000, and 5,000 meters. Maximum mixing height (ZIMAX) was set to 4,500 meters based on the WRAP modeling analysis. WRAP introduced Colorado Department of Public Health and Environment analyses of soundings for summer ozone events in the Denver area (CDPHE 2005). The CDPHE analysis suggests mixing heights in the Denver area are often well above the CALMET default value of 3,000 meters during the summer. A 3,000-meter AGL maximum mixing height might be appropriate in the eastern U.S.; however, in the western U.S. in the summer, mixing heights may exceed this value. WRAP expected that mixing heights in excess of the 3,000-meter above-ground-level CALMET default maximum would occur in the western U.S. (WRAP 2006).

E2.5 WIND FIELD MODEL OPTIONS

In general, CALMET involves two steps in developing the final wind field. First, the prognostic wind field (such as MM5) is introduced into CALMET as the initial-guess field. CALMET then adjusts this field by accounting for the kinematic terrain effects, slope flows, blocking effects, and 3-D divergence minimization. The wind field resulting from this step is called the Step 1 wind field. Second, CALMET further adjusts the Step 1 wind field by applying an objective analysis procedure with observational data from selected surface, upper air, and precipitation stations. This step generates the final (Step 2) wind field. The “Diagnostic Wind Module” (DWM) option follows this two-step procedure. In this analysis, the DWM option was chosen in order to reflect the terrain effects in the wind field. Because several mountain ranges occur within the modeling domain, it was expected that terrain effects would be significant.

The MM5 data were used as the initial-guess wind field. The extrapolation of the surface wind data aloft (IEXTRP = -4) was used as recommended by the USEPA.

Wind speed and wind direction data from observation stations were only allowed to influence the Step 1 wind field at a distance determined by setting the radius-of-influence parameter. The radius of influence for the surface (RMAX1) was set to 100 kilometers as recommended by the Federal Land Managers. The distance from a surface observation station at which the observations and Step 1 wind field were weighted was set to 50 kilometers, which is within the FLM’s recommended range of 20 to 80 kilometers. Radius of influence for terrain features was set to 10 kilometer. All of these radius-of-influence parameters were set based on CALPUFF Reviewer’s Guide (2005).

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E2.6 LULC AND TERREL PROCESSING

The CALMET and CALPUFF models incorporate assumptions regarding land-use classification, leaf-area index, and surface roughness length to estimate deposition during transport. These parameters were calculated with a 4 kilometer grid spacing for the modeling domain.

U.S. Geological Survey (USGS) 1:250,000-scale digital elevation models (DEMs) and Land Use Land Cover (LULC) classification files were obtained and used to develop the geophysical input files required by the CALMET model. USGS 1:250,000-scale (1-degree) DEMs data with 90-meters resolution were obtained from the USGS ftp site: <http://edcftp.cr.usgs.gov/pub/data/DEM/250/>. Using nine 1-degree DEM data files obtained, terrain pre-processor (TERREL) was processed to produce gridded fields of terrain elevation in the formats compatible with the CALMET. The names of 1 degree DEM quadrangles are as follows: Bakersfield-e, Bakersfield-w, Fresno-e, Fresno-w, Los_angeles-e, Los_angeles-w, Monterey-e, San_luis_obispo-e, Santa_maria-e. Figure 4 shows the elevation contours calculated within the model domain.


LULC data (*.gz) were obtained from USGS 250K site, <http://edcftp.cr.usgs.gov/pub/data/LULC/>. Land Use Data Preprocessors, CTGCOMP, and CTGPROC were processed to compress six 250K LULC data files obtained. After processing, the data were quality checked to ensure land use was accurately represented. USGS land use data contain 38 land use categories. These were mapped to 14 categories read by CALMET. The names of 250K LULC quadrangles are as follows: Bakersfield, Fresno, Los_Angeles, Monterey, San_Luis_Obispo, and Santa_Maria. Figure 5 shows the plot of land use data.

The outputs of TERREL and CTGPROC were combined in the geo-physical preprocessor (MAKEGEO) to prepare the CALMET geo-physical input file. These inputs include land use type, elevation, surface parameters (surface roughness, length, albedo, bowen ratio, soil heat flux parameter, and vegetation leaf area index) and anthropogenic heat flux.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas


Figure 4
3-D Terrain Elevation Contours



Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Figure 5
Land Use Land Cover



Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E3.0 CALPUFF PROCESSING

E3.1 RECEPTORS OF CLASS I AREAS

Receptors for all refined CALPUFF modeling of each Class I area were obtained from the NPS' Class I Areas Receptor database (NPS, 2008). No modifications were made to the receptor locations or heights, as provided in the database. The Latitude/Longitude of the Class I receptor coordinates were converted to Lambert Conformal Conic (LCC) coordinates based on domain setup, described in Section 1.2.

Three Class I areas are located within the region of the Project site: Dome Land Wilderness Area, Sequoia National Park, and San Rafael Wilderness Area. Table 1 lists the distances from the Project Site to the closest and farthest points of each Class I area.

Table 1
Class I Areas near the Project Site

Class I Areas	Distance from the Project Site (km)		Model Included?
San Rafael Wilderness Area	Closest	63	Yes
	Farthest	84	Yes
Dome Land Wilderness Area	Closest	110	No
	Farthest	169	No
Sequoia National Park	Closest	123	No
	Farthest	177	No

The NPS does not anticipate any significant air quality impact at Sequoia National Park based on the distance (123 kilometers) from the Project facility, and the low emissions from proposed Project facility. Dome Land Wilderness Area is located in the range of 110 kilometers to 169 kilometer distance from the Project Site. Based on the distance, the low emissions from the proposed Project facility, and the dominant wind direction at Bakersfield monitoring station (dominant wind is blowing from the northwest, while the Dome Land Wilderness Area is located northeast of the Project Site), it was not anticipated that there will be any significant air quality impacts at Dome Land Wilderness Area; therefore, these two Class I areas were not included in the Project analysis. The nearest parts of the San Rafael Wilderness are located beyond 31.1 miles (50 kilometer) and within 62.1 miles (100 kilometer) from the proposed facility; thus, only San Rafael Wilderness Class I area was included in the Air Quality Relative Values (AQRV) analysis.

E3.2 SOURCES INCLUDED IN CALPUFF MODELING

Required emissions in CALPUFF correspond with the needed analysis and include maximum short-term rates for increment and visibility impacts, as well as maximum annual emissions for species deposition and increment comparison. Because of the various operations involved and

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

potential occurrence during a specific period, the CALPUFF modeled sources and emissions included potential overlapping operations.

The maximum, Potential-to-Emit (PTE) emission rate for each averaging time period is shown in Table 2. The maximum emission rates shown in Table 2 in units of grams per second were converted from the corresponding maximum emission rates expressed in units of either pounds per hour, pounds per day, or tons per year contained in the emissions inventory. The maximum PTE rates are conservatively estimated based on simultaneous worst-case operation of all sources at the facility (please note that the auxiliary boiler was exempted in the modeling analysis because the auxiliary boiler is not operating when the HRSG turbine is operating). For example, for the 24-hour analysis, it was assumed that the gasification flare operates for 24 hours of wet flaring. This could happen during a cold gasification plant startup, which is anticipated to occur only one time per year and last up to about 26 hours. However, the 24-hour analysis model conservatively assumed that a full 24 hours of this event happens every day, to make sure a worst case scenario was considered. Otherwise, the gasification flare operates on pilot only. In addition, for the 24-hour analysis, the sulfur recovery unit (SRU) flare emissions were estimated assuming 3 hours of startup/shutdown flaring, and the remainder of the day in pilot operation. This startup/shutdown is anticipated to occur only 6 hours total per year; otherwise, the SRU flare operates on pilot only. However, the model conservatively assumed that a full 3 hours of this flaring event happens every day.

Not only was each source above modeled individually using emission rates based on the worst-case scenario, the modeling approach conservatively assumed that cumulatively all the sources will be operated at those emission rates every day. This is a highly improbable operating scenario and results in a very conservative modeling approach. More details of the conservative nature of the modeling approach may be found in Section 4.1 of this appendix.

The stack parameters of all sources are shown in Table 3.

The CALPUFF modeling included speciation of emissions according to the NPS' Particulate Matter Speciation (PMS) method for natural gas combustion turbines. Applying the PMS methodology, 67 percent of total (SO₂) start speciated into SO₂, and 33 percent of total SO₂ were speciated into SO₄. Also, the total particulate matter 10 microns in diameter or less (PM₁₀) emission from HRSG/Turbine was speciated into Elemental Carbon (EC) and Secondary Organic Aerosol (SOA). The SOA was speciated again into PM_{0.05}, PM_{0.01}, PM_{0.15}, PM_{0.20}, PM_{0.25}, and PM_{1.0} (indicated as PM0005, PM0010, PM0015, PM0020, PM0025, and PM0100 in the modeling, respectively). The PM₁₀ emissions from other sources were modeled directly as PM₁₀. Direct emissions of the remaining species, nitric acid (HNO₃) and nitrate (NO₃), were assumed to be zero for the natural gas burning sources of the project. The modeled emissions are shown in Table 4 (3-hour averaged), Table 5 (24-hour averaged), and Table 6 (annual averaged). The SOA size distribution is shown in Table 7. In addition, total PM emission was separately modeled as INCPM without speciation for incremental PM analysis.

The 3-hour averaged emission rate was used for the 3-hour SO₂ impact analysis. The 24-hour averaged emission rate was used for the 24-hour SO₂ and 24-hour PM₁₀ impact analyses, and

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

visibility impairment impact analysis. The annual emission rate was used for the annual NO_x, annual SO₂, and annual PM₁₀ impact analyses, as well as nitrogen and sulfur deposition analyses.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

Table 2
Maximum Emission Rates of Each Averaging Time Period

Source	3-hr (g/s)	24-hr (g/s)			Annual (g/s)		
	SO ₂	NO _x	SO ₂	PM ₁₀	NO _x	SO ₂	PM ₁₀
ASUCOOL1	-	-	-	0.0285	-	-	0.0271
ASUCOOL2	-	-	-	0.0285	-	-	0.0271
ASUCOOL3	-	-	-	0.0285	-	-	0.0271
ASUCOOL4	-	-	-	0.0285	-	-	0.0271
PWCOOL1	-	-	-	0.0382	-	-	0.0363
PWCOOL2	-	-	-	0.0382	-	-	0.0363
PWCOOL3	-	-	-	0.0382	-	-	0.0363
PWCOOL4	-	-	-	0.0382	-	-	0.0363
PWCOOL5	-	-	-	0.0382	-	-	0.0363
PWCOOL6	-	-	-	0.0382	-	-	0.0363
PWCOOL7	-	-	-	0.0382	-	-	0.0363
PWCOOL8	-	-	-	0.0382	-	-	0.0363
PWCOOL9	-	-	-	0.0382	-	-	0.0363
PWCOOL10	-	-	-	0.0382	-	-	0.0363
PWCOOL11	-	-	-	0.0382	-	-	0.0363
PWCOOL12	-	-	-	0.0382	-	-	0.0363
PWCOOL13	-	-	-	0.0382	-	-	0.0363
GASCOOL1	-	-	-	0.0300	-	-	0.0285
GASCOOL2	-	-	-	0.0300	-	-	0.0285
GASCOOL3	-	-	-	0.0300	-	-	0.0285
GASCOOL4	-	-	-	0.0300	-	-	0.0285
EMERGEN1 ^a	0.0024	0.0324	0.0003	0.0017	0.0022	0.00002	0.0001
EMERGEN2 ^a	-	-	-	-	-	-	-
HRSGSTK	0.9302	6.5718	0.9302	3.0239	4.8092	0.8394	2.8695
FIREPUMP	0.0005	0.0193	0.0001	0.0002	0.0026	0.000008	0.000026
AUX_BOIL ^b	-	-	-	-	0.0492	0.0091	0.0224
TAIL_TO	0.2546	0.6048	0.2546	0.0202	0.3128	0.2521	0.0104
CO ₂ _VENT	-	-	-	-	-	-	-
SRUFLARE	2.1933	0.0720	0.2742	0.0018	0.0049	0.0016	0.0001
GF_FLARE	0.0001	7.9380	0.0001	0.0002	0.1239	0.0001	0.0002
GASVENTA ^c	-	-	-	-	-	-	-

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 2
Maximum Emission Rates of Each Averaging Time Period (Continued)

Source	3-hr (g/s)	24-hr (g/s)			Annual (g/s)		
	SO ₂	NO _x	SO ₂	PM ₁₀	NO _x	SO ₂	PM ₁₀
GASVENTB ^c	0.0046	0.2495	0.0046	0.0181	0.0513	0.0010	0.0037
GASVENTC ^c	-	-	-	-	-	-	-
AUX_CTG	0.2343	1.1149	0.2343	0.7560	0.5011	0.1100	0.3547
DC1	-	-	-	0.0301	-	-	0.0058
DC2	-	-	-	0.0761	-	-	0.0147
DC3	-	-	-	0.0411	-	-	0.0363
DC4	-	-	-	0.0263	-	-	0.0232
DC5	-	-	-	0.0252	-	-	0.0223
DC6	-	-	-	0.0027	-	-	0.0004
RC_FLARE	0.0001	0.0045	0.0001	0.0001	0.0045	0.0001	0.0001

Notes:

- a. The analysis also assumed that all emissions from two emergency generators are released to the emergency generator 1, which has worst-dispersion characteristics.
 - b. Auxiliary boiler is not fired at the same time that the HRSG is operating.
 - c. There are three gasifiers. Only one gasifier warming will be operated at any one time. The emission is from GASVENTB, which results in the worst impact among three gasifiers. SO₂ = sulfur dioxide
- g/s = grams per second
 NO_x = oxides of nitrogen
 PM₁₀ = particulate matter 10 microns in diameter

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 3
Source Location and Parameters

Source ID	Source Description	UTM Easting (m)	UTM Northing (m)	LCC X (km)	LCC Y (km)	Base Elevation (m)	Stack Height (m)	Stack Temperature (K)	Stack Velocity (m/s)	Stack Diameter (m)
ASUCOOL1	ASU Cooling Tower	282891.3	3912002.1	23.21883	30.06171	87.93	16.76	299.9	7.98	9.14
ASUCOOL2	ASU Cooling Tower	282906.2	3912002.4	23.23371	30.06243	87.93	16.76	299.9	7.98	9.14
ASUCOOL3	ASU Cooling Tower	282922.2	3912002.1	23.24975	30.06254	87.93	16.76	299.9	7.98	9.14
ASUCOOL4	ASU Cooling Tower	282937.3	3912001.4	23.26486	30.06224	87.93	16.76	299.9	7.98	9.14
PWCOOL1	Power Block Cooling Tower	283031.9	3912001.1	23.35941	30.06445	87.93	16.76	299.9	7.98	9.14
PWCOOL2	Power Block Cooling Tower	283046.3	3912000.9	23.37385	30.06469	87.93	16.76	299.9	7.98	9.14
PWCOOL3	Power Block Cooling Tower	283061.6	3912001.0	23.38915	30.06519	87.93	16.76	299.9	7.98	9.14
PWCOOL4	Power Block Cooling Tower	283076.9	3912000.0	23.40443	30.06463	87.93	16.76	299.9	7.98	9.14
PWCOOL5	Power Block Cooling Tower	283092.1	3912000.0	23.4196	30.06494	87.93	16.76	299.9	7.98	9.14
PWCOOL6	Power Block Cooling Tower	283107.9	3912000.0	23.4354	30.06545	87.93	16.76	299.9	7.98	9.14
PWCOOL7	Power Block Cooling Tower	283122.7	3911999.4	23.45019	30.06518	87.93	16.76	299.9	7.98	9.14
PWCOOL8	Power Block Cooling Tower	283137.8	3911999.3	23.46529	30.06555	87.93	16.76	299.9	7.98	9.14
PWCOOL9	Power Block Cooling Tower	283153.5	3911999.5	23.481	30.06609	87.93	16.76	299.9	7.98	9.14
PWCOOL10	Power Block Cooling Tower	283168.8	3911999.2	23.49627	30.06622	87.93	16.76	299.9	7.98	9.14
PWCOOL11	Power Block Cooling Tower	283183.7	3911999.6	23.51118	30.06702	87.93	16.76	299.9	7.98	9.14
PWCOOL12	Power Block Cooling Tower	283199.5	3911999.0	23.52698	30.0669	87.93	16.76	299.9	7.98	9.14
PWCOOL13	Power Block Cooling Tower	283275.2	3911998.1	23.60261	30.068	87.93	16.76	299.9	7.98	9.14
GASCOOL1	Gasification Cooling Tower	283214.6	3911999.4	23.54206	30.06768	87.93	16.76	299.9	7.98	9.14
GASCOOL2	Gasification Cooling Tower	283228.6	3911998.4	23.5561	30.06699	87.93	16.76	299.9	7.98	9.14
GASCOOL3	Gasification Cooling Tower	283244.7	3911998.9	23.57215	30.06791	87.93	16.76	299.9	7.98	9.14
GASCOOL4	Gasification Cooling Tower	283259.1	3911998.1	23.5866	30.06755	87.93	16.76	299.9	7.98	9.14
EMERGEN1	Emergency Generator1	282948.3	3912172.0	23.2713	30.23302	87.93	6.10	677.6	67.38	0.37
EMERGEN2	Emergency Generator2	282948.3	3912172.0	23.2713	30.23302	87.93	6.10	677.6	67.38	0.37
HRSGSTK	HRS Stack	282940	3912211.5	23.262	30.27232	87.93	65.00	344.3	11.55	6.10
FIREPUMP	Fire Water Pump Diesel Engine	282770.9	3912535.5	23.08432	30.59164	87.93	6.10	727.6	47.52	0.21

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 3
Source Location and Parameters (Continued)

Source ID	Source Description	UTM Easting (m)	UTM Northing (m)	LCC X (km)	LCC Y (km)	Base Elevation (m)	Stack Height (m)	Stack Temperature (K)	Stack Velocity (m/s)	Stack Diameter (m)
AUX_BOIL	Auxiliary Boiler	282955.1	3912273.0	23.27539	30.33414	87.93	24.38	422.0	9.20	1.37
TAIL_TO	Tail Gas Thermal Oxidizer	283049.1	3912112.7	23.37362	30.1765	87.93	50.29	922.0	7.45	0.76
CO ₂ _VENT	CO ₂ Vent	283045.7	3912389.7	23.36286	30.45327	87.93	79.25	291.5	55.92	1.07
SRUFLARE	SRU Flare	283042.4	3912097.7	23.36739	30.16128	87.93	76.20	1273.0	20.00	1.09
GF_FLARE	Gasification Flare	283064.5	3912472.6	23.37946	30.53658	87.93	76.20	1273.0	20.00	5.47
GASVENTA	Gasifier Warming Vent A	283212.7	3912342.0	23.531	30.41005	87.93	64.01	338.7	26.39	0.30
GASVENTB	Gasifier Warming Vent B	283211.7	3912316.6	23.53075	30.38457	87.93	64.01	338.7	26.39	0.30
GASVENTC	Gasifier Warming Vent C	283211.2	3912291.0	23.53085	30.35898	87.93	64.01	338.7	26.39	0.30
AUX_CTG	AuxiliaryCombustionGasTurbine	282833.9	3912281.9	23.15408	30.33984	87.93	33.53	677.6	15.31	4.88
DC1	FeedStock-DustCollection	283365.3	3913058.7	23.6644	31.13031	87.93	13.87	291.9	15.06	0.51
DC2	FeedStock-DustCollection	283356.0	3912740.9	23.66358	30.81248	87.93	51.97	291.9	14.90	0.81
DC3	FeedStock-DustCollection	283150.4	3912310.2	23.46956	30.37655	87.93	53.79	291.9	14.66	0.56
DC4	FeedStock-DustCollection	283298.0	3912740.9	23.60564	30.81094	87.93	51.97	291.9	15.70	0.43
DC5	FeedStock-DustCollection	283150.4	3912749.0	23.45789	30.81511	87.93	24.23	291.9	15.06	0.43
DC6	FeedStock-DustCollection	283149.9	3912324.5	23.46876	30.39085	87.93	53.79	291.9	14.19	0.23
RC_FLARE	Rectisol Flare	283064.7	3912479.1	23.3795	30.54304	87.93	76.20	1,273	20.00	0.10

Notes:

Assumed that the temperature of cooling tower is 8 Kelvin degrees higher than the annual averaged temperature value from the AERMET meteorological data at Bakersfield monitoring station.

Assumed that the temperature of dust collection is the annual averaged value from the AERMET meteorological data at Bakersfield Monitoring Station B.

K = Kelvin
 km = kilometer
 LCC = Lambert Conformal Conic
 m = meter
 m/s = meters per second
 CO₂ = carbon dioxide
 UTM = Universal Transverse Mercator

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 4
3-Hour Averaged Emission Inventory for CALPUFF (3-hour SO₂ Increment Analysis)

Sources (g/s)	SO ₂	SO ₄	NO _x	HNO ₃	NO ₃	INCPM	PM ₁₀	SOA						EC
								PM0005	PM0010	PM0015	PM0020	PM0025	PM0100	
EMERGEN1	2.35E-03	-	3.89E-01	-	-	1.69E-03	1.69E-03	-	-	-	-	-	-	-
HRSGSTK	6.20E-01	4.65E-01	2.10E+01	-	-	3.02E+00	-	2.70E-01	4.51E-01	4.15E-01	2.70E-01	1.98E-01	1.98E-01	7.56E-01
FIREPUMP	4.70E-04	-	2.32E-01	-	-	1.93E-04	1.93E-04	-	-	-	-	-	-	-
TAIL_TO	2.55E-01	-	6.05E-01	-	-	2.02E-02	2.02E-02	-	-	-	-	-	-	-
SRUFLARE	2.19E+00	-	5.44E-01	-	-	1.80E-03	1.80E-03	-	-	-	-	-	-	-
GF_FLARE	1.29E-04	-	7.94E+00	-	-	1.89E-04	1.89E-04	-	-	-	-	-	-	-
GASVENTB	4.63E-03	-	2.49E-01	-	-	1.81E-02	1.81E-02	-	-	-	-	-	-	-
AUX_CTG	1.56E-01	1.17E-01	2.60E+00	-	-	7.56E-01	-	6.75E-02	1.12E-01	1.03E-01	6.75E-02	4.95E-02	4.95E-02	1.89E-01
RC_FLARE	7.72E-05	-	4.54E-03	-	-	1.13E-04	1.13E-04	-	-	-	-	-	-	-

- Notes:**
- (g/s) = grams per second
 - EC = Elemental Carbon
 - HNO₃ = nitric acid
 - INCPM = total particulate matter emission
 - NO_x = oxides of nitrogen
 - NO₃ = nitrate
 - PM0005 = particulate matter 0.05 microns or less in diameter
 - PM0010 = particulate matter 0.1 microns or less in diameter
 - PM0015 = particulate matter 0.15 microns or less in diameter
 - PM0020 = particulate matter 0.2 microns or less in diameter
 - PM0025 = particulate matter 0.25 microns or less in diameter
 - PM0100 = particulate matter 1 microns or less in diameter
 - PM₁₀ = particulate matter 10 microns or less in diameter
 - SO₂ = sulfur dioxide
 - SO₄ = sulfate compound
 - SOA = Secondary Organic Aerosol

Table 5
24-Hour Averaged Emission Inventory for CALPUFF (24-hour NO_x, SO₂, and PM₁₀ Increment and Visibility Analyses)

Sources (g/s)	SO ₂	SO ₄	NO _x	HNO ₃	NO ₃	INCPM	PM ₁₀	SOA						EC
								PM0005	PM0010	PM0015	PM0020	PM0025	PM0100	
ASUCOOL1	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
ASUCOOL2	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
ASUCOOL3	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
ASUCOOL4	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
PWCOOL1	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL2	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL3	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL4	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL5	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL6	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL7	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL8	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL9	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL10	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL11	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL12	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
PWCOOL13	-	-	-	-	-	3.82E-02	3.82E-02	-	-	-	-	-	-	-
GASCOOL1	-	-	-	-	-	3.00E-02	3.00E-02	-	-	-	-	-	-	-
GASCOOL2	-	-	-	-	-	3.00E-02	3.00E-02	-	-	-	-	-	-	-
GASCOOL3	-	-	-	-	-	3.00E-02	3.00E-02	-	-	-	-	-	-	-
GASCOOL4	-	-	-	-	-	3.00E-02	3.00E-02	-	-	-	-	-	-	-
EMERGEN1	2.94E-04	-	3.24E-02	-	-	1.69E-03	1.69E-03	-	-	-	-	-	-	-
HRSGSTK	6.20E-01	4.65E-01	6.57E+00	-	-	3.02E+00	-	2.70E-01	4.51E-01	4.15E-01	2.70E-01	1.98E-01	1.98E-01	7.56E-01
FIREPUMP	5.88E-05	-	1.93E-02			1.93E-04	1.93E-04							
TAIL_TO	2.55E-01	-	6.05E-01	-	-	2.02E-02	2.02E-02	-	-	-	-	-	-	-
SRUFLARE	2.74E-01	-	7.20E-02	-	-	1.80E-03	1.80E-03	-	-	-	-	-	-	-
GF_FLARE	1.29E-04	-	7.94E+00	-	-	1.89E-04	1.89E-04	-	-	-	-	-	-	-
GASVENTB	4.63E-03	-	2.49E-01	-	-	1.81E-02	1.81E-02	-	-	-	-	-	-	-
AUX_CTG	1.56E-01	1.17E-01	1.11E+00	-	-	7.56E-01	-	6.75E-02	1.12E-01	1.03E-01	6.75E-02	4.95E-02	4.95E-02	1.89E-01
DC1	-	-	-	-	-	3.01E-02	3.01E-02	-	-	-	-	-	-	-
DC2	-	-	-	-	-	7.61E-02	7.61E-02	-	-	-	-	-	-	-
DC3	-	-	-	-	-	4.11E-02	4.11E-02	-	-	-	-	-	-	-
DC4	-	-	-	-	-	2.63E-02	2.63E-02	-	-	-	-	-	-	-
DC5	-	-	-	-	-	2.52E-02	2.52E-02	-	-	-	-	-	-	-
DC6	-	-	-	-	-	2.67E-03	2.67E-03	-	-	-	-	-	-	-
RC_FLARE	7.72E-05	-	4.54E-03	-	-	1.13E-04	1.13E-04	-	-	-	-	-	-	-

Notes:

(g/s)

=

grams per second

EC

=

Elemental Carbon

HNO₃

=

nitric acid

INCPM

=

total particulate matter emission

NO_x

=

oxides of nitrogen

NO₃

=

nitrate

PM0005

=

particulate matter 0.05 microns or less in diameter

PM0010

=

particulate matter 0.1 microns or less in diameter

PM0015

=

particulate matter 0.15 microns or less in diameter

PM0020

=

particulate matter 0.2 microns or less in diameter

PM0025

=

particulate matter 0.25 microns or less in diameter

PM0100

=

particulate matter 1 microns or less in diameter

PM₁₀

=

particulate matter 10 microns or less in diameter

SO₂

=

sulfur dioxide

SO₄

=

sulfate compound

SOA

=

Secondary Organic Aerosol

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 6

Annual Averaged Emission Inventory for CALPUFF (Annual NO_x, SO₂, and PM₁₀ Increment and Deposition Analyses)

Sources (g/s)	SO ₂	SO ₄	NO _x	HNO ₃	NO ₃	INCPM	PM ₁₀	SOA						EC
								PM0005	PM0010	PM0015	PM0020	PM0025	PM0100	
ASUCOOL1	-	-	-	-	-	2.71E-02	2.71E-02	-	-	-	-	-	-	-
ASUCOOL2	-	-	-	-	-	2.71E-02	2.71E-02	-	-	-	-	-	-	-
ASUCOOL3	-	-	-	-	-	2.71E-02	2.71E-02	-	-	-	-	-	-	-
ASUCOOL4	-	-	-	-	-	2.71E-02	2.71E-02	-	-	-	-	-	-	-
PWCOOL1	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL2	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL3	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL4	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL5	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL6	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL7	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL8	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL9	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL10	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL11	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL12	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
PWCOOL13	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
GASCOOL1	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
GASCOOL2	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
GASCOOL3	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
GASCOOL4	-	-	-	-	-	2.85E-02	2.85E-02	-	-	-	-	-	-	-
EMERGEN1	2.01E-05	-	2.22E-03	-	-	1.15E-04	1.15E-04	-	-	-	-	-	-	-
HRSGSTK	5.60E-01	4.20E-01	4.81E+00	-	-	2.87E+00	-	2.60E-01	4.33E-01	3.98E-01	2.60E-01	1.91E-01	1.91E-01	7.17E-01
FIREPUMP	8.05E-06	-	2.64E-03	-	-	2.64E-05	2.64E-05	-	-	-	-	-	-	-
AUX_BOIL	9.13E-03	-	4.92E-02	-	-	2.24E-02	2.24E-02	-	-	-	-	-	-	-
TAIL_TO	2.52E-01	-	3.13E-01	-	-	1.04E-02	1.04E-02	-	-	-	-	-	-	-
SRUFLARE	1.58E-03	-	4.91E-03	-	-	1.23E-04	1.23E-04	-	-	-	-	-	-	-
GF_FLARE	1.29E-04	-	1.24E-01	-	-	1.89E-04	1.89E-04	-	-	-	-	-	-	-
GASVENTB	9.51E-04	-	5.13E-02	-	-	3.73E-03	3.73E-03	-	-	-	-	-	-	-
AUX_CTG	7.33E-02	5.50E-02	5.01E-01	-	-	3.55E-01	-	3.17E-02	5.28E-02	4.85E-02	3.17E-02	2.32E-02	2.32E-02	8.87E-02
DC1	-	-	-	-	-	5.82E-03	5.82E-03	-	-	-	-	-	-	-
DC2	-	-	-	-	-	1.47E-02	1.47E-02	-	-	-	-	-	-	-

Table 6
Annual Averaged Emission Inventory for CALPUFF (Annual NO_x, SO₂, and PM₁₀ Increment and Deposition Analyses) (Continued)

Sources (g/s)	SO ₂	SO ₄	NO _x	HNO ₃	NO ₃	INCPM	PM ₁₀	SOA						EC
								PM0005	PM0010	PM0015	PM0020	PM0025	PM0100	
DC3	-	-	-	-	-	3.63E-02	3.63E-02	-	-	-	-	-	-	-
DC4	-	-	-	-	-	2.32E-02	2.32E-02	-	-	-	-	-	-	-
DC5	-	-	-	-	-	2.23E-02	2.23E-02	-	-	-	-	-	-	-
DC6	-	-	-	-	-	4.00E-04	4.00E-04	-	-	-	-	-	-	-
RC_FLARE	7.72E-05	-	4.54E-03	-	-	1.13E-04	1.13E-04	-	-	-	-	-	-	-

Notes:

(g/s) = grams per second

EC = Elemental Carbon

HNO₃ = nitric acid

INCPM = total particulate matter emission

NO_x = oxides of nitrogen

NO₃ = nitrate

PM0005 = particulate matter 0.05 microns or less in diameter

PM0010 = particulate matter 0.1 microns or less in diameter

PM0015 = particulate matter 0.15 microns or less in diameter

PM0020 = particulate matter 0.2 microns or less in diameter

PM0025 = particulate matter 0.25 microns or less in diameter

PM0100 = particulate matter 1 microns or less in diameter

PM₁₀ = particulate matter 10 microns or less in diameter

SO₂ = sulfur dioxide

SO₄ = sulfate compound

SOA = Secondary Organic Aerosol

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 7
Size Distribution of SOA
(NPS, 2009)

Species Name	Size Distribution (%)	Geometric Mass Mean Diameter (microns)	Geometric Std. Deviation (microns)
SO ₄	100	0.48	0.50
NO ₃	100	0.48	0.50
PM0005	15	0.05	0.00
PM0010	40	0.10	0.00
PM0015	63	0.15	0.00
PM0020	78	0.20	0.00
PM0025	89	0.25	0.00
PM0100	100	1.00	0.00

Notes:

NO₃ = nitrate
NPS = National Park Service
PM0005 = particulate matter 0.05 microns or less in diameter
PM0010 = particulate matter 0.1 microns or less in diameter
PM0015 = particulate matter 0.15 microns or less in diameter
PM0020 = particulate matter 0.2 microns or less in diameter
PM0025 = particulate matter 0.25 microns or less in diameter
PM0100 = particulate matter 1 microns or less in diameter
SO₄ = sulfate compound
SOA = Secondary Organic Aerosol

E3.3 CALPUFF PARAMETERS

The CALPUFF options were selected to follow the EPA's recommended settings for regulatory modeling or WRAP's BART modeling.

Size parameters for dry deposition of nitrate, sulfate, and PM₁₀ particles were based on default CALPUFF model options. Chemical parameters for gaseous dry deposition and wet scavenging coefficients were based on default values presented in the CALPUFF User's Guide. Calculation of total nitrogen deposition includes the contribution of nitrogen resulting from the ammonium ion of the ammonium sulfate compound. For the CALPUFF runs that incorporate deposition and chemical transformation rates (i.e., deposition and visibility), the full chemistry option of CALPUFF was turned on (MCHEM = 1). The nighttime loss for SO₂, NO_x, and HNO₃ was set at 0.2 percent per hour, 2 percent per hour, and 2 percent per hour, respectively. CALPUFF was also configured to allow predictions of SO₂, sulfate (SO₄), NO_x, HNO₃, NO₃ and PM₁₀ using the MESOPUFF II chemical transformation module.

Hourly ozone concentration files (OZONE.DAT) were obtained from the WRAP's BART modeling website for the same years (2001 through 2003) as the meteorological data. Monthly background ozone concentration for missing data from the hourly ozone concentration file was

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

set to 80 parts per billion (ppb). The monthly background ammonia concentration was set to 10 ppb.

As described in Section 3.2, emissions were speciated in accordance with the NPS' PMS guideline (<http://www2.nature.nps.gov/air/permits/ect/index.cfm>). In doing so, the sulfur emissions were speciated to relative sulfur constituents of SO₂ and SO₄ to better account for gas-to-particulate conversion and visibility effects.

E3.4 PSD CLASS I INCREMENT SIGNIFICANCE ANALYSIS

CALMET/CALPUFF (Refined CALPUFF) was used to model ambient air impacts of NO₂, PM₁₀, and SO₂ from the emission sources, and the modeling results were compared to PSD Class I Increment modeling significance thresholds. The sources were modeled at full PTE for this analysis. The full chemistry option of CALPUFF was turned on (MCHEM = 1, MESOPUFF II scheme), and a deposition option was turned on (MWET = 1 and MDRY = 1). The 3-hour averaged maximum SO₂ emission rates were modeled for 3-hour SO₂ increment analysis. Emissions of total SO₂ from the natural gas combustion turbines was speciated based on the NPS' PMS guideline. The 24-hour averaged maximum emission rates were modeled for 24-hour SO₂ and PM₁₀ increment analyses. The annual averaged emission rates were modeled for annual averaged NO_x, SO₂, and PM₁₀ increment analyses. For 24-hour and annual PM incremental analyses, the total PM emission ("INCPM" in the modeling) was modeled without speciation, and the INCPM was treated as fine particulate matter in terms of geometric characteristics.

E3.5 CLASS I AREA VISIBILITY REDUCTION ANALYSIS

Refined CALPUFF was used to evaluate the potential for visibility reduction. All sources were modeled at the full PTE for this analysis. Emissions of total SO₂ and PM₁₀ from the natural gas combustion turbines were speciated based on NPS' PMS guideline as described.

The emissions of thirteen chemical species, SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{0.05}, PM_{0.01}, PM_{0.15}, PM_{0.20}, PM_{0.25}, PM_{1.0}, EC, and PM₁₀, were modeled in CALPUFF to predict the visibility impact based on PMS for natural gas turbine. Because only SO₂ emissions estimates were provided, one-third of the estimated SO₂ emission was assumed to be SO₄ emissions, and the remaining two-thirds remained as SO₂ emissions. For HRSG and Turbine, the total PM₁₀ emissions were speciated into EC and SOA. The SOA is speciated again into PM_{0.05}, PM_{0.01}, PM_{0.15}, PM_{0.20}, PM_{0.25}, and PM_{1.0} (indicated as PM0005, PM0010, PM0015, PM0020, PM0025, and PM0100 in the modeling, respectively). For the other sources such as cooling towers, the total PM₁₀ emissions were modeled as PM₁₀ without speciation.

CALPOST was used to post-process the estimated 24-hour averaged ammonium nitrate, ammonium sulfate, elemental carbon, SOA, and PM₁₀ concentrations into an extinction coefficient value for each day at each modeled receptor, using the 3 years of CALMET meteorological data. To do so required the use of extinction efficiency values.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

All the PM species ($PM_{0.05}$, $PM_{0.01}$, $PM_{0.15}$, $PM_{0.20}$, $PM_{0.25}$, and $PM_{1.0}$) were grouped as SOA. Default extinction efficiencies of PM_{10} (Coarse Particulate), SOA, EC, soil, ammonium sulfate, and ammonium nitrate were used.

Background visibility and extinction coefficient values from the FLAG Phase I Report (December 2000) were used for the visibility reduction analysis. Background values for hygroscopic concentration, without adjustment for relative humidity (RH), (0.6 micrograms per cubic meter [$\mu\text{g}/\text{m}^3$]) and the non-hygroscopic concentration ($4.5 \mu\text{g}/\text{m}^3$) are reported for the western wilderness areas. Therefore, $BKSO_4 = \text{hygroscopic } 0.6/3 = 0.2$ and $BKSOIL = \text{non-hygroscopic} = 4.5$ were used. Modeled visibility reductions for each modeled year were compared to the level of acceptable change (LAC) of 5.0 percent and 10.0 percent.

E3.6 TOTAL NITROGEN AND SULFUR DEPOSITION ANALYSIS

Refined CALPUFF was used to evaluate the potential for nitrogen and sulfur deposition. All sources were modeled at full PTE for this analysis. The annual average emission rates were used for the annual averaged nitrogen and sulfur deposition analyses. The NPS' PMS for natural gas combustion turbines was applied to speciate the emissions of SO_2 and PM from HRSG and turbine as it was done for increment and visibility analyses.

The total deposition rates for each pollutant were obtained by summing the modeled wet and/or dry deposition rates as follows.

For sulfur (S) deposition, the wet and dry fluxes of sulfur dioxide and sulfate are calculated, normalized by the molecular weight of S, and expressed as total S. Total nitrogen (N) deposition is the sum of N contributed by wet and dry fluxes of HNO_3 , NO_3 , ammonium sulfate $((NH_4)_2SO_4)$, and ammonium nitrate (NH_4NO_3) , and the dry flux of oxides of NO_x .

The total modeled nitrogen and sulfur deposition rates were compared to the NPSUSFWS Deposition Analysis Threshold (DAT) for western states. The DAT for nitrogen and sulfur are each 0.005 kilogram per hectare per year (kg/ha-yr), which is equal to $1.59E-11 \text{ g}/\text{m}^2/\text{s}$.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E4.0 MODELING RESULTS

E4.1 CALPUFF MODELING RESULTS

Three years of CALPUFF modeling results are provided in Tables 8 through 10. The model-predicted criteria pollutant increment concentrations were compared to the proposed Class I area Significant Impact Levels (SIL). Each criteria pollutant concentration is less than the corresponding SIL for the San Rafael Wilderness Class I area.

Modeled visibility reductions for each modeled year were compared to the level of acceptable extinction change (LAC) of 5.0 percent. The visibility impact is greater than 5 percent, but less than 10 percent of cumulative modeling threshold. The modeled number of days that exceeds 5 percent of extinction change is 2 days for 2001 and 2003, and 4 days for 2002.

The visibility modeling analysis was performed based on emission rates corresponding to the following very conservative operating scenario:

- It was assumed that the gasification flare operates for the full 24 hours using the wet flaring emission rate. This could happen in a cold gasification plant startup, and is anticipated to occur only one time per year and last up to about 26 hours. Otherwise, the gasification flare operates on pilot only. NO_x emissions from wet flaring are about 1,000 times greater than pilot operation and make the gasification flare during wet flaring the largest source of NO_x on the site. However, the 24 hour analysis model conservatively assumed that a full 24 hours of this event happens every day, a worst case scenario.
- SRU flare emissions for the 24-hour period were estimated assuming 3 hours of startup/shutdown flaring and the remainder of the day in pilot operation. This startup/shutdown is anticipated to occur only 6 hours total per year; otherwise, the SRU flare operates on pilot only. However, the model conservatively assumed that a full 3 hours of this flaring event happens every day.
- The Emergency generator and firewater pump will be operated for 50 hours per year and 100 hours per year, respectively. However, the model conservatively assumed that a full 24 hours of this event happens every day.
- HRSG NO_x emissions were estimated based on 1 cold startup and one hot startup, and the balance of the day at full load using natural gas for a 24 hour period. The model conservatively assumed that a full 24 hours of this event happens every day.

Not only was each source above modeled individually using emission rates based on the worst-case scenario, the modeling approach conservatively assumed that cumulatively all the sources will be operated at those emission rates every day. Based on this very conservative modeling approach, it is expected that no significant visibility impact would occur due to the Proposed Project.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis

For Far-Field Class I Areas

Deposition thresholds of total N and total S are both 0.005 kg/ha/yr, which is equal to 1.59E-11 g/m²/s. Total N and S deposition impact do not exceed the threshold.

None of the results of criteria pollutant increment and deposition analyses exceeded the threshold, and the maximum visibility impact was less than 10 percent with only 2 to 4 days of exceedance of 5 percent despite conservative operating scenario; therefore, the proposed Project sources will not have a significant impact on the ambient air quality of the San Rafael Wilderness Class I area. Because the criteria pollutant concentration and deposition is less than its corresponding significance level, the Project sources will not have a significant impact on either terrestrial resources such as soil and vegetation, or on aquatic resources. Therefore, no further analyses were conducted, including additional AQRV impacts.

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

Table 8
PSD Class I Increment Significance Analysis – CALPUFF Results

Class I Area	Pollutant	Annual NO _x	3-hr SO ₂	24-hr SO ₂	Annual SO ₂	24-hr PM ₁₀	Annual PM ₁₀
	Unit	µg/m ³	µg/m ³	µg/m ³	µg/m ³	µg/m ³	Annual
	Threshold	0.1	1	0.2	0.08	0.32	0.16
San Rafael Wilderness Area	2001	4.09E-03	2.23E-01	2.78E-02	8.06E-04	1.14E-01	4.17E-03
	2002	4.48E-03	2.43E-01	2.98E-02	9.54E-04	1.09E-01	4.76E-03
	2003	4.62E-03	2.84E-01	3.05E-02	9.54E-04	1.23E-01	4.68E-03
Exceed?		No	No	No	No	No	No

Notes:

µg/m³ = micrograms per cubic meter

NO_x = oxides of nitrogen

PM₁₀ = particulate matter 10 microns or less in diameter

PSD = Prevention of Significant Deterioration

SO₂ = sulfur dioxide

Table 9
Visibility Analysis – CALPUFF Results

Class I Area	Pollutant	No. of Days > 5%	No. of Days >10%	Max Extinction Change	Day of Maximum Extinction Change
	Unit	Days	Days	%	Day
	Threshold	0	0	10	
San Rafael Wilderness Area	2001	2	0	9.64	308
	2002	4	0	8.09	287
	2003	2	0	6.58	247
Exceed?				No	

Table 10
Total Nitrogen and Sulfur Deposition Analysis – CALPUFF Results

Class I Area	Pollutant	Deposition N	Deposition S
	Unit	g/m ² /s	g/m ² /s
	Threshold	1.59E-11	1.59E-11
San Rafael Wilderness Area	2001	1.04E-12	4.23E-13
	2002	1.30E-12	5.57E-13
	2003	1.32E-12	4.97E-13
Exceed?		No	No

Appendix E

CALMET/CALPUFF Air Quality Modeling Impact Analysis For Far-Field Class I Areas

E5.0 REFERENCES

- CDPHE, 2005. CALMET/CALPUFF BART Protocol for Class I federal Area Individual Source Attribution Visibility Impairment Modeling Analysis. Colorado Department of Public Health and Environment, Air Pollution Control District, Denver, Colorado. October 24.
- FLAG, 2000. U.S. Federal Land Managers' Air Quality Related Values Workgroup (FLAG) Phase I Report, U.S. Forest Service (FS), National Park Service (NPS), U.S. Fish and Wildlife Service, December 2000.
- Howard Gebhart, 2005. CALPUFF Reviewer's Guide (DRAFT) prepared for USDA Forest Service (Rich Fisher) and National Park Service (John Notar) (September, 2005).
- IWAQM, 1998. Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impact. EPA-454/R-98-019, December 1998.
- National Park Service (NPS), 2009. Permit application PSD particulate matter speciation methodology developed by Don Shepherd, found at: <http://www2.nature.nps.gov/air/permits/ect/index.cfm>.
- National Park Service (NPS), 2008. Class I Area Receptor Data, found at: <http://www2.nature.nps.gov/air/Maps/Receptors/index.cfm>.
- U.S. Environmental Protection Agency (EPA), 1998. Interagency Working Group on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts (December 1998).
- Western Regional Air Partnership (WRAP), 2006. CALMET/CALPUFF Protocol for BART Exemption Screening Analysis for Class I Areas in the Western United States (August 15, 2006).
- Western Regional Air Partnership (WRAP), 2008. BART CALPUFF Modeling, found at: <http://pah.cert.ucr.edu/aqm/308/bart.shtml>.
- Wyoming Department of Environmental Quality (WDEQ), 2006. Conversation with Josh Nall.