



CA CHP GHG Abatement



Contribution of Medium-Sized Commercial Buildings

by

Michael Stadler and Tim Lipman

DOCKET

09-IEP-1H

DATE July 23 2009

RECD. July 27 2009

<http://der.lbl.gov> / <http://www.chpcenterpr.org>

California Energy Commission - 23 July 2009

Team: Chris Marnay, Michael Stadler, Judy Lai, Tim Lipman, Gonçalo Cardoso, Olivier Megel, and Srirupa Ganguly



Environmental Energy Technologies Division



Outline



- Study Overview
- DER-CAM Overview, the **D**istributed **E**nergy Resources Customer **A**doption **M**odel
- CEUS Database
- Results for Medium-Sized Commercial Buildings
- PRAC Update
- “Appendix”: More CEUS / Result Background



Study Overview: CHP in CA Medium-Sized Commercial Buildings



Study Summary




- objective: to estimate the 2020 CO₂ abatement potential of CHP for medium-sized CA commercial buildings (100 kW – 5 MW electric peak load)
- pick a sample of representative buildings from CEUS
- use DER-CAM to examine CHP attractiveness in sample, with competition from other technologies, e.g. PV
- estimate and report CO₂ results relative to CARB goals
- model reference case and alternative scenarios including carbon taxes and “feed-in tariff” (FiT) cases in relation to AB 32 and AB 1613
- propose further work in this under-explored sector



Results Summary (Reference Case)



Incremental 4 GW CHP CARB 2020 GOAL






Distributed Energy Resources Customer Adoption Model (DER-CAM)



DER-CAM Concept





Key Features DER-CAM



- considers multiple technologies as CHP, PV, solar thermal, and storage at the same time
- optimizes costs and / or CO₂ emissions
- uses a bottom up approach, every single building is considered in detail
- can also analyze zero-net energy buildings by adding that as a constraint



CEUS Database



35% of Commercial Electric Demand



Forecasting zones (FZ)




SCE
misc 6%

SDGE
misc 1%

SMUD FZ6
PGE FZ2 5%

LADWP
FZ11-12
9%
OTHER
FZ14-15
3%

16% 15%



16% 14%

- California (statewide)
- CEUS study (limited statewide)
- excluded sites
- studied sites (100 kW < site < 5 MW)



Building Data Sample



- Objective: to estimate the 2020 CO₂ abatement potential of CHP for medium-sized CA commercial buildings (100 kW – 5 MW electric peak load)
- Scope: buildings with electricity peak within range of 100 kW – 5 MW (35% of total electric demand)
- Building sample: 138 buildings of different types and in various climate zones



Results for Medium-Sized Commercial Buildings




Key Assumptions



- not only CHP is considered, also PV, solar thermal
- technology costs in 2020 are based on “Assumptions to the Annual Energy Outlook”, e.g.
 - FC with HX: \$2220 - \$2770/kW, lifetime: 10 years
 - ICE with HX: \$2180 - \$3580/kW, lifetime: 20 years
 - PV: \$3237/kW, lifetime: 20 years
 - etc.
- natural gas tariffs are constant in real terms
- electricity tariffs from early 2009 / late 2008 are used and constant in real terms
- 6% real interest rate (except one sensitivity run)



CO₂ Abatement Best Bldgs. (Reference Case)






Electric Supply Results (Reference Case)




FZ3 (PG&E), Large College, Diurnal Electricity Pattern on a Summer Day






Carbon Tax Cases (for Considered Midsized Bldgs.)





Feed-in Tariff

sales tariff = total purchase tariff, no SGIP incentives






High SGIP for FCs versus Reference Case



High SGIP: vast majority of adopted technologies are FCs with HX





Observations

- DER-CAM delivers highly variable capacity factors between 30% and 88% depending on the considered site and tariff
 - an average capacity factor of 55% is observed in the reference case
 - high average capacity factors of 86% assumed by ARB in scoping plan appear unrealistic
- The lower observed capacity factors impact the electricity generation from CHP considerably
- Carbon taxes drive CHP and PV / solar thermal adoption



Conclusions



- In the reference case, 1.5 GW of CHP is adopted through 2020 in this analysis of the medium-size commercial sector
 - high SGIP case raises this to 2.9 GW
- FiT slightly increases the energy output from CHP
- SGIP for FCs has a big impact
- Future work:
 - more work on appropriate FiT tariffs and impacts on adoption and capacity factors
 - interaction between PV, solar thermal, and CHP
 - effect of inclusion of storage technologies



PRAC Update



PRAC Update




- PRAC is the Pacific Region Combined Heat and Power Application Center, operated by UC Berkeley, UC Irvine, and San Diego State University since 2005
- Sponsored by U.S. DOE and the CA Energy Commission, and with involvement from key partners including electric and gas utilities, Berkeley Lab, CA Clean DG Coalition, etc.
- One of eight DOE regional application centers for CHP
- Has conducted a range of educational, outreach, and direct project assistance activities to promote appropriate CHP adoption in the Pacific Region: CA, NV, HI
- PRAC: <http://www.chpcenterpr.org>



Regional CHP App. Centers

Promoting CHP technology and practices as well as identifying and implementing regional CHP projects






PRAC Update (cont'd)



- The PRAC team has just been awarded a three-year \$1.5M continuation grant by the U.S. Department of Energy
- Proposal cost-matched (20%) by the CA Energy Commission, the Energy Biosciences Institute, and the Univ. of California
- New name for the RACs:
“Pacific Region *Clean Energy* Application Center”
- Still a strong focus on CHP, adding also waste heat-to-power and waste/biogas power applications
- Eventual further expansion into other renewable energy and clean fuels is possible



PRAC Update (cont'd)



Workplan for the new center phase:

- maintain and expand PRAC website
- target market workshops
- waste-heat-to-energy workshop
- revised state “baseline assessment and action plan” reports
- project case study profiles
- policy roadmapping with stakeholders
- identify and facilitate high impact projects
- project management



Contact Info:

Michael Stadler / mstadler@lbl.gov / 510-486-4929

Tim Lipman / telipman@berkeley.edu / 510-642-4501

Thank you!



“Appendix”: More CEUS / Result Background



End-Uses in CEUS




- 3 HVAC End Uses
 - Space Heating
 - Space Cooling
 - Ventilation

- 10 Non-HVAC End Uses
 - Water Heating
 - Cooking
 - Refrigeration
 - Interior Lighting
 - Exterior Lighting
 - Office Equipment
 - Miscellaneous Equipment
 - Air Compressors
 - Motors (non-HVAC)
 - Process Equipment




Annual Electricity Use by Building Types and Zones (CEUS)






Annual Natural Gas Use by Building Types and Zones (CEUS)





NG by End Use in CEUS






Considered Bldg. Types



	Small Office			Large Office			Restaurant			Retail Store			Food/Liquor			Un. Warehouse		
TOTAL	1			25			1			9			9			7		
Zone	S	M	L	S	M	L	S	M	L	S	M	L	S	M	L	S	M	L
FCZ 01				★	★							★			★			
FCZ 03				★	★	★						★			★			★
FCZ 04			★	★	★	★			★			★			★			★
FCZ 05				★	★	★						★			★			★
FCZ 07				★	★	★						★			★			
FCZ 08				★	★	★						★			★			★
FCZ 09				★	★							★			★			★
FCZ 10				★	★	★						★			★			★
FCZ 13				★	★	★						★			★			★

optimizations take up to 10 hours

	School			College			Health Care			Hotel			Misc			Ref. Warehouse			TOTAL
TOTAL	18			18			17			16			0			17			
Zone	S	M	L	S	M	L	S	M	L	S	M	L	S	M	L	S	M	L	TOTAL
FCZ 01		★	★		★	★		★	★			★					★		12
FCZ 03		★	★		★	★		★	★		★	★					★	★	16
FCZ 04		★	★		★	★		★	★		★	★					★	★	18
FCZ 05		★	★		★	★			★		★	★					★	★	15
FCZ 07		★	★		★	★		★	★			★					★	★	14
FCZ 08		★	★		★	★		★	★		★	★					★	★	16
FCZ 09		★	★		★	★		★	★		★	★					★	★	15
FCZ 10		★	★		★	★		★	★		★	★					★	★	16
FCZ 13		★	★		★	★		★	★		★	★					★	★	16
																			138






Marginal Macrogrid CO₂ Emission Rates in 2020



used for the whole state (except **run M-hc**, see following slides)



source: Developing a Greenhouse Gas Tool for Buildings in California: Methodology and Use, Amber Mahone, Snuller Price, William Morrow, Energy and Environmental Economics, Inc., September 10, 2008 and PLEXOS Production Simulation Dispatch Model.





Tariffs



○ PGE

- electric peak load 0 – 199 kW: flat tariff A-1, no demand charge, seasonal difference between winter and summer months of a factor of 1.45
- electric peak load 200 kW – 499 kW: TOU tariff A-10, seasonal demand charge
- Electric peak load 500 kW and above: TOU tariff E-19, seasonal demand charge

○ SCE

- electric peak load 20 – 200 kW: flat tariff GS-2, no demand charge, seasonal difference between winter and summer months of a factor of 1.1
- electric peak load 200 kW – 500 kW: tariff TOU-GS-3, seasonal demand charge
- electric peak load 500 kW and above: tariff TOU-8, seasonal demand charge

○ SDGE

- The same electricity rate is used for all simulations, AL-TOU. The main difference is that fixed cost is higher for above 500kW than below.

Sources: PGE tariffs effective March 1 2009, SCE tariffs effective February 9 2009, SDGE tariffs effective January 1 2009

A-1: http://pge.com/tariffs/tm2/pdf/ELEC_SCHEDS_A-1.pdf

A-10: http://www.pge.com/tariffs/tm2/pdf/ELEC_SCHEDS_A-10.pdf

E-19: http://www.pge.com/tariffs/tm2/pdf/ELEC_SCHEDS_E-19.pdf

GS-2: <http://www.sce.com/NR/sc3/tm2/pdf/ce30-12.pdf>

TOU-GS-3: <http://www.sce.com/NR/sc3/tm2/pdf/CE281.pdf>

TOU-8: <http://www.sce.com/NR/sc3/tm2/pdf/ce54-12.pdf>

AL-TOU: http://www.sdge.com/tm2/pdf/ELEC_ELEC-SCHEDS_AL-TOU.pdf



Sensitivity Runs



18 different scenarios have been performed so far for the midsize commercial sector

- Low NG prices in 2020, spring 2009 NG prices are kept constant in real terms, SGIP of \$500/kW for FCs, **run L**
- High natural prices in 2020, maximum NG prices in 2008 are kept constant in real terms, SGIP of \$500/kW for FCs, **run H**
- Medium NG prices in 2020, average of the NG prices between January 2006 and March 2009 are constant in real terms, SGIP of \$500/kW for FCs, **run M**, **“Reference Case”**
- Medium NG prices in 2020 and higher marginal carbon emission rates during off-peak hours in southern CA, SGIP of \$500/kW for FCs, **run M-hc** (marginal CO₂ rate during off-peak hours of 0.7883kgCO₂/kWh, Marnay, C. et al., “Estimating Carbon Dioxide Emissions Factors for the California Electric Power Sector”, Lawrence Berkeley National Laboratory Report LBNL 49945, Aug.2002.)



Sensitivity Runs



- Medium NG prices in 2020 and **higher marginal carbon emission rates** during off-peak hours in southern CA and **SGIP** incentive of \$750/kW for FCs, **run M-hc-SGIP**
- Medium NG prices in 2020 and **no min.** load constraint, SGIP of \$500/kW for FCs, **run M-no-min** (for all other runs a minimum load constraint of 0.5 is imposed and the engines cannot operate with less than 50% nameplate capacity)
- Medium NG prices in 2020 and **only FCs** are allowed, SGIP of \$500/kW for FCs, **run M-onlyFC**
- Medium NG prices in 2020, **high carbon emissions** in Southern CA, **no PV** and **no solar thermal**, SGIP of \$500/kW for FCs, **run M-hc-noPVSolar**



Sensitivity Runs



do-nothing	run L	run H	run M	run M-hc	run M-hc-SGIP	run M-no-min	run M-onlyFC	run M-hc-noPVSolar
total annual costs (M\$)	4859.7	5381.8	5030.8	5030.8	5030.8	5030.8	5030.8	5030.8
total annual CO2 emissions (Mt/a)	19.7	19.7	19.7	21.4	21.4	19.7	19.7	21.4

invest cases	run L	run H	<u>run M</u> <u>Reference</u> <u>Case</u>	run M-hc	run M-hc-SGIP	run M-no-min	run M-onlyFC	run M-hc-noPVSolar
total annual costs (M\$)	4103.6	5257.0	4837.9	4837.9	4836.1	4838.7	4921.1	4857.6
total annual CO2 emissions (Mt/a)	18.5	18.7	18.4	19.7	19.7	18.4	18.5	20.0
total installed capacities (without PV) (GW)	4.7	0.1	1.5	1.5	1.5	1.6	0.7	1.5
total electricity produced by DG (without PV) (TWh)	24.1	0.4	7.4	7.4	7.4	7.4	3.7	7.4
total cooling offset (TWh)	2.2	0.0	0.4	0.4	0.4	0.4	0.0	0.4
changed costs compared to do-nothing (%)	-15.6	-2.3	-3.8	-3.8	-3.9	-3.8	-2.2	-3.4
changed CO2 compared to do-nothing (%)	-6.2	-4.9	-6.7	-8.0	-8.0	-6.7	-6.1	-6.4
average capacity factor DG (without PV) (%)	58.8	55.5	54.9	54.9	55.0	53.0	63.6	57.9



Sensitivity Runs



- Medium NG prices in 2020 and a 4% interest rate, SGIP of \$500/kW for FCs, **run M-4%i**
- Six different carbon tax runs with and without PV / solar thermal as possible option, SGIP of \$500/kW for FCs
 - \$150/tC (= \$40.1/tCO₂), **run M-lowCtax; run M-lowCtax-noPVSolar**
 - \$450/tC (= \$122.7/tCO₂), **run M-medCtax; run M-medCtax-noPVSolar**
 - \$1000/tC (= \$272.7/tCO₂), **run M-highCtax; run M-highCtax-noPVSolar**
- Medium NG prices in 2020 and a **Feed-in Tariff** which reflects the whole purchase tariff, the feed-in tariff applies to all DG technologies, no SGIP, **run M-FiT** (constraint: purchase > sales; this constraint is needed otherwise some sites would install CHP without limits. This can drive the energy conversion efficiency near the macrogrid efficiency of ca. 34% since most of the waste heat could not be utilized)



Sensitivity Runs



- Medium NG prices in 2020 and a **Feed-in Tariff** which reflects the whole purchase tariff, the feed-in tariff applies to all CHP technologies, **no PV** and **no solar**, no SGIP, **run M-FiTnoPVSolar** (constraint: purchase > sales)
- Medium NG prices in 2020 and a high SGIP incentive of \$1500/kW (=60% of the 2008 incentive value) for FCs and a 60% annual efficiency constraint for FCs using SGIP, **run M-SGIP60%**
- Medium NG prices in 2020 and a **Feed-in Tariff** which reflects the **generation** component of the tariff, the feed-in tariff applies to all DG technologies, no SGIP, **run M-FiTg**
- Medium NG prices in 2020 and a **Feed-in Tariff** using the MPR and TOD, **run M-MPR**, some technical problems / issues needs to be resolved

in all runs electricity tariffs (for purchase) from early 2009 / late 2008 are used and constant in real terms



Sensitivity Runs




do-nothing	run M-4%i	run M-lowCtax	run M-lowCtax - noPVSolar	run M-medCtax	run M-medCtax - noPVSolar	run M-highCtax	run M-highCtax - noPVSolar	run M-FiT	run M-FiT noPVSolar	run M-SGIP60%
total annual costs (M\$)	5030.8	5837.4	5837.4	7449.0	7449.0	10408.1	10408.1	5030.8	5030.8	5030.8
total annual CO2 emissions (Mt/a)	19.7	19.7	19.7	19.7	19.7	19.7	19.7	19.7	19.7	19.7

invest cases	run M-4%i	run M-lowCtax	run M-lowCtax - noPVSolar	run M-medCtax	run M-medCtax - noPVSolar	run M-highCtax	run M-highCtax - noPVSolar	run M-FiT	run M-FiT noPVSolar	run M-SGIP60%
total annual costs (M\$)	4757.0	5574.5	5624.5	6885.8	7147.2	9068.2	9934.4	4828.0	4848.9	4706.9
total annual CO2 emissions (Mt/a)	17.5	17.8	18.7	15.2	18.6	13.9	18.0	18.2	18.7	17.9
total installed capacities (without PV) (GW)	1.4	1.4	1.5	1.5	1.7	1.5	2.2	1.5	1.6	2.9
total electricity produced by DG (without PV) (TWh)	7.4	7.3	7.5	6.4	8.1	7.0	10.7	7.5	8.0	10.3
total cooling offset (TWh) :	0.4	0.4	0.4	0.2	0.4	0.1	0.2	0.4	0.5	0.6
changed costs compared to do-nothing (%)	-5.4	-4.5	-3.6	-7.6	-4.1	-12.9	-4.6	-4.0	-3.6	-6.4
changed CO2 compared to do-nothing (%)	-10.9	-9.9	-5.2	-22.9	-5.6	-29.2	-8.5	-7.8	-5.1	-9.3





Cost Savings – Best Bldgs. (Reference Case)







Installed Capacity (MW) (Reference Case)



By Climate Zone



By Building Type




Total installed capacity in limited statewide = 1.5 GW




On Site Generation (GWh/a) (Reference Case)



By climate zone



By building type



Total on site generation in limited statewide = 7.4 TWh