

INTEROFFICE MEMORANDUM
April 13, 2009

TO: Brian Lusher

Via: Scott B. Lutz *SB*
Daphne Y. Chong *dy*
Glen Long *GL*

FROM: Irma Salinas *IS*

SUBJECT: Results of Health Risk Screening Analysis for Gateway Generating Station (Antioch, CA), Fire Pump Diesel Engine, Plant #18143 Application #20242

Per your request, we have completed a health risk screening analysis for the above referenced permit application. The analysis estimates the incremental health risk resulting from toxic air contaminant (TAC) emissions from operation of a fire pump diesel engine at this facility. Results from the health risk screening analysis indicate that the maximum cancer risk is estimated at 0.82 in a million. In accordance with the District's Regulation 2-5, this risk level is considered acceptable, as the engine does meet current TBACT requirements.

EMISSIONS: Diesel particulate matter (PM) was used as a surrogate for all emitted TACs. The particulate emission rate was calculated based on the following:

Source	PM Emission Factor (g/bhp-hr)	Horsepower	Annual Usage (hours/year)	Diesel PM Emissions (lb/year)
S-47	0.112	300	50	3.694

MODELING: The ISCST3 air dispersion computer model was used to estimate annual average ambient air concentrations. The model was run with Contra Costa Power (2001-2005) meteorological data, emission rate scalars to account for operations that occur only during normal working hours, and Brentwood, Antioch South, Jersey Island and Antioch North terrain data. Model runs were made with both urban and rural dispersion coefficients. The highest concentrations occur for the model run using the rural dispersion coefficients, therefore these values were used in the health risk calculations. Stack and building parameters for the analysis were based on information provided by the applicant.

HEALTH RISK: Estimates of residential risk assume potential exposure to annual average TAC concentrations occur 24 hours per day, 350 days per year, for a 70-year lifetime. Risk estimates for offsite workers assume potential exposure occurs 8 hours per day, 245 day per year, for 40 years. Risk estimates for students assume a higher breathing rate, and potential exposure is assumed to occur 10 hours per day, 36 weeks per year, for 9 years. The estimated health risks for this permit application are presented in the table below.

Receptor	Cancer Risk	Chronic Non-cancer Hazard Index
Resident	0.82 chances in a million	5.0E-4
Worker	0.68 chances in a million	4.9E-4
Student	N/A	N/A

DOCKET

00-AFC-1C

DATE 4/13/2009

RECD. 8/06/2009

Health Risk Screening Analysis Summary for Standby Generator Diesel Engine Facility = Gateway Generating Station: (Antioch CA)

- Plant #18143, Application #20242
- ISCST3 Air Dispersion Model Used
- Contra Costa Power Meteorological Data Used
- Brentwood, Antioch South, Jersey Island, Antioch North Terrain Data Used
- Daytime Scalars Used
- Rural Land Use

Health Risk Estimates:

Receptor	Max. Annual Emission Rate (lb/yr)	Max. Annual Avg. Chl/Q (g/sec)	Max. Annual Avg. Chl/Q (ug/m ³ per g/sec)	Annual Average Exposure Concentration ¹ (ug/m ³)	Inhalation Dose ² (mg/kg-day)	Inhalation Cancer Potency Factor (CPF) (mg/kg-day) ⁻¹	Inhalation Reference Exposure Level (REL) (ug/m ³)	Diesel PM	
								Max. Cancer Risk ³	Max. Non-cancer Hazard Quotient ⁴
Resident	3,694	5.3E-05	4.7E+01	2.5E-03	7.5E-07	1.1E+00	5.0E+00	8.24E-07	5.0E-04
Worker	3,694	5.3E-05	4.7E+01	2.5E-03	6.2E-07	1.1E+00	5.0E+00	6.8E-07	4.9E-04
Student	3,694	5.3E-05	0.0E+00	0.0E+00	0.0E+00	1.1E+00	5.0E+00	0.0E+00	0.0E+00

1. Annual Average Exposure Concentration (ug/m³) = Max. Annual Emission Rate (g/sec) * Max. Annual Avg. Chl/Q (ug/m³ per g/sec)
2. Inhalation Dose (mg/kg-day) = Ann. Avg. Exp. Conc. (ug/m³) * BR (L/kg-day) * UCF (mg-m³/(ug/L) * EAF_(cancer risk)
3. Max. Cancer Risk = Inhalation Dose (mg/kg-day) * CPF (mg/kg-day)⁻¹
4. Max. Non-cancer Hazard Quotient = Ann. Avg. Exp. Conc. (ug/m³) * EAF_(non-cancer) / REL (ug/m³)

Exposure Adjustment Factors (EAFs) for Sources that Operate Intermittently:

	Daily (hours/day)	Weekly (days/week)	Annually (weeks/year)	Lifetime (years per 70 yr lifetime)	Exposure Adjustment Factors (EAFs) ⁵	
					(cancer risk)	(non-cancer hazard quotient)
Resident is Present While Source is Operating	24	7	50	70		
Worker is Present While Source is Operating	8	5	49	40		
Student is Present While Source is Operating	10	5	36	9		
Source is Operating	1	1	50	70	1.00	1.00
Fraction of Time Resident is Present While the Source is Operating	1.00	1.00	1.00	1.00	0.56	0.98
Fraction of Time Worker is Present While the Source is Operating	1.00	1.00	0.98	0.57		
Fraction of Time Student is Present While the Source is Operating	1.00	1.00	0.72	0.13	0.09	0.72

5. Note that the fraction of time that a receptor is present while a source is operating can not exceed one. Thus, if a receptor is present 10 hours/day, but the source operates only 8 hours/day, the maximum that the receptor can be present while the source is operating is the number of hours the source is operating (e.g., 8 hours).

Exposure Parameters:

Receptor	Breathing Rate (BR) ⁶ (L/kg-day)	Exposure Time (ET) (hours/day)	Exposure Frequency (EF) (day/year)	Exposure Duration (ED) (years)	Units Conversion Factor (UCF) (mg-m ³ /(ug-L))	Averaging Time (AT - 70 years) (days)
Resident	302	24	350	70	1.0E-06	25,550
Worker	447	8	245	40	1.0E-06	25,550
Student	581	10	180	9	1.0E-06	25,550

6. Based on a 24-hour day. Worker breathing rate is 149 L/kg-day (for an 8-hour workday), and 447 L/kg-day (for a 24-hour day).

NO ECHO

BEE-Line ISCS13 "BEEST" Version 9.00

Input File - C:\IRMA\BEEST\DCModel\20242\20242raincap2_2001_DIESEL.DTA

Output File - C:\IRMA\BEEST\DCModel\20242\20242raincap2_2001_DIESEL.LST

Met File - C:\metadata\ContraCostaPower\ccp01-05300A.asc

*** Message Summary For ISCS Model Setup ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 2 Warning Message(s)
A Total of 0 Informational Message(s)

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****

SO W320 18 PPARM: Input Parameter May Be Out-of-Range for Parameter DS
RE W282 29298 CHK_EL:ReclEv < Srchase; See non-DEFAULT HE>ZI option in MCB#9

***** SETUP Finishes Successfully ***

*** ISCS13 - VERSION 02035 *** *** Gateway Generation Station: A/N 20242; Plant # 18143

04/14/09
09:11:20
PAGE 1

**MODELOPTS: RURAL ELEV

NOSTD

*** MODEL SETUP OPTIONS SUMMARY ***

**Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCENTRATION Values.

```

-- SCAVENGING/DEPOSITION LOGIC --
**Model Uses NO DRY DEPLETION. DDDLETE = F
**Model Uses NO WET DEPLETION. WDDLETE = F
**NO WET SCAVENGING Data Provided.
**NO GAS DRY DEPOSITION Data Provided.
**Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations
**Model Uses RURAL Dispersion.

**Model Uses User-Specified Options:
  1. Final Plume Rise.
  2. Not Use Stack-tip Downwash.
  3. Buoyancy-induced Dispersion.
  4. Calms Processing Routine.
  5. Not Use Missing Data Processing Routine.
  6. Default Wind Profile Exponents.
  7. Default Vertical Potential Temperature Gradients.

**Model Accepts Receptors on ELEV Terrain.
**Model Assumes No FLAGPOLE Receptor Heights.
**Model Calculates PERIOD Averages Only
**This Run Includes: 1 Source(s); 1 Source Group(s); and 29261 Receptor(s)
**The Model Assumes A Pollutant Type of: DIRSEL
**Model Set To Continue RUNNING After the Setup Testing.

**Output Options Selected:
  Model Outputs Tables of PERIOD Averages by Receptor
  Model Outputs External File(s) of High Values for Plotting (PLOTFILE keyword)
**NOTE: The Following Flags May Appear Following CONC Values: c For Calm Hours
      b for Missing Hours
      m for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 20.00 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
  Emission Units = GRAMS/SEC ; Emission Rate Unit Factor = 0.10000E+07
  Output Units = MICROGRAMS/M**3

**Approximate Storage Requirements of Model = 2.4 MB of RAM.
**Input Runstream File: 20242raincap2_2001_DIRSEL.DTA

```

**Output Print File: 20242raincap2_2001_DIESEL.IST

*** ISCS3 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 *** 04/14/09 09:11:20

MODELPTS: RURAL ELEV NOSTD * PAGE 2

*** POINT SOURCE DATA ***

SOURCE ID	NUMBER EMISSION PART. (GRAMS/SEC) CATS.	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG. K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EMISSION RATE	SCALAR VARY BY
47	0	0.53177E-04	609069.0	4208026.0	3.0	3.25	683.15	0.00	32.34	YES HROFDY

*** ISCS3 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 *** 04/14/09 09:11:20

MODELPTS: RURAL ELEV NOSTD * PAGE 3

*** SOURCE IDS DEFINING SOURCE GROUPS ***

GROUP ID SOURCE IDS

ALL 47

*** ISCS3 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 *** 04/14/09 09:11:20

MODELPTS: RURAL ELEV NOSTD * PAGE 4

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: 47

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK				
1	39.0	89.8	0	2	39.0	100.8	0	3	39.0	108.8	0	4	39.0	113.5	0	5	39.0	114.7	0	6	39.0	112.5	0
7	39.0	106.8	0	8	39.0	97.9	0	9	5.2	15.0	0	10	5.2	14.8	0	11	39.0	106.8	0	12	39.0	112.5	0
13	39.0	114.7	0	14	39.0	113.5	0	15	39.0	108.8	0	16	39.0	100.8	0	17	39.0	89.8	0	18	39.0	76.0	0

19 39.0, 89.8, 0 20 39.0, 100.8, 0 21 39.0, 108.8, 0 22 39.0, 113.5, 0 23 39.0, 114.7, 0 24 39.0, 112.5, 0
 25 39.0, 106.8, 0 26 39.0, 97.9, 0 27 6.4, 9.0, 0 28 5.2, 14.8, 0 29 39.0, 106.8, 0 30 39.0, 112.5, 0
 31 39.0, 114.7, 0 32 39.0, 113.5, 0 33 39.0, 108.8, 0 34 39.0, 100.8, 0 35 39.0, 89.8, 0 36 39.0, 76.0, 0

*** ISCS3 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 ***
 04/14/09

**MODELOPTS: **
 CONC RURAL ELEV NOSTD

 09:11:20
 PAGE 5

* SOURCE EMISSION RATE SCALARS WHICH VARY FOR EACH HOUR OF THE DAY *

SOURCE ID = 47		SOURCE TYPE = POINT		SOURCE ID = 47		SOURCE TYPE = POINT	
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01
.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01	.30000E+01
.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00

*** ISCS3 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 ***
 04/14/09

**MODELOPTS: **
 CONC RURAL ELEV NOSTD

 09:11:20
 PAGE 6

*** DISCRETE CARTESIAN RECEPTORS ***
 (X-COORD, Y-COORD, ZELEV, ZFLAG)
 (METERS)

(599100.0, 4198200.0, 409.7, 0.0);	(599350.0, 4198200.0, 468.8, 0.0);
(599600.0, 4198200.0, 446.5, 0.0);	(599850.0, 4198200.0, 383.4, 0.0);
(600100.0, 4198200.0, 408.7, 0.0);	(600350.0, 4198200.0, 355.1, 0.0);
(600600.0, 4198200.0, 314.2, 0.0);	(600850.0, 4198200.0, 337.1, 0.0);
(601100.0, 4198200.0, 313.3, 0.0);	(601350.0, 4198200.0, 321.6, 0.0);
(601600.0, 4198200.0, 286.8, 0.0);	(601850.0, 4198200.0, 289.6, 0.0);
(602100.0, 4198200.0, 280.4, 0.0);	(602350.0, 4198200.0, 287.4, 0.0);
(602600.0, 4198200.0, 273.4, 0.0);	(602850.0, 4198200.0, 311.8, 0.0);
(603100.0, 4198200.0, 207.6, 0.0);	(603350.0, 4198200.0, 184.1, 0.0);
(603600.0, 4198200.0, 160.9, 0.0);	(603850.0, 4198200.0, 144.2, 0.0);
(604100.0, 4198200.0, 133.5, 0.0);	(604350.0, 4198200.0, 121.9, 0.0);
(604600.0, 4198200.0, 114.6, 0.0);	(604850.0, 4198200.0, 108.8, 0.0);

```

( 605100.0, 4198200.0, 113.1, 0.0); ( 605350.0, 4198200.0, 115.5, 0.0);
( 605600.0, 4198200.0, 153.9, 0.0); ( 605850.0, 4198200.0, 143.9, 0.0);
( 606100.0, 4198200.0, 125.6, 0.0); ( 606350.0, 4198200.0, 114.3, 0.0);
( 606600.0, 4198200.0, 105.5, 0.0); ( 606850.0, 4198200.0, 92.7, 0.0);
( 607100.0, 4198200.0, 86.0, 0.0); ( 607350.0, 4198200.0, 74.7, 0.0);
( 607600.0, 4198200.0, 77.4, 0.0); ( 607850.0, 4198200.0, 82.9, 0.0);
( 608100.0, 4198200.0, 83.5, 0.0); ( 608350.0, 4198200.0, 86.0, 0.0);
( 608600.0, 4198200.0, 66.8, 0.0); ( 608850.0, 4198200.0, 74.1, 0.0);
( 609100.0, 4198200.0, 59.7, 0.0); ( 609350.0, 4198200.0, 55.8, 0.0);
( 609600.0, 4198200.0, 53.6, 0.0); ( 609850.0, 4198200.0, 50.3, 0.0);
( 610100.0, 4198200.0, 50.9, 0.0); ( 610350.0, 4198200.0, 49.1, 0.0);
( 610600.0, 4198200.0, 43.9, 0.0); ( 610850.0, 4198200.0, 42.7, 0.0);
( 611100.0, 4198200.0, 39.9, 0.0); ( 611350.0, 4198200.0, 36.6, 0.0);
( 611600.0, 4198200.0, 35.4, 0.0); ( 611850.0, 4198200.0, 32.9, 0.0);
( 612100.0, 4198200.0, 32.0, 0.0); ( 612350.0, 4198200.0, 30.3, 0.0);
( 612600.0, 4198200.0, 29.9, 0.0); ( 612850.0, 4198200.0, 28.0, 0.0);
( 613100.0, 4198200.0, 27.1, 0.0); ( 613350.0, 4198200.0, 25.9, 0.0);
( 613600.0, 4198200.0, 25.9, 0.0); ( 613850.0, 4198200.0, 25.0, 0.0);
( 614100.0, 4198200.0, 25.0, 0.0); ( 614350.0, 4198200.0, 25.9, 0.0);
( 614600.0, 4198200.0, 24.1, 0.0); ( 614850.0, 4198200.0, 24.1, 0.0);
( 615100.0, 4198200.0, 22.9, 0.0); ( 615350.0, 4198200.0, 22.3, 0.0);
( 615600.0, 4198200.0, 20.1, 0.0); ( 615850.0, 4198200.0, 18.9, 0.0);
( 616100.0, 4198200.0, 18.9, 0.0); ( 616350.0, 4198200.0, 18.0, 0.0);
( 616600.0, 4198200.0, 17.1, 0.0); ( 616850.0, 4198200.0, 17.1, 0.0);
( 617100.0, 4198200.0, 17.1, 0.0); ( 617350.0, 4198200.0, 15.8, 0.0);
( 617600.0, 4198200.0, 14.9, 0.0); ( 617850.0, 4198200.0, 14.0, 0.0);
( 618100.0, 4198200.0, 14.0, 0.0); ( 618350.0, 4198200.0, 11.9, 0.0);
( 618600.0, 4198200.0, 11.9, 0.0); ( 618850.0, 4198200.0, 11.0, 0.0);
( 619100.0, 4198200.0, 9.4, 0.0); ( 619100.0, 4198450.0, 457.8, 0.0);
( 619350.0, 4198450.0, 484.9, 0.0); ( 619350.0, 4198450.0, 457.5, 0.0);
( 619850.0, 4198450.0, 388.6, 0.0); ( 600100.0, 4198450.0, 318.5, 0.0);
( 600350.0, 4198450.0, 391.7, 0.0); ( 600600.0, 4198450.0, 287.4, 0.0);
( 600850.0, 4198450.0, 331.3, 0.0); ( 601100.0, 4198450.0, 249.0, 0.0);

```

*** ISCS73 - VERSION 02035 *** Gateway Generation Station; A/N 20242; Plant # 18143 ***

**MODELPTS: RURAL ELEV

NOSTD

* SOURCE-RECEPTOR COMBINATIONS FOR WHICH CALCULATIONS MAY NOT BE PERFORMED *
 LESS THAN 1.0 METER OR 3*ZIB IN DISTANCE, OR WITHIN OPEN PIT SOURCE

```

SOURCE ID      RECEPTOR LOCATION  DISTANCE
              XR (METERS)  YR (METERS)  (METERS)
-----

```


F .55000E+00 .55000E+00 .55000E+00 .55000E+00 .55000E+00 .55000E+00

*** VERTICAL POTENTIAL TEMPERATURE GRADIENTS ***
(DEGREES KELVIN PER METER)

STABILITY CATEGORY	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01

*** ISCS13 - VERSION 02035 ***
*** Gateway Generation Station; A/N 20242; Plant # 18143 ***

*** MODEL_OPTS: RURAL ELEV NOSTD
04/14/09
09:11:20
PAGE 334

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: cgp01-05300A.asc
FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,I9.4,I10.1,F8.4,I4,F7.2)
SURFACE STATION NO.: 2804 UPPER ATR STATION NO.: 2804
NAME: UNKNOWN NAME: UNKNOWN
YEAR: 2001 YEAR: 2001

YR	MN	DY	HR	VECT	FLOW	SPEED	TEMP	STAB	MIXING	HEIGHT	USTAR	M-O	LENGTH	Z-O	IPCODE	PRATE
				(M/S)	(K)	CLASS	RURAL	URBAN	(M/S)	(M)	(M)	(M)	(mm/HR)			
01	01	01	01	263.5	1.52	276.0	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	02	258.7	2.10	276.4	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	03	230.0	1.39	276.0	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	04	50.8	1.00	275.3	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	05	315.0	1.00	275.3	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	06	264.2	1.12	275.4	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	07	294.2	1.39	275.7	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	08	301.9	1.79	274.9	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	09	355.5	1.00	274.5	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	10	101.3	1.21	275.8	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	11	205.5	1.00	278.0	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	12	258.1	2.68	279.3	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00
01	01	01	13	256.1	3.31	279.8	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00	0	0.00

01	01	01	14	289.7	2.19	281.5	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	15	329.8	2.28	284.5	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	16	354.7	1.79	286.0	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	17	333.9	1.00	285.4	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	18	256.0	1.61	282.9	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	19	289.0	1.52	280.8	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	20	305.9	1.30	279.4	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	21	274.4	1.00	277.9	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	22	203.7	1.00	276.9	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	23	107.0	1.12	276.7	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00
01	01	01	24	259.4	1.00	275.7	3	300.0	300.0	0.0000	0.0	0.0000	0	0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.
 FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCS73 - VERSION 02035 ***
 *** Gateway Generation Station; A/N 20242; Plant # 18143

*** MODELPOINTS: RURAL ELEV NOSTD
 *** THE PERIOD (43824 HRS) AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: ALL
 INCLUDING SOURCE(S) : 47
 *** DISCRETE CARTESIAN RECEPTOR POINTS ***

X-COORD (M)	Y-COORD (M)	CONC	** CONC OF DIESEL IN MICROGRAMS/M**3	X-COORD (M)	Y-COORD (M)	CONC
608991.00	4208345.50	0.00008	608991.00	4208370.00	0.00006	
608991.00	4208394.50	0.00006	608991.00	4208418.50	0.00005	
609009.31	4208443.50	0.00004	609027.69	4208443.50	0.00003	
609047.50	4208458.00	0.00003	609072.50	4208468.00	0.00002	
609118.50	4208457.00	0.00002	609143.25	4208486.50	0.00002	
609162.50	4208501.50	0.00002	609181.75	4208517.00	0.00002	
609200.62	4208507.00	0.00002	609200.31	4208482.50	0.00002	
609199.94	4208457.50	0.00002	609199.56	4208433.00	0.00002	
609199.25	4208408.00	0.00002	609198.88	4208383.00	0.00003	
609198.50	4208358.50	0.00003	609198.19	4208333.50	0.00003	
609197.81	4208309.00	0.00004	609197.50	4208284.00	0.00004	
609197.12	4208259.50	0.00004	609196.75	4208234.50	0.00005	
609196.44	4208209.50	0.00006	609196.06	4208185.00	0.00007	
609195.69	4208160.00	0.00008	609195.38	4208135.50	0.00010	
609195.00	4208110.50	0.00013	609194.62	4208085.50	0.00017	
609194.31	4208061.00	0.00032	609193.94	4208036.00	0.00113	

609193.56	4208011.50	0.00248	MAX	609193.25	4207986.50	0.00221
609192.88	4207961.50	0.00173		609192.50	4207937.00	0.00170
609192.19	4207912.00	0.00155		609191.81	4207887.50	0.00132
609191.50	4207862.50	0.00107		609191.12	4207838.00	0.00087
609190.75	4207813.00	0.00071		609190.44	4207788.00	0.00059
609190.06	4207763.50	0.00050		609189.69	4207738.50	0.00042
609189.38	4207714.00	0.00029		609165.69	4207689.00	0.00031
609142.31	4207689.00	0.00023		609119.00	4207689.00	0.00026
609095.69	4207689.00	0.00022		609072.31	4207689.00	0.00019
609049.19	4207712.50	0.00019		609049.38	4207736.50	0.00021
609049.62	4207760.00	0.00024		609049.81	4207784.00	0.00028
609050.00	4207807.50	0.00033		609050.19	4207831.00	0.00039
609050.38	4207855.00	0.00048		609050.62	4207878.50	0.00060
609050.81	4207902.50	0.00078		609026.81	4207926.50	0.00060
609002.62	4207927.50	0.00056		608978.44	4207928.00	0.00050
608954.25	4207928.50	0.00046		608930.06	4207929.50	0.00042
608905.94	4207930.00	0.00038		608881.75	4207931.00	0.00035
608857.56	4207931.50	0.00031		608833.38	4207932.00	0.00028
608809.19	4207933.00	0.00024		608785.00	4207933.50	0.00022
608760.81	4207934.00	0.00020		608736.62	4207935.00	0.00018
608712.44	4207935.50	0.00016		608688.25	4207936.00	0.00014
608664.06	4207937.00	0.00013		608639.94	4207937.50	0.00012
608615.75	4207938.50	0.00011		608591.56	4207939.00	0.00010
608567.38	4207939.50	0.00009		608543.19	4207940.50	0.00009

*** ISCS73 - VERSION 02035 ***
 *** Gateway Generation Station: A/N 20242; Plant # 18143 ***

**MODELOPTS: RURAL ELEV
 CONC NOSTD

*** THE SUMMARY OF MAXIMUM PERIOD (43824 HRS) RESULTS ***

** CONC OF DIESEL IN MICROGRAMS/M**3

GROUP ID	AVERAGE CONC	RECEPTOR (XR, YR, ZRLEV, ZFIAG)	OF TYPE	NETWORK GRID-ID	
ALL					
1ST HIGHEST VALUE IS	0.00248 AT (609193.56,	4208011.50,	3.00,	0.00)	DC NA
2ND HIGHEST VALUE IS	0.00248 AT (609193.56,	4208011.50,	3.00,	0.00)	DC NA
3RD HIGHEST VALUE IS	0.00240 AT (609200.00,	4208000.00,	3.00,	0.00)	DC NA
4TH HIGHEST VALUE IS	0.00240 AT (609200.00,	4208000.00,	3.00,	0.00)	DC NA
5TH HIGHEST VALUE IS	0.00221 AT (609193.25,	4207986.50,	3.00,	0.00)	DC NA
6TH HIGHEST VALUE IS	0.00221 AT (609193.25,	4207986.50,	3.00,	0.00)	DC NA
7TH HIGHEST VALUE IS	0.00184 AT (609218.25,	4207986.00,	2.90,	0.00)	DC NA

8TH HIGHEST VALUE IS	0.00184 AT (609218.25,	4207986.00,	2.90,	0.00)	DC	NA
9TH HIGHEST VALUE IS	0.00182 AT (609200.00,	4207975.00,	3.00,	0.00)	DC	NA
10TH HIGHEST VALUE IS	0.00182 AT (609225.00,	4208000.00,	2.90,	0.00)	DC	NA

*** RECEPTOR TYPES: GC = GRIDCART
 GP = GRIDPOLR
 DC = DISCCART
 DP = DISCPOLR
 BD = BOUNDARY

*** ISCS13 - VERSION 02035 ***
 *** Gateway Generation Station: A/N 20242; Plant # 18143 ***
 **MODELPTS: RURAL ELEV NOSTD
 CONC

*** Message Summary : ISCS13 Model Execution ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
 A Total of 2 Warning Message(s)
 A Total of 278 Informational Message(s)
 A Total of 278 Calm Hours Identified

***** FATAL ERROR MESSAGES *****
 *** NONE ***

***** WARNING MESSAGES *****
 SO W320 18 PPARM : Input Parameter May Be Out-of-Range for Parameter DS
 RE W282 29298 CHK_EL.Recliev < SrcBase; See non-DEFAULT HB>ZI option in MCB#9

 *** ISCS13 Finishes Successfully ***



Scale: 1" = 195.2 Meters

PERIOD VALUES FOR GROUP: ALL

Max = 0.00248 (609193.6, 4208012)