

DOCKET

09-AFC-5

File: 09-AFC-5

DATE MAR 03 2010

RECD. MAR 03 2010

Project Title: Abengoa Mojave Solar

(x) TELEPHONE() MEETING LOCATION:

NAME: Craig Hoffman

TIME: 9:30

DATE: March 3, 2010

WITH: Kathleen Sullivan, Abengoa Mojave Solar

PHONE (916) 654-4781

ADDRESS:

SUBJECT:

Water recycling as part of the Abengoa Mojave Solar power plant cooling process.

COMMENTS:

Kathleen Sullivan explained that groundwater that would be used for cooling purposes was anticipated of having a Total Dissolved Solids (TDS) of 1,700 parts per million. This is based upon the water samples from the on-site Ryken water well.

The water used in the cooling tower is expected to be recycled 5.8 times until the TDS levels increase and water is used for other activities on-site.

The applicant anticipates recycling water up to 38.5 times throughout the project for various uses until it is discharged to settling ponds.

COPIES TO:

NAME: Craig Hoffman

SIGNATURE: