

<b>DOCKET</b>	
<b>08-AFC-2</b>	
DATE	MAR 16 2010
RECD.	MAR 16 2010

**From:** Sudath Edirisuriya  
**To:** Docket Optical System  
**Date:** 3/16/2010 11:16 AM  
**Subject:** Fwd: Beacon Solar Project

>>> "Le, Ly" <[Ly.Le@ladwp.com](mailto:Ly.Le@ladwp.com)> 3/16/2010 10:58 AM >>>  
 Mr. Edirisuriya,

This e-mail is providing an update of the Beacon Solar Project (BSP):

1) The Barren Ridge- Rinaldi 230 kV is currently rated at 459 MVA. LADWP is planning to upgrade its rating from 459 MVA to 530 MVA by installing the Dynamic Rating Equipment (DRE). The hardware of the DRE was already installed along the line. It was proposed that the new rating can be achieved by November 2010.

2) BSP is entering in the Facilities Study phase. In this phase, LADWP will consider a Remedial Action Scheme (RAS) that will mitigate possible overload of the Barren Ridge-Rinaldi 230 kV Line, prior to the construction of Barren Ridge Renewable Transmission Project (BRRTP). This RAS would include ramping down BSP generation or tripping BSP and would be temporarily in-place until the completion of the BRRTP.

Regards,

Ly Le

LADWP - Transmission Studies

(213) 367-0302

-----Confidentiality Notice-----

This electronic message transmission contains information from the Los Angeles Department of Water and Power, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited. If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.