

WEDNESDAY JANUARY 10, 1990

0730 SHIFT CHANGE
 "A" on Duty "C" off Duty
 CAPT. G. MCPHEE CAPT. M. MISSILDINE
 ENG. S. MAIN ENG. M. SYLVIA

Commence Station Routine

0800 APPARATUS MAINTENANCE SHIFT CHANGE CHECKS
 AM 2 hr. \$ ROAD TEST E-17 OK S-17 OK BECK ALS OK

0850 FIRE # 953

NAME: LUZ CORPORATION
 HARPER LAKE ROAD
 SAN BERNADINO, COUNTY

Type: Structure

Loss: UNKNOWN (AT LEAST 24 MILLION)

Equip & CREW: E-17 MCPHEE & MAIN E.A.F.B. FOAM TRAILER
 CRASH TRUCK # 2 MANY UNITS FROM SAN BERDO
 & C.D.F. - HELENDALE, HINKLEY, VICTORVILLE,
 APPLE VALLEY, ADCANTO

OVERHEAD: CDF B/C

Cause: UNKNOWN

SUMMARY: EXPLOSION OR FIRE IN HEATING UNITS
 of SOGAR GENERATING PLANT. - EIT WAS

FIRE
 15:34 hr.

Assigned NORTH SIDE OF PLANT COOLING LARGE
 CONDENSING UNIT - LAID PARALLEL LINES TO
 MONITOR AND PUMPED APPROX. 360,000 GAL
 WATER - CREW WAS EXPOSED TO RUN-OFF WATER
 & AIR BORN CHEMICAL "THERMONALL" (SPELLING
 MAY BE WRONG) BLANKET EXPOSURE RECORD WILL
 BE SUBMITTED BY C.P.F. - OPERATIONS & SAFETY
 of CREW IT WERE HAMPERED BY LACK OF
 COMMUNICATIONS WITH C.D.F. & SAN BERDO FIRE
 DEPTS.

0933 E-H-2 GAETA & LILLARD 197 COVER

1551 MEDICAL AID # 985

M.A. 1 hr.

NAME: [REDACTED]

LOCATION: [REDACTED]

BOBEN

DOCKET**09-AFC-5**

DATE JAN 10 1999

RECD. JUN 22 2010