

DOCKET

09-AFC-5

DATE MAY 25 2010

RECD. JUN 22 2010

Telephone Conversation Record

To: Richard Frymyer, General Manager
Sunray Energy, Cogentrix Solar Services

From: Shon Greenberg
Risk Science Associates

Phone Number: (760) 254- 3381
Date: May 25, 2010, 1:15pm

Regarding: Emergency response to SEGS 1 and 2, Daggett, CA

In response to my inquiry Richard Frymyer indicated that his company purchased this facility in February of 2009 so he doesn't have the prior safety records. However, he has reviewed their safety records (since he was also very interested in this topic when the facility was acquired) and to the best of his knowledge there were only three fire department/emergency responses to these facilities since they began operation in 1984. Two of the incidents were false alarms. The incidents are:

1. Feb 25, 1999: An HTF fire occurred in the HTF tanks. This was a major fire and the fire department was called upon. The HTF was allowed to burn itself out which took about 2 days. There were no injuries.
2. Feb 28, 2000: An employee had a suspected heart attack (which was actually caused by drinking a whole bottle of jabanyero hot sauce), and an ambulance responded from the fire department.
3. May 15-17, 2010: An HTF spill of about 60 gallons occurred in the solar field. The facility personnel cleaned it up on May 15th and reported it to San Bernardino County on the next business day, May 17th. When receiving the report the dispatcher misunderstood the report and sent out a 911 call indicating a spill is in progress. The whole fire department showed up on scene.