

CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET
 SACRAMENTO, CA 95814-5512
 www.energy.ca.gov

**DOCKET**

January 14, 2011

08-AFC-9DATE JAN 14 2011RECD. JAN 14 2011

Dear Librarian:

**DOCUMENT HANDLING FOR THE PALMDALE HYBRID POWER PROJECT (08-AFC-9)
 and POSTING OF PUBLIC NOTICE**

The enclosed Final Staff Assessment (FSA) contains the California Energy Commission staff's engineering and environmental evaluation of the proposed Palmdale Hybrid Power Project. The FSA was issued on December 22, 2010.

Please make this FSA available for those who may wish to be informed about the project. We request that you not allow the FSA or any of its contents to be removed from the library. To increase accessibility of the document, we ask, if possible, that you cross reference it as a general reference work under the title and author categories, as well as under such subjects as "Energy Commission," "electricity energy/generation," "power plant siting," or any other relevant subject. Please retain the enclosed letter to the public behind the front cover of the FSA.

The Energy Commission's siting process is open to the public and incorporates the input of the public as well as local, state and federal agencies. To facilitate public participation in our review process, the Commission distributes copies of staff documents such as the FSA to public libraries in communities near the proposed project, and in major cities throughout the state. As such, please retain a copy of the enclosed Notice of Availability behind the front cover of the FSA.

Thank you for your cooperation. If you have any questions, please contact Felicia Miller, Siting Project Manager at (916) 654-4640 or at the address on this letterhead or by email to fmiller@energy.state.ca.us.

Sincerely,

Original Signed by: _____

ROGER JOHNSON, Siting Office Manager
 Siting, Transmission and Environmental Protection
 Division

Enclosure

Mailed to list:
 7288 - Library

PROOF OF SERVICE (REVISED 1/5/11) FILED WITH
 ORIGINAL MAILED FROM SACRAMENTO ON 1/14/11
 TKG

CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET
SACRAMENTO, CA 95814-5512
www.energy.ca.gov



January 14, 2011

**NOTICE OF AVAILABILITY
FINAL STAFF ASSESSMENT FOR THE PROPOSED
PALMDALE HYBRID POWER PROJECT (08-AFC-9)**

TO: MEMBERS OF THE PUBLIC

This notice is to inform you of the availability of the Final Staff Assessment (FSA) for the Palmdale Hybrid Power project (PHPP), Application for Certification (08-AFC-9).

Energy Commission Staff Documents and Hearings

Energy Commission staff published the FSA on the PHPP on December 22, 2010. This document included staff's analysis, conclusions, and recommendations for the project. The FSA has been prepared based upon written comments provided by the applicant, agencies and the public and discussions at the Preliminary Staff Assessment workshops held on February 11, 2010 and March 16, 2010. The PHPP FSA contains the Energy Commission staff's final environmental and engineering evaluation of the project and will serve as staff's testimony during evidentiary hearings to be held by the Energy Commission Committee assigned to hear this case. The Committee will hold evidentiary hearings and will consider the testimonies presented by staff, applicant, interveners and comments from government agencies and the public prior to preparing the Presiding Member's Proposed Decision (PMPD), which will have a 30-day comment period. The revised PMPD will then be considered by the full Energy Commission which will issue the final decision.

Summary of the California Energy Commission Staff's Conclusions

With the exception of air quality, staff believes the project as currently proposed, including the applicant's and staff's proposed mitigation measures and with the Commission's adoption of staff's proposed conditions of certification, the PHPP would not cause significant adverse impacts and would comply with all applicable laws, ordinances, regulations, and standards (LORS). For a more detailed review of potential impacts and LORS conformance, see staff's technical analysis in the FSA.

Summary of the Proposed Palmdale Hybrid Power Project

On August 4, 2008 the City of Palmdale filed an Application for Certification (08-AFC-9) with the California Energy Commission to construct and operate the Palmdale Hybrid Power Project: a hybrid of natural gas-fired combined generating equipment integrated with solar thermal generating equipment. The plant will have a net electrical output of 617 megawatts (MW), and would include two natural gas-fired combustion turbine-generators (CTGs) rated at 172 MW each, two heat recovery steam generators (HRSGs), one steam turbine-generator (STG) rated at 292 MW, and 250 acres of parabolic solar-thermal collectors with associated

heat transfer equipment. The solar-thermal collectors would contribute up to 50 MW of the STG's 292 MW output, and with plant auxiliary loads of about 19 MW, PHPP's net output would be 617 MW.

Construction of the proposed PHPP would require permanent use of 333 acres at the power plant site, located immediately north and west of the combined facilities of Los Angeles/Palmdale Regional Airport and Air Force Plant 42. Air Force Plant 42 supports facilities for the production, engineering, final assembly and flight testing of high performance aircraft. The project site is located approximately 60 miles north of downtown Los Angeles and in the northernmost portion of the city of Palmdale. The site address is 950 East Avenue M, bounded on the west by vacant land and then Sierra Highway, on the north by East Avenue M, on the east by East 15th Street and on the south by Avenue M-12.

The proposed PHPP facility would feed power through a 230- kilovolt (kV) transmission system into Southern California Edison's (SCE's) existing Pearblossom Substation and ultimately interconnect to the power grid through SCE's existing Vincent Substation. Vincent substation is located approximately 11 miles south-southwest of the proposed PHPP site, but the interconnection would require a total 35.6 miles of 230-kV overhead transmission line to avoid affecting aviation operations of the Los Angeles/Palmdale Regional Airport and Air Force Plant 42.

Natural gas would be delivered to the project through a new 8.7-mile, 20-inch diameter pipeline designed and constructed by Southern California Gas (SCG), originating at the SCG facility on East Avenue S Street, and terminating at PHPP. The pipeline route would generally follow northward near or adjacent to Sierra Highway through existing street ROWs within the city of Palmdale.

On an annual basis, the proposed PHPP would consume a maximum of about 3,150 acre-feet/year of water for power plant processes, primarily serving cooling demand for an evaporative (wet) cooling tower used for steam condensation and an evaporative cooler for each CTG's inlet air cooling. Process water needs would be met by the use of reclaimed water supplied by the Palmdale Water Reclamation Plant (PWRP). Reclaimed water would be conveyed in a new 7.4-mile, 14-inch pipeline extending from the PWRP located southeast of the proposed site, and then following a general path of westward along East Avenue P Street, northward along Sierra Highway, and then eastward along East Avenue M Street. Potable water would be supplied to the proposed project by Los Angeles County Waterworks District No. 40 via a new 1.0-mile pipeline extending to the PHPP along East Avenue M Street from a connection at an existing pipeline near the intersection with Sierra Highway.

Air emissions from the combustion of natural gas in the CTGs and duct burners within the HRSGs would be controlled using best available control technology applied to their exhaust. Oxides of nitrogen (NOx) from the CTG's stack emissions would be controlled by dry low-NOx combustors followed by a selective catalytic reduction system in each of the HRSGs. An oxidation catalyst located within each HRSG would also control carbon monoxide (CO) and volatile organic compounds (VOC). In order to be considered for licensing by the Energy Commission, the project would be required to conform with rules and regulations of the Antelope Valley Air Quality Management District and be issued a Determination of Compliance from the Air District.

Energy Commission Licensing Authority

The Energy Commission is responsible for reviewing and ultimately approving or denying all applications for construction and operation of thermal electric power plants, 50 MW and greater, proposed for construction in California. The Energy Commission's facility certification process carefully examines public health and safety, environmental impacts and engineering aspects of proposed power plants, and all related facilities such as electric transmission lines and natural gas and water pipelines. The Energy Commission is the lead agency under the California Environmental Quality Act (CEQA), and produces several environmental and decision documents rather than an Environmental Impact Report.

Public Resources, Contact Information and Additional Sources for Information

If you desire information on how to participate in the Energy Commission's review of the proposed project, please contact Jennifer Jennings, the Energy Commission's Public Adviser, at (916) 654-4489 or toll free in California at (800) 822-6228, or by email at publicadviser@energy.state.ca.us.

To request special accommodations for those persons with disabilities, please contact Lourdes Quiroz, the Energy Commission's Equal Employment Opportunity Officer at lquiroz@energy.state.ca.us or by telephone at (916) 654-5146. For those persons with limited English knowledge, request interpreter services by contacting the Project Manager, Felicia Miller at fmiller@energy.state.ca.us or by telephone at (916) 654-4640.

The status of the project, an electronic copy of the FSA, copies of notices, and other relevant documents are also available on the Energy Commission's web site at <http://www.energy.ca.gov/sitingcases/palmdale>.

News media inquiries should be directed to Assistant Director, Susanne Garfield at (916) 654-4989, or by email at mediaoffice@energy.state.ca.us.

Sincerely,

Date: _____

Original Signed by: _____
ROGER E. JOHNSON, Siting Office Manager
Siting, Transmission and Environmental
Protection Division

January 14, 2011
Page 4

Note: Please retain a copy of this Public Notice behind the front cover of the Final Staff Assessment (FSA) and post a copy of the Public Notice in a place conspicuous and accessible to those members of the general public who visit the library. Thank You.



BEFORE THE ENERGY RESOURCES CONSERVATION AND DEVELOPMENT
COMMISSION OF THE STATE OF CALIFORNIA
1516 NINTH STREET, SACRAMENTO, CA 95814
1-800-822-6228 – WWW.ENERGY.CA.GOV

APPLICATION FOR CERTIFICATION
For the *PALMDALE HYBRID*
POWER PROJECT

Docket No. 08-AFC-9

PROOF OF SERVICE

(Revised 1/5/2011)

APPLICANT

Thomas M. Barnett
Executive Vice President
Inland Energy, Inc.
3501 Jamboree Road
South Tower, Suite 606
Newport Beach, CA 92660
tbarnett@inlandenergy.com

Antonio D. Penna Jr.
Vice President
Inland Energy
18570 Kamana Road
Apple Valley, CA 92307
tonypenna@inlandenergy.com

Laurie Lile
Assistant City Manager
City of Palmdale
38300 North Sierra Highway, Suite A
Palmdale, CA 93550
llile@cityofpalmdale.org

APPLICANT'S CONSULTANTS

Sara J. Head, QEP
Vice President
AECOM Environment
1220 Avenida Acaso
Camarillo, CA 93012
sara.head@aecom.com

COUNSEL FOR APPLICANT

Michael J. Carroll
Marc Campopiano
Latham & Watkins, LLP
650 Town Center Drive, Ste. 2000
Costa Mesa, CA 92626
michael.carroll@lw.com
marc.campopiano@lw.com

INTERESTED AGENCIES

Ronald E. Cleaves, Lt. Col, USAF
Commander ASC Det 1 Air Force
Plant 42
2503 East Avenue P
Palmdale, CA 93550
Ronald.Cleaves@edwards.af.mil

Erinn Wilson
Staff Environmental Scientist
Department of Fish & Game
18627 Brookhurst Street, #559
Fountain Valley, CA 92708
E-mail preferred
ewilson@dfg.ca.gov

Richard W. Booth, Sr. Geologist
Lahontan Regional
Water Quality Control Board
2501 Lake Tahoe Blvd.
South Lake Tahoe, CA 96150-2306
rbooth@waterboards.ca.gov

Rick Buckingham
3310 El Camino Avenue, LL-90
State Water Project
Power & Risk Office
Sacramento, CA 95821
E-mail preferred
rbucking@water.ca.gov

Manuel Alvarez
Southern California Edison
1201 K Street
Sacramento, CA 95814
Manuel.Alvarez@sce.com

Robert C. Neal, P.E.
Public Works Director
City of Lancaster
44933 Fern Avenue
Lancaster, CA 93534-2461
rneal@cityoflancasterca.org

California ISO
E-mail Preferred
e-recipient@caiso.com

Robert J. Tucker
Southern California Edison
1 Innovation Drive
Pomona, CA 91768
Robert.Tucker@sce.com

Christian Anderson
Air Quality Engineer
Antelope Valley AQMD
43301 Division St, Suite 206
Lancaster, CA 93535
E-mail preferred
canderson@avaqmd.ca.gov

Keith Roderick
Air Resources Engineer
Energy Section/Stationary Sources
California Air Resources Board
P.O. Box 2815
Sacramento, California 95812
E-mail preferred
kroderic@arb.ca.gov

INTERVENORS

* Lisa T. Belenky, Senior Attorney
Center for Biological Diversity
351 California St., Suite 600
San Francisco, CA 94104
lbelenky@biologicaldiversity.org

*Jane Williams
Desert Citizens Against Pollution
Post Office Box 845
Rosamond, CA 93560
dcapjane@aol.com

ENERGY COMMISSION

JEFFREY D. BYRON
Commissioner and Presiding Member
jbyron@energy.state.ca.us

ANTHONY EGGERT
Commissioner and Associate Member
aeggert@energy.state.ca.us

Ken Celli
Hearing Officer
kcelli@energy.state.ca.us

Kristy Chew
Advisor to Commissioner Byron
E-mail preferred
kchew@energy.state.ca.us

Lorraine White
Advisor to Commissioner Eggert
E-mail preferred
lwhite@energy.state.ca.us

Felicia Miller
Project Manager
fmiller@energy.state.ca.us

Lisa DeCarlo
Staff Counsel
ldecarlo@energy.state.ca.us

Jennifer Jennings
Public Adviser
E-mail Preferred
publicadviser@energy.state.ca.us

DECLARATION OF SERVICE

I, Teraja` Golston, declare that on, January 14, 2011, I served and filed copies of the attached (08-AFC-9) Palmdale - Library Letters Regarding Final Staff Assessment. The original document, filed with the Docket Unit, is accompanied by a copy of the most recent Proof of Service list, located on the web page for this project at: [<http://www.energy.ca.gov/sitingcases/palmdale/index.html>]. The document has been sent to both the other parties in this proceeding (as shown on the Proof of Service list) and to the Commission's Docket Unit, in the following manner:

(Check all that Apply)

For service to all other parties:

sent electronically to all email addresses on the Proof of Service list;

by personal delivery;

by delivering on this date, for mailing with the United States Postal Service with first-class postage thereon fully prepaid, to the name and address of the person served, for mailing that same day in the ordinary course of business; that the envelope was sealed and placed for collection and mailing on that date to those addresses NOT marked "email preferred."

AND

For filing with the Energy Commission:

sending an original paper copy and one electronic copy, mailed and emailed respectively, to the address below (preferred method);

OR

depositing in the mail an original and 12 paper copies, as follows:

CALIFORNIA ENERGY COMMISSION

Attn: Docket No. 08-AFC-9

1516 Ninth Street, MS-4

Sacramento, CA 95814-5512

docket@energy.state.ca.us

I declare under penalty of perjury that the foregoing is true and correct, that I am employed in the county where this mailing occurred, and that I am over the age of 18 years and not a party to the proceeding.

Original Signed by: _____

Teraja` Golston