

Docket Optical System - Fwd: FW: Plan Check and the Proposed Revisions to the NSHP Guidebook

From: Le-Quyen Nguyen
To: Docket Optical System
Date: 10/7/2011 2:26 PM
Subject: Fwd: FW: Plan Check and the Proposed Revisions to the NSHP Guidebook

Hello Dockets,

Please add the email below to Docket #06-NSHP-1.

Thanks!
 Le-Quyen Nguyen
 Renewable Energy Office

DOCKET

06-NSHP-1

DATE OCT 07 2011

RECD. OCT 07 2011

-----Original Message-----

From: Sarah [mailto:sarah@soldata.com]
 Sent: Friday, October 07, 2011 10:28 AM
 To: Dimitrova, Miglena D
 Subject: RE: Plan Check and the Proposed Revisions to the NSHP Guidebook

Hi Maggie:

I have a few suggestions and comments for your consideration:

Chapt II, B: references to PV serving electric loads for portions of multi-family projects and defined rules as to which buildings must meet EE requirements but there is no place on the application for this information to be recorded. Since plan check needs to know what must be reviewed, I think the application is a good place to pass this information from applicant on down the line.

Page C-1, Appendix C: middle of page "signed by a CEPE" should include "or CEA"

Page C-2: under "B. CF-4R-EE NSHP Part I..."; first line "CF-4R-NSHP" is missing "EE"

Page C-3, C.: Is the CF-4R-EE NSHP available for review? I would like to see it, if I can. It sounds like it is to verify the special features of a project. I am concerned about the description of "Multiple conditioned zones" in the list of Special Features which were copied directly from the ACM Manual. The wording is misleading in what needs to be inspected since the special feature is to point out that zonal control credit is being taken, not that the house has multiple HVAC zones.

I am fine with the rest of the wording on plan check requirements.

Sarah
 SolData Energy Consulting
 (707) 545-4440 voice
 (707) 545-4447 fax