



**DOCTOR ENERGY**  
**Your Home Comfort, Safety, and HERS Specialists**

To Whom It May Concern,

At Doctor Energy, we feel that removing the Flow Hood as an approved method of airflow measure is a mistake. The flow hood allows us as raters to accurately, effectively, and efficiently measure HVAC system airflow. Removing this method will lead to many frustrations in the field as well as price increases for all HERS tests that utilize this method of measurement. Please re-consider this aspect of the up-coming 2013 energy code.

Thank you for your considerations,

Dan Fournier

Owner

Doctor Energy

209.756.3996

CC2005573

<b>DOCKET</b>
<b>10-BSTD-01</b>
DATE _____
RECD. <u>Jan 25 2012</u>