

## Cluster 1 & 2 Deliverability Analysis without Expensive and Long-Lead Network Upgrades

### Objective

This analysis was performed pursuant to the October 31, 2012 Technical Bulletin on Cluster 1-4 Deliverability Procedures and for the sole purpose of applying those procedures to Cluster 1 & 2. The following projects and upgrades met the criteria for removal:


- Mohave–Lugo 500 kV line loop-in at Pisgah 500 kV Substation and series capacitor banks on both Pisgah–Nipton and Pisgah–Mohave 500 kV lines
- A 31 miles of new Colorado River – Red Bluff No.3 line
- A 103 miles of new Red Bluff – Valley 500 kV line with series cap banks
- Upgrade of Pisgah 230kV substation to 500kV substation and Lugo – Eldorado 500kV line loop-in at Pisgah 500kV bus
- Tearing down Pisgah – Lugo 230kV No. 2 line and the new Pisgah – Lugo 500kV No. 1 line
- Q72 and associated upgrades

The following network upgrades and modifications were modeled due to the removal of the above elements:

- The 3<sup>rd</sup> Lugo 500/230 kV transformer bank. The transformer bank is required for the Cluster 1 & 2 projects in the North of Lugo area. In addition, the deliverability sensitivity study on the 2011/12 Base 33% renewable portfolio has identified the need for the transformer bank if Pisgah 500kV upgrade were not built.
- New Coolwater – Jasper – Lugo 230 kV line. The line is required for Serial Group projects that have signed LGIA (Q125 and Q135), and Q125 has a CPUC approved PPA. The new Jasper – Lugo line is built by tearing down portion of the existing Lugo – Pisgah 230 kV No. 1 line. In this study we replace Lugo – Pisgah 230 kV No. 1 line with Lugo – Jasper 230 kV line and Jasper – Pisgah 230 kV line. The Lugo – Jasper 230 kV line is rebuilt with higher rating and the Jasper – Pisgah 230 kV line has the same rating as the existing line.
- Lugo – Eldorado 500kV loop-in at Nipton 500 kV substation is required to interconnect a Serial Group project Q126 and will be modeled. There are two existing series capacitors on the Lugo – Eldorado 500 kV line. The study assumes that the Eldorado series capacitor is replaced by a new series capacitor at Nipton to maintain the same level of compensation as the existing line. The existing series capacitor at Lugo substation has a low rating and is normally by-passed. In this study the Lugo series capacitor is initially assumed bypassed. Then a sensitivity study is performed with this series capacitor upgraded.

The figure below shows the transmission system to be modeled. The four shaded oval areas in the diagram below represent deliverability constraints and the general location of four groups of generation affected by those constraints.

|                  |             |
|------------------|-------------|
| <b>DOCKET</b>    |             |
| <b>12-IEP-1D</b> |             |
| DATE             | JAN 31 2012 |
| RECD.            | JUN 08 2012 |



### Summary of Results – Desert<sup>1</sup> Area Constraints

Table 1 provides a very high level summary of the range of MWs that are deliverable without the delivery network upgrades identified above. Given that there is approximately 11,300 MW of generation in the ISO queue that significantly flow across the deliverability constraints described in detail later, approximately 6,000 MW to 7,900 MW can be accommodated as fully deliverable without the need for the major upgrades listed above. Approximately 8,100 MW to 9,300 MW can be accommodated as fully deliverable with the series capacitor in the Lugo – Nipton 500kV line upgraded. As a comparison, the renewable portfolios under study in the 2011/2012 ISO transmission planning process have no more than approximately 7000 MW of renewable generation that significantly flow across these constraints.

<sup>1</sup> The Desert Area refers to generating resources electrically located in the following renewable energy zones: Pisgah, Mountain Pass, Nevada C, New Mexico, Palm Springs, Riverside East, San Diego South, Imperial, and Arizona.

Table 1. Summary of Results – SCE Area

| Deliverable MW in Desert area                      | Low End of Range | High End of Range |
|--|------------------|-------------------|
| Without upgrading Nipton – Lugo series cap at Lugo | 6058             | 7887              |
| With upgrading Nipton – Lugo series cap at Lugo    | 8177             | 9302              |

**Summary of Results – SDG&E Area Constraint**

Table 2 provides the approximate number of MWs that are deliverable if Q72 and its associated transmission upgrades are not in-service. Given that there is approximately 3,800 MW of generation in the ISO queue that significantly flow across the deliverability constraint described in detail later, approximately 2,400 MW to 3,200 MW can be accommodated as fully deliverable without the need for major upgrades similar to Q72 upgrades. As a comparison, the renewable portfolios under study in the 2011/2012 ISO transmission planning process have no more than approximately 1,000 MW to 2,000 MW of generation that significantly flow across the constraint.

Table 2. Summary of Results – SDG&amp;E Area

|                              | Low End of Range | High End of Range |
|------------------------------|------------------|-------------------|
| Deliverable MW in SDG&E area | 2400             | 3200              |

**Methodology and Assumptions**

The total generation in the generation interconnection queue up to Cluster 1 & 2 exceeds the deliverability provided by the transmission system. Some of the generation projects were removed to determine the deliverable amount of MW in the affected areas. The amount of deliverable MW depends on where the generator projects are removed. Therefore a range, instead of a fixed number, of the deliverable MW was identified in the analysis.

The analysis consisted of the following major steps for the Desert area study (similar assumptions are used for the SDG&E area study):

1. The Cluster 1 & 2 East of Lugo (EOL) base case (SDG&E area base case for the SDG&E area study) was modified to represent the transmission system described above.
2. Ran deliverability assessment and identified all the deliverability constraints.
3. Built minimum generation withdrawal scenario based on the deliverability study results.
4. Tested deliverability for the minimum generation withdrawal scenario. Step 3 and 4 were repeated until there were no more deliverability constraints identified.
5. Built maximum generation withdrawal scenario based on the deliverability study results.
6. Tested deliverability for the maximum generation withdrawal scenario. Step 5 and 6 were repeated until there were no more deliverability constraints identified.

Two scenarios associated with the series capacitor bank in the Lugo – Nipton 500kV line at Lugo Substation were studied.

- Scenario A: bypass the Lugo series capacitor in the Lugo – Nipton line
- Scenario B: upgrade the Lugo series capacitor in the Lugo – Nipton line

### Results – Desert Area

Table 3 and 4 list all the deliverability constraints identified in the Desert area study.

Table 3. Deliverability constraints – Scenario A

| Contingency   | Limiting Facility                      |
|---|--|
| Normal condition  | Lugo - Pisgah 230 kV No. 2             |
| Lugo - Jasper 230 kV No. 1 & Lugo - Pisgah 230 kV No. 2 | Pisgah - Cima - Eldorado 230 kV No. 1  |
|   | Pisgah - Eldorado 230 kV No. 2         |
|   | Kramer - Lockhart 230 kV No. 1         |
| Devers - Red Bluff 500 kV No. 1 & No. 2                 | N. Gila - Imperial Valley 500 kV No. 1 |
|   | Lugo - Victorville 500 kV No. 1        |
| Red Bluff - Colorado River 500 kV No. 1 & No. 2         | N. Gila - Imperial Valley 500 kV No. 1 |
|   | Lugo - Victorville 500 kV No. 1        |

Table 4. Deliverability constraints – Scenario B

| Contingency   | Limiting Facility                      |
|---|--|
| Normal condition  | Lugo - Pisgah 230 kV No. 2             |
| Lugo - Jasper 230 kV No. 1 & Lugo - Pisgah 230 kV No. 2 | Pisgah - Cima - Eldorado 230 kV No. 1  |
|   | Pisgah - Eldorado 230 kV No. 2         |
|   | Kramer - Lockhart 230 kV No. 1         |
| Eldorado – Mohave 500 kV No. 1                          | Lugo – Nipton 500 kV No. 1             |
| Palo Verde – Colorado River 500 kV No. 1                | Lugo – Nipton 500 kV No. 1             |
| Lugo – Victorville 500 kV No. 1                         | Eldorado – Nipton 500 kV No. 1         |
| Lugo - Nipton 500 kV No. 1                              | Lugo – Victorville 500 kV No. 1        |
| Devers - Red Bluff 500 kV No. 1 & No. 2                 | N. Gila - Imperial Valley 500 kV No. 1 |
| Red Bluff - Colorado River 500 kV No. 1 & No. 2         | N. Gila - Imperial Valley 500 kV No. 1 |
|   | Eldorado – Nipton 500kV No. 1          |

### Lowest level of generation withdrawal need under Scenario A

Approximately 3420 MW generation are needed to withdraw:

- 600 MW in San Diego area
- 1250 MW at Pisgah
- 1570 MW in Riverside East area

The withdrawal amount at Pisgah is driven by the normal overload on Lugo – Pisgah 230 kV No. 2 line. The withdrawal amount in Riverside East area is driven by the emergency overload on the series capacitor in the N. Gila – Imperial Valley 500 kV line

#### Highest level of generation withdrawal need under Scenario A

Approximately 5249 MW generation are needed to withdraw if the withdrawals are not at the most effective locations:

- 600 MW in San Diego area
- 1650 MW at Pisgah
- 1070 MW in Riverside East area
- 1929 MW in Mountain Pass area

The withdrawal amount at Pisgah is driven by the normal overload on Lugo – Pisgah 230 kV No. 2 line. The withdrawal amounts in Riverside East area and Mountain Pass area are driven by the emergency rating on the series capacitor in the N. Gila – Imperial Valley 500 kV line

#### Lowest level of generation withdrawal need under Scenario B

Approximately 2005 MW generation are needed to withdraw:

- 600 MW in San Diego area
- 1250 MW at Pisgah
- 155 MW in Mountain Pass

The withdrawal amount at Pisgah is driven by the normal rating on Lugo – Pisgah 230 kV No. 2 line. The withdrawal amount in Mountain Pass area is driven by the emergency rating on the Eldorado – Nipton 500kV line and Lugo – Nipton 500 kV line.

#### Highest level of generation withdrawal need under Scenario B

Approximately 3130 MW generation are needed to withdraw if the withdrawals are not at the most effective locations:

- 600 MW in San Diego area
- 1650 MW at Pisgah
- 310 MW in Mountain Pass
- 570 MW in Riverside East area

The withdrawal amount at Pisgah is driven by the normal rating on Lugo – Pisgah 230 kV No. 2 line. The withdrawal amounts in Mountain Pass area and Riverside East area are driven by the emergency rating on the Eldorado – Nipton 500kV line and Lugo – Nipton 500 kV line.

Table 5 lists the combined set of proposed generation projects for all the deliverability constraints and Table 6 and 7 list the shift factors on the constraints. The dispatch of proposed generation by CREZ in the lowest level of withdrawal cases are also shown in Table 6 and 7.

Table 5. Generation Projects Contributing to the Desert Area Deliverability Constraints

| Generation Projects Contributing to the SCE Area Deliverability Constraints |                          |      |                          |
|---|--------------------------|------|--------------------------|
| Project Q#  | POI                      | Pmax | CREZ                     |
| 17  | Colorado River 500kV     | 520  | Riverside East (500 kV)  |
| 32  | Boulevrd 138 kV          | 201  | San Diego South          |
| 58  | Control 115 kV           | 62   | Kramer                   |
| 68  | Pisgah 230kV             | 850  | Pisgah                   |
| 103   | Border 69 kV             | 27   | SDG&E Non-CREZ           |
| 124   | Imperial Valley 230 kV   | 600  | Imperial – SDG&E         |
| 126   | Nipton 230kV             | 500  | Mountain Pass            |
| 131   | Ivanpah 230kV            | 100  | Mountain Pass            |
| 135   | Jasper 230kV             | 60   | San Bernardino - Lucerne |
| 146   | Redbluff 230 kV          | 150  | Riverside East (500 kV)  |
| 147   | Redbluff 230 kV          | 400  | Riverside East (500 kV)  |
| 150   | Border 69 kV             | 47.4 | SDG&E Non-CREZ           |
| 156   | Jasper 230kV             | 201  | San Bernardino - Lucerne |
| 162   | Ivanpah 230kV            | 114  | Mountain Pass            |
| 163   | Ivanpah 230kV            | 300  | Mountain Pass            |
| 193   | Colorado River 230kV     | 500  | Riverside East (500 kV)  |
| 219   | Colorado River 500kV     | 50   | Riverside East (500 kV)  |
| 233   | Ivanpah 230kV            | 200  | Mountain Pass            |
| 240   | Pisgah 230kV             | 400  | Pisgah                   |
| 241   | Pisgah 230kV             | 400  | Pisgah                   |
| 294   | Colorado River 230kV     | 1000 | Riverside East (500 kV)  |
| 297   | Neenach 66 kV            | 66   | Tehachapi 230kV          |
| 365   | Redbluff 230 kV          | 500  | Riverside East (500 kV)  |
| 421   | Blythe 161 kV            | 49.5 | Riverside East (161 kV)  |
| 429   | Imperial Valley 230 kV   | 100  | Imperial - SDG&E         |
| 442   | Imperial Valley 230 kV   | 125  | Imperial - SDG&E         |
| 467   | Primm 230kV              | 230  | Mountain Pass            |
| 493   | IV - Central 500kV       | 299  | Imperial - SDG&E         |
| 502   | Primm 230kV              | 20   | Mountain Pass            |
| 503   | Eldorado 230kV           | 155  | Mountain Pass            |
| 510   | Imperial Valley 230 kV   | 200  | Imperial - SDG&E         |
| 512   | Neenach 66 kV            | 26   | Tehachapi 230kV          |
| 552   | Jasper 230kV             | 60   | San Bernardino - Lucerne |
| 561   | Imperial Valley 230 kV   | 200  | Imperial - SDG&E         |
| 565   | Miguel - Sycamore 230 kV | 100  | SDG&E Non-CREZ           |
| 574   | Otay Mesa 230 kV         | 308  | SDG&E Non-CREZ           |
| 576   | Colorado River 230kV     | 485  | Riverside East (500 kV)  |
| 588   | Redbluff 230 kV          | 200  | Riverside East (500 kV)  |

|          |                        |         |                  |
|----------|------------------------|---------|------------------|
| 590      | Imperial Valley 230 kV | 150     | Imperial - SDG&E |
| 593      | Mohave 500kV           | 310     | Mountain Pass    |
| 608      | Imperial Valley 230 kV | 250     | Imperial - SDG&E |
| 106A     | Boulevrd 138 kV        | 160     | San Diego South  |
| 159A     | ECO 230 kV             | 400     | San Diego South  |
| WDT190   | Vestal 66 kV           | 49.9    | SCE Non-CREZ     |
| WDT235   | Goleta 66 kV           | 49.9    | SCE Non-CREZ     |
| WDT315   | Casa Diablo 34 kV      | 40.7    | Kramer           |
| WDT425   | Vestal 66 kV           | 51      | SCE Non-CREZ     |
| WDT433   | Vestal 66 kV           | 40      | SCE Non-CREZ     |
| Total MW |                        | 11307.4 |                  |

Table 6: Shift factors by CREZ – Scenario A

| Shift Factors and Dispatch by CREZ (Nipton-Lugo series capacitors bypassed at Lugo) |       |                           |        |                                  |        |                                  |        |
|---|-------|---------------------------|--------|----------------------------------|--------|----------------------------------|--------|
| Limiting Facility   |       | Lugo - Pisgah 230kV No. 2 |        | N. Gila - IV 500kV               |        | Lugo - Victorville 500kV line    |        |
| Contingency   |       | Normal                    |        | Red Bluff - Devers No. 1 & No. 2 |        | Red Bluff - Devers No. 1 & No. 2 |        |
|   | PMAX  | Shift Factors             | PGEN   | Shift Factors                    | PGEN   | Shift Factors                    | PGEN   |
| Pisgah  | 1650  | 0.31                      | 340    | 0.06                             | 272    | <.05                             | 272    |
| San Bernardino - Lucerne  | 321   | 0.06                      | 192.4  | 0.06                             | 113.1  | <.05                             | 113.1  |
| Riverside East (500 kV)   | 3805  | <.05                      | 896.8  | 0.26                             | 609    | 0.19                             | 869.5  |
| Riverside East (161 kV)   | 49.5  | <.05                      | 0      | <.05                             | 0      | 0.10                             | 0      |
| Mountain Pass   | 1929  | <.05                      | 1131.7 | 0.08 ~ 0.11                      | 1131.7 | 0.08 ~ 0.24                      | 1131.7 |
| Imperial Valley - SDG&E   | 1924  | <.05                      | 0      | <.05                             | 0      | 0.10                             | 382.5  |
| San Diego South   | 761   | <.05                      | 96     | <.05                             | 96     | 0.09                             | 352    |
| SDG&E non-CREZ  | 482.4 | <.05                      | 0      | <.05                             | 0      | 0.05 ~ 0.06                      | 0      |
| SCE Non-CREZ  | 190.8 | <.05                      | 0      | <.05                             | 0      | 0.11 ~ 0.15                      | 0      |
| Kramer  | 102.7 | <.05                      | 42.2   | <.05                             | 42.2   | 0.09                             | 42.2   |
| Tehachapi 230kV   | 92    | <.05                      | 0      | <.05                             | 0      | 0.08                             | 0      |



Table 7: Shift factors by CREZ – Scenario B

| Shift Factors and Dispatch by CREZ (Nipton-Lugo series capacitors in-service at Lugo) |       |                           |        |                                     |        |                                       |        |                          |        |
|---|-------|---------------------------|--------|-------------------------------------|--------|---------------------------------------|--------|--------------------------|--------|
| Limiting Facility   |       | Lugo - Pisgah 230kV No. 2 |        | N. Gila - IV 500kV                  |        | Lugo - Nipton 500kV                   |        | Lugo - Victorville 500kV |        |
| Contingency   |       | Normal                    |        | Red Bluff - Devers No. 1<br>& No. 2 |        | Palo Verde - Colorado<br>River 500 kV |        | Lugo - Nipton 500kV      |        |
|   | PMAX  | Shift Factors             | PGEN   | Shift Factors                       | PGEN   | Shift Factors                         | PGEN   | Shift Factors            | PGEN   |
| Pisgah  | 1650  | 0.31                      | 340    | 0.06                                | 136    | 0.06                                  | 272    | <.05                     | 136    |
| San Bernardino - Lucerne  | 321   | 0.06                      | 192.4  | 0.06                                | 113.1  | 0.05                                  | 113.1  | <.05                     | 113.1  |
| Riverside East (500kV)  | 3805  | <.05                      | 620    | 0.26                                | 1945   | <.05                                  | 620    | <.05                     | 620    |
| Riverside East (161kV)  | 49.5  | <.05                      | 0      | <.05                                | 0      | 0.12                                  | 0      | 0.13                     | 0      |
| Mountain Pass   | 1929  | <.05                      | 1026.3 | 0.07 ~ 0.1                          | 1026.3 | 0.14 ~ 0.61                           | 1155.9 | 0.11 ~ 0.3               | 1155.9 |
| Imperial - SDG&E  | 1924  | <.05                      | 0      | <.05                                | 0      | 0.12                                  | 977.5  | 0.10                     | 510    |
| San Diego South   | 761   | <.05                      | 96     | <.05                                | 96     | 0.11                                  | 454.4  | 0.09                     | 352    |
| SDG&E Non-CREZ  | 482.4 | <.05                      | 0      | <.05                                | 0      | 0.05 ~ 0.08                           | 478    | 0.05 ~ 0.06              | 478    |
| SCE Non-CREZ  | 190.8 | <.05                      | 0      | <.05                                | 0      | <.05                                  | 0      | 0.11 ~ 0.15              | 0      |
| Kramer  | 102.7 | <.05                      | 42.2   | <.05                                | 42.2   | <.05                                  | 42.2   | 0.09                     | 42.2   |
| Tehachapi 230kV   | 92    | <.05                      | 0      | <.05                                | 0      | <.05                                  | 0      | 0.08                     | 0      |

## Results – SDG&E Area

Table 8 lists the deliverability constraints identified in the SDG&E area study.

Table 8. Deliverability constraints

| Contingency      | Limiting Facility                    |
|------------------|--------------------------------------|
| Normal condition | Path 43 (North of SONGS) path rating |

### Generation withdrawal need

Between 600 and 1400 MW of generation in the SDG&E area are required to withdraw. The first number is based on the assumption that Encina units 4, 5 and GT (644 MW total) and Cabrillo II generation (188 MW) will not choose to be repowered. If these units choose to be repowered, their deliverability may need to be preserved, and more generation may be needed to withdraw from the Queue.

Table 9 lists the set of proposed generation projects for the deliverability constraint and Table 10 lists the shift factors on the constraint. The proposed generation dispatch by CREZ in the lower level of withdrawal case is also shown in Table 10.

Table 9. Generation Projects Contributing to the North of SONGS Deliverability Constraint

| Generation Projects Contributing to the North of SONGS Deliverability Constraint |  |       |                  |
|--|--|-------|------------------|
| Project Q#   | POI  | Pmax  | CREZ             |
| 13   | Olivehain-Bernardo-Rancho Santa Fe 69kV line       | 40    | Non-CREZ         |
| 32   | Boulevard Station 138kV Bus                        | 201   | San Diego South  |
| 103  | Border Sub 69 kV Bus                               | 27    | Non-CREZ         |
| 124  | Imperial Valley Substation 230kV bus               | 600   | Imperial – SDG&E |
| 137  | Encina Substation 230kV bus                        | 260   | Non-CREZ         |
| 150  | Border Substation                                  | 47.4  | Non-CREZ         |
| 189  | Encina 138kV Substation                            | 260   | Non-CREZ         |
| 337  | Borrego Substation 69kV                            | 25.75 | Non-CREZ         |
| 429  | Imperial Valley Substation                         | 100   | Imperial - SDG&E |
| 442  | Imperial Valley 230kV                              | 125   | Imperial - SDG&E |
| 493  | Sunrise Powerlink 500kV line                       | 299   | Imperial - SDG&E |
| 510  | Imperial Valley Substation 230kV bus               | 200   | Imperial - SDG&E |
| 561  | Imperial Valley Sub 230kV bus                      | 200   | Imperial - SDG&E |
| 565  | Miguel-Mission 230kV                               | 100   | Non-CREZ         |
| 574  | Otay Mesa Sub 230kV Bus                            | 308   | Non-CREZ         |
| 590  | Imperial Valley Sub 230kV bus                      | 150   | Imperial - SDG&E |
| 608  | Imperial Valley Sub 230kV bus                      | 250   | Imperial - SDG&E |
| 106A   | Boulevard Sub 138kV Bus                            | 160   | San Diego South  |
| 159A   | Imperial Valley-Miguel new 230/500kV Sub 230kV bus | 400   | San Diego South  |
| Total MW   |  | 3753  |                  |

Table 10: Shift Factors by CREZ

| Shift Factors and Dispatch by CREZ |         |                          |        |
|------------------------------------|---------|--------------------------|--------|
| Limiting Facility                  |         | Path 43 (North of SONGS) |        |
| Contingency                        |         | Normal                   |        |
|                                    | PMAX    | Shift Factors            | PGEN   |
| Imperial - SDG&E                   | 1924    | 0.26                     | 868.6  |
| San Diego South                    | 761     | 0.33                     | 275.5  |
| Non-CREZ                           | 1068.15 | 0.59 - 0.42              | 1037.2 |

The diagram illustrates the Lugo-Pisgah transmission line system. Key components and data points include:

- Buses:** LUGO, JASPER, COLWATER, PISGAH, CIMA, and ELDORDO.
- Transmission Lines:**
  - Top Line:** Connects LUGO to PISGAH. It includes a tap at JASPER. Voltage levels are 225.5 kV at LUGO, 229.5 kV at JASPER, and 230.0 kV at COLWATER. Power flows are indicated by arrows with values like 611/27, 617/81, 81/41, 83/32, 2/6, 238.9, 1.039, 235.1, and 1.022.
  - Bottom Line:** Connects LUGO to ELDORDO. It includes a tap at PISGAH. Voltage levels are 225.5 kV at LUGO, 229.5 kV at JASPER, and 230.0 kV at COLWATER. Power flows are indicated by arrows with values like 242/10, 254/34, 5/5, 5/12, 11/12, 11/25, 238.0, 1.035, and 235.1.
- Other Labels:** COLWATER, JASPER, PISGAH, CIMA, ELDORDO, LUGO.

12




Figure 2: Lowest level of generation withdrawal under Scenario A: N. Gila – Imperial Valley 500 kV is a limiting facility with the outage of both Devers-Red Bluff 500 kV lines.




Figure 3: Lowest level of generation withdrawal under Scenario A: Lugo – Victorville 500 kV is a limiting facility with the outage of both Devers-Red Bluff 500 kV lines.




Figure 4: Lowest level of generation withdrawal under Scenario B: N. Gila – Imperail Valley 500 kV is a limiting facility with the outage of both Devers-Red Bluff 500 kV lines.




Figure 5: Lowest level of generation withdrawal under Scenario B: Lugo – Victorville 500 kV is a limiting facility with the outage of Lugo - Nipton 500 kV line.






Figure 6: Lowest level of generation withdrawal under Scenario B: Lugo – Nipton 500 kV is a limiting facility with the outage of Palo Verde-Colorado River 500 kV line.




Figure 7. Lower level of generation withdrawal: NOS is the limiting constraint with all lines in service.