



Dave Kelley
Director,
Application Eng.
Liebert Precision
Cooling

**Emerson Network
Power**
1050 Dearborn Dr.
Columbus, OH 43229

T (614) 841-5708
F (614) 841-5869
C (614) 203-3893
E dave.kelley@emerson.com

February 3, 2014

California Energy Commission
Docket No. 13-AAER-1
Docket Unit
1516 Ninth Street, Mail Station 4
Sacramento, CA 95814-5504

To Whom it may concern:

We are a manufacturer of computer room / data center cooling equipment and have a few comments relative to the proposed changes in Title 20.

Section 1602 Definitions

Under Computer Room Air Conditioner the test method should be AHRI 1360

Section 1604 Table C-1

Under Computer Room Air Conditioners, the test method for air-cooled, glycol-cooled, water-cooled should be AHRI 1360.

Section 1605.1 Table C-6

A column needs to be added for horizontal-flow units with their own SCOP values.

Section 1606 Table X Data Submittal Requirements

Under Computer Room Air Conditioners lines need to be added for Horizontal-flow Unit Power Input (watts) and Horizontal-flow Unit SCOP

If you need any clarifications, please contact me.

Sincerely,

A handwritten signature in cursive script that reads "Dave Kelley".

Dave Kelley
Director, Application Engineering – Liebert Precision Cooling
Emerson Network Power