



9 October 2014

Matt Sigler  
Technical Director  
Plumbing Manufacturers International

California Energy Commission

**DOCKETED**

**14-AAER-01**

**TN 73953**

**NOV 04 2014**

In response to your request for more information about the potential effects from California's proposed water flowrate changes in faucets, I'd like to offer the following thoughts. It is well understood that household plumbing fixtures, including faucets accumulate attached bacterial populations – biofilms. Previous experimentation in plumbing-related systems such as pipes has shown that the flow regime within a pipe can influence the biofilm that grows on the pipe walls, particularly with regard to biofilm thickness, density and detachment. Flowrate influences shear stress on the biofilm, and biofilm grown under lower shear conditions tends to be thicker, less dense, and more easily detached than biofilm grown under high shear. The flow path within a faucet is considerably more complex than a simple pipe, but biofilm accumulation within the faucet would be expected to follow this pattern. It is also well understood that biofilms can potentially harbor frank or opportunistic pathogenic microorganisms, such as Legionella. While specific experimental results are not available to correlate pathogen survival within biofilms to biofilm thickness within faucets, it stands to reason that thicker biofilms have more capacity to harbor such organisms than do thinner biofilms.

Sincerely;

A handwritten signature in blue ink, appearing to read 'Paul Sturman'.

Paul Sturman, PhD, PE  
Industrial Coordinator  
Center for Biofilm Engineering

**Center for Biofilm  
Engineering**

366 EPS Building  
P.O. Box 173980  
Bozeman, MT 59717-3980  
[www.biofilm.montana.edu](http://www.biofilm.montana.edu)

Tel 406-994-4770  
Fax 406-994-6098  
[cbeinfo@biofilm.montana.edu](mailto:cbeinfo@biofilm.montana.edu)

**Mountains & Minds**