

**From:** Hone, Matt [<mailto:Matt.Hone@ladwp.com>]

**Sent:** Friday, March 06, 2015 3:57 PM

**To:** Energy - Docket Optical System

**Cc:** Laufenberg, Clare@Energy; Billie Blanchard; Carrie Downey; Kondoleon, Don@Energy; Dennis Peters; Sandoval, Juan C; Jan Strack; Patricia Arons; Ronnie Lau; Kiernan, Scott E Civ USAF AFMC AFTC/XPT; [Shashi.Pandey@sce.com](mailto:Shashi.Pandey@sce.com); [Kevin.Richardson@sce.com](mailto:Kevin.Richardson@sce.com); Susan Lee; Suzanne Phinney; Emily Capello; Bhuiyan, Mukhlesur; Obiang, Denis; Rahman, Atique

**Subject:** FW: Comments on Draft DRECP EIR/ EIS Appendix K

LADWP formally submitted comments on draft DRECP EIR/EIS Appendix K on February 18, 2015. Please see the email below. LADWP participated in the TTG group and would like to make sure comments incorporated and updated.

Thanks,

Matt Hone

**From:** Hone, Matt

**Sent:** Wednesday, February 18, 2015 7:03 PM

**To:** 'Laufenberg, Clare@Energy'

**Cc:** 'Billie Blanchard'; 'Carrie Downey'; 'Kondoleon, Don@Energy'; 'Dennis Peters'; 'Sandoval, Juan C'; 'Jan Strack'; 'Patricia Arons'; 'Ronnie Lau'; 'Kiernan, Scott E Civ USAF AFMC AFTC/XPT'; 'Shashi.Pandey@sce.com'; 'Kevin.Richardson@sce.com'; 'Susan Lee'; 'Suzanne Phinney'; 'Emily Capello'; Bhuiyan, Mukhlesur; Obiang, Denis; Rahman, Atique

**Subject:** Comments on DRECP Appendix K

Hi Clare,

Thank you for give me an opportunity to review the latest TTG report for DRECP. Please see below for comments from LADWP.

### **Missing Delivery Lines**

The 500kV line from Station 7 to Station E and 320kV DC line from Station 7 to Station 8 are delivery lines and are not listed in several alternatives as well as on maps. Please update them.

### **Alternative 1**

The following two delivery lines are not listed on page 29.

- Station 7 to Station E 500kV Line
- Station 7 to Station 8 320kV DC Line

The delivery line Station 7 to Station 8 is not shown on the map.

### **Alternative 2**

The delivery line Station 7 to Station 8 is not shown on the map.

### **Alternative 3**

The following two delivery lines are not listed on page 30.

- Station 7 to Station E 500kV Line
- Station 7 to Station 8 320kV DC Line

The delivery line Station 7 to Station 8 is not shown on the map.

### **Alternative 4**

The following two delivery lines are not listed on page 31.

- Station 7 to Station E 500kV Line
- Station 7 to Station 8 320kV DC Line

The delivery line Station 7 to Station 8 is not shown on the map.

### **Generation Distribution and Transmission Specification**

In August 2013, TTG group estimated acreages affected within DRECP. Table 4-1 on Page 23 of Appendix K (see below) shows increases and decreases of MW distribution from 2012 to the current. The changes in the MW will require different size of transmission. For example in Alternative 1 at Owens River Valley generation increased from 216MW to 820MW. The map is still showing 230kV single circuit which will not be sufficient to carry the increased amount. In August 2013, TTG group did not look into the sizing of transmission lines unlike previous studies. Those maps will be misrepresenting to readers.

