

Paul, Patricia@Energy

From: nathan@advancedenergysvcs.com
Sent: Tuesday, June 09, 2015 3:57 PM
To: Energy - Docket Optical System
Subject: 15-BSTD-01 and indicate Adoption of 15-Day Language for the 2016 Energy Efficiency Building Standards

California Energy Commission

DOCKETED

15-BSTD-01

TN # 75924

JUN 09 2015

To Whom It May Concern:

As I understand, there are some proposed changes to Part 6 of Title 24 2016 as follows:

- A Per retrofit savings of 30% at the fixture level relieves the contractor from Lighting Power Allowance calculations (40 % savings required for exterior)
- Multi-Level (dimming) controls, and daylighting controls are no longer required for interior retrofits
- The 40 unit threshold for requiring permitting has been upped to 70

These proposed changes would be very beneficial to the retrofiting industry in which Advanced Energy Services, Inc. (AES) has been working for the past eight years.

As the Operations Manager of AES, I fully support these proposed changes.

Regards,
Advanced Energy Services, Inc.

Nathan Schetselaar
Operations Manager
Tel: 559-324-8280
Fax: 559-402-1368
nathan@advancedenergysvcs.com