
RNM Engineering, Inc.

90 Baron Canyon Ranch Road
San Luis Obispo, CA 93401
www.RNM-Eng.com

Phone: 415-307-5106
Fax: 805-781-0816

RickMiller@RNM-Eng.com

August 4, 2015

To: docket@energy.ca.gov

California Energy Commission

DOCKETED

15-BSTD-01

TN # 76091

AUG 04 2015

RE: Docket Number 15-BSTD-01 – Adoption of 15-Day Language for 2016 BEES

Section 141.0, paragraph (b) 2 K iv is currently worded: “for each enclosed space where wiring alterations include 20 or more luminaires that are located within the primary sidelit daylight zone **and** the skylit daylight zone, meet the requirements of 130.1(d).”

Recommend changing the wording to: “for each enclosed space where wiring alterations include 20 or more luminaires that are located within the primary sidelit daylight zone **plus the luminaires that are located within** the skylit daylight zone, meet the requirements of 130.1(d).”, because there are very few luminaires that are within both a sidelit zone and a skylit zone.